McGuireWoods LLP 434 Fayetteville Street Suite 2600 PO Box 27507 (27611) Raleigh, NC 27601 Phone: 919.755.6600 Fax: 919.755.6699 www.mcguirewoods.com

E. Brett Breitschwerdt
Direct: 919.755.6563
MCGUIREWOODS

May 13, 2015

VIA ELECTRONIC FILING

Mrs. Gail Mount, Chief Clerk North Carolina Utilities Commission 430 North Salisbury Street Raleigh, North Carolina 27603

> Re: Docket No. E-22, Sub 464

Dear Mrs. Mount:

In accordance with Ordering Paragraph Seven of the North Carolina Utilities Commission's May 7, 2015, Order Approving Revised Cost Recovery and Incentive Mechanism and Granting Waiver, Virginia Electric and Power Company, d/b/a Dominion North Carolina Power hereby files its recently completed, system-wide Energy Efficiency Potential Study.

Please do not hesitate to contact me if you have any questions. Thank you for your assistance in this matter.

Very truly yours,

s/ E. Brett Breitschwerdt

Enclosures

DNV·GL

Dominion Energy Efficiency Potential Study

Dominion Virginia Power

Prepared by KEMA, Inc. January 9, 2015




Table of Contents

1. E	EXECUTIVE SUMMARY	1
1.1 S	cope and Approach	1
1.2 E	nergy Efficiency Potential	1
1.3 R	tesults	2
1.3.1	Aggregate Base Energy Efficiency Potential Results	4
1.3.2	Achievable Savings Potentials over Time	9
1.3.3	Base Energy Efficiency Results by Sector	10
2. I	NTRODUCTION	11
2.1 C	Overview	11
	tudy Approach	
2.2.1	Energy Efficiency Potential Approach	11
2.3 C	Organization of the Report	12
3. Г	DATA COLLECTION AND DEVELOPMENT	12
3.1 D	Oominion-Specific Data Collection Efforts	
3.1.1	Residential and Commercial Saturation Studies	
3.1.2	Residential Sample Selection	
3.1.3	Commercial Sample Selection	
3.1.4	Data Collection	
3.1.5 3.1.6	Response RatesResidential Conditional Demand Analysis	
3.2 A	Additional Data Sources	17
3.2.1	Measure Data	
3.2.2	Economic Data	17
3.2.3	Building Data	18
3.2.4	Program Budgets	18
4. E	ENERGY EFFICIENCY METHODS	19
4.1 E	nergy Efficiency Potential Methods	
4.1.1	Characterizing the Energy Efficiency Resource	
4.1.2	Defining Energy Efficiency Potential	
4.1.3	Summary of Analytical Steps Used for the Energy Efficiency Potential	22
5. E	ENERGY EFFICIENCY RESULTS	24

5.1 En	ergy Efficiency Baseline Analysis	24
5.2 Su	mmary of Energy Use by Sector	25
5.2.1	Residential Baseline	
5.2.2	Non-Residential Baseline	
5.3 Te	chnical and Economic Potential Results	74
5.3.1	Avoided Cost Scenario Results	
5.3.2	Electric Energy Efficiency Potential Results	76
5.3.3	Overall Technical and Economic Potential	76
5.3.4	Base Case Technical and Economic Potential Detail	77
5.3.5	Potentials by Sector	77
5.3.6	Potential within Dominion's Virginia and North Carolina Service Territories	83
5.3.7	Potentials by Building Type	
5.3.8	Potentials by End Use	
5.3.9	Avoided Cost Scenarios	
5.3.10	Energy Efficiency Supply Curves	
5.3.11	Top 20 Saving Measures	
5.4 Ac	hievable (Program) Potential	
5.4.1	Achievable (Program) Potential – Overall Results	111
5/12	Breakdown of Achievable Potential by Sector	11/

Tables

Table 1-1: Summary of Cumulative Energy Efficiency Savings	2
Table 1-2: Comparison of Energy Savings Potential as a Percent of Base Consumption	6
Table 1-3: Summary of Achievable Potential Results—2014-2023*	
Table 3-1: Residential Saturation Survey Response Rates	
Table 3-2: Commercial Saturation Survey Response Rates	
Table 3-3: DSM II EM&V Summary Indicator Tables	
Table 4-1: Conceptual Framework for Estimates of Fossil Fuel Resources	20
Table 5-1: Summary of Dominion MWh and Customers by Sector and State	
Table 5-2: Number of Residential Customers by Building Type	
Table 5-3: Residential End-Use Saturations by Base Measure	
Table 5-4: Lamps per Home by Type and Usage	
Table 5-5: Residential End-Use Energy Intensities (kWh/household with end-use)	
Table 5-6: Water-Heating-Related Outputs of the CDA Model	
Table 5-7: Water Heating Household Energy Use (kWh) by Component	
Table 5-8: Residential Energy Use by Building Type and End-Use	
Table 5-9: Summary of Residential Electric Peak Demand by Segment and End Use – MW	32
Table 5-10: Comparison of the Residential Baseline Results to RECS	
Table 5-11: Non-Residential Sector Equipment Saturations—Virginia	
Table 5-12: Non-Residential Sector Equipment Saturations—North Carolina	
Table 5-13: Non-Residential Sector Equipment Saturations—Opt-Out/Exempt	
Table 5-14: Non-Residential End-Use Energy Intensities (kWh per End-Use Square Foot)—Virginia	
Table 5-15: Non-Residential End-Use Energy Intensities (kWh per End-Use Square Foot)—North Carolina	
Table 5-16: Non-Residential End-Use Energy Intensities (kWh per End-Use Square Foot)—Opt-Out/Exempton (kWh per End-Use	pt
T. I. F. 77 N. D. 1. 1. 1. C. 1. El. (1000 C) 1. E. 1. (1001 C) 1. E. (1001	
Table 5-17: Non-Residential Sector Floor space (1000 sf) and Energy Use (MWh) by End-Use and Building	
TypeVirginia	56
Table 5-18: Non-Residential Sector Floor space (1000 sf) and Energy Use (MWh) by End-Use and Building	
Type—North Carolina	59
Table 5-19: Non-Residential Sector Floor space (1000 sf) and Energy Use (MWh) by End-Use and Building	
Type—Opt-Out/Exempt	61
Table 5-20: Non-Residential Peak Demand (MW) by End-Use and Building TypeVirginia	
Table 5-21: Non-Residential Peak Demand (MW) by End-Use and Building Type—North Carolina	
Table 5-22: Non-Residential Peak Demand (MW) by End-Use and Building Type—Opt-Out/Exempt	
Table 5-23: Avoided Cost Scenario Summary	
Table 5-24: Estimated Electric Technical and Economic Potential, 2023	
Table 5-25: Technical and Economic Potential (2023) Energy Savings by Sector	
Table 5-26: Technical and Economic Potential (2023) Demand Savings by Sector	
Table 5-27: Energy and Demand Savings Potential by Residential Building Type	
Table 5-28: Energy and Demand Savings Potential by Non-Residential Building Type	
Table 5-29: Energy and Demand Savings Potential by Residential End Use	
Table 5-30: Energy and Demand Savings Potential by Non-Residential End Use	97
Table 5-31: Summary of Potential at Three Avoided Cost Scenarios	99
Table 5-32: Top 20 Measures Contributing to Residential Technical Energy Savings Potential	101
Table 5-33: Top 20 Measures Contributing to Residential Economic Energy Savings Potential	102
Table 5-34: Top 20 Measures Contributing to Residential Technical Demand Savings Potential	
Table 5-35: Top 20 Measures Contributing to Residential Economic Demand Savings Potential	
Table 5-36: Top 20 Measures Contributing to Non-Residential Technical Energy Savings Potential	105
Table 5-37: Top 20 Measures Contributing to Non-Residential Economic Energy Savings Potential	
Table 5-38: Top 20 Measures Contributing to Non-Residential Technical Demand Savings Potential	
Table 5-39: Top 20 Measures Contributing to Non-Residential Economic Demand Savings Potential	
Table 5-40: Ten Year Cumulative Potential – GWh	
Table 5-41: Summary of Achievable Potential Results—2014-2023*	
Table 5-42: Residential Measure-Level Savings: GWh	
Table 5-43: Non-Residential Measure-Level Savings: GWh	
. 45. C	

Figures

Figure 1-1: Estimated Electric Energy Efficiency Savings Potential, 2014-2023	4
Figure 1-2: Estimated Peak Demand Savings Potential, 2014-2023	
Figure 1-3: Benefits and Costs of Energy Efficiency Savings—2014-2023*	
Figure 1-4: Achievable Electric Energy Savings: All Sectors	
Figure 1-5: Net Achievable Energy Savings	10
Figure 1-6: Net Achievable Peak-Demand Savings (2023) by Sector—MW	10
Figure 3-1: Summary Flow Chart for the DSM Potential Study Process	13
Figure 4-1: Conceptual Relationship among Energy Efficiency Potential Definitions	21
Figure 4-2: Conceptual Overview of Study Process	22
Figure 5-1: Breakout of Dominion Energy Use by Sector	25
Figure 5-2: Residential Energy Use by Building Type	34
Figure 5-3: Residential Energy Use by End-Use	35
Figure 5-4: Non-Residential Energy Use by Building Type	63
Figure 5-5: Non-Residential Energy Use by End-Use	64
Figure 5-6: Comparison of Non-Residential Baseline Energy Use by Building Type to CBECS	72
Figure 5-7: Comparison of Non-Residential Baseline Energy Use by End-Use to CBECS	73
Figure 5-8: Estimated Electric Technical and Economic Potential, 2023	76
Figure 5-9: Technical Energy Savings by Sector	
Figure 5-10: Technical Demand Savings by Sector	78
Figure 5-11: Economic Energy Savings Potential by Sector	79
Figure 5-12: Economic Demand Savings Potential by Sector	79
Figure 5-13: Technical and Economic Energy Savings by Sector (GWH)	80
Figure 5-14: Technical and Economic Peak Demand Savings by Sector (MW)	
Figure 5-15: Technical and Economic Energy Savings by State	
Figure 5-16: Technical Energy Savings Potential by State and Sector	
Figure 5-17: Economic Energy Savings Potential by State and Sector	
Figure 5-18: Technical and Economic Demand Savings by State	
Figure 5-19: Technical Demand Savings Potential by State and Sector	86
Figure 5-20: Economic Demand Savings Potential by State and Sector	
Figure 5-21: Energy Savings Potential by Residential Building Type	
Figure 5-22: Demand Savings Potential by Residential Building Type	88
Figure 5-23: Energy Savings Potential by Non-Residential Building Type	
Figure 5-24: Demand Savings Potential by Non-Residential Building Type	
Figure 5-25: Energy Savings Potential by Residential End Use	
Figure 5-26: Demand Savings Potential by Residential End Use	
Figure 5-27: Energy Savings Potential by Non-Residential End Use	
Figure 5-28: Demand Savings Potential by Non-Residential End Use	
Figure 5-29: Estimated Technical and Economic Energy Savings/Demand Potential for Alternative Avoide	ed
Cost Scenarios, 2023	
Figure 5-30: Energy Savings Potential as a Percent of Total Sales	
Figure 5-31: Achievable Electric Energy Savings: All Evaluated Sectors	
Figure 5-32: Benefits and Costs of Energy Efficiency Savings—2014-2023*	
Figure 5-33: Net Achievable Energy Savings	
Figure 5-34: Net Achievable Peak-Demand Savings (2023) by Sector—MW	. 114
Figure 5-35: Net Achievable Energy Savings	
Figure 5-36: Net Achievable Peak-Demand Savings (2023) by Sector in Virginia—MW	. 115
Figure 5-37: Net Achievable Energy Savings	
Figure 5-38: Net Achievable Peak-Demand Savings (2023) by Sector in North Carolina—MW	. 116
Figure 5-39: Achievable Energy Savings: Residential Sector	
Figure 5-40: Achievable Energy Savings: Non-Residential Sector	
5 5,	

Glossary

Achievable potential: The amount of savings that would occur in response to specific program funding and measure incentive levels. Savings associated with program potential are savings that are projected beyond those that would occur naturally in the absence of any market intervention.

Applicability factor: The percentage of the building stock that has a particular type of equipment or for which an efficiency measure applies. For example, the applicability factor for a tankless electric water heater (compared to a base standard electric water heater) is the percentage of homes with electric water heaters. The applicability factor for high-efficiency clothes washers as an electric water heating measure is the percentage of homes with electric water heating that also have a clothes washer. For base measures, this is sometimes referred to as the equipment saturation.

Business-as-usual (BAU): Represents a continuation of current activities or trends. For utility programs, it denotes a scenario in which program marketing and administrative budgets are kept constant in real terms, and incentive levels are kept constant as a percentage of incremental costs.

Baseline analysis: Characterizes how energy consumption breaks down by sector, building type, and end use.

Base measure: The equipment against which an efficiency measure is compared.

C&I: commercial and industrial.

CBECS: EIA Commercial Buildings Energy Consumption Survey

CFL: compact fluorescent lamp.

CDA: Conditional Demand Analysis.

Coincidence factor: Utility coincidence factors are the ratio of actual demand at utility peak to the average demand, as calculated from the load shape. These factors vary by market segment or building type, end use, and by time-of-use period.

Cumulative annual: Savings occurring in a particular year that are due to cumulative program activities over time. For example, if a program installs one high-efficiency widget in year 1 of the program, two in year 2, and five in year 3, the cumulative annual savings in year three would be the savings accruing on all eight surviving units in place in year 3, regardless of what year they were installed. Cumulative annual savings does account for equipment retirement. In the example above, widgets are assumed to have an effective useful life of more than three years. If the equipment in the above example were doohickeys, which only have a two-year effective useful life, the year 1 doohickey would have retired at the end of year 2, so only the units sold in years 2 and 3 would contribute to year 3 cumulative annual savings.

Demand-side management (DSM): An electric system must balance the supply of electricity with the demand for electricity. Demand-side management (DSM) programs focus on managing the demand side of this balance through energy-efficiency and load management.

DOE: Department of Energy.

Economic potential: The technical potential of those energy conservation measures that are cost effective when compared to supply-side alternatives.

Effective useful life (EUL): A measure of the typical lifetime of an efficiency measure. Technically, it is the age at which half of the units have failed and half survive. In DNV GL's ASSYST™ model, all measures are assumed to remain in place until the end of their effective useful lives and then retire.

End-use energy intensity (EUI): Energy use per unit of building stock having a specific end use. For example, the EUI for commercial electric heating is the amount of electricity used for heating divided by the number of square feet of floor space that are electrically heated. EUI differs from EI in that it accounts for the equipment type's saturation. If the saturation of the equipment type is low, the EUI will be much higher than the EUI.

Energy intensity (EI): Energy use per unit of building stock. For example, the EI for commercial electric heating is the amount of electricity used for heating divided by the total square feet. EI differs from EUI in that it does not account for the saturation of the equipment. If the saturation for the equipment type is low, EI will be much lower than the EUI.

EUI adjustment factor: Because equipment efficiencies can change over time independent of program activities, due to either naturally occurring technological changes or external intervention, such as appliance standards, the efficiency of new equipment may differ from the typical efficiency of the equipment stock. The EUI adjustment factor is the ratio of new standard efficiency equipment's energy use to the average energy use of units in the equipment stock.

Feasibility factor: The fraction of the applicable floor space, or households, that is technically feasible to convert to a DSM technology, from an engineering perspective.

Free rider: A program participant who would have invested in an energy efficiency measure even without the intervention of the program. Free riders add to program costs but do not contribute to net energy savings.

Free-rider energy savings: The subset of naturally occurring energy savings for which the utility pays incentives or provides other program benefits. These savings are included in gross program savings but not in net program savings.

Gross program savings: The total savings for all measures installed under the program, including those that would have been installed even without program intervention (free riders). Gross program savings equals net program savings minus free ridership.

HP: horsepower. A metric for the power of a motor.

HVAC: heating, ventilation and air conditioning. These space-conditioning measures are often discussed as a group and are referred to by the abbreviation HVAC, usually pronounced H-vac.

Incomplete factor: The fraction of the applicable floor space, or households, that has not yet been converted to the particular energy-efficiency technology.

Incremental cost: The additional cost required to purchase an efficiency measure compared to base equipment.

kW: kilowatts, 1,000 watts. A measure of electric power or electricity demand.

kWh: kilowatt-hour. A measure of electrical energy.

LED: light-emitting diode. LEDs are semiconductor light sources. They have been in use for decades as indicator lights; they are increasingly being used for general-purpose lighting. They are highly efficient compared to incandescent lamps.

Line losses: When electricity is transmitted over the transmission and distribution system, some of the electricity is dissipated as heat due to resistance in the transmission lines or inefficiencies in transformers in the distribution system. As a result, the amount of electricity delivered to consumers is less than the amount produced at the generator. These are referred to as line losses or transmission and distribution losses.

MW: megawatt, one million watts. A measure of electric power or electricity demand.

MWh: megawatt-hour, equal to 1,000 kWh. A measure of electrical energy.

NAICS: The North American Industry Classification System is the standard used by Federal statistical agencies in classifying business establishments for the purpose of collecting, analyzing, and publishing statistical data related to the U.S. business economy.

Naturally occurring energy savings: The amount of savings estimated to occur as a result of normal market forces, that is, in the absence of any utility or governmental intervention.

Net program savings: Program savings above and beyond naturally occurring levels. Net savings exclude free-rider energy savings.

Net-to-gross: The ratio of net program savings to gross program savings.

Program potential: This term is used interchangeably with achievable potential.

RASS: Residential Appliance and Saturation Survey.

RECS: EIA Residential Energy Consumption Survey.

Replace on burnout (ROB): A measure that is installed when the previous equipment reaches the end of its useful life. ROB measures penetrate the market gradually as the existing stock of equipment turns over due to equipment age and eventual failure.

Retrofit: A measure that is installed to achieve energy savings independent of the condition of the existing equipment. This includes measures that affect the energy use of other equipment, such as insulation to reduce heating costs. It also includes replacing equipment with higher efficiency equipment before the end of existing equipment's useful life, for example replacing T12 fluorescent lighting in an office with higher efficiency T8s. Retrofits can be done at any time and therefore have the potential to penetrate the market more quickly than ROB measures.

Technical potential: The savings that would result from complete penetration of all analyzed measures in applications where they were deemed technically feasible, from an engineering perspective.

Technology saturation: A factor that relates the cost units used in the model for a measure to its savings units. For example, the cost of a chiller may be expressed in dollars per ton, though the savings are in kWh per square foot. The technology saturation then represents the number of tons of cooling per square foot.

Time-of-use (TOU) period: The Assyst model can analyze energy use by up to six time-of-use periods. These periods are used to characterize the relationship between energy and peak demand, which varies over both season and time of day, and to capture differences in avoided costs and rates over different time periods. TOU periods usually capture differences between summer/winter and peak/off-peak but can also capture shoulder season, mid-peak, or super peak demand, depending on the needs of a utility.

Total resource cost test (TRC): A benefit-cost test that compares the value of avoided energy production and power plant construction to the costs of energy efficiency measures and the program activities necessary to deliver them. The values of both energy savings and peak-demand reductions are incorporated in the TRC test.

UEC: unit energy consumption.

1. EXECUTIVE SUMMARY

Dominion Virginia Power (Dominion) engaged DNV GL to assess the potential for electric energy (kWh) and demand (kW) savings from company-sponsored demand side management (DSM) programs over a ten-year horizon. The assessment produced:

- Estimates of the magnitude of potential savings on an annual basis under two program design scenarios
- Estimates of the costs associated with achieving those savings
- Calculation of the cost-effectiveness of the programs based on the estimates above.

DNV GL used its proprietary model, DSM ASSYST™, to produce these outputs.

DNV GL assumed an extensive data collection effort prior to this study to support the development of inputs required for the energy efficiency modeling effort. This included mail surveys of residential and commercial customers; a residential conditional demand analysis; and review, interpretation, and analysis of data provided to DNV GL by Dominion staff. The result of these efforts was a set of detailed and comprehensive model inputs that were specific to Dominion's service territory.

1.1 **Scope and Approach**

This section discusses the scope and approach of the energy efficiency modeling efforts.

1.2 **Energy Efficiency Potential**

This study estimated three basic types of energy efficiency potential:

- Technical potential: The complete penetration of all measures analyzed in applications where they were deemed technically feasible from an engineering perspective.
- Economic potential: The technical potential of those energy efficiency measures that are cost-effective when compared to supply-side alternatives.
- Achievable program potential: The amount of savings that would occur in response to specific program funding, marketing, and measure incentive levels. In this study we looked at the potential available under two funding scenarios: 50 percent incentives and 75 percent incentives.¹

DSM ASSYST™ develops an estimate of naturally occurring savings, i.e., those savings that are projected to result from normal market forces in the absence of any intervention by utility sponsors. These savings are not included in the estimate of achievable program potential.

The method used for estimating potential is a "bottom-up" approach, in which energy efficiency costs and savings are assessed at the customer segment and energy efficiency measure levels. For cost-effective measures (based on the total resource cost, or TRC, test), program savings potential was estimated as a function of measure economics, rebate levels, and program marketing and education efforts. The modeling approach was implemented using DNV GL's DSM ASSYST™ model. This model

 $^{^{}m 1}$ These scenarios reflect the percentage of incremental measure cost that is assumed to be paid in customer incentives.

allows for efficient integration of large quantities of measure, building, and economic data to determine energy efficiency potential.

For this study, DNV GL estimated the results of program efforts under two incentive scenarios. One scenario assumed that 50 percent of incremental measure costs are paid out by Dominion in customer incentives. The second scenario allowed for incentives covering 75 percent of incremental measure costs. Program marketing costs were scaled upward across scenarios to reflect increasing program effort, and program administration costs were adjusted across scenarios proportional to achievable program energy savings. These scenarios are referenced, respectively, as the "50 percent scenario" and "75 percent scenario." Program energy and peak-demand savings, as well as program cost effectiveness, were assessed under both funding scenarios.

The study did not address incremental improvements in energy efficiency due to the ongoing evolution and gradual improvement of existing technologies. These improvements will lead to increased energy efficiency potential over time. Nor did the study address the ongoing tightening of equipment and building standards (beyond those known to be effective within the study period), which will lead to a decrease in energy efficiency potential over time. The improvements in energy-efficient technologies provide opportunities for additional program savings over a static base-case technology. However, as the market matures, codes and standards are tightened to raise base-case efficiency, and the result is subsequent reduction in program savings opportunities to levels that were available prior to the improvements in leading technology efficiency. We feel that the effects of gradual technology improvement and ongoing tightening of codes and standards offset each other over an extended period.

1.3 **Results**

Table 1-1 presents the overall results of the energy efficiency potential analysis for the 2014-2023 period. All efficiency results include line losses and technical and economic potential includes savings from opt-out/exempt/non-jurisdictional customers while the program savings estimates do not.²

Table 1-1: Summary of Cumulative Energy Efficiency Savings

rubic 1 1: Junimary of Camarative Interfer of Carmings						
Energy Efficiency 2014- 2023	Technical Potential	Economic Potential	Program Savings Potential: 75% Incentives	Program Savings Potential: 50% Incentives		
Energy Savings- GWh	28,308	16,599	3,782	2,111		
Demand Savings- MW	7,282	4,026	698	370		
Program Costs- Real, \$ Million			\$1,225	\$495		

Key takeaways from this study are as follows:

The amount of achievable program potential in Dominion's service territory is higher than the
planning assumptions in its current DSM portfolio. However, compared to similar studies in
other jurisdictions using the DSM ASSYST™ model, the percentage of achievable potential as a
proportion of base energy consumption is less than typical. A comparison of savings potential

Opt-out, exempt, and non-jurisdictional customers do not have to participate in Dominion's DSM programs and were excluded from the program savings analysis accordingly

- estimates from other jurisdictions is shown in Table 1-2 and an overview of achievable program potential is included in section 0.
- Existing and planned Dominion programs cover the majority of cost-effective measures analyzed as part of this study, but potential exists in measures not currently included in Dominion's DSM programs. For example, Dominion programs cover a large portion of cost-effective measures in non-residential lighting and HVAC, but significant potential remains in residential appliance upgrades and refrigerator recycling which are not currently offered in Dominion's programs. Information about technical and economic potential by end use can be seen in section 0.
- LED upgrades account for a significant proportion of residential achievable potential over the next ten years. More information about achievable savings in the residential sector can be found in section 0.
- When viewing the range of cost-effective measures there is a clear distinction between those that are cost effective and those that are not. As seen in the supply curves in section 5.3.10, a large amount of cost effective potential exists at a low cost per kWh, but the curve sharply increases around \$0.30 per kWh. As a planning tool, the findings of this study can be helpful in identifying the cost-effective measures used in program design.

1.3.1 Aggregate Base Energy Efficiency Potential Results

Estimates of electric energy savings potential are presented in Figure 1-1, below. These savings reflect cumulative annual savings over a 10-year period potential. This can also be looked at as the annual savings potential of all installations through 2023. Technical potential is estimated at 28,308 GWh per year by 2023. Economic potential is estimated at 16,599 GWh by 2023. Achievable program potentials range between 3,782 GWh per year by 2023 in the 75 percent incentive scenario to 2,111 GWh per year for the 50 percent incentive scenario. Economic potential for energy savings is estimated to be 22 percent of base 2023 energy use; achievable potentials range from three percent of base usage in the 50 percent incentive case to five percent of base energy use in the 75 percent incentive case.³ These results suggest that while obtaining all technical and economic potential will be difficult given Dominion's avoided cost structure and limited history of comprehensive DSM programs in Virginia and North Carolina; there is additional potential available from measures not currently in Dominion's DSM portfolio. While Dominion began offering DSM programs to customers five years ago, this is limited compared to other jurisdictions that have offered programs for more than a decade. Furthermore, Dominion's past programs have not touched all end uses, so additional opportunities to start programs exist in those markets.





Figure 1-1: Estimated Electric Energy Efficiency Savings Potential, 2014-2023⁴

³ Savings under the 75% incentive scenario are six percent of base non-residential and residential consumption (excluding base consumption from opt-out/exempt/non-jurisdictional customers). Savings from the 50% scenario are 3% of residential and non-residential base consumption.

⁴ Note that base use includes 10,380 GWh associated with opt-out, exempt, and non-jurisdictional customers within Dominion's service territory. Technical and Economic Potential includes these customers but program potential does not.

Cumulative 10-year peak demand savings potential estimates are provided in 1-2.⁵ Technical potential is estimated at 7,282 MW and economic potential is estimated at 4,026 MW. Achievable program potential ranges between 698 MW in the 75 percent incentive case down to 370 MW in the 50 percent case. Economic potential for peak demand savings is estimated to be 20 percent of base 2023 peak demand; achievable potentials range from two percent of base peak demand in the 50 percent incentive case to three percent of base peak demand in the 75 percent incentive case. All results include line losses.



1-2: Estimated Peak Demand Savings Potential, 2014-2023⁶

⁵ The estimates of peak demand savings are from the installation of energy efficiency measures and do not include demand savings from demand response technologies such as direct load control or dynamic pricing.

⁶ Base use also includes 3,361 MW associated with opt-out, exempt, and non-jurisdictional customers within Dominion's service territory. Technical and Economic Potential includes these customers but program potential does not.

Table 1-2 compares the results of potential studies recently conducted by DNV GL with the DSM ASSYST™ model.^{7,8,9} Achievable energy savings potential as a percent of base consumption available in Dominion's territory is low compared to estimates from other jurisdictions that analysed savings from 50 percent and 75 percent scenarios.

Table 1-2: Comparison of Energy Savings Potential as a Percent of Base Consumption

		y savings i steiniai us		Achievable Potential Scenario	
Jurisdiction	Years of Analysis	Sectors	Economic Potential	50% Incentives	75% Incentives
Xcel Minnesota	2011-2020	Residential, Commercial, Industrial	20%	10%	11%
Xcel Colorado	2010-2020	Residential, Commercial	23%	5.50%	8.5%
Austin Energy	2012-2020	Residential, Commercial, Industrial	20%		9.8%
Dominion	2014-2023	Residential, Non- Residential	22%	3%	6%


⁷ Xcel Minnesota: http://www.xcelenergy.com/staticfiles/xe/Regulatory/Regulatory%20PDFs/MN-DSM/MN-DSM-Market-Potential-Assessment-Vol-1.pdf

 $^{^{8} \ \}textit{Xcel Colorado:} \ \underline{\textit{https://www.xcelenergy.com/staticfiles/xe/Regulatory/Regulatory\%20PDFs/CODSM-Report.pdf}$

 $^{^9}$ Austin Energy: https://austinenergy.com/wps/wcm/connect/15a83f48-4741-41f9-af6dff27a064bd03/2012DSMmarketPotentialAssessment.pdf?MOD=AJPERES

Error! Reference source not found. depicts the estimated costs and benefits under each funding scenario from 2014 to 2023. The present value of program costs (including program incentives and program admin and marketing) is \$389 million under the 50 percent incentive scenario and \$963 million under the 75 percent incentive scenario.

The present value of total avoided cost benefits is \$1,278 million under 50 percent incentives and \$2,251 million under 75 percent incentives. Finally, all scenarios have positive net benefits: the present value of net avoided cost benefits, i.e., the difference between total avoided cost benefits and total costs (which include participant costs in addition to program costs), is \$763 million under 50 percent incentives and \$1,185 million under 75 percent incentives. As a result of dramatically increasing incentive costs for higher incentive scenarios, increases in program costs outpace the increases in benefits as one moves to higher incentive scenarios. As modeled, all program participants receive the same incentives in a given scenario, even though some customers would have accepted lower incentives.



1-3: Benefits and Costs of Energy Efficiency Savings-2014-2023*

^{*} Present value of benefits and costs over normalized 20-year measure lives; nominal discount rate is 7.45 percent, inflation rate is 1.87 percent.

^{*} PV (present value) of benefits and costs is calculated for 2011-2020 program years using a nominal discount rate = 7.4 percent, and an assumed inflation rate = 1.9 percent.

Both of the funding scenarios are cost-effective based on the TRC test, which is the test used in this study to determine program cost-effectiveness. The TRC benefit-cost ratios for Dominion's service territory are 2.5 for the 50 percent scenario and 2.1 under the 75 percent scenario. ¹⁰ The high TRC in both scenarios is largely driven by LED installations, particularly in the residential sector. Key results of our efficiency scenario forecasts from 2014 to 2023 are summarized in Table 1-3.

Table 1-3: Summary of Achievable Potential Results—2014-2023*

Result - Programs	Program Scenario:			
	50 percent Incentives	75 percent Incentives		
Total Market Energy Savings - GWh	4,195	5,809		
Total Market Peak Demand Savings - MW	723	1,042		
Program Energy Savings - GWh	2,111	3,782		
Program Peak Demand Savings - MW	370	698		
Program Costs - Real, \$ Million				
Administration	\$158	\$397		
Marketing	\$54	\$74		
Incentives	\$284	\$754		
Total	\$495	\$1,225		
PV Avoided Costs	\$1,278	\$2,251		
PV Annual Program Costs (Adm/Mkt)	\$166	\$370		
PV Net Measure Costs	\$349	\$697		
Net Benefits	\$763	\$1,185		
TRC Ratio	2.5	2.1		

^{*}PV (present value) of benefits and costs is calculated over a 20-year normalized measure life for 2014-2023 program years, nominal discount rate = 7.45 percent, inflation rate = 1.87 percent; GWh and MW savings are cumulative through 2023.

 $^{^{10}}$ This report presents TRC as the cost-benefit test. Under Virginia Law, the RIM, UCT, and PCT are also considered for regulatory approval.

1.3.2 Achievable Savings Potentials over Time

Figure 1-4 shows our estimates of achievable program potential energy savings over time (peak demand savings follow a similar pattern but are not shown). Naturally occurring savings are also shown to provide a picture of total market potential. Savings continue to grow over time, again largely due to a large impact from LEDs in the analysis.




Figure 1-4: Achievable Electric Energy Savings: All Sectors

1.3.3 Base Energy Efficiency Results by Sector

Cumulative net achievable potential estimates by sector for the period of 2014-2023 are presented in Figure 1-5 and Figure 1-6. These figures compare the residential and non-residential sector results for each funding scenario. All opt-out, exempt, and non-jurisdictional customers were excluded from this analysis.

Under the program assumptions developed for this study, achievable energy and demand savings under the 50 percent and 75 percent scenarios are highest for the residential sector.




Figure 1-5: Net Achievable Energy Savings (2023) by Sector—GWh per Year

Figure 1-6: Net Achievable Peak-Demand Savings (2023) by Sector—MW

2. INTRODUCTION

Dominion retained DNV GL to conduct this demand side management (DSM) market potential study which was based on existing and proposed customer end-use energy efficiency measures and programs. The study provides estimates of potential electricity and peak demand savings from energy efficiency measures in Dominion's Virginia and North Carolina service territories, including technical, economic, and achievable program potential. The analysis also presents the technical and economic potential associated with opt-out, exempt, and non-jurisdictional customers in Dominion's service territory. These customers were not included in the estimation of program achievable potential as they do not participate in Dominion-sponsored programs. The study also does not address natural gas equipment usage or savings.

2.1 **Overview**

The scope of this study includes new and existing residential and non-residential buildings and covers a 10-year period spanning 2014–2023. Given the near- to mid-term focus, the base potential analysis was restricted to DSM measures that are presently commercially available, and only included codes and standards that are currently in place or will be effective within the next year. We did not make a prediction on the impact of future codes and standards.

Data for the study came from a number of different sources, including: data from the residential and commercial saturation studies conducted by DNV GL in 2013, a residential conditional demand analysis conducted by DNV GL in the spring of 2014, internal Dominion data, DNV GL's extensive energy efficiency database, residential and non-residential building equipment saturation surveys, and a variety of information from third parties.

2.2 **Study Approach**

2.2.1 Energy Efficiency Potential Approach

The energy efficiency potential portion of the study involved identifying and developing baseline enduse and measure data, and developing estimates of future energy efficiency impacts under varying levels of program effort.

We performed a baseline characterization that allowed us to identify the types and approximate sizes of the various market segments that are the most likely sources of DSM potential in Dominion's service territory. These characteristics then served as inputs to a modeling process that incorporated Dominion's energy-cost parameters and specific energy efficiency measure characteristics (such as costs, savings, and existing penetration estimates) to provide more detailed potential estimates.

To aid in the analysis, we utilized the DNV GL's DSM ASSYST™ model. This model provides a thorough, clear, and transparent documentation database and an extremely efficient data processing system for estimating technical, economic, and achievable potential. We estimated technical, economic, and achievable program potential for the residential and non-residential sectors, with a focus on energy efficiency impacts through 2023.

2.3 **Organization of the Report**

Section **Error! Reference source not found.** provides a brief overview of the data collection activities conducted for this study. Full results are provided in a separate report that presents the detailed results of surveys that were conducted to develop the key inputs used in the market potential models.

- Section 4 discusses the methodology and concepts used to develop the technical, economic, and achievable potential estimates.
- Section Error! Reference source not found. provides baseline results developed for the study.
- Sections 0 and 5.2.2.2 discuss the results of the electric energy efficiency potential analysis by sector and over time.

The full report contains the following appendices in a separate document from this report:

- Appendix A: Detailed Methodology and Model Description—Further detail on what was discussed in Section 4.
- Appendix B: Measure Descriptions—Describes the measures included in this study.
- Appendix C: Economic Inputs—Provides avoided cost, electric rate, discount rate, and inflation rate assumptions used for the study.
- Appendix D: Building and TOU Factor Inputs—Shows the base household counts, square footage estimates for non-residential building types, and base energy use by industrial segment. This appendix also includes time-of-use factors by sector and end-use.
- Appendix E: Measure Inputs—Lists the electric measures included in the analysis with the costs, estimated savings, applicability, and estimated current saturation factors.
- Appendix F: Non-Additive Measure Level Results—Shows energy efficiency potential for each measure independent of any other measure.
- Appendix G: Supply-Curve Data—Shows the data behind the energy supply curves provided in Section 0 of the report.
- Appendix H: Detailed technical and economic avoided cost scenario results.
- Appendix I: Measure-Level Ranking by Economic Energy Savings Potential.
- Appendix J: Achievable Program Potential—Provides the forecasts for the achievable potential scenarios.

3. DATA COLLECTION AND DEVELOPMENT

This section describes the efforts used by DNV GL to develop data inputs for this potential study. The main sources of this data were the residential/commercial saturation surveys, the residential conditional demand analysis (CDA), data provided by Dominion staff, and secondary data sources.

3.1 **Dominion-Specific Data Collection Efforts**

Dominion engaged DNV GL to collect end-use saturation and consumption data from residential and non-residential customers for use in load research and DSM planning operations. Data developed from the resulting studies were also used as direct inputs for the DSM Potential Study. The residential and commercial customer saturation surveys used for these efforts collected information on building characteristics, occupant characteristics, and the penetration and usage of various end uses throughout

Dominion's service territory. The residential saturation survey data was then fed into the residential CDA model, which produced estimates of annual electricity consumption for many end-use categories. The CDA estimates, along with data from the saturation studies, were then used as inputs in the DSM ASSYST™ model. These data were combined with other data from Dominion and secondary data sources to fully populate the data inputs required for the modeling effort. Figure 3-1 illustrates the relationship between the saturation studies, conditional demand analysis, additional data sources, and the DSM potential study.




Figure 3-1: Summary Flow Chart for the DSM Potential Study Process

3.1.1 Residential and Commercial Saturation Studies

The residential and commercial saturation study data collection efforts were initiated between September and December, 2013. The goal of these studies were to estimate the saturation of end uses of electricity associated with appliances, as well as the usage patterns and related household/building characteristics. The data gathered from these saturation studies is fed into the conditional demand analysis which then provides unit energy consumption (UEC) estimates for a range of electric end uses and market segments for the DSM potential study.

The sections below describe the sample selection, data collection and response rates for the residential and commercial saturation studies.

3.1.2 Residential Sample Selection

The residential saturation study had a final frame of 1,984,601 accounts with 180 days or more billing data and annual consumption greater than or equal to 3,600 kWh. The frame was stratified across the following variables:

- Region: Seven levels to include North Carolina service territory
- Categorized average daily kWh (four Levels)
- Categorized kWh daily variability (three Levels)
- Sampled in 2008 residential appliance and saturation survey (RASS)
- Participated in Residential DSM II program as of 7/1/2013.

Accounts were selected with probability proportionate to their total annual kWh consumption.

3.1.3 Commercial Sample Selection

The commercial saturation study had a final frame of 184,430 accounts (represents 99.62% of total annual kWh) with 180 days or more billing data and annual consumption greater than or equal 4,800 kWh. The frame was stratified across the following variables:

- Region: Seven distinct geographic areas to include NC service territory
- Categorized average daily kWh (four Levels)
- Categorized kWh daily variability (three Levels).

Selected with certainty:

- Average daily kWh ≥ 15,000 kWh
- Any company enrolled in Commercial DSM II programs as of 7/1/2013.

Accounts were selected with probability proportionate to their total annual kWh consumption. Selection was done systematically; each stratum was sorted by Office ID, NAICS code and a random number. The sample distributed across the NAICS codes proportional to the population within each Office ID.

3.1.4 Data Collection

Data collections for these saturation studies were multimodal. They included an online web survey and a mailed print survey. There was a two phase sample outreach:

Phase 1

- Business letter mailed to commercial sample; link to Dominion website/online survey.
- Postcard mailed to residential sample; link to Dominion website/online survey.

Phase 2

Printed survey package mailed to Phase 1 non-respondents.

Incentives delivered to respondents

- Residential \$5 (thank you letter mailed with Visa gift card; or online gift card).
- Commercial \$25 (online gift card).

3.1.5 Response Rates

Table 3-1 displays the response rates for the residential saturation survey. The overall response rate from residential respondents was 27%; 57% mailed in their survey, while 43% completed it online.

Table 3-1: Residential Saturation Survey Response Rates

rubic b 11 Residential Suturation Survey Response Rutes							
Region	Mail	Online	Total	Final Response			
	responses	Responses	Responses	Rate			
Total	2,275	1,714	3,989	27.0%			
Northern Virginia	402	534	936	27.0%			
Shenandoah Valley / Western Piedmont	278	172	450	30.7%			
Richmond / Tri-Cities	339	293	632	28.2%			
Southside	283	123	406	27.6%			
Gloucester / Northern Neck	322	134	456	30.8%			
Southeastern	447	336	783	25.6%			
North Carolina	204	122	326	20.4%			

Table 3-2 displays the response rates for the commercial saturation survey. The overall response rate from commercial respondents was 10.5%; 26% mailed in their survey, while 74% completed it online.

Table 3-2: Commercial Saturation Survey Response Rates							
Region	Mail	Online	Total	Final Response			
	responses	Responses	Responses	Rate			
Total	404	1,123	1,527	10.5%			
Northern Virginia	62	239	301	7.5%			
Shenandoah Valley / Western Piedmont	43	151	194	13.2%			
Richmond / Tri-Cities	65	179	244	11.6%			
Southside	50	138	188	13.1%			
Gloucester / Northern Neck	49	89	138	9.7%			
Southeastern	68	191	259	10.3%			

Table 3-2: Commercial Saturation Survey Response Rates

3.1.6 Residential Conditional Demand Analysis

67

The objective of a conditional demand analysis (CDA) is to estimate a breakdown of energy consumption into different end-use categories, such as water heaters or refrigerators, accounting for weather and a number of customer and end-use attributes such as square footage of the home and vintage of the electrical end-use device.

136

203

12.7%

The key data sources for CDA models are:

North Carolina

- Customer survey data In this study we utilized the RASS conducted by DNV GL in 2013.
- Customer billing data We merged monthly electricity consumption data from recent years specific to each RASS respondent from Dominion's customer billing database.
- Weather data We extracted hourly interval temperature data from the National Oceanic and Atmospheric Administration (NOAA) matched to the ZIP codes of RASS respondents.

The methodology develops statistical relationships between these data through regression models. The resulting model estimates are then calibrated to represent a typical meteorological year, rather than using actual weather data from the analysis period, which may have had more mild or extreme weather than normal.

Properly specified CDA models can account for major classes of end uses by residential customers, which include space heating, space cooling, and water heating, among other major end uses. Importantly, properly specified CDA models can also produce statistically significant data for end-use combinations.

There are some limiting factors for this CDA model that warrants further discussion, as noted below:

Near-saturation of the end-use across households (e.g., refrigerators or lighting).

- Co-linearity among certain end uses across households (i.e., groups of two or more types of end uses which are found in those groups more often than individually). For example, set top boxes and TVs together, as opposed to TVs alone.
- Consumption that is not discernible in monthly billing consumption data among usage behavior variation across households (e.g., printers or toasters).

If some important end-use categories are not typically meaningful to estimate through a CDA alone, they are typically combined with relevant secondary source studies. CDA-based estimates on their own can give valuable insight into end-use consumption distributions across groups of customers, as is shown in several figures in this report.

3.2 Additional Data Sources

In addition to the saturation studies and CDA described above, DNV GL used additional data sources to inform certain inputs of the potential study model that could not be ascertained through the aforementioned data collection efforts. This section outlines those sources, and how they were used in the modeling process.

3.2.1 Measure Data

Several secondary data sources provided insight on measure-level energy usage and savings potential, measure costs and lifetimes, and the current penetration of various efficiency measures. DNV GL reviewed a variety of data sources for this information with the aim to find data that was specific to Dominion's service territory or geographic location as much as possible. The sources listed below provided information for these inputs:

- EIA Commercial Buildings Energy Consumption Survey (CBECS)
- EIA Residential Energy Consumption Survey (RECS)
- ENERGY STAR Calculators
- EIA Data for Mid-Atlantic
- Mid-Atlantic TRM
- Professional judgment of DNV GL engineers with experience in Dominion's service territory
- Dominion EM&V Results.

3.2.2 Economic Data

Economic inputs from Dominion's service territory were used to provide a more accurate picture of the monetary cost and benefits associated with energy efficiency. Dominion provided data to support the following model requirements:

- Customer Discount Rate
- Inflation Rate
- Utility Discount Rate
- Avoided Cost and Retail Rate Forecasts for low, base, and high avoided cost scenarios
- Line Loss Estimates.

3.2.3 Building Data

Information pertaining to which customers were considered opt-out, exempt, and non-jurisdictional, as well as system load data, was provided by Dominion:

- Billing data to identify consumption from opt-out, exempt, and non-jurisdictional customers
- System Load Data
- EIA data for Virginia Electric & Power Co., Virginia and North Carolina to determine number of customers.

3.2.4 Program Budgets

As part of the potential modeling process, past and projected program budgets are used to as a starting point for the achievable potential analysis which estimates the market penetration of measures as a function of marketing, incentive levels and other factors. To help calibrate the achievable modeling efforts, current and past Dominion program budgets were used to gauge the range of program costs in the Dominion service territory. Specifically, marketing and administrative dollars were two inputs into the model that were derived from the indicator tables provided by DNV GL to Dominion. Table 3-3 outlines the indicator table data DNV GL reviewed for this effort.

Table 3-3: DSM II EM&V Summary Indicator Tables

Indicator Table Variable Name	Description	DNV GL Funding Designations for modelling efforts
Direct Rebate	Dollar value rebates given to participant	
Direct Implementation	Cost of Honeywell's/DOM PM Services	Marketing dollars
Direct EM&V	Cost of DNV KEMA's EM&V Services	
Indirect Other (Administrative)	Shared Dominion Services (Common Costs)	Admin dollars

 $^{^{11}}$ The methodology of calculation measure penetration is described in more detail in Section 4 and Appendix A

4. ENERGY EFFICIENCY METHODS

4.1 **Energy Efficiency Potential Methods**

This section provides a brief overview of the concepts, methods, and scenarios used to conduct this study. Additional methodological details are provided in Appendix A.

4.1.1 Characterizing the Energy Efficiency Resource

Energy efficiency has been characterized for some time now as an alternative to energy supply options, such as conventional power plants that produce electricity from fossil or nuclear fuels. In the early 1980s, researchers developed and popularized the use of a conservation supply-curve paradigm to characterize the potential costs and benefits of energy conservation and efficiency. Under this framework, technologies or practices that reduced energy use through efficiency were characterized as making the energy saved available to meet other demands, and could therefore be thought of as a resource and plotted on an energy supply curve. The energy efficiency resource paradigm argued simply that the more energy efficiency or "nega-watts" produced, the fewer new plants would be needed to meet end-users' power demands.

4.1.2 Defining Energy Efficiency Potential

Energy efficiency potential studies became popular throughout the utility industry from the late 1980s through the mid-1990s. This period coincided with the advent of what was called least-cost or integrated resource planning (IRP). Energy efficiency potential studies became one of the primary means of characterizing the resource availability and value of energy efficiency within the overall resource planning process.

¹² Term coined by environmental scientist Amory Lovins in 1989.

Like any resource, there are a number of ways in which the energy efficiency resource can be estimated and characterized. Definitions of energy efficiency potential are similar to definitions of potential developed for finite fossil fuel resources, like coal, oil, and natural gas. For example, fossil fuel resources are typically characterized along two primary dimensions: the degree of geological certainty with which resources may be found, and the likelihood that extraction of the resource will be economic. This relationship is shown conceptually in Table 4-1.

Table 4-1: Conceptual Framework for Estimates of Fossil Fuel Resources

Existence —	Possible and Economically Feasible	Possible but not Economically Feasible
Decreasing Certainty of Existence	Known and Economically Feasible	Known but not Economically Feasible

Decreasing Economic Feasibility ----

Somewhat analogously, this energy efficiency potential study defines several different *types* of energy efficiency *potential*, namely technical, economic, achievable program, and naturally occurring. These potentials are shown conceptually in Figure 4-1 and described below.

- **Technical potential** is defined in this study as the *complete* penetration of all measures analyzed in applications where they were deemed *technically* feasible from an *engineering* perspective.
- **Economic potential** refers to the *technical potential* of those energy conservation measures that are cost effective when compared to supply-side alternatives.
- Achievable program potential refers to the amount of savings that would occur in response to specific program funding and measure incentive levels. Savings associated with program potential are savings that are projected beyond those that would occur naturally in the absence of any market intervention.
- Naturally occurring potential refers to the amount of savings estimated to occur as a result of normal market forces; that is, in the absence of any utility or governmental intervention.




Figure 4-1: Conceptual Relationship among Energy Efficiency Potential Definitions

4.1.3 Summary of Analytical Steps Used for the Energy Efficiency Potential

The crux of this study involves carrying out a number of basic analytical steps to produce estimates of the energy efficiency potentials introduced above. The basic analytical steps for this study are shown in relation to one another in Figure 4-2. The bulk of the analytical process for this study was carried out in a model developed by DNV GL for conducting energy efficiency potential studies. Details on the steps employed and analyses conducted are described in Appendix A. The model used DSM ASSYST™, a Microsoft® Excel-based model that integrates technology-specific engineering and customer behavior data with utility market saturation data, load shapes, rate projections, and marginal costs into an easily updated data management system.




Figure 4-2: Conceptual Overview of Study Process

The key steps implemented in this study are:

Step 1: Develop Initial Input Data

- Develop a list of energy efficiency measure opportunities to include in scope. In this step, an initial draft measure list was developed and provided to Dominion. The final measure list was developed after incorporating comments.
- Gather and develop technical data (costs and savings) on efficient measure opportunities. Data on measures were gathered from a variety of sources. Measure descriptions are provided in Appendix B and detail on measure inputs is provided in Appendix E.
- Gather, analyze, and develop information on building characteristics, including total square footage or total number of households, energy consumption and intensity by end use, enduse consumption load patterns by time of day and year (i.e., load shapes), market shares

- of key electric consuming equipment, and market shares of energy efficiency technologies and practices. Section **Error! Reference source not found.** of this report describes the baseline data developed for this study.
- Collect data on economic parameters: avoided costs, electricity rates, discount rates, and inflation rate. These inputs are provided in Appendix C of this report.

Step 2: Estimate Technical Potential and Develop Supply Curves

 Match and integrate data on efficient measures to data on existing building characteristics to produce estimates of technical potential and energy efficiency supply curves.

Step 3: Estimate Economic Potential

Match and integrate measure and building data with economic assumptions to produce indicators of costs from different viewpoints (e.g., societal and consumer).
 Estimate total economic potential. (Note that at this stage of the analysis, program-related costs are not factored into the cost-effectiveness screening. Thus, the results reflect the theoretical estimate of the measure impacts, while disregarding the mode of delivery.)

Step 4: Estimate Achievable Program and Naturally Occurring Potentials

- Screen initial measures for inclusion in the program analysis. This screening may take into account factors such as cost effectiveness, potential market size, non-energy benefits, market barriers, and potentially adverse effects associated with a measure. For this study, measures were screened using the total-resource-cost test, with the exclusion of program costs and while considering only electric avoided-cost benefits.
- Gather and develop estimates of program costs (e.g., for administration and marketing) and historic program savings.
- Develop estimates of customer adoption of energy efficiency measures as a function of the economic attractiveness of the measures, barriers to their adoption, and the effects of program intervention.
- Estimate achievable program and naturally occurring potentials and associated program costs.

Step 5: Scenario Analyses

Recalculate potentials under alternate program scenarios.

5. ENERGY EFFICIENCY RESULTS

5.1 **Energy Efficiency Baseline Analysis**

This section presents a baseline analysis of energy use in Dominion's Virginia and North Carolina service territory. The purpose of this analysis is to provide a breakout of energy use by sector, building type and end use to provide a foundation for estimating demand side management /energy efficiency potentials.

DNV GL completed a conditional demand analysis of the residential sector using the saturation survey results and billing data to develop energy consumption values for various end uses. That data was incorporated into this analysis.

The non-residential analysis was not affected by the conditional demand analysis and is based on the best data available; however, in some cases that data was regional (for example, South Atlantic Census Division data from the Department of Energy's Commercial Buildings Energy Consumption Survey) rather than specific to Dominion's service territory. It was necessary to rely on such sources for inputs that could not be determined from the commercial survey data or from other Dominion data sources.

5.2 **Summary of Energy Use by Sector**

Energy usage by sector and business type was developed from data reported by the Energy Information Administration (EIA). These data are presented in Table 5-1 and Figure 5-1.

Table 5-1: Summary of Dominion MWh and Customers by Sector and State

	Virginia	/irginia		North Carolina		tal
	MWh	# of Customers	MWh	# of Customers	MWh	# of Customers
Residential	27,671,894	2,086,647	1,502,310	101,024	29,174,204	2,187,671
Non-Residential	44,743,695	250,032	2,612,238	17,790	47,355,933	267,822
Total	72,415,589	2,336,679	4,114,548	118,814	76,530,137	2,455,493

Source: EIA, data for Virginia Electric & Power Co., Virginia and North Carolina, 2012

Note that these values include non-jurisdictional, exempt and opt-out customers, and industrial customers. Exempt and opt-out customers will be broken out later. Industrial customers are not part of the potential study and will be excluded from the rest of the analysis.




Figure 5-1: Breakout of Dominion Energy Use by Sector

5.2.1 Residential Baseline

EIA data¹³ for Virginia was used to break out total residential customers into single family and multifamily customers, the two residential segments being examined in this study. Initially, the survey results were intended to be used for the single family/multifamily splits; however, the resulting

¹³ EIA, 2009. Household Energy Use in Virginia. Summary of state level data from the 2009 Residential Energy Consumption Survey.

estimate of three percent multifamily seemed implausibly low. EIA data for North Carolina was not available, so the Virginia splits were applied to both states. Table 5-2 shows the results.

Table 5-2: Number of Residential Customers by Building Type

Tubic 5 El Italiibei oi i	Colucticial Ca	iscomens by i	Junuing Type
Building Type	Virginia	North Carolina	Total
Single Family	1,668,245	80,767	1,749,012
Multifamily	418,402	20,257	438,659
Total	2,086,647	101,024	2,187,671

5.2.1.1 Residential End-Use Saturations

The equipment saturations (percent of households having an end use) were calculated from the results of the residential saturation surveys. ¹⁴ These results are shown in Table 5-3. For lighting, the equipment saturations interact with the number of lamps per home by usage and type. For modeling simplicity, the assumption is 100 percent saturation for each of the lighting wattage/use breakouts, with all the variation between homes being captured through the number of lamps per home for each lighting category.

Table 5-3: Residential End-Use Saturations by Base Measure

Table 5-3: Residential End-Use Saturations by Base Measure								
	Virginia		North Ca	rolina				
End-use Saturations	Single Family	Multi- family	Single Family	Multi- family				
Base Split-System Air Conditioner (13 SEER)	41%	38%	23%	38%				
Base Early Replacement Split-System Air Conditioner (11 SEER)	7%	7%	4%	7%				
Base Heat Pump Cooling (13 SEER)	37%	42%	51%	41%				
Base Early Replacement Heat Pump Cooling (11 SEER)	7%	7%	9%	7%				
Base Room Air Conditioner - EER 10.6	5%	2%	9%	2%				
Base Early Replacement Room Air Conditioner- EER 9.7	1%	0%	2%	0%				
Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	29%	14%	29%	14%				
Base Furnace Fans	90%	100%	90%	100%				
Base Heat Pump Space Heating (7.7 HSPF)	31%	48%	53%	48%				
Base Early Replacement Heat Pump Heating (11 SEER)	6%	8%	9%	8%				
Base Resistance Space Heating (Primary)	13%	30%	22%	29%				
Base High-Efficiency Incandescent Lighting, 0.5 hrs/day	100%	100%	100%	100%				
Base High-Efficiency Incandescent Lighting, 2.5 hrs/day	100%	100%	100%	100%				
Base High-Efficiency Incandescent Lighting, 6 hrs/day	100%	100%	100%	100%				
Base Lighting 15 Watt CFL, 0.5 hrs/day	100%	100%	100%	100%				
Base Lighting 15 Watt CFL, 2.5 hrs/day	100%	100%	100%	100%				
Base Lighting 15 Watt CFL, 6 hrs/day	100%	100%	100%	100%				

¹⁴ There were only four North Carolina multifamily survey respondents, so the results for that segment were not reliable. Throughout the data analysis, the combined North Carolina and Virginia multifamily data were used to represent North Carolina.

	Virginia		North Ca	rolina
Base Specialty Incandescent Lighting, 0.5 hrs/day	100%	100%	100%	100%
Base Specialty Incandescent Lighting, 2.5 hrs/day	100%	100%	100%	100%
Base Specialty Incandescent Lighting, 6 hrs/day	100%	100%	100%	100%
Base Fluorescent Fixture 1.8 hrs/day	100%	100%	100%	100%
Base Refrigerator	85%	85%	85%	85%
Base Early Replacement Refrigerator	15%	15%	15%	15%
Base Second Refrigerator	38%	1%	31%	1%
Base Freezer	30%	6%	40%	6%
Base Early Replacement Freezer	5%	1%	7%	1%
Base Second Freezer	2%	0%	6%	0%
Base 40 gal. Water Heating (EF=0.88)	44%	65%	73%	63%
Base Early Replacement Water Heating to Heat Pump Water Heater	8%	11%	13%	11%
Base Clothes washer (MEF=1.26)	92%	68%	86%	68%
Base Clothes Dryer (EF=3.01)	86%	61%	76%	61%
Base Dishwasher (EF=0.65)	78%	73%	42%	73%
Base Pool Pump (RET)	7%	0%	7%	0%
Base Plasma TV	23%	15%	29%	15%
Base LCD TV	82%	78%	66%	78%
Base CRT TV	37%	27%	41%	27%
Base Set-Top Box	74%	62%	75%	62%
Base DVD Player	77%	75%	67%	75%
Base Desktop PC	56%	38%	55%	38%
Base Laptop PC	71%	66%	55%	66%
Base Cooking	75%	75%	81%	75%
Base Miscellaneous	100%	100%	100%	100%
Base House Practices	100%	100%	100%	100%

An initial estimate of the number of incandescent lamps, CFLs, and LEDs per home was made using the survey data. These self-reported data suggested a total of 25.5 lamps per single family home and 12.2 lamps per multifamily home in Virginia, and 19.9 lamps per single family home in North Carolina. These values seem low when compared to lighting studies from other regions and the reported size of the homes. Self-reported values tend to underestimate lamp counts compared to on-site studies, since residents tend to forget about lamps used infrequently. The results of the conditional demand analysis (CDA) also suggested that the number of lamps was likely understated, since the lighting energy use from the CDA combined with the reported number of lamps implied an extremely high kWh usage per lamp—either very high wattage or very high average usage (or both). As a result of these concerns, when the model was calibrated so that lighting energy use would match the CDA results, the number of lamps per home was increased above the values found in the survey.

Also, to align the lighting saturation information with the lighting methodology used in DSM ASSYST™, the number of lamps was broken out into usage bins, as available from internal DNV GL databases (gleaned from previous potential studies and on-site data collection). The resulting breakouts are shown in Table 5-4.

Table 5-4: Lamps per Home by Type and Usage

Table 5-4: Lamps per nome by Type and Osage						
	Virginia		North Ca	rolina		
Lamp Usage	Single Family	Multi- family	Single Family	Multi- family		
Incandescent, 0.5 hrs/day	14.8	6.9	12.0	6.8		
Incandescent, 2.5 hrs/day	12.2	5.7	9.8	5.7		
Incandescent, 6 hrs/day	3.4	1.5	2.7	1.5		
CFL, 0.5 hrs/day	7.3	3.3	7.9	3.3		
CFL, 2.5 hrs/day	6.0	2.7	6.5	2.7		
CFL, 6 hrs/day	1.6	0.8	1.8	0.8		
Specialty Incandescent, 0.5 hrs/day	5.9	1.9	4.7	2.0		
Specialty Incandescent, 2.5 hrs/day	4.9	1.6	3.9	1.6		
Specialty Incandescent, 6 hrs/day	1.3	0.4	1.1	0.5		
Fluorescent Fixture 1.8 hrs/day	7.2	2.2	10.314	2.178		
Total	64.5	26.9	60.6	26.9		

5.2.1.2 Residential End-Use Energy Intensities

Table 5-5 shows the end-use energy intensities for the residential sector by base measure. End-use energy intensities represent the energy use per household for households that have that end-use. Most of these energy intensity values were derived from the conditional demand analysis. The rest were derived or calculated from a variety of sources, including:

- The Department of Energy's Home Energy Saver model
- The Environmental Protection Agency's ENERGY STAR calculators
- Engineering calculations (for lighting).

Table 5-5: Residential End-Use Energy Intensities (kWh/household with end-use)

	Virginia		North Ca	rolina
kWh/household	Single Family	Multi- family	Single Family	Multi- family
Base Split-System Air Conditioner (13 SEER)	2,912	947	2,507	960
Base Early Replacement Split-System Air Conditioner (11 SEER)	2,713	1,623	2,380	1,628
Base Heat Pump Cooling (13 SEER)	2,778	1,339	2,884	1,339
Base Early Replacement Heat Pump Cooling (11 SEER)	2,394	1,369	2,844	1,371
Base Room Air Conditioner - EER 10.6	1,504	2,122	942	2,122
Base Early Replacement Room Air Conditioner- EER 9.7	1,619	853	1,442	853
Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	57	61	69	74
Base Furnace Fans	1,109	529	1,118	533
Base Heat Pump Space Heating (7.7 HSPF)	4,546	1,710	3,685	1,710
Base Early Replacement Heat Pump Heating (11 SEER)	4,338	2,326	4,079	2,334

	Virginia		North Ca	rolina
Base Resistance Space Heating (Primary)	5,323	2,842	4,096	2,843
Base High-Efficiency Incandescent Lighting, 0.5 hrs/day	149	69	120	68
Base High-Efficiency Incandescent Lighting, 2.5 hrs/day	610	286	492	284
Base High-Efficiency Incandescent Lighting, 6 hrs/day	403	179	325	177
Base Lighting 15 Watt CFL, 0.5 hrs/day	20	9	22	9
Base Lighting 15 Watt CFL, 2.5 hrs/day	82	37	89	37
Base Lighting 15 Watt CFL, 6 hrs/day	54	25	58	25
Base Specialty Incandescent Lighting, 0.5 hrs/day	64	21	52	21
Base Specialty Incandescent Lighting, 2.5 hrs/day	266	85	214	87
Base Specialty Incandescent Lighting, 6 hrs/day	176	58	142	59
Base Fluorescent Fixture 1.8 hrs/day	442	135	637	135
Base Refrigerator	663	581	661	580
Base Early Replacement Refrigerator	533	447	534	447
Base Second Refrigerator	927	530	895	530
Base Freezer	1,101	1,043	1,305	1,043
Base Early Replacement Freezer	1,105	1,043	1,098	1,043
Base Second Freezer	1,101	1,043	1,305	1,043
Base 40 gal. Water Heating (EF=0.88)	3,538	2,791	3,047	2,759
Base Early Replacement Water Heating to Heat Pump Water Heater	3,538	2,791	3,047	2,759
Base Clothes washer (MEF=1.26)	46	46	46	46
Base Clothes Dryer (EF=3.01)	697	963	789	962
Base Dishwasher (EF=0.65)	260	260	260	260
Base Pool Pump (RET)	2,165	2,165	2,165	2,165
Base Plasma TV	338	284	368	218
Base LCD TV	219	164	193	126
Base CRT TV	157	145	151	111
Base Set-Top Box	299	206	238	158
Base DVD Player	35	29	29	22
Base Desktop PC	427	421	378	420
Base Laptop PC	61	49	54	49
Base Cooking		C00	685	600
base cooking	700	600	003	000
Base Miscellaneous	700 322	270	797	740

5.2.1.3 Water Heating End-Use Energy Intensities

Water heating energy use was broken into several components in the CDA. The first and largest component was base water heating, which did not include weather (heating degree day, or HDD), dependent water heating, or the water heating associated with clothes washers and dishwashers (which was included with the energy use for those appliances). The components produced by the CDA are shown in Table 5-6.

Table 5-6: Water-Heating-Related Outputs of the CDA Model

CDA Component	Description	Values
Base water heating	Water heating only. Corresponds to summer usage, excluding water heating associated with clothes washers and dishwashers	Ranged from 1,101 to 1,261 kWh, depending on which state (VA or NC) and the building type (single vs. multifamily)
Clothes Washers (including both machine energy and associated water heating)	Energy use attributable to clothes washers, including both the energy used by the machine and the associated water heating	Ranged from 248 to 286 kWh, depending on state and building type
Dishwashers (including both machine energy and associated water heating)	Energy use attributable to dishwashers, including both the energy used by the machine and the associated water heating	Ranged from 762 to 808 kWh, depending on state and building type
Water Heating -HDD-dependent	This includes the portion of water heating energy that increases as temperatures get colder, reflecting both increased storage losses and increased usage	Ranged from 1,187 to 1,678 kWh, depending on state and building type

For the baseline analysis, the water heating energy for the two appliances needed to be split apart from machine energy and included with the rest of water heating. To do this, data had to be pulled in from other sources. The HDD-dependent water heating needed to be included with the rest of water heating as well.

For its appliance standard setting process, the Department of Energy (DOE) performs detailed energy analyses, which are published in technical support documents. ¹⁵ Using the data from these analyses and calibrating between DOE's estimated total energy use for each appliance, and the total energy use for each from the CDA, produced estimates of 46 kWh of machine energy for clothes washers and 260 kWh of machine energy for dishwashers. The machine energy was netted out of the appliance totals to estimate the water heating portion of energy. The water heating shares were then weighted by appliance saturations by state and building type (since not all homes with electric water heating have clothes washers and dishwashers) and the result was added to the base water heating energy. The result represents the non-weather-sensitive portion of water heating energy use, including that associated with clothes washers and dishwashers.

¹⁵ These are available online at http://energy.gov/eere/buildings/standards-and-test-procedures.

Table 5-7 shows the resulting appliance-related water heating energy, with the CDA estimates of base water heating and HDD-dependent water heating energy. Total water heating energy ranges from 2,759 to 3,538 kWh, depending on building type and state.

Table 5-7: Water Heating Household Energy Use (kWh) by Component

	Virginia SF	Virginia MF	North Carolina SF	North Carolina MF
Water heating base energy use	1,261	1,101	1,219	1,102
Saturation-weighted CW/DW water heating energy	599	503	439	466
HDD-dependent water heating	1,678	1,187	1,390	1,191
Total	3,538	2,791	3,047	2,759

5.2.1.4 Residential Energy Use

Energy use was calculated as the product of the number of households, equipment saturation, and the end-use energy intensity. Energy use by building type and end-use is shown in Table 5-8.


Table 5-8: Residential Energy Use by Building Type and End-Use

	Virginia	000 2, 24	idilig Type all	North Card	olina		Total
MWh	Single Family	Multi- family	Virginia Total	Single Family	Multi- family	North Carolina Total	Total
Base Split-System Air Conditioner (13 SEER)	2,013,281	149,285	2,162,566	47,432	7,346	54,778	2,217,345
Base Early Replacement Split-System Air Conditioner (11 SEER)	331,027	45,162	376,189	7,947	2,199	10,146	386,335
Base Heat Pump Cooling (13 SEER)	1,708,907	232,645	1,941,552	119,757	11,246	131,003	2,072,554
Base Early Replacement Heat Pump Cooling (11 SEER)	259,869	41,980	301,849	20,840	2,032	22,872	324,721
Base Room Air Conditioner - EER 10.6	117,582	14,567	132,150	7,143	701	7,844	139,994
Base Early Replacement Room Air Conditioner- EER 9.7	22,340	1,033	23,373	1,930	50	1,980	25,352
Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	28,002	3,515	31,517	1,641	206	1,846	33,363
Base Furnace Fans	1,663,277	220,111	1,883,387	81,226	10,749	91,975	1,975,362
Base Heat Pump Space Heating (7.7 HSPF)	2,369,291	343,739	2,713,030	159,038	16,642	175,680	2,888,711
Base Early Replacement Heat Pump Heating (11 SEER)	398,968	82,492	481,460	31,064	4,009	35,073	516,533
Base Resistance Space Heating (Primary)	1,156,870	354,890	1,511,760	74,156	16,938	91,094	1,602,853
Base High-Efficiency Incandescent Lighting, 0.5 hrs/day	139,996	19,856	159,852	9,679	1,380	11,060	166,262
Base High-Efficiency Incandescent Lighting, 2.5 hrs/day	574,983	82,735	657,719	39,754	5,751	45,505	684,100
Base High-Efficiency Incandescent Lighting, 6 hrs/day	379,989	51,627	431,616	26,272	3,589	29,861	448,906
Base Lighting 15 Watt CFL, 0.5 hrs/day	33,253	3,749	37,001	1,742	181	1,923	38,925
Base Lighting 15 Watt CFL, 2.5 hrs/day	136,485	15,619	152,105	7,150	756	7,906	160,010
Base Lighting 15 Watt CFL, 6 hrs/day	89,336	10,309	99,645	4,680	499	5,179	104,823
Base Specialty Incandescent Lighting, 0.5 hrs/day	214,027	17,666	231,693	4,179	435	4,613	240,919
Base Specialty Incandescent Lighting, 2.5 hrs/day	886,683	71,343	958,026	17,311	1,755	19,066	996,158
Base Specialty Incandescent Lighting, 6 hrs/day	587,045	48,921	635,966	11,461	1,204	12,665	661,295
Base Fluorescent Fixture 1.8 hrs/day	738,089	56,279	794,368	51,446	2,725	54,171	848,539
Base Refrigerator	939,715	206,461	1,146,176	45,402	9,991	55,392	1,201,568
Base Early Replacement Refrigerator	133,345	28,080	161,426	6,465	1,359	7,825	169,250
Base Second Refrigerator	586,471	3,307	589,778	22,338	159	22,497	612,275

	Virginia	jinia North Carolina				Total	
Base Freezer	557,089	27,200	584,290	42,006	1,312	43,318	627,608
Base Early Replacement Freezer	98,605	4,777	103,381	6,238	231	6,470	109,851
Base Second Freezer	30,359	-	30,359	6,720	-	6,720	37,079
Base 40 gal. Water Heating (EF=0.88)	2,616,688	753,883	3,370,570	179,247	35,241	214,487	3,585,058
Base Early Replacement Water Heating to Heat Pump Water Heater	461,768	133,038	594,807	31,632	6,219	37,851	632,657
Base Clothes Washer (MEF=1.26)	71,249	13,161	84,411	3,231	637	3,868	88,279
Base Clothes Dryer (EF=3.01)	1,001,105	245,131	1,246,235	48,160	11,867	60,027	1,306,262
Base Dishwasher (EF=0.65)	337,538	79,486	417,024	8,923	3,846	12,769	429,793
Base Pool Pump (RET)	263,639	-	263,639	12,764	-	12,764	276,403
Base Plasma TV	128,600	17,986	146,586	8,711	666	9,377	155,963
Base LCD TV	300,583	53,733	354,317	10,344	1,998	12,342	366,659
Base CRT TV	97,674	16,109	113,783	5,055	599	5,654	119,437
Base Set-Top Box	369,231	53,581	422,812	14,402	1,988	16,390	439,203
Base DVD Player	44,155	9,047	53,202	1,567	337	1,904	55,106
Base Desktop PC	401,552	67,096	468,648	16,814	3,245	20,059	488,707
Base Laptop PC	71,684	13,526	85,210	2,390	654	3,044	88,254
Base Cooking	880,556	188,521	1,069,077	44,771	9,144	53,915	1,122,992
Base Miscellaneous	536,341	113,002	649,343	64,404	14,992	79,396	728,739
Base House Practices	23,777,246	3,894,648	27,671,894	1,307,432	194,878	1,502,310	29,174,204
Total	23,777,246	3,894,648	27,671,894	1,307,432	194,878	1,502,310	29,174,204

Figure 5-2 and Figure 5-3 show the breakout of residential energy use by building type and end use, respectively.

Virginia



North Carolina






Figure 5-2: Residential Energy Use by Building Type

Virginia





North Carolina




Figure 5-3: Residential Energy Use by End-Use

5.2.1.5 Residential Peak Demand

Annual 8,760 hourly data from Dominion was combined with end-use load shape data from DNV GL's end-use databases to allocate annual energy usage into time-of-use (TOU) periods. Peak period usage, developed on a sector-specific and end-use basis, was calibrated to equal the Dominion summer peak. Residential peak demand estimates by segment and end use are summarized in Table 5-9.

Table 5-9: Summary of Residential Electric Peak Demand by Segment and End Use - MW

Table 3-9. Sulfilliary of Reside	ential Electric Peak Demand by Segment and End Use – MW Virginia North Carolina					·	Total
MWh	Single Family	Multi- family	Virginia Total	Single Family	Multi- family	North Carolina Total	Total
Base Split-System Air Conditioner (13 SEER)	1,087	81	1,168	26	4	30	1,198
Base Early Replacement Split-System Air Conditioner (11 SEER)	179	24	203	4	1	5	209
Base Heat Pump Cooling (13 SEER)	923	126	1,049	65	6	71	1,119
Base Early Replacement Heat Pump Cooling (11 SEER)	140	23	163	11	1	12	175
Base Room Air Conditioner - EER 10.6	64	8	71	4	0	4	76
Base Early Replacement Room Air Conditioner- EER 9.7	12	1	13	1	0	1	14
Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	3	0	4	0	0	0	4
Base Furnace Fans	803	106	909	39	5	44	953
Base Heat Pump Space Heating (7.7 HSPF)	256	37	293	17	2	19	312
Base Early Replacement Heat Pump Heating (11 SEER)	43	9	52	3	0	4	56
Base Resistance Space Heating (Primary)	125	38	163	8	2	10	173
Base High-Efficiency Incandescent Lighting, 0.5 hrs/day	25	3	28	1	0	1	29
Base High-Efficiency Incandescent Lighting, 2.5 hrs/day	104	12	116	4	1	5	120
Base High-Efficiency Incandescent Lighting, 6 hrs/day	68	8	76	3	0	3	79
Base Lighting 15 Watt CFL, 0.5 hrs/day	3	0	4	0	0	0	4
Base Lighting 15 Watt CFL, 2.5 hrs/day	14	2	15	1	0	1	16
Base Lighting 15 Watt CFL, 6 hrs/day	9	1	10	0	0	1	11
Base Specialty Incandescent Lighting, 0.5 hrs/day	11	1	12	0	0	0	12
Base Specialty Incandescent Lighting, 2.5 hrs/day	45	4	49	2	0	2	51
Base Specialty Incandescent Lighting, 6 hrs/day	30	2	32	1	0	1	34
Base Fluorescent Fixture 1.8 hrs/day	75	6	81	5	0	6	86
Base Refrigerator	138	30	169	7	1	8	177
Base Early Replacement Refrigerator	20	4	24	1	0	1	25
Base Second Refrigerator	86	0	87	3	0	3	90

	Virginia			North C	North Carolina			
Base Freezer	80	4	84	6	0	6	90	
Base Early Replacement Freezer	14	1	15	1	0	1	16	
Base Second Freezer	4	0	4	1	0	1	5	
Base 40 gal. Water Heating (EF=0.88)	293	84	377	20	4	24	401	
Base Early Replacement Water Heating to Heat Pump Water Heater	52	15	67	4	1	4	71	
Base Clothes Washer (MEF=1.26)	12	2	14	1	0	1	15	
Base Clothes Dryer (EF=3.01)	154	38	192	7	2	9	201	
Base Dishwasher (EF=0.65)	50	12	62	1	1	2	64	
Base Pool Pump (RET)	28	0	28	1	0	1	30	
Base Plasma TV	17	2	19	1	0	1	20	
Base LCD TV	39	7	46	1	0	2	48	
Base CRT TV	13	2	15	1	0	1	16	
Base Set-Top Box	48	7	55	2	0	2	58	
Base DVD Player	6	1	7	0	0	0	7	
Base Desktop PC	48	8	56	2	0	2	59	
Base Laptop PC	9	2	10	0	0	0	11	
Base Cooking	256	55	310	13	3	16	326	
Base Miscellaneous	64	14	78	8	2	10	87	
Base House Practices	5,354	877	6,231	275	41	316	6,547	
Total	5,451	779	6,231	278	39	316	6,547	

Note: We calibrated the whole house load shape (used for house practices) so that peak demand for base house practices was equal to the sum of the peak demands across end uses by state. Due to modeling limitations (the whole-house load shape inputs are the same for both single family and multifamily); we could not calibrate these values at the building type level.

5.2.1.6 Residential Comparisons to RECS

In Table 5-10 below, we compare the results of the baseline analysis, seen above, to the Energy Information Administration's (EIA) Residential Energy Consumption Survey (RECS) from 2009.

EIA presents tabulated results for Virginia and for North Carolina/South Carolina. The comparisons below represent the Dominion's Virginia service territory versus all of Virginia, and Dominion's North Carolina service territory versus all of North and South Carolina. Some of the discrepancies in the values below may be a result of the differences in geography, particularly for North Carolina where Dominion's service territory is a small fraction of the two states.

For ease of comparison, the single- and multifamily values from the baseline analysis have been weighted together based on the housing stock to calculate a single value for each state.

Table 5-10: Comparison of the Residential Baseline Results to RECS

	Percent of Ho End use	ouseholds with	Household E Consumption			Total Annual	Comments
	2009 RECS	Dominion RASS	2009 RECS	Dominion CDA/Baseline Analysis	2009 RECS	Dominion Baseline Analysis	
Space Heating	VA: 53%		VA: 3,910		VA: 14%	VA: 17%	The saturation survey showed
	NC: 65%		NC: 2,850		NC: 13%	NC: 20%	overall higher penetrations of
HP Space Heating	VA: 37%	VA: 41%		VA: 3,978			electric heating, resulting in a
	NC: 30%	NC: 62%		NC: 3,289			higher overall share of electricity use.
Other Electric Space	VA: 17%	VA: 16%		VA: 3,338			electricity use.
Heating	NC: 35%	NC: 24%		NC: 2,261			
Water Heating	VA: 57%	VA: 57%	VA: 2,943	VA: 3,388	VA: 12%	VA: 14%	The baseline analysis found
	NC: 78%	NC: 83%	NC: 2,654	NC: 2,990	NC: 15%	NC: 17%	higher household energy consumption for water heating than RECS, resulting in a higher overall share of energy consumption. Saturations were comparable
Space Cooling	VA: 97%		VA: 2,246		VA: 15%	VA: 18%	The Dominion saturation
	NC: 96%		NC: 2,263		NC: 16%	NC: 15%	survey showed higher
Central AC	VA: 30%	VA: 48%		VA: 2,518			penetrations of central cooling
	NC: 44%	NC: 31%		NC: 2,578			(CAC + HP) than RECS, whichis reflected in the higher
HP Space Cooling	VA: 50%	VA: 44%		VA: 2,489			percent of residential
	NC: 39%	NC: 58%		NC: 2,673			electricity.
Room AC	VA: 17%	VA: 5%		VA: 1,628			
	NC: 13%	NC: 9%		NC: 1,179			
Refrigerators			VA: 1,381		VA: 10%	VA: 7%	The 2001 federal minimum
			NC: 1,279		NC: 9%	NC: 6%	refrigerator standards have
First Refrigerator	VA: 100%	VA: 100%		VA: 646			continued to penetrate the
	NC: 100%	NC: 100%		NC: 640			market since 2009, resulting — in lower unit energy
Second Refrigerator	VA: 30%	VA: 31%		VA: 847			consumption.
-	NC: 11%	NC: 25%		NC: 822			
Other	VA: 100%	VA: 100%	VA: 7,105	VA: 5,815	VA: 49%	VA: 44%	
	NC: 100%	NC: 100%	NC: 6,701	NC: 6,255	NC: 48%	NC: 42%	

5.2.2 Non-Residential Baseline

For this potential study, exempt and opt-out customers were split apart from the non-exempt customers. The non-exempt customers were further broken down by state. All three groups were broken down into building types, with non-jurisdictional customers split out of the Virginia analysis:

Building Types:

- Office
- Restaurant (not applicable for exempt/opt-out customers)
- Retail
- Grocery
- Warehouse
- Education
- Health
- Lodging
- Data Center
- Non-Jurisdictional (Virginia only)
- Religious Worship
- Other.

5.2.2.1 Non-Residential Equipment Saturations

The equipment saturations (percent of non-residential square feet having an end use) were calculated primarily from the results of the commercial saturation surveys. For a few measures, such as linear fluorescent lighting, saturations were broken down into finer levels of detail than was provided by the survey data (for example, 2-lamp 4-foot fixtures versus 4-lamp 4-foot fixtures versus other configurations). In such cases, data from internal DNV GL databases (gleaned from previous potential studies and on-site data collection) was used for the breakouts. The resulting saturations are shown in **Error! Reference source not found.**,

Table 5-12: Non-Residential Sector Equipment Saturations—North Carolina , and Error! Reference source not found..

Table 5-11: Non-Residential Sector Equipment Saturations—Virginia

End Use		Restau-			Ware-	ment Sat			Data	Non-	Religious	Other
End Ose	Office	rant	Retail	Grocery	house	Education	Health	Lodging	Center	Juris- dictional	Worship	Other
Base Fluorescent Fixture, 4L4'T8	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
Base Fluorescent Fixture, 2L4'T8, 1 EB	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
Base Other Fluorescent Fixture	5%	0%	0%	0%	0%	2%	4%	1%	4%	3%	1%	1%
Base High-Efficiency Incandescent Reflector Lamp (100W)	7%	22%	10%	25%	3%	5%	9%	16%	5%	6%	11%	10%
Base High-Efficiency Incandescent A- line Lamp (72W)	4%	11%	5%	12%	1%	2%	4%	8%	2%	3%	5%	5%
Base High-Efficiency Incandescent A- line Lamp (53W)	4%	11%	5%	12%	1%	2%	4%	8%	2%	3%	5%	5%
Base CFL (18W)	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
Base CFL (23W)	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
Base HID, 465W	2%	3%	4%	1%	25%	5%	2%	6%	2%	9%	2%	6%
Base CFL Exit Sign	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
Base Outdoor High Pressure Sodium 250W Lamp	43%	62%	41%	25%	72%	85%	64%	92%	93%	79%	89%	68%
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	13%	15%	1%	3%	0%	40%	19%	27%	66%	44%	15%	8%
Base DX Packaged System, EER=10.3, 10 tons	58%	77%	50%	84%	37%	95%	65%	68%	38%	54%	47%	32%
Base Heat Pump (13 SEER, 7.7 HSPF)	40%	24%	18%	7%	20%	75%	41%	53%	5%	23%	39%	30%
Base PTAC, EER=8.3, 1 ton	6%	3%	3%	3%	1%	68%	9%	11%	0%	36%	38%	19%
Base Fan Motor, 5hp, 1800rpm, 87.5%	42%	50%	43%	97%	30%	33%	19%	65%	19%	48%	54%	54%
Base Fan Motor, 15hp, 1800rpm, 91.0%	7%	0%	2%	0%	0%	89%	65%	0%	65%	25%	43%	43%
Base Fan Motor, 40hp, 1800rpm, 93.0%	5%	0%	2%	96%	10%	37%	69%	11%	69%	19%	34%	34%
Base Built-Up Refrigeration System	9%	67%	17%	91%	37%	37%	26%	38%	2%	40%	43%	18%
Base Self-Contained Refrigeration	68%	91%	71%	94%	90%	83%	77%	78%	95%	85%	96%	62%

End Use	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Desktop PC	98%	64%	80%	85%	98%	100%	95%	97%	98%	98%	95%	90%
Base Laptop PC	87%	44%	61%	66%	86%	98%	68%	87%	90%	83%	72%	71%
Base Monitor, CRT	60%	47%	42%	28%	68%	94%	64%	84%	79%	60%	45%	51%
Base Monitor, LCD	79%	42%	48%	92%	75%	93%	78%	87%	95%	96%	89%	78%
Base Copier	97%	45%	87%	29%	89%	99%	99%	94%	95%	97%	98%	86%
Base Multifunction	97%	78%	81%	84%	94%	98%	84%	93%	90%	97%	91%	86%
Base Printer	95%	30%	51%	17%	83%	99%	82%	43%	69%	92%	53%	71%
Base Data Center/Server Room	0%	0%	0%	0%	0%	0%	0%	0%	100%	0%	0%	0%
Base Water Heating	89%	39%	63%	78%	83%	72%	55%	31%	89%	39%	71%	51%
Base Refrigerated Vending Machines	99%	100%	90%	98%	99%	100%	99%	96%	100%	98%	100%	97%
Base Non-Refrigerated Vending Machines	78%	88%	54%	11%	95%	71%	74%	32%	100%	68%	3%	47%
Base Convection Oven	2%	15%	3%	56%	15%	8%	5%	20%	0%	22%	49%	5%
Base Fryer	1%	19%	1%	49%	11%	11%	3%	19%	0%	13%	1%	4%
Base Steamer	1%	15%	1%	42%	11%	1%	5%	7%	0%	16%	3%	2%
Base Heating, Heat Pump (13 SEER 7.7 HSPF)	35%	8%	8%	3%	2%	17%	23%	25%	0%	6%	6%	22%
Base Heating, Other Electric	35%	21%	28%	76%	12%	0%	32%	20%	41%	14%	46%	21%
Base Miscellaneous	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

Table 5-12: Non-Residential Sector Equipment Saturations—North Carolina

End Use	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Fluorescent Fixture, 4L4'T8	80%	4%	51%	62%	86%	11%	54%	2%	46%	NA	13%	9%
Base Fluorescent Fixture, 2L4'T8, 1 EB	2%	51%	17%	0%	1%	1%	14%	11%	1%	NA	12%	9%
Base Other Fluorescent Fixture	6%	0%	0%	0%	0%	0%	5%	0%	4%	NA	1%	0%
Base High-Efficiency Incandescent Reflector Lamp (100W)	7%	13%	3%	10%	6%	20%	11%	13%	5%	NA	25%	35%
Base High-Efficiency Incandescent A- line Lamp (72W)	3%	7%	1%	5%	3%	10%	5%	7%	2%	NA	13%	17%
Base High-Efficiency Incandescent A- line Lamp (53W)	3%	7%	1%	5%	3%	10%	5%	7%	2%	NA	13%	17%
Base CFL (18W)	2%	7%	9%	13%	1%	24%	12%	29%	17%	NA	34%	6%
Base CFL (23W)	2%	7%	9%	13%	1%	24%	12%	29%	17%	NA	34%	6%
Base HID, 465W	0%	0%	1%	1%	0%	1%	0%	1%	2%	NA	44%	9%
Base CFL Exit Sign	100%	100%	100%	100%	100%	100%	100%	100%	100%	NA	100%	100%
Base Outdoor High Pressure Sodium 250W Lamp	16%	42%	12%	91%	3%	93%	78%	93%	93%	NA	91%	42%
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	2%	3%	0%	0%	0%	68%	0%	0%	66%	NA	0%	0%
Base DX Packaged System, EER=10.3, 10 tons	39%	45%	53%	45%	10%	107%	34%	77%	38%	NA	89%	12%
Base Heat Pump (13 SEER, 7.7 HSPF)	43%	22%	28%	31%	0%	77%	67%	71%	5%	NA	74%	63%
Base PTAC, EER=8.3, 1 ton	5%	8%	2%	5%	5%	106%	6%	65%	0%	NA	1%	16%
Base Fan Motor, 5hp, 1800rpm, 87.5%	42%	50%	43%	97%	30%	33%	19%	65%	19%	NA	54%	54%
Base Fan Motor, 15hp, 1800rpm, 91.0%	7%	0%	2%	0%	0%	89%	65%	0%	65%	NA	43%	43%
Base Fan Motor, 40hp, 1800rpm, 93.0%	5%	0%	2%	96%	10%	37%	69%	11%	69%	NA	34%	34%
Base Built-Up Refrigeration System	0%	66%	9%	84%	3%	60%	10%	32%	2%	NA	0%	3%
Base Self-Contained Refrigeration	84%	92%	34%	76%	35%	92%	100%	79%	95%	NA	100%	75%
Base Desktop PC	98%	59%	37%	100%	3%	99%	100%	87%	98%	NA	86%	95%

End Use	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Laptop PC	64%	39%	13%	29%	3%	99%	64%	45%	90%	NA	23%	65%
Base Monitor, CRT	67%	24%	34%	62%	7%	98%	67%	80%	79%	NA	63%	67%
Base Monitor, LCD	91%	51%	21%	96%	3%	99%	100%	83%	95%	NA	33%	80%
Base Copier	92%	42%	37%	92%	3%	100%	100%	87%	95%	NA	99%	78%
Base Multifunction	91%	84%	37%	97%	3%	98%	91%	87%	90%	NA	23%	51%
Base Printer	99%	21%	11%	48%	7%	79%	77%	73%	69%	NA	14%	83%
Base Data Center/Server Room	0.07%	0.02%	0.00%	0.02%	0.03%	0.71%	1.13%	0.45%	100%	NA	0.02%	0.11%
Base Water Heating	84%	71%	83%	81%	35%	66%	88%	45%	89%	NA	45%	97%
Base Refrigerated Vending Machines	100%	100%	100%	100%	100%	94%	100%	94%	100%	NA	100%	96%
Base Non-Refrigerated Vending Machines	0%	0%	0%	6%	100%	89%	22%	29%	100%	NA	100%	52%
Base Convection Oven	0%	16%	0%	16%	0%	85%	5%	18%	0%	NA	0%	0%
Base Fryer	0%	12%	0%	2%	0%	20%	4%	8%	0%	NA	0%	0%
Base Steamer	0%	7%	0%	3%	0%	60%	4%	8%	0%	NA	0%	0%
Base Heating, Heat Pump (13 SEER 7.7HSPF)	40%	15%	27%	29%	0%	1%	74%	59%	0%	NA	14%	70%
Base Heating, Other Electric	37%	40%	7%	12%	22%	53%	0%	28%	41%	NA	0%	2%
Base Miscellaneous	100%	100%	100%	100%	100%	100%	100%	100%	100%	NA	100%	100%

Table 5-13: Non-Residential Sector Equipment Saturations—Opt-Out/Exempt

End Use	Office	Restau-	Retail	Grocery	Ware-	Education	Health		Data	Non-	Religious	Other
Eliu Ose	Office	rant	Retail	Grocery	house	Education	пеанн	Louging	Center	Juris- dictional	Worship	Other
Base Fluorescent Fixture, 4L4'T8	62%	NA	29%	42%	57%	44%	54%	3%	46%	48%	NA	8%
Base Fluorescent Fixture, 2L4'T8, 1 EB	2%	NA	10%	0%	0%	4%	14%	17%	1%	14%	NA	8%
Base Other Fluorescent Fixture	5%	NA	0%	0%	0%	2%	5%	1%	4%	3%	NA	0%
Base High-Efficiency Incandescent Reflector Lamp (100W)	7%	NA	10%	25%	3%	12%	11%	16%	5%	6%	NA	8%
Base High-Efficiency Incandescent A- line Lamp (72W)	4%	NA	5%	12%	1%	6%	6%	8%	2%	3%	NA	4%
Base High-Efficiency Incandescent A- line Lamp (53W)	4%	NA	5%	12%	1%	6%	6%	8%	2%	3%	NA	4%
Base CFL (18W)	8%	NA	17%	1%	6%	7%	3%	19%	17%	11%	NA	7%
Base CFL (23W)	8%	NA	17%	1%	6%	7%	3%	19%	17%	11%	NA	7%
Base HID, 465W	2%	NA	4%	1%	25%	10%	0%	6%	2%	9%	NA	6%
Base CFL Exit Sign	100%	NA	100%	100%	100%	100%	100%	100%	100%	100%	NA	100%
Base Outdoor High Pressure Sodium 250W Lamp	43%	NA	41%	25%	72%	100%	100%	92%	93%	79%	NA	100%
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	13%	NA	1%	3%	0%	93%	100%	27%	66%	44%	NA	4%
Base DX Packaged System, EER=10.3, 10 tons	58%	NA	50%	84%	37%	48%	100%	68%	38%	54%	NA	98%
Base Heat Pump (13 SEER, 7.7 HSPF)	40%	NA	18%	7%	20%	48%	56%	53%	5%	23%	NA	12%
Base PTAC, EER=8.3, 1 ton	6%	NA	3%	3%	1%	48%	56%	11%	0%	36%	NA	12%
Base Fan Motor, 5hp, 1800rpm, 87.5%	42%	NA	43%	97%	30%	33%	19%	65%	19%	48%	NA	54%
Base Fan Motor, 15hp, 1800rpm, 91.0%	7%	NA	2%	0%	0%	89%	65%	0%	65%	25%	NA	43%
Base Fan Motor, 40hp, 1800rpm, 93.0%	5%	NA	2%	96%	10%	37%	69%	11%	69%	19%	NA	34%
Base Built-Up Refrigeration System	9%	NA	17%	91%	37%	100%	100%	38%	2%	40%	NA	100%
Base Self-Contained Refrigeration	68%	NA	71%	94%	90%	100%	56%	78%	95%	85%	NA	50%
Base Desktop PC	98%	NA	80%	85%	98%	100%	100%	97%	98%	98%	NA	100%

End Use	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Laptop PC	87%	NA	61%	66%	86%	100%	100%	87%	90%	83%	NA	60%
Base Monitor, CRT	60%	NA	42%	28%	68%	100%	0%	84%	79%	60%	NA	93%
Base Monitor, LCD	79%	NA	48%	92%	75%	100%	100%	87%	95%	96%	NA	58%
Base Copier	97%	NA	87%	29%	89%	100%	100%	94%	95%	97%	NA	100%
Base Multifunction	97%	NA	81%	84%	94%	100%	100%	93%	90%	97%	NA	100%
Base Printer	95%	NA	51%	17%	83%	100%	100%	43%	69%	92%	NA	60%
Base Data Center/Server Room	0.20%	NA	0.02	0.01%	0.13	0.41%	0.63 %	0.17%	100.0 0%	0.21%	NA	0.18 %
Base Water Heating	89%	NA	63%	78%	83%	100%	0%	31%	89%	39%	NA	8%
Base Refrigerated Vending Machines	99%	NA	90%	98%	99%	100%	100%	96%	100%	98%	NA	95%
Base Non-Refrigerated Vending Machines	78%	NA	54%	11%	95%	51%	44%	32%	100%	68%	NA	20%
Base Convection Oven	2%	NA	3%	56%	15%	49%	100%	20%	0%	22%	NA	29%
Base Fryer	1%	NA	1%	49%	11%	49%	100%	19%	0%	13%	NA	33%
Base Steamer	1%	NA	1%	42%	11%	100%	100%	7%	0%	16%	NA	4%
Base Heating, Heat Pump (13 SEER 7.7HSPF)	34.7%	NA	7.7%	3.1%	1.5%	0.0%	0.0%	25.4%	0.0%	6.2%	NA	0.0%
Base Heating, Other Electric	35%	NA	28%	76%	12%	48%	0%	20%	41%	14%	NA	49%
Base Miscellaneous	100%	NA	100%	100%	100%	100%	100%	100%	100%	100%	NA	100%

Non-Residential End-Use Energy Intensities Table 5-14, 5.2.2.2

Table 5-15, and

Table 5-16 show the end-use energy intensities (EUIs) for the non-Residential sector by base measure. End-use energy intensities represent the energy use per square feet for businesses that have that end-use (for example, chiller annual kWh for non-Residential square feet with chillers). EUIs were developed from a variety of sources. At the base measure level, lighting EUIs were developed from engineering calculations based on wattage and hours of use. For products covered by the ENERGY STAR program, the Environmental Protection Agency's calculators were used. In addition, California's Commercial End-Use Survey (CEUS) was used for other non-weather-sensitive end uses. ¹⁶

At the end-use level, EUIs were obtained for the South Atlantic Census Division from the Department of Energy's 2003¹⁷ Commercial Building Energy Consumption Survey (CBECS). This provided concrete, survey-based, regionally appropriate values to use to calibrate the base measure-level EUIs. The resulting EUIs, when combined with the saturation data, produced intensities at the building type level that are consistent with values estimated from the Dominion survey data.

Table 5-14: Non-Residential End-Use Energy Intensities (kWh per End-Use Square Foot)—Virginia

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Fluorescent Fixture, 4L4'T8	7.8	7.8	5.2	7.4	2.1	3.4	3.1	1.6	6.1	4.9	1.57	4.9
Base Fluorescent Fixture, 2L4'T8, 1 EB	4.3	3.5	2.9	5.6	1.9	2.2	1.4	1.1	3.4	3.4	1.19	3.7
Base Other Fluorescent Fixture	3.5	0.0	1.5	0.0	3.0	0.4	1.1	0.5	2.8	1.3	0.31	1.0
Base High-Efficiency Incandescent Reflector Lamp (100W)	30.1	4.8	7.8	4.7	0.0	0.2	1.3	2.5	24.1	9.8	1.87	7.6
Base High-Efficiency Incandescent A- line Lamp (72W)	21.7	3.5	5.6	3.4	3.5	0.1	0.9	1.8	17.3	7.1	1.34	5.4
Base High-Efficiency Incandescent A- line Lamp (53W)	15.9	2.6	4.1	2.5	2.5	0.1	0.7	1.3	12.8	5.2	0.99	4.0
Base CFL (18W)	1.2	0.9	0.9	4.2	0.9	1.3	0.3	0.3	1.0	1.2	0.24	1.0
Base CFL (23W)	1.6	1.1	1.2	5.3	1.1	1.7	0.4	0.4	1.3	1.6	0.31	1.2
Base HID, 465W	0.0	0.1	0.0	14.4	2.8	5.1	0.0	2.6	0.0	3.5	0.93	2.9
Base CFL Exit Sign	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.01	0.0
Base Outdoor High Pressure Sodium	0.8	1.6	0.7	0.2	0.4	0.5	0.2	0.2	0.7	0.5	0.14	0.3

¹⁶ CEUS is the most comprehensive study available for which we can calculate EUIs right now. The CEUS is based on 2,500 DOE-2 surveys. DNV GL only relied on CEUS for non-weather sensitive measures.

 $^{^{17}}$ The most recent for which data is available.

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
250W Lamp												
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	4.4	5.8	2.7	2.7	1.6	1.5	3.0	2.8	10.7	2.5	1.0	2.1
Base DX Packaged System, EER=10.3, 10 tons	4.4	5.8	2.7	2.7	1.6	1.5	3.0	2.8	10.7	2.5	1.0	2.1
Base Heat Pump (13 SEER, 7.7 HSPF)	4.4	5.8	2.7	2.7	1.6	1.5	3.0	2.8	10.7	2.5	1.0	2.1
Base PTAC, EER=8.3, 1 ton	4.4	5.8	2.7	2.7	1.6	1.5	3.0	2.8	10.7	2.5	1.0	2.1
Base Fan Motor, 5hp, 1800rpm, 87.5%	3.3	2.9	2.1	2.3	1.1	1.0	3.0	1.9	5.5	1.7	0.7	1.4
Base Fan Motor, 15hp, 1800rpm, 91.0%	3.3	2.9	2.1	2.3	1.1	1.0	3.0	1.9	5.5	1.7	0.7	1.4
Base Fan Motor, 40hp, 1800rpm, 93.0%	3.3	2.9	2.1	2.3	1.1	1.0	3.0	1.9	5.5	1.7	0.7	1.4
Base Built-Up Refrigeration System	0.0	0.0	0.0	10.1	2.1	0.0	0.0	0.0	0.0	0.0	0.00	0.0
Base Self-Contained Refrigeration	0.6	6.9	1.0	1.1	0.2	0.5	0.5	0.9	0.6	0.8	0.5	1.0
Base Desktop PC	0.2	0.1	0.0	0.0	0.1	0.1	0.1	0.0	0.1	0.1	0.05	0.1
Base Laptop PC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.0
Base Monitor, CRT	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.02	0.0
Base Monitor, LCD	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.01	0.0
Base Copier	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.02	0.0
Base Multifunction	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.00	0.0
Base Printer	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.01	0.0
Base Data Center/Server Room	149.0	104.3	119.2	119.2	119.2	119.2	119.2	119.2	119.2	119.2	81.97	119.2
Base Water Heating	0.4	1.6	0.2	0.3	0.1	0.2	0.3	1.0	0.1	0.3	0.2	0.4
Base Refrigerated Vending Machines	0.1	0.0	0.0	0.2	0.0	0.0	0.1	0.1	0.0	0.0	0.02	0.0
Base Non-Refrigerated Vending Machines	0.002	0.001	0.000	0.003	0.002	0.001	0.001	0.001	0.002	0.001	0.00	0.001
Base Convection Oven	1.1	1.9	0.6	0.4	0.1	0.6	1.9	0.1	0.0	0.6	0.28	0.3
Base Fryer	0.9	1.9	0.3	0.6	0.2	0.1	3.2	0.2	0.0	0.5	0.50	0.5
Base Steamer	2.5	2.9	1.3	1.0	0.1	0.2	1.6	0.1	0.0	0.8	0.23	0.2

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Heating, Heat Pump (13 SEER 7.7HSPF)	0.7	0.2	0.3	0.3	0.4	0.2	0.7	0.5	0.2	0.4	0.2	0.4
Base Heating, Other Electric	0.7	0.2	0.3	0.3	0.4	0.2	0.7	0.5	0.2	0.4	0.2	0.4
Base Miscellaneous	2.2	2.6	2.2	2.4	0.9	0.6	3.3	1.4	0.6	1.5	1.7	1.7

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Fluorescent Fixture, 4L4'T8	8.01	7.3	5.6	5.9	4.4	3.6	2.8	1.6	5.2	NA	1.2	4.7
Base Fluorescent Fixture, 2L4'T8, 1 EB	4.3	3.5	3.0	4.6	3.8	2.4	1.2	1.0	2.9	NA	1.0	3.6
Base Other Fluorescent Fixture	3.5	0.0	1.5	0.0	5.9	0.5	1.0	0.5	2.4	NA	0.3	1.0
Base High-Efficiency Incandescent Reflector Lamp (100W)	28.9	4.8	7.8	3.9	0.0	0.2	1.1	2.2	20.5	NA	1.5	7.6
Base High-Efficiency Incandescent A- line Lamp (72W)	20.8	3.5	5.6	2.8	6.2	0.2	0.8	1.6	14.7	NA	1.1	5.4
Base High-Efficiency Incandescent A- line Lamp (53W)	15.3	2.6	4.1	2.1	4.6	0.1	0.6	1.2	10.8	NA	0.8	4.0
Base CFL (18W)	1.2	0.9	0.9	3.5	1.5	1.4	0.3	0.3	0.8	NA	0.2	1.0
Base CFL (23W)	1.5	1.1	1.2	4.5	2.0	1.8	0.3	0.4	1.1	NA	0.3	1.2
Base HID, 465W	0.0	0.1	0.0	12.0	5.0	5.6	0.0	2.3	0.0	NA	0.8	2.9
Base CFL Exit Sign	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	NA	0.0	0.0
Base Outdoor High Pressure Sodium 250W Lamp	0.8	1.6	0.7	0.1	0.6	0.6	0.1	0.2	0.6	NA	0.1	0.3
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	4.2	5.8	2.7	2.3	2.9	1.7	2.6	2.5	7.0	NA	0.9	2.1
Base DX Packaged System, EER=10.3, 10 tons	4.2	5.8	2.7	2.3	2.9	1.7	2.6	2.5	7.0	NA	0.9	2.1
Base Heat Pump (13 SEER, 7.7 HSPF)	4.2	5.8	2.7	2.3	2.9	1.7	2.6	2.5	7.0	NA	0.9	2.1
Base PTAC, EER=8.3, 1 ton	4.2	5.8	2.7	2.3	2.9	1.7	2.6	2.5	7.0	NA	0.9	2.1
Base Fan Motor, 5hp, 1800rpm, 87.5%	3.1	2.9	2.1	1.9	2.0	1.1	2.5	1.7	3.6	NA	0.6	1.4
Base Fan Motor, 15hp, 1800rpm, 91.0%	3.1	2.9	2.1	1.9	2.0	1.1	2.5	1.7	3.6	NA	0.6	1.4
Base Fan Motor, 40hp, 1800rpm, 93.0%	3.1	2.9	2.1	1.9	2.0	1.1	2.5	1.7	3.6	NA	0.6	1.4
Base Built-Up Refrigeration System	0.0	0.0	0.0	10.1	3.8	0.0	0.0	0.0	0.0	NA	0.0	0.0
Base Self-Contained Refrigeration	0.6	6.9	1.0	1.1	0.4	0.6	0.4	0.8	0.5	NA	0.4	1.0
Base Desktop PC	0.8	0.2	0.1	0.0	0.1	0.2	0.2	0.1	0.2	NA	0.2	0.1

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Laptop PC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	NA	0.0	0.0
Base Monitor, CRT	0.4	0.1	0.0	0.0	0.0	0.1	0.1	0.1	0.1	NA	0.1	0.0
Base Monitor, LCD	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	NA	0.0	0.0
Base Copier	0.4	0.1	0.1	0.0	0.1	0.0	0.1	0.0	0.2	NA	0.2	0.0
Base Multifunction	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	NA	0.0	0.0
Base Printer	0.4	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	NA	0.0	0.0
Base Data Center/Server Room	178.9	104.3	134.1	74.5	119.2	119.2	89.4	119.2	126.7	NA	68.6	119.2
Base Water Heating	0.4	1.6	0.2	0.3	0.1	0.2	0.2	0.9	0.1	NA	0.2	0.4
Base Refrigerated Vending Machines	0.2	0.1	0.1	0.5	0.0	0.1	0.2	0.1	0.0	NA	0.0	0.0
Base Non-Refrigerated Vending Machines	0.000	0.000	0.000	0.002	0.000	0.004	0.002	0.002	0.000	NA	0.000	0.001
Base Convection Oven	1.0	2.5	0.9	0.7	0.1	0.2	0.6	0.2	1.0	NA	0.0	0.3
Base Fryer	0.8	2.5	0.5	1.0	0.3	0.0	1.1	0.4	0.8	NA	0.0	0.5
Base Steamer	2.3	3.9	1.8	1.7	0.1	0.1	0.6	0.2	2.3	NA	0.0	0.2
Base Heating, Heat Pump (13 SEER 7.7HSPF)	0.7	0.2	0.3	0.3	0.7	0.2	0.6	0.4	0.2	NA	0.2	0.4
Base Heating, Other Electric	0.7	0.2	0.3	0.3	0.7	0.2	0.6	0.4	0.2	NA	0.2	0.4
Base Miscellaneous	2.2	2.6	2.2	2.4	0.9	0.6	3.3	1.4	0.6	NA	1.7	1.7

Table 5-16: Non-Residential End-Use Energy Intensities (kWh per End-Use Square Foot)—Opt-Out/Exempt

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Othe
Base Fluorescent Fixture, 4L4'T8	7.8	NA	5.2	6.1	2.1	2.9	2.2	1.6	5.2	6.2	NA	4.4
Base Fluorescent Fixture, 2L4'T8, 1 EB	4.3	NA	2.9	4.7	1.9	2.0	1.0	1.1	2.9	4.1	NA	3.6
Base Other Fluorescent Fixture	3.5	NA	1.5	0.0	3.0	0.4	0.8	0.5	2.4	2.3	NA	0.9
Base High-Efficiency Incandescent Reflector Lamp (100W)	30.1	NA	7.8	3.9	0.0	0.2	0.9	2.5	20.5	20.0	NA	7.6
Base High-Efficiency Incandescent A-line Lamp (72W)	21.7	NA	5.6	2.8	3.5	0.1	0.6	1.8	14.7	14.4	NA	5.4
Base High-Efficiency Incandescent A-line Lamp (53W)	15.9	NA	4.1	2.1	2.5	0.1	0.5	1.3	10.8	10.6	NA	4.0
Base CFL (18W)	1.2	NA	0.9	3.5	0.9	1.2	0.2	0.3	0.8	1.2	NA	1.0
Base CFL (23W)	1.6	NA	1.2	4.5	1.1	1.5	0.3	0.4	1.1	1.5	NA	1.2
Base HID, 465W	0.0	NA	0.0	12.0	2.8	4.6	0.0	2.6	0.0	1.5	NA	2.9
Base CFL Exit Sign	0.1	NA	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	NA	0.0
Base Outdoor High Pressure Bodium 250W Lamp	0.8	NA	0.7	0.1	0.4	0.5	0.1	0.2	0.6	0.6	NA	0.3
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	4.4	NA	2.7	2.3	1.6	1.4	2.1	2.8	7.0	2.5	NA	2.1
Base DX Packaged System, EER=10.3, 10 tons	4.4	NA	2.7	2.3	1.6	1.4	2.1	2.8	7.0	2.5	NA	2.1
Base Heat Pump (13 SEER, 7.7 HSPF)	4.4	NA	2.7	2.3	1.6	1.4	2.1	2.8	7.0	2.5	NA	2.1
Base PTAC, EER=8.3, 1 ton	4.4	NA	2.7	2.3	1.6	1.4	2.1	2.8	7.0	2.5	NA	2.1
Base Fan Motor, 5hp, 1800rpm, 37.5%	3.3	NA	2.1	1.9	1.1	0.9	2.1	1.9	3.6	1.7	NA	1.4
3ase Fan Motor, 15hp, 1800rpm, 91.0%	3.3	NA	2.1	1.9	1.1	0.9	2.1	1.9	3.6	1.7	NA	1.4
Base Fan Motor, 40hp, 1800rpm, 93.0%	3.3	NA	2.1	1.9	1.1	0.9	2.1	1.9	3.6	1.7	NA	1.4
Base Built-Up Refrigeration System	0.0	NA	0.0	10.1	2.1	0.0	0.0	0.0	0.0	0.0	NA	0.0
Base Self-Contained Refrigeration	0.6	NA	1.0	1.1	0.2	0.5	0.4	0.9	0.5	0.8	NA	1.0

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other
Base Desktop PC	0.2	NA	0.0	0.0	0.1	0.0	0.0	0.0	0.1	0.1	NA	0.0
Base Laptop PC	0.02	NA	0.00	0.00	0.00	0.00	0.00	0.00	0.01	0.01	NA	0.00
Base Monitor, CRT	0.06	NA	0.02	0.02	0.01	0.01	0.00	0.03	0.04	0.05	NA	0.00
Base Monitor, LCD	0.04	NA	0.01	0.01	0.01	0.01	0.01	0.01	0.02	0.03	NA	0.00
Base Copier	0.06	NA	0.02	0.03	0.01	0.01	0.01	0.01	0.01	0.04	NA	0.00
Base Multifunction	0.01	NA	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.01	NA	0.00
Base Printer	0.06	NA	0.01	0.02	0.02	0.01	0.01	0.01	0.01	0.05	NA	0.00
Base Data Center/Server Room	186.3	NA	134.1	74.5	119.2	134.1	74.5	119.2	126.7	178.9	NA	119.2
Base Water Heating	0.4	NA	0.2	0.3	0.1	0.2	0.2	1.0	0.1	0.3	NA	0.4
Base Refrigerated Vending Machines	0.1	NA	0.0	0.2	0.0	0.0	0.0	0.1	0.0	0.0	NA	0.0
Base Non-Refrigerated Vending Machines	0.002	NA	0.000	0.003	0.002	0.001	0.002	0.001	0.0	0.001	NA	0.000
Base Convection Oven	1.1	NA	0.6	0.4	0.1	0.2	0.0	0.1	1.1	0.6	NA	0.1
Base Fryer	0.9	NA	0.3	0.6	0.2	0.0	0.0	0.2	0.9	0.5	NA	0.1
Base Steamer	2.5	NA	1.3	1.0	0.1	0.1	0.0	0.1	2.5	0.8	NA	0.1
Base Heating, Heat Pump (13 SEER 7.7HSPF)	0.7	NA	0.3	0.3	0.4	0.2	0.5	0.5	0.2	0.4	NA	0.4
Base Heating, Other Electric	0.7	NA	0.3	0.3	0.4	0.2	0.5	0.5	0.2	0.4	NA	0.4
Base Miscellaneous	2.2	NA	2.2	2.4	0.9	0.6	3.3	1.4	0.6	1.5	NA	1.7

5.2.2.3 Non-Residential Building Stock and Energy Use

2003 CBECS data from the South Atlantic Census Division was used to estimate the proportion of customers and the average floor space by building type. Energy use was then calculated as the product of the non-Residential floor space, equipment saturation, and the end-use energy intensity. Floor space and energy use by building type and end-use is shown in Table 5-17 through Table 5-19. Figure 5-4 shows the breakout of energy use by building type. For both Virginia and North Carolina non-exempt customers, offices represent the largest share of energy use followed by miscellaneous buildings. ¹⁸ Data centers represent the largest share of energy use among opt-out/exempt customers, followed by offices.

Figure 5-4: Non-Residential Energy Use by Building Type

Figure 5-5 shows the breakout of energy use by end-use. Among the non-exempt customers, indoor lighting, cooling, miscellaneous, and ventilation end uses represent the largest shares of energy use. Among opt-out customers, the high proportion of energy from office equipment reflects the computing load in data centers, with indoor lighting, cooling and ventilation rounding out the top four end-uses.

-

 $^{^{18}}$ Miscellaneous buildings include churches, public safety, services, community centers, recreation, entertainment, etc.

Table 5-17: Non-Residential Sector Floor space (1000 sf) and Energy Use (MWh) by End-Use and Building Type--Virginia

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non-Juris- dictional	Religious Worship	Other	Total
Floor Space (1000 sf)	229,033	95,960	598,719	51,850	368,656	148,316	108,863	189,431	6,064	557,616	186,136	448,255	2,988,901
Base Fluorescent Fixture, 4L4'T8	1,099,69 0	15,289	913,464	162,271	442,150	290,555	160,278	9,190	16,883	1,318,000	73,395	440,052	4,941,217
Base Fluorescent Fixture, 2L4'T8, 1 EB	17,833	86,468	174,452	516	2,912	17,492	18,179	36,117	278	256,454	52,523	314,912	978,135
Base Other Fluorescent Fixture	38,702	0	1,363	0	442	1,353	4,883	701	603	24,313	717	4,300	77,376
Base High- Efficiency Incandescent Reflector Lamp (100W)	499,137	99,529	458,746	60,062	0	1,413	12,095	75,855	7,144	319,549	37,606	353,596	1,924,732
Base High- Efficiency Incandescent A-line Lamp (72W)	179,689	35,830	165,149	21,622	18,249	509	4,354	27,308	2,572	115,038	13,538	127,295	711,152
Base High- Efficiency Incandescent A-line Lamp (53W)	132,271	26,375	121,568	15,916	13,433	375	3,205	20,102	1,893	84,680	9,966	93,703	523,487
Base CFL (18W)	22,831	11,898	94,025	3,013	17,750	19,749	2,841	11,064	1,011	73,989	3,926	46,775	308,872
Base CFL (23W)	29,173	15,203	120,143	3,850	22,680	25,235	3,630	14,137	1,292	94,541	5,017	59,768	394,670
Base HID, 465W	0	318	0	7,202	256,445	38,980	0	28,325	0	170,097	3,330	80,911	585,610
Base CFL Exit Sign	12,200	3,995	10,776	282	1,513	2,106	4,470	6,350	258	14,025	1,918	8,915	66,810

Base Outdoor High Pressure Sodium 250W Lamp	83,484	97,521	172,635	2,194	95,315	63,666	11,927	41,209	3,797	203,452	23,915	84,523	883,637
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	129,056	80,383	22,981	3,806	0	88,503	63,204	142,370	42,651	606,522	28,518	76,915	1,284,910
Base DX Packaged System, EER=10.3, 10 tons	585,580	425,970	809,759	118,138	215,359	212,274	211,520	363,654	24,324	747,270	91,863	296,462	4,102,173
Base Heat Pump (13 SEER, 7.7 HSPF)	399,790	133,509	300,738	10,544	116,595	167,019	134,760	281,796	3,116	324,677	74,753	281,558	2,228,856
Base PTAC, EER=8.3, 1 ton	64,061	16,109	53,042	4,891	5,525	152,113	30,159	59,170	0	503,030	74,199	177,382	1,139,681
Base Fan Motor, 5hp, 1800rpm, 87.5%	316,908	142,557	548,684	114,870	121,413	50,063	60,633	237,937	6,243	463,196	69,127	332,945	2,464,575
Base Fan Motor, 15hp, 1800rpm, 91.0%	54,907	0	19,121	0	0	134,011	210,748	0	21,699	241,458	55,105	265,412	1,002,460
Base Fan Motor, 40hp, 1800rpm, 93.0%	34,615	0	19,121	113,575	40,270	55,860	223,932	41,135	23,056	185,818	43,728	210,615	991,726
Base Built-Up Refrigeration System	0	0	0	477,944	290,562	0	0	0	0	0	0	0	768,506
Base Self- Contained Refrigeration	92,975	604,643	441,780	54,463	77,652	62,946	41,479	134,300	3,453	374,598	93,384	290,806	2,272,480
Base Desktop PC	38,014	5,393	20,390	2,168	18,150	9,877	9,405	8,626	456	64,942	9,042	25,153	211,615

Base Laptop PC	3,459	221	842	66	1,288	1,102	487	414	33	5,744	621	1,437	15,715
Base Monitor, CRT	8,062	2,883	4,646	411	3,743	4,007	2,592	4,063	247	13,976	1,585	5,808	52,023
Base Monitor, LCD	7,214	1,204	2,903	646	2,989	2,069	1,663	1,799	119	15,007	1,883	5,276	42,773
Base Copier	13,205	2,244	10,066	521	4,610	2,638	2,622	2,508	102	18,100	3,667	9,315	69,598
Base Multifunction	2,242	855	1,540	208	1,035	325	423	387	13	2,597	479	1,386	11,490
Base Printer	13,077	974	4,405	174	4,626	2,756	2,128	1,094	40	21,329	1,480	7,253	59,337
Base Data Center/Server Room	68,369	5,371	15,850	422	54,061	64,306	37,394	38,146	723,051	136,349	7,637	54,882	1,205,837
Base Water Heating	78,368	58,556	84,251	12,359	20,545	22,579	15,206	59,191	364	72,919	25,612	87,612	537,563
Base Refrigerated Vending Machines	14,276	3,911	21,011	10,861	14,185	5,799	5,837	14,236	237	23,846	4,262	15,985	134,446
Base Non- Refrigerated Vending Machines	370	59	102	19	592	90	115	81	10	423	2	167	2,030
Base Convection Oven	4,199	26,995	13,370	12,228	4,684	6,337	9,210	2,818	0	68,315	25,588	5,636	179,380
Base Fryer	2,657	33,954	2,444	15,903	9,725	1,124	8,880	7,093	0	34,195	1,323	10,132	127,429
Base Steamer	5,516	43,153	9,592	22,211	4,087	308	7,972	1,171	0	68,914	1,170	2,508	166,602
Base Heating, Heat Pump (13 SEER 7.7HSPF)	58,086	1,747	13,260	535	2,031	4,080	17,011	23,533	0	14,765	2,268	42,979	180,295
Base Heating, Other Electric	58,677	4,827	48,442	13,042	16,000	0	23,941	18,872	399	33,064	18,515	39,917	275,696
Base Miscellaneous	503,873	249,497	1,317,18 3	124,439	331,791	88,990	359,248	265,203	3,638	847,698	316,430	762,034	5,170,025
Total	4,672,56	2,237,4	6,017,84	1,391,374	2,232,4	1,600,610	1,706,43	1,979,9	888,979	7,562,891	1,178,095	4,624,32	36,092,921

Table 5-18: Non-Residential Sector Floor space (1000 sf) and Energy Use (MWh) by End-Use and Building Type—North Carolina

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other	Total
Floor Space (1000 sf)	9,580	2,541	15,854	1,373	9,147	13,318	2,883	5,016	135	NA	4,929	12,480	77,872
Base Fluorescent Fixture, 4L4'T8	61,677	766	44,644	4,976	34,899	5,120	4,276	152	320	NA	800	5,338	162,970
Base Fluorescent Fixture, 2L4'T8, 1 EB	961	4,484	8,210	16	211	314	474	557	5	NA	590	3,934	19,758
Base Other Fluorescent Fixture	2,086	0	64	0	32	24	127	11	11	NA	8	54	2,418
Base High-Efficiency Incandescent Reflector Lamp (100W)	18,594	1,646	3,429	566	0	585	330	1,503	136	NA	1,907	32,853	61,548
Base High-Efficiency Incandescent A-line Lamp (72W)	6,694	593	1,235	204	1,844	210	119	541	49	NA	686	11,827	24,002
Base High-Efficiency Incandescent A-line Lamp (53W)	4,927	436	909	150	1,358	155	87	398	36	NA	505	8,706	17,668
Base CFL (18W)	235	151	1,240	634	184	4,532	87	409	19	NA	330	737	8,558
Base CFL (23W)	300	193	1,584	810	235	5,791	111	523	25	NA	421	942	10,935
Base HID, 465W	0	2	0	179	0	646	0	101	0	NA	1,679	3,355	5,961
Base CFL Exit Sign	490	106	285	6	68	208	101	151	5	NA	42	248	1,710
Base Outdoor High Pressure Sodium 250W Lamp	1,240	1,733	1,287	175	155	6,862	331	997	72	NA	530	1,454	14,836
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	713	397	0	0	0	15,051	0	0	623	NA	0	0	16,784
Base DX Packaged System, EER=10.3, 10 tons	15,638	6,541	22,945	1,414	2,610	23,488	2,500	9,799	355	NA	3,794	3,071	92,155
Base Heat Pump (13 SEER, 7.7 HSPF)	17,641	3,245	12,284	966	0	16,838	4,994	9,034	45	NA	3,155	16,366	84,569
Base PTAC, EER=8.3, 1 ton	1,968	1,208	1,050	158	1,249	23,364	429	8,212	0	NA	54	4,042	41,735
Base Fan Motor, 5hp, 1800rpm, 87.5%	12,726	3,775	14,529	2,535	5,422	4,945	1,376	5,671	91	NA	1,531	9,270	61,871


Base Fan Motor, 15hp, 1800rpm, 91.0%	2,205	0	506	0	0	13,237	4,783	0	317	NA	1,220	7,389	29,658
Base Fan Motor, 40hp, 1800rpm, 93.0%	1,390	0	506	2,506	1,798	5,517	5,083	980	337	NA	968	5,864	24,951
Base Built-Up Refrigeration System	0	0	0	11,697	913	0	0	0	0	NA	0	0	12,610
Base Self-Contained Refrigeration	4,646	16,239	5,571	1,164	1,353	6,868	1,228	3,252	63	NA	2,154	9,818	52,355
Base Desktop PC	7,712	228	779	61	14	2,074	600	399	24	NA	915	685	13,492
Base Laptop PC	188	13	10	1	2	285	17	7	3	NA	18	24	568
Base Monitor, CRT	2,762	51	241	21	30	1,209	175	227	14	NA	242	227	5,200
Base Monitor, LCD	1,138	61	75	11	3	297	106	102	5	NA	45	94	1,936
Base Copier	3,117	118	473	47	13	578	302	164	22	NA	965	219	6,018
Base Multifunction	429	40	71	8	2	66	57	22	3	NA	20	19	737
Base Printer	4,055	34	79	7	30	963	65	132	0	NA	33	152	5,551
Base Data Center/Server Room	1,271	50	76	21	419	6,962	3,024	2,790	17,158	NA	80	2,042	33,894
Base Water Heating	2,977	2,812	2,952	285	389	2,023	548	2,009	15	NA	353	4,680	19,043
Base Refrigerated Vending Machines	1,828	186	1,809	671	0	1,400	523	590	0	NA	0	571	7,577
Base Non-Refrigerated Vending Machines	0	0	0	0	0	46	1	3	0	NA	0	6	57
Base Convection Oven	0	1,001	6	156	0	2,096	81	143	0	NA	0	9	3,492
Base Fryer	0	781	2	33	0	58	119	170	0	NA	0	0	1,164
Base Steamer	0	710	5	64	0	459	70	83	0	NA	0	0	1,392
Base Heating, Heat Pump (13 SEER 7.7HSPF)	2,682	91	1,369	111	0	17	1,253	1,295	0	NA	125	3,751	10,694
Base Heating, Other Electric	2,515	243	366	46	1,316	1,559	0	628	12	NA	0	113	6,798
Base Miscellaneous	21,076	6,607	34,880	3,295	8,232	7,991	9,513	7,023	81	NA	8,379	21,216	128,293
Total	205,881	54,541	163,472	32,995	62,784	161,841	42,891	58,080	19,847	NA	31,549	159,076	992,958


Table 5-19: Non-Residential Sector Floor space (1000 sf) and Energy Use (MWh) by End-Use and Building Type—Opt-Out/Exempt

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other	Total
Floor Space (1000 sf)	32,010	NA	11,835	144	2,362	2,707	14,418	536	7,426	2,670	NA	24,846	98,954
Base Fluorescent Fixture, 4L4'T8	153,696	NA	18,056	375	2,832	3,525	17,049	26	17,573	7,986	NA	9,139	230,257
Base Fluorescent Fixture, 2L4'T8, 1 EB	2,492	NA	3,448	1	19	218	1,941	102	289	1,481	NA	6,997	16,989
Base Other Fluorescent Fixture	5,409	NA	27	0	3	17	521	2	627	205	NA	96	6,906
Base High-Efficiency Incandescent Reflector Lamp (100W)	69,761	NA	9,068	139	0	62	1,443	215	7,435	3,128	NA	15,910	107,160
Base High-Efficiency Incandescent A-line Lamp (72W)	25,114	NA	3,264	50	117	22	519	77	2,677	1,126	NA	5,728	38,694
Base High-Efficiency Incandescent A-line Lamp (53W)	18,487	NA	2,403	37	86	16	382	57	1,970	829	NA	4,216	28,483
Base CFL (18W)	3,191	NA	1,859	7	114	235	84	31	1,052	329	NA	1,805	8,707
Base CFL (23W)	4,077	NA	2,375	9	145	300	108	40	1,344	421	NA	2,306	11,125
Base HID, 465W	0	NA	0	17	1,643	1,243	0	80	0	346	NA	4,167	7,495
Base CFL Exit Sign	1,705	NA	213	1	10	35	423	18	269	97	NA	494	3,264
Base Outdoor High Pressure Sodium 250W Lamp	11,668	NA	3,412	5	611	1,232	1,764	117	3,953	1,167	NA	6,934	30,862
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	18,037	NA	454	9	0	3,412	30,927	403	34,149	2,904	NA	2,163	92,459
Base DX Packaged System, EER=10.3, 10 tons	81,842	NA	16,006	273	1,380	1,739	30,927	1,029	19,475	3,578	NA	50,820	207,070
Base Heat Pump (13 SEER, 7.7 HSPF)	55,876	NA	5,945	24	747	1,739	17,325	798	2,495	1,555	NA	6,267	92,769
Base PTAC, EER=8.3, 1 ton	8,953	NA	1,048	11	35	1,739	17,325	167	0	2,409	NA	6,267	37,955


Base Fan Motor, 5hp, 1800rpm, 87.5%	44,292	NA	10,846	265	778	822	5,736	673	4,998	2,099	NA	18,455	88,965
Base Fan Motor, 15hp, 1800rpm, 91.0%	7,674	NA	378	0	0	2,201	19,937	0	17,374	2,170	NA	14,712	64,446
Base Fan Motor, 40hp, 1800rpm, 93.0%	4,838	NA	378	262	258	918	21,185	116	18,460	1,286	NA	11,674	59,376
Base Built-Up Refrigeration System	0	NA	0	1,325	1,861	0	0	0	0	0	NA	0	3,186
Base Self-Contained Refrigeration	12,995	NA	8,733	151	497	1,242	2,867	380	3,594	1,794	NA	13,056	45,309
Base Desktop PC	5,313	NA	403	5	116	31	420	24	474	339	NA	452	7,578
Base Laptop PC	483	NA	17	0	8	7	45	1	34	30	NA	8	635
Base Monitor, CRT	1,127	NA	92	1	24	37	0	11	257	73	NA	63	1,685
Base Monitor, LCD	1,008	NA	57	1	19	14	118	5	124	78	NA	61	1,487
Base Copier	1,846	NA	199	1	30	35	209	7	106	95	NA	106	2,632
Base Multifunction	313	NA	30	0	7	5	43	1	13	14	NA	16	443
Base Printer	1,828	NA	87	0	30	25	166	3	41	111	NA	42	2,334
Base Data Center/Server Room	11,944	NA	352	1	346	1,465	6,641	108	940,750	979	NA	5,046	967,633
Base Water Heating	10,953	NA	1,665	29	132	512	0	168	445	349	NA	730	14,982
Base Refrigerated Vending Machines	1,995	NA	415	30	91	114	706	40	290	114	NA	111	3,908
Base Non-Refrigerated Vending Machines	52	NA	2	0	4	1	13	0	13	2	NA	1	88
Base Convection Oven	587	NA	264	34	30	325	369	8	5	327	NA	528	2,478
Base Fryer	371	NA	48	44	62	39	629	20	4	164	NA	1,098	2,480
Base Steamer	771	NA	190	62	26	250	444	3	12	330	NA	65	2,152
Base Heating, Heat Pump (13 SEER 7.7HSPF)	8,118	NA	295	1	13	0	0	67	0	71	NA	0	8,565
Base Heating, Other Electric	8,201	NA	1,077	30	102	232	0	53	550	158	NA	5,217	15,621
Base Miscellaneous	70,423	NA	26,037	345	2,125	1,624	47,580	751	4,455	4,059	NA	42,239	199,638


Virginia





North Carolina





Opt-Out/Exempt







Figure 5-4: Non-Residential Energy Use by Building Type


Virginia






North Carolina





Opt-Out/Exempt






Figure 5-5: Non-Residential Energy Use by End-Use

5.2.2.4 Non-Residential Peak Demand

Similar to the residential sector, Dominion's annual hourly 8,760 load data was combined with non-residential end-use load shapes from DNV GL's end-use databases to allocate annual energy usage to time-of-use (TOU) periods. Peak period usage, developed on a sector-specific and end-use basis, was calibrated to equal the Dominion summer peak. Non-residential peak demand estimates by segment and end use are summarized in Table 5-20, Table 5-21, and Table 5-22, for Virginia, North Carolina and opt-out/exempt customers, respectively.

Table 5-20: Non-Residential Peak Demand (MW) by End-Use and Building Type--Virginia

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other	Total
Base Fluorescent Fixture, 4L4'T8	186.1	2.7	150.3	22.5	71.4	35.7	22.2	1.2	2.7	213.1	11.3	67.9	787.1
Base Fluorescent Fixture, 2L4'T8, 1 EB	3.0	15.5	28.7	0.1	0.5	2.1	2.5	4.6	0.0	41.5	8.1	48.6	155.3
Base Other Fluorescent Fixture	6.5	0.0	0.2	0.0	0.1	0.2	0.7	0.1	0.1	3.9	0.1	0.7	12.6
Base High-Efficiency Incandescent Reflector Lamp (100W)	84.5	17.9	75.5	8.3	0.0	0.2	1.7	9.8	1.1	51.7	5.8	54.6	310.9
Base High-Efficiency Incandescent A-line Lamp (72W)	30.4	6.4	27.2	3.0	2.9	0.1	0.6	3.5	0.4	18.6	2.1	19.6	114.9
Base High-Efficiency Incandescent A-line Lamp (53W)	22.4	4.7	20.0	2.2	2.2	0.0	0.4	2.6	0.3	13.7	1.5	14.5	84.6
Base CFL (18W)	3.9	2.1	15.5	0.4	2.9	2.4	0.4	1.4	0.2	12.0	0.6	7.2	48.9
Base CFL (23W)	4.9	2.7	19.8	0.5	3.7	3.1	0.5	1.8	0.2	15.3	0.8	9.2	62.5
Base HID, 465W	0.0	0.1	0.0	1.0	41.4	4.8	0.0	3.6	0.0	27.5	0.5	12.5	91.4
Base CFL Exit Sign	1.6	0.7	1.8	0.0	0.3	0.2	0.6	0.9	0.0	2.0	0.3	1.3	9.7
Base Outdoor High Pressure Sodium 250W Lamp	1.0	5.9	10.3	0.0	1.2	2.3	0.1	0.3	0.0	7.7	1.7	5.9	36.5
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	82.1	45.7	17.3	2.3	0.0	41.3	31.6	77.9	9.5	406.4	20.0	54.1	788.3
Base DX Packaged System, EER=10.3, 10 tons	372.4	242.4	608.4	70.1	186.2	99.1	105.7	199.1	5.4	500.7	64.6	208.4	2,662.6
Base Heat Pump (13 SEER, 7.7 HSPF)	254.3	76.0	225.9	6.3	100.8	78.0	67.3	154.3	0.7	217.6	52.6	197.9	1,431.6
Base PTAC, EER=8.3, 1 ton	40.7	9.2	39.9	2.9	4.8	71.0	15.1	32.4	0.0	337.1	52.2	124.7	729.8
Base Fan Motor, 5hp, 1800rpm, 87.5%	87.0	33.4	139.7	22.4	34.1	8.9	11.2	45.7	1.4	123.4	17.9	86.0	611.1
Base Fan Motor, 15hp, 1800rpm, 91.0%	15.1	0.0	4.9	0.0	0.0	23.8	38.9	0.0	4.9	64.3	14.2	68.6	234.6
Base Fan Motor, 40hp, 1800rpm, 93.0%	9.5	0.0	4.9	22.1	11.3	9.9	41.3	7.9	5.2	49.5	11.3	54.4	227.3
Base Built-Up Refrigeration System	0.0	0.0	0.0	69.9	50.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	120.0
Base Self-Contained Refrigeration	11.9	82.3	61.0	8.0	13.4	7.9	5.5	17.8	0.6	49.5	12.8	39.8	310.5
Base Desktop PC	4.8	1.0	3.3	0.4	2.8	0.8	1.2	1.2	0.1	8.6	1.2	3.5	28.7

Table 5-20: Non-Residential Peak Demand (MW) by End-Use and Building Type--Virginia

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other	Total
Base Laptop PC	0.4	0.0	0.1	0.0	0.2	0.1	0.1	0.1	0.0	0.8	0.1	0.2	2.1
Base Monitor, CRT	1.0	0.5	0.8	0.1	0.6	0.3	0.3	0.5	0.0	1.8	0.2	0.8	7.0
Base Monitor, LCD	0.9	0.2	0.5	0.1	0.5	0.2	0.2	0.2	0.0	2.0	0.3	0.7	5.8
Base Copier	1.7	0.4	1.6	0.1	0.7	0.2	0.3	0.3	0.0	2.4	0.5	1.3	9.6
Base Multifunction	0.3	0.2	0.2	0.0	0.2	0.0	0.1	0.1	0.0	0.3	0.1	0.2	1.6
Base Printer	1.6	0.2	0.7	0.0	0.7	0.2	0.3	0.1	0.0	2.8	0.2	1.0	7.9
Base Data Center/Server Room	8.6	1.0	2.6	0.1	8.2	5.0	4.8	5.2	114.4	18.0	1.1	7.6	176.4
Base Water Heating	9.6	9.0	12.3	1.8	2.9	1.6	1.8	7.3	0.1	9.4	3.4	11.8	70.9
Base Refrigerated Vending Machines	1.9	0.7	3.4	1.6	2.4	0.5	0.7	2.1	0.0	3.4	0.6	2.4	19.8
Base Non-Refrigerated Vending Machines	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.3
Base Convection Oven	0.6	5.0	2.2	1.5	0.7	0.4	1.6	0.5	0.0	9.8	3.8	0.8	27.0
Base Fryer	0.4	6.3	0.4	2.0	1.5	0.1	1.5	1.3	0.0	4.9	0.2	1.5	20.1
Base Steamer	0.7	8.0	1.6	2.8	0.6	0.0	1.4	0.2	0.0	9.9	0.2	0.4	25.9
Base Heating, Heat Pump (13 SEER 7.7HSPF)	3.9	0.0	0.1	0.0	0.0	0.1	0.9	0.6	0.0	0.6	0.1	1.0	7.2
Base Heating, Other Electric	3.9	0.0	0.3	0.0	0.0	0.0	1.2	0.5	0.0	1.4	0.4	0.9	8.8
Base Miscellaneous	66.7	44.5	214.2	18.0	56.9	7.1	45.5	39.3	0.6	120.1	47.8	115.2	775.6
Total	1,324	625	1,695	271	606	407	408	625	148	2,352	339	1,225	10,025

Table 5-21: Non-Residential Peak Demand (MW) by End-Use and Building Type—North Carolina

	2												
	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other	Total
Base Fluorescent Fixture, 4L4'T8	10.4	0.1	7.3	0.7	5.6	0.6	0.6	0.0	0.1	0.0	0.1	0.8	26.5
Base Fluorescent Fixture, 2L4'T8, 1 EB	0.2	0.8	1.4	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.1	0.6	3.2
Base Other Fluorescent Fixture	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
Base High-Efficiency Incandescent Reflector Lamp (100W)	3.1	0.3	0.6	0.1	0.0	0.1	0.0	0.2	0.0	0.0	0.3	5.1	9.8
Base High-Efficiency Incandescent A-line Lamp (72W)	1.1	0.1	0.2	0.0	0.3	0.0	0.0	0.1	0.0	0.0	0.1	1.8	3.8
Base High-Efficiency Incandescent A-line Lamp (53W)	0.8	0.1	0.1	0.0	0.2	0.0	0.0	0.1	0.0	0.0	0.1	1.3	2.8
Base CFL (18W)	0.0	0.0	0.2	0.1	0.0	0.6	0.0	0.1	0.0	0.0	0.1	0.1	1.2
Base CFL (23W)	0.1	0.0	0.3	0.1	0.0	0.7	0.0	0.1	0.0	0.0	0.1	0.1	1.5
Base HID, 465W	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.3	0.5	0.9
Base CFL Exit Sign	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
Base Outdoor High Pressure Sodium 250W Lamp	0.0	0.1	0.1	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.6
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	0.5	0.2	0.0	0.0	0.0	7.0	0.0	0.0	0.1	0.0	0.0	0.0	7.8
Base DX Packaged System, EER=10.3, 10 tons	9.9	3.7	17.2	0.8	2.3	11.0	1.2	5.4	0.1	0.0	2.7	2.2	56.5
Base Heat Pump (13 SEER, 7.7 HSPF)	11.2	1.8	9.2	0.6	0.0	7.9	2.5	4.9	0.0	0.0	2.2	11.5	51.9
Base PTAC, EER=8.3, 1 ton	1.3	0.7	0.8	0.1	1.1	10.9	0.2	4.5	0.0	0.0	0.0	2.8	22.4
Base Fan Motor, 5hp, 1800rpm, 87.5%	3.5	0.9	3.7	0.5	1.5	0.9	0.3	1.1	0.0	0.0	0.4	2.4	15.1
Base Fan Motor, 15hp, 1800rpm, 91.0%	0.6	0.0	0.1	0.0	0.0	2.3	0.9	0.0	0.1	0.0	0.3	1.9	6.3
Base Fan Motor, 40hp, 1800rpm, 93.0%	0.4	0.0	0.1	0.5	0.5	1.0	0.9	0.2	0.1	0.0	0.3	1.5	5.4
Base Built-Up Refrigeration System	0.0	0.0	0.0	1.7	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	1.9
Base Self-Contained Refrigeration	0.6	2.2	0.8	0.2	0.2	0.9	0.2	0.4	0.0	0.0	0.3	1.3	7.1
Base Desktop PC	1.0	0.0	0.1	0.0	0.0	0.2	0.1	0.1	0.0	0.0	0.1	0.1	1.7

Table 5-21: Non-Residential Peak Demand (MW) by End-Use and Building Type—North Carolina

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other	Total
Base Laptop PC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
Base Monitor, CRT	0.3	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.6
Base Monitor, LCD	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
Base Copier	0.4	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.8
Base Multifunction	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
Base Printer	0.5	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.7
Base Data Center/Server Room	0.2	0.0	0.0	0.0	0.1	0.5	0.4	0.4	2.7	0.0	0.0	0.3	4.6
Base Water Heating	0.4	0.4	0.4	0.0	0.1	0.1	0.1	0.2	0.0	0.0	0.0	0.6	2.5
Base Refrigerated Vending Machines	0.2	0.0	0.3	0.1	0.0	0.1	0.1	0.1	0.0	0.0	0.0	0.1	1.0
Base Non-Refrigerated Vending Machines	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Base Convection Oven	0.0	0.2	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.4
Base Fryer	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
Base Steamer	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
Base Heating, Heat Pump (13 SEER 7.7HSPF)	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.4
Base Heating, Other Electric	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
Base Miscellaneous	2.8	1.2	5.7	0.5	1.4	0.6	1.2	1.0	0.0	0.0	1.3	3.2	18.9
Total	50.5	13.4	48.9	6.1	13.6	46.3	9.0	19.1	3.2	0.0	8.9	38.7	257.8

Table 5-22: Non-Residential Peak Demand (MW) by End-Use and Building Type—Opt-Out/Exempt

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other	Total
Base Fluorescent Fixture, 4L4'T8	26.0	0.0	3.0	0.1	0.5	0.4	2.4	0.0	2.8	1.3	0.0	1.4	37.8
Base Fluorescent Fixture, 2L4'T8, 1 EB	0.4	0.0	0.6	0.0	0.0	0.0	0.3	0.0	0.0	0.2	0.0	1.1	2.7
Base Other Fluorescent Fixture	0.9	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.0	1.1
Base High-Efficiency Incandescent Reflector Lamp (100W)	11.8	0.0	1.5	0.0	0.0	0.0	0.2	0.0	1.2	0.5	0.0	2.5	17.7
Base High-Efficiency Incandescent A-line Lamp (72W)	4.2	0.0	0.5	0.0	0.0	0.0	0.1	0.0	0.4	0.2	0.0	0.9	6.4
Base High-Efficiency Incandescent A-line Lamp (53W)	3.1	0.0	0.4	0.0	0.0	0.0	0.1	0.0	0.3	0.1	0.0	0.7	4.7
Base CFL (18W)	0.5	0.0	0.3	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.3	1.4
Base CFL (23W)	0.7	0.0	0.4	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.4	1.8
Base HID, 465W	0.0	0.0	0.0	0.0	0.3	0.2	0.0	0.0	0.0	0.1	0.0	0.6	1.1
Base CFL Exit Sign	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.5
Base Outdoor High Pressure Sodium 250W Lamp	0.1	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5	1.0
Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	11.5	0.0	0.3	0.0	0.0	1.6	15.5	0.2	7.6	1.9	0.0	1.5	40.2
Base DX Packaged System, EER=10.3, 10 tons	52.1	0.0	12.0	0.2	1.2	0.8	15.5	0.6	4.4	2.4	0.0	35.7	124.7
Base Heat Pump (13 SEER, 7.7 HSPF)	35.5	0.0	4.5	0.0	0.6	0.8	8.7	0.4	0.6	1.0	0.0	4.4	56.6
Base PTAC, EER=8.3, 1 ton	5.7	0.0	0.8	0.0	0.0	0.8	8.7	0.1	0.0	1.6	0.0	4.4	22.1
Base Fan Motor, 5hp, 1800rpm, 87.5%	12.2	0.0	2.8	0.1	0.2	0.1	1.1	0.1	1.1	0.6	0.0	4.8	23.0
Base Fan Motor, 15hp, 1800rpm, 91.0%	2.1	0.0	0.1	0.0	0.0	0.4	3.7	0.0	3.9	0.6	0.0	3.8	14.5
Base Fan Motor, 40hp, 1800rpm, 93.0%	1.3	0.0	0.1	0.1	0.1	0.2	3.9	0.0	4.1	0.3	0.0	3.0	13.1
Base Built-Up Refrigeration System	0.0	0.0	0.0	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.5
Base Self-Contained Refrigeration	1.7	0.0	1.2	0.0	0.1	0.2	0.4	0.1	0.6	0.2	0.0	1.8	6.2
Base Desktop PC	0.7	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.1	0.0	0.0	0.1	1.0

Table 5-22: Non-Residential Peak Demand (MW) by End-Use and Building Type—Opt-Out/Exempt

	Office	Restau- rant	Retail	Grocery	Ware- house	Education	Health	Lodging	Data Center	Non- Juris- dictional	Religious Worship	Other	Total
Base Laptop PC	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
Base Monitor, CRT	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
Base Monitor, LCD	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2
Base Copier	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
Base Multifunction	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1
Base Printer	0.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.3
Base Data Center/Server Room	1.5	0.0	0.1	0.0	0.1	0.1	0.9	0.0	148.8	0.1	0.0	0.7	152.2
Base Water Heating	1.3	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.1	1.9
Base Refrigerated Vending Machines	0.3	0.0	0.1	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.5
Base Non-Refrigerated Vending Machines	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Base Convection Oven	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.1	0.3
Base Fryer	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.4
Base Steamer	0.1	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.3
Base Heating, Heat Pump (13 SEER 7.7HSPF)	0.5	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.6
Base Heating, Other Electric	0.6	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.7
Base Miscellaneous	9.3	0.0	4.2	0.0	0.4	0.1	6.0	0.1	0.7	0.6	0.0	6.4	27.9
Total	185.4	0.0	33.5	0.7	3.9	6.0	67.7	1.8	177.4	12.3	0.0	75.4	564.1

5.2.2.5 Non-Residential Comparisons to CBECS

The table below compares the results of the non-residential baseline analysis to EIA's Commercial Buildings Energy Consumption Survey (CBECS).

The most recent CBECS for which data is available was conducted in 2003, and therefore does not reflect efficiency improvements, particularly in lighting, that have occurred over the last decade. The geographical resolution is also not as great for CBECS as for RECS. We therefore compare the Dominion baseline results as a whole to the South Atlantic Census division (the finest granularity available), which includes Delaware, Maryland, West Virginia, Virginia, North Carolina, South Carolina, Georgia, and Florida.

Figure 5-6 and Figure 5-7, below, compare the distribution of energy use by building type and end use, respectively. As a result of the age of the CBECS data, geographical differences, and differences in the way buildings are classified, it is difficult to assess differences between the two analyses and attribute them to Dominion-specific patterns of non-residential activity or energy use. For example, we classified non-jurisdictional buildings as "other" for this comparison, but non-jurisdictional encompasses a large share of Virginia's education buildings. However, the charts show that the breakouts found in the baseline analysis are broadly similar to CBECS.




Figure 5-6: Comparison of Non-Residential Baseline Energy Use by Building Type to CBECS




Figure 5-7: Comparison of Non-Residential Baseline Energy Use by End-Use to CBECS

5.3 **Technical and Economic Potential Results**

This section contains a summary of findings from the analysis of technical and economic savings potential of electric energy efficiency efforts in Dominion's service territory. Technical potential is defined as the complete penetration of all measures analyzed in applications where they were deemed technically feasible from an engineering perspective. Economic potential is defined as the technical potential of those energy conservation measures that are cost-effective when compared to supply-side alternatives. All measures with a total resource cost (TRC) greater than one are considered to have economic potential.

In our bottom-up modeling approach, we first estimate technical potential for energy savings by integrating key measure and market segment parameters using the following equation:

Equation 1: Technical Potential of an Efficient Measure

Technical	Total					
Potential of	sg. ft. or	Base Case		Not		
Potential of	sq. it. or	Equipment	Applicability	Complete	Feasibility	Savings
Efficient	= # of	x	× ·	×	×	×
Measure	Dwellings	EUI or UEC	Factor	Factor	Factor	Factor

Where:

- Square feet is the total floor space for all buildings in the market segment. For the residential analysis, the number of dwelling units is substituted for square feet.
- Base case equipment Energy Use Intensity (EUI) is the energy used per square foot by each base case technology in each market segment. This is the consumption of the energy-using equipment that the efficient technology replaces or affects. For example, if the efficient measure were a CFL, the base EUI would be the annual kWh per square foot of an equivalent incandescent lamp. For the residential analysis, unit energy consumption (UECs), energy used per dwelling, are substituted for EUIs and were developed as part of the Conditional Demand Analysis.
- Applicability factor is the fraction of the floor space (or dwelling units) that is applicable for the efficient technology in a given market segment; for the example above, the percentage of floor space lit by incandescent bulbs. This input was developed through results of the 2013 residential and commercial saturation surveys and the Conditional Demand Analysis and Baseline Analysis.
- Not complete factor is the fraction of applicable floor space (or dwelling units) that has not yet been converted to the efficient measure; that is, one minus the fraction of floor space that already has the EE measure installed. DNV GL relied on the results of Dominion's saturation surveys to estimate this value when possible and utilized other recent saturation surveys and internal databases for other measures not included in the saturation surveys.
- Feasibility factor is the fraction of the applicable floor space (or dwelling units) that is technically feasible for conversion to the efficient technology from an engineering perspective. DNV GL engineers familiar with Dominion's service territory reviewed these values to ensure they were consistent with Dominion's building stock.

Savings factor is the reduction in energy consumption resulting from application of the
efficient technology. DNV GL estimated energy savings through the use of sources including
the STEP manual, LBNL Home Energy Savers Model, and other engineering calculations.

Technical potential for peak demand reduction is calculated analogously.

Economic potential is then assessed by first developing a supply-curve analysis. This analysis eliminates double counting of measure savings. On a market segment and end-use/technology basis, measures are stacked in order of cost-effectiveness, and the energy consumption of the system being affected by the efficiency measures reduces as each measure is applied. As a result, the savings attributable to each subsequent measure decrease if the measures are interactive. After eliminating double counting of savings, the benefits and costs associated with a given measure and market segment are compared using the Total Resource Cost (TRC) test or other cost relevant cost effectiveness test. Measures with a TRC ratio greater than 1.0 will be passed on to our achievable potential analysis.

5.3.1 Avoided Cost Scenario Results

DNV GL analyzed technical and economic potential under three different avoided costs scenarios. The three cost scenarios used avoided costs and rates as provided to DNV GL by Dominion in November 2013. The difference between the high and low avoided cost scenarios and the expected avoided costs varied by year, but on average the costs were six percent lower and seven percent higher than the expected avoided costs. When compared to the economic energy savings potential from the expected avoided cost scenario, the high avoided cost scenario increased economic energy savings potential by about one percent (0.2 percentage points higher), and the low avoided cost scenario decreased economic energy savings potential by about three percent (0.7 percentage points lower).

It is not unusual for a large change in avoided costs to cause a smaller change in energy savings potential. A measure will only drop in or out of economic potential if its TRC ratio increases from less than one to greater than one, or vice versa. Thus, measures with high or low cost effectiveness are typically not affected. Only measures with TRCs near one will shift. The magnitude of the effect of a change to avoided costs depends on how many measures are near the margin and how much savings potential they represent. In previous studies where we have looked at avoided cost scenarios, we have often found that the effect on economic potential is relatively small across scenarios. In a recent study for Xcel Minnesota, ¹⁹ avoided cost changes of plus 57 percent and minus five percent led to economic savings that were plus 10 percent and minus four percent compared to base avoided costs.

We reran the Dominion analysis using avoided costs that were 50 percent higher than the expected avoided costs in order to see how that would impact the potential. Using these avoided costs, economic energy savings potential and demand savings were 18 percent higher than the expected avoided cost scenario.

 $^{^{19} \ \}text{http://www.xcelenergy.com/staticfiles/xe/Regulatory/Regulatory\%20PDFs/MN-DSM/MN-DSM-Market-Potential-Assessment-Vol-1.pdf}$

Table 5-23 summarizes both the findings and the differences between the avoided cost scenarios. Overall, there was little variation in energy or demand savings in the three analyses.

Table 5-23: Summary of Three Avoided Cost Scenarios

	Base (2023)	Technical Potential	Economic - High	Economic - Base	Economic - Low
GWh	74,805	28,308	16,711	16,599	16,033
MW	20,640	7,282	4,069	4,026	3,955

5.3.2 Electric Energy Efficiency Potential Results

In this section, we present the technical and economic potential results for all electric measures considered in the study. Economic potential shown in the majority of this report is for the base avoided cost scenario. We briefly present a comparison of the economic potential under the High and Low scenarios in Section 0.

Overall Technical and Economic Potential **Error! Reference source not found.** Figure 5-8 presents our overall estimates of total technical and economic potential for electrical energy and peak demand savings for Dominion.




Figure 5-8: Estimated Electric Technical and Economic Potential, 2023

Error! Not a valid bookmark self-reference. shows technical and economic potential for energy and demand, respectively. The values of both energy savings and peak-demand reductions are incorporated into the measure TRC test.

- **Energy Savings:** Technical potential is estimated at 28,308 GWH per year, and economic potential at 16,599 GWH per year by 2023 (about 38 and 22 percent of base 2023 usage, respectively).
- Peak-Demand Savings: Technical potential is estimated at 7,272 MW and economic potential at 4,016 MW by 2023 (about 35 and 20 percent of base 2023 demand, respectively).

Table 5-24: Estimated Electric Technical and Economic Potential, 2023

	2023 Base Usage (GWh)	Technical GWh	Economic GWh	2023 Base Demand (MW)	Technical MW	Economic MW
Total	74,805	28,308	16,599	20,640	7,282	4,026
Savings % of Base		38%	22%		35%	20%

5.3.3 Base Case Technical and Economic Potential Detail

In this section, we describe technical and economic potential in more detail for the base avoided cost case, and further describe potentials by sector, state, building type, and by end use.

5.3.4 Potentials by Sector

Figure 5-9 through Figure 5-12 show estimates of technical and economic energy and demand savings potential by sector. We include opt-out, exempt, and non-jurisdictional customers in this section as a separate sector to show the potential savings from these customers. The pie charts seen in these figures graphically show how technical and economic potential relates to total base consumption and demand as well as the breakout of the potential savings by sector type. Overall, each sector (residential and commercial) accounts for roughly half of the potential energy and demand savings. The residential sector is 54 percent of technical energy savings, and 46 percent of economic energy savings. The commercial sector is 35 percent of technical demand potential, as well as 41 percent of the corresponding economic potential.




Figure 5-9: Technical Energy Savings by Sector




Figure 5-10: Technical Demand Savings by Sector




Figure 5-11: Economic Energy Savings Potential by Sector




Figure 5-12: Economic Demand Savings Potential by Sector

Figure 5-13 and Figure 5-14 present the same data in a different format. These figures show the breakdown of technical and economic potential as compared to the total base consumption and demand in 2023.




Figure 5-13: Technical and Economic Energy Savings by Sector (GWH)




Figure 5-14: Technical and Economic Peak Demand Savings by Sector (MW)

Finally, Error! Not a valid bookmark self-reference. and

Table 5-26 show the contribution of technical and economic potential from each sector. These tables also compare the potential savings of each sector to base consumption and demand. The residential sector has higher technical and economic energy savings potential in relation to base energy use than does the commercial sector or non-jurisdictional and opt-outs. In technical and economic peak demand savings, residential is also higher than commercial as a percent of base demand, but the commercial sector does have a larger amount of total MW economic potential.

Table 5-25: Technical and Economic Potential (2023) Energy Savings by Sector

	2023 Base Energy Use (GWH)	Ten Year Cumulative Potential - GWh				
Sector		Technical Potential	Economic Potential (High)	Economic Potential	Economic Potential (Low)	
Residential Existing	28,285	14,720	7,044	6,988	6,593	
Residential New	2,970	655	655	655	655	
Residential Subtotal	31,255	15,374	7,698	7,642	7,247	
Savings % of Base		49.2%	24.6%	24.5%	23.2%	
Non-residential Existing	28,474	8,630	5,918	5,901	5,777	
Non-residential New	4,697	1,176	896	833	821	
Non-Residential Subtotal	33,170	9,806	6,814	6,734	6,598	
Savings % of Base		29.6%	20.5%	20.3%	19.9%	
Opt-Out, Exempt, Non-jurisdictional Existing	10,235	3,091	2,199	2,188	2,187	
Opt-Out, Exempt, Non-jurisdictional New	145	37	36	35	35	
Opt-Out, Exempt, Non-jurisdictional Subtotal	10,380	3,128	2,235	2,223	2,223	
Savings % of Base		30.1%	21.5%	21.4%	21.4%	
Total	74,805	28,308	16,711	16,599	16,033	
Savings % of Base	100%	37.8%	22.4%	22.2%	21.5%	

Table 5-26: Technical and Economic Potential (2023) Demand Savings by Sector

	2023 Base Energy Use (MW)	Ten Year Cumulative Potential - MW				
Sector		Technical Potential	Economic Potential (High)	Economic Potential	Economic Potential (Low)	
Residential Existing	7,073	3,829	1,642	1,609	1,560	
Residential New	735	59	59	59	59	
Residential Subtotal	7,809	3,888	1,701	1,668	1,619	
Savings % of Base		49.8%	21.8%	21.4%	20.7%	
Non-residential Existing	8,535	2,274	1,582	1,580	1,570	
Non-residential New	968	311	244	225	222	
Non-Residential Subtotal	9,503	2,584	1,826	1,805	1,793	
Savings % of Base		27.2%	19.2%	19.0%	18.9%	
Opt-Out, Exempt, Non- jurisdictional Existing	3,328	799	542	543	543	
Opt-Out, Exempt, Non- jurisdictional New	33	11	11	10	10	
Opt-Out, Exempt, Non- jurisdictional Subtotal	3,361	810	552	553	553	
Savings % of Base		24.1%	16.5%	16.5%	16.5%	
Total	20,640	7,282	4,069	4,026	3,955	
Savings % of Base		35.3%	19.7%	19.5%	19.2%	

5.3.5 Potential within Dominion's Virginia and North Carolina Service Territories

This section compares the energy and demand savings potential within Dominion's Virginia and North Carolina service territories. Potential savings from opt-out and non-jurisdictional customers are not included in this section.

Figure 5-15 below shows the technical and economic energy savings potential for Dominion's service territory in Virginia and North Carolina. Virginia's 24,072 GWh of technical potential compared to North Carolina's 1,109 GWh illustrates the magnitude of difference between these two states. Virginia has a 43 percent drop between technical and economic potential for a total economic energy potential of 13,736 GWh, while North Carolina has a 42 percent drop between technical and economic potential for a total economic energy potential of 640 GWh.




Figure 5-15: Technical and Economic Energy Savings by State

Figure 5-16 and Figure 5-17 break out the residential and commercial sector energy savings potential across each state. In each case, the residential sector has a slightly higher potential for technical and economic energy savings.




Figure 5-16: Technical Energy Savings Potential by State and Sector




Figure 5-17: Economic Energy Savings Potential by State and Sector

Figure 5-18 illustrates the technical and economic demand savings for Dominion's service territory in Virginia and North Carolina.




Figure 5-18: Technical and Economic Demand Savings by State

Figure 5-19 and Figure 5-20 break out the residential and commercial sector demand savings potential across each state. Technical demand savings follows a similar pattern of technical energy savings, with residential having the highest potential. However, economic demand savings for Virginia shows that the commercial sector has a higher amount of demand energy savings with 1,746 MW, compared with the Virginia residential sector, which has an economic demand-energy savings of 1,577 MW.




Figure 5-19: Technical Demand Savings Potential by State and Sector




Figure 5-20: Economic Demand Savings Potential by State and Sector

5.3.6 Potentials by Building Type

This section presents technical and economic potential by residential and commercial building type to provide more detail about where potential savings exist in Dominion's service territory. Potential savings from opt-out and non-jurisdictional customers are not included in this section.

5.3.6.1 Residential

Figure 5-21 and Figure 5-22 show the potentials in the residential sector by building type. Single family homes account for 88 percent of the economic energy potential and demand potential.




Figure 5-21: Energy Savings Potential by Residential Building Type




Figure 5-22: Demand Savings Potential by Residential Building Type

Error! Not a valid bookmark self-reference. shows the contribution from each building type toward the various types of potential.

Table 5-27: Energy and Demand Savings Potential by Residential Building Type

Residential Building Type	Energy	(GWh)	Demand (MW)	
Residential Building Type	Technical	Economic	Technical	Economic
Single Family	13,331	6,792	3,407	1,487
Multifamily	2,043	851	481	181
Total	15,374	7,642	3,888	1,668

5.3.6.2 Non-Residential

Figure 5-23 and Figure 5-24 show the building type breakdown of non-residential potential. Offices account for about 23 percent of the economic energy and 22 percent of the economic demand potential, followed by retail (21 percent of energy and 25 percent of demand potential) and restaurants (8 percent of energy and 10 percent of demand potential). Miscellaneous building types also account for a large share of total potential as well.




Figure 5-23: Energy Savings Potential by Non-Residential Building Type




Figure 5-24: Demand Savings Potential by Non-Residential Building Type

Error! Not a valid bookmark self-reference. also presents energy and demand savings potential by building type.

Table 5-28: Energy and Demand Savings Potential by Non-Residential Building Type

Non Residential Building Type	Energy (GWh)		Demand (MW)	
Non-Residential Building Type	Technical	Economic	Technical	Economic
Office	1,914	1,534	498	402
Restaurant	766	535	236	174
Retail	2,038	1,436	612	449
Grocery	510	291	105	60
Warehouse	718	419	191	89
Education	625	329	138	70
Health	472	251	116	58
Lodging	614	398	199	137
Data Centers	287	277	52	50

Religious Worship	308	114	83	40
Misc.	1,554	1,149	355	277

5.3.7 Potentials by End Use

5.3.7.1 Residential

Figure 5-25 and Figure 5-26 show the end-use breakdown of residential potential.




Figure 5-25: Energy Savings Potential by Residential End Use




Figure 5-26: Demand Savings Potential by Residential End Use

Error! Not a valid bookmark self-reference. shows the share each end use contributes to the economic potential for both energy and demand savings. Cooling is the largest contributor to both energy savings and peak demand technical savings potential. Space heating and water heating also have large technical energy savings potential, but lighting has the largest economic energy savings potential of all the residential end-uses. For residential peak demand, cooling and furnace fans have the largest economic peak demand potential.

Table 5-29: Energy and Demand Savings Potential by Residential End Use

Decidential End Hea	Energy	(GWh)	Demand (MW)	
Residential End Use	Technical	Economic	Technical	Economic
Cooling	2,993	703	1,778	418
Lighting	2,016	2,005	226	224
Refrigeration	853	774	138	125
Water Heating	2,164	957	267	118
Space Heating	2,530	518	300	61
Electronics	209	171	30	25
Furnace Fan	881	881	452	452
Miscellaneous	3,075	978	639	186
Whole Bldg (New Constr)	655	655	59	59

5.3.7.2 Non-Residential

Figure 5-27 and Figure 5-28 show energy and demand savings by non-residential end use.




Figure 5-27: Energy Savings Potential by Non-Residential End Use




Figure 5-28: Demand Savings Potential by Non-Residential End Use

Similarly, Error! Not a valid bookmark self-reference. shows the contribution to savings from each end use. Energy savings potential is greatest in lighting, followed by cooling.²⁰ Cooling accounts for most of the peak demand savings potential, since less lighting is used on hot summer afternoons.

Table 5-30: Energy and Demand Savings Potential by Non-Residential End Use

Non-Residential End Use	Energy	(GWh)	Demand (MW)	
Non-Residential Life Use	Technical	Economic	Technical	Economic
Indoor Lighting	3,747	2,893	626	487
Outdoor Lighting	483	67	29	10
Cooling	1,997	1,277	1,253	881
Ventilation	1,252	771	199	72
Refrigeration	393	209	58	32
Office Equipment	454	443	65	64
Miscellaneous	304	242	43	34
Whole Bldg (New Constr)	1,176	833	311	225

²⁰ It should be noted that that Dominion already has programs in place that target non-residential lighting, HVAC and ventilation but this study finds that additional potential remains in these end uses.

5.3.8 Avoided Cost Scenarios

Figure 5-29 shows technical and economic potential for the three scenarios (technical potential is the same for all three scenarios). In

Table 5-31, we compare the three scenarios in terms of percent of sales, percent of technical energy savings, and relative to the economic potential of the base avoided cost scenario. The low avoided cost scenario results in economic savings that are three percent lower for energy and two percent lower for peak demand compared to the base avoided cost scenario. The high avoided cost scenario results in savings that are one percent higher for both energy savings and peak demand.




Figure 5-29: Estimated Technical and Economic Energy Savings/Demand Potential for Alternative Avoided Cost Scenarios, 2023

Table 5-31: Summary of Potential at Three Avoided Cost Scenarios

Summary of Potential at Three Avoided Cost Scenarios						
		Technical Potential	Economic - High	Economic - Base	Economic - Low	
	% of Base Consumption	38%	22%	22%	21%	
GWh	% of Economic - Base Avoided Cost		101%	100%	97%	
	% of Base Consumption	35%	20%	20%	19%	
MW	% of Economic - Base Avoided Cost		101%	100%	98%	

5.3.9 Energy Efficiency Supply Curves

A common way to illustrate the amount of energy savings per dollar spent is to construct an energy efficiency supply curve. A supply curve is typically depicted on two axes: one captures the cost per unit of saved energy (e.g., levelized \$/kWh saved), and the other shows energy savings at each level of cost. Measures are sorted on a least-cost basis, and total savings are calculated incrementally with respect to measures that precede them. The costs of the measures are levelized over the life of the savings achieved. In this portion of the analysis, these costs are only referring to measure costs, and not the full cost of implementing these measures through a Dominion program. Error! Reference source not found.

Figure 5-30 presents two supply curves constructed for this study for electric energy efficiency. One curve (in dark blue) represents the ordered set of efficiency measures in terms of their savings as a percentage of total energy sales. ²¹ The second curve (in light blue) represents the same ordered set of measures at a 50 percent higher cost rate to illustrate the effect of adding program dollars for each measure on the curve. ²²

The purpose of these curves is to show how much potential (as a percent of base usage) can be realized (on the horizontal axis) compared to a scale of levelized costs (on the vertical axis), including measures that are not cost-effective. Historically, Dominion's levelized cost is estimated as approximately 6.8 cents per kWh and is specified in red. The economic potential of measures which can deliver savings at that levelized cost of energy represent approximately 23% of total energy sales. At 50 percent higher measure costs, those measures represent approximately 16% of total energy sales.




Figure 5-30: Energy Savings Potential as a Percent of Total Sales

 $^{^{21}}$ For readability, this graph only presents measures with a savings potential of less than \$1 per kWh.

Because these curves are an ordered set of measures, the second curve with the 50% cost increment should not be viewed as an assessment of achievable potential, which is estimated through a separate modelling process in Section 6, since programs are composed of bundled groups of measures rather than an ordered set of individual measures. The separate modelling process to estimate achievable potential takes into consideration consumer awareness and decision making.

5.3.10 Top 20 Saving Measures

Table 5-32 through Table 5-39 show the top 20 measures for energy and demand savings potential in the residential and non-residential sectors. For each section, the first table shows the top 20 measures as ranked by technical potential savings. The following table then shows the top 20 measures ranked by economic savings. All measures with a TRC less than one are not considered as part of the economic potential and thus were not carried over to the top 20 economic measures tables.

In both sectors, LEDs are prevalent in the top energy saving measures while cooling based measures, such as furnace fans, heat pumps, and DX packaged systems, provide a large contribution to potential demand savings.

5.3.10.1 Residential

Table 5-32: Top 20 Measures Contributing to Residential Technical Energy Savings Potential

Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh
Direct Feedback	Single Family	1164.81	0.96	0.00
Solar Domestic Water Heating	Single Family	913.38	0.45	0.00
ECM Furnace Fan (variable speed motor) - Cooling	Single Family	779.92	3.60	779.92
LEDs (base Halogen 2.5 hrs/day) 2020	Single Family	554.81	12.40	554.81
2nd Refrigerator Recycling	Single Family	459.50	2.13	459.50
Heat Recovery Ventilators (HP heating)	Single Family	454.58	0.53	0.00
Heat Pump Dryer	Single Family	430.98	0.08	0.00
Indirect Feedback	Single Family	372.52	1.17	372.52
LEDs (base Halogen 6 hrs/day) 2020	Single Family	338.04	17.01	338.04
Heat Pump Water Heater - Energy Star	Single Family	325.48	1.03	325.48
Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	295.05	1.23	295.05
LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family	282.84	34.46	282.84
Air Source Heat Pump (resistance heating)	Single Family	248.28	4.77	248.28
Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	Single Family	222.45	0.80	0.00
Whole House Fans (HP cooling)	Single Family	216.68	0.52	0.00
ROB 2L4'T8, 1EB	Single Family	209.84	2.29	209.84
Variable-Speed Pool Pump (<1 hp)	Single Family	201.08	1.90	201.08
Heat Recovery Ventilators (resistance heating)	Single Family	195.75	0.55	0.00
High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family	193.94	1.40	193.94
LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	187.26	51.26	187.26

Table 5-33: Top 20 Measures Contributing to Residential Economic Energy Savings Potential

Tubic 5 551 10p 20 Headares contribution	- 5 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1 - 1			
Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh
ECM Furnace Fan (variable speed motor) - Cooling	Single Family	779.92	3.60	779.92
LEDs (base Halogen 2.5 hrs/day) 2020	Single Family	554.81	12.40	554.81
2nd Refrigerator Recycling	Single Family	459.50	2.13	459.50
Indirect Feedback	Single Family	372.52	1.17	372.52
LEDs (base Halogen 6 hrs/day) 2020	Single Family	338.04	17.01	338.04
Heat Pump Water Heater - Energy Star	Single Family	325.48	1.03	325.48
Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	295.05	1.23	295.05
LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family	282.84	34.46	282.84
Air Source Heat Pump (resistance heating)	Single Family	248.28	4.77	248.28
ROB 2L4'T8, 1EB	Single Family	209.84	2.29	209.84
Variable-Speed Pool Pump (<1 hp)	Single Family	201.08	1.90	201.08
High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family	193.94	1.40	193.94
LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	187.26	51.26	187.26
Refrigerator (Energy Star)	Single Family	156.08	1.81	156.08
Proper Refrigerant Charging and Air Flow (CAC)	Single Family	148.83	1.10	148.83
DHW Tank Wrap	Single Family	141.00	1.09	141.00
LEDs (base Halogen 0.5 hrs/day) 2020	Single Family	124.54	2.29	124.54
Energy Star LCD TV	Single Family	109.45	15.36	109.45
ECM Furnace Fan (variable speed motor) - Cooling	Multi-Family	103.26	3.60	103.26
Drain Water Heat Recovery (GFX)	Single Family	96.60	1.43	96.60

Table 5-34: Top 20 Measures Contributing to Residential Technical Demand Savings Potential

Table 5-34: Top 20 Measures Contributing to Residential Technical Demand Savings Potential					
Measure Name	Building Type	Technical	Measure	Economic	
		MW	TRC	MW	
ECM Furnace Fan (variable speed motor) - Cooling	Single Family	779.92	3.60	779.92	
Direct Feedback	Single Family	1537.33	0.96	0.00	
Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	356.24	1.23	295.05	
Whole House Fans (HP cooling)	Single Family	836.53	0.52	0.00	
Solar Domestic Water Heating	Single Family	1718.98	0.45	0.00	
Proper Sizing and Quality Install (CAC)	Single Family	608.96	0.62	0.00	
Indirect Feedback	Single Family	372.52	1.17	372.52	
17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Single Family	761.51	0.47	0.00	
Proper Refrigerant Charging and Air Flow (CAC)	Single Family	199.16	1.10	148.83	
Cool Roof (HP cooling)	Single Family	619.84	0.63	0.00	
2nd Refrigerator Recycling	Single Family	459.50	2.13	459.50	
WINDOWS - Default With Sunscreen (CAC)	Single Family	991.72	0.23	0.00	
Heat Pump Dryer	Single Family	624.92	0.08	0.00	
14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	Single Family	345.38	0.81	0.00	
LEDs (base Halogen 2.5 hrs/day) 2020	Single Family	554.81	12.40	554.81	
Proper Refrigerant Charging and Air Flow (HP cooling)	Single Family	460.08	0.86	0.00	
15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Single Family	446.02	0.68	0.00	
Proper Sizing and Quality Install (HP cooling)	Single Family	930.36	0.36	0.00	
Heat Recovery Ventilators (HP heating)	Single Family	858.85	0.53	0.00	
ECM Furnace Fan (variable speed motor) - Cooling	Multi-Family	103.26	3.60	103.26	

Table 5-35: Top 20 Measures Contributir	ng to Residenti	al Economic	Demand Sa	vings Potentia
Measure Name	Building Type	Technical MW	Measure TRC	Economic MW
ECM Furnace Fan (variable speed motor) - Cooling	Single Family	400.06	3.60	400.06
Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	175.29	1.23	175.29
Indirect Feedback	Single Family	92.24	1.17	92.24
Proper Refrigerant Charging and Air Flow (CAC)	Single Family	88.42	1.10	88.42
2nd Refrigerator Recycling	Single Family	74.48	2.13	74.48
LEDs (base Halogen 2.5 hrs/day) 2020	Single Family	62.12	12.40	62.12
ECM Furnace Fan (variable speed motor) - Cooling	Multi-Family	52.97	3.60	52.97
Heat Pump Water Heater - Energy Star	Single Family	40.09	1.03	40.09
LEDs (base Halogen 6 hrs/day) 2020	Single Family	37.85	17.01	37.85
High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family	32.82	1.40	32.82
LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family	31.67	34.46	31.67
Air Source Heat Pump (resistance heating)	Single Family	29.46	4.77	29.46
Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replacement)	Single Family	27.06	1.08	27.06
Refrigerator (Energy Star)	Single Family	25.30	1.81	25.30
Variable-Speed Pool Pump (<1 hp)	Single Family	23.91	1.90	23.91
ROB 2L4'T8, 1EB	Single Family	23.49	2.29	23.49
Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Multi-Family	22.95	1.19	22.95
LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	20.97	51.26	20.97
ECM Furnace Fan (variable speed motor) - Cooling	Single Family	19.53	3.62	19.53
DHW Tank Wrap	Single Family	17.37	1.09	17.37

5.3.10.2 Non-Residential

Table 5-36: Top 20 Measures Contributing to Non-Residential Technical Energy Savings Potential

Table 5-36: Top 20 Measures Contributing to N	ion-Resident	iai Technica	I Energy Sa	vings Potent
Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh
LEDs (base incandescent flood) 2020	Office	279.76	16.11	279.76
LEDs (base incandescent flood) 2020	Retail	279.42	9.05	279.42
LEDs (base incandescent flood) 2020	Misc	203.64	13.89	203.64
DX Packaged System, EER=13.4, 10 tons	Retail	196.46	3.06	196.46
Variable Speed Drive Control, 5 HP	Retail	165.73	3.41	165.73
DX Packaged System, EER=13.4, 10 tons	Office	142.07	4.57	142.07
ROB 4L4' LED Tube, 2020	Office	116.53	0.29	0.00
ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	113.87	1.56	113.87
DX Packaged System, EER=13.4, 10 tons	Restaurant	103.32	5.66	103.32
ROB 4L4' LED Tube, 2020	Retail	102.48	0.22	0.00
ROB 4L4' High Performance T8 (86 W), 2020	Office	101.49	3.25	101.49
Variable Speed Drive Control, 5 HP	Misc	98.78	1.27	98.78
LEDs (base incandescent A-line 72W) 2020	Retail	98.72	7.64	98.72
LEDs (base incandescent A-line 72W) 2020	Office	98.15	13.51	98.15
ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Retail	94.03	1.10	94.03
T5 (240W) (base metal halide)	Warehouse	91.46	6.92	91.46
Data Center Best Practices	Data Centers	87.33	46.96	87.33
ROB 4L4' High Performance T8 (86 W), 2020	Retail	85.79	2.30	85.79
LED Outdoor Area Lighting	Retail	85.13	0.57	0.00
DX Packaged System, EER=13.4, 10 tons	Lodging	83.71	2.21	83.71

Table 5-37: Top 20 Measures Contributing to Non-Residential Economic Energy Savings Potential

Table 5-37: Top 20 Measures Contributing to	Economic I	Energy Sav	<u>ings Potentia</u>	
Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh
LEDs (base incandescent flood) 2020	Office	279.76	16.11	279.76
LEDs (base incandescent flood) 2020	Retail	279.42	9.05	279.42
LEDs (base incandescent flood) 2020	Misc	203.64	13.89	203.64
DX Packaged System, EER=13.4, 10 tons	Retail	196.46	3.06	196.46
Variable Speed Drive Control, 5 HP	Retail	165.73	3.41	165.73
DX Packaged System, EER=13.4, 10 tons	Office	142.07	4.57	142.07
ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	113.87	1.56	113.87
DX Packaged System, EER=13.4, 10 tons	Restaurant	103.32	5.66	103.32
ROB 4L4' High Performance T8 (86 W), 2020	Office	101.49	3.25	101.49
Variable Speed Drive Control, 5 HP	Misc	98.78	1.27	98.78
LEDs (base incandescent A-line 72W) 2020	Retail	98.72	7.64	98.72
LEDs (base incandescent A-line 72W) 2020	Office	98.15	13.51	98.15
ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Retail	94.03	1.10	94.03
T5 (240W) (base metal halide)	Warehouse	91.46	6.92	91.46
Data Center Best Practices	Data Centers	87.33	46.96	87.33
ROB 4L4' High Performance T8 (86 W), 2020	Retail	85.79	2.30	85.79
DX Packaged System, EER=13.4, 10 tons	Lodging	83.71	2.21	83.71
High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Office	80.81	5.76	80.81
Data Center Improved Operations	Data Centers	76.27	115.35	76.27
DX Packaged System, EER=13.4, 10 tons	Misc	71.92	3.38	71.92

Table 5-38: Top 20 Measures Contributing to Non-Residential Technical Demand Savings Potential

Measure Name	Building Type	Technical MW	Measure TRC	Economic MW
DX Packaged System, EER=13.4, 10 tons	Retail	162.36	3.06	162.36
DX Packaged System, EER=13.4, 10 tons	Office	99.40	4.57	99.40
DX Packaged System, EER=13.4, 10 tons	Restaurant	64.68	5.66	64.68
DX Packaged System, EER=13.4, 10 tons	Misc	55.62	3.38	55.62
Economizer Repair - DX	Retail	53.70	1.10	53.70
LEDs (base incandescent flood) 2020	Office	52.08	16.11	52.08
LEDs (base incandescent flood) 2020	Retail	50.56	9.05	50.56
DX Packaged System, EER=13.4, 10 tons	Lodging	50.41	2.21	50.41
DX Packaged System, EER=13.4, 10 tons	Warehouse	43.22	0.26	0.00
Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	36.49	6.41	36.49
LEDs (base incandescent flood) 2020	Misc	34.56	13.89	34.56
Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	32.42	4.28	32.42
Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	28.41	3.16	28.41
DX Packaged System, EER=13.4, 10 tons	Health	28.20	3.34	28.20
DX Packaged System, EER=13.4, 10 tons	School	26.43	1.64	26.43
Duct Testing/Sealing - DX	Retail	26.32	0.40	0.00
Demand Controlled Ventilation	Retail	22.57	0.09	0.00
Economizer Repair - DX	Office	22.47	1.66	22.47
Cool Roof - DX	Retail	22.46	0.84	0.00
Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	22.14	3.80	22.14

Table 5-39: Top 20 Measures Contributing to Non-Residential Economic Demand Savings
Potential

Fotential						
Measure Name	Building Type	Technical GWh	Measure TRC	Economic MW		
DX Packaged System, EER=13.4, 10 tons	Retail	162.36	3.06	162.36		
DX Packaged System, EER=13.4, 10 tons	Office	99.40	4.57	99.40		
DX Packaged System, EER=13.4, 10 tons	Restaurant	64.68	5.66	64.68		
DX Packaged System, EER=13.4, 10 tons	Misc	55.62	3.38	55.62		
Economizer Repair - DX	Retail	53.70	1.10	53.70		
LEDs (base incandescent flood) 2020	Office	52.08	16.11	52.08		
LEDs (base incandescent flood) 2020	Retail	50.56	9.05	50.56		
DX Packaged System, EER=13.4, 10 tons	Lodging	50.41	2.21	50.41		
Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	36.49	6.41	36.49		
LEDs (base incandescent flood) 2020	Misc	34.56	13.89	34.56		
Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	32.42	4.28	32.42		
Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	28.41	3.16	28.41		
DX Packaged System, EER=13.4, 10 tons	Health	28.20	3.34	28.20		
DX Packaged System, EER=13.4, 10 tons	School	26.43	1.64	26.43		
Economizer Repair - DX	Office	22.47	1.66	22.47		
Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	22.14	3.80	22.14		
ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	21.20	1.56	21.20		
HE PTAC, EER=9.6, 1 ton	Misc	19.60	1.37	19.60		
ROB 4L4' High Performance T8 (86 W), 2020	Office	18.89	3.25	18.89		
DX Packaged System, EER=13.4, 10 tons	Grocery	18.70	3.33	18.70		

5.4 **Achievable (Program) Potential**

This section provides a high-level summary of the achievable potential analysis, based on the results of the technical and economic potential analyses. This achievable analysis was conducted using the results of the base avoided cost scenario, and excludes opt-out, exempt, and non-jurisdictional customers. Although savings from these customers were included in the technical and economic results, they are excluded from the program achievable potential as they do not participate in Dominion programs and therefore should not be included in the estimation of program potential.

In contrast to the technical and economic potential estimates which are based on measure-level costs and savings, our estimates of achievable potential take into account market and other factors that affect the adoption of efficiency measures. As further described in Section 4 and Appendix A of this report, our method of estimating measure adoption takes into account market barriers and program incentives and reflects actual consumer and business implicit discount rates. This portion of the analysis also includes program budgets as they impact the savings potential and are used in the analysis of the total resource cost and other cost benefit tests. The discount rate assumptions can be

found in Appendix C of the report, while annual budget assumptions can be found in Appendix J of the draft report.

In this analysis, achievable potential refers to the amount of savings that would occur in response to one or more specific program interventions. Gross or total market savings shown in this section includes net savings and savings attributable to program free-riders – those customers who would have installed the measure in the absence of the program. Net or program savings associated with program potential are savings that are projected beyond those that would occur naturally in the absence of any market intervention.

The achievable analysis typically begins by calibrating budgets and savings to recent program results.²³ After the calibration is complete, all cost-effective measures from the technical and economic analysis are included in the model, and administrative and marketing budgets are increased to account for the additional measures.

DNV GL calibrated the non-residential sector results to recent non-residential programs but found that calibrating to current residential programs was not feasible. DNV GL attempted to calibrate the residential sector results to the current Residential Home Energy Check Up and Residential Heat Pump Upgrade programs, but found that these two programs did not replicate well in our modeling framework. This was due to the audit nature of the Residential Home Energy Check Up program not representing a natural market normally assumed by the model. As such, it did not seem reasonable to expand the results of the calibration efforts to the full potential analysis. We instead established residential budgets and parameters based on our experience rather than calibration to past program results. Initial administrative and marketing budgets were based on data from the indicator tables, which was increased to account for the additional measures included in the analysis.

Because achievable potential depends on the type and degree of intervention applied, we developed potential estimates under alternative funding scenarios: 50 percent incentives and 75 percent incentives. We estimated program energy and peak demand savings under each scenario for the 2014-2023 period. Per the direction of Dominion, we then modeled the two aforementioned incentive scenarios, defined as follows:

- 50 percent incentives: We assume customer incentives are set at 50 percent of incremental costs.
- 75 percent incentives: We assume customer incentives are offered at the midpoint between the 50 percent incentive and a 100 percent incentive. Program budgets were increased in conjunction with the increased incentive spending.

Table 5-40 shows the results of the achievable analysis as compared to base consumption, technical potential, and economic potential. The energy savings estimates from the 50 percent scenario are three percent of base consumption (excluding opt-outs/exempt/non-jurisdictional) and 15 percent of

²³ The calibration stage only includes measures that can be mapped to Dominion programs. All cost-effective measures are included in the funding scenario analyses.

In particular, RHEC provides a fixed incentive through a direct install program which does not respond in the same way as incentive-driven programs. The model would typically assume that the high levels of incentives seen in RHEC would lead to measure penetration beyond what the 2012 and 2013 RHEC EM&V results suggest. In order to replicate the results of the RHEC program we needed to set artificially high barriers in order to constrain penetration of these measures and in doing so limited the amount of potential that could realistically be feasible for these measures.

 $^{^{25}}$ These scenarios reflect the percentage of incremental measure cost that is assumed to be paid in customer incentives.

the economic potential.²⁶ Overall energy savings under the 75 percent scenario are projected to be six percent of base consumption and 26 percent of economic potential. These results as a percent of base consumption are comparatively lower than results seen in other jurisdictions for the following reasons:

- DNV GL found that the avoided cost and rate structure suppresses program savings potential. Low avoided costs and rates reduce the cost-effectiveness and associated penetration of each measure.
- Without extensive program experience to rely on, these results suggest that more effort and time are required to inform customers of program benefits than in other jurisdictions with many years of program history. Although Dominion has offered DSM programs for five years, opportunities still remain in untouched markets like appliance recycling which will take time to develop into programs.

Table 5-40: Ten Year Cumulative Potential - GWh

Sector	2023 Base		en Year Cumula	ative Potential - G	Wh
	Energy Use (GWH)	Technical Potential	Economic Potential	50% Achievable (Program)	75% Achievable (Program)
Residential	31,255	15,374	7,642	1,488	2,484
Savings % of Base	!	49%	24%	5%	8%
Non-Residential	33,170	9,806	6,734	623	1,297
Savings % of Base	!	30%	20%	2%	4%
Opt-Out/Exempt/ Non-Jurisdictional	10,380	3,128	2,223	0	0
Savings % of Base	!	30%	21%	0%	0%
Total	74,805	28,308	16,660	2,111	3,782
Savings % of Base	!	38%	22%	3%	5%
Total No Opt-Out/ Exempt/ Non-Jur.	64,425	25,181	14,437	2,111	3,782
Savings % of Base	!	39%	22%	3%	6%

Savings presented in the executive summary were compared to base consumption including opt-out/exempt/non-jurisdictional customers. In that case, savings from the 50% scenario are 3% of base consumption and savings from the 75% scenario are 5% of base.

5.4.1 Achievable (Program) Potential – Overall Results

Figure 5-31 shows our estimates of achievable potential savings over time. As shown in this figure, by 2023 cumulative net²⁷ energy savings are projected to be 2,111 GWh under the 50 percent incentive scenario and 3,782 GWh under the 75 percent incentive scenario. In each scenario, savings increase over time. A breakdown of the program costs can be seen in Figure 5-31 below.




Figure 5-31: Achievable Electric Energy Savings: All Evaluated Sectors

As incentive levels increase between program scenarios, the costs to administer and market the program also increase from additional programmatic activity. Increased incentives also affect participant costs as the incremental cost participants must pay per measure has decreased as a result of the higher incentives. It is also important to note that although the level of naturally occurring savings does not change between scenarios, program free riders receive the same incentives payments as program participants.

²⁷ Throughout this section, net refers to savings beyond those estimated to be naturally occurring; that is, from customer adoptions that would occur in the absence of any programs or standards.

Figure 5-32 depicts the estimated costs and benefits under each funding scenario from 2014 to 2023. The present value of program costs (including program incentives²⁸ and program administration, marketing²⁹) is \$389 million under the 50 percent incentive scenario and \$963 million under the 75 percent incentive scenario.




Figure 5-32: Benefits and Costs of Energy Efficiency Savings—2014-2023*

* Present value of benefits and costs over normalized 20-year measure lives; nominal discount rate is 7.45 percent, inflation rate is 1.87 percent.

The present value of total avoided cost benefits is \$1,278 million under 50 percent incentives and \$2,251 million under 75 percent incentives. Finally, all scenarios have positive net benefits: the present value of *net* avoided cost benefits, i.e., the difference between total avoided cost benefits and total costs (which include participant costs in addition to program costs), is \$763 million under 50 percent incentives and \$1,185 million under 75 percent incentives.

Both of the funding scenarios are cost-effective based on the TRC test, which is the test used in this study to determine program cost-effectiveness.³⁰ The TRC benefit-cost ratios for Dominion's service territory are 2.5 for the 50 percent scenario and 2.1 under the 75 percent scenario.

The incentive budgets reported for this study are calculated by the model based on the penetration of the energy efficiency measures and the incentives paid.

The administrative and marketing costs used in the analysis were based off the costs (indirect-other and direct implementation) from the EM&V indicator tables. These budgets were scaled up to account for the addition of other cost-effective measures in the analysis.

 $^{^{\}rm 30}$ Other cost benefit tests will be provided in the appendix of the draft report.

The high TRC in both scenarios is largely driven by LED installations, particularly in the residential sector. Without LEDs in the residential analysis, where they have the largest impact, the program TRCs would be about 1.6 over the 10-year analysis period.

The saturation study showed remaining potential exists for both CFLs and LEDs. In the early years of the analysis period, CFLs are still cost-competitive with LEDs, but using recent data on price trends, we expect LEDs to be more cost-effective than CFLs in 2016. The model projects that LEDs will have a large impact on program savings beginning in 2016. As a result, all residential lighting savings after that point can be attributed to LED lamp replacements. Recent research on LEDs has shown that the major barrier to LED penetration is still costs, which are expected to decline. Performance and quality concerns were initial barriers when LEDs were first introduced to the market, but through extensive research and development at major manufacturers and national-level quality standards, these barriers have diminished and it is expected that consumers will be more interested in LEDs than they were in CFLs. As such, we expect to see an increase in LED penetration as costs continue to decline.

Key results of our efficiency scenario forecasts from 2014 to 2023 are summarized in Table 5-41.

Table 5-41: Summary of Achievable Potential Results-2014-2023*

Result - Programs	Program Scenario:				
	50 percent Incentives	75 percent Incentives			
Total Market Energy Savings - GWh	4,195	5,809			
Total Market Peak Demand Savings - MW	723	1,042			
Program Energy Savings - GWh	2,111	3,782			
Program Peak Demand Savings - MW	370	698			
Program Costs - Real, \$ Million					
Administration	\$158	\$397			
Marketing	\$54	\$74			
Incentives	\$284	\$754			
Total	\$495	\$1,225			
PV Avoided Costs	\$1,278	\$2,251			
PV Annual Program Costs (Adm/Mkt)	\$166	\$370			
PV Net Measure Costs	\$349	\$697			
Net Benefits	\$763	\$1,185			
TRC Ratio	2.5	2.1			

^{*}PV (present value) of benefits and costs is calculated over a 20-year normalized measure life for 2014-2023 program years, nominal discount rate = 7.45 percent, inflation rate = 1.87 percent; GWh and MW savings are cumulative through 2023.

5.4.2 Breakdown of Achievable Potential by Sector

Cumulative net achievable potential estimates by sector for the period of 2014-2023 are presented in Figure 5-33 and Figure 5-34. These figures compare the residential and non-residential sector results for each funding scenario. All opt-out, exempt, and non-jurisdictional customers were excluded from this analysis.

Under the program assumptions developed for this study, achievable energy savings under the 50 percent and 75 percent scenarios are highest for the residential sector. Peak demand savings under both scenarios are also highest for the residential sector.³¹




Figure 5-33: Net Achievable Energy Savings (2023) by Sector—GWh per Year




Figure 5-34: Net Achievable Peak-Demand Savings (2023) by Sector—MW

DNV GL - Energy www.dnvgl.com/energy

³¹ The estimates of peak demand savings are from the installation of energy efficiency measures and do not include demand savings from demand response technologies such as direct load control or dynamic pricing.

Cumulative net achievable potential estimates by Virginia customer class are presented in Figure 5-35 and Figure 5-36. Similar to the system level results, achievable energy and peak demand savings are highest for the residential sector under both scenarios.




Figure 5-35: Net Achievable Energy Savings (2023) by Sector in Virginia—GWh per Year




Figure 5-36: Net Achievable Peak-Demand Savings (2023) by Sector in Virginia—MW

Figure 5-37 and Figure 5-38 show the net cumulative energy and demand savings in North Carolina. Achievable energy and peak demand savings are highest for the residential sector under both scenarios. The increase in residential savings between the 50 percent and 75 percent scenarios is much smaller in North Carolina than in Virginia.




Figure 5-37: Net Achievable Energy Savings (2023) by Sector in North Carolina—GWh per Year

Figure 5-38: Net Achievable Peak-Demand Savings (2023) by Sector in North Carolina—MW

Figure 5-39 shows cumulative net achievable program savings for the total residential sector by program scenario. By 2023, net energy savings reach 1,488 GWh under the 50 percent incentive scenario and 2,484 GWh under the 75 percent incentive scenario.




Figure 5-39: Achievable Energy Savings: Residential Sector

Table 5-42 shows detailed information for the measures that were included in the residential achievable potential analysis. This table presents savings at the system level and shows the average TRC across all building types.³² Savings from the 50 percent and 75 percent scenarios are compared against the economic potential for each measure to show how much economic potential is projected to be achieved during the 10-year analysis period. These results show that program potential generally does not reach saturation in this time frame as various forces such as measure cost-effectiveness, awareness decay, and late adopters³³ prevent additional penetration.

 32 An average TRC can be below one if the measure is not cost-effective in some, but not all, building types.

The modelling process assumes that initial awareness is a function on measure-level cost effectiveness. Awareness increases over time due to program marketing and advertising efforts, but we also assume a fraction of customers will forget and become "unaware" each year and must be reached by the program again. Furthermore, we assume that despite a program's best efforts, there will be a portion of the market that will not be converted due to factors outside a program's control.

Table 5-42: Residential Measure-Level Savings: GWh

Measure	Average TRC Ratio	Technical Potential (GWh)	Economic Potential (GWh)	Net Ach @50% Incentives	% of Economic	Net Ach @75% Incentives	% of Economic
Proper Refrigerant Charging and Air Flow (CAC)	1.07	226.7	148.8	33.4	22%	65.0	44%
Duct Insulation (CAC)	1.15	74.7	2.3	0.3	13%	0.8	37%
Return Duct Modification (CAC)	1.73	73.7	12.4	2.9	23%	6.1	49%
Programmable Thermostat (CAC)	2.14	49.3	12.7	4.4	34%	7.2	57%
Self-Install Weatherization (CAC)	6.09	27.0	27.0	10.6	39%	13.1	49%
Proper Refrigerant Charging and Air Flow (CAC early replacement)	1.00	55.2	4.0	1.1	27%	1.9	48%
Duct Insulation (CAC early replacement)	8.38	4.2	3.3	1.2	36%	1.5	44%
Return Duct Modification (CAC early replacement)	1.59	21.1	2.0	0.4	21%	0.9	47%
Programmable Thermostat (CAC early replacement)	1.97	15.0	2.4	0.8	35%	1.3	54%
Self-Install Weatherization (CAC early replacement)	5.97	9.7	6.8	2.7	40%	3.3	49%
Door Weatherization (CAC early replacement)	1.24	23.7	8.7	1.3	15%	2.7	32%
Heat pump upgrade	0.97	962.4	412.5	20.5	5%	37.3	9%
Duct Insulation (HP cooling)	8.53	17.8	17.8	6.4	36%	7.8	44%
Programmable Thermostat (HP cooling)	1.51	143.1	29.1	8.2	28%	15.4	53%
Self-Install Weatherization (HP cooling)	2.29	43.5	25.6	9.0	35%	14.9	58%
Door Weatherization (HP cooling)	0.96	535.0	12.2	2.2	18%	4.2	35%
Duct Insulation (HP cooling Early Replacement)	7.44	2.8	2.8	1.1	38%	1.3	47%
Programmable Thermostat (HP cooling Early Replacement)	0.84	69.0	0.4	0.4	80%	0.4	93%
Self-Install Weatherization (HP cooling Early Replacement)	2.06	6.8	4.0	1.3	32%	2.3	56%
Door Weatherization (HP cooling Early Replacement)	1.00	67.7	2.1	0.4	18%	0.7	35%
Self-Install Weatherization (RAC)	3.72	1.6	1.6	0.6	40%	0.9	58%
Door Weatherization (RAC)	0.87	4.2	0.7	0.2	25%	0.3	39%

Measure	Average TRC Ratio	Technical Potential (GWh)	Economic Potential (GWh)	Net Ach @50% Incentives	% of Economic	Net Ach @75% Incentives	% of Economic
ECM Furnace Fan (variable speed motor) – Cooling	3.60	926.3	926.3	47.2	5%	147.3	16%
Duct Insulation (HP heating)	8.92	24.9	24.9	7.3	29%	8.6	35%
Programmable Thermostat (HP heating)	1.22	155.3	40.1	13.4	33%	22.6	56%
Self-Install Weatherization (HP heating)	2.51	60.7	35.8	15.5	43%	21.2	59%
Door Weatherization (HP heating)	0.79	360.9	14.0	2.5	18%	4.9	35%
Duct Insulation (HP heating early replacement)	8.54	4.4	4.4	1.3	30%	1.6	35%
Programmable Thermostat (HP heating early replacement)	1.17	30.1	6.8	2.2	33%	3.8	56%
Self-Install Weatherization (HP heating early replacement)	2.57	11.0	6.5	2.8	43%	3.8	59%
Door Weatherization (HP heating early replacement)	0.80	62.0	2.5	0.4	18%	0.9	35%
Air Source Heat Pump (resistance heating)	4.89	346.9	346.9	35.5	10%	47.1	14%
Programmable Thermostat (resistance heating)	1.49	398.8	15.7	6.2	39%	9.3	60%
Self-Install Weatherization	2.52	363.5	16.6	7.2	43%	9.8	59%
Door Weatherization (resistance heating)	1.37	410.4	30.0	6.7	22%	11.2	38%
CFLs	28.31	1705.6	1705.6	55.0	3%	119.8	7%
LEDs	6.17	1249.1	1237.9	319.9	26%	455.6	37%
CFLs-specialty	3.95	138.4	138.4	0.1	0%	0.3	0%
LEDs-specialty	30.87	628.7	628.7	214.4	34%	311.7	50%
ROB 2L4'T8, 1EB	2.29	241.3	241.3	9.8	4%	15.0	6%
Refrigerator (Energy Star)	1.74	210.7	210.7	13.4	6%	21.4	10%
2nd Refrigerator Recycling	2.13	479.7	479.7	87.2	18%	193.9	40%
Freezer (Energy Star)	1.18	41.5	41.5	3.8	9%	6.4	15%
Freezer - Early Replacement (Energy Star)	1.41	62.8	62.8	17.0	27%	24.1	38%
2nd Freezer Recycling	3.03	19.4	19.4	5.3	27%	8.2	42%
Heat Pump Water Heater - Energy Star	0.98	1103.9	325.5	17.7	5%	30.5	9%

Measure	Average TRC Ratio	Technical Potential (GWh)	Economic Potential (GWh)	Net Ach @50% Incentives	% of Economic	Net Ach @75% Incentives	% of Economic
DHW Tank Wrap	1.03	661.3	141.0	15.1	11%	42.9	30%
Pipe Wrap	3.72	116.2	116.2	46.2	40%	61.5	53%
Hot water turndown 5 degrees	2.52	162.3	14.2	3.1	22%	4.2	30%
Hot water turndown 10 degrees	2.52	172.4	19.2	4.2	22%	5.7	30%
Hot water turndown 15 degrees	2.50	180.9	4.5	1.0	22%	1.3	30%
Hot water turndown 20 degrees	2.50	178.5	1.7	0.4	22%	0.5	30%
Drain Water Heat Recovery (GFX)	1.35	414.5	131.5	21.6	16%	57.9	44%
Faucet Aerators	1.30	442.2	72.1	16.2	22%	35.2	49%
Low Flow Showerhead 1.5 Gal/Min	2.55	255.3	111.2	42.3	38%	62.4	56%
Heat Pump Water Heater - Energy Star - Early Replacement	0.96	94.5	69.5	18.7	27%	33.3	48%
High Efficiency CD (EF=3.01 w/moisture sensor)	1.51	253.1	253.1	20.1	8%	32.5	13%
Variable-Speed Pool Pump (<1 hp)	1.90	210.8	210.8	19.7	9%	40.3	19%
Energy Star Plasma TV	6.96	14.3	14.3	2.6	18%	3.3	23%
Smart Power Strips	0.51	436.7	45.8	9.1	20%	14.1	31%
Energy Star LCD TV	15.35	134.6	134.6	21.1	16%	24.8	18%
Energy Star DVD Player	3.90	31.1	31.1	5.7	18%	7.6	24%
Energy Star Desktop PC	14.41	61.4	61.4	9.8	16%	11.6	19%
Indirect Feedback	2.28	457.1	372.5	12.4	3%	23.7	6%

Figure 5-40 shows cumulative net achievable program savings by non-residential program scenario. By 2023, net energy savings reach 623 GWh under the 50 percent incentive scenario and 1,297 GWh under the 75 percent incentive scenario.




Figure 5-40: Achievable Energy Savings: Non-Residential Sector

Table 5-43 presents savings information for all measures included in the non-residential achievable potential analysis. Similar to

Table 5-42, this table shows system-level savings as well as the average TRC across all building types and compares projections of achievable potential to a measure's estimated economic potential. 34

 $^{^{34}}$ An average TRC can be below 1 if the measure is not cost-effective in some, but not all building types.

Table 5-43: Non-Residential Measure-Level Savings: GWh

Measure	Average TRC ratio	Technical	Economic	Ach @50% Incentives	% of Net Economic	Ach @75% Incentives	% of Net Economic
Tube Fluorescents	2.10	1473.4	1374.8	115.3	8%	206.4	15%
LED	2.66	3710.7	2091.4	236.8	11%	368.0	18%
Lighting Controls	3.05	347.4	210.6	18.6	9%	53.4	25%
High Performance Lighting R/R	2.48	497.0	481.5	20.7	4%	97.6	20%
CFL	2.64	1464.8	1464.7	6.0	0%	8.6	1%
Cooling Equipment	2.82	1578.2	1495.7	23.1	2%	56.4	4%
Shell	2.78	199.8	83.9	3.0	4%	15.7	19%
Cooling Controls	0.62	216.2	30.7	0.3	1%	1.9	6%
Cooling Maintenance	1.29	18.8	8.2	0.1	1%	0.6	7%
VSD	2.78	1116.2	858.1	69.4	8%	202.8	24%
Economizer	0.65	359.7	91.7	0.4	0%	2.6	3%
Motors	2.01	260.6	210.7	0.5	0%	2.9	1%
Ventilation Controls	0.76	393.1	103.2	2.7	3%	12.7	12%
Other Refrigeration	5.23	213.9	137.5	10.6	8%	22.4	16%
Refrigeration Equipment	5.08	96.6	75.7	3.3	4%	7.5	10%
Power Management	1.33	131.1	117.9	1.1	1%	0.4	0%
Office Equipment	22.02	115.6	115.3	2.2	2%	3.1	3%
Data Center	63.70	601.9	601.9	36.0	6%	49.4	8%
Other Water Heating	2.28	117.3	82.7	2.4	3%	12.2	15%
Water Heating Equipment	1.61	133.0	113.9	0.3	0%	1.5	1%
Vending Controls	1.01	36.1	33.1	0.3	1%	1.0	3%
Cooking	0.59	73.3	55.3	0.3	1%	1.5	3%

DNV·GL


DOMINION ENERGY EFFICIENCY POTENTIAL STUDY

Dominion Energy Efficiency Potential Study Draft Report Appendices

Dominion Virginia Power

Prepared by Kema, Inc.

January 9, 2015



Appendices

A DETAILED METHODOLOGY AND MODEL DESCRIPTION
A.1 Overview of DSM Forecasting Method
A.2 DSM ASSYST* Model Description
B MEASURE DESCRIPTIONS B-1
B.1 Residential Measures B-1
B.2 Commercial Measures B-8
C ECONOMIC INPUTS
D BUILDING AND TOU FACTOR INPUTS
E MEASURE INPUTSE-1
F NON-ADDITIVE MEASURE LEVEL RESULTSF-1
G SUPPLY-CURVE DATA
H DETAILED TECHNICAL AND ECONOMIC AVOIDED COST SCENARIO RESULTS H-1
I MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL
J ACHIEVABLE PROGRAM POTENTIAL

A DETAILED METHODOLOGY AND MODEL DESCRIPTION

In this appendix we present and discuss our basic methodology for conducting market potential studies. We also present an overview of DSM ASSYSTTM, our model used to develop market potential estimates. Information presented here has been extracted from several recent energy efficiency potential reports.

A.1 Overview of DSM Forecasting Method

The crux of any DSM forecasting process involves carrying out a number of systematic analytical steps that are necessary to produce accurate estimates of energy efficiency (EE) effects on system load. A simplified overview of these basic analytical steps is shown in Figure A-1.




Figure 0-1: Simplified Conceptual Overview of Modeling Process

Developing a DSM forecast is viewed by DNV GL as a five-step process. The steps include:

Step 1: Develop Initial Input Data

- Develop list of EE measure opportunities to include in scope
- Gather and develop technical data (costs and savings) on efficient measure opportunities
- Gather, analyze, and develop information on building characteristics, including total square
 footage and households, electricity consumption and intensity by end use, end-use
 consumption load patterns by time of day and year (i.e., load shapes), market shares of key
 electric consuming equipment, and market shares of EE technologies and practices.

Step 2: Estimate Technical Potential and Develop Supply Curves

 Match and integrate data on efficient measures to data on existing building characteristics to produce estimates of technical potential and EE supply curves.

Step 3: Estimate Economic Potential

- Gather economic input data such as current and forecasted retail electric prices and current
 and forecasted costs of electricity generation, along with estimates of other potential benefits
 of reducing supply, such as the value of reducing environmental impacts associated with
 electricity production
- Match and integrate measure and building data with economic assumptions to produce indicators of costs from different viewpoints (e.g., utility, societal, and consumer)
- Estimate total economic potential using supply curve approach

Step 4: Estimate Achievable Program and Naturally Occurring Potentials

- Gather and develop estimates of program costs (e.g., for administration and marketing) and historic program savings
- Develop estimates of customer adoption of EE measures as a function of the economic attractiveness of the measures, barriers to their adoption, and the effects of program intervention
- Estimate achievable program and naturally occurring potentials; calibrate achievable and naturally occurring potential to recent program and market data
- Develop alternative economic estimates associated with alternative future scenarios

Step 5: Scenario Analyses and Resource Planning Inputs

• Recalculate potentials under alternate economic scenarios and deliver data in format required for resource planning.

Provided below is additional discussion of DNV GL's modeling approaches for technical, economic, and achievable DSM forecasts.

A.1.1 Estimate Technical Potential and Develop Energy-Efficiency Supply Curves

Technical potential refers to the amount of energy savings or peak demand reduction that would occur with the *complete* penetration of all measures analyzed in applications where they were deemed *technically* feasible from an *engineering* perspective. Total technical potential is developed from estimates of the technical potential of individual measures as they are applied to discrete market segments (commercial building types, residential dwelling types, etc.).

A.1.1.1 Core Equation

The core equation used to calculate the energy technical potential for each individual efficiency measure, by market segment, is shown below (using a commercial example):¹

Note that stock turnover is not accounted for in our estimates of technical and economic potential, stock turnover is accounted for in our estimates of achievable potential. Our definition of technical potential assumes instantaneous replacement of standard-efficiency with high-efficiency measures.

where:

Square feet is the total floor space for all buildings in the market segment. For the residential analysis, the **number of dwelling units** is substituted for square feet.

Base-case equipment EUI is the energy used per square foot by each base-case technology in each market segment. This is the consumption of the energy-using equipment that the efficient technology replaces or affects. For example, if the efficient measure were a CFL, the base EUI would be the annual kWh per square foot of an equivalent incandescent lamp. For the residential analysis, unit energy consumption (UECs), energy used per dwelling, are substituted for EUIs.

Applicability factor is the fraction of the floor space (or dwelling units) that is applicable for the efficient technology in a given market segment; for the example above, the percentage of floor space lit by incandescent bulbs.

Not complete factor is the fraction of applicable floor space (or dwelling units) that has not yet been converted to the efficient measure; that is, (1 minus the fraction of floor space that already has the EE measure installed).

Feasibility factor is the fraction of the applicable floor space (or dwelling units) that is technically feasible for conversion to the efficient technology from an *engineering* perspective.

Savings factor is the percent reduction in energy consumption resulting from application of the efficient technology.

Technical potential for peak demand reduction is calculated analogously.

An example of the core equation is shown in Table A-1 for the case of a prototypical 4-lamp 4-foot standard T-8 lighting fixture, which is replaced by a 4-lamp 4-foot premium T-8 fixture in the office segment of a large utility service territory.

Table 0-1
Example of Technical Potential Calculation—Replace 4-Lamp 4-Foot Standard T-8s with 4-Lamp 4-Foot Premium T-8s in the Office Segment of a Utility Service Territory (Note: Data are illustrative only)

Technical	Total	Base Case		Not		
Potential of =	square feet	× Equipment	× Applicability	× Complete	× Feasibility	× Savings
Efficient		UEC	Factor	Factor	Factor	Factor
Measure						
57 million kWh	195 million	5.74	0.34	0.95	1.00	0.16

Technical EE potential is calculated in two steps. In the first step, all measures are treated independently; that is, the savings of each measure are not marginalized or otherwise adjusted for overlap between competing or synergistic measures. By treating measures independently, their relative economics are analyzed without making assumptions about the order or combinations in which they might be implemented in customer buildings. However, the total technical potential across measures cannot be estimated by summing the individual measure potentials directly. The cumulative savings cannot be estimated by adding the savings from the individual savings estimates because some savings would be double counted. For example, the savings from a measure that reduces heat gain into a building, such as window film, are partially dependent on other measures that affect the efficiency of the system being used to cool the building, such as a high-efficiency chiller; the more efficient the chiller, the less energy saved from the application of the window film.

A.1.1.2 Use of Supply Curves

In the second step, cumulative technical potential is estimated using an EE supply curve approach.² This method eliminates the double-counting problem. In Figure A-2, we present a generic example of a supply curve. As shown in the figure, a supply curve typically consists of two axes—one that captures the cost per unit of saving a resource or mitigating an impact (e.g., \$/kWh saved or \$/ton of carbon avoided) and the other that shows the amount of savings or mitigation that could be achieved at each level of cost. The curve is typically built up across individual measures that are applied to specific base-case practices or technologies by market segment. Savings or mitigation measures are sorted on a least-cost basis, and total savings or impacts mitigated are calculated incrementally with respect to measures that precede them. Supply curves typically, but not always, end up reflecting diminishing returns, i.e., as costs increase rapidly and savings decrease significantly at the end of the curve.

_

² This section describes conservation supply curves as they have been defined and implemented in numerous studies. Readers should note that Stoft 1995 describes several technical errors in the definition and implementation of conservation supply curves in the original and subsequent conservation supply curve studies. Stoft concludes that conservation supply curves are not "true" supply curves in the standard economic sense but can still be useful (albeit with his recommended improvements) for their intended purpose (demonstration of cost-effective conservation opportunities).




Figure 0-2: Generic Illustration of EE Supply Curve

As noted above, the cost dimension of most EE supply curves is usually represented in dollars per unit of energy savings. Costs are usually annualized (often referred to as "levelized") in supply curves. For example, EE supply curves usually present levelized costs per kWh or kW saved by multiplying the initial investment in an efficient technology or program by the "capital recovery rate" (CRR):

CRR =
$$\frac{d}{1 - (1 + d)^{-n}}$$

where d is the real discount rate and n is the number of years over which the investment is written off (i.e., amortized).

Thus,

Levelized Cost per kWh Saved = Initial Cost x CRR/Annual Energy Savings

Levelized Cost per kW Saved = Initial Cost x CRR/Peak Demand Savings

The levelized cost per kWh and kW saved are useful because they allow simple comparison of the characteristics of EE with the characteristics of energy supply technologies. However, the levelized cost per kW saved is a biased indicator of cost-effectiveness because all of the efficiency measure costs are arbitrarily allocated to peak savings.

Returning to the issue of EE supply curves, Table A-2 shows a simplified numeric example of a supply curve calculation for several EE measures applied to commercial lighting for a hypothetical population of buildings. What is important to note is that in an EE supply curve, the measures are sorted by relative cost—from least to most expensive. In addition, the energy consumption of the system being

affected by the efficiency measures goes down as each measure is applied. As a result, the savings attributable to each subsequent measure decrease if the measures are interactive. For example, the occupancy sensor measure shown in Table 1-2 would save more at less cost per unit saved if it were applied to the base-case consumption before the T8 lamp and electronic ballast combination. Because the T8 electronic ballast combination is more cost-effective, however, it is applied first, reducing the energy savings potential for the occupancy sensor. Thus, in a typical EE supply curve, the base-case end-use consumption is reduced with each unit of EE that is acquired. Notice in Table 1-2 that the total end-use GWh consumption is recalculated after each measure is implemented, thus reducing the base energy available to be saved by the next measure.

Table A-2 shows an example that would represent measures for one base-case technology in one market segment. These calculations are performed for all of the base-case technologies, market segments, and measure combinations in the scope of a study. The results are then ordered by levelized cost and the individual measure savings are summed to produce the EE potential for the entire sector.

In the next subsection, we discuss how economic potential is estimated as a subset of the technical potential.

Table 0-2
Sample Technical Potential Supply Curve Calculation for Commercial Lighting (Note: Data are illustrative only)

	Total End Use Consumption	Applicable, Not Complete and	Average			Levelized
Measure	of Population (GWh)	Feasible (1000s of ft ²)	kWh/ft ² of population	Savings %	GWh Savings	Cost (\$/kWh saved)
Base Case: T12 lamps with Magnetic Ballast	425	100,000	4.3	N/A	N/A	N/A
1. T8 w. Elec. Ballast	425	100,000	4.3	21%	89	\$0.04
2. Occupancy Sensors	336	40,000	3.4	10%	13	\$0.11
3. Perimeter Dimming	322	10,000	3.2	45%	14	\$0.25
With all measures	309		3.1	27%	116	

A.1.2 Estimation of Economic Potential

Economic potential is typically used to refer to the technical potential of those energy conservation measures that are cost effective when compared to either supply-side alternatives or the price of energy. Economic potential takes into account the fact that many EE measures cost more to purchase initially than do their standard-efficiency counterparts. The incremental costs of each efficiency measure are compared to the savings delivered by the measure to produce estimates of energy

savings per unit of additional cost. These estimates of EE resource costs can then be compared to estimates of other resources such as building and operating new power plants.

A.1.2.1 Cost Effectiveness Tests

To estimate economic potential, it is necessary to develop a method by which it can be determined that a measure or program is economic. There is a large body of literature that debates the merits of different approaches to calculating whether a public purpose investment in EE is cost effective (Chamberlin and Herman 1993, RER 2000, Ruff 1988, Stoft 1995, and Sutherland 2000). We usually utilize the total resource cost (TRC) test to assess cost effectiveness. The TRC is a form of societal benefit-cost test. Other tests that have been used in analyses of program cost-effectiveness by EE analysts include the utility cost, ratepayer impact measure (RIM), and participant tests. These tests are discussed in detail the California Standard Practice Manual (CASPM).

Before discussing the TRC test and how it is often used in our DSM forecasts, we present below a brief introduction to the basic tests as described in the CASPM:³

- Total Resource Cost Test—The TRC test measures the net costs of a demand-side management program as a resource option based on the total costs of the program, including both the participants' and the utility's costs. The test is applicable to conservation, load management, and fuel substitution programs. For fuel substitution programs, the test measures the net effect of the impacts from the fuel not chosen versus the impacts from the fuel that is chosen as a result of the program. TRC test results for fuel substitution programs should be viewed as a measure of the economic efficiency implications of the total energy supply system (gas and electric). A variant on the TRC test is the societal test. The societal test differs from the TRC test in that it includes the effects of externalities (e.g. environmental, national security), excludes tax credit benefits, and uses a different (societal) discount rate.
- Participant Test—The participant test is the measure of the quantifiable benefits and costs to
 the customer due to participation in a program. Since many customers do not base their
 decision to participate in a program entirely on quantifiable variables, this test cannot be a
 complete measure of the benefits and costs of a program to a customer.
- Utility (Program Administrator) Test—The program administrator cost test measures the net
 costs of a demand-side management program as a resource option based on the costs
 incurred by the program administrator (including incentive costs) and excluding any net costs
 incurred by the participant. The benefits are similar to the TRC benefits. Costs are defined
 more narrowly.
- Ratepayer Impact Measure Test—The ratepayer impact measure (RIM) test measures what happens to customer bills or rates due to changes in utility revenues and operating costs caused by the program. Rates will go down if the change in revenues from the program is greater than the change in utility costs. Conversely, rates or bills will go up if revenues collected after program implementation are less than the total costs incurred by the utility in implementing the program. This test indicates the direction and magnitude of the expected change in customer bills or rate levels.

 $^{^{3}}$ These definitions are direct excerpts from the California Standard Practice Manual, October 2001.

The key benefits and costs of the various cost-effectiveness tests are summarized in Table A-3.

Table 0-3
Summary of Benefits and Costs of California Standard Practice Manual Tests

Test	Benefits	Costs
TRC Test	Generation, transmission and distribution savings Participants avoided equipment costs (fuel switching only)	Generation costs Program costs paid by the administrator Net participant measure costs
Participant Test	Bill reductions Incentives Participants avoided equipment costs (fuel switching only)	Bill increases Participant measure costs
Utility (Program Administrator) Test	Generation, transmission and distribution savings	Generation costs Program costs paid by the administrator Incentives
Ratepayer Impact Measure Test	Generation, transmission and distribution savings Revenue gain	Generation costs Revenue loss Program costs paid by the administrator Incentives

Generation, transmission and distribution savings (hereafter, energy benefits) are defined as the economic value of the energy and demand savings stimulated by the interventions being assessed. These benefits are typically measured as induced changes in energy consumption, valued using some mix of avoided costs. Electricity benefits are valued using three types of avoided electricity costs: avoided distribution costs, avoided transmission costs, and avoided electricity generation costs.

Participant costs are comprised primarily of incremental measure costs. Incremental measure costs are essentially the costs of obtaining EE. In the case of an add-on device (say, an adjustable-speed drive or ceiling insulation), the incremental cost is simply the installed cost of the measure itself. In the case of equipment that is available in various levels of efficiency (e.g., a central air conditioner), the incremental cost is the excess of the cost of the high-efficiency unit over the cost of the base (reference) unit.

Administrative costs encompass the real resource costs of program administration, including the costs of administrative personnel, program promotions, overhead, measurement and evaluation, and shareholder incentives. In this context, administrative costs are not defined to include the costs of various incentives (e.g., customer rebates and salesperson incentives) that may be offered to encourage certain types of behavior. The exclusion of these incentive costs reflects the fact that they are essentially transfer payments. That is, from a societal perspective they involve offsetting costs (to the program administrator) and benefits (to the recipient).

A.1.2.2 Use of the Total Resource Cost to Estimate Economic Potential

We often use the TRC test in two ways in our model. First, we develop an estimate of economic potential by calculating the TRC of individual measures and applying the methodology described below. Second, we develop estimates of whether different program scenarios are cost effective.

Economic potential can be defined either inclusively or exclusively of the costs of programs that are designed to increase the adoption rate of EE measures. In many of our projects, we define economic potential to exclude program costs. We do so primarily because program costs are dependent on a number of factors that vary significantly as a function of program delivery strategy. There is no single estimate of program costs that would accurately represent such costs across the wide range of program types and funding levels possible. Once an assumption is made about program costs, one must also link those assumptions to expectations about market response to the types of interventions assumed. Because of this, we believe it is more appropriate to factor program costs into our analysis of program potential. Thus, our definition of economic potential is that portion of the technical potential that passes our economic screening test (described below) exclusive of program costs. Economic potential, like technical potential, is a theoretical quantity that will exceed the amount of potential we estimate to be achievable through current or more aggressive program activities.

As implied in Table A-3 and defined in the CASPM 2001, the TRC focuses on resource savings and counts benefits as utility-avoided supply costs and costs as participant costs and utility program costs. It ignores any impact on rates. It also treats financial incentives and rebates as transfer payments; i.e., the TRC is not affected by incentives. The somewhat simplified benefit and cost formulas for the TRC are presented in Equations A-1 and A-2 below.

Equation 0-1

Benefits =
$$\sum_{t=1}^{N} \frac{\text{Avoided Costs of Supply}_{p,t}}{(1+d)^{t-1}}$$

Equation 0-2

$$Costs = \sum_{t=1}^{N} \frac{Program Cost_{t} + Participant Cost_{t}}{(1+d)^{t-1}}$$

Where:

d = the discount rate

p = the costing period

t = time (in years)

n = 20 years

A nominal discount rate is typically used in the analysis, as inflation is taken into account separately.

The avoided costs of supply are calculated by multiplying measure energy savings and peak demand impacts by per-unit avoided costs by costing period. Energy savings are allocated to costing periods and peak impacts estimated using load shape factors.

As noted previously, in the measure-level TRC calculation used to estimate economic potential, program costs are excluded from Equation A-2. Using the supply curve methodology discussed previously, measures are ordered by TRC (highest to lowest) and then the economic potential is calculated by summing the energy savings for all of the technologies for which the marginal TRC test is greater than 1.0. In the example in Table A-4, the economic potential would include the savings for measures 1 and 2, but exclude saving for measure 3 because the TRC is less than 1.0 for measure 3. The supply curve methodology, when combined with estimates of the TRC for individual measures, produces estimates of the economic potential of efficiency improvements. By definition and intent, this estimate of economic potential is a theoretical quantity that will exceed the amount of potential we estimate to be achievable through program activities in the final steps of our analyses.

Table 0-4: Sample Use of Supply Curve Framework to Estimate Economic Potential (Note: Data are illustrative only)

Measure	of Population	Applicable, Not Complete and Feasible Sq.Feet (000s)	Average kWh/ft ² of population	Savings %	GWh Savings	Total Resource Cost Test	Savings Included in Economic Potential?
Base Case: T12 lamps with Magnetic Ballast	425	100,000	4.3	N/A	N/A	N/A	N/A
1. T8 w. Elec. Ballast	425	100,000	4.3	21%	89	2.5	Yes
2. Occupancy Sensors	336	40,000	3.4	10%	13	1.3	Yes
3. Perimeter Dimming	322	10,000	3.2	45%	14	0.8	No
Technical Potential with all measures				27%	116		
Economic Potential with measures for which TRC Ratio > 1.0				24%	102		

A.1.3 Estimation of Program and Naturally occurring Potentials

In this section we present the method we employ to estimate the fraction of the market that adopts each EE measure in the presence and absence of EE programs. We define:

- Program potential as the amount of savings that would occur in response to one or more specific market interventions
- Naturally occurring potential as the amount of savings estimated to occur as a result of normal market forces, that is, in the absence of any utility or governmental intervention.

Our estimates of program potential are typically the most important results of the modeling process. Estimating technical and economic potentials are necessary steps in the process from which important information can be obtained; however, the end goal of the process is better understanding how much of the remaining potential can be captured in programs, whether it would be cost-effective to increase

program spending, and how program costs may be expected to change in response to measure adoption over time.

A.1.3.1 Adoption Method Overview

We use a method of estimating adoption of EE measures that applies equally to be our program and naturally occurring analyses. Whether as a result of natural market forces or aided by a program intervention, the rate at which measures are adopted is modeled in our method as a function of the following factors:

- The availability of the adoption opportunity as a function of capital equipment turnover rates and changes in building stock over time
- Customer awareness of the efficiency measure
- The cost-effectiveness of the efficiency measure
- Market barriers associated with the efficiency measure.

The method we employ is executed in the measure penetration module of DNV GL's DSM ASSYST™ model.

In many of our projects, only measures that pass the measure-level TRC test are put into the penetration module for estimation of customer adoption.

A.1.3.2 Availability

A crucial part of the model is a stock accounting algorithm that handles capital turnover and stock decay over a period of up to 20 years. In the first step of our achievable potential method, we calculate the number of customers for whom each measure will apply. The input to this calculation is the total floor space available for the measure from the technical potential analysis, i.e., the total floor space multiplied by the applicability, not complete, and feasibility factors described previously. We call this the eligible stock. The stock algorithm keeps track of the amount of floor space available for each efficiency measure in each year based on the total eligible stock and whether the application is new construction, retrofit, or replace-on-burnout.⁴

Retrofit measures are available for implementation by the entire eligible stock. The eligible stock is reduced over time as a function of adoptions⁵ and building decay.⁶ Replace-on-burnout measures are available only on an annual basis, approximated as equal to the inverse of the service life.⁷ The annual portion of the eligible market that does not accept the replace-on-burnout measure does not have an opportunity again until the end of the service life.

Replace-on-burnout measures are defined as the efficiency opportunities that are available only when the base equipment turns over at the end of its service life. For example, a high-efficiency chiller measure is usually only considered at the end of the life of an existing chiller. By contrast, retrofit measures are defined to be constantly available, for example, application of a window film to existing glazing.

⁵ That is, each square foot that adopts the retrofit measure is removed from the eligible stock for retrofit in the subsequent year, and remains out of the eligible stock until the end of the measure's useful life.

⁶ Buildings do not last forever. An input to the model is the rate of decay of the existing floor space. Floor space typically decays at a very slow rate.

For example, a base-case technology with a service life of 15 years is only available for replacement to a high-efficiency alternative each year at the rate of 1/15 times the total eligible stock. For example, the fraction of the market that does not adopt the high-efficiency measure in year t will not be available to adopt the efficient alternative again until year t + 15.

New construction applications are available for implementation in the first year. Those customers that do not accept the measure are given subsequent opportunities corresponding to whether the measure is a replacement or retrofit-type measure.

A.1.3.3 Awareness

In our modeling framework, customers cannot adopt an efficient measure merely because there is stock available for conversion. Before they can make the adoption choice, they must be aware and informed about the efficiency measure. Thus, in the second stage of the process, the model calculates the portion of the available market that is informed. An initial user-specified parameter sets the initial level of awareness for all measures. Incremental awareness occurs in the model as a function of the amount of money spent on awareness/information building and how costly it is to reach each customer.

The model also controls for information retention. An information decay parameter in the model is used to control for the percentage of customers that will retain program information from one year to the next. Information retention is based on the characteristics of the target audience and the temporal effectiveness of the marketing techniques employed.

A.1.3.4 Adoption

The portion of the total market this is available and informed can now face the choice of whether or not to adopt a particular measure. Only those customers for whom a measure is available for implementation (stage 1) and, of those customers, only those who have been informed about the program/measure (stage 2), are in a position to make the implementation decision.

In the third stage of our penetration process, the model calculates the fraction of the market that adopts each efficiency measure as a function of the participant test. The participant test is a benefit-cost ratio that is generally calculated as follows:

Equation 0-3

Benefits =
$$\sum_{t=1}^{N} \frac{\text{Customer Bill Savings (\$)}_{t}}{(1+d)^{t-1}}$$

Equation 0-4

$$Costs = \sum_{t=1}^{N} \frac{Participant Costs (\$)_{t}}{(1+d)^{t-1}}$$

Where:

d = the discount ratet = time (in years)N = measure lifetime

The bill reductions are calculated by multiplying measure energy savings and customer peak demand impacts by retail energy and demand rates.

The model uses measure implementation curves to estimate the percentage of the informed market that will accept each measure based on the participant's benefit-cost ratio. The model provides

enough flexibility so that each measure in each market segment can have a separate implementation rate curve. The functional form used for the implementation curves is:

$$y = \frac{a}{\left(1 + e^{-\ln\frac{x}{4}}\right) \times \left(1 + e^{-c\ln(bx)}\right)}$$

where:

- y = the fraction of the market that installs a measure in a given year from the pool of informed applicable customers;
- x = the customer's benefit-cost ratio for the measure;
- a = the maximum annual acceptance rate for the technology;
- b = the inflection point of the curve. It is generally 1 over the benefit-cost ratio that will give a value of 1/2 the maximum value; and
- c = the parameter that determines the general shape (slope) of the curve.

The primary curves utilized in our model are shown in Figure A-3. These curves produce base year program results that are calibrated to actual measure implementation results associated with major IOU commercial efficiency programs over the past several years. Different curves are used to reflect different levels of market barriers for different efficiency measures. A list of market barriers is shown in Table A-5. It is the existence of these barriers that necessitates program interventions to increase the adoption of EE measures.




Figure 0-3: Primary Measure Implementation Curves Used in Adoption Model

Note that for the moderate, high barrier, and extremely high curves, the participant benefit-cost ratios have to be very high before significant adoption occurs. This is because the participant benefit-cost ratios are based on a 15-percent discount rate. This discount rate reflects likely adoption if there were no market barriers or market failures, as reflected in the no-barriers curve in the figure. Experience has shown, however, that actual adoption behavior correlates with implicit discount rates several times those that would be expected in a perfect market.⁸

Table 0-5: Summary Description of Market Barriers from Eto, Prahl, Schlegel 1997

Barrier	Description Or Market Barriers from Eto, Prani, Schieger 1997 Description
Information or Search Costs	The costs of identifying energy-efficient products or services or of learning about energy-efficient practices, including the value of time spent finding out about or locating a product or service or hiring someone else to do so.
Performance Uncertainties	The difficulties consumers face in evaluating claims about future benefits. Closely related to high search costs, in that acquiring the information needed to evaluate claims regarding future performance is rarely costless.
Asymmetric Information and Opportunism	The tendency of sellers of energy-efficient products or services to have more and better information about their offerings than do consumers, which, combined with potential incentives to mislead, can lead to sub-optimal purchasing behavior.
Hassle or Transaction Costs	The indirect costs of acquiring EE, including the time, materials and labor involved in obtaining or contracting for an energy-efficient product or service. (Distinct from search costs in that it refers to what happens once a product has been located.)
Hidden Costs	Unexpected costs associated with reliance on or operation of energy-efficient products or services - for example, extra operating and maintenance costs.
Access to Financing	The difficulties associated with the lending industry's historic inability to account for the unique features of loans for energy savings products (i.e., that future reductions in utility bills increase the borrower's ability to repay a loan) in underwriting procedures.
Bounded Rationality	The behavior of an individual during the decision-making process that either seems or actually is inconsistent with the individual's goals.
Organization Practices or Customs	Organizational behavior or systems of practice that discourage or inhibit cost-effective EE decisions, for example, procurement rules that make it difficult to act on EE decisions based on economic merit.
Misplaced or Split incentives	Cases in which the incentives of an agent charged with purchasing EE are not aligned with those of the persons who would benefit from the purchase.
Product or Service Unavailability	The failure of manufacturers, distributors or vendors to make a product or service available in a given area or market. May result from collusion, bounded rationality, or supply constraints.
Externalities	Costs that are associated with transactions, but which are not reflected in the price paid in the transaction.

8

⁸ For some, it is easier to consider adoption as a function of simple payback. However, the relationship between payback and the participant benefit-cost ratio varies depending on measure life and discount rate. For a long-lived measure of 15 years with a 15-percent discount rate, the equivalent payback at which half of the market would adopt a measure is roughly 6 months, based on the high barrier curve in Figure 2-3. At a 1-year payback, one-quarter of the market would adopt the measure. Adoption reaches near its maximum at a 3-month payback. The curves reflect the real-world observation that implicit discount rates can average up to 100 percent.

Non-externality Pricing	Factors other than externalities that move prices away from marginal cost. An example arises when utility commodity prices are set using ratemaking practices based on average (rather than marginal) costs.
Inseparability of Product Features	The difficulties consumers sometimes face in acquiring desirable EE features in products without also acquiring (and paying for) additional undesired features that increase the total cost of the product beyond what the consumer is willing to pay.
Irreversibility	The difficulty of reversing a purchase decision in light of new information that may become available, which may deter the initial purchase, for example, if energy prices decline, one cannot resell insulation that has been blown into a wall.

The model estimates adoption under both naturally occurring and program intervention situations. There are only two differences between the naturally occurring and program analyses. First, in any program intervention case in which measure incentives are provided, the participant benefit-cost ratios are adjusted based on the incentives. Thus, if an incentive that pays 50 percent of the incremental measure cost is applied in the program analysis, the participant benefit-cost ratio for that measure will double (since the costs have been halved). The effect on the amount of adoption estimated will depend on where the pre- and post-incentive benefit-cost ratios fall on the curve. This effect is illustrated in Figure A-4.




Figure 0-4: Illustration of Effect of Incentives on Adoption Level as Characterized in Implementation Curves

In many of our projects achievable potential EE forecasts are developed for several scenarios, ranging from base levels of program intervention, through moderate levels, up to an aggressive EE acquisition scenario. Uncertainty in rates and avoided costs are often characterized in alternate scenarios. The final results produced are annual streams of achievable program impacts (energy and demand by time-of-use period) and all societal and participant costs (program costs plus end-user costs).

A.1.4 Scenario Analyses

Achievable potential forecasts can be developed for multiple scenarios. For example, program savings can be modeled under low levels of program intervention, through moderate levels, up to an aggressive DSM acquisition scenario. Uncertainty in rates and avoided costs can be characterized in alternate scenarios as well. The final results produced will be annual streams of achievable DSM program impacts (energy and demand by time-of-use period) and all societal and participant costs. An example of the types of outputs that have been produced for similar studies in the past is shown in Table A-6 and Figure A-5.

Table 0-6: Example Format of DSM ASSYST Achievable Potential Outputs

DSM ASSYST Program Output	2006	2007	2008	etc.
Annual Energy Savings (kWh)				
Summer Period Energy Savings (kWh)				
Non Summer Period Energy Savings (kWh)				
Net Annual Energy Savings (kWh)				
Summer Period Net Energy Savings (kWh)				
Non Summer Period Net Energy Savings (kWh)				
Peak Demand Savings (kW)				
Net Peak Demand Savings (kW)				
Annual Program Costs				
Supplemental Customer Costs				




Figure 0-5: Example of DSM Scenario Outputs

A.1.5 Measure "Bundles" for Complex End Uses

Although potential can be estimated through measure-specific analyses for many sectors and end uses, there are some cases where the measure-specific approach becomes problematic because of the complexity or heterogeneity of the base-case energy systems being addressed. Two key examples are industrial processes and some aspects of residential and commercial new construction.

In the industrial case, there may be dozens or even hundreds of individual measures that can be applied to industrial processes throughout the population of industrial facilities in a service territory; however, analyzing each of these opportunities, though possible, is impractical within a resource and time-constrained study such as this one.

In the case of new construction, the problem is sometimes that an equipment substitution paradigm does not fit the real-world circumstances in which efficiency levels are improved. For example, in commercial lighting, virtually all new buildings tend to have electronic ballasts and T-8 lamps, as well as CFLs, and other high-efficiency components. However, the overall lighting system efficiency can often be increased by using these same components in smarter designs configurations or by combining with other features such as daylighting.

For both of these situations, our approach on recent related work has been to bundle multiple individual efficiency measures into somewhat simplified efficiency levels. For example, lighting levels for commercial new construction might be set at 10- and 20-percent improvement over those required by building codes. Similarly, for industrial compressed air systems, we have bundled savings opportunities into three levels where both savings and costs increase with each level. We then estimate an incremental cost for achieving each of the efficiency levels. An example of these results

developed in a recent study for industrial motors, compressed air, and processes in California is shown in Table A-7.

Once the levels efficiency are specified in terms of costs and savings, they are run through the modeling system as if they were individual measures. Thus, cost-effectiveness indicators are calculated for each level, those that pass the TRC are included in the achievable potential forecasting, and adoption is modeled using the same process as described above. Although we recommend using this approach for complex end uses because it creates a manageable forecasting process, care must be taken in developing the levels and recognizing that this approach results in some aggregation bias.

A.2 DSM ASSYST™ Model Description

DSM ASSYST™ (Demand-Side Management Technology Assessment System) is a tool developed to assess the technical, economic and market potential of DSM technologies in the residential, commercial and industrial sectors. Based on user-specified information about base technologies, conservation technologies, load shapes, utility avoided costs, utility service rates, and economic parameters, DSM ASSYST yields numeric data for a variety of criteria. The user can then evaluate and compare technologies. DSM ASSYST allows the user to analyze each DSM technology in multiple combinations of building types, market segments, end uses, and vintages both individually and compared to other DSM technology options.

Table 0-7: Example of Industrial Efficiency Levels Developed for a Recent California Potential Study

DSM ASSYST ADI	DITIVE SUPI	PLY ANALYSIS	Year	2011			
End Use	Measure Number	Vintage: Existing Sector: Industrial Scenario: Base Measure	GWH Savings	MW Savings	Levelized Cost per KWh Saved \$/kWH	Levelized Cost per KW Saved \$/kW	Total Resource Cost Test TRC
Motors	101	Replace 1-5 HP Motor	248.7	34.1	\$0.10	\$698	0.8
Motors	102	Add 1-5 HP VSD	447.1	61.3	\$0.14	\$1,019	0.6
Motors	103	Motor Practices Level 1	607.0	83.2	\$0.06	\$440	1.3
Motors	104	Motor Practices Level 2	539.1	73.9	\$0.24	\$1,764	0.3
Motors	121	Replace 21-50 HP Motor	78.1	10.7	\$0.09	\$661	0.9
Motors	122	Add 21-50 HP VSD	319.0	43.7	\$0.04	\$278	2.1
Motors	123	Motor Practices Level 1	404.3	55.4	\$0.03	\$211	2.7
Motors	124	Motor Practices Level 2	361.9	49.6	\$0.12	\$840	0.7
Motors	151	Replace 201-500 HP Motor	143.5	19.7	\$0.03	\$201	2.8
Motors	152	Add 201-500 HP VSD	516.6	70.8	\$0.01	\$106	5.4
Motors	153	Motor Practices Level 1	598.6	82.0	\$0.02	\$152	3.7
Motors	154	Motor Practices Level 2	554.9	76.0	\$0.08	\$586	1.0
Compressed Air	202	CAS Level 1	433.9	59.5	\$0.02	\$168	3.4
Compressed Air	203	CAS Level 2	453.6	62.2	\$0.05	\$362	1.6
Compressed Air	204	CAS Level 3	325.5	44.6	\$0.13	\$936	0.6
Other Process	301	Process Level 1	1,031.8	141.4	\$0.03	\$190	3.0
Other Process	302	Process Level 2	1,219.7	167.1	\$0.05	\$345	1.7
Other Process	303	Process Level 3	767.3	105.1	\$0.25	\$1,831	0.3

The current version of DSM ASSYST uses a combination of Microsoft Excel spreadsheets and Visual Basic (VB) programming software. All input and output data are stored in spreadsheets. The VB modules read input data from various spreadsheets, perform the various analyses, and store output results into spreadsheets.

There are three major VB analysis modules: Basic, Supply, and Penetration. Figure A-6 provides an overview of the model process and key inputs. Each module is briefly described below.

A.2.1 Basic Module

In the Basic module, each technology is assessed individually by comparing it to a base case. Comparisons are made at a high degree of segmentation. The segmentation may include, but is not limited to sector, building type, end use, vintage and geographic area.

The Basic module reads four types of information, contained within four spreadsheet files. These files include:

- Economic: containing utility rates paid by customers, discount rates, avoided costs, and other utility-specific economic parameters
- Building: containing square footage or number of households and load shape data
- Measure: containing technology based inputs for the Basic Analysis
- Driver: containing information that drives the analysis process.




Figure 0-6: DSM ASSYST Analytic Flow

The output files produced by the Basic module include a Summary Basic Output file that contains an assessment of how much energy and demand each technology will save relative to the base case

within each segment. In addition, the summary contains cost data, savings fractions, before and after EUIs or UECs, service life, the levelized costs of implementing the technology, and results of economic tests including the TRC test, participant test, and customer payback.

This module also produces a second file that contains all the measures that were assessed in the Basic Analysis sorted in the highest to lowest TRC order within each market segment and end use. This file serves as an input file for the Supply module.

A.2.2 Supply Module

In the Supply Module each technology, within each market segment, is stacked, or implemented, such that all energy savings are realized from preceding technologies prior to the implementation of all subsequent technologies. The stacking order generally follows the TRC sort order, highest to lowest, resulting from the Basic module.

The Supply module requires two input files: a Driver file and a modified output file from the Basic module. As in the Basic module, the Driver file contains instructions for the analysis process. The output file from the basic analysis must be modified in Excel to address overlapping measures, such as different SEER levels or measures that are direct substitutes for each other.

Output from the Supply module contains the technical and economic potential plus energy and demand supply curves. The Supply module produces measure-level information that can be incorporated into the input file for the Penetration module.

A.2.3 Penetration Module

The Penetration (or Program Potential) module of ASSYST is designed to calculate the costs and net energy and demand savings from DSM programs under a variety of marketing scenarios. This module estimates the net impact and cost of a program over time by forecasting the naturally occurring penetration of each measure as well as the penetration of each measure given the program activities (i.e., incentives and awareness building).

Using a stock accounting algorithm over a period of 20 years, this module first calculates the number of customers for whom the measure will apply. Second, the model calculates the number of informed customers based on the amount of money spent on advertising. Third, the model calculates the number of customers who will implement the technology based on their benefit/cost ratio. Finally, the model compares the number of customers that implement the technology due to the program with those who would take the technology anyway (naturally occurring). Per-unit energy and demand savings are applied to the net number of customers (total minus naturally occurring) over the 20-year period. After completing the analysis, the results are automatically summed across measures to provide program-level costs and savings for 20 years, and formatted for input into Integrated Resource Planning models.

A program input file is used to define a program and provide the building stock forecast. The program characterization variables include:

- Incentive Levels
- Incentive Budget Constraints
- Yearly Incentive Adjuster
- Technology Acceptance Curve Parameters
- Administration Budgets
- Advertising Budgets
- Awareness Decay Rate
- Advertising Effective Ratio.

B MEASURE DESCRIPTIONS

This appendix describes the energy efficiency measures used in the study.

B.1 Residential Measures

This subsection provides brief descriptions of the residential electric measures included in this study. Measures are grouped by end use.

B.1.1HVAC Equipment

Central air conditioner upgrade: Air conditioner equipment includes a compressor, an air-cooled or evaporatively-cooled condenser (located outdoors), an expansion valve, and an evaporator coil (located in the supply air duct near the supply fan). Cooling efficiencies vary based on the quality of the materials used, the size of equipment, the condenser type, and the configuration of the system. Central air conditioners may be of the unitary variety (all components housed in a factory-built assembly) or be a split system (an outdoor condenser section and an indoor evaporator section connected by refrigerant lines and with the compressor at either the outdoor or indoor location). Efficient air conditioner measures involve the upgrade of a standard efficiency unit (13 SEER) to a higher efficiency unit (14 SEER or higher), assuming quality installation.

Central air conditioner early replacement: For this measure we assume replacement of an older central air conditioner (11 SEER) with a new high-efficiency unit (14 SEER). Energy savings are diminished to account for the fact that a fraction of the associated energy savings would have been realized at the end of the older unit's useful life, when a minimum EER unit would have been purchased as a replacement.

Heat pump upgrade: Air-source heat pumps transfer heat from the outside air to the inside of a building or vice versa, providing both heating and cooling. We consider a 15 SEER/8.2 HSPF replacement and a 16 SEER/8.7 HSPF replacement. We consider both a replace-on-burnout measure and an early replacement measure.

AC maintenance: The efficiency of a central air conditioner can be reduced if the unit is not properly maintained. This group of measures includes both indoor and outdoor coil cleaning, as well as other standard efficiency practices such as filter replacement.

Proper refrigerant charging and air flow: This measure involves diagnostic and repair services for existing central air conditioners to improve their efficiency. Inspection and services of AC systems involves checking the refrigerant level, cleaning the coils, cleaning the blower, cleaning or replacing filters, and making sure air is flowing properly through the system.

High efficiency room air conditioner: Window (or wall) mounted room air conditioners are designed to cool individual rooms or spaces. This type of unit incorporates a complete air-cooled refrigeration and air-handling system in an individual package. Cooled air is discharged in response to thermostatic control to meet room requirements. Each unit has a self-contained, air-cooled direct expansion (DX) cooling system and associated controls. Room air conditioners are rated by energy efficiency ratio (EER), which is cooling output divided by power consumption. The efficient room air conditioner measure involves the upgrade of a standard efficiency unit (10.6 EER) to a higher efficiency unit (EER 10.8 or 11.3).

Room air conditioner early replacement: For this measure we assume replacement of an older room air conditioner (EER 9.7) with a new high-efficiency unit (EER 11.3). Energy savings are diminished to account for the fact that a fraction of the associated energy savings would have been realized at the end of the older unit's useful life, when a minimum EER unit would have been purchased as a replacement.

High-efficiency dehumidifier: ENERGY STAR® qualified dehumidifiers use less energy to remove moisture from the air on account of more efficient refrigeration coils, fans, and compressors. Savings are compared to a unit meeting the minimum federal standard.

Ceiling fans: ENERGY STAR® Ceiling Fans save energy through improved motors and blade designs. Ceiling fans save energy from space conditioning in the summer by creating a wind chill, and during the winter by distributing hot air evenly throughout the room.

Variable speed furnace/AC fans: Air handler models with the lowest electrical use ratings employ electronically commutated motors (ECMs). ECMs, also known as brushless DC motors or variable speed blower motors, have two principal advantages over the typical permanent-magnet split capacitor (PSC) blower motors found in the majority of air handlers. First, ECMs are claimed to be 20% to 30% more efficient than standard blower motors. Second, the typical ECM blower can produce a much wider range of airflow than a PSC blower, which typically has only three or four set speeds over a fairly narrow range. Because power consumption by an air handler rises with the cube of airflow, the ability to reduce airflow when appropriate can dramatically reduce the electrical power draw by the air handler.

Proper sizing and quality install: Most HVAC systems are typically over-sized by contractors for a variety of reasons: as a precaution against peak day temperatures or future problems from duct leaks, improper flow across the coils, and improper charge, or because they replace older systems with the same size (or larger) unit – even though the house may have been made more energy efficient since it was originally constructed (through home improvements, window replacements, insulation, caulking, and so on). Oversized air conditioners will be more expensive and tend to cycle, rather than run continuously, during both typical and peak cooling periods. This more frequent cycling reduces overall operating efficiency and also results in more variable indoor humidity levels. This measure assumes the contractor performs an Air Conditioning Contractors of America (ACCA) Manual J calculation to size the HVAC system and an ACCA Manual D calculation to size the ducts. These calculations take into account climate, house and site characteristics and orientation, air exchange rates, occupancy, and heat-emitting appliances. Since our central air conditioner upgrade measure includes quality installation, this measure applies only to the installation of standard efficiency equipment.

Programmable thermostat: ENERGY STAR® programmable thermostats come pre-programmed with settings intended to deliver energy savings without sacrificing comfort. The settings vary for the cooling and heating months, with specific temperature ranges and setback points for the morning, daytime, evening, and night. Programmable thermostat settings may also be changed to reflect individual schedules and preferences.

B.1.2 Building Envelope

Duct repair: An ideal duct system would be free of leaks, especially when the ducts are outside the conditioned space. Leakage in unsealed ducts varies considerably with the fabricating machinery used, the

methods for assembly, installation workmanship, and age of the ductwork. To seal ducts, a wide variety of sealing methods and products exist. Care should be taken to tape or otherwise seal all joints to minimize leakage in all duct systems and the sealing material should have a projected life of 20 to 30 years. Current duct sealing methods include use of computer-controlled aerosol and pre- and post-sealing duct pressurization testing.

Duct insulation: Insulation material inhibits the transfer of heat through the air-supply duct. Several types of ducts and duct insulation are available, including flexible duct, pre-insulated flexible duct, duct board, duct wrap, tacked or glued rigid insulation, and water proof hard shell materials for exterior ducts. Duct insulation for existing construction involves wrapping un-insulated ducts with an R-4 insulating material.

ENERGY STAR® windows: Windows which meet the ENERGY STAR® requirements have U-value and solar heat gain coefficients (SHGC) specified by climate zone, and are certified by the National Fenestration Rating Council (NFRC). These are modeled as a replace on burnout measure, so the costs are not the full cost of the window and installation, but rather the cost compared to installing a new non-ENERGY STAR® window.

Comprehensive shell air sealing - infiltration reduction: Professional installation of weather stripping, caulking, and expanding foam insulation aided by a blower door test. These measures reduce energy consumption by improving the tightness of the building shell and limiting heat gain and loss.

Self-install weatherization: Installation of weather stripping, caulking, and expanding foam insulation from a spray can to fix easily found leaks and reduce air infiltration, completed by the homeowner.

Ceiling and floor insulation: Thermal insulation is material or combinations of materials that are used to inhibit the flow of heat energy by conductive, convective, and radiative transfer modes. By inhibiting the flow of heat energy, thermal insulation can conserve energy by reducing heat loss or gain of a structure. An important characteristic of insulating materials is the thermal resistivity, or R-value. The R-value of a material is the reciprocal of the time rate of heat flow through a unit of this material in a direction perpendicular to two areas of different temperatures.

Basement insulation: Basement walls are typically insulated by constructing a stud wall inside the house foundation, and insulating it as any interior wall. This increases the cost of basement insulation compared to crawlspace insulation (in addition to the taller wall height to be insulated). The cost-effectiveness of basement insulation depends on whether the basement will be conditioned. Basement insulation includes rim joist insulation.

Wall insulation: For existing construction, this measure involves adding R-13 insulation to un-insulated walls. This is usually accomplished by drilling holes into the building's siding or interior walls and blowing in insulation material.

B.1.3 Lighting

Compact fluorescent lighting (CFLs): Compact fluorescent lamps are designed to replace standard incandescent lamps. They are approximately four times more efficient than incandescent light sources.

Screw-in modular lamps have reusable ballasts that typically last the life of four lamps. This study takes into account recently enacted Federal standards under the Energy Policy and Conservation Act. The standards mandate an increase in efficiency of approximately 30% for the majority of residential incandescent light bulbs using a phased approach, beginning with 100 watt bulbs in 2012 and ending with 40 watt bulbs in 2014. It was that this would result in a shift to a high efficiency incandescent lamps baseline for the specified bulb types.

LED general purpose lighting: A light emitting diode (LED) is a solid state lighting (SSL) technology that produces light by passing electrons through a semiconductor material, which is mounted on a heat sink and encased in a lens. Each LED is 7 mm to 9 mm on a side, and typically mounted in arrays on a circuit board, which is in turn mounted on another heat sink and encased in a fixture or bulb. This technology is revolutionizing the field in terms of light quality, energy efficiency, and design. However, poor manufacture has led to a range of problems in early products, notably color degradation and prematurely dimmed diodes from under-performing heat sinks, and "burnt out" diodes from faulty circuit boards. ENERGY STAR® provides rigorous standards to certify quality LED lighting fixtures, which are commercially available and currently rebated in numerous energy efficiency programs, and has recently completed an LED bulb specification around which products are being rapidly developed. LED general purpose lighting is applied as a measure to both high efficiency incandescent lighting and to base CFLs.

Super T-8 lamps with electronic ballasts: T-8 lamps are a smaller diameter fluorescent lamp than T-12 lamps. When paired with specially designed electronic ballasts, T-8 lamps provide more lumens per watt, resulting in energy savings. Electronic ballasts replace the standard core and coil technology in magnetic ballasts with solid-state components. This technology allows for more consistent control over ballast output and converts power to higher frequencies, causing the fluorescent lamps to operate more efficiently. For existing first generation T-8 systems, this measure is specified as an upgrade to efficiency levels associated with optimal Super T-8 lamp-ballast combinations on a replace-on-burnout basis.

Photocell/time clock (outdoor lighting): Photocells automatically turn off lights when the sensor detects enough ambient light. Used on outdoor fixtures, photocells ensure that the lamp is turned off during daylight hours. Photocells can be combined with other lighting controls, such as motion sensors or time clocks. Time clocks are devices that can be programmed to turn lights on and off according to a set schedule.

B 1 4 Water Heat

Heat pump water heater: Air-to-water heat pump water heaters extract low-grade heat from the air then transfer this heat to the water by means of an immersion coil. This is the most commonly utilized residential heat pump water heater. The air-to-water heat pump unit includes a compressor, air-to-refrigerant evaporator coil, evaporator fan, water circulating pump, refrigerant-to-water condenser coil, expansion valve, and controls. Residential heat pump water heaters replace base electric units with the same tank capacities.

Early replacement water heater to heat pump water heater: For this measure we assume replacement of an older water heater with a heat pump water heater as a retrofit measure. Energy savings are diminished to account for the fact that a fraction of the associated energy savings would have been realized

at the end of the older unit's useful life, when a new unit meeting current standards would have been purchased.

High efficiency water heater: Higher efficiency water heaters have greater insulation to reduce standby heat loss.

Solar water heater: Heat transfer technology that uses the sun's energy to warm water. Solar water heaters preheat water supplied to a conventional domestic hot water heating system. The energy savings for the system depend on solar radiation, air temperatures, water temperatures at the site, and the hot water use pattern.

Tankless water heater: Also known as "instant" or "on-demand" water heaters, tankless units function only when a hot water faucet is turned on. There is no energy required to maintain the temperature of the water in a tank, eliminating standby losses.

Drain water heat recovery (GFX): Gravity film exchange (GFX) drain-water heat recovery systems consist of a copper pipe for incoming cold water coiled tightly around a copper drain-water pipe. When water goes down the drain, it doesn't drop straight down as though poured from a spout, but rather falls against the side of the pipe. This phenomenon allows the GFX unit to easily re-capture some of this energy, as heat is transferred through the copper pipes to the incoming water supply going to the water heater.

Hot water temperatures turndown: Many residential water heaters are set well above the recommended 120 degrees Fahrenheit. Turning down the setpoint will save energy, and, depending on the original temperature, may also improve resident safety.

Low-flow showerhead: Many households are still equipped with showerheads using 3+ gallons per minute. Low flow showerheads can significantly reduce water heating energy for a nominal cost. Typical low-flow showerheads use 1.0-2.5 gallons per minute compared to conventional flow rate of 3.5-6.0 gallons per minute. The reduction in shower water use can substantially lower water heating energy use since showering accounts for about one-fourth of total domestic hot water energy use.

Pipe wrap: Thermal insulation is material or combinations of materials that are used to inhibit the flow of heat energy by conductive, convective, and radiative transfer modes. By inhibiting the flow of heat energy, thermal insulation can conserve energy by reducing heat loss or gain.

Faucet aerators: Water faucet aerators are threaded screens that attach to existing faucets. They reduce the volume of water coming out of faucets while introducing air into the water stream. A standard nonconserving faucet aerator has a typical flow rate of 3-5 gallons per minute. A water-saving aerator can reduce the flow to 1-2 gallons per minute. The reduction in the flow rate will lower hot water use and save energy (kitchen and bathroom sinks utilize approximately 7 percent of total domestic hot water energy use).

B.1.5 Appliances

High efficiency refrigerator: We model both an ENERGY STAR® and a CEE Tier 2 refrigerator. ENERGY STAR® refrigerators must exceed the stringent July 1, 2001 minimum federal standards for refrigerator

energy consumption by at least 10%. As specified for this study, the average efficiency improvement is 20% for ENERGY STAR® and 25% for CEE Tier II. An energy efficient refrigerator/freezer is designed by improving the various components of the cabinet and refrigeration system. These component improvements include cabinet insulation, compressor efficiency, evaporator fan efficiency, defrost controls, mullion heaters, oversized condenser coils, and improved door seals.

Early replacement refrigerator: We model an ENERGY STAR® refrigerator as an early replacement measure. Energy savings are diminished to account for the fact that a fraction of the associated energy savings would have been realized at the end of the older unit's useful life, when a minimum efficiency unit would have been purchased as a replacement.

Refrigerator/freezer recycling: For this measure we assume replacement of an older refrigerator (10 years old or more) with a new standard-efficiency refrigerator. The early replacement assumes that the same new refrigerator would have been bought, only six years later. Savings for this measure result for six years because the newer refrigerators, given the stringent efficiency standards implemented in 2001, use much less energy than older units.

High efficiency freezer: Stand-alone freezers include either upright or chest models. Efficient freezers should exceed standard efficiencies by 10 percent or more. As specified for this study, the average efficiency improvement is 15 percent.

Early replacement freezer: We also model an ENERGY STAR® freezer as an early replacement measure. Energy savings are diminished to account for the fact that a fraction of the associated energy savings would have been realized at the end of the older unit's useful life, when a minimum efficiency unit would have been purchased as a replacement.

ENERGY STAR® dishwasher: ENERGY STAR® labeled dishwashers save by using both improved technology for the primary wash cycle, and by using less hot water to clean. They include more effective washing action, energy efficient motors and other advanced technology such as sensors that determine the length of the wash cycle and the temperature of the water necessary to clean the dishes.

High efficiency clothes washer: A standard clothes washer uses various temperatures, water levels, and cycle durations to wash clothes depending on the clothing type and size of the laundry load. A high-efficiency vertical-axis clothes washer, which eliminates the warm rinse option and utilizes a spray technology to rinse clothes, can significantly reduce washer-related energy. Such machines also utilize a spin cycle that eliminates more water from the clothes than conventional clothes washers and are generally driven by more efficient motors. A horizontal axis clothes washer utilizes a cylinder that rotates horizontally to wash, rinse, and spin the clothes. These types of washing machines can be top loading or front loading, and utilize significantly less water (hot and cold) than the standard vertical axis machines. A vertical axis machine generally fills the tub until all of the clothes are immersed in water. In contrast, the horizontal axis machine only requires about one third of the tub to be full, since the rotation of the drum around its axis forces the clothes into the water and thus can drastically reduce the total energy use for washing. These machines are also easier on clothes and use less detergent.

High efficiency clothes dryer: High efficiency clothes dryers incorporate moisture sensors and prevent the frequency and magnitude of over-drying compared to clothes dryers without moisture sensors. The Federal minimum Energy Factor (pounds of clothing per kilowatt hour) is 3.01, and does not vary widely between models currently on the market.

Heat pump clothes dryer: These clothes dryers are sometimes referred to as "ventless" dryers because the warm, moist process air is passed in a closed-loop cycle from the tumbler through a heat pump. The refrigerant first takes energy out of the process air sufficient to cool it to the ambient dew point in order to condense any water vapor, which is then drained. Then the cycle transfers heat back into the dehumidified process air, which is passed into the clothes tumbler, and the cycle repeats.

B.1.6 Home Electronics

ENERGY STAR® home electronics (televisions, set-top boxes, DVD players, laptop and desktop computers): ENERGY STAR® qualified home electronics have off-mode power draws of 1 watt or less. Some home electronic devices spend the vast majority of their time in off-mode but often continue to draw a small "trickle charge" to maintain clock or other memory functions. Reductions in off-mode power draws can thus produce significant reductions in total energy consumption without changing on-mode power consumption characteristics. In addition, some products, such as TVs and computers, have active mode power requirements. Savings from ENERGY STAR® home electronics considered in this study were estimated based data from the Environmental Protection Agency.

Smart power strip: These power strips use a variety of controls to reduce standby power consumption of home electronics, including timers, occupancy sensors, and secondary outlets which automatically turn off in tandem with a pre-specified outlet.

B.1.7 Whole House Measures

Behavioral conservation: Indirect feedback approaches utilize energy information report mailers that motivate customers to use less, while direct feedback interventions use in-home energy-use monitors.

Residential new construction: The Environmental Protection Agency's ENERGY STAR® Homes Program sets efficiency requirements for new homes. To earn the ENERGY STAR label, homes must be at least 15% more energy efficient than homes built to the 2004 International Residential Code (IRC), and include additional energy-saving features that typically make them 20–30% more efficient than standard homes.

B.1.8 Other Fnd Uses

Variable-speed pool pump: This measure saves energy much in the same way as two-speed pool pumps, with the exception that variable-speed pumps are able to further optimize pump operation and pool water flows to match the specific needs and requirements of individual owners.

B.2 Commercial Measures

This subsection provides brief descriptions of the commercial measures included in this study.

B.1.1. Lighting

Super T-8 lamps with electronic ballast: T-8 lamps are a smaller diameter fluorescent lamp than T-12 lamps. When paired with specially designed electronic ballasts, T-8 lamps provide more lumens per watt, resulting in energy savings. Electronic ballasts replace the standard core and coil technology in magnetic ballasts with solid-state components. This technology allows for more consistent control over ballast output and converts power to higher frequencies, causing the fluorescent lamps to operate more efficiently. For existing first generation T-8 systems, this measure is specified as an upgrade to efficiency levels associated with optimal Super T-8 lamp-ballast combinations on a replace-on-burnout basis.

T-5 high-output lighting with electronic ballast: Like T8 lamps, straight tube T5 lamps are available in nominal 2', 3', 4', and 5' lengths. Standard T-5 lamps have light output and efficiency comparable to T-8/electronic ballast systems. High output T-5 lamps have considerably higher light output: a 1-lamp high output T-5 cross-section can replace a 2-lamp T-8 cross-section. The 5/8" bulb diameter of the T-5 lamp lends itself to low profile luminaires well-suited for cove lighting and display case lighting. Its smaller scale allows for sleeker fluorescent indirect and direct/indirect pendants and shallower profile recessed troffer type luminaires. Because of variances in actual lamp lengths and a different socket design, the T-5 lamp cannot easily be retrofitted in existing T-12 and T-8 luminaires. Consequently, use the T-5 lamp to its best advantage in specially designed luminaires.

Induction lamps: The primary difference between induction lighting and conventional fluorescent lamps is that induction lighting does not have an electrical connection going inside the glass bulb (electrodeless). Instead, energy is transferred wirelessly into the glass envelope via electromagnetic induction. Induction lamps typically take the place of HID lamps. Their advantage is both long life and quick start, which unlike HID lamps, allows them to be turned off and on with the demand. Although induction lamps have a longer service life than other lamp technology they are also more expensive. They are most often used in places where the lamps are difficult to reach and replace. Induction lamps have very long lifetimes (100,000 hours), excellent color rendering, and perform well in a wide temperature range. They have better lumen maintenance than HID lamps. Our study looks at two applications for induction lighting--high bay lighting and streetlighting.

Pulse-start metal halide lamps: Pulse start lamps have a greater light output than standard metal halide, provide a white light and require special ballasts and fixtures for each specific lamp. The pulse start metal halide combined with new, more efficient low current crest factor ballasts using high voltage igniters provides higher light levels initially (20% more) and significantly more maintained light over time (40% more) than today's standard metal halide.

Compact fluorescent lighting (CFLs): Compact fluorescent lamps are designed to replace standard incandescent lamps. They are approximately four times more efficacious than incandescent light sources. Screw-in modular lamps have reusable ballasts that typically last for four lamp lives.

Lighting control tune-up: This involves various measures to optimize the customer's current lighting control systems, with measures such as: relocating/tuning occupancy sensors, relocating photocells, optimizing sweep timers, repairing lighting timers, and adjust lighting schedules.

Occupancy sensors: Occupancy sensors (infrared or ultrasonic motion detection devices) turn lights on upon entry of a person into a room, and then turn the lights off from ½ minute to 20 minutes after they have left. Occupancy sensors require proper installation and calibration. Their savings depend on the mounting type.

Outdoor lighting controls (photocells and timeclocks): Photocells can be used to automatically control both outdoor lamps and indoor lamps adjacent to skylights and windows. When lights do not need to be on all night, a photocell in series with a time clock provides maximum savings and eliminates the need for manual operation and seasonal time clock adjustments. Time clocks enable users to turn on and off electrical equipment at specific times during the day or week.

LED lighting: A light emitting diode (LEDs) is a semiconductor light source. They have been use for many years in niche application (such as indicator lights), but it was not until the late 1990's that high-output white LEDs became feasible. Over the last decade, LEDs have begun appearing in a variety of illumination applications. LEDs have the potential to be more efficient than fluorescent lighting, although efficacy varies widely between products (but in general continues to improve). They have long lifetimes (about 50,000 hours), are shock resistant and dimmable, can be cycled rapidly, and they perform well in low temperatures. The light from LEDs is highly directional, creating challenges for luminaire design, which is reflected in highly variable luminaire performance. This study considers LED lighting as a measure for indoor lighting, outdoor lighting, and streetlighting

LED technology, both in the LEDs themselves and in luminaire design, continues to change rapidly. In certain applications (architectural lighting, undercabinet lighting, streetlighting), highly effective LED products are available and competitive on a life-cycle-cost basis with incandescent and fluorescent technologies. LED products are rapidly becoming competitive in other applications.

LED exit sign: Exit signs were an early application of LED technology. Since exit signs are typically red or green, colored LEDs could be used directly, without the colored filter necessary when using a white light source. LED exit signs require significantly less maintenance than incandescent or CFL exit sign. Even a CFL would need to be replaced every year or two, while an LED sign could go without maintenance for up to 10 years. Because exit signs are operated continuously, the energy savings are significant.

Bi-level outdoor lighting controls: Bi-level lighting is designed to operate at a minimum level of light output until occupancy is detected (e.g. through a motion sensor), then temporarily increase to a higher level of illumination.

High performance lighting retrofit/replacement: Because of the interaction between lighting measures (daylighting, controls, etc.), the costs and benefits may not be additive. We allocate a percent of the applicable stock to comprehensive lighting retrofits, at a 25 percent savings level.

B.2.2 Space Cooling

Chiller efficiency upgrade: Centrifugal chillers are used in building types which normally use water-based cooling systems and have cooling requirements greater than 200 tons. Centrifugal chillers reject heat through a water cooled condenser or cooling tower. In general, efficiency levels for centrifugal chillers start at 0.80 kW/ton (for older units) and may go as high as 0.4 kW/ton. This measure involves installation of a

high-efficiency chiller (0.51 kW per ton) versus a standard unit (0.58 kW per ton). This measure also serves in the potential analysis as a proxy for other non-centrifugal chiller systems.

High-efficiency chiller motors: This measure involves replacement of standard efficiency motors that power compressor systems on chillers. High-efficiency chiller motors have typically have efficiencies exceeding 90% and are typically electronically-commutated motors, which produce higher average operating efficiencies at partial loads compared to standard efficiency, brushed DC compressor motors.

VSD – cooling circulation pumps: Variable speed drives installed on chilled water pumps can reduce energy use by varying the pump speed according to the building's demand for cooling. There is also a reduction in piping losses associated with this measure, which can have a major impact on the heating loads and energy use for a building. Pump speeds, however, can generally only be reduced to a minimum specified rate, because chillers and the control valves may require a minimum flow rate to operate.

VSD – cooling tower fans: Energy usage in cooling tower fans can be reduced by installing electronic variable speed drives (VSDs). VSDs are a far more efficient method of regulating speed or torque than other control mechanisms. Energy required to operate a fan motor can be reduced significantly during reduced load conditions by installing a VSD.

Chiller tune-up/diagnostics: In addition to some of the activities conducted in a DX tune-up, an optimization of the chilled water plant can include activities such as: optimizing CW/CHW set points, improving chiller staging, trimming pump impellers, resetting chilled water supply temperature, and staging cooling tower fan operation.

Energy management system: The term Energy Management System (EMS) refers to a complete building control system which usually can include controls for both lighting and HVAC systems. The HVAC control system may include on\off scheduling and warm-up routines. The complete lighting and HVAC control systems are generally integrated using a personal computer and control system software.

Cool roof: The color and material of a building structure surface will determine the amount of solar radiation absorbed by that surface. By using an appropriate reflective material to coat the roof, the roof will absorb less solar radiation and consequently reduce the cooling load.

DX packaged system efficiency upgrade: A single-package A/C unit consists of a single package (or cabinet housing) containing a condensing unit, a compressor, and an indoor fan/coil. An additional benefit of package units is that there is no need for field-installed refrigerant piping, thus minimizing labor costs and the possibility of contaminating the system with dirt, metal, oxides or non-condensing gases. We look at two efficiency levels, EERs of 1 10.9 and an EER 13.4, compared to a base case unit with EER=10.3.

Tune up/advanced diagnostics: The assumed tune-up includes cleaning the condenser and evaporator coils, establishing optimal refrigerant levels, and purging refrigerant loops of entrained air. The qualifying relative performance range for a tune-up is between 60 and 85 percent of the rated efficiency of the unit. This measure includes fresh air economizer controls providing demand control ventilation and consisting of a logic module, enthalpy sensor(s), and CO2 sensors in appropriate applications.

Window film: Reflective window film is an effective way to reduce solar energy gains, thus reducing mechanical cooling energy consumption. Windows affect building energy use through thermal heat transfer (U-value), solar heat gains (shading coefficient), daylighting (visible light transmittance), and air leakage.

Programmable thermostat: Setback programmable thermostats are appropriate controls for HVAC equipment that serve spaces with regular occupied and unoccupied periods, resulting in long periods of time when heating and cooling set points can be adjusted.

Roof / ceiling insulation: Thermal insulation is material or combinations of materials that are used to inhibit the flow of heat energy by conductive, convective, and radiative transfer modes. By inhibiting the flow of heat energy, thermal insulation can conserve energy by reducing heat loss or gain of a structure. An important characteristic of insulating materials is the thermal resistance, or R-value. The R-value of a material is the reciprocal of the time rate of heat flow through a unit of this material in a direction perpendicular to two areas of different temperatures.

Installation of air-side economizers: Air-side economizers reduce the energy consumption associated with cooling by providing access to outside air – when temperatures permit – in lieu of using mechanical cooling of recirculated indoor air. We specifically consider a dual-enthalpy economizer replacing a dry-bulb economizer.

Duct insulation: Insulation material inhibits the transfer of heat through air supply ducts or hot water pipes. Several types of ducts and duct insulation are available, including flexible duct, pre-insulated flexible duct, duct board, duct wrap, tacked or glued rigid insulation, and water proof hard shell materials for exterior ducts.

Duct repair and sealing: An ideal duct system would be free of leaks, especially when the ducts are outside the conditioned space. Leakage in unsealed ducts varies considerably with the fabricating machinery used, the methods for assembly, installation workmanship, and age of the ductwork. To seal ducts, a wide variety of sealing methods and products exist. Care should be taken to tape or otherwise seal all joints to minimize leakage in all duct systems and the sealing material should have a projected life of 20-30 years. Current duct sealing methods include use of computer-controlled aerosol and pre- and post-sealing duct pressurization testing.

Heat pump upgrade: Air-source heat pumps transfer heat from the outside air to the inside of a building or vice versa, providing both heating and cooling. We consider a 15 SEER, 8.2 HSPF heat pump.

Geothermal heat pump: A geothermal, or ground-source, heat pump operates on the same principle as more common air-source heat pumps. But unlike air-source heat pumps, which transfers heat to or from the outside air, geothermal heat pumps exchange heat with the ground. Underground temperatures maintain a relatively constant temperature throughout the year, especially compared to air temperatures, which increases the system efficiency compared to an air-source heat pump. Because the system relies on extensive subterranean piping for heat exchange, geothermal heat pumps are expensive to install, and installation opportunities in existing buildings are limited.

High efficiency packaged terminal air conditioner: A packaged terminal air conditioner (PTAC) is a self-contained heating and air conditioning system commonly found in hotels. High efficiency units are available, offering significant energy savings in the lodging industry.

Hotel room controllers: Large amounts of energy are wasted in the lodging industry heating, cooling, and lighting unoccupied hotel room. Hotel guest room energy management control systems use occupancy sensors to determine whether anyone is present in the room, and adjusts the HVAC settings for energy savings when the room is empty.

B.2.3 Ventilation

Motor efficiency upgrade: Premium-efficiency motors use additional copper to reduce electrical losses and better magnetic materials to reduce core losses, and are generally built to more precise tolerances. Consequently, such motors are more reliable, resulting in reduced downtime and replacement costs. Premium-efficiency motors may also carry longer manufacturer's warranties.

VFD on motor installation: Energy usage in HVAC systems can be reduced by installing electronic variable frequency drives (VFDs) on ventilation fans. VFDs are a far more efficient method of regulating speed or torque than throttling valves, inlet vanes and fan dampers. Energy required to operate a fan motor can be reduced as much as 85% during reduced load conditions by installing a VFD.

Installation of demand-controlled ventilation (via occupancy sensors, CO2 sensors, etc.): Often, usage of a building's ventilation control goes beyond what is necessary to maintain a healthy and comfortable environment. A variety of controls can save energy by limiting the use of the ventilation system to minimum amount necessary. Sensors that detect critical contaminants activate ventilations systems only when necessary. Occupancy sensors limit the operation ventilation systems to periods when the building is in use.

Air handler optimization: Optimization of a building's air-handling system is concerned principally with the proper sizing and configuration of its HVAC units. Energy savings can result from a variety of improvements, including reduced equipment loads and better functionality of existing equipment.

Electronically commutated motors (ECM) on air-handler unit: Air handler models with the lowest electrical use ratings employ ECMs. ECMs, also known as brushless DC motors or variable speed blower motors, have two principal advantages over the typical permanent magnet split capacitor (PSC) blower motors found in the majority of air handlers. First, ECMs are claimed to be 20% to 30% more efficient than standard blower motors. Second, the typical ECM blower can produce a much wider range of airflow than a PSC blower, which typically has only three or four set speeds over a narrow range. Because power consumption by an air handler rises with the cube of airflow, the ability to reduce airflow when appropriate can dramatically reduce the electrical power draw by the air handler.

Energy recovery ventilation: These systems provide a controlled way of ventilating a building while minimizing energy loss. Heating energy requirements are reduced during the winter season by transferring

heat from the warm inside air being exhausted to the fresh (but cold) supply air. Similarly, in the summer, the inside air being exhausted cools the warmer supply air and reduces cooling energy requirements.

Separate makeup air/exhaust hoods: Ventilation requirements in restaurants and grocery stores are driven both by occupancy and by the need to exhaust fumes from food preparation activities. Standard ventilation and exhaust systems operate at constant speeds that are most often matched to maximum ventilation requirements. Systems that modulate both exhaust and make-up air flow rates in response to measurements of "smoke" and temperature in the exhaust hood reduce exhaust and make-up air flow rates when full exhaust capacity is not required, and can thereby produce significant reduction in fan power and space conditioning energy use.

B.2.4. Refrigeration

Motor efficiency upgrade for fans and compressors: In addition to saving energy, premium-efficiency motors are more reliable, resulting in reduced downtime and replacement costs.

Strip curtains: Installing strip curtains on doorways to walk-in boxes and refrigerated warehouses can produce energy savings due to decreased infiltration of outside air into the refrigerated space. Although refrigerated spaces have doors, these doors are often left open, for example during product delivery and store stocking activities.

Night covers: Installing film or blanket type night covers on display cases can significantly reduce the infiltration of warm ambient air into the refrigerated space. This reduction in display case loads in turn reduces the electric use of the central plant, including compressors and condensers, thus saving energy. The target market for this measure is small, independently owned grocery stores and other stores that are typically closed at night and restock their shelves during the day. The target cases are vertical displays, with a single- or double-air curtain, and tub (coffin) type cases.

Auto door closers for walk-ins and reach-ins: Auto door closers minimize air infiltrations in walk-in and reach-in refrigerators and freezers.

Variable speed compressor retrofit: A variable speed compressor is a screw or reciprocating compressor whose current is modulated by a frequency inverter. A controller senses the compressor suction pressure and modulates the current and therefore the motor speed in response to changes in this pressure. When low load conditions exist, the current to the compressor motor is decreased, decreasing the compressor work done on the refrigerant.

Floating head pressure controls: Floating head pressure controls allow a refrigeration system to operate under lower condensing temperature and pressure settings, where compressor operation is most efficient, working against a relatively low head pressure. The condensing temperature is allowed to float below the design set point of, say, 95 deg. F under lower outdoor temperatures, which in-turn lowers the condensate pressure. In a conventional system a higher fixed condensing temperature set point is used which results in a lowered capacity for the system, requires extra power, and may overload the compressor motor. Energy savings can be realized if the refrigeration system head pressure is allowed to float during periods of low ambient temperature, when the condensing temperature can be dramatically reduced.

Refrigeration commissioning: Refrigeration commissioning refers to a process whereby refrigeration systems are subject to inspection on a variety of criteria to ensure efficiency. The commissioning process can involve tests that cover a system's controls for humidity and temperature, anti-condensation, and heat recovery, among others.

Demand defrost: Defrost of a refrigeration system is critical to its efficient operation. Demand defrost uses a pressure-sensing device to activate the defrost cycle when it detects a significant drop in pressure of the air across the refrigeration coil. Because load during defrost can be three times that of normal operation, defrosting on demand only – not when an individual operator deems it necessary – can save energy by minimizing the amount of time spent on defrosting.

Humidistat controls: A humidistat control is a control device to turn refrigeration display case anti-sweat heaters off when ambient relative humidity is low enough that sweating will not occur. Anti-sweat heaters evaporate moisture by heating the door rails, case frame and glass of display cases. Savings result from reducing the operating hours of the anti-sweat heaters, which without a humidistat control generally run continuously. There are various types of control strategies including cycling on a fixed schedule.

LED display lighting: This measure involves the replacement of standard fluorescent tube lighting fixtures within medium and low-temperature display cases with LED fixtures. The higher luminous efficacy of LED lamps compared to T-8 and T-5 fluorescent lamps delivers significant energy savings and also results in lower heat gains inside refrigerator and freezer cases, which in turn reduces the effective load served by the compressor. LED fixtures also exhibit much longer service lives compared to T-8 or T-5 fixtures and very little maintenance requirements.

High R-value glass doors: This measure involves the replacement of standard glass doors on refrigerated display cases with advanced glass doors that incorporate heat-reflective treated glass and/or low-conductivity gas fills between panes to produce high R-values. The greater insulation properties of the insulated glass doors reduce condensation buildup and reduce or eliminate the need for anti-sweat heaters.

Multiplex compressor systems: Multiplex refrigeration systems involve the use of multiple compressors in parallel, rather than single compressors, to serve specific refrigeration loads. Multiplex systems are designed so that compressors can be selectively selected and cycled in order to better match changes in refrigeration load dynamically and increase the overall operational efficiency of the compressors.

Oversized air cooled condenser: The use of oversized condensers can provide additional "natural subcooling" of the condensed refrigerant, which results in lower-temperature refrigerant liquid in the system, lower evaporator temperatures, and reduced load on the compressor.

Freezer/cooler replacement gaskets: Worn out freezer/cooler door gaskets can result in significant leakage and increased cooling energy consumption. Regular replacement of worn door gaskets reduces unnecessary air leaks and can lead to significant refrigeration energy savings.

ENERGY STAR® refrigeration: The Environmental Protection Agency's ENERGY STAR® program labels high-efficiency commercial refrigerators, freezers, and ice machines. High efficiency units are designed with components such as ECM evaporator and condenser fan motors, hot gas anti-sweat heaters, or high-efficiency compressors, which significantly reduce energy consumption.

Compared to standard models, ENERGY STAR labeled commercial refrigerators and freezers can lead to energy savings of as much as 35 percent with a 1.3 year payback.

B.2.5 Office Equipment

Power management enabling: Most PCs, monitors, printers and copiers have the capability of entering a low-power "sleep" mode when idle. However devices may come with this feature disabled or users may disable it for a variety of reasons. Enabling power management reduces energy use when devices are left idle during the day, or when a device is left on overnight. Most savings occur off-peak. This measure can be applied to PCs, PC monitors, printers and copiers.

ENERGY STAR® or better office equipment: For many years, virtually all PCs and monitors met the ENERGY STAR® efficiency requirements, which required only that devices be capable of entering a low-power "sleep" mode after a period of inactivity. The Environmental Protection Agency (EPA) has tightened its requirements, adding active-mode power requirements to the specifications. Choosing ENERGY STAR® PCs, monitors, copiers and printers can reduce energy use both in all power modes.

Data center energy efficiency: Data centers are facilities that are densely packed with electronic equipment for data processing, data storage, and networking. Ranging from a server closet in a small building to building that provide remote data operations to multiple clients, data centers are extremely energy intensive, both for the information architecture and the for cooling required to support it. We analyze three scenarios for reduce energy use in data centers, taken from a 2007 EPA report: (1) Improved operations focuses on operational improvements with little or no capital investment. (1) Best Practices assumes the adoption of practices and technologies used in the most energy-efficient of today's data centers. (3) State of the Art Practices represents the maximum efficiency achievable using available technologies.

A.2.6 Water Heating

High efficiency water heater: Higher efficiency water heater have greater insulation to reduce standby heat loss. For this study, efficiency of the base unit (measured as the Energy Factor) is specified as 0.88, whereas the efficiency of the high efficiency electric water heater is specified as 0.93.

Heat pump water heater: Air-to-water heat pump water heaters extract low-grade heat from the air then transfer this heat to the water by means of an immersion coil. This is the most commonly utilized residential heat pump water heater. The air-to-water heat pump unit includes a compressor, air-to-refrigerant evaporator coil, evaporator fan, water circulating pump, refrigerant-to-water condenser coil, expansion valve, and controls. Residential heat pump water heaters replace base electric units with the same tank

⁹ EPA, 2007. Report to Congress on Server and Data Center Energy Efficiency, Public Law 109-431. Available at: http://www.energystar.gov/ia/partners/prod_development/downloads/EPA_Datacenter_Report_Congress_Final1.pdf

capacities. For this study, efficiency of the base unit (measured as the Energy Factor) is specified as 0.88, whereas the efficiency of the heat pump water heater is specified as 2.9.

Solar water heater: Heat transfer technology that uses the sun's energy to warm water. Solar water heaters preheat water supplied to a conventional domestic hot water heating system. The energy savings for the system depend on solar radiation, air temperatures, water temperatures at the site, and the hot water use pattern.

Demand-controlled circulating systems: Hot water circulation systems are designed to maintain water in hot water pipes at a pre-determined temperature and prevent excess water demand (and associated water heating energy) from waiting for hot water to arrive from the water heater. Demand-controlled circulating systems provide additional savings by optimizing pumping energy requirements to only specific moments of hot water demand. This is achieved through the integration of an electronic controller on the circulation pump that is triggered by a switch engaged by the consumer at the point of hot water demand.

Heat recovery units: This measure is heat transfer strategy that uses the heat rejected during the refrigerant cycle on air conditioning units to heat water.

Pipe wrap: Thermal insulation is material or combinations of materials that are used to inhibit the flow of heat energy by conductive, convective, and radiative transfer modes. By inhibiting the flow of heat energy, thermal insulation can conserve energy by reducing heat loss or gain.

Heat trap: Heat traps are valves or loops of pipe, which allow water to flow into the water heater tank but prevent unwanted hot-water flow out of the tank that would otherwise occur due to convection.

Tankless water heater: Tankless water heaters eliminate the standby tank (and associated losses) of a standard water heater. The water is heated instantaneously by a high energy heat source that can be either gas or electric.

B.2.7 Cooking

Convection oven: Convection ovens use a small fan to circulate hot air within the oven cavity. Circulating air can heat food more efficiently than the still air found in conventional ovens. The hot air in the oven can be heated by gas or electricity. In general, a convection oven will save 30% of the energy used by an oven. These savings result from burners cycling off for a longer period.

ENERGY STAR® fryer: Fryers cook foods by submerging them in hot animal or vegetable oils, and utilize a range of different burner types. In order to qualify as ENERGY STAR, electric fryers must meet a minimum cooking efficiency 80 percent while also meeting a maximum idle energy rate of 1,000 watts. Energy efficient fryers offer shorter cook times and higher production rates through advanced burner and heat exchanger designs. Fry pot insulation reduces standby losses resulting in a lower idle energy rate.

ENERGY STAR® steamer: Commercial steam cookers are versatile appliances which can be used to quickly prepare any foods that do not require a crust. Steamers come in a variety of configurations but generally resemble an oven, with between one and four gasketed and windowless compartments. The stacked compartments typically accommodate a standard 12 by 20-inch hotel pan. Pressure steamers have

an external boiler that produces potable steam under pressure, and atmospheric steamers have a steam generator located directly below the compartments. Both require a water line and drain hookup. In contrast, the connectionless steamer is a closed loop system with a reservoir that is periodically drained and refilled. Significant improvements in water- and energy- efficiency are achieved because no steam is allowed to escape down the condensate drain.

Vending misers: The Vending Miser is an after-market energy control technology for refrigerated vending machines. It incorporates an occupancy sensor, thermostat, and timer to power down the vending machine for extended period, while periodically repowering refrigerated devices to ensure that the product stays cold.

C. ECONOMIC INPUTS

APPENDIX C - ECONOMIC INPUTS

Residential Electricity

UTILITY NAME Dominion SECTOR Res BATCH# UTILITY DISCOUNT RATE 7.45% CUSTOMER DISCOUNT RATE 8.45% GENERAL INFLATION RATE (M 1.87% BASE YEAR 2014 START YEAR 2014 UTILITY LINE LOSS RATE 5.20%

ENERGY COSTS AND RATES

RATE TYPE Residential ENERGY UNITS \$/kWh DEMAND UNITS \$/kW Rate/Time F Summer Summer Off- Winter On- Winter Off-On-Peak Peak Peak Abbreviatior SON SOFF WON WOFF TOTAL Hours 850 2078 1392 4440 8760

	AVOIDED I	ENERGY COST	TS BY TIME	PERIOD	AVOIDED I	DEMAND CO	STS BY TIME	PERIOD	RES	SIDENTIAL EN	IERGY RATES	3
	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF
Year	\$/kWh	\$/kWh	\$/kWh	\$/kWh	\$/kWh	\$/kWh	\$/kWh	\$/kWh	\$/kWh	\$/kWh	\$/kWh	\$/kWh
2014	0.050	0.035	0.050	0.035	31.040	0.000	0.000	0.000	0.112	0.112	0.112	0.112
2015	0.051	0.037	0.051	0.037	48.120	0.000	0.000	0.000	0.114	0.114	0.114	0.114
2016	0.054	0.042	0.054	0.042	33.370	0.000	0.000	0.000	0.116	0.116	0.116	0.116
2017	0.057	0.044	0.057	0.044	21.270	0.000	0.000	0.000	0.118	0.118	0.118	0.118
2018	0.061	0.047	0.061	0.047	29.310	0.000	0.000	0.000	0.121	0.121	0.121	0.121
2019	0.062	0.048	0.062	0.048	38.610	0.000	0.000	0.000	0.123	0.123	0.123	0.123
2020	0.064	0.050	0.064	0.050	50.840	0.000	0.000	0.000	0.125	0.125	0.125	0.125
2021	0.066	0.051	0.066	0.051	66.990	0.000	0.000	0.000	0.128	0.128	0.128	0.128
2022	0.068	0.053	0.068	0.053	88.280	0.000	0.000	0.000	0.130	0.130	0.130	0.130
2023	0.073	0.059	0.073	0.059	111.280	0.000	0.000	0.000	0.133	0.133	0.133	0.133
2024	0.075	0.061	0.075	0.061	113.510	0.000	0.000	0.000	0.135	0.135	0.135	0.135
2025	0.077	0.063	0.077	0.063	115.760	0.000	0.000	0.000	0.138	0.138	0.138	0.138
2026	0.080	0.066	0.080	0.066	118.000	0.000	0.000	0.000	0.141	0.141	0.141	0.141
2027	0.082	0.068	0.082	0.068	120.250	0.000	0.000	0.000	0.143	0.143	0.143	0.143
2028	0.085	0.070	0.085	0.070	121.320	0.000	0.000	0.000	0.146	0.146	0.146	0.146
2029	0.087	0.073	0.087	0.073	122.230	0.000	0.000	0.000	0.149	0.149	0.149	0.149
2030	0.090	0.076	0.090	0.076	123.130	0.000	0.000	0.000	0.152	0.152	0.152	0.152
2031	0.094	0.079	0.094	0.079	127.460	0.000	0.000	0.000	0.154	0.154	0.154	0.154
2032	0.097	0.083	0.097	0.083	131.780	0.000	0.000	0.000	0.157	0.157	0.157	0.157
2033	0.101	0.087	0.101	0.087	134.170	0.000	0.000	0.000	0.160	0.160	0.160	0.160
2034	0.105	0.091	0.105	0.091	136.590	0.000	0.000	0.000	0.163	0.163	0.163	0.163
2035	0.110	0.095	0.110	0.095	139.070	0.000	0.000	0.000	0.166	0.166	0.166	0.166
2036	0.114	0.099	0.114	0.099	141.590	0.000	0.000	0.000	0.169	0.169	0.169	0.169
2037	0.118	0.104	0.118	0.104	144.180	0.000	0.000	0.000	0.172	0.172	0.172	0.172
2038	0.123	0.108	0.123	0.108	146.840	0.000	0.000	0.000	0.175	0.175	0.175	0.175
2039	0.128	0.112	0.128	0.112	149.530	0.000	0.000	0.000	0.178	0.178	0.178	0.178
2040	0.133	0.117	0.133	0.117	152.250	0.000	0.000	0.000	0.182	0.182	0.182	0.182
2041	0.137	0.121	0.137	0.121	154.940	0.000	0.000	0.000	0.185	0.185	0.185	0.185
2042	0.143	0.126	0.143	0.126	157.580	0.000	0.000	0.000	0.189	0.189	0.189	0.189
2043	0.148	0.131	0.148	0.131	160.510	0.000	0.000	0.000	0.192	0.192	0.192	0.192
2044	0.154	0.136	0.154	0.136	163.490	0.000	0.000	0.000	0.196	0.196	0.196	0.196
2045	0.160	0.142	0.160	0.142	166.530	0.000	0.000	0.000	0.200	0.200	0.200	0.200
2046	0.166	0.147	0.166	0.147	169.620	0.000	0.000	0.000	0.203	0.203	0.203	0.203
2047	0.172	0.153	0.172	0.153	168.740	0.000	0.000	0.000	0.207	0.207	0.207	0.207
2048	0.178	0.160	0.178	0.160	165.270	0.000	0.000	0.000	0.211	0.211	0.211	0.211
2049	0.185	0.166	0.185	0.166	161.870	0.000	0.000	0.000	0.215	0.215	0.215	0.215
2050	0.192	0.173	0.192	0.173	158.530	0.000	0.000	0.000	0.219	0.219	0.219	0.219
2051	0.196	0.176	0.196	0.176	161.495	0.000	0.000	0.000	0.223	0.223	0.223	0.223
2052	0.199	0.179	0.199	0.179	164.514	0.000	0.000	0.000	0.227	0.227	0.227	0.227
2053	0.203	0.182	0.203	0.173	167.591	0.000	0.000	0.000	0.231	0.231	0.231	0.231

APPENDIX C - ECONOMIC INPUTS

Commercial Electricity

UTILITY NAME Dominion
SECTOR Com
BATCH # 1
UTILITY DISCOUNT RATE 7.45%
CUSTOMER DISCOUNT RATE 8.45%
GENERAL INFLATION RATE (Measure) 1.87%
BASE YEAR 2014
START YEAR 2014
UTILITY LINE LOSS RATE 5.20%

ENERGY COSTS AND RATES

RATE TYPE Commercial ENERGY UNITS \$/kWh DEMAND UNITS \$/kW

Rate/Time Per	1	2	3	4	
	Summer	Summer Off-	Winter On-	Winter Off-	
Name	On-Peak	Peak	Peak	Peak	
Abbreviation	SON	SOFF	WON	WOFF	TOTAL
Hours	850	2078	1392	4440	8760

		AVOIDED	ENERGY CC	STS BY TIME	PERIOD	AVOIDED	DEMAND COS	TS BY TIME PE	RIOD	CC	OMMERCIAL EN	IERGY RATES	
,	Year	SON \$/kWh	SOFF \$/kWh	WON \$/kWh	WOFF \$/kWh	SON \$/kWh	SOFF \$/kWh	WON \$/kWh	WOFF \$/kWh	SON \$/kWh	SOFF \$/kWh	WON \$/kWh	WOFF \$/kWh
:	2014	0.050	0.035	0.050	0.035	31.040	0.000	0.000	0.000	0.079	0.079	0.079	0.079
	2015	0.051	0.037	0.051	0.037	48.120	0.000	0.000	0.000	0.081	0.081	0.081	0.081
1	2016	0.054	0.042	0.054	0.042	33.370	0.000	0.000	0.000	0.082	0.082	0.082	0.082
	2017	0.057	0.044	0.057	0.044	21.270	0.000	0.000	0.000	0.084	0.084	0.084	0.084
	2018	0.061	0.047	0.061	0.047	29.310	0.000	0.000	0.000	0.085	0.085	0.085	0.085
	2019	0.062	0.048	0.062	0.048	38.610	0.000	0.000	0.000	0.087	0.087	0.087	0.087
	2020	0.064	0.050	0.064	0.050	50.840	0.000	0.000	0.000	0.088	0.088	0.088	0.088
1	2021	0.066	0.051	0.066	0.051	66.990	0.000	0.000	0.000	0.090	0.090	0.090	0.090
	2022	0.068	0.053	0.068	0.053	88.280	0.000	0.000	0.000	0.092	0.092	0.092	0.092
	2023	0.073	0.059	0.073	0.059	111.280	0.000	0.000	0.000	0.094	0.094	0.094	0.094
	2024	0.075	0.061	0.075	0.061	113.510	0.000	0.000	0.000	0.095	0.095	0.095	0.095
	2025	0.077	0.063	0.077	0.063	115.760	0.000	0.000	0.000	0.097	0.097	0.097	0.097
	2026	0.080	0.066	0.080	0.066	118.000	0.000	0.000	0.000	0.099	0.099	0.099	0.099
	2027	0.082	0.068	0.082	0.068	120.250	0.000	0.000	0.000	0.101	0.101	0.101	0.101
	2028	0.085	0.070	0.085	0.070	121.320	0.000	0.000	0.000	0.103	0.103	0.103	0.103
	2029	0.087	0.073	0.087	0.073	122.230	0.000	0.000	0.000	0.105	0.105	0.105	0.105
	2030	0.090	0.076	0.090	0.076	123.130	0.000	0.000	0.000	0.107	0.107	0.107	0.107
	2031	0.094	0.079	0.094	0.079	127.460	0.000	0.000	0.000	0.109	0.109	0.109	0.109
	2032	0.097	0.083	0.097	0.083	131.780	0.000	0.000	0.000	0.111	0.111	0.111	0.111
1	2033	0.101	0.087	0.101	0.087	134.170	0.000	0.000	0.000	0.113	0.113	0.113	0.113
	2034	0.105	0.091	0.105	0.091	136.590	0.000	0.000	0.000	0.115	0.115	0.115	0.115
	2035	0.110	0.095	0.110	0.095	139.070	0.000	0.000	0.000	0.117	0.117	0.117	0.117
	2036	0.114	0.099	0.114	0.099	141.590	0.000	0.000	0.000	0.119	0.119	0.119	0.119
	2037	0.118	0.104	0.118	0.104	144.180	0.000	0.000	0.000	0.121	0.121	0.121	0.121
1	2038	0.123	0.108	0.123	0.108	146.840	0.000	0.000	0.000	0.124	0.124	0.124	0.124
	2039	0.128	0.112	0.128	0.112	149.530	0.000	0.000	0.000	0.126	0.126	0.126	0.126
	2040	0.133	0.117	0.133	0.117	152.250	0.000	0.000	0.000	0.128	0.128	0.128	0.128
	2041	0.137	0.121	0.137	0.121	154.940	0.000	0.000	0.000	0.131	0.131	0.131	0.131
	2042	0.143	0.126	0.143	0.126	157.580	0.000	0.000	0.000	0.133	0.133	0.133	0.133
1	2043	0.148	0.131	0.148	0.131	160.510	0.000	0.000	0.000	0.136	0.136	0.136	0.136
	2044	0.154	0.136	0.154	0.136	163.490	0.000	0.000	0.000	0.138	0.138	0.138	0.138
	2045	0.160	0.142	0.160	0.142	166.530	0.000	0.000	0.000	0.141	0.141	0.141	0.141
	2046	0.166	0.147	0.166	0.147	169.620	0.000	0.000	0.000	0.143	0.143	0.143	0.143
:	2047	0.172	0.153	0.172	0.153	168.740	0.000	0.000	0.000	0.146	0.146	0.146	0.146
:	2048	0.178	0.160	0.178	0.160	165.270	0.000	0.000	0.000	0.149	0.149	0.149	0.149
:	2049	0.185	0.166	0.185	0.166	161.870	0.000	0.000	0.000	0.152	0.152	0.152	0.152
1 :	2050	0.192	0.173	0.192	0.173	158.530	0.000	0.000	0.000	0.154	0.154	0.154	0.154
1	2051	0.196	0.176	0.196	0.176	161.495	0.000	0.000	0.000	0.157	0.157	0.157	0.157
:	2052	0.199	0.179	0.199	0.179	164.514	0.000	0.000	0.000	0.160	0.160	0.160	0.160
:	2053	0.203	0.182	0.203	0.182	167.591	0.000	0.000	0.000	0.163	0.163	0.163	0.163

D. BUILDING AND TOU FACTOR INPUTS

Residential Electric Building Stock Table

Number of Homes

_			
		Single Family	Multifamily
	Segment	Building Type 1	Building Type 2
	VA Existing	1,668,245	418,402
	NC Existing	80,767	20,257
	Opt-Outs	0	0
	VA New	16,101	4,038



Residential Electric End Use Load Shape Table

(Fraction of annual energy)

	End	Use 1 - S	Space Cod	oling		End Use 2	! - Lighting	3	En	d Use 3 -	Refrigerat	ion		End Use 4	l - Freeze	r	End Use 5	- Water H	eating	
Building Type	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF
VA Existing	0.3338	0.4394	0.0511	0.1757	0.1178	0.1863	0.2058	0.4902	0.1243	0.2397	0.1467	0.4893	0.1271	0.2366	0.1466	0.4897	0.0980	0.1731	0.2025	0.5265
NC Existing	0.3338	0.4394	0.0511	0.1757	0.1178	0.1863	0.2058	0.4902	0.1243	0.2397	0.1467	0.4893	0.1271	0.2366	0.1466	0.4897	0.0980	0.1731	0.2025	0.5265
Opt-Outs	0.3338	0.4394	0.0511	0.1757	0.1178	0.1863	0.2058	0.4902	0.1243	0.2397	0.1467	0.4893	0.1271	0.2366	0.1466	0.4897	0.0980	0.1731	0.2025	0.5265
VA New	0.3338	0.4394	0.0511	0.1757	0.1178	0.1863	0.2058	0.4902	0.1243	0.2397	0.1467	0.4893	0.1271	0.2366	0.1466	0.4897	0.0980	0.1731	0.2025	0.5265
NC New	0.3338	0.4394	0.0511	0.1757	0.1178	0.1863	0.2058	0.4902	0.1243	0.2397	0.1467	0.4893	0.1271	0.2366	0.1466	0.4897	0.0980	0.1731	0.2025	0.5265

Residential Electric End Use Load Shape Table - Continued

(Fraction of annual energy)

		377																		
	End	Use 6 - C	lothes Wa	asher	End	d Use 7 - 0	Clothes D	ryer	Er	nd Use 8 -	Dishwash	ner	End	Use 9 - S	Space Hea	ating	E	nd Use 10	- Cooking	
Building Type	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF
VA Existing	0.1471	0.1857	0.1841	0.4832	0.1419	0.1529	0.1704	0.5348	0.1467	0.1538	0.2700	0.4295	0.1673	0.1970	0.1793	0.4564	0.1627	0.1381	0.2812	0.4180
NC Existing	0.1471	0.1857	0.1841	0.4832	0.1419	0.1529	0.1704	0.5348	0.1467	0.1538	0.2700	0.4295	0.1673	0.1970	0.1793	0.4564	0.1627	0.1381	0.2812	0.4180
Opt-Outs	0.1471	0.1857	0.1841	0.4832	0.1419	0.1529	0.1704	0.5348	0.1467	0.1538	0.2700	0.4295	0.1673	0.1970	0.1793	0.4564	0.1627	0.1381	0.2812	0.4180
VA New	0.1471	0.1857	0.1841	0.4832	0.1419	0.1529	0.1704	0.5348	0.1467	0.1538	0.2700	0.4295	0.1673	0.1970	0.1793	0.4564	0.1627	0.1381	0.2812	0.4180
NC New	0.1471	0.1857	0.1841	0.4832	0.1419	0.1529	0.1704	0.5348	0.1467	0.1538	0.2700	0.4295	0.1673	0.1970	0.1793	0.4564	0.1627	0.1381	0.2812	0.4180

Residential Electric End Use Load Shape Table - Continued

(Fraction of annual energy)

		End Use	11 - TV		En	d Use 12	- Pool Pu	mp	End Us	e 13 - Co	oling and	Heating	End	Use 14 -	Miscellan	eous		End Use 1	5 - House	
Building Type	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF
VA Existing	0.1387	0.1929	0.1811	0.4874	0.1675	0.1967	0.1799	0.4559	0.2882	0.3544	0.0733	0.2842	0.0935	0.1978	0.2139	0.4948	0.12255	0.19678	0.19326	0.48740
NC Existing	0.1387	0.1929	0.1811	0.4874	0.1675	0.1967	0.1799	0.4559	0.2882	0.3544	0.0733	0.2842	0.0935	0.1978	0.2139	0.4948	0.12255	0.19678	0.19326	0.48740
Opt-Outs	0.1387	0.1929	0.1811	0.4874	0.1675	0.1967	0.1799	0.4559	0.2882	0.3544	0.0733	0.2842	0.0935	0.1978	0.2139	0.4948	0.12255	0.19678	0.19326	0.48740
VA New	0.1387	0.1929	0.1811	0.4874	0.1675	0.1967	0.1799	0.4559	0.2882	0.3544	0.0733	0.2842	0.0935	0.1978	0.2139	0.4948	0.12255	0.19678	0.19326	0.48740



(Ratio of peak kW to average kW)

	End	l Use 1 - S	Space Cod	oling		End Use 2	2 - Lighting	g	En	d Use 3 -	Refrigerat	ion		End Use 4	l - Freeze	r	End	d Use 5 - W	/ater Heati	ng
Building Type	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN
VA Existing	1.5129	1.5914	0.0687	0.2291	0.8079	2.3723	0.6263	0.7655	1.1080	1.1183	1.0498	1.0162	1.0585	0.9582	1.0367	1.0011	1.0684	0.9985	1.4694	1.5534
NC Existing	1.5129	1.5914	0.0687	0.2291	0.8079	2.3723	0.6263	0.7655	1.1080	1.1183	1.0498	1.0162	1.0585	0.9582	1.0367	1.0011	1.0684	0.9985	1.4694	1.5534
Opt-Outs	1.5129	1.5914	0.0687	0.2291	0.8079	2.3723	0.6263	0.7655	1.1080	1.1183	1.0498	1.0162	1.0585	0.9582	1.0367	1.0011	1.0684	0.9985	1.4694	1.5534
VA New	1.5129	1.5914	0.0687	0.2291	0.8079	2.3723	0.6263	0.7655	1.1080	1.1183	1.0498	1.0162	1.0585	0.9582	1.0367	1.0011	1.0684	0.9985	1.4694	1.5534
NC New	1.5129	1.5914	0.0687	0.2291	0.8079	2.3723	0.6263	0.7655	1.1080	1.1183	1.0498	1.0162	1.0585	0.9582	1.0367	1.0011	1.0684	0.9985	1.4694	1.5534

Residential Electric Peak To Energy Relationship Table (Utility Coincidence) - Continued

(Ratio of peak kW to average kW)

	End	Use 6 - C	lothes Wa	sher	End	l Use 7 - (Clothes Di	ryer	Er	ıd Use 8 -	Dishwash	er	End	Use 9 - S	Space Hea	ıting	E	nd Use 10	- Cooking	
Building Type	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN
VA Existing	1.0442	0.9414	1.4570	1.1445	1.0135	1.4988	0.8660	0.5408	0.9501	1.7548	0.6900	0.8324	0.6030	0.0894	0.9475	0.6168	1.6679	0.6518	0.5557	0.9439
NC Existing	1.0442	0.9414	1.4570	1.1445	1.0135	1.4988	0.8660	0.5408	0.9501	1.7548	0.6900	0.8324	0.6030	0.0894	0.9475	0.6168	1.6679	0.6518	0.5557	0.9439
Opt-Outs	1.0442	0.9414	1.4570	1.1445	1.0135	1.4988	0.8660	0.5408	0.9501	1.7548	0.6900	0.8324	0.6030	0.0894	0.9475	0.6168	1.6679	0.6518	0.5557	0.9439
VA New	1.0442	0.9414	1.4570	1.1445	1.0135	1.4988	0.8660	0.5408	0.9501	1.7548	0.6900	0.8324	0.6030	0.0894	0.9475	0.6168	1.6679	0.6518	0.5557	0.9439
NC New	1.0442	0.9414	1.4570	1.1445	1.0135	1.4988	0.8660	0.5408	0.9501	1.7548	0.6900	0.8324	0.6030	0.0894	0.9475	0.6168	1.6679	0.6518	0.5557	0.9439

Residential Electric Peak To Energy Relationship Table (Utility Coincidence) - Continued

(Ratio of peak kW to average kW)

		End Use	e 11 - TV		En	d Use 12	- Pool Pu	mp	End Us	e 13 - Co	oling and	Heating	End	Use 14 -	Miscellan	eous		End Use 1	5 - House	
Building Type	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN
VA Existing	0.8844	3.3941	0.1809	0.1237	0.6034	0.0901	0.9704	0.6345	1.5129	1.5808	0.1464	0.8593	1.1979	2.2884	0.4056	0.4841	1.7174	1.6188	0.7100	0.7816
NC Existing	0.8844	3.3941	0.1809	0.1237	0.6034	0.0901	0.9704	0.6345	1.5129	1.5808	0.1464	0.8593	1.1979	2.2884	0.4056	0.4841	1.7174	1.6188	0.7100	0.7816
Opt-Outs	0.8844	3.3941	0.1809	0.1237	0.6034	0.0901	0.9704	0.6345	1.5129	1.5808	0.1464	0.8593	1.1979	2.2884	0.4056	0.4841	1.7174	1.6188	0.7100	0.7816
VA New	0.8844	3.3941	0.1809	0.1237	0.6034	0.0901	0.9704	0.6345	1.5129	1.5808	0.1464	0.8593	1.1979	2.2884	0.4056	0.4841	1.7174	1.6188	0.7100	0.7816
NC New	0.8844	3.3941	0.1809	0.1237	0.6034	0.0901	0.9704	0.6345	1.5129	1.5808	0.1464	0.8593	1.1979	2.2884	0.4056	0.4841	1.7174	1.6188	0.7100	0.7816

APPENDIX D



Commercial Electric Building Stock Table Square Feet

	Office	Restaurant	Retail	Grocery	Warehouse	School	Health	Lodging	Data Centers	Non-Jurisdictional	Religious Worship	Misc.
Segment	Building Type 1	Building Type 2	Building Type 3	Building Type 4	Building Type 5	Building Type 6	Building Type 7	Building Type 8	Building Type 9	Building Type 10	Building Type 11	Building Type 12
VA Existing	229,033,353	95,960,213	598,719,467	51,849,706	368,656,381	148,316,397	108,863,065	189,430,773	6,064,089	557,616,115	186,135,561	448,255,447
NC Existing	9,580,125	2,541,070	15,854,363	1,373,004	9,146,991	13,317,823	2,882,743	5,016,213	135,434	0	4,928,954	12479962.15

Commercial Electric End Use Load Shape Table

(Fraction of annual energy)

	End	Use 1 - In	door Light	ing	End	Use 2 - O	utdoor Lig	hting		End Use 3	3 - Cooling	ı	E	nd Use 4	- Ventilatio	on
Building Type	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF
Office Equipment	0.1576	0.1762	0.2228	0.4433	0.0618	0.2491	0.1321	0.5570	0.2955	0.2266	0.1330	0.3449	0.1532	0.1975	0.1915	0.4578
Restaurant	0.1564	0.1792	0.1966	0.4679	0.0782	0.2360	0.1533	0.5324	0.2821	0.2632	0.1235	0.3312	0.1452	0.2179	0.1738	0.4631
Retail	0.1456	0.1892	0.2030	0.4622	0.0823	0.2364	0.1563	0.5249	0.3411	0.2598	0.1046	0.2945	0.1545	0.2032	0.1903	0.4519
Grocery	0.1283	0.2062	0.1860	0.4794	0.0637	0.2454	0.1372	0.5537	0.2852	0.2914	0.1111	0.3123	0.1255	0.2204	0.1732	0.4810
Warehouse	0.1507	0.1818	0.2208	0.4467	0.0565	0.2481	0.1330	0.5623	0.4274	0.2537	0.0858	0.2331	0.1732	0.1946	0.1963	0.4359
School	0.1360	0.1629	0.2497	0.4514	0.0678	0.2422	0.1398	0.5503	0.3909	0.1905	0.1149	0.3037	0.1666	0.1467	0.2390	0.4477
Health	0.1271	0.2081	0.1849	0.4798	0.0591	0.2498	0.1301	0.5610	0.2455	0.2927	0.1179	0.3439	0.1163	0.2244	0.1609	0.4983
Lodging	0.1191	0.2162	0.1900	0.4747	0.0590	0.2505	0.1296	0.5610	0.2469	0.2978	0.1137	0.3416	0.1180	0.2271	0.1556	0.4993
Data Centers	0.1343	0.2179	0.2916	0.3562	0.1343	0.2179	0.2916	0.3562	0.1343	0.2179	0.2916	0.3562	0.1343	0.2179	0.2916	0.3562
Non-Jurisdictional	0.1519	0.1816	0.2133	0.4533	0.0722	0.2392	0.1468	0.5418	0.3154	0.2495	0.1163	0.3189	0.1545	0.2024	0.1837	0.4594
Religious Worship	0.1462	0.1869	0.2037	0.4632	0.0827	0.2292	0.1614	0.5267	0.3352	0.2724	0.0996	0.2928	0.1558	0.2073	0.1759	0.4609
Miscellaneous	0.1462	0.1869	0.2037	0.4632	0.0827	0.2292	0.1614	0.5267	0.3352	0.2724	0.0996	0.2928	0.1558	0.2073	0.1759	0.4609

Commercial Electric End Use Load Shape Table - Continued

(Fraction of annual energy)

	End	d Use 5 - F	Refrigeration	on	End	Use 6 - Of	fice Equip	ment	End	d Use 7 - \	Vater Hea	ting	1	End Use 8	- Vending	9
Building Type	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF
Office Equipment	0.1121	0.2237	0.1610	0.5032	0.1303	0.2040	0.1837	0.4821	0.1180	0.1873	0.1903	0.5043	0.1396	0.1954	0.1941	0.4709
Restaurant	0.1162	0.2260	0.1586	0.4993	0.1562	0.1794	0.1952	0.4692	0.1435	0.1644	0.2093	0.4827	0.1428	0.1929	0.1881	0.4761
Retail	0.1179	0.2291	0.1567	0.4963	0.1494	0.1856	0.1971	0.4679	0.1334	0.1705	0.2088	0.4873	0.1469	0.1888	0.2008	0.4635
Grocery	0.1231	0.2349	0.1525	0.4895	0.1432	0.1914	0.2002	0.4651	0.1279	0.1804	0.2120	0.4797	0.1291	0.2054	0.1870	0.4784
Warehouse	0.1396	0.2625	0.1419	0.4559	0.1545	0.1794	0.2211	0.4450	0.1332	0.1716	0.2171	0.4781	0.1501	0.1857	0.2155	0.4488
School	0.1124	0.2250	0.1615	0.5012	0.1268	0.1744	0.2333	0.4655	0.1309	0.1657	0.2561	0.4474	0.1179	0.1672	0.2647	0.4502
Health	0.1140	0.2244	0.1609	0.5006	0.1260	0.2083	0.1794	0.4862	0.1143	0.1875	0.1925	0.5057	0.1256	0.2090	0.1795	0.4859
Lodging	0.1138	0.2231	0.1623	0.5007	0.1243	0.2111	0.1808	0.4838	0.1092	0.1942	0.2013	0.4953	0.1267	0.2109	0.1805	0.4819
Data Centers	0.1343	0.2179	0.2916	0.3562	0.1343	0.2179	0.2916	0.3562	0.1343	0.2179	0.2916	0.3562	0.1343	0.2179	0.2916	0.3562
Non-Jurisdictional	0.1146	0.2263	0.1593	0.4998	0.1387	0.1950	0.1921	0.4742	0.1224	0.1812	0.1928	0.5037	0.1412	0.1929	0.1980	0.4679
Religious Worship	0.1170	0.2290	0.1576	0.4963	0.1472	0.1859	0.2006	0.4663	0.1267	0.1750	0.1952	0.5030	0.1429	0.1904	0.2019	0.4648
Miscellaneous	0.1170	0.2290	0.1576	0.4963	0.1472	0.1859	0.2006	0.4663	0.1267	0.1750	0.1952	0.5030	0.1429	0.1904	0.2019	0.4648

Commercial Electric End Use Load Shape Table - Continued

(Fraction of annual energy)

(· · · · · · · · · · · · · · · · · · ·		<i>3) </i>														
	Е	End Use 9	 Cooking 			End Use 1	0 - Heatin	g	Er	nd Use 11	- Pool Pur	mp	End	l Use 13 -	Miscellane	eous
Building Type	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF
Office Equipment	0.1721	0.1629	0.2416	0.4235	0.06272	0.13812	0.25370	0.54545	0.1396	0.1954	0.1941	0.4709	0.1396	0.1954	0.1941	0.4709
Restaurant	0.1556	0.1792	0.2080	0.4571	0.00723	0.02733	0.28671	0.67873	0.1428	0.1929	0.1881	0.4761	0.1428	0.1929	0.1881	0.4761
Retail	0.1552	0.1805	0.2167	0.4476	0.00756	0.04826	0.30983	0.63434	0.1469	0.1888	0.2008	0.4635	0.1469	0.1888	0.2008	0.4635
Grocery	0.1258	0.2093	0.1977	0.4673	0.00461	0.01892	0.21321	0.76325	0.1291	0.2054	0.1870	0.4784	0.1291	0.2054	0.1870	0.4784
Warehouse	0.1676	0.1655	0.2424	0.4245	0.00279	0.02598	0.41896	0.55227	0.1501	0.1857	0.2155	0.4488	0.1501	0.1857	0.2155	0.4488
School	0.1253	0.1561	0.3053	0.4134	0.00644	0.02242	0.36722	0.60391	0.1179	0.1672	0.2647	0.4502	0.1179	0.1672	0.2647	0.4502
Health	0.1446	0.1906	0.2058	0.4591	0.06064	0.18585	0.17665	0.57686	0.1256	0.2090	0.1795	0.4859	0.1256	0.2090	0.1795	0.4859
Lodging	0.1472	0.1934	0.2116	0.4478	0.02778	0.08631	0.16632	0.71959	0.1267	0.2109	0.1805	0.4819	0.1267	0.2109	0.1805	0.4819
Data Centers	0.1343	0.2179	0.2916	0.3562	0.13431	0.21791	0.29156	0.35621	0.1343	0.2179	0.2916	0.3562	0.1343	0.2179	0.2916	0.3562
Non-Jurisdictional	0.1558	0.1792	0.2208	0.4442	0.04382	0.09923	0.26017	0.59679	0.1412	0.1929	0.1980	0.4679	0.1412	0.1929	0.1980	0.4679
Religious Worship	0.1396	0.1954	0.2001	0.4649	0.02492	0.06034	0.26663	0.64812	0.1429	0.1904	0.2019	0.4648	0.1429	0.1904	0.2019	0.4648
Miscellaneous	0.1396	0.1954	0.2001	0.4649	0.02492	0.06034	0.26663	0.64812	0.1429	0.1904	0.2019	0.4648	0.1429	0.1904	0.2019	0.4648

Commercial Electric Peak To Energy Relationship Table (Utility Coincidence) (Ratio of peak kW to average kW)

(realise of pount is			,													
	End	Use 1 - In	door Light	ing	End	Use 2 - O	utdoor Lig	hting		End Use 3	3 - Cooling	1	E	nd Use 4	- Ventilatio	on
Building Type	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN	SON	SMID	SOFF	WIN
Office Equipment	1.003982	0.7324	1.2595	1.7423	0.1893	1.8290	0.0839	0.1523	2.01216	0.9714	1.5826	1.4847	1.67536	0.9149	1.2451	1.4973
Restaurant	1.073194	1.0799	0.7350	0.8189	0.7198	1.9077	0.0581	0.1953	1.88626	1.3117	0.9883	0.7890	1.50961	1.1172	0.9158	0.9896
Retail	1.0566	0.68217	1.09947	1.21884	0.6754	1.94868	0.01762	0.20031	2.05957	0.96074	1.1922	0.60813	1.5410	0.93158	0.92751	0.98573
Grocery	1.0105	0.94668	1.02002	1.16757	0.3183	1.80051	0.10274	0.12882	1.94676	1.29009	1.277	1.12042	1.4512	0.99799	1.00091	1.09687
Warehouse	1.0021	0.77279	1.28169	2.05114	0.2037	1.8441	0.0471	0.61431	1.89144	1.49235	1.89354	1.54961	1.5153	1.20664	1.20289	1.62568
School	0.8446	0.55787	1.60299	2.36239	0.5000	2.04493	0	0.44761	1.11641	0.34983	3.0434	1.65738	0.9955	0.34091	1.92928	2.74996
Health	1.0176	0.80318	1.12299	1.32205	0.1345	1.77184	0.08161	0.13359	1.90314	1.21469	1.34892	1.19026	1.4834	0.98969	1.03746	1.0564
Lodging	1.0102	1.09218	0.99315	1.14475	0.1242	1.83348	0.27543	1.33368	2.07316	1.36751	0.62052	0.28927	1.5238	1.02359	1.00866	1.02147
Data Centers	1.1010	1.10105	1.24392	1.24392	0.0700	1.82905	0.51254	1.24839	1.55772	1.10105	1.24392	1.24392	1.5577	1.10105	1.24392	1.24392
Non-Jurisdictional	0.9955	0.7088	1.2266	1.6178	0.4927	1.9625	0.0486	0.2931	1.98666	1.07465	1.49159	1.13346	1.6126	0.9456	1.15458	1.27396
Religious Worship	0.9870	0.68522	1.19369	1.49322	0.7961	2.096	0.01329	0.4339	1.96116	1.17786	1.40054	0.78223	1.5499	0.97631	1.06407	1.05062
Miscellaneous	0.9870	0.68522	1.19369	1.49322	0.7961	2.096	0.01329	0.4339	1.96116	1.17786	1.40054	0.78223	1.5499	0.97631	1.06407	1.05062

Commercial Electric Peak To Energy Relationship Table (Utility Coincidence) - Continued (Ratio of peak kW to average kW)

<u> </u>															0.7278 1.2997 1. 1.1733 0.7577 0. 0.73509 1.05629 1.2						
	En	d Use 5 - F	Refrigeration	on	End	Use 6 - Of	fice Equip	ment	En	d Use 7 - \	Vater Hea	ting		End Use 8	- Vending	9					
Building Type	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF					
Office Equipment	1.0631	0.9732	1.0417	1.0464	0.9055	0.8080	1.2487	1.3518	0.9733	0.8523	1.1474	1.2175	0.8862	0.7278	1.2997	1.4241					
Restaurant	1.0953	0.9945	0.9888	1.0020	1.0620	0.9047	0.7691	0.8676	0.9994	0.7015	0.8807	0.9520	1.1680	1.1733	0.7577	0.8192					
Retail	1.0962	0.98118	1.02264	1.02267	1.0157	0.63313	1.08927	1.19508	1.0235	0.62576	1.08131	1.06033	1.0347	0.73509	1.05629	1.22828					
Grocery	1.1118	1.00075	1.01137	1.01862	1.0627	0.74363	1.02881	1.16793	1.0687	0.71743	1.04516	1.38286	1.0464	0.73115	1.09853	1.33604					
Warehouse	1.1532	1.04592	1.10858	1.1155	0.9177	0.6006	1.41332	2.02535	1.0008	0.74503	1.14146	1.52959	1.0677	0.96774	1.17853	1.73969					
School	1.0464	0.97066	1.06068	1.05916	0.5758	0.71631	1.46319	1.58238	0.5051	0.44793	1.52439	1.72396	0.6287	0.57904	1.5163	1.96456					
Health	1.0800	0.96856	1.02464	1.05157	0.9585	0.75212	1.21583	1.30782	0.9585	0.81491	1.17497	1.30169	0.9421	0.74223	1.21392	1.31197					
Lodging	1.0917	0.98095	0.97405	0.99651	1.0155	0.92646	1.03459	1.09242	1.0500	0.82523	1.20061	1.5591	1.0919	1.02521	0.91636	1.03278					
Data Centers	1.1891	1.10105	1.24392	1.24392	1.1010	1.10105	1.24392	1.24392	1.1010	1.10105	1.24392	1.24392	1.1010	1.10105	1.24392	1.24392					
Non-Jurisdictional	1.0782	0.9785	1.02906	1.03688	0.8900	0.71161	1.25802	1.43651	0.9818	0.86376	1.05269	1.09966	0.9377	0.73638	1.23433	1.46525					
Religious Worship	1.0933	0.98384	1.01641	1.02735	0.8745	0.61524	1.26734	1.52121	0.9902	0.87524	0.95794	0.9818	0.9892	0.74502	1.16891	1.50639					
Miscellaneous	1.0933	0.98384	1.01641	1.02735	0.8745	0.61524	1.26734	1.52121	0.9902	0.87524	0.95794	0.9818	0.9892	0.74502	1.16891	1.50639					

Commercial Electric Peak To Energy Relationship Table (Utility Coincidence) - Continued (Ratio of peak kW to average kW)

	E	End Use 9	- Cooking			End Use 1	0 - Heatin	g	Er	nd Use 11	- Pool Pur	np	End	Use 13 - N	/liscellane	ous
Building Type	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF	SON	SOFF	WON	WOFF
Office Equipment	0.7377	0.2447	1.6038	2.1886	0.0000	0.7077	0.8480	1.2188	0.88623	0.7278	1.2997	1.4241	0.8862	0.7278	1.2997	1.4241
Restaurant	1.1200	0.8805	0.7999	0.9876	0.0000	0.7489	0.2214	0.4592	1.16798	1.1733	0.7577	0.8192	1.1680	1.1733	0.7577	0.8192
Retail	0.9886	0.43922	1.2705	1.65943	0.0000	0.18747	0.24661	0.72119	1.0347	0.73509	1.05629	1.22828	1.0347	0.7351	1.0563	1.2283
Grocery	0.9402	0.61281	1.21734	1.61202	0.0000	0.36411	0.10073	0.20945	1.0464	0.73115	1.09853	1.33604	1.0464	0.7312	1.0985	1.3360
Warehouse	0.8348	0.32442	1.49748	2.35407	0.0000	0.23812	0.22433	1.72647	1.0677	0.96774	1.17853	1.73969	1.0677	0.9677	1.1785	1.7397
School	0.5011	0.24827	1.8326	3.52681	0.0000	0.18466	0.57632	2.39847	0.6287	0.57904	1.5163	1.96456	0.6287	0.5790	1.5163	1.9646
Health	1.1222	0.52643	1.11133	1.63007	0.0000	0.82392	0.8514	0.91417	0.9421	0.74223	1.21392	1.31197	0.9421	0.7422	1.2139	1.3120
Lodging	1.1797	0.87842	1.04424	1.36196	0.0000	0.59381	3.71416	4.01853	1.0919	1.02521	0.91636	1.03278	1.0919	1.0252	0.9164	1.0328
Data Centers	1.1010	1.10105	1.24392	1.24392	0.0000	1.10105	1.24392	1.24392	1.1010	1.10105	1.24392	1.24392	1.1010	1.1010	1.2439	1.2439

E. MEASURE INPUTS

esidentiai Ei	ectric Measure Inputs	BASE TECHNOLO	GY EUIs
		(kWh/home)	
Segment	Measure # Measure Description	Single Family	Multifamily
A Existing	1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	2912.00	947.
A Existing	1100 Base Split-System Air Conditioner - Early Replacement (11 SEER)	2713.00	1623.
A Existing	1200 Base Heat Pump Cooling (13 SEER)	2778.00	1339.
A Existing	1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	2394.00	1369.
A Existing	1400 Base Room Air Conditioner - EER 10.6	1504.00	2122.
A Existing	1500 Base Room Air Conditioner, Early Replacement - EER 9.7	1619.00	853.
A Existing	1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	57.00	61.
A Existing	1700 Base Furnace Fan - Furnace & CAC	1109.00	529.
A Existing	2000 Base Heat Pump Space Heating (7.7 HSPF)	4546.00	1710.
A Existing	2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSPF)	4338.00	2326.
A Existing	2200 Base Resistance Space Heating (Primary)	5323.00	2842
A Existing	3000 Base Halogen Lighting - 0.5 hrs/day 2014-2015	148.59	68.
A Existing	3010 Base Halogen Lighting - 0.5 hrs/day 2016-2017	148.59	68
A Existing	3020 Base Halogen Lighting - 0.5 hrs/day 2018-2019	148.59	68
A Existing	3030 Base Halogen Lighting - 0.5 hrs/day 2020	148.59	68
A Existing	3100 Base Halogen Lighting - 2.5 hrs/day 2014-2015	610.29	286
A Existing	3110 Base Halogen Lighting - 2.5 hrs/day 2016-2017	610.29	286
A Existing	3120 Base Halogen Lighting - 2.5 hrs/day 2018-2019	610.29	286
A Existing	3130 Base Halogen Lighting - 2.5 hrs/day 2020	610.29	286
A Existing	3200 Base Halogen Lighting - 6 hrs/day 2014-2015	403.32	178
A Existing	3210 Base Halogen Lighting - 6 hrs/day 2016-2017	403.32	178
A Existing	3220 Base Halogen Lighting - 6 hrs/day 2018-2019	403.32	178
A Existing	3230 Base Halogen Lighting - 6 hrs/day 2020	403.32	178
A Existing	3300 Base CFL Lighting - 0.5 hrs/day 2014-2015	20.00	g
A Existing	3310 Base CFL Lighting - 0.5 hrs/day 2016-2017	20.00	g
A Existing	3320 Base CFL Lighting - 0.5 hrs/day 2018-2019	20.00	g
A Existing	3330 Base CFL Lighting - 0.5 hrs/day 2020	20.00	g
A Existing	3400 Base CFL Lighting - 2.5 hrs/day 2014-2015	82.00	37
A Existing	3410 Base CFL Lighting - 2.5 hrs/day 2016-2017	82.00	37
A Existing	3420 Base CFL Lighting - 2.5 hrs/day 2018-2019	82.00	37
A Existing	3430 Base CFL Lighting - 2.5 hrs/day 2020	82.00	37
A Existing	3500 Base CFL Lighting - 6 hrs/day 2014-2015	54.00	25
A Existing	3510 Base CFL Lighting - 6 hrs/day 2016-2017	54.00	25
A Existing	3520 Base CFL Lighting - 6 hrs/day 2018-2019	54.00	25
A Existing	3530 Base CFL Lighting - 6 hrs/day 2020	54.00	25
A Existing	3600 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2014-2015	64.15	21
A Existing	3610 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2016-2017	64.15	21
A Existing	3620 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2018-2019	64.15	21
A Existing	3630 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	64.15	21
A Existing	3700 Base Halogen (Specialty) Lighting - 2.5 hrs/day 2014-2015	265.75	85
A Existing A Existing	3710 Base Halogen (Specialty) Lighting - 2.5 hrs/day 2016-2017	265.75	85
, L LAISHING	or to base halogen (Openaity) Lighting - 2.3 ms/day 2010-2017	203.13	00

Residential El	ectric Measure Inputs	BASE TECHNOLO	GY EUIs
		(kWh/home)	
Segment	Measure # Measure Description	Single Family	Multifamily
/A Existing	3730 Base Halogen (Specialty) Lighting - 2.5 hrs/day 2020	265.75	85.2
/A Existing	3800 Base Halogen (Specialty) Lighting - 6 hrs/day 2014-2015	175.95	58.4
/A Existing	3810 Base Halogen (Specialty) Lighting - 6 hrs/day 2016-2017	175.95	58.4
/A Existing	3820 Base Halogen (Specialty) Lighting - 6 hrs/day 2018-2019	175.95	58.4
/A Existing	3830 Base Halogen (Specialty) Lighting - 6 hrs/day 2020	175.95	58.
/A Existing	3900 Base Fluorescent Fixture 1.8 hrs/day	442.00	135.
/A Existing	4000 Base Refrigerator	663.00	581.
/A Existing	4100 Base RefrigeratorEarly Replacement	533.00	447.
/A Existing	4200 Base 2nd Refrigerator - Recycling	927.00	530.
/A Existing	4500 Base Freezer	1101.00	1043.
/A Existing	4600 Base Early Replacement Freezer	1105.00	1043.
/A Existing	4700 Base 2nd Freezer Recycling	1101.00	1043.
'A Existing	5000 Base Water Heating (40 gal, EF=0.88)	3538.00	2791.
/A Existing	5100 Base Water Heating Early Replacement to Heat Pump Water Heater	3538.00	2791.
'A Existing	5500 Base Clotheswasher (MEF=1.26)	46.00	46.
A Existing	5600 Base Clothes Dryer (EF=3.01)	697.00	963.
'A Existing	5700 Base Dishwasher (EF=0.65)	260.00	260.
'A Existing	6000 Base Single Speed Pool Pump (RET)	2165.00	2165.
'A Existing	7000 Base Plasma TV	338.00	284.
'A Existing	7100 Base LCD TV	219.00	164.
/A Existing	7200 Base CRT TV	157.00	145.
/A Existing	7300 Base Set-Top Box	299.00	206.
'A Existing	7400 Base DVD Player	35.00	29.
'A Existing	7500 Base Desktop PC	427.00	421.
'A Existing	7600 Base Laptop PC	61.00	49.
'A Existing	8000 Base Cooking	700.00	600.
A Existing	9000 Base Miscellaneous	321.50	270.
'A Existing	9900 Base House Use	14,253	9,30
IC Existing	1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	2507.00	960.
IC Existing	1100 Base Split-System Air Conditioner - Early Replacement (11 SEER)	2380.00	1628.
IC Existing	1200 Base Heat Pump Cooling (13 SEER)	2884.00	1339.
IC Existing	1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	2844.00	1371.
IC Existing	1400 Base Room Air Conditioner - EER 10.6	942.00	2122.
IC Existing	1500 Base Room Air Conditioner, Early Replacement - EER 9.7	1442.00	853.
IC Existing	1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	69.00	74.
NC Existing	1700 Base Furnace Fan - Furnace & CAC	1118.00	533.
NC Existing	2000 Base Heat Pump Space Heating (7.7 HSPF)	3685.00	1710.0

D	Florida Monta de la constante						11517 7									_	
Residential	Electric Measure Inputs				Unit	Unit	NPV of Lifetime			Full = 1	Full						Implementation
		Start	End Saving	s Cost	Equipment	Labor	O & M	Implementation Cost		Incr. = 0 tial Replace		elative Energy	Poduction	Eastors			Type End ROB = Replace on Bu
Seament	Measure # Measure Description	Year	Year Units	Units	Cost	Cost	Cost	Factor		ost Cost	Cost	SS S-ON					Jse RET = Retrofit
VA Existing	1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	2014	2053 home	ton	\$0.00	\$0.00	\$0.00	\$0.00	18	1 1	\$0.00	1 1	1	1	1	1	1 ROB
VA Existing	1001 14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	2014	2053 home	ton	\$107.00	\$0.00	\$0.00	\$107.00	18	1 1	\$107.00	1 1	1	1	1	1	1 ROB
VA Existing	1002 15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	2014	2053 home	ton	\$218.00	\$0.00	\$0.00	\$218.00	18	1 1	\$218.00	1 1	1	1	1	1	1 ROB
VA Existing	1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	2014	2053 home	ton	\$460.00	\$0.00	\$0.00	\$460.00	18	1 1	\$460.00	1 1	1	1	1	1	1 ROB
VA Existing	1004 Proper Refrigerant Charging and Air Flow (CAC)	2014	2053 home	effective ton	\$67.38	\$0.00	\$0.00	\$67.38	10	1 1	\$67.38	1 1	1	1	1	1	1 RET
VA Existing	1005 Proper Sizing and Quality Install (CAC)	2014	2053 home	Unit	\$0.00	\$439.43	\$0.00	\$439.43	18	1 1	\$439.43	1 1	1	1	1	1	1 ROB
VA Existing	1006 AC Maintenance and/or tune-up (CAC)	2014	2053 home	unit	\$0.00	\$82.14	\$0.00	\$82.14	4	1 1	\$82.14	1 1	1	1	1	1	1 ROB
VA Existing	1007 AC Filter Changes (CAC)	2014	2053 home	unit	\$20.00	\$0.00	\$0.00	\$20.00	1	1 1	\$20.00	1 1	1	1	1	1	1 ROB
VA Existing	1008 Ceiling R-0 to R-38 Insulation (CAC)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1 1	\$0.70	1 1	1	1	1	1	1 RET
VA Existing	1009 Ceiling R-0 to R-49 Insulation (CAC)	2014	2053 home	sq.ft.	\$0.87	\$0.00	\$0.00	\$0.87	20	1 1	\$0.87	1 1	1	1	1	1	1 RET
VA Existing	1010 Ceiling R-11 to R-38 Insulaton (CAC)	2014	2053 home	sq.ft.	\$0.54	\$0.00	\$0.00	\$0.54	20	1 1	\$0.54	1 1	1	1	1	1	1 RET
VA Existing	1011 Ceiling R-11 to R-49 Insulation (CAC)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1 1	\$0.70	1 1	1	1	1	1	1 RET
VA Existing	1012 Ceiling R-19 to R-38 Insulation (CAC)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41	20	1 1	\$0.41	1 1	1	1	1	1	1 RET
VA Existing	1013 Ceiling R-19 to R-49 Insulation (CAC)	2014	2053 home	sq.ft.	\$0.58	\$0.00	\$0.00	\$0.58	20	1 1	\$0.58	1 1	1	1	1	1	1 RET
VA Existing	1014 Crawlspace insulation (CAC)	2014	2053 home	sq.ft.	\$0.23	\$0.00	\$0.00	\$0.23	20	1 1	\$0.23	1 1	1	1	1	1	1 RET
VA Existing	1015 Basement insulation R-13 (CAC)	2014	2053 home	sq.ft.	\$0.29	\$0.58	\$0.00	\$0.87	20	1 1	\$0.87	1 1	1	1	1	1	1 RET
VA Existing	1016 Floor R-0 to R-19 Insulation-Batts (CAC)	2014	2053 home	sq.ft.	\$0.38	\$0.51	\$0.00	\$0.89	20	1 1	\$0.89	1 1	1	1	1	1	1 RET
VA Existing	1017 Wall Blow-in R-0 to R-13 Insulation (CAC)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41	20	1 1	\$0.41	1 1	1	1	1	1	1 RET
VA Existing	1018 Cool Roof (CAC)	2014	2053 home	sq.ft.	\$0.27	\$0.00	\$0.00	\$0.27	15	1 1	\$0.27	1 1	1	1	1	1	1 ROB
VA Existing	1019 Duct Insulation (CAC)	2014	2053 home	linear foot	\$0.75	\$0.00	\$0.00	\$0.75	20	1 1	\$0.75	1 1	1	1	1	1	1 RET
VA Existing	1020 Duct Testing and Sealing (CAC)	2014	2053 home	home	\$346.85	\$0.00	\$0.00	\$346.85	18	1 1	\$346.85	1 1	1	1	1	1	1 RET
VA Existing	1021 Return Duct Modification (CAC)	2014	2053 home	Unit	\$350.00	\$0.00	\$0.00	\$350.00	20	1 1	\$350.00	1 1	1	1	1	1	1 RET
VA Existing	1022 Programmable Thermostat (CAC)	2014	2053 home	unit	\$15.60	\$0.00	\$0.00	\$15.60	12	1 1	\$15.60	1 1	1	1	1	1	1 RET
VA Existing	1023 Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	2014	2053 home	home	\$265.63	\$0.00	\$0.00	\$265.63	10	1 1	\$265.63	1 1	1	1	1	1	1 RET
VA Existing	1024 Self Install Weatherization (CAC)	2014	2053 home	home	\$5.74	\$0.00	\$0.00	\$5.74	10	1 1	\$5.74	1 1	1	1	1	1	1 RET
VA Existing	1025 Door Weatherization (CAC)	2014	2053 home	unit	\$11.97	\$0.00	\$0.00	\$11.97	5	1 1	\$11.97	1 1	1	1	1	1	1 RET
VA Existing	1026 Ceiling Fans (CAC)	2014	2053 home	unit	\$80.00	\$40.00	\$0.00	\$120.00	15	1 1	\$120.00	1 1	1	1	1	1	1 RET
VA Existing	1027 Whole House Fans (CAC)	2014	2053 home	unit	\$243.17	\$269.72	\$0.00	\$512.89	15	1 1	\$512.89	1 1	1	1	1	1	1 RET
VA Existing	1028 Window Film (CAC)	2014	2053 home	sq.ft.	\$0.90	\$0.64	\$0.00	\$1.54	10	1 1	\$1.54	1 1	1	1	1	1	1 RET
VA Existing	1029 WINDOWS - Default With Sunscreen (CAC)	2014	2053 home	sq.ft.	\$0.63	\$0.64	\$0.00	\$1.27	10	1 1	\$1.27	1 1	1	1	1	1	1 RET
VA Existing	1030 WINDOWS - Double-Glazed Clear to Energy Star (CAC)	2014	2053 home	sq.ft.	\$0.97	\$0.00	\$0.00	\$0.97	20	1 1	\$0.97	1 1	1	1	1	1	1 ROB
VA Existing	1100 Base Split-System Air Conditioner - Early Replacement (11 SEER)	2014	2053 home	Unit	\$0.00	\$0.00	\$0.00	\$0.00	8	1 1	\$0.00	1 1	1	1	1	1	1 RET
VA Existing	1101 14 SEER (12.15 EER) Split-System Air Conditioner w/ Quality Install - Early Repli	2014	2053 home	Unit	\$546.43	\$0.00	\$0.00	\$546.43	8	1 1	\$546.43	1 1	1	1	1	1	1 RET
VA Existing	1102 Proper Refrigerant Charging and Air Flow (CAC early replacement)	2014	2053 home	effective ton	\$67.38	\$0.00	\$0.00	\$67.38	10	1 1	\$67.38	1 1	1	1	1	1	1 RET
VA Existing	1103 Proper Sizing and Quality Install (CAC early replacement)	2014	2053 home	Unit	\$0.00	\$439.43	\$0.00	\$439.43	18	1 1	\$439.43	1 1	1	1	1	1	1 ROB
VA Existing	1104 AC Maintenance and/or tune-up (CAC early replacement)	2014	2053 home	unit	\$0.00	\$82.14	\$0.00	\$82.14	4	1 1	\$82.14	1 1	1	1	1	1	1 ROB
VA Existing	1105 AC Filter Changes (CAC early replacement)	2014	2053 home	unit	\$20.00	\$0.00	\$0.00	\$20.00	1	1 1	\$20.00	1 1	1	1	1	1	1 ROB
VA Existing	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1 1	\$0.70	1 1	1	1	1	1	1 RET
VA Existing	1107 Ceiling R-0 to R-49 Insulation (CAC early replacement)	2014	2053 home	sq.ft.	\$0.87	\$0.00	\$0.00	\$0.87	20	1 1	\$0.87	1 1	1	1	1	1	1 RET
VA Existing	1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	2014	2053 home	sq.ft.	\$0.54	\$0.00	\$0.00	\$0.54	20	1 1	\$0.54	1 1	1	1	1	1	1 RET
VA Existing	1109 Ceiling R-11 to R-49 Insulation (CAC early replacement)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1 1	\$0.70	1 1	1	1	1	1	1 RET
VA Existing	1110 Ceiling R-19 to R-38 Insulation (CAC early replacement)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41	20	1 1	\$0.41	1 1	1	1	1	1	1 RET
VA Existing	1111 Ceiling R-19 to R-49 Insulation (CAC early replacement)	2014	2053 home	sq.ft.	\$0.58	\$0.00	\$0.00	\$0.58	20	1 1	\$0.58	1 1	1	1	1	1	1 RET
VA Existing	1112 Crawlspace insulation (CAC early replacement)	2014	2053 home	sq.ft.	\$0.23	\$0.00	\$0.00	\$0.23	20	1 1	\$0.23	1 1	1	1	1	1	1 RET
VA Existing	1113 Basement insulation R-13 (CAC early replacement)	2014	2053 home	sq.ft.	\$0.29	\$0.58	\$0.00	\$0.87	20	1 1	\$0.87	1 1	1	1	1	1	1 RET
VA Existing	1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	2014	2053 home	sq.ft.	\$0.38	\$0.51	\$0.00	\$0.89		1 1	\$0.89	1 1	1	1	1	1	1 RET
VA Existing	1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41	20	1 1	\$0.41	1 1	1	1	1	1	1 RET
VA Existing	1116 Cool Roof (CAC early replacement)	2014	2053 home	sq.ft.	\$0.27	\$0.00	\$0.00	\$0.27	15	1 1	\$0.27	1 1	1	1	1	1	1 ROB
VA Existing	1117 Duct Insulation (CAC early replacement)	2014	2053 home	linear foot	\$0.75	\$0.00	\$0.00	\$0.75	20	1 1	\$0.75	1 1	1	1	1	1	1 RET
VA Existing	1118 Duct Testing and Sealing (CAC early replacement)	2014	2053 home	home	\$346.85	\$0.00	\$0.00	\$346.85	18	1 1	\$346.85	1 1	1	1	1	1	1 RET
VA Existing	1119 Return Duct Modification (CAC early replacement)	2014	2053 home	Unit	\$350.00	\$0.00	\$0.00	\$350.00		1 1	\$350.00	1 1	1	1	1	1	1 RET
VA Existing	1120 Programmable Thermostat (CAC early replacement)	2014	2053 home	unit	\$15.60	\$0.00	\$0.00	\$15.60	12	1 1	\$15.60	1 1	1	1	1	1	1 RET
VA Existing	1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early replacement)	2014	2053 home	home	\$265.63	\$0.00	\$0.00	\$265.63	10	1 1	\$265.63	1 1	1	1	1	1	1 RET
VA Existing	1122 Self Install Weatherization (CAC early replacement)	2014	2053 home	home	\$5.74	\$0.00	\$0.00	\$5.74	10	1 1	\$5.74	1 1	1	1	1	1	1 RET
VA Existing	1123 Door Weatherization (CAC early replacement)	2014	2053 home	unit	\$11.97	\$0.00	\$0.00	\$11.97	5	1 1	\$11.97	1 1	1	1	1	1	1 RET
VA Existing	1124 Ceiling Fans (CAC early replacement)	2014	2053 home	unit	\$80.00	\$40.00	\$0.00	\$120.00	15	1 1	\$120.00	1 1	1	1	1	1	1 RET
VA Existing	1125 Whole House Fans (CAC early replacement)	2014	2053 home	unit	\$243.17	\$269.72	\$0.00	\$512.89	15	1 1	\$512.89	1 1	1	1	1	1	1 RET
VA Existing	1126 Window Film (CAC early replacement)	2014	2053 home	sq.ft.	\$0.90	\$0.64	\$0.00	\$1.54	10	1 1	\$1.54	1 1	1	1	1	1	1 RET
VA Existing	1127 WINDOWS - Default With Sunscreen (CAC early replacement)	2014	2053 home	sq.ft.	\$0.63	\$0.64	\$0.00	\$1.27	10	1 1	\$1.27	1 1	1	1	1	1	1 RET
VA Existing		2014	2053 home	sa.ft.	\$0.97	\$0.00	\$0.00	\$0.97	20	1 1	\$0.97	1 1	1	1	1	1	1 ROB
	1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early replacement)	2014	2000 1101116	oq.it.	Ψ0.57	ψ0.00	Ψ0.00	Ψ0.01			*****						
VA Existing	1200 Base Heat Pump Cooling (13 SEER)	2014	2053 home	ton	\$0.00	\$0.00	\$0.00	\$0.00	15	1 1	\$0.00	1 1	1	1	1	1	1 ROB
VA Existing VA Existing					• • •			• • •	15			1 1 1 1	1	1	1 1	1 1	

																_	I Comment
Residential	Electric Measure Inputs						NPV of			Full = 1							mentation
		011	Full Outro		Unit	Unit Labor	Lifetime O & M	Implementation		Incr. = 0	Full Unit	Databas Faccas	S. d d F.			Type	Davidson Davidson
Seament	Measure # Measure Description	Start Year	End Savings Year Units	s Cost Units	Equipment Cost	Cost	Cost	Cost Factor	Service Initi		Cost	Relative Energy SS S-ON			N W OFF	Use RET	Replace on Burnout
VA Existing	1203 Ground Source Heat Pump with Desuperheater (HP cooling)	2014	2053 home	ton	\$1,230.90	\$615.45	\$0.00	\$1,846.35		1 1	\$1,846.35	1 1	1	1	1 1	1 ROB	Retioni
VA Existing	1204 Proper Refrigerant Charging and Air Flow (HP cooling)	2014	2053 home	effective ton	\$67.38	\$0.00	\$0.00	\$67.38		1 1	\$67.38	1 1	1	1	1 1	1 RET	
VA Existing	1205 Proper Sizing and Quality Install (HP cooling)	2014	2053 home	Unit	\$0.00	\$439.43	\$0.00	\$439.43		1 1	\$439.43	1 1	1	1	1 1	1 ROB	
VA Existing	1206 Heat pump tune up	2014	2053 home	unit	\$0.00	\$140.00	\$0.00	\$140.00	5	1 1	\$140.00	1 1	1	1	1 1	1 RET	
VA Existing	1207 Heat Pump Filter Replacement	2014	2053 home	unit	\$20.00	\$0.00	\$0.00	\$20.00		1 1	\$20.00	1 1	1	1	1 1	1 RET	
VA Existing	1208 Ceiling R-0 to R-38 Insulation (HP cooling)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70		1 1	\$0.70	1 1	1		1 1	1 RET	
VA Existing VA Existing	1209 Ceiling R-0 to R-49 Insulation (HP cooling)	2014 2014	2053 home 2053 home	sq.ft. sa.ft.	\$0.87 \$0.54	\$0.00 \$0.00	\$0.00 \$0.00	\$0.87 \$0.54	20 20	1 1	\$0.87 \$0.54	1 1	1		1 1	1 RET 1 RET	
VA Existing VA Existing	1210 Ceiling R-11 to R-38 Insulaton (HP cooling) 1211 Ceiling R-11 to R-49 Insulation (HP cooling)	2014	2053 nome 2053 home	sq.it.	\$0.54	\$0.00	\$0.00	\$0.54		1 1	\$0.54	1 1	1		1 1	1 RET	
VA Existing	1212 Ceiling R-19 to R-38 Insulation (HP cooling)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70		1 1	\$0.70	1 1	1	1	1 1	1 RET	
VA Existing	1213 Ceiling R-19 to R-49 Insulation (HP cooling)	2014	2053 home	sq.ft.	\$0.58	\$0.00	\$0.00	\$0.58	20	1 1	\$0.58	1 1	1	1	1 1	1 RET	
VA Existing	1214 Crawlspace insulation (HP cooling)	2014	2053 home	sq.ft.	\$0.23	\$0.00	\$0.00	\$0.23	20	1 1	\$0.23	1 1	1	1	1 1	1 RET	
VA Existing	1215 Basement insulation R-13 (HP cooling)	2014	2053 home	sq.ft.	\$0.29	\$0.58	\$0.00	\$0.87	20	1 1	\$0.87	1 1	1	1	1 1	1 RET	
VA Existing	1216 Floor R-0 to R-19 Insulation-Batts (HP cooling)	2014	2053 home	sq.ft.	\$0.38	\$0.51	\$0.00	\$0.89		1 1	\$0.89	1 1	1	1	1 1	1 RET	
VA Existing	1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling)	2014	2053 home	sq.ft.	\$0.15	\$1.17	\$0.00	\$1.32		1 1	\$1.32	1 1	1	1	1 1	1 RET	
VA Existing VA Existing	1218 Cool Roof (HP cooling) 1219 Duct Insulation (HP cooling)	2014 2014	2053 home 2053 home	sq.ft. linear foot	\$0.27 \$0.75	\$0.00 \$0.00	\$0.00 \$0.00	\$0.27 \$0.75		1 1	\$0.27 \$0.75	1 1	1	1	1 1	1 ROB 1 RET	
VA Existing	1220 Duct Testing and Sealing (HP cooling)	2014	2053 home	home	\$346.85	\$0.00	\$0.00	\$346.85		1 1	\$346.85	1 1	1		1 1	1 RET	
VA Existing	1221 Programmable Thermostat (HP cooling)	2014	2053 home	unit	\$49.25	\$14.82	\$0.00	\$64.07		1 1	\$64.07	1 1	1		1 1	1 RET	
VA Existing	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)	2014	2053 home	home	\$265.63	\$0.00	\$0.00	\$265.63	10	1 1	\$265.63	1 1	1	1	1 1	1 RET	
VA Existing	1223 Self Install Weatherization (HP cooling)	2014	2053 home	home	\$15.00	\$0.00	\$0.00	\$15.00	10	1 1	\$15.00	1 1	1	1	1 1	1 RET	
VA Existing	1224 Door Weatherization (HP cooling)	2014	2053 home	unit	\$11.97	\$0.00	\$0.00	\$11.97	-	1 1	\$11.97	1 1	1	1	1 1	1 RET	
VA Existing	1225 Ceiling Fans (HP cooling)	2014	2053 home	unit	\$80.00	\$40.00	\$0.00	\$120.00	15	1 1	\$120.00	1 1	1	1	1 1	1 RET	
VA Existing	1226 Whole House Fans (HP cooling)	2014	2053 home	unit	\$243.17	\$269.72	\$0.00	\$512.89		1 1	\$512.89	1 1	1	1	1 1	1 RET	
VA Existing VA Existing	1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling) 1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	2014 2014	2053 home 2053 home	sq.ft. ton	\$1.50 \$0.00	\$0.00 \$0.00	\$0.00 \$0.00	\$1.50 \$0.00		1 1	\$1.50 \$0.00	1 1	1	1	1 1	1 ROB 1 ROB	
VA Existing VA Existing	1301 Heat pump upgrade to (14.5-15.9 SEER, 8.2+ HSPF) (HP cooling Early Replace	2014	2053 home	ton	\$162.06	\$0.00	\$0.00	\$162.06		1 1	\$162.06	1 1	1	1	1 1	1 ROB	
VA Existing	1302 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replacement)	2014	2053 home	ton	\$213.96	\$0.00	\$0.00	\$213.96		1 1	\$213.96	1 1	1	1	1 1	1 ROB	
VA Existing	1303 Ground Source Heat Pump with Desuperheater (HP cooling Early Replacement)	2014	2053 home	ton	\$1,230.90	\$615.45	\$0.00	\$1,846.35		1 1	\$1,846.35	1 1	1	1	1 1	1 ROB	
VA Existing	1304 Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement)	2014	2053 home	effective ton	\$67.38	\$0.00	\$0.00	\$67.38	10	1 1	\$67.38	1 1	1	1	1 1	1 RET	
VA Existing	1305 Proper Sizing and Quality Install (HP cooling Early Replacement)	2014	2053 home	Unit	\$0.00	\$439.43	\$0.00	\$439.43	18	1 1	\$439.43	1 1	1	1	1 1	1 ROB	
VA Existing	1306 Heat pump tune up	2014	2053 home	unit	\$0.00	\$140.00	\$0.00	\$140.00	-	1 1	\$140.00	1 1	1		1 1	1 RET	
VA Existing VA Existing	1307 Heat Pump Filter Replacement 1308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	2014 2014	2053 home 2053 home	unit sa.ft.	\$20.00 \$0.70	\$0.00 \$0.00	\$0.00 \$0.00	\$20.00 \$0.70	1 20	1 1	\$20.00 \$0.70	1 1	1		1 1	1 RET	
VA Existing VA Existing	1308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement) 1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement)	2014	2053 nome 2053 home	sq.rt. sq.ft.	\$0.70 \$0.87	\$0.00	\$0.00	\$0.70		1 1	\$0.70	1 1	1		1 1	1 RET	
VA Existing VA Existing	1310 Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement)	2014	2053 home	sq.n. sa.ft.	\$0.54	\$0.00	\$0.00	\$0.54		1 1	\$0.54	1 1	1	1	1 1	1 RET	
VA Existing	1311 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70		1 1	\$0.70	1 1	1	1	1 1	1 RET	
VA Existing	1312 Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41	20	1 1	\$0.41	1 1	1	1	1 1	1 RET	
VA Existing	1313 Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)	2014	2053 home	sq.ft.	\$0.58	\$0.00	\$0.00	\$0.58		1 1	\$0.58	1 1	1	1	1 1	1 RET	
VA Existing	1314 Crawlspace insulation (HP cooling Early Replacement)	2014	2053 home	sq.ft.	\$0.23	\$0.00	\$0.00	\$0.23		1 1	\$0.23	1 1	1	1	1 1	1 RET	
VA Existing	1315 Basement insulation R-13 (HP cooling Early Replacement)	2014	2053 home	sq.ft.	\$0.29	\$0.58	\$0.00	\$0.87	20	1 1	\$0.87	1 1	1	1	1 1	1 RET	
VA Existing	1316 Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement)	2014	2053 home	sq.ft.	\$0.38 \$0.15	\$0.51	\$0.00 \$0.00	\$0.89		1 1	\$0.89 \$1.32	1 1	1		1 1	1 RET 1 RET	
VA Existing VA Existing	1317 Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement) 1318 Cool Roof (HP cooling Early Replacement)	2014 2014	2053 home 2053 home	sq.ft. sa.ft.	\$0.15	\$1.17 \$0.00	\$0.00	\$1.32 \$0.27	20 15	1 1	\$0.27	1 1	1	1	1 1	1 ROB	
VA Existing	1319 Duct Insulation (HP cooling Early Replacement)	2014	2053 home	linear foot	\$0.75	\$0.00	\$0.00	\$0.75		1 1	\$0.75	1 1	1	1	1 1	1 RET	
VA Existing	1320 Duct Testing and Sealing (HP cooling Early Replacement)	2014	2053 home	home	\$346.85	\$0.00	\$0.00	\$346.85	18	1 1	\$346.85	1 1	1	1	1 1	1 RET	
VA Existing	1321 Programmable Thermostat (HP cooling Early Replacement)	2014	2053 home	unit	\$49.25	\$14.82	\$0.00	\$64.07	12	1 1	\$64.07	1 1	1	1	1 1	1 RET	
VA Existing	1322 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early Replacement	2014	2053 home	home	\$265.63	\$0.00	\$0.00	\$265.63	10	1 1	\$265.63	1 1	1	1	1 1	1 RET	
VA Existing	1323 Self Install Weatherization (HP cooling Early Replacement)	2014	2053 home	home	\$15.00	\$0.00	\$0.00	\$15.00		1 1	\$15.00	1 1	1		1 1	1 RET	
VA Existing	1324 Door Weatherization (HP cooling Early Replacement)	2014	2053 home	unit	\$11.97	\$0.00	\$0.00	\$11.97	-	1 1	\$11.97	1 1	1	1	1 1	1 RET	
VA Existing VA Existing	1325 Ceiling Fans (HP cooling early replacement) 1326 Whole House Fans (HP cooling early replacement)	2014 2014	2053 home 2053 home	unit unit	\$80.00 \$243.17	\$40.00 \$269.72	\$0.00 \$0.00	\$120.00 \$512.89		1 1	\$120.00 \$512.89	1 1	1	1	1 1	1 RET 1 RET	
VA Existing VA Existing	1325 Whole House Fans (HP cooling early replacement) 1327 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Replacemer	2014	2053 nome 2053 home	unit sq.ft.	\$243.17 \$1.50	\$269.72	\$0.00	\$512.89 \$1.50		1 1	\$512.89 \$1.50	1 1	1	1	1 1	1 REI	
VA Existing	1400 Base Room Air Conditioner - EER 10.6	2014	2053 home	unit	\$0.00	\$0.00	\$0.00	\$0.00	9	1 1	\$0.00	1 1	1	1	1 1	1 ROB	
VA Existing	1401 Energy Star Room Air Conditioner - EER 10.8	2014	2053 home	unit	\$50.00	\$0.00	\$0.00	\$50.00		1 1	\$50.00	1 1	1	1	1 1	1 ROB	
VA Existing	1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	2014	2053 home	unit	\$103.00	\$0.00	\$0.00	\$103.00	9	1 1	\$103.00	1 1	1	1	1 1	1 ROB	
VA Existing	1403 Room AC Filter Replacement	2014	2053 home	unit	\$20.00	\$0.00	\$0.00	\$20.00	1	1 1	\$20.00	1 1	1	1	1 1	1 RET	
VA Existing	1404 Ceiling R-0 to R-38 Insulation (RAC)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70		1 1	\$0.70	1 1	1		1 1	1 RET	
VA Existing	1405 Ceiling R-0 to R-49 Insulation (RAC)	2014	2053 home	sq.ft.	\$0.87	\$0.00	\$0.00	\$0.87		1 1	\$0.87	1 1	1		1 1	1 RET	
VA Existing	1406 Ceiling R-11 to R-38 Insulaton (RAC)	2014	2053 home	sq.ft.	\$0.54	\$0.00	\$0.00	\$0.54		1 1	\$0.54	1 1	1	1	1 1	1 RET	
VA Existing VA Existing	1407 Ceiling R-11 to R-49 Insulation (RAC) 1408 Ceiling R-19 to R-38 Insulation (RAC)	2014 2014	2053 home 2053 home	sq.ft. sq.ft.	\$0.70 \$0.41	\$0.00 \$0.00	\$0.00 \$0.00	\$0.70 \$0.41		1 1	\$0.70 \$0.41	1 1	1	1	1 1	1 RET 1 RET	
VA Existing VA Existing	1409 Ceiling R-19 to R-36 Insulation (RAC)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41		1 1	\$0.41	1 1	1		1 1	1 RET	
VA ENSUIN	. 100 Salling IV-10 to IV-40 insulation (IVAO)	2014	2000 1101118	Jq.11.	φυ.υδ	φυ.υυ	90.00	φυ.36	20	. '	φυ.υδ		'			I KET	

Decidential	Electric Measure Inputs						NPV of			Full = 1					_		Implementation
Residential	Electric weasure inputs				Unit	Unit	Lifetime	Implementation		Incr. = 0	Full						Implementation Type
		Start	End Saving	s Cost	Equipment	Labor	O & M	Cost	Service Ini	tial Replace		elative Energy	Reduction	Factors		E	End ROB = Replace on Burnor
Segment	Measure # Measure Description	Year	Year Units	Units	Cost	Cost	Cost	Factor	Life Co	ost Cost	Cost	SS S-ON	S-MD S	S-OFF V	v-on w-		Jse RET = Retrofit
VA Existing	1410 Wall Blow-in R-0 to R-13 Insulation (RAC)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41	20	1 1	\$0.41	1 1	1	1	1	1	1 RET
VA Existing	1411 Cool Roof (RAC)	2014	2053 home	sq.ft.	\$0.27	\$0.00	\$0.00	\$0.27	15	1 1	\$0.27	1 1	1	1	1	1	1 ROB
VA Existing	1412 Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	2014	2053 home	home	\$265.63	\$0.00	\$0.00	\$265.63	10	1 1	\$265.63	1 1	1	1	1	1	1 RET
VA Existing	1413 Self Install Weatherization (RAC)	2014	2053 home	home	\$5.74	\$0.00	\$0.00	\$5.74	10	1 1	\$5.74	1 1	1	1	1	1	1 RET
VA Existing	1414 Door Weatherization (RAC)	2014	2053 home	unit	\$11.97	\$0.00	\$0.00	\$11.97	5	1 1	\$11.97	1 1	1	1	1	1	1 RET
VA Existing	1415 Ceiling Fans (RAC)	2014	2053 home	unit	\$80.00	\$40.00	\$0.00	\$120.00		1 1	\$120.00	1 1	1	1	1	1	1 RET
VA Existing VA Existing	1416 Whole House Fans (RAC) 1417 Window Film (RAC)	2014 2014	2053 home 2053 home	unit sa.ft.	\$243.17 \$0.90	\$269.72 \$0.64	\$0.00 \$0.00	\$512.89 \$1.54	15 10	1 1	\$512.89 \$1.54	1 1	1	1	1	1	1 RET 1 RET
VA Existing VA Existing	1417 William (RAC) 1418 WINDOWS - Default With Sunscreen (RAC)	2014	2053 nome	sq.it.	\$0.90	\$0.64	\$0.00	\$1.54 \$1.27	10	1 1	\$1.54 \$1.27	1 1	1	1	1	1	1 RFT
VA Existing VA Existing	1419 WINDOWS - Delault Will Sunscieer (KAC) 1419 WINDOWS - Double-Glazed Clear to Energy Star (RAC)	2014	2053 home	sq.ft.	\$0.97	\$0.04	\$0.00	\$0.97	20	1 1	\$0.97	1 1	1	1	1	1	1 ROB
VA Existing	1500 Base Room Air Conditioner, Early Replacement - EER 9.7	2014	2053 home	unit	\$271.00	\$0.00	\$0.00	\$271.00		1 1	\$271.00	1 1	1	1	1	1	1 ROB
VA Existing	1501 EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early replacement)	2014	2053 home	unit	\$736.25	\$0.00	\$0.00	\$736.25	9	1 1	\$736.25	1 1	1	1	1	1	1 RET
VA Existing	1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	2014	2053 home	unit	\$100.00	\$0.00	\$0.00	\$100.00	12	1 1	\$100.00	1 1	1	1	1	1	1 ROB
VA Existing	1601 10% better than Energy Star Dehumidifier ROB (35-45 pints/day)	2014	2053 home	unit	\$110.00	\$0.00	\$0.00	\$110.00	12	0 0	\$110.00	1 1	1	1	1	1	1 ROB
VA Existing	1700 Base Furnace Fan - Furnace & CAC	2014	2053 home	Unit	\$0.00	\$0.00	\$0.00	\$0.00		1 1	\$0.00	1 1	1	1	1	1	12 ROB
VA Existing	1701 ECM Furnace Fan (variable speed motor) - Cooling	2014	2053 home	Unit	\$175.00	\$0.00	\$0.00	\$175.00		1 1	\$175.00	1 1	1	1	1	1	12 RET
VA Existing	2000 Base Heat Pump Space Heating (7.7 HSPF)	2014	2053 home	Unit	\$0.00	\$0.00	\$0.00	\$0.00	18	1 1	\$0.00	1 1	1	1	1	1	9 ROB
VA Existing	2001 Heat pump upgrade to 14.5-15.9 SEER/8.2+ HSPF (HP heating)	2014	2053 home	ton	\$111.94	\$0.00	\$0.00	\$111.94	15	1 1	\$111.94	1 1	1	1	1	1	9 ROB
VA Existing	2002 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	2014	2053 home	ton	\$197.04	\$0.00	\$0.00	\$197.04	15	1 1	\$197.04	1 1	1	1	1	1	9 ROB
VA Existing VA Existing	2003 Ground Source Heat Pump with Desuperheater (HP heating) 2004 Heat pump tune up	2014 2014	2053 home 2053 home	ton unit	\$1,230.90 \$0.00	\$615.45 \$140.00	\$0.00 \$0.00	\$1,846.35 \$140.00	15 5	1 1	\$1,846.35 \$140.00	1 1	1	1	1	1	9 ROB 9 RET
VA Existing VA Existing	2004 Heat pump titre up 2005 Heat Pump Filter Replacement	2014	2053 nome 2053 home	unit	\$20.00	\$0.00	\$0.00	\$140.00	1	1 1	\$20.00	1 1	1	1	1	1	9 RET
VA Existing	2006 Ceiling R-0 to R-38 Insulation (HP heating)	2014	2053 home	sa.ft.	\$0.70	\$0.00	\$0.00	\$0.70		1 1	\$0.70	1 1	1	1	1	1	9 RET
VA Existing	2007 Ceiling R-0 to R-49 Insulation (HP heating)	2014	2053 home	sa.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1 1	\$0.70	1 1	1	1	1	1	9 RET
VA Existing	2008 Ceiling R-11 to R-38 Insulaton (HP heating)	2014	2053 home	sq.ft.	\$0.54	\$0.00	\$0.00	\$0.54	20	1 1	\$0.54	1 1	1	1	1	1	9 RET
VA Existing	2009 Ceiling R-11 to R-49 Insulation (HP heating)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1 1	\$0.70	1 1	1	1	1	1	9 RET
VA Existing	2010 Ceiling R-19 to R-38 Insulation (HP heating)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41	20	1 1	\$0.41	1 1	1	1	1	1	9 RET
VA Existing	2011 Ceiling R-19 to R-49 Insulation (HP heating)	2014	2053 home	sq.ft.	\$0.58	\$0.00	\$0.00	\$0.58	20	1 1	\$0.58	1 1	1	1	1	1	9 RET
VA Existing	2012 Crawlspace insulation (HP heating)	2014	2053 home	sq.ft.	\$0.23	\$0.00	\$0.00	\$0.23	20	1 1	\$0.23	1 1	1	1	1	1	9 RET
VA Existing	2013 Basement insulation R-13 (HP heating)	2014	2053 home	sq.ft.	\$0.29	\$0.58	\$0.00	\$0.87	20	1 1	\$0.87	1 1	1	1	1	1	9 RET
VA Existing	2014 Floor R-0 to R-19 Insulation-Batts (HP heating)	2014	2053 home	sq.ft.	\$0.38	\$0.51	\$0.00	\$0.89	20	1 1	\$0.89	1 1	1	1	1	1	9 RET
VA Existing	2015 Wall Blow-in R-0 to R-13 Insulation (HP heating)	2014	2053 home	sq.ft.	\$0.15	\$1.17	\$0.00	\$1.32	20	1 1	\$1.32	1 1	1	1	1	1	9 RET
VA Existing	2016 Duct Insulation (HP heating)	2014	2053 home	linear foot	\$0.75	\$0.00	\$0.00	\$0.75	20	1 1	\$0.75	1 1	1	1	1	1	9 RET
VA Existing	2017 Duct Testing and Sealing (HP heating) 2018 Heat Recovery Ventilators (HP heating)	2014 2014	2053 home 2053 home	home	\$346.85 \$1,200.00	\$0.00 \$500.00	\$0.00 \$0.00	\$346.85	18 20	1 1	\$346.85 \$1,700.00	1 1	1	1	1	1	9 RET 9 ROB
VA Existing VA Existing	2019 Programmable Thermostat (HP heating)	2014	2053 nome 2053 home	unit	\$1,200.00	\$14.82	\$0.00	\$1,700.00 \$64.07	12	1 1	\$64.07	1 1	1	1	1	1	9 ROB 9 RET
VA Existing	2020 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	2014	2053 home	home	\$265.63	\$0.00	\$0.00	\$265.63		1 1	\$265.63	1 1	1	1	1	1	9 RET
VA Existing	2021 Self Install Weatherization (HP heating)	2014	2053 home	home	\$15.00	\$0.00	\$0.00	\$15.00	10	1 1	\$15.00	1 1	1	1	1	1	9 RET
VA Existing	2022 Door Weatherization (HP heating)	2014	2053 home	unit	\$11.97	\$0.00	\$0.00	\$11.97	5	1 1	\$11.97	1 1	1	1	1	1	9 RET
VA Existing	2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	2014	2053 home	sq.ft.	\$1.50	\$0.00	\$0.00	\$1.50	20	1 1	\$1.50	1 1	1	1	1	1	9 ROB
VA Existing	2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSPF)	2014	2053 home	Unit	\$0.00	\$0.00	\$0.00	\$0.00	18	1 1	\$0.00	1 1	1	1	1	1	9 ROB
VA Existing	2101 Heat pump upgrade to 14.5-15.9 SEER/8.2+ HSPF (HP heating early replaceme	2014	2053 home	ton	\$111.94	\$0.00	\$0.00	\$111.94	15	1 1	\$111.94	1 1	1	1	1	1	9 ROB
VA Existing	2102 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early replacement)	2014	2053 home	ton	\$197.04	\$0.00	\$0.00	\$197.04	15	1 1	\$197.04	1 1	1	1	1	1	9 ROB
VA Existing	2103 Ground Source Heat Pump with Desuperheater (HP heating early replacement)	2014	2053 home	ton	\$1,230.90	\$615.45	\$0.00	\$1,846.35		1 1	\$1,846.35	1 1	1	1	1	1	9 ROB
VA Existing	2104 Heat pump tune up (heating)	2014	2053 home	unit	\$0.00	\$140.00	\$0.00	\$140.00		1 1	\$140.00	1 1	1	1	1	1	9 RET
VA Existing	2105 Heat Pump Filter Replacement (heating)	2014	2053 home	unit	\$20.00	\$0.00	\$0.00	\$20.00		1 1	\$20.00	1 1	1	1	1	1	9 RET
VA Existing	2106 Ceiling R-0 to R-38 Insulation (HP heating early replacement)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70		1 1	\$0.70	1 1	1	1	1	1	9 RET
VA Existing VA Existing	2107 Ceiling R-0 to R-49 Insulation (HP heating early replacement) 2108 Ceiling R-11 to R-38 Insulaton (HP heating early replacement)	2014 2014	2053 home 2053 home	sq.ft. sa.ft.	\$0.87 \$0.54	\$0.00 \$0.00	\$0.00 \$0.00	\$0.87 \$0.54	20 20	1 1	\$0.87 \$0.54	1 1	1	1	1	1	9 RET 9 RET
VA Existing VA Existing	2109 Ceiling R-11 to R-36 insulation (HP heating early replacement)	2014	2053 nome 2053 home	sq.n. sq.ft.	\$0.54	\$0.00	\$0.00	\$0.54	20	1 1	\$0.54	1 1	1	1	1	1	9 RET
VA Existing VA Existing	2110 Ceiling R-19 to R-38 Insulation (HP heating early replacement)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1 1	\$0.70	1 1	1	1	1	1	9 RET
VA Existing	2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement)	2014	2053 home	sa.ft.	\$0.58	\$0.00	\$0.00	\$0.58	20	1 1	\$0.58	1 1	1	1	1	1	9 RET
VA Existing	2112 Crawlspace insulation (HP heating early replacement)	2014	2053 home	sq.ft.	\$0.23	\$0.00	\$0.00	\$0.23	20	1 1	\$0.23	1 1	1	1	1	1	9 RET
VA Existing	2113 Basement insulation R-13 (HP heating early replacement)	2014	2053 home	sq.ft.	\$0.29	\$0.58	\$0.00	\$0.87	20	1 1	\$0.87	1 1	1	1	1	1	9 RET
VA Existing	2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replacement)	2014	2053 home	sq.ft.	\$0.38	\$0.51	\$0.00	\$0.89	20	1 1	\$0.89	1 1	1	1	1	1	9 RET
VA Existing	2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacement)	2014	2053 home	sq.ft.	\$0.15	\$1.17	\$0.00	\$1.32	20	1 1	\$1.32	1 1	1	1	1	1	9 RET
VA Existing	2116 Duct Insulation (HP heating early replacement)	2014	2053 home	linear foot	\$0.75	\$0.00	\$0.00	\$0.75	20	1 1	\$0.75	1 1	1	1	1	1	9 RET
VA Existing	2117 Duct Testing and Sealing (HP heating early replacement)	2014	2053 home	home	\$346.85	\$0.00	\$0.00	\$346.85	18	1 1	\$346.85	1 1	1	1	1	1	9 RET
VA Existing	2118 Heat Recovery Ventilators (HP heating early replacement)	2014	2053 home	unit	\$1,200.00	\$500.00	\$0.00	\$1,700.00		1 1	\$1,700.00	1 1	1	1	1	1	9 ROB
VA Existing	2119 Programmable Thermostat (HP heating early replacement)	2014	2053 home	unit	\$49.25	\$14.82	\$0.00	\$64.07	12	1 1	\$64.07	1 1	1	1	1	1	9 RET
VA Existing	2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating early replacement)	2014	2053 home	home	\$265.63	\$0.00	\$0.00	\$265.63	10	1 1	\$265.63	1 1	1	1	1	1	9 RET
VA Existing	2121 Self Install Weatherization (HP heating early replacement)	2014	2053 home	home	\$15.00	\$0.00	\$0.00	\$15.00 \$14.07	10	1 1	\$15.00	1 1	1	1	1	1	9 RET
VA Existing	2122 Door Weatherization (HP heating early replacement)	2014	2053 home	unit	\$11.97	\$0.00	\$0.00	\$11.97	5	1 1	\$11.97	1 1	1	1	1	1	9 RET

Residentia	Electric Measure Inputs						NPV of			Full = 1						Implementation
		Start	Fad Carian		Unit	Unit	Lifetime	Implementation	Caniaa la	Incr. = 0	Full	Dalatina Faces	. Dadination F			Type
Seament	Measure # Measure Description	Year	End Savings	s Cost	Equipment Cost	Labor	O & M Cost	Cost		itial Replac	e Unit	Relative Energ				End ROB = Replace on Burnout Use RET = Retrofit
VA Existing	2123 WINDOWS - Double-Glazed Clear to Energy Star (HP heating early replacement	2014	2053 home	sa.ft.	\$1.50	\$0.00	\$0.00	\$1.50	20	1	1 \$1.50	1	1 1	1	1 1	9 ROB
VA Existing	2200 Base Resistance Space Heating (Primary)	2014	2053 home	ton	\$0.00	\$0.00	\$0.00	\$0.00	15		1 \$0.00	1	1 1	1	1 1	9 ROB
VA Existing	2201 Air Source Heat Pump (resistance heating)	2014	2053 home	ton	\$60.00	\$0.00	\$0.00	\$60.00	15	1	1 \$60.00	1	 1 1	1	1 1	9 ROB
VA Existing	2202 Ground Source Heat Pump with Desuperheater (resistance heating)	2014	2053 home	ton	\$1,230.90	\$615.45	\$0.00	\$1,846.35	15	1	1 \$1.846.35	1	1 1	1	1 1	9 ROB
VA Existing	2203 Ceiling R-0 to R-38 Insulation (resistance heating)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1	1 \$0.70	1	1 1	1	1 1	9 RET
VA Existing	2204 Ceiling R-0 to R-49 Insulation (resistance heating)	2014	2053 home	sq.ft.	\$0.87	\$0.00	\$0.00	\$0.87	20	1	1 \$0.87	1	1 1	1	1 1	9 RET
VA Existing	2205 Ceiling R-11 to R-38 Insulaton (resistance heating)	2014	2053 home	sq.ft.	\$0.54	\$0.00	\$0.00	\$0.54	20	1	1 \$0.54	1	1 1	1	1 1	9 RET
VA Existing	2206 Ceiling R-11 to R-49 Insulation (resistance heating)	2014	2053 home	sq.ft.	\$0.70	\$0.00	\$0.00	\$0.70	20	1	1 \$0.70	1	1 1	1	1 1	9 RET
VA Existing	2207 Ceiling R-19 to R-38 Insulation (resistance heating)	2014	2053 home	sq.ft.	\$0.41	\$0.00	\$0.00	\$0.41	20	1	1 \$0.41	1	1 1	1	1 1	9 RET
VA Existing	2208 Ceiling R-19 to R-49 Insulation (resistance heating)	2014	2053 home	sq.ft.	\$0.58	\$0.00	\$0.00	\$0.58	20	1	1 \$0.58	1	1 1		1 1	9 RET
VA Existing	2209 Crawlspace insulation (resistance heating)	2014	2053 home	sq.ft.	\$0.23	\$0.00	\$0.00	\$0.23	20	1	1 \$0.23	1	1 1		1 1	9 RET
VA Existing	2210 Basement insulation R-13 (resistance heating)	2014	2053 home	sq.ft.	\$0.29	\$0.58	\$0.00	\$0.87	20	1	1 \$0.87	1	1 1	1	1 1	9 RET
VA Existing	2211 Floor R-0 to R-19 Insulation-Batts (resistance heating)	2014	2053 home	sq.ft.	\$0.38	\$0.51	\$0.00	\$0.89	20	1	1 \$0.89 1 \$1.32	1	1 1	1	1 1	9 RET 9 RET
VA Existing VA Existing	2212 Wall Blow-in R-0 to R-13 Insulation (resistance heating) 2213 Heat Recovery Ventilators (resistance heating)	2014 2014	2053 home 2053 home	sq.ft. unit	\$0.15 \$1.200.00	\$1.17 \$500.00	\$0.00 \$0.00	\$1.32 \$1.700.00	20 20		1 \$1.32	1	1 1	1	1 1	9 REI 9 ROB
VA Existing VA Existing	2214 Programmable Thermostat (resistance heating)	2014	2053 nome 2053 home	unit	\$1,200.00	\$14.82	\$0.00	\$1,700.00	12	1	1 \$64.07	1	1 1	1	1 1	9 RET
VA Existing VA Existing	2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating)	2014	2053 home	home	\$265.63	\$0.00	\$0.00	\$265.63	10	1	1 \$265.63	1	1 1	1	1 1	9 RET
VA Existing	2216 Self Install Weatherization	2014	2053 home	home	\$15.00	\$0.00	\$0.00	\$15.00	10	1	1 \$15.00	1	1 1	1	1 1	9 RET
VA Existing	2217 Door Weatherization (resistance heating)	2014	2053 home	unit	\$11.97	\$0.00	\$0.00	\$11.97	5	1	1 \$11.97	1	1 1	1	1 1	9 RET
VA Existing	2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance heating)	2014	2053 home	sq.ft.	\$1.50	\$0.00	\$0.00	\$1.50	20	1	1 \$1.50	1	1 1	1	1 1	9 ROB
VA Existing	3000 Base Halogen Lighting - 0.5 hrs/day 2014-2015	2014	2015 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1	1	1 1	2 RET
VA Existing	3001 CFL (base Halogen 0.5 hrs/day) 2014-2015	2014	2015 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 ROB
VA Existing	3002 LEDs (base Halogen 0.5 hrs/day) 2014-2015	2014	2015 home	lamp	\$11.00	\$0.00	\$0.00	\$11.00	35000	0	0 \$11.00	1	1 1	1	1 1	2 ROB
VA Existing	3010 Base Halogen Lighting - 0.5 hrs/day 2016-2017	2016	2017 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1	1	1 1	2 RET
VA Existing	3011 CFL (base Halogen 0.5 hrs/day) 2016-2017	2016	2017 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 ROB
VA Existing	3012 LEDs (base Halogen 0.5 hrs/day) 2016-2017	2016	2017 home	lamp	\$8.00	\$0.00	\$0.00	\$8.00			0 \$8.00	1	1 1		1 1	2 ROB
VA Existing	3020 Base Halogen Lighting - 0.5 hrs/day 2018-2019	2018	2019 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1		1 1	2 RET
VA Existing	3021 CFL (base Halogen 0.5 hrs/day) 2018-2019	2018	2019 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 ROB
VA Existing	3022 LEDs (base Halogen 0.5 hrs/day) 2018-2019	2018	2019 home	lamp	\$5.00 \$1.57	\$0.00 \$0.00	\$0.00 \$0.00	\$5.00	35000 1000	-	0 \$5.00 1 \$1.57	1	1 1	1	1 1	2 ROB 2 RFT
VA Existing VA Existing	3030 Base Halogen Lighting - 0.5 hrs/day 2020 3032 LEDs (base Halogen 0.5 hrs/day) 2020	2020	2053 home 2053 home	lamp lamp	\$1.57 \$4.00	\$0.00	\$0.00	\$1.57 \$4.00		0	0 \$4.00	1	1 1		1 1	2 ROB
VA Existing VA Existing	3100 Base Halogen Lighting - 2.5 hrs/day 2014-2015	2014	2015 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1	1	1 1	2 RET
VA Existing VA Existing	3101 CFL (base Halogen 2.5 hrs/day) 2014-2015	2014	2015 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 ROB
VA Existing	3102 LEDs (base Halogen 2.5 hrs/day) 2014-2015	2014	2015 home	lamp	\$11.00	\$0.00	\$0.00	\$11.00		-	0 \$11.00	1	1 1	1	1 1	2 ROB
VA Existing	3110 Base Halogen Lighting - 2.5 hrs/day 2016-2017	2016	2017 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1	1	1 1	2 RET
VA Existing	3111 CFL (base Halogen 2.5 hrs/day) 2016-2017	2016	2017 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 ROB
VA Existing	3112 LEDs (base Halogen 2.5 hrs/day) 2016-2017	2016	2017 home	lamp	\$8.00	\$0.00	\$0.00	\$8.00	35000	0	0 \$8.00	1	1 1	1	1 1	2 ROB
VA Existing	3120 Base Halogen Lighting - 2.5 hrs/day 2018-2019	2018	2019 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1	1	1 1	2 RET
VA Existing	3121 CFL (base Halogen 2.5 hrs/day) 2018-2019	2018	2019 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 ROB
VA Existing	3122 LEDs (base Halogen 2.5 hrs/day) 2018-2019	2018	2019 home	lamp	\$5.00	\$0.00	\$0.00	\$5.00	35000	0	0 \$5.00	1	1 1	1	1 1	2 ROB
VA Existing	3130 Base Halogen Lighting - 2.5 hrs/day 2020	2020	2053 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1	1	1 1	2 RET
VA Existing	3132 LEDs (base Halogen 2.5 hrs/day) 2020	2020	2053 home	lamp	\$4.00	\$0.00	\$0.00	\$4.00	35000		0 \$4.00	1	1 1	1	1 1	2 ROB
VA Existing	3200 Base Halogen Lighting - 6 hrs/day 2014-2015	2014	2015 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1	1	1 1	2 RET
VA Existing	3201 CFL (base Halogen 6 hrs/day) 2014-2015	2014	2015 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 ROB
VA Existing VA Existing	3202 LEDs (base Halogen 6 hrs/day) 2014-2015 3210 Base Halogen Lighting - 6 hrs/day 2016-2017	2014 2016	2015 home	lamp lamp	\$11.00 \$1.57	\$0.00 \$0.00	\$0.00 \$0.00	\$11.00 \$1.57	35000 1000	0	0 \$11.00 1 \$1.57	1	1 1	1	1 1	2 ROB 2 RFT
VA Existing VA Existing	3210 Base Halogen Eightling - 6 His/day 2016-2017 3211 CFL (base Halogen 6 hrs/day) 2016-2017	2016	2017 home 2017 home	lamp	\$1.82	\$0.00	\$0.00	\$1.57 \$1.82	8000	0	1 \$1.82	1	1 1		1 1	2 ROB
VA Existing VA Existing	3212 LEDs (base Halogen 6 hrs/day) 2016-2017	2016	2017 home	lamp	\$8.00	\$0.00	\$0.00	\$8.00	35000		0 \$8.00	1	1 1		1 1	2 ROB
VA Existing	3220 Base Halogen Lighting - 6 hrs/day 2018-2019	2018	2019 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	 1 1	1	1 1	2 RET
VA Existing	3221 CFL (base Halogen 6 hrs/day) 2018-2019	2018	2019 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 ROB
VA Existing	3222 LEDs (base Halogen 6 hrs/day) 2018-2019	2018	2019 home	lamp	\$5.00	\$0.00	\$0.00	\$5.00	35000	0	0 \$5.00	1	1 1	1	1 1	2 ROB
VA Existing	3230 Base Halogen Lighting - 6 hrs/day 2020	2020	2053 home	lamp	\$1.57	\$0.00	\$0.00	\$1.57	1000	0	1 \$1.57	1	1 1	1	1 1	2 RET
VA Existing	3232 LEDs (base Halogen 6 hrs/day) 2020	2020	2053 home	lamp	\$4.00	\$0.00	\$0.00	\$4.00	35000	0	0 \$4.00	1	1 1	1	1 1	2 ROB
VA Existing	3300 Base CFL Lighting - 0.5 hrs/day 2014-2015	2014	2015 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 RET
VA Existing	3301 LEDs (base CFL 0.5 hrs/day) 2014-2015	2014	2015 home	lamp	\$11.00	\$0.00	\$0.00	\$11.00		0	0 \$11.00	1	1 1	1	1 1	2 ROB
VA Existing	3310 Base CFL Lighting - 0.5 hrs/day 2016-2017	2016	2017 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1		1 1	2 RET
VA Existing	3311 LEDs (base CFL 0.5 hrs/day) 2016-2017	2016	2017 home	lamp	\$8.00	\$0.00	\$0.00	\$8.00	35000		0 \$8.00	1	1 1		1 1	2 ROB
VA Existing	3320 Base CFL Lighting - 0.5 hrs/day 2018-2019	2018	2019 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 RET
VA Existing	3321 LEDs (base CFL 0.5 hrs/day) 2018-2019	2018	2019 home	lamp	\$5.00	\$0.00	\$0.00	\$5.00		-	0 \$5.00	1	1 1	1	1 1	2 ROB
VA Existing	3330 Base CFL Lighting - 0.5 hrs/day 2020	2020	2053 home	lamp	\$1.82	\$0.00	\$0.00 \$0.00	\$1.82	8000	0	1 \$1.82	1	1 1	1	1 1	2 RET 2 ROB
VA Existing	3331 LEDs (base CFL 0.5 hrs/day) 2020	2020 2014	2053 home	lamp lamp	\$4.00	\$0.00	\$0.00 \$0.00	\$4.00	35000 8000	0	0 \$4.00	1	1 1	1	1 1	
VA Existing VA Existing	3400 Base CFL Lighting - 2.5 hrs/day 2014-2015 3401 LEDs (base CFL 2.5 hrs/day) 2014-2015	2014	2015 home 2015 home	lamp	\$1.82 \$11.00	\$0.00 \$0.00	\$0.00	\$1.82 \$11.00			1 \$1.82 0 \$11.00	1	ı 1		1 1	2 RET 2 ROB
VA EXISTING	3401 LEDS (Dase OFL 2.5 HIS/day) 2014-2015	2014	ZUI5 nome	amp	\$11.00	\$0.00	\$0.00	\$11.00	35000	U	U \$11.00	1	1	1	1	2 KUD

Residential	Electric Measure Inputs						NPV of			Full =	1								Implementation
					Unit	Unit	Lifetime I	mplementation		Incr. =	0	Full							Туре
		Start	End Saving	s Cost	Equipment	Labor	O & M	Cost	Service	Initial Re	place	Unit R	Relative E	nergy Re	eduction	Factors		E	End ROB = Replace on Burnout
Segment	Measure # Measure Description	Year	Year Units	Units	Cost	Cost	Cost	Factor	Life	Cost C	Cost	Cost	SS :	S-ON	S-MD S	OFF W	ON W	OFF L	Jse RET = Retrofit
VA Existing	3410 Base CFL Lighting - 2.5 hrs/day 2016-2017	2016	2017 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1	\$1.82	1	1	1	1	1	1	2 RET
VA Existing	3411 LEDs (base CFL 2.5 hrs/day) 2016-2017	2016	2017 home	lamp	\$8.00	\$0.00	\$0.00	\$8.00	35000	0	0	\$8.00	1	1	1	1	1	1	2 ROB
VA Existing	3420 Base CFL Lighting - 2.5 hrs/day 2018-2019	2018	2019 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1	\$1.82	1	1	1	1	1	1	2 RET
VA Existing	3421 LEDs (base CFL 2.5 hrs/day) 2018-2019	2018	2019 home	lamp	\$5.00	\$0.00	\$0.00	\$5.00	35000	0	0	\$5.00	1	1	1	1	1	1	2 ROB
VA Existing	3430 Base CFL Lighting - 2.5 hrs/day 2020	2020	2053 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1	\$1.82	1	1	1	1	1	1	2 RET
VA Existing	3431 LEDs (base CFL 2.5 hrs/day) 2020	2020	2053 home	lamp	\$4.00	\$0.00	\$0.00	\$4.00	35000	0	0	\$4.00	1	1	1	1	1	1	2 ROB
VA Existing	3500 Base CFL Lighting - 6 hrs/day 2014-2015	2014	2015 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1	\$1.82	1	1	1	1	1	1	2 RET
VA Existing	3501 LEDs (base CFL 6 hrs/day) 2014-2015	2014	2015 home	lamp	\$11.00	\$0.00	\$0.00	\$11.00	35000	0	0	\$11.00	1	1	1	1	1	1	2 ROB
VA Existing	3510 Base CFL Lighting - 6 hrs/day 2016-2017	2016	2017 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1	\$1.82	1	1	1	1	1	1	2 RET
VA Existing	3511 LEDs (base CFL 6 hrs/day) 2016-2017	2016	2017 home	lamp	\$8.00	\$0.00	\$0.00	\$8.00	35000	0	0	\$8.00	1	1	1	1	1	1	2 ROB
VA Existing	3520 Base CFL Lighting - 6 hrs/day 2018-2019	2018	2019 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1	\$1.82	1	1	1	1	1	1	2 RET
VA Existing	3521 LEDs (base CFL 6 hrs/day) 2018-2019	2018	2019 home	lamp	\$5.00	\$0.00	\$0.00	\$5.00	35000	0	0	\$5.00	1	1	1	1	1	1	2 ROB
VA Existing	3530 Base CFL Lighting - 6 hrs/day 2020	2020	2053 home	lamp	\$1.82	\$0.00	\$0.00	\$1.82	8000	0	1	\$1.82	1	1	1	1	1	1	2 RET
VA Existing	3531 LEDs (base CFL 6 hrs/day) 2020	2020	2053 home	lamp	\$4.00	\$0.00	\$0.00	\$4.00	35000	0	0	\$4.00	1	1	1	1	1	1	2 ROB
VA Existing	3600 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2014-2015	2014	2015 home	lamp	\$2.74	\$0.00	\$0.00	\$2.74	1000	0	1	\$2.74	1	1	1	1	1	1	2 RET
VA Existing	3601 CFL (base Halogen (Specialty) 0.5 hrs/day 2014-2015	2014	2015 home	lamp	\$5.00	\$0.00	\$0.00	\$5.00	8000	0	1	\$5.00	1	1	1	1	1	1	2 ROB
VA Existing	3602 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2014-2015	2014	2015 home	lamp	\$11.00	\$0.00	\$0.00	\$11.00	35000	0	0	\$11.00	1	1	1	1	1	1	2 ROB
VA Existing	3610 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2016-2017	2016	2017 home	lamp	\$2.74	\$0.00	\$0.00	\$2.74	1000	0	1	\$2.74	1	1	1	1	1	1	2 RET
VA Existing	3611 CFL (base Halogen (Specialty) 0.5 hrs/day) 2016-2017	2016	2017 home	lamp	\$5.00	\$0.00	\$0.00	\$5.00	8000	0	1	\$5.00	1	1	1	1	1	1	2 ROB
VA Existing	3612 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2016-2017	2016	2017 home	lamp	\$8.00	\$0.00	\$0.00	\$8.00	35000	0	0	\$8.00	1	1	1	1	1	1	2 ROB
VA Existing	3620 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2018-2019	2018	2019 home	lamp	\$2.74	\$0.00	\$0.00	\$2.74	1000	0	1	\$2.74	1	1	1	1	1	1	2 RET
VA Existing	3621 CFL (base Halogen (Specialty) 0.5 hrs/day) 2018-2019	2018	2019 home	lamp	\$5.00	\$0.00	\$0.00	\$5.00	8000	0	1	\$5.00	1	1	1	1	1	1	2 ROB

Docidontial	Electric Measure Inputs	Applicability F	- cotor	Incomplete Fe		Faccibility Fa	-1	APaul I	
Residential	Electric Measure inputs	Applicability F	actor	Incomplete Fa	ictor	Feasibility Fa	Ctor	Applicable x Inco	omplete x
0	Marana # Marana Daraintina	(percent)	N.A. daife ee ib.	(percent)	N. de aleide a see ile a	,	N.414:5 :1		N.A. daif a see it
Segment VA Existing	Measure # Measure Description 1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	Single Family 41.4%	37.7%	Single Family 100.00%	100.00%	Single Family 100.00%	Multifamily 100.00%	Single Family 41.44%	Multifamily 37.69%
VA Existing	1000 base Split-System All Conditioner - (13 SEER, 11.09 EER) 1001 14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	41.4%	37.7%	84.00%	89.00%	100.00%	100.00%	34.81%	
VA Existing									
VA Existing	1002 15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	41.4%	37.7%	84.00%	89.00%	100.00%	100.00%	34.81%	
VA Existing	1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	41.4%	37.7%	84.00%	89.00%	100.00%	100.00%	34.81%	
VA Existing	1004 Proper Refrigerant Charging and Air Flow (CAC)	41.4%	37.7%	72.00%	72.00%	100.00%	100.00%	29.84%	
VA Existing	1005 Proper Sizing and Quality Install (CAC)	41.4%	37.7%	72.00%	72.00%	100.00%	100.00%	29.84%	
VA Existing	1006 AC Maintenance and/or tune-up (CAC)	41.4%	37.7%	44.28%	31.14%	100.00%	100.00%	18.35%	
VA Existing	1007 AC Filter Changes (CAC)	41.4%	37.7%	42.35%	29.96%	100.00%	100.00%	17.55%	
VA Existing	1008 Ceiling R-0 to R-38 Insulation (CAC)	8.5%	22.8%	100.00%	100.00%	75.00%	75.00%	6.34%	
VA Existing	1009 Ceiling R-0 to R-49 Insulation (CAC)	8.5%	22.8%	100.00%	100.00%	50.00%	50.00%	4.23%	
VA Existing	1010 Ceiling R-11 to R-38 Insulaton (CAC)	18.3%	11.9%	100.00%	100.00%	75.00%	75.00%	13.74%	
VA Existing	1011 Ceiling R-11 to R-49 Insulation (CAC)	18.3%	11.9%	100.00%	100.00%	50.00%	50.00%	9.16%	5.94%
VA Existing	1012 Ceiling R-19 to R-38 Insulation (CAC)	10.5%	3.1%	100.00%	100.00%	75.00%	75.00%	7.86%	
VA Existing	1013 Ceiling R-19 to R-49 Insulation (CAC)	10.5%	3.1%	100.00%	100.00%	50.00%	50.00%	5.24%	1.55%
VA Existing	1014 Crawlspace insulation (CAC)	17.0%	4.5%	74.00%	74.00%	100.00%	100.00%	12.57%	3.35%
VA Existing	1015 Basement insulation R-13 (CAC)	17.8%	4.5%	74.00%	74.00%	65.00%	65.00%	8.57%	2.18%
VA Existing	1016 Floor R-0 to R-19 Insulation-Batts (CAC)	0.8%	9.0%	74.00%	74.00%	75.00%	75.00%	0.46%	5.02%
VA Existing	1017 Wall Blow-in R-0 to R-13 Insulation (CAC)	41.4%	37.7%	12.86%	30.63%	75.00%	75.00%	4.00%	8.66%
VA Existing	1018 Cool Roof (CAC)	41.4%	37.7%	80.70%	80.70%	100.00%	100.00%	33.44%	30.41%
VA Existing	1019 Duct Insulation (CAC)	41.4%	37.7%	5.00%	5.00%	100.00%	100.00%	2.07%	1.88%
VA Existing	1020 Duct Testing and Sealing (CAC)	41.4%	37.7%	20.00%	65.00%	100.00%	100.00%	8.29%	24.50%
VA Existing	1021 Return Duct Modification (CAC)	41.4%	37.7%	5.00%	5.00%	50.00%	50.00%	1.04%	0.94%
VA Existing	1022 Programmable Thermostat (CAC)	41.4%	37.7%	28.97%	38.37%	100.00%	100.00%	12.01%	14.46%
VA Existing	1023 Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	41.4%	37.7%	74.00%	74.00%	100.00%	100.00%	30.66%	27.89%
VA Existing	1024 Self Install Weatherization (CAC)	41.4%	37.7%	55.22%	79.25%	100.00%	100.00%	22.88%	29.87%
VA Existing	1025 Door Weatherization (CAC)	41.4%	37.7%	55.22%	79.25%	100.00%	100.00%	22.88%	29.87%
VA Existing	1026 Ceiling Fans (CAC)	41.4%	37.7%	17.86%	50.93%	100.00%	100.00%	7.40%	19.20%
VA Existing	1027 Whole House Fans (CAC)	41.4%	37.7%	89.72%	96.92%	100.00%	100.00%	37.18%	36.53%
VA Existing	1028 Window Film (CAC)	41.4%	37.7%	100.00%	100.00%	100.00%	100.00%	41.44%	37.69%
VA Existing	1029 WINDOWS - Default With Sunscreen (CAC)	41.4%	37.7%	90.20%	90.20%	100.00%	100.00%	37.38%	34.00%
VA Existing	1030 WINDOWS - Double-Glazed Clear to Energy Star (CAC)	41.4%	37.7%	27.00%	46.00%	100.00%	100.00%	11.19%	17.34%
VA Existing	1100 Base Split-System Air Conditioner - Early Replacement (11 SEER)	7.3%	6.7%	100.00%	100.00%	100.00%	100.00%	7.31%	
VA Existing	1101 14 SEER (12.15 EER) Split-System Air Conditioner w/ Quality Install - Early		6.7%	84.00%	89.00%	100.00%	100.00%	6.14%	
VA Existing	1102 Proper Refrigerant Charging and Air Flow (CAC early replacement)	7.3%	6.7%	84.00%	89.00%	100.00%	100.00%	6.14%	
VA Existing	1103 Proper Sizing and Quality Install (CAC early replacement)	7.3%	6.7%	84.00%	89.00%	100.00%	100.00%	6.14%	
VA Existing	1104 AC Maintenance and/or tune-up (CAC early replacement)	7.3%	6.7%	44.28%	31.14%	100.00%	100.00%	3.24%	
VA Existing	1105 AC Filter Changes (CAC early replacement)	7.3%	6.7%	42.35%	29.96%	100.00%	100.00%	3.10%	
VA Existing	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	1.5%	4.0%	100.00%	100.00%	75.00%	75.00%	1.12%	
VA Existing	1107 Ceiling R-0 to R-49 Insulation (CAC early replacement)	1.5%	4.0%	100.00%	100.00%	50.00%	50.00%	0.75%	
VA Existing	1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	3.2%	2.1%	100.00%	100.00%	75.00%	75.00%	2.42%	
VA Existing VA Existing	1109 Ceiling R-11 to R-99 Insulation (CAC early replacement)	3.2%	2.1%	100.00%	100.00%	50.00%	50.00%	1.62%	
VA Existing VA Existing	1110 Ceiling R-19 to R-38 Insulation (CAC early replacement)	1.9%	0.5%	100.00%	100.00%	75.00%	75.00%	1.39%	
•	· , , , ,	1.9%	0.5%	100.00%	100.00%	50.00%	50.00%	0.93%	
VA Existing	1111 Ceiling R-19 to R-49 Insulation (CAC early replacement)								
VA Existing	1112 Crawlspace insulation (CAC early replacement)	3.0%	0.8%	74.00% 74.00%	74.00%	100.00%	100.00%	2.21%	
VA Existing	1113 Basement insulation R-13 (CAC early replacement)	3.1%	0.8%		74.00%	65.00%	65.00%	1.51%	
VA Existing	1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	0.1%	1.6%	74.00%	74.00%	75.00%	75.00%	0.08%	
VA Existing	1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement)	7.3%	6.7%	12.86%	30.63%	75.00%	75.00%	0.71%	1.53%

Residential	Electric Measure Inputs	Applicability F	actor	Incomplete Fa	ctor	Feasibility Fac	ctor	Applicable x Inco	omnlete x
rtoolaontia	2.00th o modelate in pate	(percent)	uotoi	(percent)	.0.01	(percent)	5.0.	Feasible	Jilipiete X
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily		Multifamily
VA Existing	1116 Cool Roof (CAC early replacement)	7.3%	6.7%	80.70%	80.70%	100.00%	100.00%	5.90%	
VA Existing	1117 Duct Insulation (CAC early replacement)	7.3%	6.7%	5.00%	5.00%	100.00%	100.00%	0.37%	
VA Existing	1118 Duct Testing and Sealing (CAC early replacement)	7.3%	6.7%	20.00%	65.00%	100.00%	100.00%	1.46%	
VA Existing	1119 Return Duct Modification (CAC early replacement)	7.3%	6.7%	5.00%	5.00%	50.00%	50.00%	0.18%	
VA Existing	1120 Programmable Thermostat (CAC early replacement)	7.3%	6.7%	28.97%	38.37%	100.00%	100.00%	2.12%	
VA Existing	1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early replacement)	7.3%	6.7%	74.00%	74.00%	100.00%	100.00%	5.41%	
VA Existing	1122 Self Install Weatherization (CAC early replacement)	7.3%	6.7%	84.00%	84.00%	100.00%	100.00%	6.14%	
VA Existing	1123 Door Weatherization (CAC early replacement)	7.3%	6.7%	55.22%	79.25%	100.00%	100.00%	4.04%	
VA Existing	1124 Ceiling Fans (CAC early replacement)	7.3%	6.7%	17.86%	50.93%	100.00%	100.00%	1.31%	
VA Existing VA Existing	1125 Whole House Fans (CAC early replacement)	7.3%	6.7%	89.72%	96.92%	100.00%	100.00%	6.56%	
VA Existing	1126 Window Film (CAC early replacement)	7.3%	6.7%	100.00%	100.00%	100.00%	100.00%	7.31%	
	1127 WINDOWS - Default With Sunscreen (CAC early replacement)	7.3%	6.7%	90.20%	90.20%	100.00%	100.00%	6.60%	
VA Existing	` ', '	7.3%	6.7%	27.00%		100.00%	100.00%		
VA Existing	1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early replacement)	36.9%	41.5%	100.00%	46.00% 100.00%	100.00%	100.00%	1.97%	
VA Existing	1200 Base Heat Pump Cooling (13 SEER)							36.87%	
VA Existing	1201 Heat pump upgrade to (14.5-15.9 SEER, 8.2+ HSPF) (HP cooling)	36.9%	41.5%	68.00%	68.00%	100.00%	100.00%	25.07%	
VA Existing	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	36.9%	41.5%	68.00%	68.00%	100.00%	100.00%	25.07%	
VA Existing	1203 Ground Source Heat Pump with Desuperheater (HP cooling)	36.9%	41.5%	97.35%	100.00%	100.00%	100.00%	35.90%	
VA Existing	1204 Proper Refrigerant Charging and Air Flow (HP cooling)	36.9%	41.5%	72.00%	72.00%	100.00%	100.00%	26.55%	
VA Existing	1205 Proper Sizing and Quality Install (HP cooling)	36.9%	41.5%	72.00%	72.00%	100.00%	100.00%	26.55%	
VA Existing	1206 Heat pump tune up	36.9%	41.5%	44.28%	31.14%	100.00%	100.00%	16.33%	
VA Existing	1207 Heat Pump Filter Replacement	36.9%	41.5%	42.35%	29.96%	100.00%	100.00%	15.61%	
VA Existing	1208 Ceiling R-0 to R-38 Insulation (HP cooling)	7.5%	25.1%	100.00%	100.00%	75.00%	75.00%	5.64%	
VA Existing	1209 Ceiling R-0 to R-49 Insulation (HP cooling)	7.5%	25.1%	100.00%	100.00%	50.00%	50.00%	3.76%	
VA Existing	1210 Ceiling R-11 to R-38 Insulaton (HP cooling)	16.3%	13.1%	100.00%	100.00%	75.00%	75.00%	12.22%	
VA Existing	1211 Ceiling R-11 to R-49 Insulation (HP cooling)	16.3%	13.1%	100.00%	100.00%	50.00%	50.00%	8.15%	
VA Existing	1212 Ceiling R-19 to R-38 Insulation (HP cooling)	9.3%	3.4%	100.00%	100.00%	75.00%	75.00%	7.00%	
VA Existing	1213 Ceiling R-19 to R-49 Insulation (HP cooling)	9.3%	3.4%	100.00%	100.00%	50.00%	50.00%	4.66%	
VA Existing	1214 Crawlspace insulation (HP cooling)	15.1%	5.0%	74.00%	74.00%	100.00%	100.00%	11.20%	3.69%
VA Existing	1215 Basement insulation R-13 (HP cooling)	15.9%	5.0%	74.00%	74.00%	65.00%	65.00%	7.63%	2.40%
VA Existing	1216 Floor R-0 to R-19 Insulation-Batts (HP cooling)	0.7%	10.0%	74.00%	74.00%	75.00%	75.00%	0.41%	5.53%
VA Existing	1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling)	36.9%	41.5%	12.86%	30.63%	75.00%	75.00%	3.56%	9.54%
VA Existing	1218 Cool Roof (HP cooling)	36.9%	41.5%	80.70%	80.70%	100.00%	100.00%	29.76%	33.52%
VA Existing	1219 Duct Insulation (HP cooling)	36.9%	41.5%	5.00%	5.00%	100.00%	100.00%	1.84%	2.08%
VA Existing	1220 Duct Testing and Sealing (HP cooling)	36.9%	41.5%	20.00%	65.00%	100.00%	100.00%	7.37%	27.00%
VA Existing	1221 Programmable Thermostat (HP cooling)	36.9%	41.5%	28.97%	38.37%	100.00%	100.00%	10.68%	15.94%
VA Existing	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)	36.9%	41.5%	74.00%	74.00%	100.00%	100.00%	27.29%	30.74%
VA Existing	1223 Self Install Weatherization (HP cooling)	36.9%	41.5%	55.22%	79.25%	100.00%	100.00%	20.36%	32.92%
VA Existing	1224 Door Weatherization (HP cooling)	36.9%	41.5%	55.22%	79.25%	100.00%	100.00%	20.36%	32.92%
VA Existing	1225 Ceiling Fans (HP cooling)	36.9%	41.5%	17.86%	50.93%	100.00%	100.00%	6.58%	21.16%
VA Existing	1226 Whole House Fans (HP cooling)	36.9%	41.5%	89.72%	96.92%	100.00%	100.00%	33.08%	40.26%
VA Existing	1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling)	36.9%	41.5%	27.00%	46.00%	100.00%	100.00%	9.96%	
VA Existing	1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	6.5%	7.3%	100.00%	100.00%	100.00%	100.00%	6.51%	
VA Existing	1301 Heat pump upgrade to (14.5-15.9 SEER, 8.2+ HSPF) (HP cooling Early Rep	6.5%	7.3%	68.00%	68.00%	100.00%	100.00%	4.42%	
VA Existing	1302 Heat pump upgrade to (14.6 16.6 SEER, 8.7+ HSPF) (HP cooling Early Replacem	6.5%	7.3%	68.00%	68.00%	100.00%	100.00%	4.42%	
VA Existing	1303 Ground Source Heat Pump with Desuperheater (HP cooling Early Replacem	6.5%	7.3%	97.35%	100.00%	100.00%	100.00%	6.33%	
VA Existing	1304 Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement)	6.5%	7.3%	72.00%	72.00%	100.00%	100.00%	4.69%	
VA Existing	1305 Proper Sizing and Quality Install (HP cooling Early Replacement)	6.5%	7.3%	72.00%	72.00%	100.00%	100.00%		

Residential	·	Applicability F	actor	Incomplete Fa	octor	Feasibility Fac	ctor	Applicable x Inco	omplete x
		(percent)		(percent)		(percent)		Feasible	
Segment	Measure # Measure Description	Single Family		Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
/A Existing	1306 Heat pump tune up	6.5%	7.3%	44.28%	31.14%	100.00%	100.00%	2.88%	2.28%
/A Existing	1307 Heat Pump Filter Replacement	6.5%	7.3%	42.35%	29.96%	100.00%	100.00%	2.76%	2.20%
/A Existing	1308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	1.3%	4.4%	100.00%	100.00%	75.00%	75.00%	1.00%	3.32%
'A Existing	1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement)	1.3%	4.4%	100.00%	100.00%	50.00%	50.00%	0.66%	2.21%
'A Existing	1310 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)	2.9%	2.3%	100.00%	100.00%	75.00%	75.00%	2.16%	1.73%
/A Existing	1311 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement)	2.9%	2.3%	100.00%	100.00%	50.00%	50.00%	1.44%	1.15%
/A Existing	1312 Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)	1.6%	0.6%	100.00%	100.00%	75.00%	75.00%	1.23%	0.45%
/A Existing	1313 Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)	1.6%	0.6%	100.00%	100.00%	50.00%	50.00%	0.82%	0.30%
/A Existing	1314 Crawlspace insulation (HP cooling Early Replacement)	2.7%	0.9%	74.00%	74.00%	100.00%	100.00%	1.97%	0.65%
/A Existing	1315 Basement insulation R-13 (HP cooling Early Replacement)	2.8%	0.9%	74.00%	74.00%	65.00%	65.00%	1.34%	0.42%
/A Existing	1316 Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement)	0.1%	1.8%	74.00%	74.00%	75.00%	75.00%	0.07%	0.97%
/A Existing	1317 Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement)	6.5%	7.3%	12.86%	30.63%	75.00%	75.00%	0.63%	1.68%
/A Existing	1318 Cool Roof (HP cooling Early Replacement)	6.5%	7.3%	80.70%	80.70%	100.00%	100.00%	5.25%	5.92%
/A Existing	1319 Duct Insulation (HP cooling Early Replacement)	6.5%	7.3%	5.00%	5.00%	100.00%	100.00%	0.33%	0.37%
/A Existing	1320 Duct Testing and Sealing (HP cooling Early Replacement)	6.5%	7.3%	20.00%	65.00%	100.00%	100.00%	1.30%	4.76%
/A Existing	1321 Programmable Thermostat (HP cooling Early Replacement)	6.5%	7.3%	28.97%	38.37%	100.00%	100.00%	1.89%	2.81%
/A Existing	1322 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early Replacer	6.5%	7.3%	74.00%	74.00%	100.00%	100.00%	4.82%	5.42%
/A Existing	1323 Self Install Weatherization (HP cooling Early Replacement)	6.5%	7.3%	55.22%	79.25%	100.00%	100.00%	3.59%	5.81%
/A Existing	1324 Door Weatherization (HP cooling Early Replacement)	6.5%	7.3%	55.22%	79.25%	100.00%	100.00%	3.59%	5.81%
/A Existing	1325 Ceiling Fans (HP cooling early replacement)	6.5%	7.3%	17.86%	50.93%	100.00%	100.00%	1.16%	
/A Existing	1326 Whole House Fans (HP cooling early replacement)	6.5%	7.3%	89.72%	96.92%	100.00%	100.00%	5.84%	
/A Existing	1327 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Replace		7.3%	27.00%	46.00%	100.00%	100.00%	1.76%	
/A Existing	1400 Base Room Air Conditioner - EER 10.6	4.7%	1.6%	100.00%	100.00%	100.00%	100.00%	4.69%	
/A Existing	1401 Energy Star Room Air Conditioner - EER 10.8	4.7%	1.6%	90.00%	95.00%	100.00%	100.00%	4.22%	
/A Existing	1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	4.7%	1.6%	90.00%	95.00%	100.00%	100.00%	4.22%	1.56%
/A Existing	1403 Room AC Filter Replacement	4.7%	1.6%	42.35%	29.96%	100.00%	100.00%	1.98%	
/A Existing	1404 Ceiling R-0 to R-38 Insulation (RAC)	1.0%	1.0%	100.00%	100.00%	75.00%	75.00%	0.72%	
/A Existing	1405 Ceiling R-0 to R-49 Insulation (RAC)	1.0%	1.0%	100.00%	100.00%	50.00%	50.00%	0.48%	
/A Existing	1406 Ceiling R-11 to R-38 Insulaton (RAC)	2.1%	0.5%	100.00%	100.00%	75.00%	75.00%	1.55%	
/A Existing	1407 Ceiling R-11 to R-49 Insulation (RAC)	2.1%	0.5%	100.00%	100.00%	50.00%	50.00%	1.04%	
/A Existing	1408 Ceiling R-19 to R-38 Insulation (RAC)	1.2%	0.1%	100.00%	100.00%	75.00%	75.00%	0.89%	
/A Existing	1409 Ceiling R-19 to R-49 Insulation (RAC)	1.2%	0.1%	100.00%	100.00%	50.00%	50.00%	0.59%	
/A Existing	1410 Wall Blow-in R-0 to R-13 Insulation (RAC)	4.7%	1.6%	13.01%	30.62%	75.00%	75.00%	0.46%	
/A Existing	1411 Cool Roof (RAC)	4.7%	1.6%	80.70%	80.70%	100.00%	100.00%	3.78%	
/A Existing	1412 Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	4.7%	1.6%	74.00%	74.00%	100.00%	100.00%	3.47%	
/A Existing	1413 Self Install Weatherization (RAC)	4.7%	1.6%	55.22%	79.25%	100.00%	100.00%	2.59%	
/A Existing	1414 Door Weatherization (RAC)	4.7%	1.6%	55.22%	79.25%	100.00%	100.00%	2.59%	
/A Existing	1415 Ceiling Fans (RAC)	4.7%	1.6%	17.86%	50.93%	100.00%	100.00%	0.84%	
/A Existing	1416 Whole House Fans (RAC)	4.7%	1.6%	89.72%	96.92%	100.00%	100.00%	4.20%	
/A Existing	1417 Window Film (RAC)	4.7%	1.6%	100.00%	100.00%	100.00%	100.00%	4.69%	
/A Existing	1418 WINDOWS - Default With Sunscreen (RAC)	4.7%	1.6%	90.20%	90.20%	100.00%	100.00%	4.23%	
/A Existing	1419 WINDOWS - Delault Willi Sunscieer (RAC) 1419 WINDOWS - Double-Glazed Clear to Energy Star (RAC)	4.7%	1.6%	27.00%	46.00%	100.00%	100.00%	1.27%	
/A Existing	1500 Base Room Air Conditioner, Early Replacement - EER 9.7	0.8%	0.3%	100.00%	100.00%	100.00%	100.00%	0.83%	
/A Existing	1500 base Room Air Conditioner, Early Replacement - EER 9.7 1501 EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early replacement)		0.3%	100.00%	100.00%	100.00%	100.00%	0.83%	
/A Existing /A Existing		29.4%	13.7%	100.00%	100.00%	100.00%	100.00%	29.40%	
0	1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)		13.7%	98.00%	100.00%	100.00%	100.00%		
/A Existing	1601 10% better than Energy Star Dehumidifier ROB (35-45 pints/day)	29.4% 89.9%				100.00%		28.81%	
/A Existing	1700 Base Furnace Fan - Furnace & CAC	09.9%	99.5%	100.00%	100.00%	100.00%	100.00%	89.92%	99.519

Residential	Electric Measure Inputs	Applicability F	actor	Incomplete Fa	ictor	Feasibility Fa	ctor	Applicable x Inco	omplete x
	·	(percent)		(percent)		(percent)		Feasible	,
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
VA Existing	1701 ECM Furnace Fan (variable speed motor) - Cooling	89.9%	99.5%	80.00%	80.00%	100.00%	100.00%	71.94%	79.61%
VA Existing	2000 Base Heat Pump Space Heating (7.7 HSPF)	31.2%	48.0%	100.00%	100.00%	100.00%	100.00%	31.24%	48.04%
VA Existing	2001 Heat pump upgrade to 14.5-15.9 SEER/8.2+ HSPF (HP heating)	31.2%	48.0%	68.00%	68.00%	100.00%	100.00%	21.24%	32.67%
VA Existing	2002 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	31.2%	48.0%	68.00%	68.00%	100.00%	100.00%	21.24%	32.67%
VA Existing	2003 Ground Source Heat Pump with Desuperheater (HP heating)	31.2%	48.0%	97.35%	100.00%	100.00%	100.00%	30.41%	48.04%
VA Existing	2004 Heat pump tune up	31.2%	48.0%	44.28%	31.14%	100.00%	100.00%	13.83%	14.96%
VA Existing	2005 Heat Pump Filter Replacement	31.2%	48.0%	42.35%	29.96%	100.00%	100.00%	13.23%	14.39%
VA Existing	2006 Ceiling R-0 to R-38 Insulation (HP heating)	6.4%	29.0%	100.00%	100.00%	75.00%	75.00%	4.78%	21.76%
VA Existing	2007 Ceiling R-0 to R-49 Insulation (HP heating)	6.4%	29.0%	100.00%	100.00%	50.00%	50.00%	3.19%	14.51%
VA Existing	2008 Ceiling R-11 to R-38 Insulaton (HP heating)	13.8%	15.1%	100.00%	100.00%	75.00%	75.00%	10.36%	11.35%
VA Existing	2009 Ceiling R-11 to R-49 Insulation (HP heating)	13.8%	15.1%	100.00%	100.00%	50.00%	50.00%	6.90%	7.57%
VA Existing	2010 Ceiling R-19 to R-38 Insulation (HP heating)	7.9%	3.9%	100.00%	100.00%	75.00%	75.00%	5.93%	2.95%
VA Existing	2011 Ceiling R-19 to R-49 Insulation (HP heating)	7.9%	3.9%	100.00%	100.00%	50.00%	50.00%	3.95%	1.97%
VA Existing	2012 Crawlspace insulation (HP heating)	12.8%	5.8%	74.00%	74.00%	100.00%	100.00%	9.47%	4.26%
VA Existing	2013 Basement insulation R-13 (HP heating)	13.4%	5.8%	74.00%	74.00%	65.00%	65.00%	6.45%	2.77%
VA Existing	2014 Floor R-0 to R-19 Insulation-Batts (HP heating)	0.6%	11.5%	74.00%	74.00%	75.00%	75.00%	0.35%	6.39%
VA Existing	2015 Wall Blow-in R-0 to R-13 Insulation (HP heating)	31.2%	48.0%	12.86%	30.63%	75.00%	75.00%	3.01%	11.04%
VA Existing	2016 Duct Insulation (HP heating)	31.2%	48.0%	5.00%	5.00%	100.00%	100.00%	1.56%	2.40%
VA Existing	2017 Duct Trisdiation (Thir Realing) 2017 Duct Testing and Sealing (HP heating)	31.2%	48.0%	20.00%	65.00%	100.00%	100.00%	6.25%	31.23%
VA Existing	2018 Heat Recovery Ventilators (HP heating)	31.2%	48.0%	95.00%	95.00%	75.00%	75.00%	22.26%	34.23%
VA Existing VA Existing	2019 Programmable Thermostat (HP heating)	31.2%	48.0%	28.97%	38.37%	100.00%	100.00%	9.05%	18.43%
VA Existing VA Existing	2020 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	31.2%	48.0%	74.00%	74.00%	100.00%	100.00%	23.12%	35.55%
VA Existing VA Existing	2021 Self Install Weatherization (HP heating)	31.2%	48.0%	55.22%	79.25%	100.00%	100.00%	17.25%	38.07%
VA Existing VA Existing	2022 Door Weatherization (HP heating)	31.2%	48.0%	55.22%	79.25%	100.00%	100.00%	17.25%	38.07%
VA Existing	2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	31.2%	48.0%	27.00%	46.00%	100.00%	100.00%	8.43%	22.10%
VA Existing VA Existing	2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSPF)	5.5%	8.5%	100.00%	100.00%	100.00%	100.00%	5.51%	8.48%
VA Existing	2101 Heat pump upgrade to 14.5-15.9 SEER/8.2+ HSPF (HP heating early replace		8.5%	68.00%	68.00%	100.00%	100.00%	3.75%	5.77%
VA Existing	2102 Heat pump upgrade to 14:3 10:3 GEET/8.7+ HSPF (HP heating early replacemen		8.5%	68.00%	68.00%	100.00%	100.00%	3.75%	5.77%
VA Existing VA Existing	2103 Ground Source Heat Pump with Desuperheater (HP heating early replacement		8.5%	97.35%	100.00%	100.00%	100.00%	5.37%	8.48%
VA Existing VA Existing	2103 Ground Source Heat Furth with Desuperheater (Fir Heating early replacement	5.5%	8.5%	44.28%	31.14%	100.00%	100.00%	2.44%	2.64%
VA Existing	2105 Heat Pump Filter Replacement (heating)	5.5%	8.5%	42.35%	29.96%	100.00%	100.00%	2.33%	2.54%
VA Existing VA Existing	2106 Ceiling R-0 to R-38 Insulation (HP heating early replacement)	1.1%	5.1%	100.00%	100.00%	75.00%	75.00%	0.84%	3.84%
VA Existing VA Existing	2107 Ceiling R-0 to R-49 Insulation (HP heating early replacement)	1.1%	5.1%	100.00%	100.00%	50.00%	50.00%	0.56%	2.56%
VA Existing VA Existing	2108 Ceiling R-11 to R-38 Insulation (HP heating early replacement)	2.4%	2.7%	100.00%	100.00%	75.00%	75.00%	1.83%	2.00%
VA Existing VA Existing	2109 Ceiling R-11 to R-99 Insulation (HP heating early replacement)	2.4%	2.7%	100.00%	100.00%	50.00%	50.00%	1.22%	1.34%
VA Existing VA Existing	2110 Ceiling R-11 to R-38 Insulation (HP heating early replacement)	1.4%	0.7%	100.00%	100.00%	75.00%	75.00%	1.05%	0.52%
VA Existing VA Existing	2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement)	1.4%	0.7%	100.00%	100.00%	50.00%	50.00%	0.70%	0.35%
	2111 Ceiling K-19 to K-49 insulation (HP heating early replacement) 2112 Crawlspace insulation (HP heating early replacement)	2.3%	1.0%	74.00%	74.00%	100.00%	100.00%	1.67%	0.35%
VA Existing		2.3%	1.0%	74.00%	74.00%	65.00%	65.00%	1.07%	0.75%
VA Existing	2113 Basement insulation R-13 (HP heating early replacement)	0.1%	2.0%	74.00%	74.00%	75.00%	75.00%	0.06%	
VA Existing	2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replacement)								1.13%
VA Existing	2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacement)	5.5%	8.5%	12.86%	30.63%	75.00%	75.00%	0.53%	1.95%
VA Existing	2116 Duct Insulation (HP heating early replacement)	5.5%	8.5%	5.00%	5.00%	100.00%	100.00%	0.28%	0.42%
VA Existing	2117 Duct Testing and Sealing (HP heating early replacement)	5.5%	8.5%	20.00%	65.00%	100.00%	100.00%	1.10%	5.51%
VA Existing	2118 Heat Recovery Ventilators (HP heating early replacement)	5.5%	8.5%	95.00%	95.00%	75.00%	75.00%	3.93%	6.04%
VA Existing	2119 Programmable Thermostat (HP heating early replacement)	5.5%	8.5%	28.97%	38.37%	100.00%	100.00%	1.60%	3.25%
VA Existing	2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating early replacem		8.5%	74.00%	74.00%	100.00%	100.00%	4.08%	6.27%
VA Existing	2121 Self Install Weatherization (HP heating early replacement)	5.5%	8.5%	55.22%	79.25%	100.00%	100.00%	3.04%	6.72%

Residential	Electric Measure Inputs	Applicability F	actor	Incomplete Fa	ctor	Feasibility Fac	ctor	Applicable x Inco	omplete x
		(percent)		(percent)		(percent)		Feasible	
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
VA Existing	2122 Door Weatherization (HP heating early replacement)	5.5%	8.5%	55.22%	79.25%	100.00%	100.00%	3.04%	6.72%
VA Existing	2123 WINDOWS - Double-Glazed Clear to Energy Star (HP heating early replacer	5.5%	8.5%	27.00%	46.00%	100.00%	100.00%	1.49%	3.90%
VA Existing	2200 Base Resistance Space Heating (Primary)	13.0%	29.8%	100.00%	100.00%	100.00%	100.00%	13.03%	29.85%
VA Existing	2201 Air Source Heat Pump (resistance heating)	13.0%	29.8%	100.00%	100.00%	100.00%	100.00%	13.03%	29.85%
VA Existing	2202 Ground Source Heat Pump with Desuperheater (resistance heating)	13.0%	29.8%	100.00%	100.00%	100.00%	100.00%	13.03%	29.85%
VA Existing	2203 Ceiling R-0 to R-38 Insulation (resistance heating)	2.7%	18.0%	100.00%	100.00%	75.00%	75.00%	1.99%	13.52%
VA Existing	2204 Ceiling R-0 to R-49 Insulation (resistance heating)	2.7%	18.0%	100.00%	100.00%	50.00%	50.00%	1.33%	9.01%
VA Existing	2205 Ceiling R-11 to R-38 Insulaton (resistance heating)	5.8%	9.4%	100.00%	100.00%	75.00%	75.00%	4.32%	7.05%
VA Existing	2206 Ceiling R-11 to R-49 Insulation (resistance heating)	5.8%	9.4%	100.00%	100.00%	50.00%	50.00%	2.88%	4.70%
VA Existing	2207 Ceiling R-19 to R-38 Insulation (resistance heating)	3.3%	2.4%	100.00%	100.00%	75.00%	75.00%	2.47%	1.84%
VA Existing	2208 Ceiling R-19 to R-49 Insulation (resistance heating)	3.3%	2.4%	100.00%	100.00%	50.00%	50.00%	1.65%	1.22%
VA Existing	2209 Crawlspace insulation (resistance heating)	5.3%	3.6%	74.00%	74.00%	100.00%	100.00%	3.95%	2.65%
VA Existing	2210 Basement insulation R-13 (resistance heating)	5.6%	3.6%	74.00%	74.00%	100.00%	100.00%	4.15%	2.65%
VA Existing	2211 Floor R-0 to R-19 Insulation-Batts (resistance heating)	0.3%	7.2%	74.00%	74.00%	75.00%	75.00%	0.14%	3.98%
VA Existing	2212 Wall Blow-in R-0 to R-13 Insulation (resistance heating)	13.0%	29.8%	12.86%	30.63%	75.00%	75.00%	1.26%	6.86%
VA Existing	2213 Heat Recovery Ventilators (resistance heating)	13.0%	29.8%	95.00%	95.00%	75.00%	75.00%	9.28%	21.27%
VA Existing	2214 Programmable Thermostat (resistance heating)	13.0%	29.8%	28.97%	38.37%	100.00%	100.00%	3.77%	11.45%
VA Existing	2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating)	13.0%	29.8%	74.00%	74.00%	100.00%	100.00%	9.64%	22.09%
VA Existing	2216 Self Install Weatherization	13.0%	29.8%	55.22%	79.25%	100.00%	100.00%	7.19%	23.65%
VA Existing	2217 Door Weatherization (resistance heating)	13.0%	29.8%	55.22%	79.25%	100.00%	100.00%	7.19%	23.65%
VA Existing	2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance heating)	13.0%	29.8%	27.00%	46.00%	100.00%	100.00%	3.52%	13.73%
VA Existing	3000 Base Halogen Lighting - 0.5 hrs/day 2014-2015	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3001 CFL (base Halogen 0.5 hrs/day) 2014-2015	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3002 LEDs (base Halogen 0.5 hrs/day) 2014-2015	100.0%	100.0%	100.00%	100.00%	80.00%	80.00%	80.00%	80.00%
VA Existing	3010 Base Halogen Lighting - 0.5 hrs/day 2016-2017	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3011 CFL (base Halogen 0.5 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3012 LEDs (base Halogen 0.5 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	85.00%	85.00%	85.00%	85.00%
VA Existing	3020 Base Halogen Lighting - 0.5 hrs/day 2018-2019	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3021 CFL (base Halogen 0.5 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3022 LEDs (base Halogen 0.5 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3030 Base Halogen Lighting - 0.5 hrs/day 2020	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3032 LEDs (base Halogen 0.5 hrs/day) 2020	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3100 Base Halogen Lighting - 2.5 hrs/day 2014-2015	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3101 CFL (base Halogen 2.5 hrs/day) 2014-2015	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3102 LEDs (base Halogen 2.5 hrs/day) 2014-2015	100.0%	100.0%	100.00%	100.00%	80.00%	80.00%	80.00%	80.00%
VA Existing	3110 Base Halogen Lighting - 2.5 hrs/day 2016-2017	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3111 CFL (base Halogen 2.5 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing VA Existing	3112 LEDs (base Halogen 2.5 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	85.00%	85.00%	85.00%	85.00%
VA Existing VA Existing	3120 Base Halogen Lighting - 2.5 hrs/day 2018-2019	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3121 CFL (base Halogen 2.5 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing VA Existing	3121 CFE (base Halogen 2.5 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing VA Existing	3130 Base Halogen Lighting - 2.5 hrs/day 2020	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing VA Existing	3132 LEDs (base Halogen 2.5 hrs/day) 2020	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing VA Existing	3200 Base Halogen Lighting - 6 hrs/day 2014-2015	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing VA Existing		100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
Ü	3201 CFL (base Halogen 6 hrs/day) 2014-2015	100.0%		100.00%		80.00%	80.00%		
VA Existing	3202 LEDs (base Halogen 6 hrs/day) 2014-2015	100.0%	100.0%		100.00%	100.00%		80.00%	80.00% 100.00%
VA Existing	3210 Base Halogen Lighting - 6 hrs/day 2016-2017	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%

Residential	Electric Measure Inputs	Applicability I	actor	Incomplete Fa	ictor	Feasibility Fac	ctor	Applicable x Inco	omplete x
		(percent)		(percent)		(percent)		Feasible	•
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
VA Existing	3211 CFL (base Halogen 6 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3212 LEDs (base Halogen 6 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	85.00%	85.00%	85.00%	85.00%
VA Existing	3220 Base Halogen Lighting - 6 hrs/day 2018-2019	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3221 CFL (base Halogen 6 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3222 LEDs (base Halogen 6 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3230 Base Halogen Lighting - 6 hrs/day 2020	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3232 LEDs (base Halogen 6 hrs/day) 2020	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90.00%	90.00%
VA Existing	3300 Base CFL Lighting - 0.5 hrs/day 2014-2015	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3301 LEDs (base CFL 0.5 hrs/day) 2014-2015	100.0%	100.0%	100.00%	100.00%	80.00%	80.00%	80.00%	80.00%
VA Existing	3310 Base CFL Lighting - 0.5 hrs/day 2016-2017	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3311 LEDs (base CFL 0.5 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	85.00%	85.00%	85%	85%
VA Existing	3320 Base CFL Lighting - 0.5 hrs/day 2018-2019	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3321 LEDs (base CFL 0.5 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90%	90%
VA Existing	3330 Base CFL Lighting - 0.5 hrs/day 2020	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3331 LEDs (base CFL 0.5 hrs/day) 2020	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90%	90%
VA Existing	3400 Base CFL Lighting - 2.5 hrs/day 2014-2015	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3401 LEDs (base CFL 2.5 hrs/day) 2014-2015	100.0%	100.0%	100.00%	100.00%	80.00%	80.00%	80%	80%
VA Existing	3410 Base CFL Lighting - 2.5 hrs/day 2016-2017	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3411 LEDs (base CFL 2.5 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	85.00%	85.00%	85%	85%
VA Existing	3420 Base CFL Lighting - 2.5 hrs/day 2018-2019	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3421 LEDs (base CFL 2.5 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90%	90%
VA Existing	3430 Base CFL Lighting - 2.5 hrs/day 2020	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3431 LEDs (base CFL 2.5 hrs/day) 2020	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90%	90%
VA Existing	3500 Base CFL Lighting - 6 hrs/day 2014-2015	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3501 LEDs (base CFL 6 hrs/day) 2014-2015	100.0%	100.0%	100.00%	100.00%	80.00%	80.00%	80%	80%
VA Existing	3510 Base CFL Lighting - 6 hrs/day 2016-2017	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3511 LEDs (base CFL 6 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	85.00%	85.00%	85%	85%
VA Existing	3520 Base CFL Lighting - 6 hrs/day 2018-2019	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3521 LEDs (base CFL 6 hrs/day) 2018-2019	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90%	90%
VA Existing	3530 Base CFL Lighting - 6 hrs/day 2020	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3531 LEDs (base CFL 6 hrs/day) 2020	100.0%	100.0%	100.00%	100.00%	90.00%	90.00%	90%	90%
VA Existing	3600 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2014-2015	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3601 CFL (base Halogen (Specialty) 0.5 hrs/day 2014-2015	100.0%	100.0%	75.00%	75.00%	90.00%	90.00%	67.50%	67.50%
VA Existing	3602 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2014-2015	100.0%	100.0%	100.00%	100.00%	50.00%	50.00%	50%	50%
VA Existing	3610 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2016-2017	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100%	100%
VA Existing	3611 CFL (base Halogen (Specialty) 0.5 hrs/day) 2016-2017	100.0%	100.0%	75.00%	75.00%	90.00%	90.00%	67.50%	67.50%
VA Existing	3612 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2016-2017	100.0%	100.0%	100.00%	100.00%	60.00%	60.00%	60%	60%
VA Existing	3620 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2018-2019	100.0%	100.0%	100.00%	100.00%	100.00%	100.00%	100.00%	100.00%
VA Existing	3621 CFL (base Halogen (Specialty) 0.5 hrs/day) 2018-2019	100.0%	100.0%	75.00%	75.00%	90.00%	90.00%	68%	68%

				Standards Ad	justment		
Residential	Electric Measure Inputs	Energy Saving	ıs	Factor	,	Technology Sa	aturation
		(percent)	,	(percent)		(units/home)	
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
VA Existing	1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1001 14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1002 15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1004 Proper Refrigerant Charging and Air Flow (CAC)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1005 Proper Sizing and Quality Install (CAC)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1006 AC Maintenance and/or tune-up (CAC)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1007 AC Filter Changes (CAC)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1008 Ceiling R-0 to R-38 Insulation (CAC)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1009 Ceiling R-0 to R-49 Insulation (CAC)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1010 Ceiling R-11 to R-38 Insulaton (CAC)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1011 Ceiling R-11 to R-49 Insulation (CAC)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1012 Ceiling R-19 to R-38 Insulation (CAC)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1013 Ceiling R-19 to R-49 Insulation (CAC)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1014 Crawlspace insulation (CAC)	100.00%	100.00%	100.00%	100.00%	482.7	419.3
VA Existing	1015 Basement insulation R-13 (CAC)	100.00%	100.00%	100.00%	100.00%	1,287.3	1,118.0
VA Existing	1016 Floor R-0 to R-19 Insulation-Batts (CAC)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1017 Wall Blow-in R-0 to R-13 Insulation (CAC)	100.00%	100.00%	100.00%	100.00%	1,897.2	1,043.9
VA Existing	1018 Cool Roof (CAC)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1019 Duct Insulation (CAC)	100.00%	100.00%	100.00%	100.00%	78.8	86.8
VA Existing	1020 Duct Testing and Sealing (CAC)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	1021 Return Duct Modification (CAC)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1022 Programmable Thermostat (CAC)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1023 Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	1024 Self Install Weatherization (CAC)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	1025 Door Weatherization (CAC)	100.00%	100.00%	100.00%	100.00%	2.0	1.5
VA Existing VA Existing	1026 Ceiling Fans (CAC)	100.00%	100.00%	100.00%	100.00%	3.9	2.1
VA Existing VA Existing	1027 Whole House Fans (CAC)	100.00%	100.00%	100.00%	100.00%	1.3	1.0
VA Existing VA Existing	1027 Whole House Pails (CAC) 1028 Window Film (CAC)	100.00%	100.00%	100.00%	100.00%	388.6	213.8
VA Existing VA Existing	1029 WINDOWS - Default With Sunscreen (CAC)	100.00%	100.00%	100.00%	100.00%	388.6	213.8
-	1030 WINDOWS - Delault With Sunscient (CAC)	100.00%	100.00%	100.00%	100.00%	388.6	213.8
VA Existing	5 , , ,	100.00%	100.00%	100.00%	100.00%	1.3	1.0
VA Existing	1100 Base Split-System Air Conditioner - Early Replacement (11 SEER)		100.00%	100.00%	100.00%		
VA Existing	1101 14 SEER (12.15 EER) Split-System Air Conditioner w/ Quality Install - Early R	100.00%	100.00%	100.00%	100.00%	1.3 2.4	1.0 1.1
VA Existing	1102 Proper Refrigerant Charging and Air Flow (CAC early replacement)					1.2	
VA Existing	1103 Proper Sizing and Quality Install (CAC early replacement)	100.00%	100.00%	100.00%	100.00%		1.1
VA Existing	1104 AC Maintenance and/or tune-up (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1105 AC Filter Changes (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1107 Ceiling R-0 to R-49 Insulation (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1109 Ceiling R-11 to R-49 Insulation (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1110 Ceiling R-19 to R-38 Insulation (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1111 Ceiling R-19 to R-49 Insulation (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1112 Crawlspace insulation (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	482.7	419.3
VA Existing	1113 Basement insulation R-13 (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,287.3	1,118.0
VA Existing	1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,897.2	1,043.9
VA Existing	1116 Cool Roof (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1117 Duct Insulation (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	78.8	86.8
VA Existing	1118 Duct Testing and Sealing (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1.0	0.5

				Standards Ad	justment		
Residential	Electric Measure Inputs	Energy Saving	js –	Factor		Technology Sa	ituration
		(percent)		(percent)		(units/home)	
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
VA Existing	1119 Return Duct Modification (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1120 Programmable Thermostat (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1.2	1.1
VA Existing	1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	1122 Self Install Weatherization (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	1123 Door Weatherization (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	2.0	1.5
VA Existing	1124 Ceiling Fans (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	3.9	2.1
VA Existing	1125 Whole House Fans (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	1.3	1.0
VA Existing	1126 Window Film (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	388.6	213.8
VA Existing	1127 WINDOWS - Default With Sunscreen (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	388.6	213.8
VA Existing	1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early replacement)	100.00%	100.00%	100.00%	100.00%	388.6	213.8
VA Existing	1200 Base Heat Pump Cooling (13 SEER)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1201 Heat pump upgrade to (14.5-15.9 SEER, 8.2+ HSPF) (HP cooling)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1203 Ground Source Heat Pump with Desuperheater (HP cooling)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1204 Proper Refrigerant Charging and Air Flow (HP cooling)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1205 Proper Sizing and Quality Install (HP cooling)	100.00%	100.00%	100.00%	100.00%	1.4	1.3
VA Existing	1206 Heat pump tune up	100.00%	100.00%	100.00%	100.00%	1.4	1.3
VA Existing	1207 Heat Pump Filter Replacement	100.00%	100.00%	100.00%	100.00%	1.4	1.3
VA Existing	1208 Ceiling R-0 to R-38 Insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1209 Ceiling R-0 to R-49 Insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1210 Ceiling R-11 to R-38 Insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing VA Existing	1211 Ceiling R-11 to R-49 Insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1212 Ceiling R-19 to R-38 Insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1213 Ceiling R-19 to R-49 Insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing VA Existing	1214 Crawlspace insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	482.7	419.3
_	•	100.00%	100.00%	100.00%	100.00%		
VA Existing	1215 Basement insulation R-13 (HP cooling)					1,287.3	1,118.0
VA Existing	1216 Floor R-0 to R-19 Insulation-Batts (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,897.2	1,043.9
VA Existing	1218 Cool Roof (HP cooling)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1219 Duct Insulation (HP cooling)	100.00%	100.00%	100.00%	100.00%	78.8	86.8
VA Existing	1220 Duct Testing and Sealing (HP cooling)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	1221 Programmable Thermostat (HP cooling)	100.00%	100.00%	100.00%	100.00%	1.0	1.0
VA Existing	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	1223 Self Install Weatherization (HP cooling)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	1224 Door Weatherization (HP cooling)	100.00%	100.00%	100.00%	100.00%	2.0	1.5
VA Existing	1225 Ceiling Fans (HP cooling)	100.00%	100.00%	100.00%	100.00%	3.9	2.1
VA Existing	1226 Whole House Fans (HP cooling)	100.00%	100.00%	100.00%	100.00%	1.3	1.0
VA Existing	1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling)	100.00%	100.00%	100.00%	100.00%	388.6	213.8
VA Existing	1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1301 Heat pump upgrade to (14.5-15.9 SEER, 8.2+ HSPF) (HP cooling Early Repla	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1302 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replacement	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1303 Ground Source Heat Pump with Desuperheater (HP cooling Early Replacement	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1304 Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	2.4	1.1
VA Existing	1305 Proper Sizing and Quality Install (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1.4	1.3
VA Existing	1306 Heat pump tune up	100.00%	100.00%	100.00%	100.00%	1.4	1.3
VA Existing	1307 Heat Pump Filter Replacement	100.00%	100.00%	100.00%	100.00%	1.4	1.3
VA Existing	1308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	1310 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0

				Standards Ad	ustment		
Residential	Electric Measure Inputs	Energy Saving	js	Factor		Technology Sa	turation
		(percent)		(percent)		(units/home)	
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
/A Existing	1312 Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.
A Existing	1313 Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
'A Existing	1314 Crawlspace insulation (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	482.7	419
'A Existing	1315 Basement insulation R-13 (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,287.3	1,118
/A Existing	1316 Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	1317 Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,897.2	1,043
'A Existing	1318 Cool Roof (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	1319 Duct Insulation (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	78.8	86
/A Existing	1320 Duct Testing and Sealing (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1.0	(
/A Existing	1321 Programmable Thermostat (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1.4	1
/A Existing	1322 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early Replacem	100.00%	100.00%	100.00%	100.00%	1.0	(
/A Existing	1323 Self Install Weatherization (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	1.0	
/A Existing	1324 Door Weatherization (HP cooling Early Replacement)	100.00%	100.00%	100.00%	100.00%	2.0	1
A Existing	1325 Ceiling Fans (HP cooling early replacement)	100.00%	100.00%	100.00%	100.00%	3.9	2
A Existing	1326 Whole House Fans (HP cooling early replacement)	100.00%	100.00%	100.00%	100.00%	1.3	
/A Existing	1327 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Replacer	100.00%	100.00%	100.00%	100.00%	388.6	213
/A Existing	1400 Base Room Air Conditioner - EER 10.6	90.50%	90.50%	90.50%	90.50%	1.2	210
/A Existing	1401 Energy Star Room Air Conditioner - EER 10.8	90.50%	90.50%	90.50%	90.50%	1.2	
/A Existing	1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	90.50%	90.50%	90.50%	90.50%	1.2	
A Existing /A Existing	1402 Room AC Filter Replacement	90.50%	90.50%	90.50%	90.50%	1.2	
-	•	90.50%	90.50%	90.50%			
A Existing	1404 Ceiling R-0 to R-38 Insulation (RAC) 1405 Ceiling R-0 to R-49 Insulation (RAC)		90.50%		90.50% 90.50%	1,441.9	1,08
/A Existing	, ,	90.50%		90.50%		1,441.9	1,085
/A Existing	1406 Ceiling R-11 to R-38 Insulaton (RAC)	90.50%	90.50%	90.50%	90.50%	1,441.9	1,08
/A Existing	1407 Ceiling R-11 to R-49 Insulation (RAC)	90.50%	90.50%	90.50%	90.50%	1,441.9	1,085
/A Existing	1408 Ceiling R-19 to R-38 Insulation (RAC)	90.50%	90.50%	90.50%	90.50%	1,441.9	1,085
/A Existing	1409 Ceiling R-19 to R-49 Insulation (RAC)	90.50%	90.50%	90.50%	90.50%	1,441.9	1,085
/A Existing	1410 Wall Blow-in R-0 to R-13 Insulation (RAC)	90.50%	90.50%	90.50%	90.50%	1,897.2	1,043
/A Existing	1411 Cool Roof (RAC)	90.50%	90.50%	90.50%	90.50%	1,441.9	1,08
/A Existing	1412 Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	90.50%	90.50%	90.50%	90.50%	1.0	(
/A Existing	1413 Self Install Weatherization (RAC)	90.50%	90.50%	90.50%	90.50%	1.0	(
/A Existing	1414 Door Weatherization (RAC)	90.50%	90.50%	90.50%	90.50%	2.0	1
A Existing	1415 Ceiling Fans (RAC)	90.50%	90.50%	90.50%	90.50%	3.9	2
/A Existing	1416 Whole House Fans (RAC)	90.50%	90.50%	90.50%	90.50%	1.3	
/A Existing	1417 Window Film (RAC)	90.50%	90.50%	90.50%	90.50%	388.6	213
/A Existing	1418 WINDOWS - Default With Sunscreen (RAC)	90.50%	90.50%	90.50%	90.50%	388.6	213
/A Existing	1419 WINDOWS - Double-Glazed Clear to Energy Star (RAC)	90.50%	90.50%	90.50%	90.50%	388.6	213
/A Existing	1500 Base Room Air Conditioner, Early Replacement - EER 9.7	100.00%	100.00%	100.00%	100.00%	1.2	•
/A Existing	1501 EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early replacement)	100.00%	100.00%	100.00%	100.00%	1.2	1
/A Existing	1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	86.00%	86.00%	86.00%	86.00%	1.1	1
A Existing	1601 10% better than Energy Star Dehumidifier ROB (35-45 pints/day)	86.00%	86.00%	86.00%	86.00%	1.1	
A Existing	1700 Base Furnace Fan - Furnace & CAC	100.00%	100.00%	100.00%	100.00%	1.0	(
A Existing	1701 ECM Furnace Fan (variable speed motor) - Cooling	100.00%	100.00%	100.00%	100.00%	1.0	(
/A Existing	2000 Base Heat Pump Space Heating (7.7 HSPF)	100.00%	100.00%	100.00%	100.00%	1.0	
'A Existing	2001 Heat pump upgrade to 14.5-15.9 SEER/8.2+ HSPF (HP heating)	100.00%	100.00%	100.00%	100.00%	2.4	
'A Existing	2002 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	100.00%	100.00%	100.00%	100.00%	2.4	
/A Existing	2003 Ground Source Heat Pump with Desuperheater (HP heating)	100.00%	100.00%	100.00%	100.00%	2.4	
/A Existing	2004 Heat pump tune up	100.00%	100.00%	100.00%	100.00%	1.4	
'A Existing	2005 Heat Pump Filter Replacement	100.00%	100.00%	100.00%	100.00%	1.4	
/A Existing	2006 Ceiling R-0 to R-38 Insulation (HP heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
9	3 (100.00%	100.00%	100.00%	100.00%		.,00

				Standards Ad	justment		
Residential	Electric Measure Inputs	Energy Saving	js	Factor		Technology Sa	aturation
		(percent)		(percent)		(units/home)	
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
VA Existing	2008 Ceiling R-11 to R-38 Insulaton (HP heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.
VA Existing	2009 Ceiling R-11 to R-49 Insulation (HP heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.
VA Existing	2010 Ceiling R-19 to R-38 Insulation (HP heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.
VA Existing	2011 Ceiling R-19 to R-49 Insulation (HP heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.
VA Existing	2012 Crawlspace insulation (HP heating)	100.00%	100.00%	100.00%	100.00%	482.7	419.
VA Existing	2013 Basement insulation R-13 (HP heating)	100.00%	100.00%	100.00%	100.00%	1,287.3	1,118.
VA Existing	2014 Floor R-0 to R-19 Insulation-Batts (HP heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.
VA Existing	2015 Wall Blow-in R-0 to R-13 Insulation (HP heating)	100.00%	100.00%	100.00%	100.00%	1,897.2	1,043
VA Existing	2016 Duct Insulation (HP heating)	100.00%	100.00%	100.00%	100.00%	78.8	86
VA Existing	2017 Duct Testing and Sealing (HP heating)	100.00%	100.00%	100.00%	100.00%	1.0	0.
/A Existing	2018 Heat Recovery Ventilators (HP heating)	100.00%	100.00%	100.00%	100.00%	1.0	1
VA Existing	2019 Programmable Thermostat (HP heating)	100.00%	100.00%	100.00%	100.00%	1.4	1.
VA Existing	2020 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	100.00%	100.00%	100.00%	100.00%	1.0	0.
/A Existing	2021 Self Install Weatherization (HP heating)	100.00%	100.00%	100.00%	100.00%	1.0	0
/A Existing	2022 Door Weatherization (HP heating)	100.00%	100.00%	100.00%	100.00%	2.0	1
/A Existing	2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	100.00%	100.00%	100.00%	100.00%	388.6	213
/A Existing	2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSPF)	100.00%	100.00%	100.00%	100.00%	1.0	1
/A Existing	2101 Heat pump upgrade to 14.5-15.9 SEER/8.2+ HSPF (HP heating early replace		100.00%	100.00%	100.00%	2.4	1
/A Existing	2102 Heat pump upgrade to 14.3-13.9 SEER/8.7+ HSPF (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	2.4	1
/A Existing	2103 Ground Source Heat Pump with Desuperheater (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	2.4	1
•							
/A Existing	2104 Heat pump tune up (heating)	100.00%	100.00% 100.00%	100.00%	100.00%	1.4	1
/A Existing	2105 Heat Pump Filter Replacement (heating)	100.00%		100.00%	100.00%	1.4	1
/A Existing	2106 Ceiling R-0 to R-38 Insulation (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2107 Ceiling R-0 to R-49 Insulation (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2108 Ceiling R-11 to R-38 Insulaton (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2109 Ceiling R-11 to R-49 Insulation (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2110 Ceiling R-19 to R-38 Insulation (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2112 Crawlspace insulation (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	482.7	419
/A Existing	2113 Basement insulation R-13 (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,287.3	1,118
/A Existing	2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1,897.2	1,043
/A Existing	2116 Duct Insulation (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	78.8	86
/A Existing	2117 Duct Testing and Sealing (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1.0	C
/A Existing	2118 Heat Recovery Ventilators (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1.0	1
/A Existing	2119 Programmable Thermostat (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1.4	1
/A Existing	2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating early replacement	100.00%	100.00%	100.00%	100.00%	1.0	0
/A Existing	2121 Self Install Weatherization (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	1.0	C
/A Existing	2122 Door Weatherization (HP heating early replacement)	100.00%	100.00%	100.00%	100.00%	2.0	1
/A Existing	2123 WINDOWS - Double-Glazed Clear to Energy Star (HP heating early replacem	100.00%	100.00%	100.00%	100.00%	388.6	213
/A Existing	2200 Base Resistance Space Heating (Primary)	100.00%	100.00%	100.00%	100.00%	1.0	1
/A Existing	2201 Air Source Heat Pump (resistance heating)	100.00%	100.00%	100.00%	100.00%	2.4	1
/A Existing	2202 Ground Source Heat Pump with Desuperheater (resistance heating)	100.00%	100.00%	100.00%	100.00%	2.4	1
/A Existing	2203 Ceiling R-0 to R-38 Insulation (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2204 Ceiling R-0 to R-49 Insulation (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2205 Ceiling R-11 to R-38 Insulaton (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2206 Ceiling R-11 to R-49 Insulation (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2207 Ceiling R-19 to R-38 Insulation (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
/A Existing	2208 Ceiling R-19 to R-49 Insulation (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085
	ALOO OGIIIIY IX-13 tO IX-43 IIISUIAUON (IESISIAIICE HEAUNY)	100.00/0	100.00/0	100.00/0	100.00/0		1.000

				Standards Ad	justment		
Residential	Electric Measure Inputs	Energy Saving	gs	Factor	-	Technology Sa	aturation
		(percent)		(percent)		(units/home)	
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
VA Existing	2210 Basement insulation R-13 (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,287.3	1,118.0
VA Existing	2211 Floor R-0 to R-19 Insulation-Batts (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,441.9	1,085.0
VA Existing	2212 Wall Blow-in R-0 to R-13 Insulation (resistance heating)	100.00%	100.00%	100.00%	100.00%	1,897.2	1,043.9
VA Existing	2213 Heat Recovery Ventilators (resistance heating)	100.00%	100.00%	100.00%	100.00%	1.0	1.0
VA Existing	2214 Programmable Thermostat (resistance heating)	100.00%	100.00%	100.00%	100.00%	1.0	1.0
VA Existing	2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating)	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	2216 Self Install Weatherization	100.00%	100.00%	100.00%	100.00%	1.0	0.5
VA Existing	2217 Door Weatherization (resistance heating)	100.00%	100.00%	100.00%	100.00%	2.0	1.5
VA Existing	2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance heating)	100.00%	100.00%	100.00%	100.00%	388.6	213.8
VA Existing	3000 Base Halogen Lighting - 0.5 hrs/day 2014-2015	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3001 CFL (base Halogen 0.5 hrs/day) 2014-2015	100.00%	100.00%	100.00%	100.00%	14.8	6.9
VA Existing	3002 LEDs (base Halogen 0.5 hrs/day) 2014-2015	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3010 Base Halogen Lighting - 0.5 hrs/day 2016-2017	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3011 CFL (base Halogen 0.5 hrs/day) 2016-2017	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3012 LEDs (base Halogen 0.5 hrs/day) 2016-2017	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3020 Base Halogen Lighting - 0.5 hrs/day 2018-2019	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3021 CFL (base Halogen 0.5 hrs/day) 2018-2019	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3022 LEDs (base Halogen 0.5 hrs/day) 2018-2019	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3030 Base Halogen Lighting - 0.5 hrs/day 2020	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3032 LEDs (base Halogen 0.5 hrs/day) 2020	70.00%	70.00%	70.00%	70.00%	14.8	6.9
VA Existing	3100 Base Halogen Lighting - 2.5 hrs/day 2014-2015	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing VA Existing	3101 CFL (base Halogen 2.5 hrs/day) 2014-2015	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing	3102 LEDs (base Halogen 2.5 hrs/day) 2014-2015	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing VA Existing	3110 Base Halogen Lighting - 2.5 hrs/day 2016-2017	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing VA Existing	3111 CFL (base Halogen 2.5 hrs/day) 2016-2017	70.00%	70.00%	70.00%	70.00%	12.2	5.7
-	The state of the s	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing VA Existing	3112 LEDs (base Halogen 2.5 hrs/day) 2016-2017	70.00%	70.00%	70.00%	70.00%	12.2	5.7
	3120 Base Halogen Lighting - 2.5 hrs/day 2018-2019						
VA Existing	3121 CFL (base Halogen 2.5 hrs/day) 2018-2019	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing	3122 LEDs (base Halogen 2.5 hrs/day) 2018-2019	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing	3130 Base Halogen Lighting - 2.5 hrs/day 2020	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing	3132 LEDs (base Halogen 2.5 hrs/day) 2020	70.00%	70.00%	70.00%	70.00%	12.2	5.7
VA Existing	3200 Base Halogen Lighting - 6 hrs/day 2014-2015	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3201 CFL (base Halogen 6 hrs/day) 2014-2015	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3202 LEDs (base Halogen 6 hrs/day) 2014-2015	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3210 Base Halogen Lighting - 6 hrs/day 2016-2017	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3211 CFL (base Halogen 6 hrs/day) 2016-2017	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3212 LEDs (base Halogen 6 hrs/day) 2016-2017	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3220 Base Halogen Lighting - 6 hrs/day 2018-2019	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3221 CFL (base Halogen 6 hrs/day) 2018-2019	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3222 LEDs (base Halogen 6 hrs/day) 2018-2019	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3230 Base Halogen Lighting - 6 hrs/day 2020	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3232 LEDs (base Halogen 6 hrs/day) 2020	70.00%	70.00%	70.00%	70.00%	3.4	1.5
VA Existing	3300 Base CFL Lighting - 0.5 hrs/day 2014-2015	100.00%	100.00%	100.00%	100.00%	7.3	3.3
VA Existing	3301 LEDs (base CFL 0.5 hrs/day) 2014-2015	100.00%	100.00%	100.00%	100.00%	7.3	3.3
VA Existing	3310 Base CFL Lighting - 0.5 hrs/day 2016-2017	100.00%	100.00%	100.00%	100.00%	7.3	3.3
VA Existing	3311 LEDs (base CFL 0.5 hrs/day) 2016-2017	100.00%	100.00%	100.00%	100.00%	7.3	3.3
VA Existing	3320 Base CFL Lighting - 0.5 hrs/day 2018-2019	100.00%	100.00%	100.00%	100.00%	7.3	3.3
VA Existing	3321 LEDs (base CFL 0.5 hrs/day) 2018-2019	100.00%	100.00%	100.00%	100.00%	7.3	3.3
VA Existing	3330 Base CFL Lighting - 0.5 hrs/day 2020	100.00%	100.00%	100.00%	100.00%	7.3	3.3
		100.00%	100.00%	100.00%	100.00%	7.3	3.3

				Standards Ad	justment		
Residential	Electric Measure Inputs	Energy Saving	js –	Factor		Technology Sa	ituration
		(percent)		(percent)		(units/home)	
Segment	Measure # Measure Description	Single Family	Multifamily	Single Family	Multifamily	Single Family	Multifamily
VA Existing	3400 Base CFL Lighting - 2.5 hrs/day 2014-2015	100.00%	100.00%	100.00%	100.00%	6.0	2.7
VA Existing	3401 LEDs (base CFL 2.5 hrs/day) 2014-2015	100.00%	100.00%	100.00%	100.00%	6.0	2.7
VA Existing	3410 Base CFL Lighting - 2.5 hrs/day 2016-2017	100.00%	100.00%	100.00%	100.00%	6.0	2.7
VA Existing	3411 LEDs (base CFL 2.5 hrs/day) 2016-2017	100.00%	100.00%	100.00%	100.00%	6.0	2.7
VA Existing	3420 Base CFL Lighting - 2.5 hrs/day 2018-2019	100.00%	100.00%	100.00%	100.00%	6.0	2.7
VA Existing	3421 LEDs (base CFL 2.5 hrs/day) 2018-2019	100.00%	100.00%	100.00%	100.00%	6.0	2.7
VA Existing	3430 Base CFL Lighting - 2.5 hrs/day 2020	100.00%	100.00%	100.00%	100.00%	6.0	2.7
VA Existing	3431 LEDs (base CFL 2.5 hrs/day) 2020	100.00%	100.00%	100.00%	100.00%	6.0	2.7
VA Existing	3500 Base CFL Lighting - 6 hrs/day 2014-2015	100.00%	100.00%	100.00%	100.00%	1.6	0.8
VA Existing	3501 LEDs (base CFL 6 hrs/day) 2014-2015	100.00%	100.00%	100.00%	100.00%	1.6	0.8
VA Existing	3510 Base CFL Lighting - 6 hrs/day 2016-2017	100.00%	100.00%	100.00%	100.00%	1.6	8.0
VA Existing	3511 LEDs (base CFL 6 hrs/day) 2016-2017	100.00%	100.00%	100.00%	100.00%	1.6	8.0
VA Existing	3520 Base CFL Lighting - 6 hrs/day 2018-2019	100.00%	100.00%	100.00%	100.00%	1.6	0.8
VA Existing	3521 LEDs (base CFL 6 hrs/day) 2018-2019	100.00%	100.00%	100.00%	100.00%	1.6	0.8
VA Existing	3530 Base CFL Lighting - 6 hrs/day 2020	100.00%	100.00%	100.00%	100.00%	1.6	0.8
VA Existing	3531 LEDs (base CFL 6 hrs/day) 2020	100.00%	100.00%	100.00%	100.00%	1.6	0.8
VA Existing	3600 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2014-2015	100.00%	100.00%	100.00%	100.00%	5.9	1.9
VA Existing	3601 CFL (base Halogen (Specialty) 0.5 hrs/day 2014-2015	100.00%	100.00%	100.00%	100.00%	5.9	1.9
VA Existing	3602 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2014-2015	100.00%	100.00%	100.00%	100.00%	5.9	1.9
VA Existing	3610 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2016-2017	100.00%	100.00%	100.00%	100.00%	5.9	1.9
VA Existing	3611 CFL (base Halogen (Specialty) 0.5 hrs/day) 2016-2017	100.00%	100.00%	100.00%	100.00%	5.9	1.9
VA Existing	3612 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2016-2017	100.00%	100.00%	100.00%	100.00%	5.9	1.9
VA Existing	3620 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2018-2019	100.00%	100.00%	100.00%	100.00%	5.9	1.9
VA Existing	3621 CFL (base Halogen (Specialty) 0.5 hrs/day) 2018-2019	100.00%	100.00%	100.00%	100.00%		1.9

Commercial Electric Measure Inputs		BASE TECHNO (kWh/square f											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery W	Varehouse	Education	Health	Lodging [Data Centers	Non-Jurisdictional F	Religious Worship	Misc
VA Existing	1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	7.8	7.8	5.2	7.4	2.1	3.4	3.1	1.6	6.1	4.9	1.6	4.9
VA Existing	1010 Base Fluorescent Fixture, 4L4T8, 1EB, 2016-2017	7.8	7.8	5.2	7.4	2.1	3.4	3.1	1.6	6.1	4.9	1.6	4.9
VA Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019	7.8	7.8	5.2	7.4	2.1	3.4	3.1	1.6	6.1	4.9	1.6	4.9
VA Existing	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	7.8	7.8	5.2	7.4	2.1	3.4	3.1	1.6	6.1	4.9	1.6	4.9
VA Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015 1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	4.3 4.3	3.5 3.5	2.9 2.9	5.6 5.6	1.9	2.2 2.2	1.4 1.4	1.1 1.1	3.4 3.4	3.4 3.4	1.2	3.7 3.7
VA Existing VA Existing	1120 Base Fluorescent Fixture, 2L4T8, 1EB, 2018-2019	4.3	3.5	2.9	5.6	1.9 1.9	2.2	1.4	1.1	3.4	3.4	1.2 1.2	3.7
VA Existing	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020	4.3	3.5	2.9	5.6	1.9	2.2	1.4	1.1	3.4	3.4	1.2	3.7
VA Existing	1200 Base Other Fluorescent Fixture	3.5	0.0	1.5	0.0	3.0	0.4	1.1	0.5	2.8	1.3	0.3	1.0
VA Existing	1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	30.1	4.8	7.8	4.7		0.2	1.3	2.5	24.1	9.8	1.9	7.6
VA Existing	1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	30.1	4.8	7.8	4.7		0.2	1.3	2.5	24.1	9.8	1.9	7.6
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	30.1	4.8	7.8	4.7		0.2	1.3	2.5	24.1	9.8	1.9	7.6
VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	30.1	4.8	7.8	4.7		0.2	1.3	2.5	24.1	9.8	1.9	7.6
VA Existing	1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	21.7	3.5	5.6	3.4	3.5	0.1	0.9	1.8	17.3	7.1	1.3	5.4
VA Existing	1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	21.7	3.5	5.6	3.4	3.5	0.1	0.9	1.8	17.3	7.1	1.3	5.4
VA Existing	1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	21.7	3.5	5.6	3.4	3.5	0.1	0.9	1.8	17.3	7.1	1.3	5.4
VA Existing	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	21.7	3.5	5.6	3.4	3.5	0.1	0.9	1.8	17.3	7.1	1.3	5.4
VA Existing	1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	15.9	2.6	4.1	2.5	2.5	0.1	0.7	1.3	12.8	5.2	1.0	4.0
VA Existing	1510 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	15.9	2.6	4.1	2.5	2.5	0.1	0.7	1.3	12.8	5.2	1.0	4.0
VA Existing	1520 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	15.9	2.6	4.1	2.5	2.5	0.1	0.7	1.3	12.8	5.2	1.0	4.0
VA Existing	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	15.9	2.6	4.1	2.5	2.5	0.1	0.7	1.3	12.8	5.2	1.0	4.0
VA Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	1.2	0.9	0.9	4.2	0.9	1.3	0.3	0.3	1.0	1.2	0.2	1.0
VA Existing	1610 Base CFL 18W to screw-in replacement 2016-2017	1.2	0.9	0.9	4.2	0.9	1.3	0.3	0.3	1.0	1.2	0.2	1.0
VA Existing	1620 Base CFL 18W to screw-in replacement 2018-2019	1.2	0.9	0.9	4.2 4.2	0.9	1.3	0.3	0.3	1.0	1.2	0.2	1.0
VA Existing	1630 Base CFL 18W to screw-in replacement 2020	1.2	0.9				1.3	0.3	0.3	1.0	1.2	0.2	1.0
VA Existing	1700 Base CFL 23W to screw-in replacement 2014-2015	1.6 1.6	1.1 1.1	1.2 1.2	5.3 5.3	1.1 1.1	1.7 1.7	0.4 0.4	0.4 0.4	1.3 1.3	1.6 1.6	0.3 0.3	1.2
VA Existing VA Existing	1710 Base CFL 23W to screw-in replacement 2016-2017 1720 Base CFL 23W to screw-in replacement 2018-2019	1.6	1.1	1.2	5.3	1.1	1.7	0.4	0.4	1.3	1.6	0.3	1.2 1.2
VA Existing	1730 Base CFL 23W to screw-in replacement 2010-2019	1.6	1.1	1.2	5.3	1.1	1.7	0.4	0.4	1.3	1.6	0.3	1.2
VA Existing	1800 BaseMetal Halide, 465W	1.0	0.1	1.2	14.4	2.8	5.1	0.4	2.6	1.5	3.5	0.9	2.9
VA Existing	1850 Base CFL Exit Sign	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
VA Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp	0.8	1.6	0.7	0.2	0.4	0.5	0.2	0.2	0.7	0.5	0.1	0.3
VA Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	4.4	5.8	2.7	2.7	1.6	1.5	3.0	2.8	10.7	2.5	1.0	2.1
VA Existing	2100 Base DX Packaged System, EER=10.3, 10 tons	4.4	5.8	2.7	2.7	1.6	1.5	3.0	2.8	10.7	2.5	1.0	2.1
VA Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	4.4	5.8	2.7	2.7	1.6	1.5	3.0	2.8	10.7	2.5	1.0	2.1
VA Existing	2300 Base PTAC, EER=8.3, 1 ton	4.4	5.8	2.7	2.7	1.6	1.5	3.0	2.8	10.7	2.5	1.0	2.1
VA Existing	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	3.3	2.9	2.1	2.3	1.1	1.0	3.0	1.9	5.5	1.7	0.7	1.4
VA Existing	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	3.3	2.9	2.1	2.3	1.1	1.0	3.0	1.9	5.5	1.7	0.7	1.4
VA Existing	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	3.3	2.9	2.1	2.3	1.1	1.0	3.0	1.9	5.5	1.7	0.7	1.4
VA Existing	4000 Base Built-Up Refrigeration System				10.1	2.1							
VA Existing	4100 Base Self-Contained Refrigeration	0.6	6.9	1.0	1.1	0.2	0.5	0.5	0.9	0.6	0.8	0.5	1.0
VA Existing	5000 Base Desktop PC	0.2	0.1	0.0	0.0	0.1	0.1	0.1	0.0	0.1	0.1	0.1	0.1
VA Existing	5100 Base Laptop PC	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
VA Existing	5200 Base Monitor, CRT	0.1	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0	0.0
VA Existing	5300 Base Monitor, LCD	0.0 0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
VA Existing	5400 Base Copier			0.0									
VA Existing VA Existing	5500 Base Multifunction 5600 Base Printer	0.0 0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0 0.0	0.0	0.0
VA Existing	5700 Base Printer 5700 Base Data Center/Server Room	149.0	104.3	119.2	119.2	119.2	119.2	119.2	119.2	119.2	119.2	82.0	119.2
VA Existing	6000 Base Water Heating	0.4	1.6	0.2	0.3	0.1	0.2	0.3	1.0	0.1	0.3	0.2	0.4
VA Existing	7000 Base Refrigerated Vending Machines	0.1	0.0	0.0	0.2	0.0	0.0	0.1	0.1	0.0	0.0	0.0	0.0
VA Existing	7100 Base Non-Refrigerated Vending Machines	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
VA Existing	7200 Base Oven	1.1	1.9	0.6	0.4	0.1	0.6	1.9	0.1	0.0	0.6	0.3	0.3
VA Existing	7300 Base Fryer	0.9	1.9	0.3	0.6	0.2	0.1	3.2	0.2		0.5	0.5	0.5
VA Existing	7400 Base Steamer	2.5	2.9	1.3	1.0	0.1	0.2	1.6	0.1		0.8	0.2	0.2
VA Existing	8000 Base Heating, Heat Pump (7.7 HSPF)	0.7	0.2	0.3	0.3	0.4	0.2	0.7	0.5	0.2	0.4	0.2	0.4
VA Existing	8100 Base Heating, Other Electric	0.7	0.2	0.3	0.3	0.4	0.2	0.7	0.5	0.2	0.4	0.2	0.4
VA Existing	9500 Base Miscellaneous	2.2	2.6	2.2	2.4	0.9	0.6	3.3	1.4	0.6	1.5	1.7	1.7
NC Existing	1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	8.0	7.3	5.6	5.9	4.4	3.6	2.8	1.6	5.2		1.2	4.7
NC Existing	1010 Base Fluorescent Fixture, 4L4T8, 1EB, 2016-2017	8.0	7.3	5.6	5.9	4.4	3.6	2.8	1.6	5.2		1.2	4.7
NC Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019	8.0	7.3	5.6	5.9	4.4	3.6	2.8	1.6	5.2		1.2	4.7
NC Existing	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	8.0	7.3	5.6	5.9	4.4	3.6	2.8	1.6	5.2		1.2	4.7
NC Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	4.3	3.5	3.0	4.6	3.8	2.4	1.2	1.0	2.9		1.0	3.6

MEASURE COSTS							NPV o	lander - to		ull = 1		Eur						Implementation
		Start	End	Savings	Unit Cost Equipme	Unit nt Labor	Lifetime r O & M	Implementation Cost	Service In	ncr. = 0 Initial	Replace	Full Unit						Type RET = Retrofit
Segment	Measure # Measure Description	Year	Year	Units	nits Cost	Cost	Cost	Factor	Life	Cost	Cost	Cost	SS S-ON	S-MD S-			W-OFF E	nd Use ROB = Replace on Burnout
VA Existing	1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	2014	2015 sqft	fixture	\$0.			\$0.00	18	1	1	\$0.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing VA Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015 1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	2014 2014	2015 sqft 2015 sqft	fixture fixture	\$7. \$23.		00	\$7.00 \$23.00	30,000	1	1	\$7.00 \$23.00	1.00 1.00		1.00	1.00	1.00	1 ROB 1 ROB
VA Existing	1002 ROB 4L4 LOW Walk right Performance 18 (75 W), 2014-2015	2014	2015 sqit 2015 saft	fixture	\$23.		00	\$25.00	20,000	1	1	\$25.00	1.00		1.00	1.00	1.00	1 RET
VA Existing	1004 ROB 4L4' LED Tube, 2014-2015	2014	2015 sqft	fixture	\$308	00 \$0.0	00 (\$12.7	\$308.00	50,000	1	1	\$295.27	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1005 LED Troffer (base 4L4T8), 2014-2015	2014	2015 sqft	fixture	\$375	00 \$15.0	00 (\$12.7		50,000	1	1	\$377.27	1.00		1.00	1.00	1.00	1 RET
VA Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	2014	2015 sqft	sqft		\$0.0	01	\$0.01	6	1	1	\$0.01	0.50		1.31	0.50	1.31	1 RET
VA Existing VA Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015 1008 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	2014	2015 sqft 2015 sqft	fixture	\$55. \$0			\$55.00 \$0.20	10 15	1	1	\$55.00 \$0.20	0.25		1.46	0.25	1.46	1 RET 1 ROB
VA Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	2016	2017 sqft	fixture	\$0.		00	\$0.00	18	1	1	\$0.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	2016	2017 sqft	fixture	\$7.		00	\$7.00	30,000	1	1	\$7.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	2016	2017 sqft	fixture	\$23			\$23.00	30,000	1	1	\$23.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing VA Existing	1013 ROB 4L4'T5, 2016-2017 1014 ROB 4L4' LED Tube. 2016-2017	2016 2016	2017 sqft 2017 sqft	fixture	\$70. \$215			\$85.00 \$215.60	20,000 50,000	1	1	\$85.00 \$202.87	1.00		1.00	1.00	1.00	1 RET 1 ROB
VA Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	2016	2017 sqit 2017 saft	fixture	\$262		(4	,	50,000	1	1	\$264.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1016 Lighting Control Tuneup (base 4L4T8), 2016-2017	2016	2017 sqft	sqft		\$0.0	01	\$0.01	6	1	1	\$0.01	0.50		1.31	0.50	1.31	1 RET
VA Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	2016	2017 sqft	fixture	\$55			\$55.00	10	1	1	\$55.00	0.25		1.46	0.25	1.46	1 RET
VA Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	2016	2017 sqft	sqft	\$0.			\$0.20	15	1	1	\$0.20	0.80		1.12	0.80	1.12	1 ROB
VA Existing VA Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019 1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	2018 2018	2019 sqft 2019 sqft	fixture	\$0. \$7.			\$0.00 \$7.00	18 30.000	1	1	\$0.00 \$7.00	1.00 1.00		1.00	1.00	1.00	1 ROB 1 ROB
VA Existing	1022 ROB 4L4 High Performance T8 (75 W), 2018-2019	2018	2019 sqit	fixture	\$23		50	\$23.00	30,000	1	1	\$23.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1023 ROB 4L4'T5, 2018-2019	2018	2019 sqft	fixture	\$70.		00	\$85.00	20,000	1	1	\$85.00	1.00		1.00	1.00	1.00	1 RET
VA Existing	1024 ROB 4L4' LED Tube, 2018-2019	2018	2019 sqft	fixture	\$195				50,000	1	1	\$182.54	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	2018	2019 sqft	fixture	\$237		(4		50,000	1	1	\$240.02	1.00		1.00	1.00	1.00	1 RET
VA Existing VA Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019 1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	2018 2018	2019 sqft 2019 sqft	sqft fixture	\$55.	\$0.0	01	\$0.01 \$55.00	6 10	1	1	\$0.01 \$55.00	0.50 0.25		1.31	0.50 0.25	1.31	1 RET 1 RET
VA Existing VA Existing	1027 Occupancy Sensor, 4L4 Fluorescent Fixtures, 2018-2019 1028 High Performance Lighting R/R - 25% Savings (base 4L4/T8), 2018-2019	2018	2019 sqft 2019 saft	nxture	\$55.			\$55.00	10	1	1	\$0.20	0.25		1.46	0.25	1.46	1 REI 1 ROB
VA Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	2020	2019 sqft 2054 sqft	fixture	\$0.		00	\$0.00	18	1	1	\$0.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	2020	2054 sqft	fixture	\$7			\$7.00	30,000	1	1	\$7.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	2020	2054 sqft	fixture	\$23			\$23.00	30,000	1	1	\$23.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1033 ROB 4L4'T5, 2020	2020	2054 sqft	fixture	\$70			\$85.00	20,000	1	1	\$85.00	1.00		1.00	1.00	1.00	1 RET
VA Existing VA Existing	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	2020 2020	2054 sqft 2054 sqft	fixture	\$184 \$225				50,000 50,000	1	1	\$172.07 \$227.27	1.00		1.00	1.00	1.00	1 ROB 1 RET
VA Existing VA Existing	1035 LED Troffer (base 4L4 T8), 2020 1036 Lighting Control Tuneup (base 4L4 T8), 2020	2020	2054 sqft 2054 sqft	nxture	\$225	JU \$15.U \$0.0		\$240.00	50,000	1	1	\$227.27	0.50		1.00	0.50	1.00	1 RET
VA Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	2020	2054 sqft	fixture	\$55.			\$55.00	10	1	1	\$55.00	0.25		1.46	0.25	1.46	1 RET
VA Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	2020	2054 sqft	sqft	\$0.			\$0.20	15	1	1	\$0.20	0.80		1.12	0.80	1.12	1 ROB
VA Existing	1100 Base Fluorescent Fixture, 2L4T8, 1EB, 2014-2015	2014	2015 sqft	fixture	\$0			\$0.00	18	1	1	\$0.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing VA Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	2014	2015 sqft 2015 sqft	fixture	\$5. \$16			\$5.00 \$16.43	30,000	1	1	\$5.00 \$16.43	1.00		1.00	1.00	1.00	1 ROB 1 ROB
VA Existing VA Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015 1103 ROB 2L4'T5, 2014-2015	2014	2015 sqft 2015 sqft	fixture	\$16. \$40.			\$16.43 \$55.00	20,000	1	1	\$16.43 \$55.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1104 ROB 2L4' LED Tube, 2014-2015	2014	2015 sqft	fixture	\$154				50,000	1	1	\$141.27	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1105 LED Troffer (base 2L4T8), 2014-2015	2014	2015 sqft	fixture	\$202	00 \$15.0	00 (\$12.7	\$217.00	50,000	1	1	\$204.27	1.00		1.00	1.00	1.00	1 RET
VA Existing	1106 Lighting Control Tuneup (base 2L4T8), 2014-2015	2014	2015 sqft	sqft		\$0.0	01	\$0.01	6	1	1	\$0.01	0.50		1.31	0.50	1.31	1 RET
VA Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	2014	2015 sqft	fixture	\$55.			\$55.00	10	1	1	\$55.00	0.25		1.46	0.25	1.46	1 RET
VA Existing VA Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015 1110 Base Fluorescent Fixture, 2L4T8, 1EB, 2016-2017	2014 2016	2015 sqft 2017 sqft	sqft fixture	\$0. \$0.		nn	\$0.20 \$0.00	15 18	1	1	\$0.20 \$0.00	0.80		1.12	0.80	1.12	1 ROB 1 ROB
VA Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	2016	2017 sqft	fixture	\$5.			\$5.00	30.000	1	1	\$5.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	2016	2017 sqft	fixture	\$16.			\$16.43	30,000	1	1	\$16.43	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1113 ROB 2L4'T5, 2016-2017	2016	2017 sqft	fixture	\$40			\$55.00	20,000	1	1	\$55.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1114 ROB 2L4' LED Tube, 2016-2017	2016	2017 sqft	fixture	\$107				50,000	1	1	\$100.37	1.00		1.00	1.00	1.00	1 ROB
VA Existing VA Existing	1115 LED Troffer (base 2L4T8), 2016-2017 1116 Lighting Control Tuneup (base 2L4T8), 2016-2017	2016 2016	2017 sqft 2017 sqft	fixture	\$141.		(4	\$156.40 \$0.01	50,000	1	1	\$148.97 \$0.01	1.00 0.50		1.00	1.00 0.50	1.00	1 RET 1 RET
VA Existing VA Existing	1116 Lighting Control I uneup (base 2L4 18), 2016-2017 1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	2016	2017 sqft 2017 sqft	sqft fixture	\$55.	\$0.0 00	J1	\$55.00	10	1	1	\$0.01 \$55.00	0.50		1.31	0.50	1.46	1 RET
VA Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	2016	2017 sqft	sqft	\$0			\$0.20	15	1	1	\$0.20	0.80		1.12	0.80	1.12	1 ROB
VA Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	2018	2019 sqft	fixture	\$0.	00 \$0.0	00	\$0.00	18	1	1	\$0.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	2018	2019 sqft	fixture	\$5.			\$5.00	30,000	1	1	\$5.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	2018	2019 sqft	fixture	\$16.			\$16.43	30,000	1	1	\$16.43	1.00		1.00	1.00	1.00	1 ROB 1 ROB
VA Existing VA Existing	1123 ROB 2L4'T5, 2018-2019 1124 ROB 2L4' LED Tube. 2018-2019	2018 2018	2019 sqft 2019 sqft	fixture	\$40. \$97.			\$55.00 \$97.64	20,000 50,000	1	1	\$55.00 \$90.21	1.00 1.00		1.00	1.00	1.00	1 ROB 1 ROB
VA Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	2018	2019 sqft	fixture	\$128				50,000	1	1	\$135.64	1.00		1.00	1.00	1.00	1 RET
VA Existing	1126 Lighting Control Tuneup (base 2L4T8), 2018-2019	2018	2019 sqft	sqft		\$0.0		\$0.01	6	1	1	\$0.01	0.50		1.31	0.50	1.31	1 RET
VA Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	2018	2019 sqft	fixture	\$55			\$55.00	10	1	1	\$55.00	0.25		1.46	0.25	1.46	1 RET
VA Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2018-2019	2018	2019 sqft	sqft	\$0			\$0.20	15	1	1	\$0.20	0.80		1.12	0.80	1.12	1 ROB
VA Existing VA Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	2020 2020	2054 sqft 2054 sqft	fixture fixture	\$0. \$5.			\$0.00 \$5.00	18 30,000	1	1	\$0.00 \$5.00	1.00 1.00		1.00	1.00	1.00	1 ROB 1 ROB
VA Existing VA Existing	1131 ROB 2L4 High Performance 18 (86 W), 2020 1132 ROB 2L4 Low Watt High Performance T8 (75 W), 2020	2020	2054 sqft 2054 sqft	fixture	\$5. \$16.			\$5.00 \$16.43	30,000	1	1	\$5.00 \$16.43	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1133 ROB 2L4T5, 2020	2020	2054 sqft	fixture	\$40			\$55.00	20,000	1	1	\$55.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1134 ROB 2L4' LED Tube, 2020	2020	2054 sqft	fixture	\$92				50,000	1	1	\$84.97	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1135 LED Troffer (base 2L4'T8), 2020	2020	2054 sqft	fixture	\$121				50,000	1	1	\$128.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1136 Lighting Control Tuneup (base 2L4T8), 2020	2020	2054 sqft	sqft		\$0.0	01	\$0.01	6	1	1	\$0.01	0.50		1.31	0.50	1.31	1 RET
VA Existing VA Existing	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	2020 2020	2054 sqft 2054 sqft	fixture	\$55. \$0.			\$55.00 \$0.20	10 15	1	1	\$55.00 \$0.20	0.25 0.80		1.46	0.25	1.46	1 RET 1 ROB
VA Existing VA Existing	1138 High Performance Lighting R/R - 25% Savings (base 2L4*18), 2020 1200 Base Other Fluorescent Fixture	2020 2014	2054 sqft 2054 sqft	sqft fixture	\$0. \$0.		00	\$0.20 \$0.00	15 18	1	1	\$0.20 \$0.00	0.80		1.12	1.00	1.12	1 ROB 1 ROB
VA Existing VA Existing	1200 Base Other Plublescent Pixture 1201 ROB High Performance T8 (base other fluorescent)	2014	2054 sqft 2054 sqft	fixture	\$0.			\$8.00	30,000	1	1	\$8.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1202 ROB Low Watt High Performance T8 (base other fluorescent)	2014	2054 sqft	fixture	\$26			\$26.29	30,000	1	1	\$26.29	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1203 Lighting Control Tuneup (base other fluorescent fixture)	2014	2054 sqft	sqft	\$0.			\$0.01	6	1	1	\$0.01	0.50		1.31	0.50	1.31	1 RET
VA Existina	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	2014	2054 saft	fixture	\$55.	0.0\$	00	\$55.00	10	1	1	\$55.00	0.25		1.46	0.25	1.46	1 RET

										_								$NV \cdot G$
MEASURE COSTS					Unit	Unit	NPV of Lifetime	Implementation		ull = 1 cr. = 0		Full						Implementation Type
		Start	End Savings	Cost	Equipment	Labor	O & M	Cost	Service	Initial	Replace	Unit	20 0.01	S-MD	S-OFF			RET = Retrofit
Segment N VA Existing	Measure # Measure Description 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Year 2014	Year Units 2054 sqft	Units	Cost \$0.20	Cost \$0.00	Cost	Factor \$0.20	Life 15	Cost 1	Cost 1	\$0.20	SS S-ON 0.80		1.12	0.80	W-OFF En	d Use ROB = Replace on Burnout 1 RET
VA Existing	1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	2014	2015 sqft	lamp	\$4.00	\$3.77		\$7.77	3,500	1	1	\$7.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1301 CFLs (base incandescent flood) 2014-2015	2014	2015 sqft	lamp	\$5.00	\$3.77	\$0.00	\$8.77	12,000	1	1	\$8.77	1.00		1.00	1.00	1.00	1 RET
VA Existing VA Existina	1302 LEDs (base incandescent flood) 2014-2015 1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	2014	2015 sqft 2017 sqft	lamp lamp	\$30.00 \$4.00	\$3.77 \$3.77	\$0.00	\$33.77 \$7.77	25,000 3,500	1	1	\$33.77 \$7.77	1.00		1.00	1.00	1.00	1 RET 1 ROB
VA Existing VA Existing	1311 CFLs (base incandescent flood) 2016-2017	2016	2017 sqft	lamp	\$5.00	\$3.77	\$0.00	\$8.77	12,000	1	1	\$8.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1312 LEDs (base incandescent flood) 2016-2017	2016	2017 sqft	lamp	\$21.80	\$3.77	\$0.00	\$25.57	25,000	1	1	\$25.57	1.00		1.00	1.00	1.00	1 RET
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	2018	2019 sqft	lamp	\$4.00	\$3.77		\$7.77	3,500	1	1	\$7.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing VA Existina	1321 CFLs (base incandescent flood) 2018-2019 1322 LEDs (base incandescent flood) 2018-2019	2018	2019 sqft 2019 sqft	lamp lamp	\$5.00 \$9.90	\$3.77 \$3.77	\$0.00 \$0.00	\$8.77 \$13.67	12,000 25,000	1	1	\$8.77 \$13.67	1.00		1.00	1.00	1.00	1 RET 1 RET
VA Existing VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	2020	2019 sqft 2054 sqft	lamp	\$4.00	\$3.77	30.00	\$7.77	3,500	1	1	\$7.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1331 CFLs (base incandescent flood) 2020	2020	2054 sqft	lamp	\$5.00	\$3.77	\$0.00	\$8.77	12,000	1	1	\$8.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1332 LEDs (base incandescent flood) 2020	2020	2054 sqft	lamp	\$3.60	\$3.77	\$0.00	\$7.37	25,000	1	1	\$7.37	1.00		1.00	1.00	1.00	1 RET
VA Existing VA Existina	1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015 1401 CFLs (base incandescent A-line 72W) 2014-2015	2014 2014	2015 sqft 2015 sqft	lamp lamp	\$4.00 \$3.00	\$3.77 \$3.77	\$0.00	\$7.77 \$6.77	3,500 12.000	1	1	\$7.77 \$6.77	1.00		1.00	1.00	1.00	1 ROB 1 RET
VA Existing VA Existing	1402 LEDs (base incandescent A-line 72W) 2014-2015	2014	2015 sqft	lamp	\$20.00	\$3.77	\$0.00	\$23.77	25.000	1	1	\$23.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	2016	2017 sqft	lamp	\$4.00	\$3.77		\$7.77	3,500	1	1	\$7.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1411 CFLs (base incandescent A-line 72W) 2016-2017	2016	2017 sqft	lamp	\$3.00	\$3.77	\$0.00	\$6.77	12,000	1	1	\$6.77	1.00		1.00	1.00	1.00	1 RET
VA Existing VA Existina	1412 LEDs (base incandescent A-line 72W) 2016-2017 1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	2016 2018	2017 sqft 2019 sqft	lamp lamp	\$14.50 \$4.00	\$3.77 \$3.77	\$0.00	\$18.27 \$7.77	25,000 3.500	1	1	\$18.27 \$7.77	1.00		1.00 1.00	1.00	1.00	1 RET 1 ROB
VA Existing VA Existing	1420 Base incandescent A-Line Earlip, 72W to Screw-in Replacement 2018-2019 1421 CFLs (base incandescent A-line 72W) 2018-2019	2018	2019 sqft	lamp	\$3.00	\$3.77	\$0.00	\$6.77	12,000	1	1	\$6.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1422 LEDs (base incandescent A-line 72W) 2018-2019	2018	2019 sqft	lamp	\$6.60	\$3.77	\$0.00	\$10.37	25,000	1	1	\$10.37	1.00		1.00	1.00	1.00	1 RET
VA Existing	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	2020	2054 sqft	lamp	\$4.00	\$3.77		\$7.77	3,500	1	1	\$7.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1431 CFLs (base incandescent A-line 72W) 2020	2020	2054 sqft	lamp	\$3.00 \$2.40	\$3.77	\$0.00	\$6.77	12,000	1	1	\$6.77	1.00		1.00 1.00	1.00	1.00	1 RET 1 RET
VA Existing VA Existina	1432 LEDs (base incandescent A-line 72W) 2020 1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	2020 2014	2054 sqft 2015 sqft	lamp lamp	\$2.40 \$4.00	\$3.77 \$3.77	\$0.00	\$6.17 \$7.77	25,000 3.500	1	1	\$6.17 \$7.77	1.00		1.00	1.00	1.00	1 REI 1 ROB
VA Existing VA Existing	1501 CFLs (base incandescent A-line 53W) 2014-2015	2014	2015 sqft	lamp	\$2.50	\$3.77	\$0.00	\$6.27	12.000	1	1	\$6.27	1.00		1.00	1.00	1.00	1 RET
VA Existing	1502 LEDs (base incandescent A-line 53W) 2014-2015	2014	2015 sqft	lamp	\$15.00	\$3.77	\$0.00	\$18.77	25,000	1	1	\$18.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1510 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	2016	2017 sqft	lamp	\$4.00	\$3.77		\$7.77	3,500	1	1	\$7.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing VA Existina	1511 CFLs (base incandescent A-line 53W) 2016-2017 1512 LEDs (base incandescent A-line 53W) 2016-2017	2016 2016	2017 sqft 2017 sqft	lamp lamp	\$2.50 \$10.90	\$3.77 \$3.77	\$0.00 \$0.00	\$6.27 \$14.67	12,000 25.000	1	1	\$6.27 \$14.67	1.00		1.00	1.00	1.00	1 RET 1 RET
VA Existing VA Existing	1512 LEDS (base incandescent A-line 53W) 2016-2017 1520 Base Incandescent A-Line Lamp. 53W to Screw-in Replacement 2018-2019	2018	2017 Sqft 2019 Sqft	lamp	\$10.90	\$3.77	\$0.00	\$7.77	3.500	1	1	\$7.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1521 CFLs (base incandescent A-line 53W) 2018-2019	2018	2019 sqft	lamp	\$2.50	\$3.77	\$0.00	\$6.27	12,000	1	1	\$6.27	1.00		1.00	1.00	1.00	1 RET
VA Existing	1522 LEDs (base incandescent A-line 53W) 2018-2019	2018	2019 sqft	lamp	\$5.00	\$3.77	\$0.00	\$8.77	25,000	1	1	\$8.77	1.00		1.00	1.00	1.00	1 RET
VA Existing VA Existina	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1531 CFLs (base incandescent A-line 53W) 2020	2020 2020	2054 sqft 2054 sqft	lamp	\$4.00 \$2.50	\$3.77 \$3.77	\$0.00	\$7.77 \$6.27	3,500 12,000	1	1	\$7.77 \$6.27	1.00		1.00 1.00	1.00	1.00	1 ROB 1 RET
VA Existing VA Existing	1531 CFLs (base incandescent A-line 53W) 2020 1532 LEDs (base incandescent A-line 53W) 2020	2020	2054 sqft	lamp lamp	\$2.50 \$1.80	\$3.77	\$0.00	\$6.27 \$5.57	25,000	1	1	\$5.57	1.00		1.00	1.00	1.00	1 RET
VA Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	2014	2015 sqft	lamp	\$10.00	\$3.77	Q 0.00	\$13.77	12,000	1	1	\$13.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1601 LED screw-in replacement (base CFL 18W) 2014-2015	2014	2015 sqft	lamp	\$20.00	\$3.77	\$0.00	\$23.77	25,000	1	1	\$23.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1610 Base CFL 18W to screw-in replacement 2016-2017	2016	2017 sqft	lamp	\$10.00	\$3.77		\$13.77	12,000	1	1	\$13.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing VA Existing	1611 LED screw-in replacement (base CFL 18W) 2016-2017 1620 Base CFL 18W to screw-in replacement 2018-2019	2016 2018	2017 sqft 2019 sqft	lamp lamp	\$14.50 \$10.00	\$3.77 \$3.77	\$0.00	\$18.27 \$13.77	25,000 12.000	1	1	\$18.27 \$13.77	1.00		1.00 1.00	1.00	1.00	1 RET 1 ROB
VA Existing VA Existing	1621 LED screw-in replacement (base CFL 18W) 2018-2019	2018	2019 sqft	lamp	\$6.60	\$3.77	\$0.00	\$10.37	25,000	1	1	\$10.37	1.00		1.00	1.00	1.00	1 RET
VA Existing	1630 Base CFL 18W to screw-in replacement 2020	2020	2054 sqft	lamp	\$10.00	\$3.77		\$13.77	12,000	1	1	\$13.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1631 LED screw-in replacement (base CFL 18W) 2020	2020	2054 sqft	lamp	\$2.40	\$3.77	\$0.00	\$6.17	25,000	1	1	\$6.17	1.00		1.00	1.00	1.00	1 RET
VA Existing VA Existina	1700 Base CFL 23W to screw-in replacement 2014-2015 1701 LED screw-in replacement (base CFL 23W) 2014-2015	2014 2014	2015 sqft 2015 sqft	lamp	\$10.00 \$15.00	\$3.77 \$3.77	\$0.00	\$13.77 \$18.77	12,000 25.000	1	1	\$13.77 \$18.77	1.00		1.00	1.00	1.00	1 ROB 1 RET
VA Existing VA Existina	1701 LED screw-in replacement (base CFL 23W) 2014-2015 1710 Base CFL 23W to screw-in replacement 2016-2017	2014	2015 sqft 2017 sqft	lamp lamp	\$15.00 \$10.00	\$3.77	\$0.00	\$18.77 \$13.77	12 000	1	1	\$18.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1711 LED screw-in replacement (base CFL 23W) 2016-2017	2016	2017 sqft	lamp	\$10.90	\$3.77	\$0.00	\$14.67	25,000	1	1	\$14.67	1.00		1.00	1.00	1.00	1 RET
VA Existing	1720 Base CFL 23W to screw-in replacement 2018-2019	2018	2019 sqft	lamp	\$10.00	\$3.77		\$13.77	12,000	1	1	\$13.77	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1721 LED screw-in replacement (base CFL 23W) 2018-2019	2018	2019 sqft	lamp	\$5.00	\$3.77	\$0.00	\$8.77	25,000	1	1	\$8.77	1.00		1.00	1.00	1.00	1 RET
VA Existing	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	2020	2054 sqft 2054 sqft	lamp lamp	\$10.00 \$1.80	\$3.77 \$3.77	\$0.00	\$13.77 \$5.57	12,000 25,000	1	1	\$13.77 \$5.57	1.00		1.00	1.00	1.00	1 ROB 1 RFT
VA Existing	1800 BaseMetal Halide, 465W	2014	2054 sqft	fixture	\$200.00	\$60.00	\$0.00	\$260.00	18	1	1	\$260.00	1.00		1.00	1.00	1.00	1 ROB
VA Existing	1801 T5 (240W) (base metal halide)	2014	2054 sqft	fixture	\$100.00	\$0.00		\$100.00	18	1	1	\$100.00	1.00		1.00	1.00	1.00	1 RET
VA Existing	1802 Induction High Bay Lighting	2014	2054 sqft	fixture	\$480.00	\$60.00		\$540.00	20	1	1	\$540.00	1.00		1.00	1.00	1.00	1 RET
VA Existing	1803 PSMH + electronic ballast 1804 PSMH, magnetic ballast 320 W	2014	2054 sqft 2054 sqft	fixture	\$144.00 \$213.60	\$60.00 \$60.00		\$204.00 \$273.60	16	1	1	\$204.00 \$273.60	1.00		1.00	1.00	1.00	1 RET 1 RET
VA Existing VA Existina	1804 PSMH, magnetic ballast, 320 W 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	2014	2054 sqπ 2054 sqft	nxture saft	\$213.60	\$60.00		\$273.60	15	1	1	\$273.60	0.80		1.00	0.80	1.12	1 REI 1 ROB
VA Existing	1806 Occupancy Sensor, High Bay T5	2014	2054 sqft	fixture	\$55.00			\$55.00	10	1	1	\$55.00	0.25		1.46	0.25	1.46	1 ROB
VA Existing	1850 Base CFL Exit Sign	2014	2054 sqft	unit	\$0.00	\$0.00		\$0.00	18	1	1	\$0.00	1.00		1.00	1.00	1.00	1 RET
VA Existing	1851 LED Exit Sign	2014	2054 sqft	unit	\$25.00	***		\$25.00	7	1	1	\$25.00	1.00		1.00	1.00	1.00	1 RET
VA Existing VA Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	2014 2014	2054 sqft 2054 sqft	fixture fixture	\$0.00 \$51.00	\$0.00 \$57.00		\$0.00 \$108.00	15 18	1	1	\$0.00 \$108.00	1.00		1.00 0.10	1.00 3.31	1.00 0.60	2 ROB 2 RET
VA Existing	1902 LED Outdoor Area Lighting	2014	2054 sqft	fixture	\$400.00	\$57.00	(\$49.81)	\$457.00	60,000	1	1	\$407.19	1.00		1.00	1.00	1.00	2 RET
VA Existing	1903 Bi-Level LED Outdoor Lighting	2014	2054 sqft	fixture	\$1,300.00	\$57.00	(\$49.81)	\$1,357.00	60,000	1	1	\$1,307.19	0.90		1.02	0.90	1.02	2 RET
VA Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	2014	2054 sqft	ton	\$220.00			\$220.00	20	1	1	\$220.00	1.00		1.00	1.00	1.00	3 ROB
VA Existing VA Existing	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2002 Window Film (Standard) - Chiller	2014 2014	2054 sqft 2054 sqft	ton sf-window	\$54.00 \$2.60			\$54.00 \$2.60	20 10	1	1	\$54.00 \$2.60	1.00		1.00 1.00	1.00	1.00	3 ROB 3 RET
VA Existing VA Existing	2002 Window Film (Standard) - Chiller 2003 EMS - Chiller	2014	2054 sqπ 2054 sqft	sr-window ton	\$60.00			\$60.00	10	1	1	\$60.00	0.25		1.00	0.80	1.44	3 RET
VA Existing	2004 Cool Roof - Chiller	2014	2054 sqft	sf-roof	\$0.25			\$0.25	10	1	1	\$0.25	1.00		1.00	1.00	1.00	3 RET
VA Existing	2005 Chiller Tune Up/Diagnostics	2014	2054 sqft	ton	\$17.00			\$17.00	10	1	1	\$17.00	0.50		1.28	0.90	1.28	3 RET
VA Existing	2006 VSD for Chiller Pumps and Towers	2014 2014	2054 sqft	ton	\$32.00	\$10.00	80.00	\$42.00	15	1	1	\$42.00	0.50		1.28	0.90	1.28	3 RET 3 RET
VA Existing VA Existina	2007 EMS Optimization - Chiller 2008 New Economizer - Chiller	2014 2014	2054 sqft 2054 sqft	sqft ton	\$0.00 \$126.76	\$43.34	\$0.06	\$0.00 \$170.10	5 10	1	1	\$0.06 \$170.10	0.25		1.44 1.44	0.80	1.44	3 RET 3 RET
						+ · · · · ·							0.20					
VA Existing	2009 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - Chiller	2014	2054 sqft	unit	\$400.00	\$0.00		\$400.00	10	1	1	\$400.00	0.25		1.44	0.80	1.44	3 RET

A Existing	acure # Measure Description 2011 Ducf/Pipe Insulation - Chillier 2012 DucT Testing/Sealing - Chillier 2013 High Efficiency Chillier Motors 2100 Base DX Packaged System, EER-10 3, 10 tons 2100 Seasong System, EER-10 0, 30 tons 2102 DX Packaged System, EER-10 0, 30 tons 2103 Geothermal Heat Pump, EER-13, 10 tons - DX 2104 DX Cod Cleaning 2105 DX Tune Upf Advanced Diagnostics 2106 Prog. Thermostat - DX 2107 Cod Rod - DX 2107 Cod Rod - DX 2108 Optimize Controls - DX 2109 Economizer - DX 2109 Economizer - DX 2110 Dual Enthally Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Repair - DX 2112 Duct Testing/Sealing - DX 2112 Duct Testing/Sealing - DX 2113 Vindow Fine (Sandard) - DX 2114 Sundry Pope haulation - DX 2115 Vindow Fine (Sandard) - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2300 Base Plan (Seardard) - DX 2302 Cocupancy Sensor (Motor), 6140 2302 Cocupancy Sensor (Motor), 85% 3001 Variable Speed Drive Control, 5 HP 3108 Senardard Controlled Variables 3109 First Motor, 5hp, 1800rpm, 93.5% 3101 First Motor, 5hp, 1800rpm, 94.6% 3102 Variable Speed Drive Control, 15 HP 3104 Electronically Commutated Motors (EM) on an Air Handler Unit 5165 Energy Resoure Volume (EN)	Start Year 201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	्वत् । विकास स्वतः	Cost Units sqft-insulation ton ton ton ton ton ton ton ton ton t	Unit Equipment 5	\$0.00 \$0.00 \$34.00 \$43.34 \$0.00 \$0.00	Lifetime O & M Cost	Cost Factor \$3.08 \$38.00 \$19.49 \$672.40 \$5.08 \$7.40 \$5.00 \$672.40 \$5.00 \$672.40 \$5.00 \$672.40 \$5.00 \$672.40 \$6	Life Co	itial Rep	Full blace Unit Cost Cost Signature Cost Cost Cost Signature Cost	SS S-ON 1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.0	S-MD S	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.00	Type RET - Retrofit d Use ROB - Replace on Burnout 3 RET 3 RET 3 RET 3 ROB 3 ROB 3 ROB 3 ROB 3 RET 3 RET	
A Existing	2011 DuctPipe Insulation - Chiller 2012 Duct Testing/Sealing - Chiller 2013 High Efficiency Chiller Motors 2100 Base DX Packaged System, EER-10.3, 10 tons 2100 DX Packaged System, EER-10.9, 10 tons 2100 DX Packaged System, EER-13.4, 10 tons 2100 DX Packaged System, EER-13.4, 10 tons 2100 DX Packaged System, EER-13.4, 10 tons 2100 DX Cold Cleaning 2105 DX Tune Up/ Advanced Diagnostics 2106 Prog. Thermostat - DX 2107 Cod Rod - DX 2107 Cod Rod - DX 2108 Optimize Controls - DX 2109 Economizer - DX 2109 Economizer - DX 2110 Dual Erhalby Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Repair - DX 2112 Duct Testing/Sealing - DX 2112 Duct Testing/Sealing - DX 2113 Vindow Pine (Sandard) - DX 2114 DuctPipe Insulation - DX 2115 Window Pine (Sandard) - DX 2109 Base Heat Pump (13 SEER, 77 HSPF) 2300 Base Heat Pump (13 SEER, 77 HSPF) 2300 Base PTAC, EER-8.3, 1 ton 2302 Occupancy Sensor (hotels) 3000 Base Fan Motor, Shp. (800pm, 87 5% 3001 Fan Motor, Shp. (800pm, 89 5%) 3002 Variable Speed Drive Control, 5 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization, Communicated Motors (ECM) on an Air Handler Unit	Year 201- 201- 201- 201- 201- 201- 201- 201-	Year 2054 2	Units solt solt solt solt solt solt solt so	Units sqft-insulation ton ton ton ton ton ton ton ton ton t	Cost \$3.08 \$3.8.08 \$3.8.08 \$3.8.08 \$19.49 \$572.40 \$54.78 \$74.30 \$800.00 \$8.77 \$28.00 \$0.25 \$126.76 \$400.00 \$0.12 \$3.08 \$2.60 \$0.00 \$0.00 \$117.00 \$320.00 \$117.00 \$220.00	\$0.00 \$0.00 \$34.00 \$43.34 \$0.00	Cost	\$3.08 (\$3.00 (\$3	Life Ci 10 18 20 15 15 15 15 10 0 8 10 10 10 10 10 10 10 10 10 10 10 10 10	ost C	Cost Cost 1 \$3.08 1 \$3.38.00 1 \$3.38.00 1 \$57.240 1 \$54.78 1 \$74.30 1 \$80.00 1 \$33.00 1 \$28.00 1 \$28.00 1 \$28.00 1 \$28.00 1 \$3	1.00 1.00 1.00 1.00 1.00 1.00 1.00 0.50 0.25 1.00 0.25 0.25 0.25 1.50	S-MD S	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.00	3 RET 3 RET 3 RET 3 ROB 3 ROB 3 ROB 3 ROB 3 RET	
A Existing	2012 Dux Testing/Sealing - Childre 2013 High Efficiency Chillier Motors 2100 Base DV Packaged System, EER-10.3, 10 tons 2101 DX Packaged System, EER-13.4, 10 tons 2101 DX Packaged System, EER-13.4, 10 tons 2103 Geothermal Heat Pump, EER-13, 10 tons - DX 2104 DX Cod Cleaning 2105 DX Tume Upf Advanced Diagnostics 2106 Prog. Thermostat - DX 2107 Cod Roof - DX 2107 Cod Roof - DX 2107 Cod Roof - DX 2108 Opamize Controls - DX 2108 Opamize Controls - DX 2108 Dybarize Controls - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Repair - DX 2112 Ducl Testing/Sealing - DX 2112 Ducl Testing/Sealing - DX 2113 Geilingtoof Insulation - DX 2114 Ducl*Pipe Insulation - DX 2115 Window Time (Sandard) - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2300 Base PTAC, EER-83, 1 ton 2301 He PTAC, EER-83, 1 ton 2301 He PTAC, EER-83, 1 ton 2301 Hear Motor, 5hp, 1800pm, 82-5% 3000 Variable Speed Drive Control, 5 HP 3003 Denand Controlled Variables 3101 Fan Motor, 5hp, 1800pm, 92-5% 3000 Bease Fan Motor, 5hp, 1800pm, 93-5% 3000 Variable Speed Drive Control, 5 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization Communitated Motors (ECM) on an Air Hendler Unit	2014 2017 2017 2017 2017 2017 2017 2017 2017	2054 2054 2054 2054 2054 2054 2054 2054	्वत् । विकास स्वतः	ton	\$338.00 \$19.49 \$672.40 \$54.78 \$74.30 \$800.00 \$8.77 \$28.00 \$0.25 \$126.76 \$400.00 \$900.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$300.00 \$0.00 \$117.00	\$0.00 \$34.00 \$43.34 \$0.00	\$0.04	\$338.00 \$19.49 \$572.40 \$54.78 \$74.30 \$800.00 \$28.00 \$0.25 \$0.00 \$170.10 \$400.00 \$800.00 \$33.00 \$3.00 \$3.00 \$3.00 \$3.00 \$3.00 \$3.00 \$0.00 \$3.00 \$0.00 \$	18 20 15 15 15 15 15 15 15 15 15 15 10 8 10 10 10 5 18 20 10 10	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1 \$338.00 1 \$19.49 1 \$672.40 1 \$57.20 1 \$54.78 1 \$500.00 1 \$8.77 1 \$34.00 1 \$22.00 1 \$0.25 1 \$0.00 1 \$170.10 1 \$400.00 1 \$338.00 1 \$338.00 1 \$338.00 1 \$0.12 1 \$3.00	1.00 1.00 1.00 1.00 1.00 1.00 0.50 0.25 1.00 0.25 0.25 0.25 1.50 1.50		1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.28 1.44 1.00 1.44 1.44 1.20 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.00 1.00 0.90 0.80 0.80 0.80 0.60 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.28 1.44 1.00 1.44 1.44 1.44 0.60 1.00	3 RET 3 RET 3 ROB 3 ROB 3 ROB 3 RET	
A Existing	2013 High Efficiency Chiller Motors 2100 Base DX Packaged System, EER=10.3, 10 tons 2100 DX Packaged System, EER=10.9, 10 tons 2100 DX Packaged System, EER=13.4, 10 tons 2100 DX Packaged System, EER=13.4, 10 tons 2103 Geothermal Heat Pump, EER=13.4, 10 tons 2104 DX Coll Cleaning 2105 DX Ture Up Advanced Diagnostics 2106 Prog. Thermostat - DX 2107 Cod Rod - DX 2107 Cod Rod - DX 2108 Optimize Controls - DX 2109 Economizer - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Cellingfroof Insulation - DX 2112 Dual Testing Regalia - DX 2113 Cellingfroof Insulation - DX 2141 Dual Pep Insulation - DX 2141 Sylmotor Pinc (Sandard) - DX 2200 Base Heat Pump (13 SEER, 7 T HSF) 2300 Base Heat Pump (13 SEER, 5 T HSF) 2300 Base PTAC, EER=8.3, 1 ton 2302 Occupancy Sensor (hotels) 3000 Base Fan Motor, Shp. 1800pm, 87 5% 3001 Fan Motor, Shp. 1800pm, 89 5% 3002 Variabile Speed Drive Control, 5 HP 3103 Aft Handler Optimization, 15 HP 3103 Aft Handler Optimization, 15 HP 3103 Aft Handler Optimization, Communicated Motors (ECM) on an Air Handler Unit	2011 2012 2012 2013 2014 2014 2014 2014 2014 2014 2014 2014	2054 2054 2054 2054 2054 2054 2054 2054	ज्यां ज् ज् ज् ज् ज् ज् ज् ज् ज् ज् ज् ज् ज्	ton	\$19.49 \$672.40 \$54.78 \$74.30 \$80.00 \$8.77 \$28.00 \$0.25 \$126.76 \$400.00 \$0.12 \$3.38 \$2.60 \$0.00 \$0.00 \$117.00 \$280.00	\$0.00 \$34.00 \$43.34 \$0.00	\$0.04	\$19.49 \$672.40 \$54.78 \$74.30 \$800.00 \$28.00 \$28.00 \$0.25 \$0.00 \$170.10 \$400.00 \$800.00 \$3.38.00 \$0.12 \$3.08 \$2.60 \$0.00	20 15 15 15 15 15 10 8 10 5 10 10 10 10 10 10	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1 \$19.49 1 \$672.40 1 \$547.88 1 \$74.30 1 \$800.00 1 \$8.77 1 \$34.00 1 \$28.00 1 \$0.04 1 \$170.10 1 \$400.00 1 \$400.00 1 \$338.00 1 \$338.00 1 \$0.12 1 \$33.88	1.00 1.00 1.00 1.00 1.00 0.50 0.25 1.00 0.25 0.25 0.25 1.50		1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.28 1.44 1.00 1.44 1.44 1.20 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.00 0.90 0.80 1.00 0.80 0.80 0.60 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.00 1.28 1.44 1.00 1.44 1.44 1.44 1.44 0.60 1.00	3 RET 3 ROB 3 ROB 3 ROB 3 RET	
A Existing	2100 Base DX Packaged System, EER-10.3, 10 tons 2101 DX Packaged System, EER-10.3, 10 tons 2102 DX Packaged System, EER-13.4, 10 tons 2103 Geothermal Heat Pump, EER-13, 10 tons - DX 2104 DX Coll Cleaning 2105 DX Tune Upf Advanced Diagnostics 2106 Prog. Thermostat - DX 2107 Cod Rod - DX 2107 Cod Rod - DX 2107 Cod Rod - DX 2108 Optimize Controls - DX 2109 Daul Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2110 Daul Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2110 Daul Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Brajair - DX 2112 Daul Testing/Sealing - DX 2113 Gellingrotof Insulation - DX 2114 Daul Ferling (Sealing) - DX 2115 Window Film (Slandard) - DX 2200 Base Heat Pump (13 SEER, 77 HSPF) 2300 Base Film (Slandard) - DX 2301 Hear Pump (19 SEER, 2 HSPF) 2300 Base Film (Sealing) - SSEER, 2 HSPF) 2300 Base Film (Sealing) - SSEER, 2 HSPF) 2300 Base Film (Sealing) - SSEER, 2 HSPF) 2300 Base Film (Searing) - SSEER, 2 HSPF) 2301 Base Film (Motr., 15hp, 1800rpm, 82 % 2302 Cocupany - Ssear (Institute) 2303 Film Motor, 5hp, 1800rpm, 92 % 2304 Variable Speed Drive Control, 5 HP 2305 Art Handler (Optimization, 15 HP 23103 Art Handler (Optimization) - SHP 23104 Handler (Optimization) - SHP 23104 Handler (Optimization) - SHP 23104 Handler (Optimization) - SHP 23105 Art Handler (Optimization) - SHP 23106 Electronically Commutated Motors (ECM) on an Air Handler Unit	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	ton ton ton ton ton ton ton si-roof sept ton unit ton si-reiling sel-reiling sel-reiling sel-reindow unit unit ton ton ton ton ton ton ton	\$672.40 \$54.78 \$74.30 \$800.00 \$8.77 \$28.00 \$0.25 \$126.76 \$400.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	\$0.00 \$34.00 \$43.34 \$0.00	\$0.04	\$672.40 \$54.78 \$74.30 \$800.00 \$8.77 \$34.00 \$0.25 \$0.00 \$170.10 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	15 15 15 15 10 8 10 5 10 10 5 18 20 10	111111111111111111111111111111111111111	1 \$672.40 1 \$54.78 1 \$74.30 1 \$800.00 1 \$8.77 1 \$34.00 1 \$28.00 1 \$1.0	1.00 1.00 1.00 1.00 0.50 0.25 1.00 0.25 0.25 0.25 1.50 1.00		1.00 1.00 1.00 1.00 1.00 1.00 1.28 1.44 1.00 1.44 1.44 1.20 1.00 1.00	1.00 1.00 1.00 1.00 1.00 0.90 0.80 1.00 0.80 0.80 0.80 0.60 1.00 1.00	1.00 1.00 1.00 1.00 1.00 1.28 1.44 1.00 1.44 1.44 0.60 1.00	3 ROB 3 ROB 3 ROB 3 RET	
A Existing	2101 DX Packaged System, EER=10, 9, 10 tons 2102 DX Packaged System, EER=13, 10 tons 2103 Geothermal Heat Pump, EER=13, 10 tons - DX 2104 DX Coll Cleaning 2105 DX Tune Up Advanced Diagnostics 2106 Prog. Thermostat - DX 2107 Cool Root - DX 2108 Optimize Controls - DX 2108 Optimize Controls - DX 2109 Economizer - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Court Team of Package - DX 2112 Dual Team of Package - DX 2113 Ceiling Tool Insulation - DX 2113 Ceiling Tool Insulation - DX 2114 Dual Perp Insulation - DX 215 Window Film (Slandard) - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2300 Base Heat Pump (13 SEER, 8.2 HSPF) 2308 Base FIA, EER=8.3, 1 ton 2302 Cocupancy Sensor (hotels) 300 Base Fia Motor, Sip., 1800pm, 87.5% 3001 Fain Motor, Sip., 1800pm, 89.5% 3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Versillation 3106 Base Fia Motor, 15p., 1800pm, 99.5% 3107 Fain Motor, 15p., 1800pm, 91.0% 3108 Electronically Commutated Motors (ECM) on an Air Handler Unit	2011 2011 2011 2011 2011 2011 2011 2011	2054 2054 2054 2054 2054 2054 2054 2054	व्यक्तं व्यक्	ton ton ton ton sf-roof sgft ton unit ton sf-window unit ton sf-window unit unit ton ton ton ton	\$74.30 \$800.00 \$8.77 \$28.00 \$0.25 \$126.76 \$400.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$330.00 \$0.00 \$350.00	\$0.00 \$34.00 \$43.34 \$0.00	\$0.04	\$74.30 \$800.00 \$8.77 \$34.00 \$28.00 \$0.25 \$0.00 \$170.10 \$400.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	15 15 10 8 10 5 10 10 5 18 20 10	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1 \$74.30 1 \$800.00 1 \$8.77 1 \$34.00 1 \$28.00 1 \$0.25 1 \$0.04 1 \$170.10 1 \$400.00 1 \$800.00 1 \$338.00 1 \$338.00	1.00 1.00 0.50 0.25 1.00 0.25 0.25 0.25 1.50		1.00 1.00 1.00 1.28 1.44 1.00 1.44 1.44 1.20 1.00 1.00	1.00 1.00 1.00 0.90 0.80 1.00 0.80 0.80 0.60 1.00 1.00	1.00 1.00 1.00 1.28 1.44 1.00 1.44 1.44 0.60 1.00	3 ROB 3 RET	
A Existing	2103 Geothermal Heat Pump, EER-13, 10 tons - DX 2104 DX Cold Cleaming 2105 DX Tune Upf Advanced Diagnostics 2106 Prog. Thermostat - DX 2107 Cod Roxd - DX 2108 Colmition - DX 2108 Colmition - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Repair - DX 2112 Dual Testing/Sealing - DX 2113 Celliagnotin Repair - DX 2114 DuctPepe Insulation - DX 2115 Window Film (Sandard) - DX 2109 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base FIA, EER-8.3, 1 ton 2301 HE PTAC, EER-8.5, 1 ton 2301 HE PTAC, EER-8.5, 1 ton 2301 HE PTAC, EER-8.5, 1 ton 2301 Coupany, Sensor (hotels) 3000 Base Fan Motor, Shp. 1800pm, 82-5% 3000 Variable Speed Drive Control, 5 HP 3003 Denand Controlled Versitation 3100 Base Fan Motor, 15hp, 1800pm, 92-5% 3001 Command Controlled Versitation 3100 Base Fan Motor, 15hp, 1800pm, 92-5% 3101 Fan Motor, 5hp, 1800pm, 92-5%	2011 2012 2014 2014 2014 2014 2014 2014	2054 2054 2054 2054 2054 2054 2054 2054	sqt sqt sqt sqt sqt sqt sqt sqt sqt sqt	ton ton ton ton servor sept ton unit ton servor sept ton unit ton servor sept ton servor serv	\$800.00 \$8.77 \$28.00 \$0.25 \$126.76 \$400.00 \$800.00 \$3.08 \$2.60 \$0.00 \$930.00 \$117.00 \$280.00	\$34.00 \$43.34 \$0.00	\$0.04	\$800.00 \$8.77 \$34.00 \$28.00 \$0.25 \$0.00 \$170.10 \$400.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	15 10 8 10 5 10 10 5 18 20 10 10 10	1	1 \$800.00 1 \$8.77 1 \$34.00 1 \$28.00 1 \$0.25 1 \$0.04 1 \$170.10 1 \$400.00 1 \$800.00 1 \$338.00 1 \$338.00 1 \$3.012 1 \$3.08	1.00 1.00 0.50 0.25 1.00 0.25 0.25 0.25 1.50 1.00		1.00 1.00 1.28 1.44 1.00 1.44 1.44 1.20 1.00 1.00	1.00 1.00 0.90 0.80 1.00 0.80 0.80 0.60 1.00 1.00	1.00 1.28 1.44 1.00 1.44 1.44 1.44 0.60 1.00	3 RET 3 RET 3 RET 5 RET	
A Existing	2104 DX Coll Cleaning 2105 DX Tune Up/ Advanced Diagnosics 2106 Ptog. Thermostat - DX 2107 Cool Roof - DX 2108 Cool Roof - DX 2108 Cool Roof - DX 2109 Economizer - DX 2109 Economizer - DX 2109 Economizer - DX 2109 Economizer - DX 2110 Dual Enthalty Economizer Replaces Dry Bulb Economizer - DX 2111 Couling Flow - DX 2111 Couling Flow - DX 2112 Dual Testing Sealing - DX 2113 Celling Tool Insulation - DX 2114 Dual Pipe Insulation - DX 2115 Window Pine (Sandard) - DX 2109 Base Heat Pump (13 SEER, 77 HSPF) 2200 Base Heat Pump (13 SEER, 77 HSPF) 2300 Base PTAC, EER=8, 3, 1 ton 2302 Cocupancy Sensor (hotels) 3000 Base Flow - DA (15 SEER) 3109 Sensor - Controlled Verification 3100 Base Flow - DA (15 SEER) 3103 Air Handler (Dortmizmon, 15 HP) 3103 Air Handler Optimizmon, 15 HP 3103 Air Handler Optimizmon, 15 HP 3103 Air Handler Optimizmon, 15 HP	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqtt sqtt sqtt sqtt sqtt sqtt sqtt sqtt	ton ton sf-roof sqft ton unit ton sf-roifing sqft-insulation sf-window unit unit ton ton ton ton	\$8.77 \$28.00 \$0.25 \$126.76 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$930.00 \$117.00 \$280.00	\$43.34 \$0.00	\$0.04	\$8.77 \$34.00 \$28.00 \$0.25 \$0.00 \$170.10 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	10 8 10 5 10 10 5 18 20 10	1 1 1 1 1 1 1 1 1 1 1 1	1 \$8.77 1 \$34.00 1 \$28.00 1 \$0.25 1 \$0.04 1 \$170.10 1 \$400.00 1 \$338.00 1 \$0.12 1 \$3.08	1.00 0.50 0.25 1.00 0.25 0.25 0.25 1.50 1.00		1.00 1.28 1.44 1.00 1.44 1.44 1.44 1.20 1.00 1.00	1.00 0.90 0.80 1.00 0.80 0.80 0.80 0.60 1.00 1.00	1.00 1.28 1.44 1.00 1.44 1.44 0.60 1.00	3 RET 3 RET 3 RET 3 RET 3 RET 3 RET 3 RET 3 RET 3 RET 3 RET	
A Existing	2105 DX Tune Up/ Advanced Diagnostics 2106 Prog. Thermostat - DX 2107 Cod Rox! - DX 2108 Opimize Controls - DX 2108 Opimize Controls - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Repair - DX 2112 Dual Testing/Sealing - DX 2113 Cellagroof Insulation - DX 2114 DuctPipe Insulation - DX 2114 DuctPipe Insulation - DX 2115 Window Film (Sandard) - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base FIAC, EER-8.3, 1 ton 2301 HE PTAC, EER-8.3, 1 ton 2301 HE PTAC, EER-8.3, 1 ton 2301 Coupany, Sensor (Instal) 3000 Base Fan Motor, Shp. 1800pm, 87.5% 3000 Yanábié Speed Drive Control, 5 HP 3003 Denand Controlled Versillation 3100 Base Fan Motor, 15hp, 1800pm, 92.9% 3001 Pan Motor, Shp. 1800pm, 92.9% 3101 Fan Motor, Shp. 1800pm, 92.9% 3102 Variable Speed Drive Control, 15 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization Commutated Motors (ECM) on an Air Handler Unit	201 201 201 201 201 201 201 201 201 201	2054 2054 2054 2054 2054 2054 2054 2054	sqtt sqtt sqtt sqtt sqtt sqtt sqtt sqtt	ton ton ton si-roof sqft ton unit unit ton sf-ceiling sqft-insulation sf-window unit unit ton ton ton	\$28.00 \$0.25 \$126.76 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$930.00 \$117.00 \$280.00	\$43.34 \$0.00	\$0.04	\$34.00 \$28.00 \$0.25 \$0.00 \$170.10 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	8 10 5 10 10 5 18 20 10	1 1 1 1 1 1 1 1 1 1	1 \$34.00 1 \$28.00 1 \$0.25 1 \$0.04 1 \$170.10 1 \$400.00 1 \$338.00 1 \$338.00 1 \$3.08	0.50 0.25 1.00 0.25 0.25 0.25 1.50 1.00		1.28 1.44 1.00 1.44 1.44 1.20 1.00 1.00	0.90 0.80 1.00 0.80 0.80 0.80 0.60 1.00 1.00	1.28 1.44 1.00 1.44 1.44 1.44 0.60 1.00	3 RET	
A Existing	2106 Prog. Thermostat - DX 2107 Cool Rod - DX 2108 Optimize Controls - DX 2109 Economizer - DX 2109 Economizer - DX 2109 Economizer Repair - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Ceconomizer Repair - DX 2112 Dual Testing/Sealing - DX 2113 Celling/tool Insulation - DX 2113 Celling/tool Insulation - DX 2114 Dual/Pop Insulation - DX 2115 Window Fine (Sandardy - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2300 Base Heat Pump (13 SEER, 7.8 HSPF) 2300 Base PTAC, EER-8.3, 1 ton 2302 Cocupancy Sensor (hotels) 3000 Base Fan Motor, Shp. 1800pm, 87.5% 3001 Fan Motor, Shp. 1800pm, 89.5% 3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Vernillation 3108 Base Fan Motor, Shp. 1800pm, 91.0% 3107 Fan Motor, Shp. 1800pm, 91.0% 3107 Fan Motor, Shp. 1800pm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization, 15 HP	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	saft saft saft saft saft saft saft saft	soft ton si-roof sqft ton unit unit ton sf-ceiling sqft-insulation sf-window unit unit ton ton ton ton	\$0.25 \$126.76 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$930.00 \$117.00 \$280.00	\$43.34 \$0.00	\$0.04	\$28.00 \$0.25 \$0.00 \$170.10 \$400.00 \$800.00 \$3.12 \$3.08 \$2.60 \$0.00	8 10 5 10 10 5 18 20 10	1 1 1 1 1 1 1 1	1 \$28.00 1 \$0.25 1 \$0.04 1 \$170.10 1 \$400.00 1 \$338.00 1 \$0.12 1 \$3.08	0.25 1.00 0.25 0.25 0.25 1.50 1.00		1.44 1.00 1.44 1.44 1.20 1.00 1.00	0.80 1.00 0.80 0.80 0.80 0.60 1.00 1.00	1.44 1.00 1.44 1.44 1.44 0.60 1.00	3 RET 3 RET 3 RET 3 RET 3 RET 3 RET 3 RET	
A Existing	2108 Optimize Controls - DX 2109 Economizer Controls - DX 2109 Economizer Replaces Dry Bulb Economizer - DX 2111 Court Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Court Teating Plasming - DX 2113 Coeffing Food Insulation - DX 2113 Ceiling Food Insulation - DX 2114 DucPipe Insulation - DX 2115 Window Film (Slandard) - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2300 Base Food Pupparide (15 SEER, 8.2 HSPF) 2300 Base Food Pupparide (15 SEER, 8.2 HSPF) 2300 Base Food SEER-8.6., 1 ton 2302 Cocupancy Sensor Rotells) 3000 Base Food Mort, Sfep, 1800pm, 87.5% 3001 Food Mort, Sfep, 1800pm, 89.5% 3001 Parishbit Speed Drive Control, S HP 3003 Demand Controlled Ventilation 3100 Base Food Notrolled Ventilation 3100 Base Food Controlled Ventilation 3100 Base Food Controlled Ventilation 3100 Base Food Controlled Ventilation 3100 Base Food Pupper Sensor Rotells 3102 Variable Speed Drive Control, 15 HP 3103 Art Handler Optimization, 15 HP	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqtt sqtt sqtt sqtt sqtt sqtt sqtt sqtt	sqft ton unit unit ton sf-ceiling sqft-insulation sf-window unit ton ton HP	\$126.76 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$930.00 \$0.00 \$117.00 \$280.00	\$0.00 \$0.00	\$0.04	\$0.00 \$170.10 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	5 10 10 5 18 20 10 10 10	1 1 1 1 1 1 1 1	1 \$0.04 1 \$170.10 1 \$400.00 1 \$800.00 1 \$338.00 1 \$0.12 1 \$3.08	0.25 0.25 0.25 1.50 1.00		1.44 1.44 1.44 1.20 1.00 1.00	0.80 0.80 0.80 0.60 1.00 1.00	1.44 1.44 1.44 0.60 1.00	3 RET 3 RET 3 RET 3 RET 3 RET	
A Existing	2109 Economizer - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Repair - DX 2112 Dual Testing/Sealing - DX 2112 Dual Testing/Sealing - DX 2113 Cellingrotor Insulation - DX 2114 Duc/Pipe Insulation - DX 2114 Duc/Pipe Insulation - DX 2115 Window Film (Slandard) - DX 2200 Base Heat Pump (13 SEER, 77 HSPF) 2200 Base Heat Pump (13 SEER, 77 HSPF) 2301 Heat Pump Upgrade (15 SEER, 82 HSPF) 2302 Base PTAC, EER=8.3, 1 ton 2301 HE PTAC, EER=8.5, 1 ton 2301 Hear Pump, Seasor (Insulation) 2302 Cocupany, Seasor (Insulation) 3000 Base Fan Motor, 5thp, 1800rpm, 82 % 3000 Variable Speed Drive Control, 5 HP 3103 Art Handler Controlled Variables 3109 Base Fan Motor, 15thp, 1800rpm, 92 .4% 3101 Fan Motor, 15thp, 1800rpm, 92 .4% 3102 Variable Speed Drive Control, 5 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization, 15 HP	2014 2017 2017 2019 2019 2019 2019 2019 2019 2019 2019	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	ton unit unit ton sf-ceiling sqft-insulation st-window unit ton ton ton HP	\$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$930.00 \$117.00 \$280.00	\$0.00 \$0.00	\$0.04	\$170.10 \$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	10 10 5 18 20 10	1 1 1 1 1 1 1	1 \$170.10 1 \$400.00 1 \$800.00 1 \$338.00 1 \$0.12 1 \$3.08	0.25 0.25 1.50 1.00		1.44 1.44 1.20 1.00 1.00	0.80 0.80 0.60 1.00 1.00	1.44 1.44 0.60 1.00	3 RET 3 RET 3 RET 3 RET	
A Existing	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Repair - DX 2112 DucT Testing Sealing - DX 2113 Colling Sealing - DX 2113 Colling Sealing - DX 2113 Vinidow Film (Slandard) - DX 2115 Vinidow Film (Slandard) - DX 2115 Vinidow Film (Slandard) - DX 2105 Base Heat Pump (13 SEER, 7.7 HSPF) 2200 Base Heat Pump (13 SEER, 8.2 HSPF) 2300 Base Film (Slendard) - DX 2300 Cocupancy Sensor (Bottle) 2300 Cocupancy Sensor (Bottle) 2300 Cocupancy Sensor (Bottle) 2300 Base Film Motor, Shp. 1800pm, 89.5% 3001 Fan Motor, Shp. 1800pm, 89.5% 3002 Variable Speed Drive Control, S HP 3003 Demand Cortrolled Versillation 3100 Base Fan Motor, 15hp. 1800pm, 91.0% 3101 Fan Motor, 15hp. 1800pm, 91.24% 3102 Variable Speed Drive Control, 15 HP 3103 Air Handler Optimization, 15 HP 3103 Air Handler Optimization, 15 HP	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	unit unit ton sf-ceiling sqft-insulation sf-window unit ton ton HP	\$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$930.00 \$117.00 \$280.00	\$0.00 \$0.00		\$400.00 \$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	10 5 18 20 10	1 1 1 1 1 1	1 \$400.00 1 \$800.00 1 \$338.00 1 \$0.12 1 \$3.08	0.25 1.50 1.00 1.00		1.44 1.20 1.00 1.00 1.00	0.80 0.60 1.00 1.00	1.44 0.60 1.00 1.00	3 RET 3 RET 3 RET	
A Existing	2111 Economizar Repair - DX 2112 Duct Testing/Sealing - DX 2113 Celling/Sealing - DX 2114 Duct/Pep Insulation - DX 2114 Duct/Pep Insulation - DX 2115 Window Fine (Standard) - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2300 Base PTAC, EER-8.3, 1 ton 2301 Her PTAC, EER-8.3, 1 ton 2301 Her PTAC, EER-8.6, 1 ton 2302 Cocupancy Sensor (hotels) 3000 Base Fan Motor, Shp. 1800pm, 87.5% 3000 Fan Motor, Shp. 1800pm, 89.5% 3002 Variable Speed Drive Control, 5 HP 3103 Air Handler (Controlled Ventilation) 3106 Base Fan Motor, 15hp, 1800pm, 91.9% 3107 Fan Motor, 15hp, 1800pm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Air Handler Optimization, 15 HP 3103 Air Handler Optimization, 15 HP	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	unit ton sf-ceiling sqft-insulation sf-window unit unit ton ton ton	\$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00 \$930.00 \$117.00 \$280.00	\$0.00		\$800.00 \$338.00 \$0.12 \$3.08 \$2.60 \$0.00	5 18 20 10	1 1 1 1 1	1 \$800.00 1 \$338.00 1 \$0.12 1 \$3.08	1.50 1.00 1.00		1.20 1.00 1.00 1.00	0.60 1.00 1.00 1.00	0.60 1.00 1.00	3 RET 3 RET	
A Existing	2112 Duct Testing/Gealing - DX 2113 Cellingtord Insulation - DX 2114 DuctPipe Insulation - DX 2115 Window Film (Slandard) - DX 2115 Window Film (Slandard) - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2200 Base FILD, EER-8.3, 1 ton 2301 HE PTAC, EER-8.3, 1 ton 2301 HE PTAC, EER-8.3, 1 ton 2302 Occupany, Sensor (Instell) 3000 Base Fan Motor, 51p, 1800pm, 87.5% 3000 Yanáble Speed Drive Control, 5 HP 3003 Denand Controlled Versillation 3100 Base Fan Motor, 15tp, 1800pm, 91.0% 3101 Fan Motor, 15tp, 1800pm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Art Handler (Optimization, 15 HP 3103 Art Handler Optimization, 15 HP	2011 2014 2014 2014 2010 2010 2010 2010	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	sf-ceiling sqft-insulation sf-window unit unit ton ton ton	\$0.12 \$3.08 \$2.60 \$0.00 \$930.00 \$0.00 \$117.00 \$280.00			\$0.12 \$3.08 \$2.60 \$0.00	20 10 10	1 1 1	1 \$0.12 1 \$3.08	1.00		1.00 1.00 1.00	1.00	1.00		
A Existing	2114 DuctPipe Insulation - DX 2115 Window Film (Slandard) - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2200 Heat PLA, EER-8.3, 1 ton 2301 HE PTAC, EER-8.3, 1 ton 2301 HE PTAC, EER-8.3, 1 ton 2302 Occupany, Sensor (Instell) 3000 Base Fan Motor, 5Fp, 1800pm, 87.5% 3000 Fan Motor, 5Fp, 1800pm, 89.5% 3000 Variable Speed Drive Control, 5 HP 3003 Denand Controlled Variablision 3100 Base Fan Motor, 15Pp, 1800pm, 91.0% 3101 Fan Motor, 15Pp, 1800pm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization, 15 HP	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	sqft-insulation sf-window unit unit ton ton ton	\$3.08 \$2.60 \$0.00 \$930.00 \$0.00 \$117.00 \$280.00			\$3.08 \$2.60 \$0.00	10 10	1 1 1	1 \$3.08			1.00	1.00		3 RET	
A Existing	2115 Window Flint (Slandard) - DX 200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump (19 SEER, 8.2 HSPF) 2300 Base PTAC, EER-8.3, 1 ton 2302 Cocupancy Sensor (hotels) 2302 Cocupancy Sensor (hotels) 2302 Cocupancy Sensor (hotels) 3000 Base Fan Motor, Shp. 1800pm, 89.5% 3001 Fan Motor, Shp. 1800pm, 89.5% 3002 Variable Speed Drive Control, S HP 3003 Demand Cortrolled Vertillation 3100 Base Fan Motor, 15hp, 1800pm, 91.0% 3101 Fan Motor, 15hp, 1800pm, 91.24% 3102 Variable Speed Drive Control, 15 HP 3103 Air Handler Optimization, 15 HP 3103 Air Handler Optimization, 15 HP	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	sf-window unit unit ton ton ton	\$2.60 \$0.00 \$930.00 \$0.00 \$117.00 \$280.00			\$2.60 \$0.00	10	1		1.00						
A Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER-8.3, 1 ton 2301 HE PTAC, EER-8.3, 1 ton 2301 HE PTAC, EER-8.3, 1 ton 2302 Occupany, Sensor floxtels) 3000 Base Fan Motor, Shp. 1800rpm, 87.5% 3001 Fan Motor, Shp. 1800rpm, 89.5% 3001 Fan Motor, Shp. 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP 3103 Art Motor, 15hp, 1800rpm, 91.0% 3101 Fan Motor, 15hp, 1800rpm, 92.4% 3101 Fan Motor, 15hp, 1800rpm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization, 15 HP	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	unit unit ton ton ton HP	\$0.00 \$930.00 \$0.00 \$117.00 \$280.00			\$0.00		1						1.00	3 RET	
A Existing	2201 Heat Pump Uppmade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton 2301 HE PTAC, EER=8.5, 1 ton 2302 Cocupancy Sensor (hotels) 3000 Base Fan Motor, 5hp, 1800pm, 87.5% 3001 Fan Motor, 5hp, 1800pm, 89.5% 3001 Fan Motor, 5hp, 1800pm, 89.5% 3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Venilation 3100 Base Fan Motor, 15hp, 1800pm, 91.0% 3101 Fan Motor, 15hp, 1800pm, 91.0% 3101 Fan Motor, 15hp, 1800pm, 15hp, 1800pm, 91.0% 3101 Fan Motor, 15hp, 1800pm, 15hp, 1800pm, 91.0% 3101 Fan Motor, 15hp, 1800pm, 15hp, 1800pm, 91.0% 3104 Fan Motor, 15hp, 1800pm, 91.0% 3105 Fan Motor, 15hp, 1800pm, 91.0% 3106 Fan Motor, 15hp, 1800pm, 91.0% 3107 Fan Motor, 15hp, 1800pm, 91.0%	201- 201- 201- 201- 201- 201- 201- 201-	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft sqft	unit ton ton ton HP	\$930.00 \$0.00 \$117.00 \$280.00					1	1 \$2.60 1 \$0.00	1.00		1.00	1.00	1.00	3 REI 3 ROB	
A Existing	2301 HE PTAC, EER=9.6, 1 ton 2302 Cooppany Sensor (hotels) 300 Base Fan Motor, Shp. 1800pm, 87.5% 3001 Fan Motor, Shp. 1800pm, 89.5% 3001 Fan Motor, Shp. 1800pm, 89.5% 3002 Variabble Speed Drive Control, 5 HP 3003 Demand Controlled Vernilation 3100 Base Fan Motor, 15hp, 1800pm, 91.0% 3101 Fan Motor, 15hp, 1800pm, 91.0% 3101 Fan Motor, 15hp, 1800pm, 15hp, 1800pm, 91.0% 3101 Avinable Speed Drive Control, 15 HP 3103 Air Handler Optimization, 15 HP 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	2014 2017 2017 2017 2017 2017 2017 2017 2017	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft sqft sqft	ton ton HP	\$117.00 \$280.00	\$0.00		\$930.00	15	1	1 \$930.00	1.00		1.00	1.00	1.00	3 ROB	
A Existing	2302 Occupancy Sensor (hotels) 3000 Base Fan Motor, Shp. 1800pm, 87.5% 3001 Fan Motor, Shp. 1800pm, 89.5% 3002 Variable Speed Drive Control, S HP 3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp. 1800pm, 91.0% 3101 Fan Motor, 15hp. 1800pm, 91.0% 3101 Fan Motor, 15hp. 1800pm, 91.0% 3102 Variable Speed Drive Control, 15 HP 3103 Art Handler Optimization, 15 HP	2014 2014 2014 2014 2014 2014 2014 2014	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft sqft	ton HP	\$280.00			\$0.00	15	1	1 \$0.00	1.00		1.00	1.00	1.00	3 ROB	
A Existing	3000 Base Fan Motor, Shp. 1800rpm, 87.5% 3001 Fan Motor, Shp. 1800rpm, 89.5% 3001 Variable Speed Drive Control, St PP 3003 Demand Controlled Vantilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3101 Fan Motor, 15hp, 1800rpm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Air Handler Optimization, 15 HP 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	2014 2014 2014 2014 2014 2014 2014 2014	2054 2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft sqft	HP				\$117.00	15	1	1 \$117.00	1.00		1.00	1.00	1.00	3 ROB	
A Existing	3001 Fan Motor, Shp. 1800/pm, 89.5% 3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800/pm, 91.0% 3101 Fan Motor, 15hp, 1800/pm, 22.4% 3102 Variable Speed Drive Control, 15 HP 3103 Air Handler Optimization, 15 HP 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	2014 2014 2014 2014 2014 2014 2014 2014	2054 2054 2054 2054 2054 2054 2054	sqft sqft sqft		\$52.00			\$280.00 \$52.00	10	1	1 \$280.00 1 \$52.00	1.30		0.78	1.30	0.78	3 RET 4 ROB	
A Existing	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3101 Fan Motor, 15hp, 1800rpm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Air Handler Cybinizzation, 15 HP 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	2014 2014 2014 2014 2014 2014	2054 2054 2054 2054 2054	sqft sqft		\$52.00 \$43.00			\$52.00 \$43.00	20	1	1 \$52.00	1.00		1.00	1.00	1.00	4 ROB 4 ROB	
A Existing	3100 Base Fan Motor, 15hp, 1800/pm, 91.0% 3101 Fan Motor, 15hp, 1800/pm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Art Handler Optimization, 15 HP 3103 Art Handler Optimization, 15 HP	2014 2014 2014 2014	2054 2054 2054		HP	\$214.00	\$171.00		\$385.00	15	1	1 \$385.00	0.25		1.21	0.90	1.21	4 RET	
A Existing	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3102 Variable Speed Drive Control, 15 HP 3103 Air Handler Optimization, 15 HP 3104 Electrorically Commutated Motors (ECM) on an Air Handler Unit	2014 2014 2014	2054 2054		sqft	\$0.33		\$2.03	\$0.33	15	1	1 \$2.36	1.90		0.52	1.50	0.70	4 RET	
AE Existing	3102 Variable Speed Drive Control, 15 HP 3103 Air Handler Optimization, 15 HP 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	2014 2014	2054		HP	\$43.00			\$43.00	20	1	1 \$43.00	1.00		1.00	1.00	1.00	4 ROB	
A Existing	3103 Air Handler Optimization, 15 HP 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	2014			HP HP	\$29.00 \$129.00	6400.00		\$29.00 \$231.00	20 15	1	1 \$29.00 1 \$231.00	1.00 0.25		1.00	1.00	1.00	4 ROB 4 RET	
A Existing	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit		2054		sqft	\$0.00	\$102.00	\$0.03	\$0.00	8	1	1 \$0.03	0.25		1.21	0.90	1.21	4 RET	
A Existing	3105 Energy Recovery Ventilation (ERV)	201			ton	\$27.76			\$27.76	15	1	1 \$27.76	0.90		1.05	0.90	1.05	4 ROB	
A Existing		2014			ton	\$130.95			\$130.95	20	1	1 \$130.95	1.90		0.52	1.50	0.70	4 RET	
A Existing	3106 Separate Makeup Air / Exhaust Hoods AC 3107 Demand Controlled Ventilation	2014			HP	\$3.00			\$3.00	15	1	1 \$3.00 1 \$2.36	1.00 1.90		1.00	1.00	1.00	4 RET 4 RET	
A Existing	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	2014			sqft HP	\$0.33 \$37.00		\$2.03	\$0.33 \$37.00	15 20	1	1 \$2.36 1 \$37.00	1.90		0.52 1.00	1.50	0.70 1.00	4 REI 4 ROB	
/A Existing	3201 Fan Motor, 40hp, 1800rpm, 94.1%	2014			HP	\$23.00			\$23.00	20	1	1 \$23.00	1.00		1.00	1.00	1.00	4 ROB	
A Existing	3202 Variable Speed Drive Control, 40 HP	2014			HP	\$120.00	\$37.00		\$157.00	15	1	1 \$157.00	0.25		1.21	0.90	1.21	4 RET	
A Existing	3203 Air Handler Optimization, 40 HP	2014			sqft	\$0.00		\$0.03	\$0.00	8	1	1 \$0.03	0.25		1.21	0.90	1.21	4 RET	
/A Existing	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	2014			sqft 40.000 sqft store	\$0.33 \$0.00	\$0.00	\$2.03	\$0.33 \$0.00	15	1	1 \$2.36 1 \$0.00	1.90 1.00		0.52 1.00	1.50	0.70 1.00	4 RET 5 ROB	
A Existing	4000 Base Bull-Op Reingeration System 4001 High-efficiency fan motors	2014			40,000 sqft store 40,000 sqft store	\$46,429.20	\$0.00		\$46,429,20	20	1	1 \$46.429.20	1.00		1.00	1.00	1.00	5 RET	
/A Existing	4002 Strip curtains for walk-ins (built-up)	2014			40,000 sqft store	\$1,995.00	\$0.00		\$1,995.00	4	1	1 \$1,995.00	1.00		1.00	1.00	1.00	5 RET	
A Existing	4003 Auto-closer on main door to walk-in freezer (built-up)	2014			unit	\$150.00			\$150.00	8	1	1 \$150.00	1.00		1.00	1.00	1.00	5 RET	
/A Existing	4004 Night covers for display cases	2014			linear ft. display	\$9.25	\$0.00		\$9.25	5	1	1 \$9.25	0.50		1.11	0.90	1.11	5 RET	
/A Existing	4005 Evaporator fan controller for MT walk-ins 4006 Electronically commutated evaporator fan motor	2014			controller motor	\$1,050.00 \$50.00	\$0.00		\$1,050.00 \$50.00	16 15	1	1 \$1,050.00 1 \$50.00	0.50 1.00		1.11	0.90	1.11	5 RET 5 RET	
/A Existing /A Existing /A Existing /A Existing /A Existing /A Existing	4007 Efficient compressor motor	2014			40,000 sqft store	\$3,510.00	\$0.00		\$3,510.00	10	1	1 \$3,510.00	1.00		1.00	1.00	1.00	5 ROB	
/A Existing /A Existing /A Existing /A Existing /A Existing	4008 Compressor VSD retrofit	2014	2054	sqft	40,000 sqft store	\$16,200.00	\$0.00		\$16,200.00	13	1	1 \$16,200.00	0.50		1.11	0.90	1.11	5 RET	
/A Existing /A Existing /A Existing	4009 Floating head pressure controls	2014			40,000 sqft store	\$4,995.00	\$0.00		\$4,995.00	14	1	1 \$4,995.00	0.50		1.11	0.90	1.11	5 RET	
/A Existing /A Existing	4010 Refrigeration Commissioning 4011 Demand Hot Gas Defrost	2014 2014			Ton of Load	\$113.00 \$25.00	\$0.00 \$0.00		\$113.00 \$25.00	10	1	1 \$113.00 1 \$25.00	1.00		1.00	1.00	1.00	5 RET 5 RET	
	4012 Demand Defrost Electric	2014			HP	\$25.00	\$0.00		\$25.00	10	1	1 \$25.00	1.00		1.00	1.00	1.00	5 RET	
/A Friedra	4013 Anti-sweat (humidistat) controls	2014			40,000 sqft store	\$6,500.00	\$0.00		\$6,500.00	12	1	1 \$6,500.00	0.50		1.11	0.90	1.11	5 RET	
	4014 Freezer-Cooler Replacement Gaskets	2014			lin ft doors	\$8.00	\$0.00		\$8.00	4	1	1 \$8.00	1.00		1.00	1.00	1.00	5 RET	
/A Existing	4015 High R-Value Glass Doors	2014			lin ft glass doors	\$100.28	\$0.00		\$100.28	10	1	1 \$100.28	1.00		1.00	1.00	1.00	5 RET	
/A Existing /A Existina	4016 LED Display Lighting 4017 Multiplex Compressor System	2014			lin ft glass doors tons	\$100.00 \$1.750.00	\$0.00 \$0.00		\$100.00 \$1.750.00	8 14	1	1 \$100.00 1 \$1.750.00	1.00		1.00	1.00	1.00	5 RET 5 RET	
/A Existing	4018 Oversized Air Cooled Condenser	2014			tons	\$350.00	\$0.00		\$350.00	16	1	1 \$350.00	1.00		1.00	1.00	1.00	5 RET	
/A Existing	4019 Insulated suction lines	2014			ft. of suction line	\$6.00	\$0.00		\$6.00	11	1	1 \$6.00	1.00		1.00	1.00	1.00	5 RET	
	4100 Base Self-Contained Refrigeration	2014			refrigerator	\$0.00	\$0.00		\$0.00	10	1	1 \$0.00	1.00		1.00	1.00	1.00	5 ROB	
/A Existing	4101 Strip curtains for walk-ins (self-contained)	2014			sq. ft. doorway	\$22.00			\$22.00	4	1	1 \$22.00	1.00		1.00	1.00	1.00	5 RET	
/A Existing /A Existing		2014 2014			unit lin. ft. cover	\$150.00 \$42.00			\$150.00 \$42.00	5	1	1 \$150.00 1 \$42.00	1.00		1.00	1.00	1.00	5 RET 5 RET	
	4102 Auto-closer on main door to walk-in freezer (self-contained)	2014			lin ft doors	\$8.00	\$0.00		\$8.00	4	1	1 \$8.00	1.00		1.00	1.00	1.00	5 RET	
		2014			lin ft glass doors	\$100.00	\$0.00		\$100.00	8	1	1 \$100.00	1.00		1.00	1.00	1.00	5 RET	
	4102 Auto-closer on main door to walk-in freezer (self-contained) 4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Gaskets (self-contained) 4105 El-level LED Case Lighting (self-contained units) 2014	2014			unit	\$164.00	\$0.00		\$164.00	10	1	1 \$164.00	1.00		1.00	1.00	1.00	5 ROB	
/A Existing /A Existing	4 102. Auto-closer on main door to walk-in freezer (self-contained) 4 103 Night covers for display cases (self-contained) 4 104 Freezer-Cooler Replacement Gaskets (self-contained) 4 105 Belved LED Case Lighting (self-contained units) 2014 4 105 Energy Star Refrigerator, solid door	2014			unit unit	\$166.00 \$164.00	\$0.00 \$0.00		\$166.00 \$164.00	9	1	1 \$166.00 1 \$164.00	1.00 1.00		1.00	1.00	1.00	5 ROB 5 ROB	
	4102 Auto-closer on main door to walk-in freezer (self-contained) 4103 Night covers for display cases (self-contained) 4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Claskets (self-contained) 4105 Elevert LED Case Lighting (self-contained units) 2014 4106 Energy-Star Freezer, solid door 4107 Energy-Star Freezer, solid door				unit	\$164.00 \$166.00	\$0.00		\$164.00 \$166.00	9	1	1 \$164.00 1 \$166.00	1.00		1.00	1.00	1.00	5 ROB 5 ROB	
	4 102. Auto-closer on main door to walk-in freezer (self-contained) 4103. Night covers for display cases (self-contained) 4104. Freezer-Cooler Replacement Gaskets (self-contained) 4105. Belved LED Case Lighting (self-contained units) 2014 4105. Energy-Star Refrigerator, solid door 4107. Energy-Star Freezer, solid door 4107. Energy-Star Refrigerator, solid soor	2014			unit	\$312.00	\$0.00		\$312.00	10	1	1 \$312.00	1.00		1.00	1.00	1.00	5 RET	
	4102 Auto-closer on main door to walk-in freezer (self-contained) 4103 Night covers for display cases (self-contained) 4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Claskets (self-contained) 4105 Elevert LED Case Lighting (self-contained units) 2014 4106 Energy-Star Freezer, solid door 4107 Energy-Star Freezer, solid door	2014			unit	\$85.00	\$36.82		\$121.82	8	1	1 \$121.82	1.00		1.00	1.00	1.00	5 RET	
	4102 Auto-closer on main door to walk-in freezer (self-contained) 4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Classkets (self-contained) 4105 Belwel LED Case Lighting (self-contained units) 2014 4105 Energy-Star Refringerator, solid door 4107 Energy-Star Freezer, solid door 4108 Energy-Star Freezer, solid door	2014 2014			unit	\$68.00	\$0.00		\$68.00	10	1	1 \$68.00	1.00		1.00	1.00	1.00	5 RET	
/A Existing /A Existing	4102 Auto-closer on main door to walk-in freezer (self-contained) 4103 Night covers for display cases (self-contained) 4104 Freezzer-Cooler Replacement Classkets (self-contained) 4105 Elevel LED Case Lighting (self-contained units) 2014 4106 Energy-Star Freezzer, solid door 4107 Energy-Star Freezzer, solid door 4108 Energy-Star Freezzer, solid door 4108 Energy-Star Freezzer, solid door 4108 Energy-Star Freezzer, solid door 4106 Energy-Star Freezzer, solid door 4110 Energy-Star Freezzer, slow door 4110 Energy-Star Freezzer, slow door 4110 Energy Star Lee Machines 4111 Hydraulii-type door closer on reach-in cooler glass doors 4111 Reach-in unit occupancy sensors	2014 2014 2014 2014 2014	2054	sqft	PC PC	\$0.00 \$0.00	\$0.00 \$20.00		\$0.00						1.00	1.00	1.00	6 RET	
/A Existing /A Existing	4102 Auth-closer on main door to walk-in freezer (self-contained) 4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Glaskets (self-contained) 4105 Bi-level LED Case Lighting (self-contained units) 2014 4105 Energy-Star Refrigerator, Self-contained units) 2014 4107 Energy-Star Freezer, solid door 4107 Energy-Star Freezer, solid door 4109 Energy-Star Freezer, glass door 4109 Energy-Star Les Machines 4111 Hydraulicype door closer on reach-in cooler glass doors	2014 2014 2014 2014	2054 2054		r-C	\$0.00	⊅∠U.UU		\$20.00	4	1	1 \$0.00	1.00		1.00	0.75	1.15		

Part	RE COSTS					1.1-14	Heir	NPV of	Implomentation	Full			Full					DNV-G
Section Sect			Start	End Sav	rings Cost	Unit Equipment	Unit Labor	Lifetime O & M	Cost			Replace						Type RET = Retrofit
Section Sect			Year	Year U		Cost			Factor				Cost				V-OFF E	nd Use ROB = Replace on Burnout
Section Sect	-									4	1	1					1.00	6 RET
Securing Members of Me											1	1					1.00	6 ROB 6 RET
State Stat											1	1					1.00	6 ROB
Marche M	ting		2014		unit	\$15.00			\$15.00	4	1	1	\$15.00	1.00	1.00	1.00	1.00	6 RET
Mathematical Math					Monitor						1	1					1.00	6 RET
Marchane	5										1	1					1.00	6 ROB
Marchane 1986 Marchane	5						\$8.00				1	1					1.15	6 RET 6 RET
Marchester 1906 Energy State (Part Part Part Part Part Part Part Part							\$0.00				1	1					1.00	6 RET
No. Montanies	ting			2054 sqft	Monitor		\$0.00		\$1.00	4	1	1	\$1.00	1.00			1.00	6 ROB
NA Exemple 1988 Desire Desire Complete	5						\$8.00			4	1	1					1.15	6 RET
Marked See Person See Person See S							60.00			4	1	1					1.28	6 RET 6 RET
No. Sealery										-	1	1	40.00				1.00	6 ROB
Mathematic Power Management Fooding 1941 2041 2014	ting		2014	2054 sqft	Copier	\$0.00	\$45.00		\$45.00	6	1	1	\$45.00	0.50		0.75	1.15	6 RET
No. Seemely 1982 (1982) SEEMELY SEEMEL	5									-	1	1					1.00	6 RET
No Search 500 Sean Fermion 501	-										1	1					1.15	6 RET
Marie Mari											1	1					1.00	6 ROB 6 RET
No Searly 1970 Base Date Center Processor 1974 1976 1979 1970 1970 Center 1970											1	1					1.15	6 RET
Valestring 1971 Dual Counter Improved Development Operations 2014 2016 styll 2016 st	ting	5602 ENERGY STAR Printer	2014	2054 sqft	Printer	\$1.00	\$0.00		\$1.00	5	1	1	\$1.00	1.00	1.00	1.00	1.00	6 ROB
N. Essang 1982 Dauk Cheen Sang Parkanese 1982 05 1982 05 1983 1985 1985 1985 1985 1985 1985 1985 1985							\$0.00				1	1					1.00	6 RET
Ministry 1970 Date Charter Ministry Interpretation 2014 1964 1974 1974 1974 1975											1	1					1.00	6 RET
No. Board Sub- Board Arment Arment Memogrammen 2014											1	1					1.00	6 RET 6 RET
Western West	5				data center squ	\$1.00				10	1	1					1.00	6 RET
Mathematical Model Mathematical Mathematica	ting	6000 Base Water Heating	2014	2054 sqft	kBtu/hr	\$0.00	\$0.00		\$0.00	15	1	1	\$0.00	1.00	1.00	1.00	1.00	7 RET
Vicinity Modern	5										1	1					1.00	7 RET
Vicinity Good Fate Name Number Heaser Secure (1988) 2014											1	1					1.00	7 ROB
Western West											1	1					1.00	7 RET 7 ROB
V.E. Esting 6000 Hear Recovery Unit											1	1					1.00	7 ROB
Vale Entires 0.000 Stand Winter Netwer 0.000 Stand Winter Netwer 0.000 Stand Stan											1	1					1.00	7 RET
Vicinity 7000 Base Neingerander Vording Materian (Reingerander durch) 2014 2054 sigt mode) 3000 3000 31750 50 1 31750 500 5000 5125 51750 5000 5125 51750 5000 5125 51750 5000 5125 51750 5000 5125 51750 5000 5125 51750 5000 5125 51750 51					kBtu/hr						1	1					1.00	7 RET
M. Esting 7001 Verding Misser (Reingement developed winds) 2014 2054 stl. machine 3176.0 30.0 3175.0 5 1 1 3175.0 0.50 1.25 0.75 W. Esting 7100 Base Nor-Refligement Verding Machines 2014 2054 stl. machine 30.0 30.0 315.00 10 1 1 315.00 0.50 1.25 0.75 W. Esting 7100 Base Nor-Refligement Verding Machines 2014 2054 stl. machine 350.0 30.0 315.00 10 1 1 315.00 0.0 0.10 1.25 W. Esting 7100 Base Nor-Refligement Verding Machines 2014 2054 stl. machine 350.0 30.0 315.00 310.0 10 1 1 315.00 0.0 0.0 1.25 W. Esting 7200 Base Over 2014 2054 stl. single over 350.00 30.0 350.00 10 1 1 350.00 1.0 0.10 W. Esting 7200 Base Fiver 2014 2054 stl. single over 350.00 30.0 350.00 10 1 1 1 350.00 1.0 0.10 W. Esting 7200 Base Fiver 2014 2054 stl. single over 350.00 30.0 350.00 10 1 1 1 350.00 1.0 0.10 W. Esting 7200 Base Fiver 2014 2054 stl. single over 350.00 30.0 350.00 10 1 1 1 350.00 1.0 0.10 W. Esting 7200 Base Fiver 2014 2054 stl. single over 350.00 30.0 350.00 10 1 1 1 350.00 1.0 0.10 W. Esting 7200 Base Fiver 2014 2054 stl. single over 350.00 30.0 30.0 30.0 10 1 1 1 350.00 1.0 0.10 W. Esting 7200 Base Fiver 2014 2054 stl. single over 350.00 30.0											1	1					1.00	7 ROB
Medical Mode Mode Mode Medical Mode M											1	1					1.00	8 RET 8 RET
Mathematic 17.00 Statisting											1	1					1.15	8 RET
VAE Easting 7200 Dass Overs (100 Dass Over										-	1	1	4				1.00	8 RET
Validating 7300 Convention Common 2014 2054 still single-own 3,000 300 3,000 100 1 1 1 5,000 1,000 1,00	ting	7101 Vending Misers (Non-Refrigerated)	2014	2054 sqft	machine	\$150.00			\$150.00	5	1	1	\$150.00	0.50	1.25		1.15	8 RET
VA. Estating 700 Base Fryer 730 Estating 73											1	1					1.00	9 ROB
Value Valu					-						1	1					1.00	9 ROB 9 ROB
Vale Leisting 7400 Base Stammer 2014 2054 sight sessamer \$5,000 \$0.00 \$5,000 \$10 1 1 \$0.00 \$1.00 \$					* "						1	1	40.00				1.00	9 ROB 9 ROB
Ne Restring 800 Base heating, Heating Pump (77 HSPF) 2014 2014 2015 sqt sign state 1 \$70.00 \$0.00 \$0.00 \$0.00 \$15 \$1 \$1 \$50.00 \$1.00	5										1	1					1.00	9 ROB
VA. Esisting 8100 Host Pump (Ligopade (if SEER, 8.2 48)PF) 2044 2045 48)t 491t 512.00 510.00 512.00 512.00 10 1 512.00 10.00 10.00 10.00 VA. Esisting 8100 Baste Miscellamous 2014 2045 480t 491t 491t 512.00 510.00 512.00 512.00 10 1 512.00 10.00 10.00 10.00 VA. Esisting 9501 Vision 1000 Base Fluorescene Flature, 4.14/T8, 1.18B, 2.014-2.015 2014 2015 581t 581.00 581	ting	7401 Efficient Steamer	2014		steamer	\$5,000.00	\$0.00		\$5,000.00	12	1	1	\$5,000.00	1.00	1.00	1.00	1.00	9 ROB
VA Esisting S100 Base Heating, Other Electric 2014 2054 sqrt sqrt \$12.00 \$10.00 \$1.20 \$1.00 \$1.01 \$1.20 \$1.00	-						\$0.00				1	1					1.00	10 ROB
VA Existing 9500 Base Miscellaneous 2014 2054 staft sqft \$1,25 50,00 \$1,25 10 1 \$1,25 1,00						4			4.0.00		1	1	4.0.00				1.00	10 ROB
VR. Esisting 950 Xmisc 950 Xmisc 2014 2015 sqrll Subtree S	5										1	1					1.00	10 RET 12 RET
NC Existing 1000 Base Fluorescent Fixture, 4L4TR, ER, 2014-2015 2014 2015 sqlt fixture \$0.00 \$0.											1	1	4				1.00	12 RET
NC Existing 1002 ROB ALL*Low Wat High Performance T8 (75 W), 2014-2015 2014 2015 sqlt fixture \$2.00 \$0	ting	1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	2014	2015 sqft	fixture	\$0.00	\$0.00	\$0.00	\$0.00	18	1	1	\$0.00	1.00	1.00	1.00	1.00	1 ROB
NC Existing 1003 ROB 4L4TS, 2014-2015					fixture						1	1					1.00	1 ROB
NC Existing 1008 ROB 4L4 LED Tube, 2014-2015 2014 2015 sqlt fature \$300.0 \$10.											1	1					1.00	1 ROB
NC Existing 1006 LED Traffer (base 4 LATS), 2014-2015 2014 2015 sqt bature \$376.00 \$1.00 \$0.00 \$											1	1					1.00	1 RET 1 ROB
NC Existing 1000 Lighting Control Tuneup (base 4L4TB), 2014-2015 2014 2015 sqlt sqlt sqlt sqlt sqlt sqlt sqlt sqlt											1	1					1.00	1 RET
NC Existing 1008 High Performance Lighting RR - 25% Savings (base 4L4T8), 2014-2015 2014 2015 sqt sqt sqt \$0.00 \$0											1	1					1.31	1 RET
NC Existing 1010 Base Fluorescent Fixture, 4L4T8, IEB, 2016-2017 2016 2017 sqlt foxure \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$1.0 \$1 \$0.00 \$1.00 \$	ting	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	2014		fixture	\$55.00	\$0.00	\$0.00	\$55.00	10	1	1	\$55.00	0.25	1.46	0.25	1.46	1 RET
NC Existing 1011 ROB 4L4 High Performance T8 (86 W), 2016-2017 2016 2017 sqtt fexture \$5.00 \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$1.0											1	1					1.12	1 ROB
NC Existing 1012 ROB 4L/4 Low Wart High Performance T8 (75 W), 2016-2017 2016 2017 sqlt foxure \$2.00 \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$1 \$1 \$23.00 \$1.00											1	1					1.00	1 ROB
NC Existing 1013 ROB 4L4TES, 2016-2017 2016 2017 sight feature \$70.00 \$15.00 \$0.00 \$85.00 \$0.00 \$0.00 \$1 1 \$85.00 \$1.00											1	1					1.00	1 ROB 1 ROB
NC Existing 1014 ROB 4.14* LED Tube, 2016-2017 2016 2017 sqt fixture \$215.00 \$0.00 \$12.73\$ \$215.60 \$0.000 \$1 1 \$202.87\$ 1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.0											1	1					1.00	1 RET
NC Existing 1016 Lighting Control Tuneup (base 4L4TB), 2016-2017 2016 2017 sqlt sqlt sqlt \$0.00 \$0.01 \$0.00	ting	1014 ROB 4L4' LED Tube, 2016-2017	2016	2017 sqft	fixture	\$215.60	\$0.00	(\$12.73)	\$215.60	50000	1	1	\$202.87	1.00	1.00		1.00	1 ROB
NC Existing 1017 Occupancy Sensor, 4L4 Fluorescent Fixtures, 2016-2017 2016 2017 sqlt fixture \$55.00 \$0.00 \$5.00 \$5.00 \$1.0 \$1 \$1 \$55.00 \$0.25 \$1.46 \$0.25 \$1.50 \$											1	1					1.00	1 RET
NC Existing 1018 High Performance Lighting R.R 25% Savings (base 4L4T8), 2016-2017 2016 2017 sqtt sqt \$0.20 \$0.00 \$0.00 \$0.00 \$0.00 \$0.00 \$1.01 \$1 \$0.20 \$0.80 \$1.12 \$1.12 \$0.80 \$1.12	-										1	1					1.31	1 RET
NC Existing 1020 Base Fluorescent Fixture, 4.4/18, 1EB, 2018-2019 2018 2019 sqft fixture \$0.00 \$0.00 \$0.00 \$0.00 18 1 1 \$0.00 1.00 1.00 1.00 1.00 NC Existing 1021 ROB 4.4/ High Performance T8 (86 W), 2018-2019 2018 2019 sqft fixture \$7.00 \$0.00 \$0.00 \$0.00 \$0.00 1 1 \$7.00 1.00 1.00 1.00 1.00 1.00											1	1					1.46	1 RET 1 ROB
NC Existing 1021 ROB 4L4' High Performance T8 (86 W), 2018-2019 2018 2019 sqlt fixture \$7.00 \$0.00 \$0.00 \$7.00 30000 1 1 \$7.00 1.00 1.00 1.00											1	1					1.12	1 ROB
											1	1					1.00	1 ROB
NC Existing 1022 ROB 4L4* Low Watt High Performance T8 (75 W), 2018-2019 2018 2019 sqft fixture \$2.3.00 \$0.00 \$23.00 3000 1 1 \$23.00 1.00 1.00 1.00		1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	2018	2019 sqft		\$23.00	\$0.00	\$0.00	\$23.00	30000	1	1	\$23.00	1.00		1.00	1.00	1 ROB
NC Existing 1023 ROB 4L4T5, 2018-2019 2018 2019 sqft foxture \$70.00 \$15.00 \$0.00 \$85.00 20000 1 1 \$85.00 1.00 1.00 1.00											1	1					1.00	1 RET
NC Existing 1024 ROB 4L4 LED Tube, 2018-2019 2018 2019 sqt finture \$195.27 \$0.00 (\$12.73) \$195.27 5.0000 1 1 \$182.54 1.00 1.00 1.00 1.00 1.00 1.00 1.00 1.0											1	1					1.00	1 ROB 1 RET
								(4.2)			1	1	4				1.00	1 RET
NC Existing 1026 Lighting Control Tuneup (base 4L478), 2018-2019 2018 2019 sqft sqft \$0.00 \$0.01 \$0.00 \$0.01 6 1 1 \$0.01 0.50 1.31 0.50	ung	TUZO Ligiting Control Tuneup (base 4L4 18), 2018-2019	2018	2019 sqft	sqrt	\$0.00	\$0.01	\$0.00	\$0.01	ь	1	1	\$0.01	0.50	1.37	0.50	1.31	IKEI

																			DNV
ASURE COST	S							NPV of		F	Full = 1								Implementation
						Unit	Unit	Lifetime	Implementation	16	ncr. = 0		Full						Type
		Start	End	Savings	Cost	Equipment	Labor	O & M	Cost	Service	Initial	Replace	Unit						RET = Retrofit
Segment	Measure # Measure Description	Year	Year	Units	Units	Cost	Cost	Cost	Factor	Life	Cost	Cost	Cost	SS	S-ON S-M	ID S-OFF	W-ON	W-OFF E	nd Use ROB = Replace on Burno
Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	2018	2019 s	qft	fixture	\$55.00	\$0.00	\$0.00	\$55.00	10	1	1	\$55.00		0.25	1.46	0.25	1.46	1 RET
Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	2018	2019 s	qft	sqft	\$0.20	\$0.00	\$0.00	\$0.20	15	1	1	\$0.20		0.80	1.12	0.80	1.12	1 ROB
Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	2020	2054 s	qft	fixture	\$0.00	\$0.00	\$0.00	\$0.00	18	1	1	\$0.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	2020	2054 s	qft	fixture	\$7.00	\$0.00	\$0.00	\$7.00	30000	1	1	\$7.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	2020	2054 s	qft	fixture	\$23.00	\$0.00	\$0.00	\$23.00	30000	1	1	\$23.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1033 ROB 4L4'T5, 2020	2020	2054 s	qft	fixture	\$70.00	\$15.00	\$0.00	\$85.00	20000	1	1	\$85.00		1.00	1.00	1.00	1.00	1 RET
Existing	1034 ROB 4L4' LED Tube, 2020	2020	2054 s	qft	fixture	\$184.80	\$0.00	(\$12.73)	\$184.80	50000	1	1	\$172.07		1.00	1.00	1.00	1.00	1 ROB
Existing	1035 LED Troffer (base 4L4'T8), 2020	2020	2054 s	qft	fixture	\$225.00	\$15.00	(\$12.73)	\$240.00	50000	1	1	\$227.27		1.00	1.00	1.00	1.00	1 RET
Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	2020	2054 s	qft	sqft	\$0.00	\$0.01	\$0.00	\$0.01	6	1	1	\$0.01		0.50	1.31	0.50	1.31	1 RET
Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	2020	2054 s	qft	fixture	\$55.00	\$0.00	\$0.00	\$55.00	10	1	1	\$55.00		0.25	1.46	0.25	1.46	1 RET
Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	2020	2054 s	qft	sqft	\$0.20	\$0.00	\$0.00	\$0.20	15	1	1	\$0.20		0.80	1.12	0.80	1.12	1 ROB
Existing	1100 Base Fluorescent Fixture, 2L4T8, 1EB, 2014-2015	2014	2015 s	qft	fixture	\$0.00	\$0.00	\$0.00	\$0.00	18	1	1	\$0.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	2014	2015 s	qft	fixture	\$5.00	\$0.00	\$0.00	\$5.00	30000	1	1	\$5.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	2014	2015 s	qft	fixture	\$16.43	\$0.00	\$0.00	\$16.43	30000	1	1	\$16.43		1.00	1.00	1.00	1.00	1 ROB
Existing	1103 ROB 2L4'T5, 2014-2015	2014	2015 s	qft	fixture	\$40.00	\$15.00	\$0.00	\$55.00	20000	1	1	\$55.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1104 ROB 2L4' LED Tube, 2014-2015	2014	2015 s	qft	fixture	\$154.00	\$0.00	(\$12.73)	\$154.00	50000	1	1	\$141.27		1.00	1.00	1.00	1.00	1 ROB
Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	2014	2015 s	qft	fixture	\$202.00	\$15.00	(\$12.73)	\$217.00	50000	1	1	\$204.27		1.00	1.00	1.00	1.00	1 RET
Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	2014	2015 s	qft	sqft	\$0.00	\$0.01	\$0.00	\$0.01	6	1	1	\$0.01		0.50	1.31	0.50	1.31	1 RET
Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	2014	2015 s	qft	fixture	\$55.00	\$0.00	\$0.00	\$55.00	10	1	1	\$55.00		0.25	1.46	0.25	1.46	1 RET
Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	2014	2015 s	qft	sqft	\$0.20	\$0.00	\$0.00	\$0.20	15	1	1	\$0.20		0.80	1.12	0.80	1.12	1 ROB
Existing	1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	2016	2017 s	qft	fixture	\$0.00	\$0.00	\$0.00	\$0.00	18	1	1	\$0.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	2016	2017 s	qft	fixture	\$5.00	\$0.00	\$0.00	\$5.00	30000	1	1	\$5.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	2016	2017 s	qft	fixture	\$16.43	\$0.00	\$0.00	\$16.43	30000	1	1	\$16.43		1.00	1.00	1.00	1.00	1 ROB
Existing	1113 ROB 2L4'T5, 2016-2017	2016	2017 s	qft	fixture	\$40.00	\$15.00	\$0.00	\$55.00	20000	1	1	\$55.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1114 ROB 2L4' LED Tube, 2016-2017	2016	2017 s	qft	fixture	\$107.80	\$0.00	(\$7.43)	\$107.80	50000	1	1	\$100.37		1.00	1.00	1.00	1.00	1 ROB
Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	2016	2017 s	qft	fixture	\$141.40	\$15.00	(\$7.43)	\$156.40	50000	1	1	\$148.97		1.00	1.00	1.00	1.00	1 RET
Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	2016	2017 s	qft	sqft	\$0.00	\$0.01	\$0.00	\$0.01	6	1	1	\$0.01		0.50	1.31	0.50	1.31	1 RET
Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	2016	2017 s	qft	fixture	\$55.00	\$0.00	\$0.00	\$55.00	10	1	1	\$55.00		0.25	1.46	0.25	1.46	1 RET
Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	2016	2017 s	qft	sqft	\$0.20	\$0.00	\$0.00	\$0.20	15	1	1	\$0.20		0.80	1.12	0.80	1.12	1 ROB
Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	2018	2019 s	qft	fixture	\$0.00	\$0.00	\$0.00	\$0.00	18	1	1	\$0.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	2018	2019 s	qft	fixture	\$5.00	\$0.00	\$0.00	\$5.00	30000	1	1	\$5.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	2018	2019 s	qft	fixture	\$16.43	\$0.00	\$0.00	\$16.43	30000	1	1	\$16.43		1.00	1.00	1.00	1.00	1 ROB
Existing	1123 ROB 2L4'T5, 2018-2019	2018	2019 s	qft	fixture	\$40.00	\$15.00	\$0.00	\$55.00	20000	1	1	\$55.00		1.00	1.00	1.00	1.00	1 ROB
Existing	1124 ROB 2L4' LED Tube, 2018-2019	2018	2019 s	qft	fixture	\$97.64	\$0.00	(\$7.43)	\$97.64	50000	1	1	\$90.21		1.00	1.00	1.00	1.00	1 ROB
Existing	1125 LED Troffer (base 2L4T8), 2018-2019	2018	2019 s	qft	fixture	\$128.07	\$15.00	(\$7.43)	\$143.07	50000	1	1	\$135.64		1.00	1.00	1.00	1.00	1 RET
Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	2018	2019 s	qft	sqft	\$0.00	\$0.01	\$0.00	\$0.01	6	1	1	\$0.01		0.50	1.31	0.50	1.31	1 RET
Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	2018	2019 s	qft	fixture	\$55.00	\$0.00	\$0.00	\$55.00	10	1	1	\$55.00		0.25	1.46	0.25	1.46	1 RET
Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2018-2019	2018	2019 s	qft	sqft	\$0.20	\$0.00	\$0.00	\$0.20	15	1	1	\$0.20		0.80	1.12	0.80	1.12	1 ROB
Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	2020	2054 s		fixture	\$0.00	\$0.00	\$0.00	\$0.00	18	1	1	\$0.00		1.00	1.00	1.00	1.00	1 ROB

Commercial Elec M	Reasure Inputs	APPLICABILI (percent)	TY FACTOR										
		(percent)											/
	Measure # Measure Description	Office	Restaurant	Retail			Education	Health			Non-Jurisdictional	Religious Worship	Misc
VA Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing VA Existina	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015 1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	61.7% 61.7%	2.1% 2.1%	29.3% 29.3%	42.5% 42.5%	57.5% 57.5%	57.4% 57.4%	47.5% 47.5%	3.1%	45.8% 45.8%	47.9% 47.9%	25.1% 25.1%	20.1%
VA Existing VA Existing	1002 ROB 4L4 Low Watt high Performance 16 (75 W), 2014-2015	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9% 47.9%	25.1%	20.1%
VA Existing	1004 ROB 4L4 LED Tube, 2014-2015	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	9.8%	0.1%	1.3%	0.8%	18.8%	10.8%	1.3%	0.3%	3.0%	10.5%	2.5%	2.0%
VA Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2014-2015	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1013 ROB 4L4'T5, 2016-2017	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1014 ROB 4L4' LED Tube, 2016-2017	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8% 3.0%	47.9%	25.1%	20.1%
VA Existing VA Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017 1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	9.8% 61.7%	0.1% 2.1%	1.3% 29.3%	0.8% 42.5%	18.8% 57.5%	10.8% 57.4%	1.3% 47.5%	0.3% 3.1%	45.8%	10.5% 47.9%	2.5% 25.1%	2.0% 20.1%
VA Existing VA Existing	1017 Occupancy Sensor, 4L4 Fluorescent Fixtures, 2016-2017 1018 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1020 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1023 ROB 4L4'T5, 2018-2019	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1024 ROB 4L4' LED Tube, 2018-2019	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	9.8%	0.1%	1.3%	0.8%	18.8%	10.8%	1.3%	0.3%	3.0%	10.5%	2.5%	2.0%
VA Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2018-2019	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	61.7% 61.7%	2.1%	29.3% 29.3%	42.5% 42.5%	57.5% 57.5%	57.4% 57.4%	47.5% 47.5%	3.1%	45.8% 45.8%	47.9%	25.1% 25.1%	20.1% 20.1%
VA Existing VA Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1033 ROB 4L4'T5, 2020	61.7%	2.1% 2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9% 47.9%	25.1%	20.1%
VA Existing	1034 ROB 4L4 LED Tube, 2020	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1035 LED Troffer (base 4L4'T8), 2020	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	9.8%	0.1%	1.3%	0.8%	18.8%	10.8%	1.3%	0.3%	3.0%	10.5%	2.5%	2.0%
VA Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	61.7%	2.1%	29.3%	42.5%	57.5%	57.4%	47.5%	3.1%	45.8%	47.9%	25.1%	20.1%
VA Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1103 ROB 2L4'T5, 2014-2015	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1104 ROB 2L4' LED Tube, 2014-2015	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1106 Lighting Control Tuneup (base 2L4T8), 2014-2015	0.3%	0.8%	0.5%	0.0%	0.1%	1.0%	0.3%	1.5%	0.1%	3.0%	2.4%	1.9%
VA Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	1.8%	25.5%	10.0% 10.0%	0.2%	0.4%	5.3%	12.1%	17.4% 17.4%	1.3%	13.7%	23.6% 23.6%	18.9%
VA Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015 1110 Base Fluorescent Fixture, 2L4T8, 1EB, 2016-2017	1.8% 1.8%	25.5% 25.5%	10.0%	0.2% 0.2%	0.4% 0.4%	5.3% 5.3%	12.1% 12.1%	17.4%	1.3% 1.3%	13.7% 13.7%	23.6%	18.9% 18.9%
VA Existing VA Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1113 ROB 2L4'T5, 2016-2017	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1114 ROB 2L4' LED Tube, 2016-2017	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	0.3%	0.8%	0.5%	0.0%	0.1%	1.0%	0.3%	1.5%	0.1%	3.0%	2.4%	1.9%
VA Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1123 ROB 2L4'T5, 2018-2019	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1124 ROB 2L4' LED Tube, 2018-2019	1.070	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing VA Existing	1125 LED Troffer (base 2L4'T8), 2018-2019 1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	1.8% 0.3%	25.5% 0.8%	10.0% 0.5%	0.2% 0.0%	0.4% 0.1%	5.3% 1.0%	12.1% 0.3%	17.4% 1.5%	1.3% 0.1%	13.7% 3.0%	23.6% 2.4%	18.9% 1.9%
	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	1.8%	25.5%	10.0%	0.0%	0.1%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing			20.070	. 0.0 /0	0.2 /0	U. /0	0.070	.2.1/0	70	1.0/0	10.7 /6	20.070	10.070

Commercial Elec N	Measure Inputs	APPLICABILI'	TY FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging		Non-Jurisdictional	Religious Worship	Misc
VA Existing	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing VA Existing	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	1.8%	25.5% 25.5%	10.0% 10.0%	0.2%	0.4%	5.3% 5.3%	12.1% 12.1%	17.4% 17.4%	1.3%	13.7% 13.7%	23.6% 23.6%	18.9% 18.9%
VA Existing VA Existing	1132 ROB 2L4 Low Walt right renormance 16 (75 W), 2020	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing VA Existing	1134 ROB 2L4 LED Tube, 2020	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1135 LED Troffer (base 2L4'T8), 2020	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1136 Lighting Control Tuneup (base 2L4'T8), 2020	0.3%	0.8%	0.5%	0.0%	0.1%	1.0%	0.3%	1.5%	0.1%	3.0%	2.4%	1.9%
VA Existing	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	1.8%	25.5%	10.0%	0.2%	0.4%	5.3%	12.1%	17.4%	1.3%	13.7%	23.6%	18.9%
VA Existing	1200 Base Other Fluorescent Fixture	4.8%	0.0%	0.2%	0.0%	0.0%	2.2%	4.1%	0.8%	3.6%	3.4%	1.2%	1.0%
VA Existing	1201 ROB High Performance T8 (base other fluorescent)	4.8%	0.0%	0.2%	0.0%	0.0%	2.2%	4.1%	0.8%	3.6%	3.4%	1.2%	1.0%
VA Existing	1202 ROB Low Watt High Performance T8 (base other fluorescent)	4.8%	0.0%	0.2%	0.0%	0.0%	2.2%	4.1%	0.8%	3.6%	3.4%	1.2%	1.0%
VA Existing	1203 Lighting Control Tuneup (base other fluorescent fixture)	0.8%	0.0%	0.0%	0.0%	0.0%	0.4%	0.1%	0.1%	0.2%	0.7%	0.1%	0.1%
VA Existing VA Existing	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	4.8% 4.8%	0.0%	0.2% 0.2%	0.0%	0.0%	2.2% 2.2%	4.1% 4.1%	0.8%	3.6% 3.6%	3.4% 3.4%	1.2% 1.2%	1.0% 1.0%
VA Existing VA Existing	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	4.8% 7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	4.1% 8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1301 CFLs (base incandescent flood) 2014-2015	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1302 LEDs (base incandescent flood) 2014-2015	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1311 CFLs (base incandescent flood) 2016-2017	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1312 LEDs (base incandescent flood) 2016-2017	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1321 CFLs (base incandescent flood) 2018-2019	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1322 LEDs (base incandescent flood) 2018-2019	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing	1331 CFLs (base incandescent flood) 2020	7.2%	21.5%	9.8%	24.6%	2.9%	4.7%	8.9%	16.2%	4.9%	5.8%	10.8%	10.4%
VA Existing VA Existing	1332 LEDs (base incandescent flood) 2020 1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	7.2%	21.5% 10.8%	9.8% 4.9%	24.6% 12.3%	2.9% 1.4%	4.7% 2.3%	8.9% 4.4%	16.2% 8.1%	4.9% 2.4%	5.8% 2.9%	10.8% 5.4%	10.4% 5.2%
VA Existing VA Existing	1400 Base incandescent x-Line Lamp, 72W to sciew-in replacement 2014-2015	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1402 LEDs (base incandescent A-line 72W) 2014-2015	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1411 CFLs (base incandescent A-line 72W) 2016-2017	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1412 LEDs (base incandescent A-line 72W) 2016-2017	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1421 CFLs (base incandescent A-line 72W) 2018-2019	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1422 LEDs (base incandescent A-line 72W) 2018-2019	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1431 CFLs (base incandescent A-line 72W) 2020	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1432 LEDs (base incandescent A-line 72W) 2020	3.6%	10.8% 10.8%	4.9% 4.9%	12.3% 12.3%	1.4%	2.3%	4.4%	8.1% 8.1%	2.4%	2.9%	5.4% 5.4%	5.2% 5.2%
VA Existing VA Existing	1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015 1501 CFLs (base incandescent A-line 53W) 2014-2015	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1502 LEDs (base incandescent A-line 53W) 2014-2015	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1510 Base Incandescent A-line Lamp, 53W to Screw-in Replacement 2016-2017	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1511 CFLs (base incandescent A-line 53W) 2016-2017	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1512 LEDs (base incandescent A-line 53W) 2016-2017	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1520 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1521 CFLs (base incandescent A-line 53W) 2018-2019	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1522 LEDs (base incandescent A-line 53W) 2018-2019	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1531 CFLs (base incandescent A-line 53W) 2020	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1532 LEDs (base incandescent A-line 53W) 2020	3.6%	10.8%	4.9%	12.3%	1.4%	2.3%	4.4%	8.1%	2.4%	2.9%	5.4%	5.2%
VA Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing VA Existing	1601 LED screw-in replacement (base CFL 18W) 2014-2015	8.0% 8.0%	14.0% 14.0%	17.3% 17.3%	1.4% 1.4%	5.7% 5.7%	10.3% 10.3%	8.9% 8.9%	18.7% 18.7%	16.7% 16.7%	10.7% 10.7%	8.7% 8.7%	10.7% 10.7%
VA Existing VA Existing	1610 Base CFL 18W to screw-in replacement 2016-2017 1611 LED screw-in replacement (base CFL 18W) 2016-2017	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing VA Existing	1620 Base CFL 18W to screw-in replacement 2018-2019	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing	1621 LED screw-in replacement (base CFL 18W) 2018-2019	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing	1630 Base CFL 18W to screw-in replacement 2020	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing	1631 LED screw-in replacement (base CFL 18W) 2020	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing	1700 Base CFL 23W to screw-in replacement 2014-2015	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing	1701 LED screw-in replacement (base CFL 23W) 2014-2015	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing	1710 Base CFL 23W to screw-in replacement 2016-2017	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing	1711 LED screw-in replacement (base CFL 23W) 2016-2017	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%

Commercial Elec N	leasure Inputs	APPLICABILI'	TY FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Center	Non-Jurisdictional	Religious Worship	Misc
VA Existing	1720 Base CFL 23W to screw-in replacement 2018-2019	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing VA Existing	1721 LED screw-in replacement (base CFL 23W) 2018-2019 1730 Base CFL 23W to screw-in replacement 2020	8.0% 8.0%	14.0% 14.0%	17.3% 17.3%	1.4% 1.4%	5.7% 5.7%	10.3% 10.3%	8.9% 8.9%	18.7% 18.7%	16.7% 16.7%	10.7% 10.7%	8.7% 8.7%	10.7% 10.7%
VA Existing VA Existing	1731 LED screw-in replacement (base CFL 23W) 2020	8.0%	14.0%	17.3%	1.4%	5.7%	10.3%	8.9%	18.7%	16.7%	10.7%	8.7%	10.7%
VA Existing	1800 BaseMetal Halide, 465W	2.4%	2.7%	4.1%	1.4%	25.2%	5.2%	1.9%	5.8%	1.6%	8.8%	1.9%	6.2%
VA Existing	1801 T5 (240W) (base metal halide)	2.4%	2.7%	4.1%	1.0%	25.2%	5.2%	1.9%	5.8%	1.6%	8.8%	1.9%	6.2%
VA Existing	1802 Induction High Bay Lighting	2.4%	2.7%	4.1%	1.0%	25.2%	5.2%	1.9%	5.8%	1.6%	8.8%	1.9%	6.2%
VA Existing	1803 PSMH + electronic ballast	2.4%	2.7%	4.1%	1.0%	25.2%	5.2%	1.9%	5.8%	1.6%	8.8%	1.9%	6.2%
VA Existing	1804 PSMH, magnetic ballast, 320 W	2.4%	2.7%	4.1%	1.0%	25.2%	5.2%	1.9%	5.8%	1.6%	8.8%	1.9%	6.2%
VA Existing	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	2.4%	2.7%	4.1%	1.0%	25.2%	5.2%	1.9%	5.8%	1.6%	8.8%	1.9%	6.2%
VA Existing	1806 Occupancy Sensor, High Bay T5	2.4%	2.7%	4.1%	1.0%	25.2%	5.2%	1.9%	5.8%	1.6%	8.8%	1.9%	6.2%
VA Existing	1850 Base CFL Exit Sign	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
VA Existing	1851 LED Exit Sign	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
VA Existing VA Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	43.3% 43.3%	62.4% 62.4%	40.9% 40.9%	25.1% 25.1%	72.0% 72.0%	84.9% 84.9%	63.9% 63.9%	91.6% 91.6%	93.1% 93.1%	78.6% 78.6%	88.8% 88.8%	67.6% 67.6%
VA Existing VA Existing	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	43.3%	62.4%	40.9%	25.1%	72.0%	84.9% 84.9%	63.9%	91.6%	93.1%	78.6% 78.6%	88.8% 88.8%	67.6%
VA Existing	1903 Bi-Level LED Outdoor Lighting	43.3%	62.4%	40.9%	25.1%	72.0%	84.9%	63.9%	91.6%	93.1%	78.6%	88.8%	67.6%
VA Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2002 Window Film (Standard) - Chiller	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2003 EMS - Chiller	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2004 Cool Roof - Chiller	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2005 Chiller Tune Up/Diagnostics	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2006 VSD for Chiller Pumps and Towers	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2007 EMS Optimization - Chiller	4.1%	2.7%	0.2%	0.1%	0.0%	16.8%	2.4%	6.6%	51.6%	27.9%	7.8%	0.9%
VA Existing	2008 New Economizer - Chiller	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2009 Dual Enthalpy Economizer Replaced Dry Bulb Economizer - Chiller	10.4%	14.6%	1.4%	2.6%	0.0%	10.5%	9.0%	8.5%	6.8%	2.4%	0.6%	0.6%
VA Existing	2010 Ceiling/roof Insulation - Chiller 2011 Duct/Pipe Insulation - Chiller	12.8% 12.8%	14.6% 14.6%	1.4% 1.4%	2.7% 2.7%	0.0%	39.8% 39.8%	19.3% 19.3%	26.7% 26.7%	65.8% 65.8%	43.9% 43.9%	14.7% 14.7%	8.3% 8.3%
VA Existing VA Existing	2011 Duct/Pipe Insulation - Chiller 2012 Duct Testing/Sealing	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2013 High Efficiency Chiller Motors	12.8%	14.6%	1.4%	2.7%	0.0%	39.8%	19.3%	26.7%	65.8%	43.9%	14.7%	8.3%
VA Existing	2100 Base DX Packaged System, EER=10.3, 10 tons	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2101 DX Packaged System, EER=10.9, 10 tons	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2102 DX Packaged System, EER=13.4, 10 tons	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2103 Geothermal Heat Pump, EER=13, 10 tons - DX	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2104 DX Coil Cleaning	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2105 DX Tune Up/ Advanced Diagnostics	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2106 Prog. Thermostat - DX	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2107 Cool Roof - DX	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2108 Optimize Controls - DX 2109 Economizer - DX	57.9% 57.9%	77.1% 77.1%	49.6% 49.6%	83.6% 83.6%	36.9% 36.9%	95.4% 95.4%	64.7% 64.7%	68.1% 68.1%	37.5% 37.5%	54.1% 54.1%	47.5% 47.5%	31.8% 31.8%
VA Existing	2109 Economizer - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX		77.1% 53.6%					8.7%		6.0%		47.5% 20.3%	
VA Existing VA Existing	2110 Dual Enthalpy Economizer Replaces Dry Build Economizer - DX 2111 Economizer Repair - DX	16.0% 16.0%	53.6%	20.7% 20.7%	82.8% 82.8%	24.1% 24.1%	73.1% 73.1%	8.7%	16.4% 16.4%	6.0%	9.8% 9.8%	20.3%	20.3% 20.3%
VA Existing	2112 Aerosol Duct Sealing - DX	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2113 Ceiling/roof Insulation - DX	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2114 Duct/Pipe Insulation - DX	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2115 Window Film (Standard) - DX	57.9%	77.1%	49.6%	83.6%	36.9%	95.4%	64.7%	68.1%	37.5%	54.1%	47.5%	31.8%
VA Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	39.5%	24.2%	18.4%	7.5%	20.0%	75.1%	41.2%	52.8%	4.8%	23.5%	38.6%	30.2%
VA Existing	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	39.5%	24.2%	18.4%	7.5%	20.0%	75.1%	41.2%	52.8%	4.8%	23.5%	38.6%	30.2%
VA Existing	2300 Base PTAC, EER=8.3, 1 ton	6.3%	2.9%	3.2%	3.5%	0.9%	68.4%	9.2%	11.1%	0.0%	36.4%	38.3%	19.0%
VA Existing	2301 HE PTAC, EER=9.6, 1 ton	6.3%	2.9%	3.2%	3.5%	0.9%	68.4%	9.2%	11.1%	0.0%	36.4%	38.3%	19.0%
VA Existing	2302 Occupancy Sensor (hotels)	6.3%	2.9%	3.2%	3.5%	0.9%	68.4%	9.2%	11.1%	0.0%	36.4%	38.3%	19.0%
VA Existing	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	42.5%	50.4%	43.3%	96.7%	30.2%	33.4%	18.8%	65.4%	18.8%	48.0%	53.6%	53.6%
VA Existing	3001 Fan Motor, 5hp, 1800rpm, 89.5%	42.5%	50.4%	43.3%	96.7%	30.2%	33.4%	18.8%	65.4%	18.8%	48.0%	53.6%	53.6%
VA Existing	3002 Variable Speed Drive Control, 5 HP	42.5% 42.5%	50.4% 50.4%	43.3% 43.3%	96.7%	30.2%	33.4%	18.8%	65.4%	18.8%	48.0% 48.0%	53.6% 53.6%	53.6%
VA Existing VA Existing	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	42.5% 7.4%	50.4% 0.0%	43.3% 1.5%	96.7% 0.0%	30.2% 0.0%	33.4% 89.5%	18.8% 65.4%	65.4% 0.0%	18.8% 65.4%	48.0% 25.0%	53.6% 42.7%	53.6% 42.7%
VA Existing VA Existing	3100 Base Fan Motor, 15np, 1800rpm, 91.0% 3101 Fan Motor, 15hp, 1800rpm, 92.4%	7.4%	0.0%	1.5%	0.0%	0.0%	89.5% 89.5%	65.4%	0.0%	65.4%	25.0%	42.7% 42.7%	42.7%
VA Existing	3102 Variable Speed Drive Control, 15 HP	7.4%	0.0%	1.5%	0.0%	0.0%	89.5%	65.4%	0.0%	65.4%	25.0%	42.7%	42.7%
VA Existing	3103 Air Handler Optimization, 15 HP	7.4%	0.0%	1.5%	0.0%	0.0%	89.5%	65.4%	0.0%	65.4%	25.0%	42.7%	42.7%
VA Existing	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	7.4%	0.0%	1.5%	0.0%	0.0%	89.5%	65.4%	0.0%	65.4%	25.0%	42.7%	42.7%
VA Existing	3105 Energy Recovery Ventilation (ERV)	7.4%	0.0%	1.5%	0.0%	0.0%	89.5%	65.4%	0.0%	65.4%	25.0%	42.7%	42.7%
	3106 Separate Makeup Air / Exhaust Hoods AC	7.4%	0.0%	1.5%	0.0%	0.0%	89.5%	65.4%	0.0%	65.4%	25.0%	42.7%	42.7%

Commercial Elec N	leasure Inputs	APPLICABILI	TY FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Center	Non-Jurisdictional	Religious Worship	Misc
VA Existing	3107 Demand Controlled Ventilation	7.4%	0.0%	1.5%	0.0%	0.0%	89.5%	65.4%	0.0%	65.4%	25.0%	42.7%	42.7%
VA Existing	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	4.6%	0.0%	1.5%	95.6%	10.0%	37.3%	69.5%	11.3%	69.5%	19.3%	33.9%	33.9%
VA Existing	3201 Fan Motor, 40hp, 1800rpm, 94.1%	4.6%	0.0%	1.5%	95.6%	10.0%	37.3%	69.5%	11.3%	69.5%	19.3%	33.9%	33.9%
VA Existing VA Existing	3202 Variable Speed Drive Control, 40 HP 3203 Air Handler Optimization, 40 HP	4.6% 4.6%	0.0%	1.5% 1.5%	95.6% 95.6%	10.0% 10.0%	37.3% 37.3%	69.5% 69.5%	11.3% 11.3%	69.5% 69.5%	19.3% 19.3%	33.9% 33.9%	33.9% 33.9%
VA Existing	3204 Demand Controlled Ventilation	4.6%	0.0%	1.5%	95.6%	10.0%	37.3%	69.5%	11.3%	69.5%	19.3%	33.9%	33.9%
VA Existing	4000 Base Built-Up Refrigeration System	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4001 High-efficiency fan motors	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4002 Strip curtains for walk-ins (built-up)	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4003 Auto-closer on main door to walk-in freezer (built-up)	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4004 Night covers for display cases	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4005 Evaporator fan controller for MT walk-ins	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4006 Electronically commutated evaporator fan motor	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4007 Efficient compressor motor	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4008 Compressor VSD retrofit	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4009 Floating head pressure controls	8.7% 8.7%	67.0% 67.0%	17.4% 17.4%	91.4% 91.4%	37.3% 37.3%	36.6% 36.6%	25.6% 25.6%	37.7% 37.7%	2.3%	40.4%	43.4% 43.4%	18.2% 18.2%
VA Existing VA Existing	4010 Refrigeration Commissioning 4011 Demand Hot Gas Defrost	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4% 40.4%	43.4%	18.2%
VA Existing VA Existing	4012 Demand Defrost Electric	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4012 Demand Demost Electric 4013 Anti-sweat (humidistat) controls	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4014 Freezer-Cooler Replacement Gaskets	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4015 High R-Value Glass Doors	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4016 LED Display Lighting	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4017 Multiplex Compressor System	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4018 Oversized Air Cooled Condenser	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4019 Insulated suction lines	8.7%	67.0%	17.4%	91.4%	37.3%	36.6%	25.6%	37.7%	2.3%	40.4%	43.4%	18.2%
VA Existing	4100 Base Self-Contained Refrigeration	67.9%	91.2%	71.3%	93.7%	89.7%	83.2%	76.7%	77.9%	95.2%	84.7%	96.0%	62.1%
VA Existing	4101 Strip curtains for walk-ins (self-contained)	12.4%	91.2%	17.6%	93.7%	33.8%	22.1%	26.6%	58.9%	2.3%	55.0%	2.2%	27.3%
VA Existing	4102 Auto-closer on main door to walk-in freezer (self-contained)	12.4%	91.2%	17.6%	93.7%	33.8%	22.1%	26.6%	58.9%	2.3%	55.0%	2.2%	27.3%
VA Existing	4103 Night covers for display cases (self-contained)	7.1%	47.6%	15.2%	27.5%	1.8%	32.1%	14.5%	37.7%	0.0%	33.7%	10.3%	17.6%
VA Existing VA Existing	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4105 Bi-level LED Case Lighting (self-contained units) 2014	67.9% 8.7%	91.2% 67.0%	71.3% 17.4%	93.7% 91.4%	89.7% 1.5%	83.2% 36.6%	76.7% 25.6%	77.9% 29.6%	95.2% 2.3%	84.7% 40.4%	96.0% 43.4%	62.1% 18.2%
VA Existing VA Existing	4106 Energy-Star Refrigerator, solid door	8.7%	67.0%	17.4%	91.4%	1.5%	36.6%	25.6%	29.6%	2.3%	40.4%	43.4%	18.2%
VA Existing	4107 Energy-Star Freezer, solid door	8.7%	67.0%	17.4%	91.4%	1.5%	36.6%	25.6%	29.6%	2.3%	40.4%	43.4%	18.2%
VA Existing	4108 Energy-Star Refrigerator, glass door	8.7%	67.0%	17.4%	91.4%	1.5%	36.6%	25.6%	29.6%	2.3%	40.4%	43.4%	18.2%
VA Existing	4109 Energy-Star Freezer, glass door	8.7%	67.0%	17.4%	91.4%	1.5%	36.6%	25.6%	29.6%	2.3%	40.4%	43.4%	18.2%
VA Existing	4110 Energy Star Ice Machines	17.2%	88.0%	16.6%	73.1%	39.5%	83.2%	34.4%	77.9%	6.3%	66.6%	81.9%	35.5%
VA Existing	4111 Hydraulic-type door closer on reach-in cooler glass doors	8.7%	67.0%	17.4%	91.4%	1.5%	36.6%	25.6%	29.6%	2.3%	40.4%	43.4%	18.2%
VA Existing	4112 Reach-in unit occupancy sensors	8.7%	67.0%	17.4%	91.4%	1.5%	36.6%	25.6%	29.6%	2.3%	40.4%	43.4%	18.2%
VA Existing	5000 Base Desktop PC	97.6%	63.7%	80.3%	84.9%	97.9%	99.6%	95.0%	96.9%	97.7%	97.6%	95.3%	89.5%
VA Existing	5001 PC Network Power Management Enabling	97.6%	63.7%	80.3%	84.9%	97.9%	99.6%	95.0%	96.9%	97.7%	97.6%	95.3%	89.5%
VA Existing	5002 Energy Star or Better PC	97.6%	63.7%	80.3%	84.9%	97.9%	99.6%	95.0%	96.9%	97.7%	97.6%	95.3%	89.5%
VA Existing	5003 Plug-load controls - Commercial Smart Strip (base desktop PC)	97.6%	63.7%	80.3%	84.9%	97.9%	99.6%	95.0%	96.9%	97.7%	97.6%	95.3%	89.5%
VA Existing	5100 Base Laptop PC	86.9%	44.0%	60.5%	65.7%	85.5%	97.5%	68.2%	86.6%	90.1%	83.0%	72.1%	70.6%
VA Existing VA Existing	5101 Laptop Network Power Management Enabling 5102 Energy Star or Better Laptop	86.9% 86.9%	44.0% 44.0%	60.5% 60.5%	65.7% 65.7%	85.5% 85.5%	97.5% 97.5%	68.2% 68.2%	86.6% 86.6%	90.1% 90.1%	83.0% 83.0%	72.1% 72.1%	70.6% 70.6%
VA Existing	5103 Plug-load controls - Commercial Smart Strip (base laptop PC)	86.9%	44.0%	60.5%	65.7%	85.5%	97.5%	68.2%	86.6%	90.1%	83.0%	72.1%	70.6%
VA Existing VA Existing	5200 Base Monitor, CRT	59.8%	46.8%	41.7%	28.1%	68.3%	93.6%	64.4%	83.7%	78.9%	60.2%	45.4%	50.8%
VA Existing	5201 Energy Star or Better Monitor - CRT	59.8%	46.8%	41.7%	28.1%	68.3%	93.6%	64.4%	83.7%	78.9%	60.2%	45.4%	50.8%
VA Existing	5202 Monitor Power Management Enabling - CRT	59.8%	46.8%	41.7%	28.1%	68.3%	93.6%	64.4%	83.7%	78.9%	60.2%	45.4%	50.8%
VA Existing	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	59.8%	46.8%	41.7%	28.1%	68.3%	93.6%	64.4%	83.7%	78.9%	60.2%	45.4%	50.8%
VA Existing	5300 Base Monitor, LCD	78.6%	42.2%	48.4%	91.8%	75.3%	93.3%	77.7%	87.1%	94.9%	95.9%	89.1%	77.7%
VA Existing	5301 Energy Star or Better Monitor - LCD	78.6%	42.2%	48.4%	91.8%	75.3%	93.3%	77.7%	87.1%	94.9%	95.9%	89.1%	77.7%
VA Existing	5302 Monitor Power Management Enabling - LCD	78.6%	42.2%	48.4%	91.8%	75.3%	93.3%	77.7%	87.1%	94.9%	95.9%	89.1%	77.7%
VA Existing	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	78.6%	42.2%	48.4%	91.8%	75.3%	93.3%	77.7%	87.1%	94.9%	95.9%	89.1%	77.7%
VA Existing	5400 Base Copier	96.6%	44.8%	87.1%	29.0%	89.4%	98.6%	99.3%	93.6%	95.2%	97.4%	98.4%	85.8%
VA Existing	5401 Energy Star or Better Copier	96.6%	44.8%	87.1%	29.0%	89.4%	98.6%	99.3%	93.6%	95.2%	97.4%	98.4%	85.8%
VA Existing	5402 Copier Power Management Enabling	96.6%	44.8%	87.1%	29.0%	89.4%	98.6%	99.3%	93.6%	95.2%	97.4%	98.4%	85.8%
VA Existing	5500 Base Multifunction	96.6%	78.2%	81.5%	84.0%	93.9%	97.9%	83.6%	93.3%	90.1%	96.8%	90.8%	86.2%
VA Existing	5501 Multifunction Power Management Enabling 5502 ENERGY STAR Multi-Function Printer	96.6% 96.6%	78.2% 78.2%	81.5% 81.5%	84.0%	93.9%	97.9%	83.6% 83.6%	93.3% 93.3%	90.1%	96.8%	90.8%	86.2%
VA Existing VA Existing	5502 ENERGY STAR Multi-Function Printer 5600 Base Printer	96.6% 95.4%	78.2% 30.3%	81.5% 51.1%	84.0% 17.4%	93.9% 83.1%	97.9% 98.6%	83.6% 82.5%	93.3% 42.8%	90.1% 69.0%	96.8% 91.7%	90.8% 53.1%	86.2% 71.0%
	JOOU DASE FILIREI	90.4%	30.3%	J1.176	17.4%	03.1%	30.070	02.5%	42.0%	09.0%	91.7%	33.1%	/ 1.0%

Commercial Elec N	Measure Inputs	APPLICABILI	TY FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery		Education	Health	Lodging		Non-Jurisdictional	Religious Worship	Misc
VA Existing	5602 ENERGY STAR Printer	95.4%	30.3%	51.1%	17.4%	83.1%	98.6%	82.5%	42.8%	69.0%	91.7%	53.1%	71.0%
VA Existing	5700 Base Data Center/Server Room	0.2%	0.1%	0.0%	0.0%	0.1%	0.4%	0.3%	0.2%	100.0%	0.2%	0.1%	0.1%
/A Existing /A Existing	5701 Data Center Improved Operations 5702 Data Center Best Practices	0.2%	0.1% 0.1%	0.0%	0.0%	0.1%	0.4%	0.3%	0.2% 0.2%	100.0% 100.0%	0.2% 0.2%	0.1%	0.1% 0.1%
/A Existing /A Existing	5702 Data Center Best Practices 5703 Data Center State of the Art practices	0.2%	0.1%	0.0%	0.0%	0.1%	0.4%	0.3%	0.2%	100.0%	0.2%	0.1%	0.1%
/A Existing /A Existing	5704 Data Center State of the Art practices 5704 Data Center Airflow Management	0.2%	0.1%	0.0%	0.0%	0.1%	0.4%	0.3%	0.2%	100.0%	0.2%	0.1%	0.1%
/A Existing	6000 Base Water Heating	88.9%	39.3%	62.5%	77.9%	82.6%	72.5%	55.4%	31.2%	88.9%	38.7%	71.5%	50.8%
VA Existing	6001 Demand controlled circulating systems	88.9%	39.3%	62.5%	77.9%	82.6%	72.5%	55.4%	31.2%	88.9%	38.7%	71.5%	50.8%
VA Existing	6002 High Efficiency Water Heater (electric)	88.9%	39.3%	62.5%	77.9%	82.6%	72.5%	55.4%	31.2%	88.9%	38.7%	71.5%	50.8%
VA Existing	6003 Hot Water Pipe Insulation	88.9%	39.3%	62.5%	77.9%	82.6%	72.5%	55.4%	31.2%	88.9%	38.7%	71.5%	50.8%
/A Existing	6004 Tankless Water Heater	88.9%	39.3%	62.5%	77.9%	82.6%	72.5%	55.4%	31.2%	88.9%	38.7%	71.5%	50.8%
VA Existing	6005 Heat Pump Water Heater (air source)	88.9%	39.3%	62.5%	77.9%	82.6%	72.5%	55.4%	31.2%	88.9%	38.7%	71.5%	50.8%
VA Existing	6006 Heat Recovery Unit	88.9%	39.3%	62.5%	77.9%	82.6%	72.5%	55.4%	31.2%	88.9%	38.7%	71.5%	50.8%
VA Existing	6007 Heat Trap	88.9% 88.9%	39.3% 39.3%	62.5% 62.5%	77.9% 77.9%	82.6% 82.6%	72.5% 72.5%	55.4% 55.4%	31.2% 31.2%	88.9% 88.9%	38.7% 38.7%	71.5% 71.5%	50.8% 50.8%
VA Existing VA Existing	6008 Solar Water Heater 7000 Base Refrigerated Vending Machines	99.3%	100.0%	90.1%	98.3%	98.6%	100.0%	98.6%	95.7%	100.0%	98.1%	100.0%	97.0%
/A Existing	7000 Base Refrigerated vertaining infact lines 7001 Vending Misers (Refrigerated units)	49.7%	50.0%	45.0%	49.1%	49.3%	50.0%	49.3%	47.8%	50.0%	49.1%	50.0%	48.5%
VA Existing	7002 Vending Misers (Refrigerated data) 7002 Vending Misers (Refrigerated glass-front units)	49.7%	50.0%	45.0%	49.1%	49.3%	50.0%	49.3%	47.8%	50.0%	49.1%	50.0%	48.5%
/A Existing	7100 Base Non-Refrigerated Vending Machines	78.1%	88.4%	53.8%	11.4%	95.2%	70.9%	74.4%	31.5%	100.0%	67.9%	3.4%	46.6%
VA Existing	7101 Vending Misers (Non-Refrigerated)	78.1%	88.4%	53.8%	11.4%	95.2%	70.9%	74.4%	31.5%	100.0%	67.9%	3.4%	46.6%
VA Existing	7200 Base Oven	1.7%	15.1%	3.5%	55.7%	15.0%	7.6%	4.5%	20.4%	0.1%	22.2%	49.4%	4.5%
/A Existing	7201 Convection Oven	1.7%	15.1%	3.5%	55.7%	15.0%	7.6%	4.5%	20.4%	0.1%	22.2%	49.4%	4.5%
VA Existing	7300 Base Fryer	1.3%	19.1%	1.3%	49.1%	10.9%	11.2%	2.5%	19.2%	0.1%	13.0%	1.4%	4.5%
VA Existing	7301 Efficient Fryer	1.3%	19.1%	1.3%	49.1%	10.9%	11.2%	2.5%	19.2%	0.1%	13.0%	1.4%	4.5%
VA Existing	7400 Base Steamer	1.0%	15.3%	1.3%	41.9%	10.9%	1.1%	4.5%	7.0%	0.1%	16.3%	2.7%	2.4%
VA Existing	7401 Efficient Steamer	1.0%	15.3%	1.3%	41.9%	10.9%	1.1%	4.5%	7.0%	0.1%	16.3%	2.7%	2.4%
/A Existing	8000 Base Heating, Heat Pump (7.7 HSPF)	34.7%	7.6%	7.7%	3.1%	1.5%	17.2%	22.8%	25.4%	0.0%	6.2%	5.7%	22.4%
/A Existing /A Existing	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	34.7% 35.1%	7.6% 21.1%	7.7% 28.1%	3.1% 76.2%	1.5% 12.0%	17.2% 0.0%	22.8% 32.1%	25.4% 20.3%	0.0% 41.2%	6.2% 13.9%	5.7% 46.4%	22.4% 20.8%
/A Existing	9500 Base Miscellaneous	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
VA Existing	9501 Xmisc	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%
NC Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1003 ROB 4L4'T5, 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1004 ROB 4L4' LED Tube, 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015 1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	0.9% 80.4%	0.1% 4.1%	0.0% 50.7%	0.1% 61.7%	0.0% 86.4%	0.7% 10.6%	3.8% 53.6%	0.1% 1.9%	0.0% 45.8%	0.0% 47.9%	0.0% 13.2%	0.0% 9.2%
NC Existing NC Existing	1007 Occupancy Sensor, 4L4 Fluorescent Fixtures, 2014-2015 1008 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8% 45.8%	47.9% 47.9%	13.2%	9.2%
NC Existing	1010 Base Fluorescent Fixture, 4L4T8, 1EB, 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
IC Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
IC Existing	1013 ROB 4L4'T5, 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
IC Existing	1014 ROB 4L4' LED Tube, 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
IC Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	0.9%	0.1%	0.0%	0.1%	0.0%	0.7%	3.8%	0.1%	0.0%	0.0%	0.0%	0.0%
IC Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
IC Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
C Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
IC Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
IC Existing IC Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019 1023 ROB 4L4'T5, 2018-2019	80.4% 80.4%	4.1% 4.1%	50.7% 50.7%	61.7% 61.7%	86.4% 86.4%	10.6% 10.6%	53.6% 53.6%	1.9% 1.9%	45.8% 45.8%	47.9% 47.9%	13.2% 13.2%	9.2% 9.2%
IC Existing	1024 ROB 4L4 LED Tube. 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9% 47.9%	13.2%	9.2%
IC Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9% 47.9%	13.2%	9.2%
NC Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	0.9%	0.1%	0.0%	0.1%	0.0%	0.7%	3.8%	0.1%	0.0%	0.0%	0.0%	0.0%
NC Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
IC Existing	1033 ROB 4L4'T5, 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1034 ROB 4L4' LED Tube, 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%

Commercial Elec N	leasure Inputs	APPLICABILI	TY FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Contor	Non-Jurisdictional	Religious Worship	Misc
NC Existing	1035 LED Troffer (base 4L4T8), 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	0.9%	0.1%	0.0%	0.1%	0.0%	0.7%	3.8%	0.1%	0.0%	0.0%	0.0%	0.0%
NC Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	47.9%	13.2%	9.2%
NC Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1103 ROB 2L4'T5, 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1104 ROB 2L4' LED Tube, 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	0.0%	1.0%	0.0%	0.0%	0.0%	0.1%	1.0%	0.7%	0.0%	0.0%	0.0%	0.0%
NC Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1110 Base Fluorescent Fixture, 2L4T8, 1EB, 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1113 ROB 2L4'T5, 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1114 ROB 2L4' LED Tube, 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1115 LED Troffer (base 2L4T8), 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	0.0%	1.0%	0.0%	0.0%	0.0%	0.1%	1.0%	0.7%	0.0%	0.0%	0.0%	0.0%
NC Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1123 ROB 2L4'T5, 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1124 ROB 2L4' LED Tube, 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	0.0%	1.0%	0.0%	0.0%	0.0%	0.1%	1.0%	0.7%	0.0%	0.0%	0.0%	0.0%
NC Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%
NC Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	13.7%	12.5%	8.7%

		ENEDOVICA											
Commercial Elec	Measure Inputs	ENERGY SAV (percent)	INGS										
		(por com)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centers	Non-Jurisdictional	Religious Worship	Misc
VA Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	10%	10%	10%	10%	10% 22%	10%	10%	10%	10%	10%	10%	10%
VA Existing VA Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015 1003 ROB 4L4'T5, 2014-2015	22% 12%	22% 12%	22% 12%	22% 12%	12%	22% 12%	22% 12%	22% 12%	22% 12%	22% 12%	22% 12%	22% 12%
VA Existing VA Existing	1003 ROB 4L4 15, 2014-2015 1004 ROB 4L4' LED Tube, 2014-2015	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
VA Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	20%
VA Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
VA Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing VA Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017 1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	10% 22%	10% 22%	10% 22%	10% 22%	10% 22%	10% 22%	10% 22%	10% 22%	10% 22%	10% 22%	10% 22%	10% 22%
VA Existing VA Existing	1013 ROB 4L4 Low Wall right Performance to (75 W), 2016-2017	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
VA Existing	1014 ROB 4L4' LED Tube, 2016-2017	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
VA Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	20%
VA Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
VA Existing	1020 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
VA Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	22% 12%	22% 12%	22% 12%	22% 12%	22%	22%	22%	22%	22%	22% 12%	22% 12%	22% 12%
VA Existing VA Existing	1023 ROB 4L4'T5, 2018-2019 1024 ROB 4L4' LED Tube, 2018-2019	12% 34%	34%	34%	34%	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%	34%	12% 34%	34%
VA Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	20%
VA Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
VA Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
VA Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%
VA Existing VA Existing	1033 ROB 4L4'T5, 2020 1034 ROB 4L4' LED Tube, 2020	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%	12% 34%
VA Existing VA Existing	1035 LED Troffer (base 4L4'T8), 2020	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing VA Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	20%
VA Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
VA Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
VA Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%
VA Existing	1103 ROB 2L4'T5, 2014-2015	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
VA Existing	1104 ROB 2L4' LED Tube, 2014-2015	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
VA Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing VA Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	30% 25%	20% 25%	30% 25%	25% 25%	20% 25%	20% 25%						
VA Existing VA Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015 1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	25%	25% 0%	25%	25%	25%	25%	25% 0%	25%	25%	25%	25%	25%
VA Existing VA Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
VA Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%
VA Existing	1113 ROB 2L4'T5, 2016-2017	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
VA Existing	1114 ROB 2L4' LED Tube, 2016-2017	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
VA Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	20%
VA Existing VA Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017 1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	25%	25% 0%	25% 0%	25% 0%	25% 0%							
VA Existing VA Existing	1120 Base Fluorescent Fixture, 2L4 18, 1EB, 2018-2019 1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
VA Existing VA Existing	1122 ROB 2L4' High Performance To (86 W), 2016-2019 1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%
VA Existing	1123 ROB 2L4'T5, 2018-2019	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
VA Existing	1124 ROB 2L4' LED Tube, 2018-2019	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
VA Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	20%

Commercial Elec	: Measure Inputs	ENERGY SA	VINGS										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centers	Non-Jurisdictional	Religious Worship	Misc
VA Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
VA Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1131 ROB 2L4' High Performance T8 (86 W), 2020	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
VA Existing	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1133 ROB 2L4'T5, 2020	22% 12%	22% 12%	22% 12%	22% 12%	22% 12%	22% 12%	22%	22% 12%	22% 12%	22% 12%	22% 12%	22% 12%
VA Existing VA Existing	1134 ROB 2L4' LED Tube, 2020	12%	34%	34%	34%	34%	34%	12% 34%	34%	34%	34%	34%	34%
VA Existing VA Existing	1135 LED Troffer (base 2L4'T8), 2020	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing	1136 Lighting Control Tuneup (base 2L4'T8), 2020	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	20%
VA Existing	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
VA Existing	1200 Base Other Fluorescent Fixture	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1201 ROB High Performance T8 (base other fluorescent)	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
VA Existing	1202 ROB Low Watt High Performance T8 (base other fluorescent)	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%
VA Existing	1203 Lighting Control Tuneup (base other fluorescent fixture)	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
VA Existing	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	52% 25%	52% 25%	52% 25%	52% 25%								
VA Existing VA Existing	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	25%	0%	0%	0%	0%	0%	0%	0%	0%	25%	0%	0%
VA Existing VA Existing	1301 CFLs (base incandescent flood) 2014-2015	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%
VA Existing	1302 LEDs (base incandescent flood) 2014-2015	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%
VA Existing	1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1311 CFLs (base incandescent flood) 2016-2017	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%
VA Existing	1312 LEDs (base incandescent flood) 2016-2017	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1321 CFLs (base incandescent flood) 2018-2019	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%	77%
VA Existing	1322 LEDs (base incandescent flood) 2018-2019	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%	83%
VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	0%	0%	0%	0%	0%	0%	0%	0%	0% 77%	0%	0%	0%
VA Existing VA Existing	1331 CFLs (base incandescent flood) 2020 1332 LEDs (base incandescent flood) 2020	77% 83%	77% 83%	77% 83%	77% 83%								
VA Existing VA Existing	1400 Base Incandescent Roud) 2020 1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	0%	0%	03%	0%	0%	0%	03%	03%	03%	0%	0%	0%
VA Existing	1401 CFLs (base incandescent A-line 72W) 2014-2015	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%
VA Existing	1402 LEDs (base incandescent A-line 72W) 2014-2015	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%
VA Existing	1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1411 CFLs (base incandescent A-line 72W) 2016-2017	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%
VA Existing	1412 LEDs (base incandescent A-line 72W) 2016-2017	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%
VA Existing	1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1421 CFLs (base incandescent A-line 72W) 2018-2019	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%
VA Existing	1422 LEDs (base incandescent A-line 72W) 2018-20191430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	82% 0%	82% 0%	82% 0%	82% 0%								
VA Existing VA Existing	1430 Base incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1431 CFLs (base incandescent A-line 72W) 2020	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%	74%
VA Existing	1432 LEDs (base incandescent A-line 72W) 2020	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%
VA Existing	1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1501 CFLs (base incandescent A-line 53W) 2014-2015	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%
VA Existing	1502 LEDs (base incandescent A-line 53W) 2014-2015	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%
VA Existing	1510 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1511 CFLs (base incandescent A-line 53W) 2016-2017	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%
VA Existing	1512 LEDs (base incandescent A-line 53W) 2016-2017	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%
VA Existing	1520 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	0% 66%	0% 66%	0% 66%	0% 66%	0% 66%	0% 66%	0%	0% 66%	0% 66%	0% 66%	0% 66%	0% 66%
VA Existing VA Existing	1521 CFLs (base incandescent A-line 53W) 2018-2019 1522 LEDs (base incandescent A-line 53W) 2018-2019	75%	75%	75%	75%	75%	75%	66% 75%	75%	75%	75%	75%	75%
VA Existing VA Existing	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1531 CFLs (base incandescent A-line 53W) 2020	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%
VA Existing	1532 LEDs (base incandescent A-line 53W) 2020	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%
VA Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1601 LED screw-in replacement (base CFL 18W) 2014-2015	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%
VA Existing	1610 Base CFL 18W to screw-in replacement 2016-2017	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1611 LED screw-in replacement (base CFL 18W) 2016-2017	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%
VA Existing	1620 Base CFL 18W to screw-in replacement 2018-2019	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1621 LED screw-in replacement (base CFL 18W) 2018-2019	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%	28%
VA Existing	1630 Base CFL 18W to screw-in replacement 2020	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing VA Existing	1631 LED screw-in replacement (base CFL 18W) 2020 1700 Base CFL 23W to screw-in replacement 2014-2015	28% 0%	28% 0%	28% 0%	28% 0%								
VA Existing VA Existing	1700 Base CFL 23W to screw-in replacement 2014-2015 1701 LED screw-in replacement (base CFL 23W) 2014-2015	26%	26%	26%	26%	26%	26%	26%	26%	26%	26%	26%	26%
VA Existing	1710 Base CFL 23W to screw-in replacement 2016-2017	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
3		***	,,,			,,,,			- /-		-,-		

Commercial Elec	Measure Inputs	ENERGY SAV	/INGS										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health			Non-Jurisdictional	Religious Worship	Misc
VA Existing VA Existing	1711 LED screw-in replacement (base CFL 23W) 2016-2017 1720 Base CFL 23W to screw-in replacement 2018-2019	26% 0%	26% 0%	26% 0%	26% 0%	26% 0%	26% 0%	26% 0%	26% 0%	26% 0%	26% 0%	26% 0%	26% 0%
VA Existing VA Existing	1721 LED screw-in replacement (base CFL 23W) 2018-2019	26%	26%	26%	26%	26%		26%	26%	26%	26%	26%	26%
VA Existing	1730 Base CFL 23W to screw-in replacement 2020	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1731 LED screw-in replacement (base CFL 23W) 2020	26%	26%	26%	26%	26%		26%	26%	26%	26%	26%	26%
VA Existing	1800 BaseMetal Halide, 465W	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	1801 T5 (240W) (base metal halide)	48%	48%	48%	48%	48%	48%	48%	48%	48%	48%	48%	48%
VA Existing	1802 Induction High Bay Lighting	37%	37%	37%	37%	37%	37%	37%	37%	37%	37%	37%	37%
VA Existing	1803 PSMH + electronic ballast	43%	43%	43%	43%	43%	43%	43%	43%	43%	43%	43%	43%
VA Existing	1804 PSMH, magnetic ballast, 320 W	31%	31%	31%	31%	31%		31%	31%	31%	31%	31%	31%
VA Existing	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	25%	25%	25%	25%	25%		25%	25%	25%	25%	25%	25%
VA Existing	1806 Occupancy Sensor, High Bay T5 1850 Base CFL Exit Sign	20%	20% 0%	20% 0%	20% 0%	20% 0%		20%	20% 0%	20% 0%	20% 0%	20% 0%	20% 0%
VA Existing VA Existing	1851 LED Exit Sign	69%	69%	69%	69%	69%		69%	69%	69%	69%	69%	69%
VA Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp	0%	0%	0%	0%	0%		09%	09%	09%	0%	0%	0%
VA Existing	1901 Outdoor Lighting Controls (Photocell/Timeclock)	22%	22%	22%	22%	22%		22%	22%	22%	22%	22%	22%
VA Existing	1902 LED Outdoor Area Lighting	52%	52%	52%	52%	52%		52%	52%	52%	52%	52%	52%
VA Existing	1903 Bi-Level LED Outdoor Lighting	70%	70%	70%	70%	70%		70%	70%	70%	70%	70%	70%
VA Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
VA Existing	2002 Window Film (Standard) - Chiller	9%	10%	2%	9%	12%		1%	7%	9%	5%	1%	1%
VA Existing	2003 EMS - Chiller	10%	10%	10%	10%	10%		10%	10%	10%	10%	10%	10%
VA Existing	2004 Cool Roof - Chiller	2%	7%	13%	15%	18%		1%	0%	2%	1%	0%	0%
VA Existing	2005 Chiller Tune Up/Diagnostics	8%	8%	8%	8%	8%	8%	8%	8%	8%	8%	8%	8%
VA Existing	2006 VSD for Chiller Pumps and Towers	10% 5%	10% 5%	10% 5%	10% 5%	10% 5%		10% 5%	10% 5%	10% 5%	10% 5%	10% 5%	10% 5%
VA Existing VA Existing	2007 EMS Optimization - Chiller 2008 New Economizer - Chiller	27%	5% 0%	21%	5% 0%	5% 0%		18%	43%	27%	14%	0%	5% 0%
VA Existing VA Existing	2009 Dual Enthalpy Economizer Replaced Dry Bulb Economizer - Chiller	0%	0%	0%	0%	0%		0%	0%	0%	0%	0%	0%
VA Existing	2010 Ceiling/roof Insulation - Chiller	12%	12%	12%	12%	12%		12%	12%	12%	12%	12%	12%
VA Existing	2011 Duct/Pipe Insulation - Chiller	2%	2%	2%	2%	2%		2%	2%	2%	2%	2%	2%
VA Existing	2012 Duct Testing/Sealing	19%	19%	19%	19%	19%		19%	19%	19%	19%	19%	19%
VA Existing	2013 High Efficiency Chiller Motors	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%
VA Existing	2100 Base DX Packaged System, EER=10.3, 10 tons	0%	0%	0%	0%	0%		0%	0%	0%	0%	0%	0%
VA Existing	2101 DX Packaged System, EER=10.9, 10 tons	6%	6%	6%	6%	6%		6%	6%	6%	6%	6%	6%
VA Existing	2102 DX Packaged System, EER=13.4, 10 tons	23%	23%	23%	23%	23%		23%	23%	23%	23%	23%	23%
VA Existing	2103 Geothermal Heat Pump, EER=13, 10 tons - DX	21%	21%	21%	21%	21%		21%	21%	21%	21%	21%	21%
VA Existing VA Existing	2104 DX Coil Cleaning	5% 5%	5% 5%	5% 5%	5% 5%	5% 5%		5% 5%	5% 5%	5% 5%	5% 5%	5% 5%	5% 5%
VA Existing VA Existing	2105 DX Tune Up/ Advanced Diagnostics 2106 Prog. Thermostat - DX	5% 5%	5% 5%	5% 5%	5% 5%	5% 5%		5% 5%	5% 5%	5% 5%	5% 5%	5% 5%	5% 5%
VA Existing	2107 Cool Roof - DX	2%	7%	13%	15%	18%		1%	0%	2%	1%	0%	0%
VA Existing	2108 Optimize Controls - DX	5%	5%	5%	5%	5%		5%	5%	5%	5%	5%	5%
VA Existing	2109 Economizer - DX	28%	12%	27%	2%	0%		0%	4%	28%	14%	0%	0%
VA Existing	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	3%	3%	4%	1%	3%		0%	1%	3%	2%	0%	0%
VA Existing	2111 Economizer Repair - DX	28%	12%	27%	2%	0%	5%	0%	4%	28%	14%	0%	0%
VA Existing	2112 Aerosol Duct Sealing - DX	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%
VA Existing	2113 Ceiling/roof Insulation - DX	12%	12%	12%	12%	12%		12%	12%	12%	12%	12%	12%
VA Existing	2114 Duct/Pipe Insulation - DX	2%	2%	2%	2%	2%		2%	2%	2%	2%	2%	2%
VA Existing	2115 Window Film (Standard) - DX	9%	10%	2%	9%	12%		1%	7%	9%	5%	1%	1%
VA Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	0%	0%	0%	0%	0%		0%	0%	0%	0%	0%	0%
VA Existing	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	13%	13%	13% 0%	13% 0%	13%	13% 0%	13%	13% 0%	13% 0%	13%	13% 0%	13%
VA Existing VA Existing	2300 Base PTAC, EER=8.3, 1 ton 2301 HE PTAC, EER=9.6, 1 ton	14%	0% 14%	14%	14%	14%		0% 14%	14%	14%	14%	14%	14%
VA Existing VA Existing	2302 Occupancy Sensor (hotels)	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%
VA Existing	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	0%	0%	0%	0%	0%		0%	0%	0%	0%	0%	0%
VA Existing VA Existing	3001 Fan Motor, 5hp, 1800rpm, 89.5%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%
VA Existing	3002 Variable Speed Drive Control, 5 HP	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
VA Existing	3003 Demand Controlled Ventilation	15%	15%	15%	15%	15%		15%	15%	15%	15%	15%	15%
VA Existing	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	0%	0%	0%	0%	0%		0%	0%	0%	0%	0%	0%
VA Existing	3101 Fan Motor, 15hp, 1800rpm, 92.4%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%
VA Existing	3102 Variable Speed Drive Control, 15 HP	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
VA Existing	3103 Air Handler Optimization, 15 HP	10%	10%	10%	10%	10%		10%	10%	10%	10%	10%	10%
VA Existing	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	14%	14%	14%	14%	14%		14%	14%	14%	14%	14%	14%
VA Existing	3105 Energy Recovery Ventilation (ERV)	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%

Commercial Elec	Measure Inputs	ENERGY SA	VINGS										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health		Data Centers	Non-Jurisdictional	Religious Worship	Misc
VA Existing	3106 Separate Makeup Air / Exhaust Hoods AC	25%	25.0%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
VA Existing	3107 Demand Controlled Ventilation	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%
VA Existing	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	3201 Fan Motor, 40hp, 1800rpm, 94.1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%	1%
VA Existing VA Existing	3202 Variable Speed Drive Control, 40 HP 3203 Air Handler Optimization, 40 HP	30% 10%	30% 10%	30% 10%	30% 10%								
VA Existing VA Existing	3204 Demand Controlled Ventilation	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%
VA Existing	4000 Base Built-Up Refrigeration System	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	4001 High-efficiency fan motors	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
VA Existing	4002 Strip curtains for walk-ins (built-up)	4%	4%	4%	4%	4%	4%	4%	4%	4%	4%	4%	4%
VA Existing	4003 Auto-closer on main door to walk-in freezer (built-up)												
VA Existing	4004 Night covers for display cases	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%
VA Existing	4005 Evaporator fan controller for MT walk-ins	0.55%	0.55%	0.55%	0.32%	0.41%	0.55%	0.55%	0.55%	0.55%	0.55%	0.55%	0.55%
VA Existing	4006 Electronically commutated evaporator fan motor	11.8%	11.8%	11.8%	11.8%	11.8%	11.8%	11.8%	11.8%	11.8%	11.8%	11.8%	11.8%
VA Existing	4007 Efficient compressor motor	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%
VA Existing	4008 Compressor VSD retrofit	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%
VA Existing	4009 Floating head pressure controls	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%
VA Existing	4010 Refrigeration Commissioning	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	4011 Demand Hot Gas Defrost	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%	3%
VA Existing VA Existing	4012 Demand Defrost Electric 4013 Anti-sweat (humidistat) controls	8% 5%	8% 5%	8% 5%	8% 5%								
VA Existing VA Existing	4014 Freezer-Cooler Replacement Gaskets	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%
VA Existing VA Existing	4014 Freezer-Cooler Replacement Gaskers 4015 High R-Value Glass Doors	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%
VA Existing	4016 LED Display Lighting	7.8%	7.8%	7.8%	7.8%	7.8%	7.8%	7.8%	7.8%	7.8%	7.8%	7.8%	7.8%
VA Existing	4017 Multiplex Compressor System	14%	14%	14%	14%	14%	14%	14%	14%	14%	14%	14%	14%
VA Existing	4018 Oversized Air Cooled Condenser	8%	8%	8%	8%	8%	8%	8%	8%	8%	8%	8%	8%
VA Existing	4019 Insulated suction lines												
VA Existing	4100 Base Self-Contained Refrigeration	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	4101 Strip curtains for walk-ins (self-contained)	0%	1%	1%	2%	4%	0%	0%	1%	0%	0%	0%	0%
VA Existing	4102 Auto-closer on main door to walk-in freezer (self-contained)												
VA Existing	4103 Night covers for display cases (self-contained)	9%	9%	9%	9%	9%	9%	9%	9%	9%	9%	9%	9%
VA Existing	4104 Freezer-Cooler Replacement Gaskets (self-contained)	4%	3%	4%	3%	0%	3%	3%	3%	4%	3%	3%	3%
VA Existing	4105 Bi-level LED Case Lighting (self-contained units) 2014	0.2%	0.3%	3.4%	0.7%	0.0%	0.2%	0.4%	0.1%	0.2%	0.1%	0.2%	0.1%
VA Existing	4106 Energy-Star Refrigerator, solid door	3% 1%	3% 1%	2% 1%	0% 3%	0% 0%	5% 1%	5% 0%	2% 3%	3% 1%	4% 0%	6% 0%	6% 0%
VA Existing	4107 Energy-Star Freezer, solid door			10%	3% 0%				3% 0%	7%	5%	2%	2%
VA Existing VA Existing	4108 Energy-Star Refrigerator, glass door 4109 Energy-Star Freezer, glass door	7% 2%	2% 3%	3%	8%	0% 0%	1% 2%	4% 0%	6%	2%	1%	0%	0%
VA Existing	4110 Energy Star Incezer, glass door	2%	2%	1%	0%	0%		4%	1%	2%	3%	4%	4%
VA Existing	4111 Hydraulic-type door closer on reach-in cooler glass doors	270	2,0	1,0	070	0,0	0,0	170	1,0	270	0,0	170	.,,
VA Existing	4112 Reach-in unit occupancy sensors	0.1%	0.1%	1.8%	0.03%	0.0%	0.0%	0.1%	0.0%	0.1%	0.0%	0.0%	0.0%
VA Existing	5000 Base Desktop PC	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	5001 PC Network Power Management Enabling	68%	68%	68%	68%	68%	68%	68%	68%	68%	68%	68%	68%
VA Existing	5002 Energy Star or Better PC	33%	33%	33%	33%	33%	33%	33%	33%	33%	33%	33%	33%
VA Existing	5003 Plug-load controls - Commercial Smart Strip (base desktop PC)	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	5100 Base Laptop PC	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	5101 Laptop Network Power Management Enabling	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%	7%
VA Existing	5102 Energy Star or Better Laptop	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
VA Existing VA Existing	5103 Plug-load controls - Commercial Smart Strip (base Laptop PC) 5200 Base Monitor, CRT	0% 0%	0% 0%	0% 0%	0% 0%								
VA Existing VA Existing	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	56%	56%	56%	56%	56%		56%	56%	56%	56%	56%	56%
VA Existing VA Existing	5202 Monitor Power Management Enabling - CRT	53%	53%	53%	53%	53%	53%	53%	53%	53%	53%	53%	53%
VA Existing	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%
VA Existing	5300 Base Monitor, LCD	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	5301 Energy Star or Better Monitor - LCD	21%	21%	21%	21%	21%	21%	21%	21%	21%	21%	21%	21%
VA Existing	5302 Monitor Power Management Enabling - LCD	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%
VA Existing	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%	15%
VA Existing	5400 Base Copier	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	5401 Energy Star or Better Copier	21%	21%	21%	21%	21%	21%	21%	21%	21%	21%	21%	21%
VA Existing	5402 Copier Power Management Enabling	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%	19%
VA Existing	5500 Base Multifunction	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	5501 Multifunction Power Management Enabling	49%	49%	49%	49%	49%	49%	49%	49%	49%	49%	49%	49%
VA Existing	5502 ENERGY STAR Multi-Function Printer	40%	40%	40%	40% 0%	40% 0%	40% 0%	40% 0%	40% 0%	40%	40%	40%	40%
VA Existing	5600 Base Printer	0%	0%	0%						0%	0%	0%	0%

Commercial Elec	Measure Inputs	ENERGY SA	/INGS										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health			Non-Jurisdictional	Religious Worship	Misc
VA Existing	5601 Printer Power Management Enabling	49%	49%	49%	49%	49%	49%	49%	49%	49%	49%	49%	49%
VA Existing	5602 ENERGY STAR Printer	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
VA Existing	5700 Base Data Center/Server Room	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing VA Existing	5701 Data Center Improved Operations 5702 Data Center Best Practices	20% 45%	20% 45%	20% 45%									
VA Existing VA Existing	5703 Data Center State of the Art practices	45% 56%	45% 56%	56%	56%	45% 56%		45% 56%	56%	56%	56%	45% 56%	56%
VA Existing VA Existing	5704 Data Center State of the Art practices 5704 Data Center Airflow Management	30 /8	3076	30 /6	30 /6	30 /6	30 /6	30 /8	30 /8	3076	30 /6	3076	3076
VA Existing	6000 Base Water Heating	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	6001 Demand controlled circulating systems	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	6002 High Efficiency Water Heater (electric)	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%
VA Existing	6003 Hot Water Pipe Insulation	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%	2%
VA Existing	6004 Tankless Water Heater	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
VA Existing	6005 Heat Pump Water Heater (air source)	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%	20%
VA Existing	6006 Heat Recovery Unit	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%	65%
VA Existing	6007 Heat Trap	9%	9%	9%	9%	9%	9%	9%	9%	9%	9%	9%	9%
VA Existing	6008 Solar Water Heater	70%	70%	70% 0%	70%	70% 0%	70% 0%	70% 0%	70% 0%	70% 0%	70% 0%	70% 0%	70%
VA Existing VA Existing	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	46%	0% 46%	46%	0% 46%	46%	46%	46%	46%	46%	46%	46%	0% 46%
VA Existing VA Existing	7002 Vending Misers (Refrigerated dints) 7002 Vending Misers (Refrigerated glass-front units)	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
VA Existing	7100 Base Non-Refrigerated Vending Machines	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	7101 Vending Misers (Non-Refrigerated)	46%	46%	46%	46%	46%	46%	46%	46%	46%	46%	46%	46%
VA Existing	7200 Base Oven	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	7201 Convection Oven	23%	23%	23%	23%	23%	23%	23%	23%	23%	23%	23%	23%
VA Existing	7300 Base Fryer	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	7301 Efficient Fryer	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%	6%
VA Existing	7400 Base Steamer	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	7401 Efficient Steamer	69%	69%	69%	69%	69%	69%	69%	69%	69%	69%	69%	69%
VA Existing	8000 Base Heating, Heat Pump (7.7 HSPF)	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	6% 0%	6%	6% 0%	6% 0%	6%	6% 0%	6%	6%	6% 0%	6%	6% 0%	6%
VA Existing	8100 Base Heating, Other Electric 9500 Base Miscellaneous	0%	0% 0%	0%	0%	0% 0%	0%	0% 0%	0% 0%	0%	0%	0%	0% 0%
VA Existing VA Existing	9501 Xmisc	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
NC Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
NC Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
NC Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%
NC Existing	1003 ROB 4L4'T5, 2014-2015	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
NC Existing	1004 ROB 4L4' LED Tube, 2014-2015	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
NC Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
NC Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
NC Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	30%	20%	20%	20%	20%		20%	20%	30%	25%	20%	20%
NC Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
NC Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	0% 10%	0% 10%	0% 10%									
NC Existing NC Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017 1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	10%	22%
NC Existing	1013 ROB 4L4 LOW Wall Fight Performance To (75 W), 2010-2017	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
NC Existing	1014 ROB 4L4' LED Tube, 2016-2017	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
NC Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%
NC Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
NC Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	20%
NC Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%
NC Existing	1020 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
NC Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
NC Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%
NC Existing	1023 ROB 4L4'T5, 2018-2019	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%
NC Existing	1024 ROB 4L4' LED Tube, 2018-2019	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%
NC Existing NC Existing	1025 LED Troffer (base 4L4'T8), 2018-2019 1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	40% 5%	40% 5%	40% 5%									
NC Existing NC Existing	1026 Lighting Control Luneup (base 4L4 18), 2018-2019 1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	30%	20%	5% 20%	20%	5% 20%	20%	5% 20%	5% 20%	30%	5% 25%	5% 20%	20%
NC Existing NC Existing	1027 Occupancy Sensor, 4L4 Fluorescent Fixtures, 2018-2019 1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	30% 25%	20% 25%	25%	25%	20% 25%	20%	20% 25%	25%	30% 25%	25% 25%	20%	20%
NC Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	25%	0%	0%	0%	25%	0%	0%	0%	0%	25%	25%	0%
NC Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%
NC Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%
NC Existing	1033 ROB 4L4'T5, 2020	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%

ommercial Elec	Measure Inputs	ENERGY SA (percent)	VINGS										
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centers	Non-Jurisdictional	Religious Worship	Misc
C Existing	1034 ROB 4L4' LED Tube, 2020	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	
CExisting	1035 LED Troffer (base 4L4'T8), 2020	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	
C Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	
C Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	
C Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	
CExisting	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
C Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	
C Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	
CExisting	1103 ROB 2L4'T5, 2014-2015	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	
C Existing	1104 ROB 2L4' LED Tube, 2014-2015	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	
C Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	
Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	
Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	
Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	
Existing	1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	
Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	
Existing	1113 ROB 2L4'T5, 2016-2017	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	
Existing	1114 ROB 2L4' LED Tube, 2016-2017	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	
C Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	
Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	
Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	
Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	
Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	
Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	10%	
Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	22%	
Existing	1123 ROB 2L4'T5, 2018-2019	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	12%	
C Existing	1124 ROB 2L4' LED Tube, 2018-2019	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	34%	
Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	40%	
C Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	
C Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	30%	20%	20%	20%	20%	20%	20%	20%	30%	25%	20%	
C Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	25%	
C Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	0%	0%	0%	0%		0%	0%	0%	0%	0%	0%	

Commercial Elec	Measure Inputs		djustment Facto	or									
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centerຄ-	Jurisdictidigiou	ıs Wors	Misc
VA Existing	1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	94%	92%	93%	85%	96%	93%	90%		96%	96%	89%	89%
VA Existing	1003 ROB 4L4'T5, 2014-2015	94%	92%	93%	85%	96%	93%	90%	95%		96%	89%	89%
VA Existing VA Existing	1004 ROB 4L4' LED Tube, 2014-2015 1005 LED Troffer (base 4L4'T8), 2014-2015	94% 94%	92% 92%	93% 93%	85% 85%	96% 96%	93% 93%	90% 90%	95% 95%	96% 96%	96% 96%	89% 89%	89% 89%
VA Existing VA Existing	1006 Lighting Control Tuneup (base 4L4T8), 2014-2015	94%	92%	93%	85%	96%	93%	90%	95% 95%	96%	96%	89%	89%
VA Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2014-2015	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	94%	92%	93%	85%	96%	93%	90%		96%	96%	89%	89%
VA Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1013 ROB 4L4'T5, 2016-2017	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1014 ROB 4L4' LED Tube, 2016-2017	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1020 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	94% 94%	92% 92%	93% 93%	85%	96%	93%	90% 90%	95%	96% 96%	96%	89%	89%
VA Existing VA Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019 1023 ROB 4L4'T5, 2018-2019	94%	92%	93%	85% 85%	96% 96%	93% 93%	90%	95% 95%	96%	96% 96%	89% 89%	89% 89%
VA Existing VA Existing	1024 ROB 4L4' LED Tube. 2018-2019	94%	92%	93%	85%	96%	93%	90%	95%		96%	89%	89%
VA Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1033 ROB 4L4'T5, 2020	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1034 ROB 4L4' LED Tube, 2020	94%	92%	93%	85%	96%	93%	90%		96%	96%	89%	89%
VA Existing	1035 LED Troffer (base 4L4'T8), 2020	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	94%	92%	93%	85%	96%	93%	90%	95%	96%	96%	89%	89%
VA Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	94% 94%	92% 92%	93% 93%	85% 85%	96% 96%	93% 93%	90% 90%	95% 95%	96% 96%	96% 96%	89% 89%	89% 89%
VA Existing VA Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	98%	92% 97%	93%	93%	100%	93%	96%	95%	96%	96%	96%	96%
VA Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1103 ROB 2L4'T5, 2014-2015	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1104 ROB 2L4 LED Tube, 2014-2015	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	98%	97%	97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1106 Lighting Control Tuneup (base 2L4T8), 2014-2015	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	98%	97%	97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1113 ROB 2L4'T5, 2016-2017	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1114 ROB 2L4' LED Tube, 2016-2017	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	98%	97%	97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	98%	97%	97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1123 ROB 2L4'T5, 2018-2019	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%

Commercial Elec	Measure Inputs		djustment Facto	or									
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centerก-	Jurisdictidigio	ous Wors	Misc
VA Existing	1124 ROB 2L4' LED Tube, 2018-2019	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1131 ROB 2L4' High Performance T8 (86 W), 2020	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1133 ROB 2L4'T5, 2020	98%		97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1134 ROB 2L4' LED Tube, 2020	98%		97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1135 LED Troffer (base 2L4'T8), 2020	98%		97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1136 Lighting Control Tuneup (base 2L4'T8), 2020	98%		97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	98%		97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	98%	97%	97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1200 Base Other Fluorescent Fixture	98%		97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1201 ROB High Performance T8 (base other fluorescent)	98%		97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1202 ROB Low Watt High Performance T8 (base other fluorescent)	98%		97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1203 Lighting Control Tuneup (base other fluorescent fixture)	98%		97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	98%		97%	93%	100%	97%	96%	98%	99%	99%	96%	96%
VA Existing	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	98%		97%	93%	100%	97%	96%		99%	99%	96%	96%
VA Existing	1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1301 CFLs (base incandescent flood) 2014-2015	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1302 LEDs (base incandescent flood) 2014-2015	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	70%	70%	70%	70%	70%	70%	70%	70%		70%	70%	70%
VA Existing	1311 CFLs (base incandescent flood) 2016-2017	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1312 LEDs (base incandescent flood) 2016-2017	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%
VA Existing	1321 CFLs (base incandescent flood) 2018-2019	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%	70%
VA Existing	1322 LEDs (base incandescent flood) 2018-2019	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1331 CFLs (base incandescent flood) 2020	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1332 LEDs (base incandescent flood) 2020	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1401 CFLs (base incandescent A-line 72W) 2014-2015	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1402 LEDs (base incandescent A-line 72W) 2014-2015	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1411 CFLs (base incandescent A-line 72W) 2016-2017	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1412 LEDs (base incandescent A-line 72W) 2016-2017	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1421 CFLs (base incandescent A-line 72W) 2018-2019	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1422 LEDs (base incandescent A-line 72W) 2018-2019	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1431 CFLs (base incandescent A-line 72W) 2020	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1432 LEDs (base incandescent A-line 72W) 2020	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1501 CFLs (base incandescent A-line 53W) 2014-2015	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1502 LEDs (base incandescent A-line 53W) 2014-2015	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1510 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1511 CFLs (base incandescent A-line 53W) 2016-2017	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1512 LEDs (base incandescent A-line 53W) 2016-2017	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1520 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1521 CFLs (base incandescent A-line 53W) 2018-2019	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1522 LEDs (base incandescent A-line 53W) 2018-2019	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	70%		70%	70%	70%	70%	70%		70%	70%	70%	70%
VA Existing	1531 CFLs (base incandescent A-line 53W) 2020	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1532 LEDs (base incandescent A-line 53W) 2020	70%		70%	70%	70%	70%	70%			70%	70%	70%
VA Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1601 LED screw-in replacement (base CFL 18W) 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

Commercial Elec	Measure Inputs		djustment Fact	or									
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centerຄ-	Jurisdictidigio	us Wors	Misc
VA Existing	1610 Base CFL 18W to screw-in replacement 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1611 LED screw-in replacement (base CFL 18W) 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1620 Base CFL 18W to screw-in replacement 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1621 LED screw-in replacement (base CFL 18W) 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1630 Base CFL 18W to screw-in replacement 2020	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1631 LED screw-in replacement (base CFL 18W) 2020	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1700 Base CFL 23W to screw-in replacement 2014-2015	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	1701 LED screw-in replacement (base CFL 23W) 2014-2015	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1710 Base CFL 23W to screw-in replacement 2016-2017	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	1711 LED screw-in replacement (base CFL 23W) 2016-2017	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1720 Base CFL 23W to screw-in replacement 2018-2019	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1721 LED screw-in replacement (base CFL 23W) 2018-2019	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1730 Base CFL 23W to screw-in replacement 2020	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	1731 LED screw-in replacement (base CFL 23W) 2020	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1800 BaseMetal Halide, 465W	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	1801 T5 (240W) (base metal halide)	100% 100%		100%	100% 100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1802 Induction High Bay Lighting	100%		100% 100%	100%	100% 100%	100% 100%	100% 100%		100% 100%	100% 100%	100% 100%	100% 100%
VA Existing	1803 PSMH + electronic ballast	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing VA Existing	1804 PSMH, magnetic ballast, 320 W 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1806 Occupancy Sensor, High Bay T5	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	1850 Base CFL Exit Sign	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing VA Existing	1851 LED Exit Sign	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	1901 Outdoor Lighting Controls (Photocell/Timeclock)	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1902 LED Outdoor Area Lighting	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1903 Bi-Level LED Outdoor Lighting	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2002 Window Film (Standard) - Chiller	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2003 EMS - Chiller	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2004 Cool Roof - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2005 Chiller Tune Up/Diagnostics	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2006 VSD for Chiller Pumps and Towers	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2007 EMS Optimization - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2008 New Economizer - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2009 Dual Enthalpy Economizer Replaced Dry Bulb Economizer - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2010 Ceiling/roof Insulation - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2011 Duct/Pipe Insulation - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2012 Duct Testing/Sealing	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2013 High Efficiency Chiller Motors	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2100 Base DX Packaged System, EER=10.3, 10 tons	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2101 DX Packaged System, EER=10.9, 10 tons	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2102 DX Packaged System, EER=13.4, 10 tons	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2103 Geothermal Heat Pump, EER=13, 10 tons - DX	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2104 DX Coil Cleaning	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2105 DX Tune Up/ Advanced Diagnostics	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2106 Prog. Thermostat - DX	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2107 Cool Roof - DX	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2108 Optimize Controls - DX	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2109 Economizer - DX	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2111 Economizer Repair - DX	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2112 Aerosol Duct Sealing - DX	100%		100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2113 Ceiling/roof Insulation - DX	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2114 Duct/Pipe Insulation - DX	100%		100%	100%	100%	100%	100%			100%	100%	100%
VA Existing	2115 Window Film (Standard) - DX	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

Commercial Elec	Measure Inputs	Standards Ad (percent)	djustment Fact	or									
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodaina	Data Centers	Jurisdictidiai	ous Wors	Misc
VA Existing	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2300 Base PTAC, EER=8.3, 1 ton	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2301 HE PTAC, EER=9.6, 1 ton	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2302 Occupancy Sensor (hotels)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3001 Fan Motor, 5hp, 1800rpm, 89.5%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3002 Variable Speed Drive Control, 5 HP	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3003 Demand Controlled Ventilation	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3101 Fan Motor, 15hp, 1800rpm, 92.4%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3102 Variable Speed Drive Control, 15 HP	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3103 Air Handler Optimization, 15 HP	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3105 Energy Recovery Ventilation (ERV)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3106 Separate Makeup Air / Exhaust Hoods AC	100%	100.0%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3107 Demand Controlled Ventilation	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3201 Fan Motor, 40hp, 1800rpm, 94.1%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3202 Variable Speed Drive Control, 40 HP	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3203 Air Handler Optimization, 40 HP	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3204 Demand Controlled Ventilation	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4000 Base Built-Up Refrigeration System	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4001 High-efficiency fan motors	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4002 Strip curtains for walk-ins (built-up)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4003 Auto-closer on main door to walk-in freezer (built-up)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4004 Night covers for display cases	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4005 Evaporator fan controller for MT walk-ins	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4006 Electronically commutated evaporator fan motor	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4007 Efficient compressor motor	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4008 Compressor VSD retrofit	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4009 Floating head pressure controls	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4010 Refrigeration Commissioning	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4011 Demand Hot Gas Defrost	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4012 Demand Defrost Electric	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4013 Anti-sweat (humidistat) controls	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4014 Freezer-Cooler Replacement Gaskets	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4015 High R-Value Glass Doors	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4016 LED Display Lighting	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4017 Multiplex Compressor System	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4018 Oversized Air Cooled Condenser	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4019 Insulated suction lines	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4100 Base Self-Contained Refrigeration	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4101 Strip curtains for walk-ins (self-contained)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4102 Auto-closer on main door to walk-in freezer (self-contained)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4103 Night covers for display cases (self-contained)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4104 Freezer-Cooler Replacement Gaskets (self-contained)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4105 Bi-level LED Case Lighting (self-contained units) 2014	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4106 Energy-Star Refrigerator, solid door	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4107 Energy-Star Freezer, solid door	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4108 Energy-Star Refrigerator, glass door	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4109 Energy-Star Freezer, glass door	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4110 Energy Star Ice Machines	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4111 Hydraulic-type door closer on reach-in cooler glass doors	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4112 Reach-in unit occupancy sensors	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5000 Base Desktop PC	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5001 PC Network Power Management Enabling	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5002 Energy Star or Better PC	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5003 Plug-load controls - Commercial Smart Strip (base desktop PC)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

ommercial Elec	Measure Inputs	Standards Ad (percent)	djustment Fact	or									
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging 3	ata Centern-	lurisdicticlic	nious Wors	Misc
A Existing	5100 Base Laptop PC	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	10
A Existing	5101 Laptop Network Power Management Enabling	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	10
A Existing	5102 Energy Star or Better Laptop	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	10
A Existing	5103 Plug-load controls - Commercial Smart Strip (base desktop PC)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	10
Existing	5200 Base Monitor, CRT	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	10
Existing	5201 Energy Star or Better Monitor - CRT	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	10
A Existing	5202 Monitor Power Management Enabling - CRT	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	10
A Existing	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5300 Base Monitor, LCD	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5301 Energy Star or Better Monitor - LCD	100%		100%	100%	100%	100%	100%		100%	100%	100%	1
A Existing	5302 Monitor Power Management Enabling - LCD	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5400 Base Copier	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5401 Energy Star or Better Copier	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5402 Copier Power Management Enabling	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5500 Base Multifunction	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5501 Multifunction Power Management Enabling	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5502 ENERGY STAR Multi-Function Printer	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5600 Base Printer	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5601 Printer Power Management Enabling	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5602 ENERGY STAR Printer	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	5700 Base Data Center/Server Room	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	5701 Data Center Improved Operations	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
Existing	5702 Data Center Improved Operations 5702 Data Center Best Practices	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	5703 Data Center State of the Art practices	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	5704 Data Center State of the Art practices 5704 Data Center Airflow Management	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	6000 Base Water Heating	100%		100%	100%	100%	100%	100%		100%	100%	100%	
A Existing	6001 Demand controlled circulating systems	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
A Existing	6002 High Efficiency Water Heater (electric)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	6003 Hot Water Pipe Insulation	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	6004 Tankless Water Heater	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	6005 Heat Pump Water Heater (air source)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	6006 Heat Recovery Unit	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
Existing	6007 Heat Trap	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
Existing	6008 Solar Water Heater	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	7000 Base Refrigerated Vending Machines	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	7001 Vending Misers (Refrigerated units)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
A Existing	7001 Vending Misers (Refrigerated dints) 7002 Vending Misers (Refrigerated glass-front units)	100%		100%	100%	100%	100%	100%		100%	100%	100%	1
Existing	7100 Base Non-Refrigerated Vending Machines	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	7100 Base Non-Reinigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
Existing	7200 Base Oven	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
Existing	7201 Convection Oven	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1
Existing	7300 Base Fryer	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	7301 Efficient Fryer	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
		100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing Existing	7400 Base Steamer 7401 Efficient Steamer	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
		100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	8000 Base Heating, Heat Pump (7.7 HSPF)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	100%		100% 100%	100%	100%	100% 100%	100% 100%		100% 100%	100% 100%	100% 100%	
Existing	8100 Base Heating, Other Electric 9500 Base Miscellaneous	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing	9500 Base Miscellaneous 9501 Xmisc	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	
Existing													
Existing	1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	
Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	
Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	
Existing	1003 ROB 4L4'T5, 2014-2015	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	
Existing	1004 ROB 4L4' LED Tube, 2014-2015	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	
Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	
C Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	

Commercial Elec	Measure Inputs	Standards Ad (percent)	djustment Fact	or									
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centern-	Jurisdictidigiou	ıs Wors	Misc
NC Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2014-2015	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	87%	98%	87%	88%	82%	97%	87%		96%	96%	94%	94%
NC Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1013 ROB 4L4'T5, 2016-2017	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1014 ROB 4L4' LED Tube, 2016-2017	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	87%		87%	88%	82%	97%	87%		96%	96%	94%	94%
NC Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	87%		87%	88%	82%	97%	87%		96%	96%	94%	94%
NC Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	87%		87%	88%	82%	97%	87%		96%	96%	94%	94%
NC Existing	1020 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	87%		87%	88%	82%	97%	87%		96%	96%	94%	94%
NC Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	87%		87%	88%	82%	97%	87%			96%	94%	94%
NC Existing	1023 ROB 4L4'T5, 2018-2019	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1024 ROB 4L4' LED Tube, 2018-2019	87%		87%	88%	82%	97%	87%		96%	96%	94%	94%
NC Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	87%		87%	88%	82%	97%	87%			96%	94%	94%
NC Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	87% 87%		87%	88%	82%	97%	87%		96%	96%	94%	94%
NC Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	87% 87%		87% 87%	88% 88%	82% 82%	97% 97%	87% 87%	85% 85%		96%	94%	94% 94%
NC Existing NC Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2018-2019 1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	87%		87%	88%	82%	97%	87% 87%		96% 96%	96% 96%	94% 94%	94%
NC Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1032 ROB 4L4 Low Watt High Performance T8 (75 W), 2020	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1032 ROB 4L4 LOW Walt Hight Fromhance to (75 W), 2020	87%		87%	88%	82%	97%	87%			96%	94%	94%
NC Existing	1034 ROB 4L4' LED Tube, 2020	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1035 LED Troffer (base 4L4'T8), 2020	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	87%		87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	87%	98%	87%	88%	82%	97%	87%	85%	96%	96%	94%	94%
NC Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1103 ROB 2L4'T5, 2014-2015	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1104 ROB 2L4' LED Tube, 2014-2015	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	95%		95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	95%		95%	95%	92%	99%	94%	93%		99%	98%	98%
NC Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	95%		95%	95%	92%	99%	94%	93%		99%	98%	98%
NC Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	95%		95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1113 ROB 2L4'T5, 2016-2017	95%		95%	95%	92%	99%	94%	93%		99%	98%	98%
NC Existing	1114 ROB 2L4' LED Tube, 2016-2017	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	95%	99% 99%	95% 95%	95% 95%	92%	99%	94% 94%	93%	99% 99%	99%	98%	98% 98%
NC Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	95% 95%		95% 95%	95% 95%	92% 92%	99% 99%	94% 94%	93% 93%	99% 99%	99% 99%	98% 98%	98% 98%
NC Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	95% 95%		95% 95%	95% 95%	92%		94%					
NC Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	95% 95%	99%	95% 95%	95% 95%	92%	99% 99%	94%		99% 99%	99% 99%	98% 98%	98% 98%
NC Existing NC Existing	1120 Base Fluorescent Fixture, 2L4T8, 1EB, 2018-2019 1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	95% 95%	99% 99%	95% 95%	95% 95%	92% 92%	99%	94% 94%	93% 93%	99% 99%	99% 99%	98% 98%	98% 98%
NC Existing	1121 ROB 2L4 High Performance 18 (86 W), 2018-2019 1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	95%	99%	95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1122 ROB 2L4 LOW Walt right Ferrormance 16 (75 W), 2016-2019	95%		95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing	1124 ROB 2L4 15, 2016-2019 1124 ROB 2L4' LED Tube, 2018-2019	95%		95%	95%	92%	99%	94%			99%	98%	98%
NC Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	95%		95%	95%	92%	99%	94%	93%	99%	99%	98%	98%
NC Existing NC Existing	1126 Lighting Control Tuneup (base 2L4T8), 2018-2019	95%		95%	95%	92%	99%	94%			99%	98%	98%
NC Existing NC Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	95%		95% 95%	95% 95%	92%	99%	94%	93%		99%	98%	98%
NC Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2018-2019	95%		95%	95%	92%	99%	94%		99%	99%	98%	98%

Commercial Elec	Measure Inputs	FEASIBILITY F	ACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging)	ata Centenn	n-Jurisdictionlig	ious Wors	Misc
/A Existing	1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100
/A Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100
/A Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
/A Existing	1003 ROB 4L4T5, 2014-2015	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1004 ROB 4L4' LED Tube, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
VA Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
VA Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
VA Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	28%	7%	7%	7%	14%	35%	35%	14%	28%	21%	14%	149
VA Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	309
VA Existing	1010 Base Fluorescent Fixture, 4L4T8, 1EB, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
VA Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
VA Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
VA Existing	1013 ROB 4L4T5, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
VA Existing	1014 ROB 4L4' LED Tube, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
VA Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	28%	7%	7%	7%	14%	35%	35%		28%	21%	14%	149
VA Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	30%	30%	30%	30%	30%	30%	30%		30%	30%	30%	30%
VA Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1023 ROB 4L4T5, 2018-2019	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1024 ROB 4L4' LED Tube, 2018-2019	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	28%	7%	7%	7%	14%	35%	35%		28%	21%	14%	149
VA Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	30%	30%	30%	30%	30%	30%	30%		30%	30%	30%	30%
VA Existing	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1033 ROB 4L4'T5, 2020	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1034 ROB 4L4' LED Tube, 2020	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1035 LED Troffer (base 4L4'T8), 2020	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	28%	7%	7%	7%	14%	35%	35%		28%	21%	14%	149
VA Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	30%	30%	30%	30%	30%	30%	30%		30%	30%	30%	30%
VA Existing	1100 Base Fluorescent Fixture, 2L4T8, 1EB, 2014-2015	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015 1103 ROB 2L4'T5, 2014-2015	100% 100%	100% 100%	100% 100%	100% 100%	100% 100%	100% 100%	100% 100%		100% 100%	100% 100%	100% 100%	100% 100%
VA Existing	1104 ROB 2L4 LED Tube, 2014-2015		30%	30%						30%			
VA Existing VA Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	30% 100%	100%	100%	30% 100%	30% 100%	30% 100%	30% 100%		100%	30% 100%	30% 100%	309 1009
-		100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing VA Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015 1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	100%	7%	100% 7%	100% 7%	100%	35%	35%		100% 28%	21%	100%	100%
VA Existing VA Existing	1107 Occupancy Sensor, 2L4 Fluorescent Fixtures, 2014-2015 1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015	30%	30%	30%	30%	30%	30%	30%		30%	30%	30%	309
VA Existing VA Existing	1108 Fight Performance Lighting R/R - 25% Savings (base 2L4 18), 2014-2015 1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing VA Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing VA Existing	1111 ROB 2L4 High Performance 18 (86 W), 2016-2017 1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100%
VA Existing VA Existing	1113 ROB 2L4T5, 2016-2017	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing VA Existing	1113 ROB 2L4 15, 2016-2017 1114 ROB 2L4' LED Tube, 2016-2017	30%	30%	30%	30%	30%	30%	30%		30%	30%	30%	30
VA Existing VA Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100
/A Existing /A Existing	1115 LED Froner (base 2L4*18), 2016-2017 1116 Lighting Control Tuneup (base 2L4*T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	100
/A Existing /A Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	28%	7%	7%	7%	14%	35%	35%		28%	21%	14%	149
/A Existing /A Existing		28% 30%	7% 30%	30%	7% 30%	14% 30%	35%	35%		28% 30%	30%	14% 30%	309
	1118 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017 1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
VA Existing		100%	100%	100%	100%	100%	100%	100%		100%	100%	100%	1009
/A Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	10

Commercial Elec I	Measure Inputs	FEASIBILITY F	ACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging)	ata Centeor	n-Jurisdictiorlig	ious Wors	Misc
/A Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1123 ROB 2L4'T5, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1124 ROB 2L4' LED Tube, 2018-2019	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30
/A Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	28%		7%	7%	14%	35%	35%	14%	28%	21%	14%	14
/A Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	30%		30%	30%	30%	30%	30%	30%	30%	30%	30%	30
VA Existing	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1131 ROB 2L4' High Performance T8 (86 W), 2020	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1133 ROB 2L4'T5, 2020	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1134 ROB 2L4' LED Tube, 2020	30%		30%	30%	30%	30%	30%	30%	30%	30%	30%	30
VA Existing	1135 LED Troffer (base 2L4'T8), 2020	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1136 Lighting Control Tuneup (base 2L4'T8), 2020	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	28%		7%	7%	14%	35%	35%	14%	28%	21%	14%	14
VA Existing	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30
VA Existing	1200 Base Other Fluorescent Fixture	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1201 ROB High Performance T8 (base other fluorescent)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1202 ROB Low Watt High Performance T8 (base other fluorescent)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1203 Lighting Control Tuneup (base other fluorescent fixture)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	28%		7%	7%	14%	35%	35%	14%	28%	21%	14%	14 30
/A Existing	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	30% 100%	30% 100%	30% 100%	30% 100%	30% 100%	30% 100%	30% 100%	30% 100%	30% 100%	30% 100%	30% 100%	100
/A Existing		90%			90%	90%	90%	90%		90%		90%	
/A Existing /A Existing	1301 CFLs (base incandescent flood) 2014-2015 1302 LEDs (base incandescent flood) 2014-2015	90%		50% 100%	100%	100%	100%	100%	70% 100%	100%	90% 100%	90% 100%	90 100
VA Existing	1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	100%		100%	100%	100%	100%	100%		100%	100%	100%	100
VA Existing	1311 CFLs (base incandescent flood) 2016-2017	90%		50%	90%	90%	90%	90%	70%	90%	90%	90%	90
VA Existing VA Existing	1312 LEDs (base incandescent flood) 2016-2017	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1321 CFLs (base incandescent flood) 2018-2019	90%		50%	90%	90%	90%	90%	70%	90%	90%	90%	90
VA Existing	1322 LEDs (base incandescent flood) 2018-2019	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1331 CFLs (base incandescent flood) 2020	90%		50%	90%	90%	90%	90%	70%	90%	90%	90%	90
/A Existing	1332 LEDs (base incandescent flood) 2020	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1401 CFLs (base incandescent A-line 72W) 2014-2015	90%		50%	90%	90%	90%	90%	70%	90%	90%	90%	90
VA Existing	1402 LEDs (base incandescent A-line 72W) 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1411 CFLs (base incandescent A-line 72W) 2016-2017	90%	50%	50%	90%	90%	90%	90%	70%	90%	90%	90%	90
/A Existing	1412 LEDs (base incandescent A-line 72W) 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1421 CFLs (base incandescent A-line 72W) 2018-2019	90%	50%	50%	90%	90%	90%	90%	70%	90%	90%	90%	90
/A Existing	1422 LEDs (base incandescent A-line 72W) 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1431 CFLs (base incandescent A-line 72W) 2020	90%	50%	50%	90%	90%	90%	90%	70%	90%	90%	90%	90
/A Existing	1432 LEDs (base incandescent A-line 72W) 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1501 CFLs (base incandescent A-line 53W) 2014-2015	90%		50%	90%	90%	90%	90%	70%	90%	90%	90%	90
/A Existing	1502 LEDs (base incandescent A-line 53W) 2014-2015	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1510 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1511 CFLs (base incandescent A-line 53W) 2016-2017	90%		50%	90%	90%	90%	90%	70%	90%	90%	90%	90
/A Existing	1512 LEDs (base incandescent A-line 53W) 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1520 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
/A Existing	1521 CFLs (base incandescent A-line 53W) 2018-2019	90%	50%	50%	90%	90%	90%	90%	70%	90%	90%	90%	90
/A Existing	1522 LEDs (base incandescent A-line 53W) 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100
VA Existing	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100

Commercial Elec	Measure Inputs	FEASIBILITY I (percent)	-ACTOR										
		(porosin)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	ata Centenn	-Jurisdictiorligi	ous Wors	Misc
VA Existing	1531 CFLs (base incandescent A-line 53W) 2020	90%		50%	90%			90%	70%	90%	90%	90%	90%
VA Existing	1532 LEDs (base incandescent A-line 53W) 2020	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1601 LED screw-in replacement (base CFL 18W) 2014-2015	100%		100%	100%		100%	100%	100%	100%	100%	100%	100%
VA Existing	1610 Base CFL 18W to screw-in replacement 2016-2017	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1611 LED screw-in replacement (base CFL 18W) 2016-2017	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1620 Base CFL 18W to screw-in replacement 2018-2019	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1621 LED screw-in replacement (base CFL 18W) 2018-2019	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1630 Base CFL 18W to screw-in replacement 2020	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1631 LED screw-in replacement (base CFL 18W) 2020	100%		100%	100%			100%			100%	100%	100%
VA Existing	1700 Base CFL 23W to screw-in replacement 2014-2015	100%		100%	100%		100%	100%	100%	100%	100%	100%	100%
VA Existing	1701 LED screw-in replacement (base CFL 23W) 2014-2015	100% 100%		100% 100%	100% 100%			100% 100%	100% 100%	100% 100%	100% 100%	100% 100%	100% 100%
VA Existing	1710 Base CFL 23W to screw-in replacement 2016-2017	100%		100%	100%				100%	100%		100%	100%
VA Existing VA Existing	1711 LED screw-in replacement (base CFL 23W) 2016-2017 1720 Base CFL 23W to screw-in replacement 2018-2019	100%		100%	100%			100% 100%	100%	100%	100% 100%	100%	100%
VA Existing VA Existing	1720 base CFL 23W to screw-in replacement 2016-2019 1721 LED screw-in replacement (base CFL 23W) 2018-2019	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	1730 Base CFL 23W to screw-in replacement 2020	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing VA Existing	1731 LED screw-in replacement (base CFL 23W) 2020	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	1800 BaseMetal Halide, 465W	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing VA Existing	1801 T5 (240W) (base metal halide)	70%		70%	70%			70%	70%	70%	70%	70%	70%
VA Existing VA Existing	1802 Induction High Bay Lighting	70%		70%	70%			70%	70%	70%	70%	70%	70%
VA Existing VA Existing	1803 PSMH + electronic ballast	70%		70%	70%			70%	70%	70%	70%	70%	70%
VA Existing VA Existing	1804 PSMH, magnetic ballast, 320 W	70%		70%	70%			70%	70%	70%	70%	70%	70%
VA Existing VA Existing	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	30%		30%	30%			30%	30%	30%	30%	30%	30%
VA Existing VA Existing	1806 Occupancy Sensor, High Bay T5	19%		19%	19%			19%	19%	19%	19%	19%	19%
VA Existing	1850 Base CFL Exit Sign	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing	1851 LED Exit Sign	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1901 Outdoor Lighting Controls (Photocell/Timeclock)	90%		90%	90%			90%	90%	90%	90%	90%	90%
VA Existing	1902 LED Outdoor Area Lighting	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	1903 Bi-Level LED Outdoor Lighting	80%		80%	80%			80%	80%	80%	80%	80%	80%
VA Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing	2002 Window Film (Standard) - Chiller	75%		50%	75%		75%	75%	75%	75%	75%	75%	75%
VA Existing	2003 EMS - Chiller	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing	2004 Cool Roof - Chiller	50%		50%	50%			50%	50%	50%	50%	50%	50%
VA Existing	2005 Chiller Tune Up/Diagnostics	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	2006 VSD for Chiller Pumps and Towers	16%		0%	100%			15%	4%	16%	39%	62%	62%
VA Existing	2007 EMS Optimization - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2008 New Economizer - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2009 Dual Enthalpy Economizer Replaced Dry Bulb Economizer - Chiller	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2010 Ceiling/roof Insulation - Chiller	22%	100%	43%	100%	3%	100%	100%	100%	22%	36%	49%	49%
VA Existing	2011 Duct/Pipe Insulation - Chiller	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%
VA Existing	2012 Duct Testing/Sealing	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2013 High Efficiency Chiller Motors	29%	0%	0%	100%	0%	6%	19%	4%	29%	16%	4%	4%
VA Existing	2100 Base DX Packaged System, EER=10.3, 10 tons	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2101 DX Packaged System, EER=10.9, 10 tons	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2102 DX Packaged System, EER=13.4, 10 tons	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	2103 Geothermal Heat Pump, EER=13, 10 tons - DX	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%	5%
VA Existing	2104 DX Coil Cleaning	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	2105 DX Tune Up/ Advanced Diagnostics	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing	2106 Prog. Thermostat - DX	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	2107 Cool Roof - DX	50%		50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
VA Existing	2108 Optimize Controls - DX	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	2109 Economizer - DX	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
					5%	5%		5%	5%				5%

Commercial Elec	Measure Inputs	FEASIBILITY	FACTOR										
		(percent)											
Seament	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	lata Centenn	-Jurisdictiorligi	nue Wors	Misc
VA Existing	2111 Economizer Repair - DX	80%		80%	80%			80%	80%	80%	80%	80%	80%
VA Existing	2112 Aerosol Duct Sealing - DX	32%		32%	32%			32%	32%	32%	32%	32%	32%
VA Existing	2113 Ceiling/roof Insulation - DX	22%		100%	100%			100%		22%	61%	100%	100%
VA Existing	2114 Duct/Pipe Insulation - DX	75%		75%	75%			75%	75%	75%	75%	75%	75%
VA Existing	2115 Window Film (Standard) - DX	75%		50%	75%			75%	75%	75%	75%	75%	75%
VA Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2300 Base PTAC, EER=8.3, 1 ton	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2301 HE PTAC, EER=9.6, 1 ton	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2302 Occupancy Sensor (hotels)	0%	0%	0%	0%	0%	0%	0%	75%	0%	0%	0%	0%
VA Existing	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3001 Fan Motor, 5hp, 1800rpm, 89.5%	94%	100%	92%	100%	100%	100%	100%	100%	94%	97%	100%	100%
VA Existing	3002 Variable Speed Drive Control, 5 HP	83%	100%	100%	100%	100%	100%	100%	0%	83%	91%	100%	100%
VA Existing	3003 Demand Controlled Ventilation	79%	92%	70%	100%	100%	100%	100%	100%	79%	85%	91%	91%
VA Existing	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3101 Fan Motor, 15hp, 1800rpm, 92.4%	94%	100%	92%	100%	100%	100%	100%	100%	94%	97%	100%	100%
VA Existing	3102 Variable Speed Drive Control, 15 HP	83%	100%	100%	100%	100%	100%	100%	0%	83%	91%	100%	100%
VA Existing	3103 Air Handler Optimization, 15 HP	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3105 Energy Recovery Ventilation (ERV)	55%		100%	100%			100%	100%	55%	71%	88%	88%
VA Existing	3106 Separate Makeup Air / Exhaust Hoods AC	0%	100.0%	0%	10%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	3107 Demand Controlled Ventilation	79%		70%	100%			100%	100%	79%	85%	91%	91%
VA Existing	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	3201 Fan Motor, 40hp, 1800rpm, 94.1%	94%		92%	100%		100%	100%	100%	94%	97%	100%	100%
VA Existing	3202 Variable Speed Drive Control, 40 HP	83%		100%	100%	100%	100%	100%	0%	83%	91%	100%	100%
VA Existing	3203 Air Handler Optimization, 40 HP	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing	3204 Demand Controlled Ventilation	79%		70%	100%			100%	100%	79%	85%	91%	91%
VA Existing	4000 Base Built-Up Refrigeration System	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing	4001 High-efficiency fan motors	64%		59%	49%			100%	0%	64%	49%	34%	34%
VA Existing	4002 Strip curtains for walk-ins (built-up)	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	4003 Auto-closer on main door to walk-in freezer (built-up)	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing	4004 Night covers for display cases	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	4005 Evaporator fan controller for MT walk-ins	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	4006 Electronically commutated evaporator fan motor	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	4007 Efficient compressor motor	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing	4008 Compressor VSD retrofit	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	4009 Floating head pressure controls	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	4010 Refrigeration Commissioning	20%		60%	20%			20%	20%	20%	20%	20%	20%
VA Existing	4011 Demand Hot Gas Defrost	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	4012 Demand Defrost Electric	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing	4013 Anti-sweat (humidistat) controls	100% 100%		100% 100%	100% 100%			100% 100%	100%	100% 100%	100%	100% 100%	100% 100%
VA Existing	4014 Freezer-Cooler Replacement Gaskets	100%		100%	100%			100%	100% 100%	100%	100% 100%	100%	100%
VA Existing VA Existing	4015 High R-Value Glass Doors 4016 LED Display Lighting	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4017 Multiplex Compressor System	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4017 Indulpiex Compressor System 4018 Oversized Air Cooled Condenser	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4019 Insulated suction lines	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4100 Base Self-Contained Refrigeration	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4100 Base Self-Contained Reingeration 4101 Strip curtains for walk-ins (self-contained)	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing VA Existing	4101 Strip curtains for walk-ins (self-contained) 4102 Auto-closer on main door to walk-in freezer (self-contained)	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4103 Night covers for display cases (self-contained)	100%		100%	100%			100%	100%		100%	100%	100%
VA Existing VA Existing	4104 Freezer-Cooler Replacement Gaskets (self-contained)	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4104 Preezer-Cooler Replacement Gaskets (self-contained) 4105 Bi-level LED Case Lighting (self-contained units) 2014	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4105 Energy-Star Refrigerator, solid door	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4106 Energy-Star Reingerator, solid door	100%		100%	100%			100%	100%	100%	100%	100%	100%
VA Existing VA Existing	4108 Energy-Star Refrigerator, glass door	100%		100%	100%			100%	100%		100%	100%	100%
VA LABURIY	TIOU ETICITY TOTAL INCHINGUIATOR, GIASS 4001	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	10076	100%

												-	
Commercial Elec	Measure Inputs	FEASIBILITY (percent)	FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging)ata Centenr	-Jurisdictiorligi	ous Wors	Misc
VA Existing	4109 Energy-Star Freezer, glass door	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing	4110 Energy Star Ice Machines	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4111 Hydraulic-type door closer on reach-in cooler glass doors	100%		100%	100%	100%	100%	100%	100%		100%	100%	100%
VA Existing	4112 Reach-in unit occupancy sensors	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing	5000 Base Desktop PC	100%		100%	100%			100%			100%	100%	100%
VA Existing	5001 PC Network Power Management Enabling	75%		75%	75%			75%			75%	75%	75%
VA Existing	5002 Energy Star or Better PC	75%		75%	100%			100%			88%	100%	100%
VA Existing	5003 Plug-load controls - Commercial Smart Strip (base desktop PC)	0%		0%	0%			0%			0%	0%	0%
VA Existing	5100 Base Laptop PC	100%		100%	100%			100%			100%	100%	100%
VA Existing	5101 Laptop Network Power Management Enabling	100%		100%	100%			100%			100%	100%	1009
VA Existing	5102 Energy Star or Better Laptop	100%		100%	100%			100%			100%	100%	100%
VA Existing	5103 Plug-load controls - Commercial Smart Strip (base desktop PC)	0%		0%	0%			0%			0%	0%	0%
VA Existing	5200 Base Monitor, CRT	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing	5201 Energy Star or Better Monitor - CRT	100%		100%	100%			100%			100%	100%	100%
VA Existing	5202 Monitor Power Management Enabling - CRT	75%		75%	75%			75%			75%	75%	75%
VA Existing	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing	5300 Base Monitor, LCD	100%		100%	100%			100%			100%	100%	100%
VA Existing	5301 Energy Star or Better Monitor - LCD	100%		100%	100%			100%			100%	100%	1009
VA Existing	5302 Monitor Power Management Enabling - LCD	75%		75%	75%			75%			75%	75%	75%
VA Existing	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	100% 100%		100% 100%	100% 100%		100%	100%			100%	100% 100%	100% 100%
VA Existing	5400 Base Copier			100%	100%			100%			100%		100%
VA Existing VA Existing	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	100% 75%		75%	75%			100% 75%			100% 75%	100% 75%	75%
VA Existing VA Existing	5500 Base Multifunction	100%		100%	100%			100%			100%	100%	100%
VA Existing VA Existing	5501 Multifunction Power Management Enabling	75%		75%	75%		75%	75%			75%	75%	759
VA Existing VA Existing	5502 ENERGY STAR Multi-Function Printer	100%		100%	100%			100%			100%	100%	100%
VA Existing VA Existing	5600 Base Printer	100%		100%	100%			100%			100%	100%	100%
VA Existing VA Existing	5601 Printer Power Management Enabling	75%		75%	75%			75%			75%	75%	75%
VA Existing VA Existing	5602 ENERGY STAR Printer	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing VA Existing	5700 Base Data Center/Server Room	100%		100%	100%			100%			100%	100%	100%
VA Existing VA Existing	5701 Data Center Improved Operations	60%		60%	60%			60%			60%	60%	60%
VA Existing	5701 Data Center Improved Operations 5702 Data Center Best Practices	30%		30%	30%		30%	30%			30%	30%	30%
VA Existing	5703 Data Center State of the Art practices	10%		10%	10%			10%			10%	10%	10%
VA Existing	5704 Data Center Airflow Management	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing	6000 Base Water Heating	100%		100%	100%			100%			100%	100%	100%
VA Existing	6001 Demand controlled circulating systems	75%		75%	75%			75%			75%	75%	75%
VA Existing	6002 High Efficiency Water Heater (electric)	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing	6003 Hot Water Pipe Insulation	58%		82%	100%			100%			79%	100%	100%
VA Existing	6004 Tankless Water Heater	75%		75%	75%		75%	75%			75%	75%	75%
VA Existing	6005 Heat Pump Water Heater (air source)	80%		80%	80%		80%	80%			80%	80%	80%
VA Existing	6006 Heat Recovery Unit	10%		5%	80%			80%			8%	5%	59
VA Existing	6007 Heat Trap	75%		75%	75%			75%			75%	75%	759
VA Existing	6008 Solar Water Heater	76%		4%	20%		10%	20%			38%	0%	0%
VA Existing	7000 Base Refrigerated Vending Machines	100%		100%	100%			100%			100%	100%	100%
VA Existing	7001 Vending Misers (Refrigerated units)	70%		70%	70%			70%			70%	70%	70%
VA Existing	7002 Vending Misers (Refrigerated glass-front units)	70%	70%	70%	70%			70%			70%	70%	70%
VA Existing	7100 Base Non-Refrigerated Vending Machines	100%		100%	100%			100%			100%	100%	100%
VA Existing	7101 Vending Misers (Non-Refrigerated)	100%		100%	100%			100%			100%	100%	100%
VA Existing	7200 Base Oven	100%		100%	100%			100%			100%	100%	1009
VA Existing	7201 Convection Oven	100%		100%	100%			100%			100%	100%	100%
VA Existing	7300 Base Fryer	100%		100%	100%			100%			100%	100%	1009
VA Existing	7301 Efficient Fryer	100%		100%	100%		100%	100%			100%	100%	1009
VA Existing	7400 Base Steamer	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing	7401 Efficient Steamer	100%		100%	100%			100%			100%	100%	100%
VA Existing	8000 Base Heating, Heat Pump (7.7 HSPF)	100%		100%	100%		100%	100%			100%	100%	100%
VA Existing	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	100%		100%	100%			100%			100%	100%	100%
va Existing	out near rump upgrade (15 SEEK, 8.2 FISPF)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	

Commercial Elec	Measure Inputs	FEASIBILITY I	FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	1 - 4-1 1-	0	n-Jurisdictiorlig	: \\\	Misc
VA Existing	8100 Base Heating, Other Electric	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	9500 Base Miscellaneous	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	9501 Xmisc	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	100%		100%	100%	100%		100%	100%	100%	100%	100%	1009
NC Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1003 ROB 4L4'T5, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1004 ROB 4L4' LED Tube, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	28%	7%	7%	7%	14%	35%	35%	14%	28%	21%	14%	149
NC Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1010 Base Fluorescent Fixture, 4L4T8, 1EB, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1013 ROB 4L4'T5, 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1014 ROB 4L4' LED Tube, 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	1009
NC Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	28%		7%	7%	14%		35%	14%	28%	21%	14%	149
NC Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	30%		30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019	100%		100%	100%	100%		100%	100%	100%	100%	100%	1009
NC Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	100%		100%	100%	100%		100%	100%	100%	100%	100%	1009
NC Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	100%		100%	100%	100%		100%	100%	100%	100%	100%	1009
NC Existing	1023 ROB 4L4'T5, 2018-2019	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1024 ROB 4L4' LED Tube, 2018-2019	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	100% 100%		100% 100%	100% 100%	100% 100%		100%	100%	100% 100%	100%	100% 100%	1009 1009
NC Existing NC Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019 1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	28%		7%	7%	14%		100% 35%	100% 14%	28%	100% 21%	14%	149
NC Existing	1027 Occupancy Sensor, 4L4 Problescent Pixtures, 2016-2019 1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	30%		30%	30%	30%	30%	30%	30%	30%	30%	30%	309
NC Existing	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	100%		100%	100%	100%		100%	100%	100%	100%	100%	1007
NC Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1033 ROB 4L4'T5, 2020	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1034 ROB 4L4' LED Tube, 2020	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1035 LED Troffer (base 4L4'T8), 2020	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	28%		7%	7%	14%		35%	14%	28%	21%	14%	149
NC Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1103 ROB 2L4'T5, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1104 ROB 2L4' LED Tube, 2014-2015	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	28%		7%	7%	14%		35%	14%	28%	21%	14%	149
NC Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1110 Base Fluorescent Fixture, 2L4T8, 1EB, 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1113 ROB 2L4'T5, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	1009
NC Existing	1114 ROB 2L4' LED Tube, 2016-2017	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	100%		100%	100%	100%		100%	100%	100%	100%	100%	100%
NC Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	28%	7%	7%	7%	14%	35%	35%	14%	28%	21%	14%	149

Commercial Elec I	Measure Inputs	FEASIBILITY F	ACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging)a	ita Centenn	 Jurisdictiorlig 	ious Wors	Misc
NC Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1120 Base Fluorescent Fixture, 2L4T8, 1EB, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1123 ROB 2L4'T5, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1124 ROB 2L4' LED Tube, 2018-2019	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	28%	7%	7%	7%	14%	35%	35%	14%	28%	21%	14%	14%
NC Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%	30%
NC Existing	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

Commercial Elec	Measure Inputs	INCOMPLET	E FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging Da	ta Centern-	Jurisdicticig	ious Wors	Misc
VA Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	98%	100%	100%	98%	78%	99%	100%	100%	98%	99%	100%	100%
VA Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1003 ROB 4L4'T5, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1004 ROB 4L4' LED Tube, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1005 LED Troffer (base 4L4T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	97%	93%	100%	98%	100%	86%	99%	100%	97%	98%	99%	99%
VA Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	98%	100%	100%	98%	78%	99%	100%	100%	98%	99%	100%	100%
VA Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1013 ROB 4L4'T5, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1014 ROB 4L4' LED Tube, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	97%	93%	100%	98%	100%	86%	99%	100%	97%	98%	99%	99%
VA Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1020 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	98%	100%	100%	98%	78%	99%	100%	100%	98%	99%	100%	100%
VA Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1023 ROB 4L4'T5, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1024 ROB 4L4' LED Tube, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1026 Lighting Control Tuneup (base 4L4T8), 2018-2019	97%	93%	100%	98%	100%	86%	99%	100%	97%	98%	99%	99%
VA Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	98%	100%	100%	98%	78%	99%	100%	100%	98%	99%	100%	100%
VA Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1033 ROB 4L4'T5, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1034 ROB 4L4' LED Tube, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1035 LED Troffer (base 4L4'T8), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1036 Lighting Control Tuneup (base 4L4T8), 2020	97%	93%	100%	98%	100%	86%	99%	100%	97%	98%	99%	99%
VA Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	100%	100%	100%	95%	99%	98%	100%	100%	100%	95%	90%	90%
VA Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1103 ROB 2L4'T5, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1104 ROB 2L4' LED Tube, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1105 LED Troffer (base 2L4T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	100%		100%	95%	99%	98%	100%	100%	100%	95%	90%	90%
VA Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1113 ROB 2L4'T5, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1114 ROB 2L4' LED Tube, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1115 LED Troffer (base 2L4T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

Commercial Elec	Measure Inputs	INCOMPLET	E FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging Ja	ta Centern-J	urisdicticio	ious Wor	Misc
VA Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	100%	100%	100%	95%	99%	98%	100%	100%	100%	95%	90%	90%
VA Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1123 ROB 2L4'T5, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1124 ROB 2L4' LED Tube, 2018-2019	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1131 ROB 2L4' High Performance T8 (86 W), 2020	100%	100%	100%	95%	99%	98%	100%	100%	100%	95%	90%	90%
VA Existing	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1133 ROB 2L4'T5, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1134 ROB 2L4' LED Tube, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1135 LED Troffer (base 2L4T8), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1136 Lighting Control Tuneup (base 2L4'T8), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1200 Base Other Fluorescent Fixture	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1201 ROB High Performance T8 (base other fluorescent)	100%	100%	100%	100%	100%	81%	100%	100%	100%	85%	71%	71%
VA Existing	1202 ROB Low Watt High Performance T8 (base other fluorescent)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1203 Lighting Control Tuneup (base other fluorescent fixture)	100%	100%	100%	100%	100%	74%	50%	100%	100%	100%	100%	100%
VA Existing	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	84%	97%	95%	98%	67%	81%	97%	91%	94%	78%	90%	90%
VA Existing	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1301 CFLs (base incandescent flood) 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1302 LEDs (base incandescent flood) 2014-2015	64.5%	76.0%	96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1311 CFLs (base incandescent flood) 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1312 LEDs (base incandescent flood) 2016-2017	64.5%	76.0%	96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1321 CFLs (base incandescent flood) 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1322 LEDs (base incandescent flood) 2018-2019	64.5%	76.0%	96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1331 CFLs (base incandescent flood) 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1332 LEDs (base incandescent flood) 2020	64.5%		96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1401 CFLs (base incandescent A-line 72W) 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1402 LEDs (base incandescent A-line 72W) 2014-2015	64.5%		96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1411 CFLs (base incandescent A-line 72W) 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1412 LEDs (base incandescent A-line 72W) 2016-2017	64.5%	76.0%	96.5%	34.1%	50.1%	82.5%	94.0%		83.8%	61.6%	94.2%	72.6%
VA Existing	1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1421 CFLs (base incandescent A-line 72W) 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1422 LEDs (base incandescent A-line 72W) 2018-2019	64.5%		96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1431 CFLs (base incandescent A-line 72W) 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1432 LEDs (base incandescent A-line 72W) 2020	64.5%	76.0%	96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1501 CFLs (base incandescent A-line 53W) 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1502 LEDs (base incandescent A-line 53W) 2014-2015	64.5%		96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1510 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1511 CFLs (base incandescent A-line 53W) 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1512 LEDs (base incandescent A-line 53W) 2016-2017	64.5%	76.0%	96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
VA Existing	1520 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1521 CFLs (base incandescent A-line 53W) 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

Commercial Elec	Measure Inputs	INCOMPLET (percent)	E FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging Da	ta Centern-	Jurisdictici	jious Wors	Misc
/A Existing	1522 LEDs (base incandescent A-line 53W) 2018-2019	64.5%	76.0%	96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
/A Existing	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1531 CFLs (base incandescent A-line 53W) 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1532 LEDs (base incandescent A-line 53W) 2020	64.5%	76.0%	96.5%	34.1%	50.1%	82.5%	94.0%	85.6%	83.8%	61.6%	94.2%	72.6%
/A Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1601 LED screw-in replacement (base CFL 18W) 2014-2015	100% 100%	100%	100%	100% 100%	100%	100% 100%	100%	100%	100% 100%	100%	100% 100%	100% 100%
/A Existing /A Existing	1610 Base CFL 18W to screw-in replacement 2016-2017 1611 LED screw-in replacement (base CFL 18W) 2016-2017	100%	100% 100%	100% 100%	100%	100% 100%	100%	100% 100%	100% 100%	100%	100% 100%	100%	100%
/A Existing	1620 Base CFL 18W to screw-in replacement 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1621 LED screw-in replacement (base CFL 18W) 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1630 Base CFL 18W to screw-in replacement 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1631 LED screw-in replacement (base CFL 18W) 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1700 Base CFL 23W to screw-in replacement 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1701 LED screw-in replacement (base CFL 23W) 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1710 Base CFL 23W to screw-in replacement 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1711 LED screw-in replacement (base CFL 23W) 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1720 Base CFL 23W to screw-in replacement 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1721 LED screw-in replacement (base CFL 23W) 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1730 Base CFL 23W to screw-in replacement 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1731 LED screw-in replacement (base CFL 23W) 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1800 BaseMetal Halide, 465W	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1801 T5 (240W) (base metal halide)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1802 Induction High Bay Lighting	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1803 PSMH + electronic ballast	100% 100%	100% 100%	100% 100%	97% 100%	100% 100%	50% 100%	100%	99% 100%	100% 100%	100% 100%	99% 100%	99% 100%
/A Existing /A Existing	1804 PSMH, magnetic ballast, 320 W 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	100%	100%	100%	100%	100%	100%	100% 100%	100%	100%	100%	100%	100%
/A Existing	1806 Occupancy Sensor, High Bay T5	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%	82%
/A Existing	1850 Base CFL Exit Sign	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1851 LED Exit Sign	35%	64%	58%	1%	100%	56%	6%	35%	35%	37%	39%	39%
/A Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1901 Outdoor Lighting Controls (Photocell/Timeclock)	54%	68%	37%	49%	16%	42%	35%	36%	19%	27%	6%	32%
/A Existing	1902 LED Outdoor Area Lighting	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	1903 Bi-Level LED Outdoor Lighting	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	68%	68%	68%	68%	68%	68%	68%	68%	68%	68%	68%	68%
/A Existing	2002 Window Film (Standard) - Chiller	0%	0%	0%	99%	0%	17%	17%	67%	0%	43%	85%	85%
/A Existing	2003 EMS - Chiller	68%	81%	85%	96%	63%	58%	88%	75%	22%	36%	47%	90%
/A Existing	2004 Cool Roof - Chiller	34%	0%	0%	100%	0%	61%	88%	100%	34%	67%	100%	100%
/A Existing	2005 Chiller Tune Up/Diagnostics	3%	2%	8%	2%	0%	3%	2%	26%	1%	7%	1%	6%
/A Existing	2006 VSD for Chiller Pumps and Towers	39%	0%	0%	100%	0%	10%	13%	100%	39%	50%	62%	62%
/A Existing	2007 EMS Optimization - Chiller	0%	0%	0%	0% 3%	0%	0%	0%	0%	0%	0%	0% 95%	0%
/A Existing /A Existing	2008 New Economizer - Chiller 2009 Dual Enthalpy Economizer Replaced Dry Bulb Economizer - Chiller	19%	0%	0%	3%	0%	74%	54%	68%	19%	57%	95%	95%
/A Existing	2010 Ceiling/roof Insulation - Chiller	15%	57%	15%	0%	33%	0%	0%	0%	15%	17%	19%	19%
/A Existing	2011 Duct/Pipe Insulation - Chiller	20%	0%	0%	100%	0%	39%	75%	33%	20%	55%	89%	89%
/A Existing	2012 Duct Testing/Sealing	100%	92%	100%	100%	97%	85%	100%	100%	100%	98%	96%	96%
/A Existing	2013 High Efficiency Chiller Motors	19%	0%	0%	100%	0%	49%	55%	4%	19%	41%	62%	62%
/A Existing	2100 Base DX Packaged System, EER=10.3, 10 tons	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	2101 DX Packaged System, EER=10.9, 10 tons	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	2102 DX Packaged System, EER=13.4, 10 tons	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
/A Existing	2103 Geothermal Heat Pump, EER=13, 10 tons - DX	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%	99%
/A Existing	2104 DX Coil Cleaning	3%	2%	8%	2%	0%	3%	2%	26%	1%	7%	1%	6%
/A Existing	2105 DX Tune Up/ Advanced Diagnostics	3%	2%	8%	2%	0%	3%	2%	26%	1%	7%	1%	6%
/A Existing	2106 Prog. Thermostat - DX	41%	42%	56%	28%	68%	19%	37%	54%	90%	67%	45%	38%
/A Existing	2107 Cool Roof - DX	94%	91%	66%	100%	78%	95%	100%	100%	94%	97%	100%	100%

Commercial Elec	Measure Inputs	INCOMPLETI	FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse I	Education	Health	Lodging Dat	ta Centern-J	urisdicticigi	ous Wors	Misc
VA Existing	2108 Optimize Controls - DX	33%	33%	33%	33%	33%	33%	33%	33%	33%	33%	33%	33%
VA Existing	2109 Economizer - DX	72%	31%	58%	1%	35%	23%	87%	76%	72%	61%	50%	50%
VA Existing	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	53%	53%	53%	53%	53%	53%	53%	53%	53%	53%	53%	53%
VA Existing	2111 Economizer Repair - DX	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%
VA Existing	2112 Aerosol Duct Sealing - DX	100%	92%	100%	100%	97%	85%	100%	100%	100%	98%	96%	96%
VA Existing	2113 Ceiling/roof Insulation - DX	0%	1%	0%	1%	35%	1%	0%	0%	0%	0%	0%	0%
VA Existing	2114 Duct/Pipe Insulation - DX	43%	81%	48%	100%	13%	79%	73%	72%	43%	42%	42%	42%
VA Existing	2115 Window Film (Standard) - DX	28%	93%	29%	99%	43%	30%	61%	97%	28%	36%	44%	44%
VA Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%
VA Existing	2300 Base PTAC, EER=8.3, 1 ton	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2301 HE PTAC, EER=9.6, 1 ton	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	2302 Occupancy Sensor (hotels)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3001 Fan Motor, 5hp, 1800rpm, 89.5%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%	78%
VA Existing	3002 Variable Speed Drive Control, 5 HP	74%	98%	96%	100%	100%	86%	90%	80%	30%	66%	98%	93%
VA Existing	3003 Demand Controlled Ventilation	42%	100%	100%	100%	7%	93%	65%	100%	42%	27%	13%	13%
VA Existing	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3101 Fan Motor, 15hp, 1800rpm, 92.4%	42%	100%	21%	100%	100%	64%	15%	100%	42%	71%	100%	100%
VA Existing	3102 Variable Speed Drive Control, 15 HP	74%	98%	96%	100%	100%	86%	90%	80%	30%	66%	98%	93%
VA Existing	3103 Air Handler Optimization, 15 HP	95%	100%	100%	100%	100%	100%	0%	100%	95%	81%	66%	66%
VA Existing	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	42%	100%	100%	100%	100%	98%	100%	100%	42%	71%	100%	100%
VA Existing	3105 Energy Recovery Ventilation (ERV)	59%	100%	98%	100%	100%	82%	100%	100%	59%	39%	20%	20%
VA Existing	3106 Separate Makeup Air / Exhaust Hoods AC	100%	100.0%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3107 Demand Controlled Ventilation	42%	100%	100%	100%	7%	93%	65%	100%	42%	27%	13%	13%
VA Existing	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	3201 Fan Motor, 40hp, 1800rpm, 94.1%	42%	100%	21%	100%	0%	19%	0%	0%	42%	39%	36%	36%
VA Existing	3202 Variable Speed Drive Control, 40 HP	74%	98%	96%	100%	100%	86%	90%	80%	30%	66%	98%	93%
VA Existing	3203 Air Handler Optimization, 40 HP	95%	100%	100%	100%	100%	100%	0%	100%	95%	81%	66%	66%
VA Existing	3204 Demand Controlled Ventilation	42%	100%	100%	100%	7%	93%	65%	100%	42%	27%	13%	13%
VA Existing	4000 Base Built-Up Refrigeration System	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4001 High-efficiency fan motors	64%	100%	48%	57%	48%	100%	100%	100%	64%	82%	100%	100%
VA Existing	4002 Strip curtains for walk-ins (built-up)	88%	60%	80%	21%	10%	87%	73%	48%	0%	48%	100%	40%
VA Existing	4003 Auto-closer on main door to walk-in freezer (built-up)												
VA Existing	4004 Night covers for display cases	69%	96%	97%	91%	100%	100%	97%	99%	100%	68%	100%	96%
VA Existing	4005 Evaporator fan controller for MT walk-ins	60%	26%	51%	22%	5%	21%	37%	30%	0%	44%	66%	57%
VA Existing	4006 Electronically commutated evaporator fan motor	64%	100%	48%	57%	48%	100%	100%	100%	64%	82%	100%	100%
VA Existing	4007 Efficient compressor motor	0%	0%	0%	3%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	4008 Compressor VSD retrofit	58%	100%	100%	100%	0%	76%	100%	100%	58%	79%	100%	100%
VA Existing	4009 Floating head pressure controls	0%	0%	0%	3%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	4010 Refrigeration Commissioning	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
VA Existing	4011 Demand Hot Gas Defrost	58%	100%	100%	100%	0%	76%	100%	100%	58%	79%	100%	100%
VA Existing	4012 Demand Defrost Electric	0%	0%	19%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	4013 Anti-sweat (humidistat) controls	0%	0%	0%	27%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	4014 Freezer-Cooler Replacement Gaskets	50%	50%	50%	50%	50%	50%	50%	50%	50%	0.5	0.5	0.5
VA Existing	4015 High R-Value Glass Doors	0%	0%	100%	95%	0%	0%	0%	0%	0%	50%	100%	100%
VA Existing	4016 LED Display Lighting	100%	76%	59%	97%	95%	94%	98%	99%	100%	87%	100%	79%
VA Existing	4017 Multiplex Compressor System	0%	0%	0%	11%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	4018 Oversized Air Cooled Condenser	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
VA Existing	4019 Insulated suction lines												
VA Existing	4100 Base Self-Contained Refrigeration	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	4101 Strip curtains for walk-ins (self-contained)	88%	60%	80%	21%	10%	87%	73%	48%	0%	48%	100%	40%
VA Existing	4102 Auto-closer on main door to walk-in freezer (self-contained)	5575	2270	2270	,0	. = /0	2.70	. 270					.070
VA Existing	4103 Night covers for display cases (self-contained)	69%	96%	97%	91%	100%	100%	97%	99%	100%	68%	100%	96%

Commercial Elec	Measure Inputs	INCOMPLET	E FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse		Health		ta Centern-			Misc
VA Existing	4105 Bi-level LED Case Lighting (self-contained units) 2014	100%	76%	59%	97%	95%	94%	98%	99%	100%	87%	100%	79%
VA Existing	4106 Energy-Star Refrigerator, solid door	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%
VA Existing	4107 Energy-Star Freezer, solid door	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%	66%
VA Existing	4108 Energy-Star Refrigerator, glass door	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%
VA Existing	4109 Energy-Star Freezer, glass door	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%
VA Existing	4110 Energy Star Ice Machines	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%	64%
VA Existing	4111 Hydraulic-type door closer on reach-in cooler glass doors												
VA Existing	4112 Reach-in unit occupancy sensors	100%		62%	96%	100%	100%	99%	99%	100%	87%	100%	78%
VA Existing	5000 Base Desktop PC	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5001 PC Network Power Management Enabling	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%
VA Existing	5002 Energy Star or Better PC	86%	99%	51%	98%	99%	83%	94%	54%	86%	89%	92%	92%
VA Existing	5003 Plug-load controls - Commercial Smart Strip (base desktop PC)	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
VA Existing	5100 Base Laptop PC	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5101 Laptop Network Power Management Enabling	29%	29%	29%	29%	29%	29%	29%	29%	29%	29%	29%	29%
VA Existing	5102 Energy Star or Better Laptop	54%	54%	54%	54%	54%	54%	54%	54%	54%	54%	54%	54%
VA Existing	5103 Plug-load controls - Commercial Smart Strip (base desktop PC)	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
VA Existing	5200 Base Monitor, CRT	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5201 Energy Star or Better Monitor - CRT	58%	100%	100%	100%	100%	100%	95%	100%	58%	79%	100%	100%
VA Existing	5202 Monitor Power Management Enabling - CRT	19%	44%	25%	100%	70%	53%	66%	41%	19%	33%	46%	46%
VA Existing	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
VA Existing	5300 Base Monitor, LCD	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5301 Energy Star or Better Monitor - LCD	58%	97%	62%	98%	99%	84%	94%	43%	58%	72%	85%	85%
VA Existing	5302 Monitor Power Management Enabling - LCD	46%	55%	23%	95%	7%	14%	30%	74%	46%	33%	20%	20%
VA Existing	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
VA Existing	5400 Base Copier	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5401 Energy Star or Better Copier	43%	67%	65%	99%	53%	24%	78%	42%	43%	51%	60%	60%
VA Existing	5402 Copier Power Management Enabling	25%	60%	29%	96%	21%	25%	38%	24%	25%	28%	30%	30%
VA Existing	5500 Base Multifunction	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5501 Multifunction Power Management Enabling	33%	100%	25%	63%	17%	35%	25%	33%	33%	32%	30%	30%
VA Existing	5502 ENERGY STAR Multi-Function Printer	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%	50%
VA Existing	5600 Base Printer	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5601 Printer Power Management Enabling	33%	100%	25%	63%	17%	35%	25%	33%	33%	32%	30%	30%
VA Existing	5602 ENERGY STAR Printer	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%
VA Existing	5700 Base Data Center/Server Room	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5701 Data Center Improved Operations	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%	80%
VA Existing	5702 Data Center Best Practices	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%	90%
VA Existing	5703 Data Center State of the Art practices	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	5704 Data Center Airflow Management												
VA Existing	6000 Base Water Heating	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	6001 Demand controlled circulating systems	79%	100%	40%	97%	51%	100%	100%	100%	79%	89%	100%	100%
VA Existing	6002 High Efficiency Water Heater (electric)	100%	100%	99%	100%	100%	97%	100%	100%	100%	100%	100%	100%
VA Existing	6003 Hot Water Pipe Insulation	92%	76%	100%	99%	20%	91%	44%	85%	0%	81%	96%	86%
VA Existing	6004 Tankless Water Heater	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	6005 Heat Pump Water Heater (air source)	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	6006 Heat Recovery Unit	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	6007 Heat Trap	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%	75%
VA Existing	6008 Solar Water Heater	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	7000 Base Refrigerated Vending Machines	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	7001 Vending Misers (Refrigerated units)	88%	100%	80%	85%	57%	92%	96%	92%	100%	85%	100%	100%
VA Existing	7002 Vending Misers (Refrigerated glass-front units)	88%	100%	80%	85%	57%	92%	96%	92%	100%	85%	100%	100%
VA Existing	7100 Base Non-Refrigerated Vending Machines	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	7101 Vending Misers (Non-Refrigerated)	88%	100%	80%	85%	57%	92%	96%	92%	100%	85%	100%	100%
VA Existing	7200 Base Oven	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	7201 Convection Oven	0%	100%	100%	0%	0%	100%	0%	0%	0%	0%	0%	0%
VA Existing	7300 Base Fryer	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

Commercial Elec	Measure Inputs	INCOMPLET	E FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging Da	ta Centern-	lurisdicticia	ious Wor	Misc
VA Existing	7301 Efficient Fryer	0%		100%	0%	0%	0%	100%	0%	0%	50%	100%	100%
VA Existing	7400 Base Steamer	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	7401 Efficient Steamer	0%		79%	100%	0%	76%	0%	0%	0%	0%	0%	0%
VA Existing	8000 Base Heating, Heat Pump (7.7 HSPF)	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%	92%
VA Existing	8100 Base Heating, Other Electric	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	9500 Base Miscellaneous	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	9501 Xmisc	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	98%	100%	100%	98%	78%	99%	100%	100%	98%	99%	100%	100%
NC Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1003 ROB 4L4'T5, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1004 ROB 4L4' LED Tube, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1005 LED Troffer (base 4L4T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	97%	93%	100%	98%	100%	86%	99%	100%	97%	98%	99%	99%
NC Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	99%	98%	100%	100%	100%	94%	93%	93%	100%	100%	100%	100%
NC Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	98%	100%	100%	98%	78%	99%	100%	100%	98%	99%	100%	100%
NC Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1013 ROB 4L4'T5, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1014 ROB 4L4' LED Tube, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	97%	93%	100%	98%	100%	86%	99%	100%	97%	98%	99%	99%
NC Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	99%	98%	100%	100%	100%	94%	93%	93%	100%	100%	100%	100%
NC Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1020 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	98%	100%	100%	98%	78%	99%	100%	100%	98%	99%	100%	100%
NC Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1023 ROB 4L4'T5, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1024 ROB 4L4' LED Tube, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	97%	93%	100%	98%	100%	86%	99%	100%	97%	98%	99%	99%
NC Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	99%	98%	100%	100%	100%	94%	93%	93%	100%	100%	100%	100%
NC Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	98%	100%	100%	98%	78%	99%	100%	100%	98%	99%	100%	100%
NC Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1033 ROB 4L4'T5, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1034 ROB 4L4' LED Tube, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1035 LED Troffer (base 4L4'T8), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	97%	93%	100%	98%	100%	86%	99%	100%	97%	98%	99%	99%
NC Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	99%	98%	100%	100%	100%	94%	93%	93%	100%	100%	100%	100%
NC Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	100%	100%	100%	95%	99%	98%	100%	100%	100%	95%	90%	90%
NC Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	100%		100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1103 ROB 2L4'T5, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1104 ROB 2L4' LED Tube, 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1106 Lighting Control Tuneup (base 2L4T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	99%	98%	100%	100%	100%	94%	93%	93%	100%	100%	100%	100%
NC Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	100%	100%	100%	95%	99%	98%	100%	100%	100%	95%	90%	90%

Commercial Elec	Measure Inputs	INCOMPLET	E FACTOR										
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging D	ata Centern-	Jurisdicticigi	ous Wors	Misc
NC Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1113 ROB 2L4'T5, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1114 ROB 2L4' LED Tube, 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1115 LED Troffer (base 2L4T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	99%	98%	100%	100%	100%	94%	93%	93%	100%	100%	100%	100%
NC Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	100%	100%	100%	95%	99%	98%	100%	100%	100%	95%	90%	90%
NC Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1123 ROB 2L4'T5, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1124 ROB 2L4' LED Tube, 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1125 LED Troffer (base 2L4T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	99%	98%	100%	100%	100%	94%	93%	93%	100%	100%	100%	100%
NC Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2018-2019	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
NC Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%

												1000	10-17
Commercial Ele	c Measure Inputs		SY SATURATION	N									
		(units/square	: 100t)										
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging a	ta Centen-	Jurisdictielig	ious Wors	Misc
VA Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	0.0114		0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1003 ROB 4L4'T5, 2014-2015	0.0114		0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1004 ROB 4L4' LED Tube, 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	0.0114		0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	1.0000		1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	1.0000		1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	0.0114		0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1013 ROB 4L4'T5, 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1014 ROB 4L4' LED Tube, 2016-2017	0.0114		0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	1.0000		1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
/A Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	0.0114		0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
/A Existing	1020 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1023 ROB 4L4'T5, 2018-2019	0.0114		0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1024 ROB 4L4' LED Tube, 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
/A Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
'A Existing	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1033 ROB 4L4'T5, 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1034 ROB 4L4' LED Tube, 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1035 LED Troffer (base 4L4'T8), 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
VA Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
/A Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
/A Existing	1100 Base Fluorescent Fixture, 2L4T8, 1EB, 2014-2015	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1103 ROB 2L4'T5, 2014-2015	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1104 ROB 2L4' LED Tube, 2014-2015	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
'A Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
/A Existing	1110 Base Fluorescent Fixture, 2L4T8, 1EB, 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
'A Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
'A Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1113 ROB 2L4'T5, 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1114 ROB 2L4' LED Tube, 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	1.0000		1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
A Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	1.0000		1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
A Existing A Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
A Existing A Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
/A Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA LABING	1122 NOD 224 LOW Wall High renominance to (15 W), 2010-2015	0.0116	0.0132	0.0097	0.0103	0.0001	0.0112	0.0000	0.0039	0.0110	0.0103	0.0030	0.0030

Commercial Ele	c Measure Inputs	TECHNOLOG	Y SATURATIO	N									
		(units/square	foot)										
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodeine	to Conta	lurio-ti-si ti	gious Wors	Misc
VA Existing	1123 ROB 2L4'T5, 2018-2019	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1124 ROB 2L4* IS, 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1131 ROB 2L4' High Performance T8 (86 W), 2020	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1133 ROB 2L4'T5, 2020	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1134 ROB 2L4' LED Tube, 2020	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1135 LED Troffer (base 2L4'T8), 2020	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1136 Lighting Control Tuneup (base 2L4'T8), 2020	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
VA Existing	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1200 Base Other Fluorescent Fixture	0.0190	0.0000	0.0100	0.0000	0.0192	0.0042	0.0095	0.0052	0.0190	0.0081	0.0050	0.0050
VA Existing	1201 ROB High Performance T8 (base other fluorescent)	0.0190	0.0000	0.0100	0.0000	0.0192	0.0042	0.0095	0.0052	0.0190	0.0081	0.0050	0.0050
VA Existing	1202 ROB Low Watt High Performance T8 (base other fluorescent)	0.0190	0.0000	0.0100	0.0000	0.0192	0.0042	0.0095	0.0052	0.0190	0.0081	0.0050	0.0050
VA Existing	1203 Lighting Control Tuneup (base other fluorescent fixture)	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	0.0190	0.0000	0.0100	0.0000	0.0192	0.0042	0.0095	0.0052	0.0190	0.0081	0.0050	0.0050
VA Existing	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1301 CFLs (base incandescent flood) 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1302 LEDs (base incandescent flood) 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1311 CFLs (base incandescent flood) 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1312 LEDs (base incandescent flood) 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1321 CFLs (base incandescent flood) 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1322 LEDs (base incandescent flood) 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1331 CFLs (base incandescent flood) 2020	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1332 LEDs (base incandescent flood) 2020	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1401 CFLs (base incandescent A-line 72W) 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1402 LEDs (base incandescent A-line 72W) 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1411 CFLs (base incandescent A-line 72W) 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1412 LEDs (base incandescent A-line 72W) 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1421 CFLs (base incandescent A-line 72W) 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1422 LEDs (base incandescent A-line 72W) 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1431 CFLs (base incandescent A-line 72W) 2020	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1432 LEDs (base incandescent A-line 72W) 2020	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1501 CFLs (base incandescent A-line 53W) 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1502 LEDs (base incandescent A-line 53W) 2014-2015	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1510 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1511 CFLs (base incandescent A-Line 53W) 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1512 LEDs (base incandescent A-line 53W) 2016-2017	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing VA Existing	1520 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing VA Existing	1521 CFLs (base incandescent A-line 53W) 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing	1522 LEDs (base incandescent A-line 53W) 2018-2019	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing VA Existing	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing VA Existing	1531 CFLs (base incandescent A-line 53W) 2020	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063	0.0175	0.0684	0.0241	0.0155	0.0155
VA Existing VA Existing	· · · · · · · · · · · · · · · · · · ·	0.0684	0.0162	0.0197	0.0157	0.0000	0.0008	0.0063		0.0684	0.0241	0.0155	0.0155
	1532 LEDs (base incandescent A-line 53W) 2020	0.0684	0.0162	0.0197	0.015/	0.0000	0.0008	0.0063	0.0175	0.0084	0.0241	0.0100	0.0105

Commercial Ele	c Measure Inputs	TECHNOLOG	Y SATURATION	N									
		(units/square	foot)										
0	Measure # Measure Description	0//		D 4 7			E1				1		
Segment VA Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	Office 0.0157	Restaurant 0.0166	0.0127	Grocery 0.0774	Warehouse 0.0132	Education 0.0286	Health 0.0081	0.0123	0.0157	0.0170	gious Wors 0.0111	Misc 0.0111
VA Existing	1601 LED screw-in replacement (base CFL 18W) 2014-2015	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1610 Base CFL 18W to screw-in replacement 2016-2017	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1611 LED screw-in replacement (base CFL 18W) 2016-2017	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1620 Base CFL 18W to screw-in replacement 2018-2019	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1621 LED screw-in replacement (base CFL 18W) 2018-2019	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1630 Base CFL 18W to screw-in replacement 2020	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1631 LED screw-in replacement (base CFL 18W) 2020	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1700 Base CFL 23W to screw-in replacement 2014-2015	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1701 LED screw-in replacement (base CFL 23W) 2014-2015	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1710 Base CFL 23W to screw-in replacement 2016-2017	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1711 LED screw-in replacement (base CFL 23W) 2016-2017	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1720 Base CFL 23W to screw-in replacement 2018-2019	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1721 LED screw-in replacement (base CFL 23W) 2018-2019	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1730 Base CFL 23W to screw-in replacement 2020	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1731 LED screw-in replacement (base CFL 23W) 2020	0.0157	0.0166	0.0127	0.0774	0.0132	0.0286	0.0081	0.0123	0.0157	0.0170	0.0111	0.0111
VA Existing	1800 BaseMetal Halide, 465W	0.0000	0.0001	0.0000	0.0086	0.0015	0.0045	0.0000	0.0024	0.0000	0.0019	0.0013	0.0013
VA Existing	1801 T5 (240W) (base metal halide)	0.0000	0.0001	0.0000	0.0086	0.0015	0.0045	0.0000	0.0024	0.0000	0.0019	0.0013	0.0013
VA Existing	1802 Induction High Bay Lighting	0.0000	0.0001	0.0000	0.0086	0.0015	0.0045	0.0000	0.0024	0.0000	0.0019	0.0013	0.0013
VA Existing	1803 PSMH + electronic ballast	0.0000	0.0001	0.0000	0.0086	0.0015	0.0045	0.0000	0.0024	0.0000	0.0019	0.0013	0.0013
VA Existing	1804 PSMH, magnetic ballast, 320 W	0.0000	0.0001 1.0000	0.0000	0.0086	0.0015	0.0045	0.0000	0.0024 1.0000	0.0000 1.0000	0.0019 1.0000	0.0013 1.0000	0.0013
VA Existing VA Existing	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1806 Occupancy Sensor, High Bay T5	1.0000 0.0000	0.0001	1.0000 0.0000	1.0000 0.0086	1.0000 0.0015	1.0000 0.0045	1.0000 0.0000	0.0024	0.0000	0.0019	0.0013	1.0000 0.0013
-		0.0003	0.0001	0.0000	0.0000	0.0013	0.0045	0.0005	0.0024	0.0000	0.0019	0.0013	0.0013
VA Existing VA Existing	1850 Base CFL Exit Sign 1851 LED Exit Sign	0.0003	0.0005	0.0002	0.0001	0.0000	0.0001	0.0005	0.0003	0.0003	0.0002	0.0001	0.0001
VA Existing VA Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp	0.0008	0.0003	0.0002	0.0001	0.0004	0.0001	0.0003	0.0003	0.0003	0.0002	0.0001	0.0001
VA Existing	1901 Outdoor Lighting Controls (Photocell/Timeclock)	0.0008	0.0028	0.0009	0.0003	0.0004	0.0006	0.0003	0.0003	0.0008	0.0005	0.0003	0.0003
VA Existing	1902 LED Outdoor Area Lighting	0.0008	0.0028	0.0009	0.0003	0.0004	0.0006	0.0003	0.0003	0.0008	0.0005	0.0003	0.0003
VA Existing	1903 Bi-Level LED Outdoor Lighting	0.0008	0.0028	0.0009	0.0003	0.0004	0.0006	0.0003	0.0003	0.0008	0.0005	0.0003	0.0003
VA Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2002 Window Film (Standard) - Chiller	0.0877	0.0284	0.0409	0.0460	1.0172	0.0335	0.0171	0.0171	0.0877	0.0877	0.0284	0.0284
VA Existing	2003 EMS - Chiller	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2004 Cool Roof - Chiller	0.3315	1.0000	0.8973	1.0000	1.0000	0.4838	0.2500	0.2500	0.3315	0.3315	0.5000	0.5000
VA Existing	2005 Chiller Tune Up/Diagnostics	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2006 VSD for Chiller Pumps and Towers	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2007 EMS Optimization - Chiller	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	2008 New Economizer - Chiller	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2009 Dual Enthalpy Economizer Replaced Dry Bulb Economizer - Chiller	0.00001	0.00001	0.00001	0.00000	0.00004	0.00001	0.00001	0.00001	0.00001	0.00001	0.00000	0.00000
VA Existing	2010 Ceiling/roof Insulation - Chiller	0.3315	1.0000	0.8973	1.0000	1.0000	0.4838	0.2500	0.2500	0.3315	0.3315	0.5000	0.5000
VA Existing	2011 Duct/Pipe Insulation - Chiller	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500
VA Existing	2012 Duct Testing/Sealing	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2013 High Efficiency Chiller Motors	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2100 Base DX Packaged System, EER=10.3, 10 tons	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2101 DX Packaged System, EER=10.9, 10 tons	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2102 DX Packaged System, EER=13.4, 10 tons	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2103 Geothermal Heat Pump, EER=13, 10 tons - DX	0.0030	0.0030 0.0030	0.0030	0.0025	0.0189 0.0189	0.0025	0.0025	0.0035 0.0035	0.0030	0.0030	0.0020 0.0020	0.0020
VA Existing	2104 DX Coil Cleaning	0.0030	0.0030	0.0030	0.0025 0.0025	0.0189	0.0025 0.0025	0.0025 0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2105 DX Tune Up/ Advanced Diagnostics 2106 Prog. Thermostat - DX	0.0030 0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020 0.0020
VA Existing VA Existing	2106 Prog. Thermostat - DX 2107 Cool Roof - DX	0.0030	1.0000	0.0030	1.0000	1.0000	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing VA Existing	2108 Optimize Controls - DX	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing VA Existing	2109 Economizer - DX	0.0030	0.0030	0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	0.0030	0.0030	0.0030	0.0023	0.0019	0.0023	0.0023	0.0003	0.0003	0.0003	0.0020	0.0020
				0.0003	0.0002								0.0002
_	2111 Economizer Repair - DX	U UUU.3	0 0003						0 0004	0.0003	0 0003	0.0002	
VA Existing VA Existing	2111 Economizer Repair - DX 2112 Aerosol Duct Sealing - DX	0.0003 0.0030	0.0003 0.0030	0.0003	0.0002	0.0019 0.0189	0.0003 0.0025	0.0003 0.0025	0.0004 0.0035	0.0003	0.0003	0.0002 0.0020	0.0002

												100	10-10-
Commercial Ele	c Measure Inputs		SY SATURATIO	N									
		(units/square	toot)										
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging (a	ata Conton	Juriedictiali	gious Wors	Misc
VA Existing	2114 Duct/Pipe Insulation - DX	0.2500		0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500	0.2500
VA Existing	2115 Window Film (Standard) - DX	0.0877	0.0284	0.0409	0.0460	1.0172	0.0335	0.0171	0.0171	0.0877	0.0877	0.0284	0.0284
VA Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001
VA Existing	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001
VA Existing	2300 Base PTAC, EER=8.3, 1 ton	0.0000	0.0000	0.0000	0.0000	0.0000	0.0020	0.0000	0.0024	0.0000	0.0000	0.0018	0.0018
VA Existing	2301 HE PTAC, EER=9.6, 1 ton	0.0000	0.0000	0.0000	0.0000	0.0000	0.0020	0.0000	0.0024	0.0000	0.0000	0.0018	0.0018
VA Existing	2302 Occupancy Sensor (hotels)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0020	0.0000	0.0024	0.0000	0.0000	0.0018	0.0018
VA Existing	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	0.0003	0.0018	0.0003	0.0005	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0005	0.0005
VA Existing	3001 Fan Motor, 5hp, 1800rpm, 89.5%	0.0003	0.0018	0.0003	0.0005	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0005	0.0005
VA Existing	3002 Variable Speed Drive Control, 5 HP	0.0003	0.0018	0.0003	0.0005	0.0003	0.0003	0.0003	0.0003	0.0003	0.0003	0.0005	0.0005
VA Existing	3003 Demand Controlled Ventilation	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	0.0002		0.0013	0.0000	0.0000	0.0006	0.0002	0.0000	0.0002	0.0002	0.0009	0.0009
VA Existing	3101 Fan Motor, 15hp, 1800rpm, 92.4%	0.0002		0.0013	0.0000	0.0000	0.0006	0.0002	0.0000	0.0002	0.0002	0.0009	0.0009
VA Existing	3102 Variable Speed Drive Control, 15 HP	0.0002		0.0013	0.0000	0.0000	0.0006	0.0002	0.0000	0.0002	0.0002	0.0009	0.0009
VA Existing	3103 Air Handler Optimization, 15 HP	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	0.0030		0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	3105 Energy Recovery Ventilation (ERV)	0.0030		0.0030	0.0025	0.0189	0.0025	0.0025	0.0035	0.0030	0.0030	0.0020	0.0020
VA Existing	3106 Separate Makeup Air / Exhaust Hoods AC	0.0002		0.0013	0.0000	0.0000	0.0006	0.0002	0.0000	0.0002	0.0002	0.0009	0.0009
VA Existing	3107 Demand Controlled Ventilation	1.0000		1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	0.0012		0.0019	0.0000	0.0004	0.0001	0.0000	0.0000	0.0012	0.0012	0.0024	0.0024
VA Existing	3201 Fan Motor, 40hp, 1800rpm, 94.1%	0.0012		0.0019 0.0019	0.0000	0.0004 0.0004	0.0001 0.0001	0.0000	0.0000	0.0012	0.0012	0.0024 0.0024	0.0024 0.0024
VA Existing VA Existing	3202 Variable Speed Drive Control, 40 HP 3203 Air Handler Optimization, 40 HP	0.0012 1.0000		1.0000	0.0000 1.0000	1.0000	1.0000	0.0000 1.0000	1.0000	1.0000	0.0012 1.0000	1.0000	1.0000
VA Existing VA Existing	3204 Demand Controlled Ventilation	1.0000		1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing VA Existing	4000 Base Built-Up Refrigeration System	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003
VA Existing VA Existing	4000 base built-op itemgeration system 4001 High-efficiency fan motors	0.00003		0.00003	0.00003	0.00003	0.00003	0.00003	0.00003		0.00003	0.00003	0.00003
VA Existing	4002 Strip curtains for walk-ins (built-up)	0.00003		0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003		0.00003	0.00003
VA Existing	4003 Auto-closer on main door to walk-in freezer (built-up)	0.00013		0.00008	0.00005	0.00001	0.00002	0.00027	0.00003	0.00015		0.00009	0.00009
VA Existing	4004 Night covers for display cases	0.00073		0.00058	0.01454	0.00000	0.00018	0.00026	0.00020	0.00073	0.00073	0.00024	0.00024
VA Existing	4005 Evaporator fan controller for MT walk-ins	0.00013		0.00008	0.00005	0.00001	0.00002	0.00027	0.00003	0.00015	0.00019	0.00009	0.00009
VA Existing	4006 Electronically commutated evaporator fan motor	0.00500	0.00500	0.00500	0.00500	0.00500	0.00500	0.00500	0.00500	0.00500	0.00500	0.00500	0.00500
VA Existing	4007 Efficient compressor motor	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003
VA Existing	4008 Compressor VSD retrofit	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003
VA Existing	4009 Floating head pressure controls	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003	0.00003
VA Existing	4010 Refrigeration Commissioning	0.00002	0.00078	0.00016	0.00155	0.00016	0.00012	0.00003	0.00002	0.00002	0.00002	0.00016	0.00016
VA Existing	4011 Demand Hot Gas Defrost	0.00002	0.00065	0.00013	0.00130	0.00013	0.00010	0.00002	0.00002	0.00002	0.00002	0.00013	0.00013
VA Existing	4012 Demand Defrost Electric	0.00002	0.00065	0.00013	0.00130	0.00013	0.00010	0.00002	0.00002	0.00002	0.00002	0.00013	0.00013
VA Existing	4013 Anti-sweat (humidistat) controls	0.00003		0.00003	0.00003	0.00003	0.00003	0.00003		0.00003		0.00003	0.00003
VA Existing	4014 Freezer-Cooler Replacement Gaskets	0.00073		0.00058	0.01454	0.00000	0.00018	0.00026	0.00020	0.00073	0.00073	0.00024	0.00024
VA Existing	4015 High R-Value Glass Doors	0.00073		0.00058	0.01454	0.00000	0.00018	0.00026	0.00020	0.00073		0.00024	0.00024
VA Existing	4016 LED Display Lighting	0.00073		0.00058	0.01454	0.00000	0.00018	0.00026	0.00020		0.00073	0.00024	0.00024
VA Existing	4017 Multiplex Compressor System	0.00002		0.00016	0.00155	0.00016	0.00012	0.00003				0.00016	0.00016
VA Existing	4018 Oversized Air Cooled Condenser	0.00002	0.00078	0.00016	0.00155	0.00016	0.00012	0.00003	0.00002	0.00002	0.00002	0.00016	0.00016
VA Existing	4019 Insulated suction lines												
VA Existing	4100 Base Self-Contained Refrigeration	0.0000	0.0003	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing	4101 Strip curtains for walk-ins (self-contained)	0.00239		0.00152	0.00167	0.00024	0.00029	0.00488	0.00056	0.00262	0.00339	0.00166	0.00166
VA Existing VA Existing	4102 Auto-closer on main door to walk-in freezer (self-contained)	0.00013 0.00001	0.00013 0.00025	0.00008	0.00009 0.00000	0.00001 0.00000	0.00002 0.00001	0.00027 0.00002		0.00015	0.00019	0.00009 0.00001	0.00009 0.00001
	4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Gaskets (self-contained)	0.00001		0.00009	0.00000	0.00000	0.00001	0.00002			0.00001	0.00001	
VA Existing VA Existing	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4105 Bi-level LED Case Lighting (self-contained units) 2014	0.00002	0.00052	0.00068	0.00017	0.00000	0.00002	0.00003	0.00002 0.00001	0.00002		0.00002	0.00002 0.00002
VA Existing VA Existing	4106 Energy-Star Refrigerator, solid door	0.00002	0.00044	0.00009	0.00000	0.00000	0.00002	0.00003		0.00002	0.00002	0.00002	0.00002
VA Existing VA Existing	4107 Energy-Star Freezer, solid door	0.00001		0.00009	0.00000	0.00000	0.000001	0.00002		0.00000		0.00001	0.00001
VA Existing VA Existing	4108 Energy-Star Refrigerator, glass door	0.00001	0.00007	0.00052	0.00010	0.00000	0.00000	0.00001	0.00000	0.00001	0.00000	0.00000	0.00000
VA Existing VA Existing	4109 Energy-Star Freezer, glass door	0.00001		0.00004	0.00001	0.00000	0.000001	0.00001	0.00001	0.00000	0.00000	0.00001	0.00001
VA Existing VA Existing	4110 Energy Star I ce Machines	0.00001	0.00007	0.00004	0.00000	0.00000	0.00000	0.00000	0.00001	0.00001	0.00000	0.00001	0.00001
VA Existing VA Existing	4111 Hydraulic-type door closer on reach-in cooler glass doors	0.00001	0.00023	0.00052	0.00001	0.00000	0.00001	0.00002	0.00000	0.00001	0.00001	0.00001	0.00001
VA Existing VA Existing	4112 Reach-in unit occupancy sensors	0.00001	0.00011	0.00052	0.00001	0.00000	0.00001	0.00001		0.00001		0.00001	0.00001
Labing	sacii iii aiii oocapaney oonooro	0.00001	3.00011	0.00002	5.00001	3.00000	3.30001	5.00001	0.00000	3.00001	3.00001	0.00001	0.00001

Commercial Ele	ec Measure Inputs		Y SATURATIO	N									
		(units/square	foot)										
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	ata Centen-	Jurisdictieli	igious Wors	Misc
VA Existing	5000 Base Desktop PC	0.00025	0.00024	0.00009	0.00015	0.00009	0.00012	0.00024	0.00009	0.00014	0.00020	0.00017	0.00011
VA Existing	5001 PC Network Power Management Enabling	0.00025	0.00024	0.00009	0.00015	0.00009	0.00012	0.00024	0.00009	0.00014	0.00020	0.00017	0.00011
VA Existing	5002 Energy Star or Better PC	0.00025	0.00024	0.00009	0.00015	0.00009	0.00012	0.00024	0.00009	0.00014		0.00017	0.00011
VA Existing	5003 Plug-load controls - Commercial Smart Strip (base desktop PC)	0.00025	0.00024	0.00009	0.00015	0.00009	0.00012	0.00024	0.00009	0.00014		0.00017	0.00011
VA Existing	5100 Base Laptop PC	0.00018	0.00010	0.00003	0.00004	0.00005	0.00010	0.00012				0.00011	0.00005
VA Existing	5101 Laptop Network Power Management Enabling	0.00018	0.00010	0.00003	0.00004	0.00005	0.00010	0.00012			0.00014	0.00011	0.00005
VA Existing	5102 Energy Star or Better Laptop	0.00018	0.00010	0.00003	0.00004	0.00005	0.00010	0.00012			0.00014	0.00011	0.00005
VA Existing	5103 Plug-load controls - Commercial Smart Strip (base desktop PC)	0.00018	0.00010	0.00003	0.00004	0.00005	0.00010	0.00012		80000.0		0.00011	0.00005
VA Existing	5200 Base Monitor, CRT	0.00012	0.00024	0.00005	0.00012	0.00004	0.00007	0.00014			0.00010	0.00009	0.00006
VA Existing	5201 Energy Star or Better Monitor - CRT	0.00012	0.00024	0.00005	0.00012	0.00004	0.00007	0.00014		0.00013		0.00009	0.00006
VA Existing	5202 Monitor Power Management Enabling - CRT	0.00012	0.00024	0.00005	0.00012	0.00004	0.00007	0.00014		0.00013		0.00009	0.00006
VA Existing	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	0.00012	0.00024	0.00005	0.00012	0.00004	0.00007	0.00014		0.00013		0.00009	0.00006
VA Existing	5300 Base Monitor, LCD	0.00021	0.00028	0.00007	0.00015	0.00007	0.00010	0.00019	0.00007	0.00014		0.00014	0.00009
VA Existing	5301 Energy Star or Better Monitor - LCD	0.00021	0.00028	0.00007	0.00015	0.00007	0.00010	0.00019	0.00007		0.00017	0.00014	0.00009
VA Existing	5302 Monitor Power Management Enabling - LCD	0.00021	0.00028 0.00028	0.00007 0.00007	0.00015	0.00007 0.00007	0.00010 0.00010	0.00019	0.00007	0.00014		0.00014 0.00014	0.00009
VA Existing	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	0.00021			0.00015			0.00019	0.00007	0.00014			
VA Existing	5400 Base Copier	0.00010	0.00015	0.00004	0.00012	0.00003	0.00004	0.00007	0.00003			0.00007	0.00004
VA Existing	5401 Energy Star or Better Copier	0.00010	0.00015	0.00004	0.00012	0.00003	0.00004	0.00007	0.00003		0.00006	0.00007	0.00004
VA Existing	5402 Copier Power Management Enabling	0.00010	0.00015	0.00004	0.00012	0.00003	0.00004	0.00007	0.00003		0.00006	0.00007	0.00004
VA Existing	5500 Base Multifunction	0.00011	0.00022 0.00022	0.00005	0.00011	0.00004	0.00003	0.00009	0.00003	0.00003		0.00007	0.00004
VA Existing	5501 Multifunction Power Management Enabling 5502 ENERGY STAR Multi-Function Printer	0.00011 0.00011	0.00022	0.00005 0.00005	0.00011 0.00011	0.00004 0.00004	0.00003	0.00009	0.00003		0.00006	0.00007	0.00004 0.00004
VA Existing VA Existing	5600 Base Printer	0.00011	0.00022	0.00005	0.000011	0.00004	0.00003	0.00009	0.00003	0.00003		0.00007	0.00004
VA Existing	5601 Printer Power Management Enabling	0.00012	0.00012	0.00004	0.00008	0.00004	0.00005	0.00009	0.00003		0.00010	0.00007	0.00005
VA Existing	5602 ENERGY STAR Printer	0.00012	0.00012	0.00004	0.00008	0.00004	0.00005	0.00009	0.00003		0.00010	0.00007 1.00000	0.00005
VA Existing	5700 Base Data Center/Server Room	1.00000	1.00000 1.00000	1.00000	1.00000 1.00000	1.00000 1.00000	1.00000 1.00000	1.00000	1.00000		1.00000	1.00000	1.00000
VA Existing	5701 Data Center Improved Operations 5702 Data Center Best Practices	1.00000 1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000		1.00000	1.00000	1.00000
VA Existing VA Existing	5702 Data Center State of the Art practices	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000		1.00000	1.00000	1.00000
VA Existing VA Existing	5704 Data Center State of the Art practices 5704 Data Center Airflow Management	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000	1.00000
VA Existing VA Existing	6000 Base Water Heating	0.0015	0.0027	0.0013	0.0021	0.0080	0.0025	0.0026	0.0038	0.0015	0.0015	0.0016	0.0016
VA Existing VA Existing	6001 Demand controlled circulating systems	0.0015	0.0027	0.0013	0.0021	0.0000	0.0025	0.0026	0.0038	0.0013	0.0015	0.0016	0.0016
VA Existing VA Existing	6002 High Efficiency Water Heater (electric)	0.001	0.0002	0.0001	0.0001	0.0002	0.0000	0.0006	0.0038	0.0001	0.0001	0.0001	0.0001
VA Existing VA Existing	6003 Hot Water Pipe Insulation	0.0013	0.0027	0.0013	0.0021	0.0060	0.0025	0.0026	0.0038	0.0013	0.0015	0.0016	0.0016
VA Existing VA Existing	6004 Tankless Water Heater	0.0011	0.0021	0.0010	0.0010	0.0080	0.0019	0.0026	0.0029	0.0011	0.0011	0.0012	0.0012
VA Existing VA Existing	6005 Heat Pump Water Heater (air source)	0.0015	0.0027	0.0013	0.0021	0.0080	0.0025	0.0026	0.0038	0.0015	0.0015	0.0016	0.0016
VA Existing VA Existing	6006 Heat Recovery Unit	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing VA Existing	6007 Heat Trap	0.0015	0.0027	0.0013	0.0021	0.0080	0.0025	0.0026	0.0038	0.0015	0.0015	0.0016	0.0016
VA Existing VA Existing	6008 Solar Water Heater	0.0015	0.0027	0.0013	0.0021	0.0080	0.0025	0.0026	0.0038	0.0015	0.0015	0.0016	0.0016
VA Existing	7000 Base Refrigerated Vending Machines	0.0000	0.0000	0.0000	0.0021	0.0000	0.0020	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing	7001 Vending Misers (Refrigerated units)	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing	7002 Vending Misers (Refrigerated glass-front units)	0.0000	0.0000	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing	7100 Base Non-Refrigerated Vending Machines	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing	7101 Vending Misers (Non-Refrigerated)	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing	7200 Base Oven	0.0001	0.0000	0.0001	0.0000	0.0000	0.0000	0.0002	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing VA Existing	7201 Convection Oven	0.0001	0.0002	0.0001	0.0000	0.0000	0.0000	0.0002	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing VA Existing	7300 Base Fryer	0.0001	0.0002	0.0001	0.0000	0.0000	0.0000	0.0002	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing VA Existing	7301 Efficient Fryer	0.0000	0.0001	0.0000	0.0000	0.0000	0.0000	0.0002	0.0000	0.0000	0.0000	0.0000	0.0000
VA Existing VA Existing	7400 Base Steamer	0.0002	0.0001	0.0001	0.0001	0.0000	0.0000	0.0002	0.0000	0.0000	0.0001	0.0000	0.0000
VA Existing VA Existing	7400 base steamer 7401 Efficient Steamer	0.0002	0.0002	0.0001	0.0001	0.0000	0.0000	0.0001	0.0000	0.0000	0.0001	0.0000	0.0000
VA Existing VA Existing	8000 Base Heating, Heat Pump (7.7 HSPF)	0.0002	0.0002	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0000	0.0001
VA Existing VA Existing	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001	0.0001
VA Existing VA Existing	8100 Base Heating, Other Electric	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing VA Existing	9500 Base Miscellaneous	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
_	9501 Xmisc	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
VA Existing NC Existing	9501 Xmisc 1000 Base Fluorescent Fixture, 4L4T8, 1EB, 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
ING EXISTING	1001 1100 414 Figir Ferioritative 10 (00 W), 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0005	0.0000	0.0000

Commercial Flo	c Measure Inputs	TECHNOLOG	Y SATURATIO	N									
Commercial Lic	e medadre riputa	(units/square		•									
Cog====+	Magazira # Magazira Deposition	2//	Danta: 1	D-4."	0	10/1	Educati	Haatti	1 - 4-1		to calle all control	101	N.45
Segment NC Existing	Measure # Measure Description 1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	Office 0.0114	Restaurant 0.0179	0.0094	Grocery 0.0123	Warehouse 0.0036	0.0093	0.0071	0.0046	o.0114	Jurisdictielie 0.0085	0.0066	0.0066
NC Existing	1003 ROB 4L4 Low Walt high Fertolinance 16 (75 W), 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1004 ROB 4L4* LED Tube. 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1006 Lighting Control Tuneup (base 4L4'T8), 2014-2015	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1010 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1013 ROB 4L4'T5, 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1014 ROB 4L4' LED Tube, 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1023 ROB 4L4'T5, 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1024 ROB 4L4' LED Tube, 2018-2019	0.0114	0.0179 0.0179	0.0094	0.0123 0.0123	0.0036 0.0036	0.0093	0.0071 0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	0.0114 1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	0.0066 1.0000
NC Existing NC Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing NC Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019 1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1033 ROB 4L4T5, 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1034 ROB 4L4' LED Tube, 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1035 LED Troffer (base 4L4'T8), 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	0.0114	0.0179	0.0094	0.0123	0.0036	0.0093	0.0071	0.0046	0.0114	0.0085	0.0066	0.0066
NC Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1100 Base Fluorescent Fixture, 2L4T8, 1EB, 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1103 ROB 2L4'T5, 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1104 ROB 2L4' LED Tube, 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1106 Lighting Control Tuneup (base 2L4'T8), 2014-2015	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2014-2015	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1110 Base Fluorescent Fixture, 2L4T8, 1EB, 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	0.0118		0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1113 ROB 2L4T5, 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1114 ROB 2L4' LED Tube, 2016-2017	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	0.0118	0.0152 1.0000	0.0097 1.0000	0.0183	0.0061 1.0000	0.0112	0.0060	0.0059	0.0118 1.0000	0.0105 1.0000	0.0096 1.0000	0.0096
NC Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017 1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	1.0000 0.0118		0.0097	1.0000 0.0183	0.0061	1.0000 0.0112	1.0000 0.0060	1.0000 0.0059	0.0118	0.0105	0.0096	1.0000 0.0096
NC Existing NC Existing	1117 Occupancy Sensor, 2L4 Fluorescent Fixtures, 2016-2017 1118 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2016-2017	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing NC Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4 18), 2016-2017 1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing NC Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1123 ROB 2L4 Low Watt High Performance 18 (75 W), 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1124 ROB 2L4 LED Tube, 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
INO ENGUING	1127 NOD 2L4 LLD 1000, 2010-2013	0.0118	0.0132	0.0097	0.0163	0.0001	0.0112	0.0000	0.0059	0.0110	0.0100	0.0090	0.0090

Commercial Elec	The second secon		Y SATURATION	N									
		(units/square	foot)										
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging a	ita Centen-	Jurisdictielie	gious Wors	Misc
NC Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096
NC Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000	1.0000
NC Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	0.0118	0.0152	0.0097	0.0183	0.0061	0.0112	0.0060	0.0059	0.0118	0.0105	0.0096	0.0096

Commercial Elec Mea	asure Inputs		Y*INCOMPLETE	*FEASIBILITY									
		(percent)											
	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health		ata Centers Ion-			Misc
VA Existing VA Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015 1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	62% 60%	2% 2%	29% 29%	42% 42%	57% 45%	57% 57%	47% 47%	3% 3%	46% 45%	48% 47%	25% 25%	20%
VA Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1003 ROB 4L4'T5, 2014-2015	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1004 ROB 4L4' LED Tube, 2014-2015	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1006 Lighting Control Tuneup (base 4L4T8), 2014-2015	10%	0%	1%	1%	19%	9%	1%	0%	3%	10%	3%	2%
VA Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	15%	0%	2%	3%	5%	16%	16%	0%	12%	8%	3%	3%
VA Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2014-2015 1010 Base Fluorescent Fixture, 4L4T8, 1EB, 2016-2017	18% 62%	1% 2%	9% 29%	13% 42%	17% 57%	17% 57%	14% 47%	1% 3%	14% 46%	14% 48%	8% 25%	6% 20%
VA Existing VA Existing	1010 Base Problescent Pixture, 4L4 To, 1EB, 2016-2017 1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	60%	2%	29%	42%	45%	57%	47%	3%	45%	47%	25%	20%
VA Existing VA Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1013 ROB 4L4'T5, 2016-2017	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1014 ROB 4L4' LED Tube, 2016-2017	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1015 LED Troffer (base 4L4'T8), 2016-2017	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1016 Lighting Control Tuneup (base 4L4'T8), 2016-2017	10%	0%	1%	1%	19%	9%	1%	0%	3%	10%	3%	2%
VA Existing	1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	15%	0%	2%	3%	5%	16%	16%	0%	12%	8%	3%	3%
VA Existing	1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	18%	1%	9%	13%	17%	17%	14%	1%	14%	14%	8%	6%
VA Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing VA Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019 1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	60% 62%	2% 2%	29% 29%	42% 42%	45% 57%	57% 57%	47% 47%	3% 3%	45% 46%	47% 48%	25% 25%	20% 20%
VA Existing VA Existing	1022 ROB 4L4 T5, 2018-2019	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing VA Existing	1024 ROB 4L4' LED Tube, 2018-2019	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1026 Lighting Control Tuneup (base 4L4T8), 2018-2019	10%	0%	1%	1%	19%	9%	1%	0%	3%	10%	3%	2%
VA Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	15%	0%	2%	3%	5%	16%	16%	0%	12%	8%	3%	3%
VA Existing	1028 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	18%	1%	9%	13%	17%	17%	14%	1%	14%	14%	8%	6%
VA Existing	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	60%	2%	29%	42%	45%	57%	47%	3%	45%	47%	25%	20%
VA Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing VA Existing	1033 ROB 4L4'T5, 2020 1034 ROB 4L4' LED Tube, 2020	62% 62%	2% 2%	29% 29%	42% 42%	57% 57%	57% 57%	47% 47%	3% 3%	46% 46%	48% 48%	25% 25%	20% 20%
VA Existing VA Existing	1034 ROB 4L4 LED 1006, 2020 1035 LED Troffer (base 4L4'T8), 2020	62%	2%	29%	42%	57%	57%	47%	3%	46%	48%	25%	20%
VA Existing VA Existing	1036 Lighting Control Tuneup (base 4L4T8), 2020	10%	0%	1%	1%	19%	9%	1%	0%	3%	10%	3%	2%
VA Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	15%	0%	2%	3%	5%	16%	16%	0%	12%	8%	3%	3%
VA Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	18%	1%	9%	13%	17%	17%	14%	1%	14%	14%	8%	6%
VA Existing	1100 Base Fluorescent Fixture, 2L4T8, 1EB, 2014-2015	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	2%	25%	10%	0%	0%	5%	12%	17%	1%	13%	21%	17%
VA Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1103 ROB 2L4'T5, 2014-2015	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1104 ROB 2L4' LED Tube, 2014-2015	1%	8%	3%	0%	0%	2%	4%	5%	0%	4%	7%	6%
VA Existing VA Existing	1105 LED Troffer (base 2L4T8), 2014-2015 1106 Lighting Control Tuneup (base 2L4T8), 2014-2015	2% 0%	25% 1%	10% 0%	0% 0%	0% 0%	5% 1%	12% 0%	17% 2%	1% 0%	14% 3%	24% 2%	19% 2%
VA Existing VA Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	0%	2%	1%	0%	0%	2%	4%	2%	0%	2%	3%	2%
VA Existing VA Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	1%	8%	3%	0%	0%	2%	4%	5%	0%	4%	7%	6%
VA Existing	1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	2%	25%	10%	0%	0%	5%	12%	17%	1%	13%	21%	17%
VA Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1113 ROB 2L4'T5, 2016-2017	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1114 ROB 2L4' LED Tube, 2016-2017	1%	8%	3%	0%	0%	2%	4%	5%	0%	4%	7%	6%
VA Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1116 Lighting Control Tuneup (base 2L4T8), 2016-2017	0%	1%	0%	0%	0%	1%	0%	2%	0%	3%	2%	2%
VA Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	0%	2% 8%	1%	0%	0% 0%	2% 2%	4% 4%	2% 5%	0% 0%	2% 4%	3% 7%	2% 6%
VA Existing VA Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017 1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	1% 2%	8% 25%	3% 10%	0% 0%	0%	2% 5%	4% 12%	5% 17%	0% 1%	4% 14%	7% 24%	19%
VA Existing VA Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	2%	25%	10%	0%	0%	5%	12%	17%	1%	13%	24%	17%
VA Existing VA Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1123 ROB 2L4'T5, 2018-2019	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1124 ROB 2L4' LED Tube, 2018-2019	1%	8%	3%	0%	0%	2%	4%	5%	0%	4%	7%	6%
VA Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1126 Lighting Control Tuneup (base 2L4T8), 2018-2019	0%	1%	0%	0%	0%	1%	0%	2%	0%	00/	2%	2%
VA Existing	5 5 5 6 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7 7	0%	2%	0 /0	0 /0	0 /0	1 /0	0%	2%	0%	3%	3%	270

Commercial Elec	Measure Inputs		Y*INCOMPLETE	E*FEASIBILITY									
		(percent)											
Seament	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centers Ion-	luriodiction/olic	gious Worshi	Misc
VA Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2018-2019	1%	Restaurant 8%	3%	0%	0%	2%	Health 4%	5%	0%	4%	7%	6%
VA Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1131 ROB 2L4' High Performance T8 (86 W), 2020	2%	25%	10%	0%	0%	5%	12%	17%	1%	13%	21%	17%
VA Existing	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1133 ROB 2L4'T5, 2020	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1134 ROB 2L4' LED Tube, 2020	1%	8%	3%	0%	0%	2%	4%	5%	0%	4%	7%	6%
VA Existing	1135 LED Troffer (base 2L4'T8), 2020	2%	25%	10%	0%	0%	5%	12%	17%	1%	14%	24%	19%
VA Existing	1136 Lighting Control Tuneup (base 2L4'T8), 2020	0%	1%	0%	0%	0%	1%	0%	2%	0%	3%	2%	2%
VA Existing	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	0%	2%	1%	0%	0%	2%	4%	2%	0%	2%	3%	2%
VA Existing	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	1%	8%	3%	0%	0%	2%	4%	5%	0%	4%	7%	6%
VA Existing	1200 Base Other Fluorescent Fixture	5%	0%	0%	0%	0%	2%	4%	1%	4%	3%	1%	1%
VA Existing	1201 ROB High Performance T8 (base other fluorescent)	5% 5%	0% 0%	0% 0%	0% 0%	0% 0%	2%	4%	1% 1%	4% 4%	3% 3%	1%	1%
VA Existing	1202 ROB Low Watt High Performance T8 (base other fluorescent)		0%	0%		0%	2% 0%	4%	1%	4% 0%	-,-	1% 0%	1% 0%
VA Existing VA Existing	1203 Lighting Control Tuneup (base other fluorescent fixture) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	1% 1%	0%	0%	0% 0%	0%	1%	0% 1%	0%	1%	1% 1%	0%	0%
VA Existing VA Existing	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	1%	0%	0%	0%	0%	1%	1%	0%	1%	1%	0%	0%
VA Existing VA Existing	1300 Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	7%	22%	10%	25%	3%	5%	9%	16%	5%	6%	11%	10%
VA Existing	1301 CFLs (base incandescent flood) 2014-2015	7%	11%	5%	22%	3%	4%	8%	11%	4%	5%	10%	9%
VA Existing	1302 LEDs (base incandescent flood) 2014-2015	5%	16%	9%	8%	1%	4%	8%	14%	4%	4%	10%	8%
VA Existing	1310 Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	7%	22%	10%	25%	3%	5%	9%	16%	5%	6%	11%	10%
VA Existing	1311 CFLs (base incandescent flood) 2016-2017	7%	11%	5%	22%	3%	4%	8%	11%	4%	5%	10%	9%
VA Existing	1312 LEDs (base incandescent flood) 2016-2017	5%	16%	9%	8%	1%	4%	8%	14%	4%	4%	10%	8%
VA Existing	1320 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	7%	22%	10%	25%	3%	5%	9%	16%	5%	6%	11%	10%
VA Existing	1321 CFLs (base incandescent flood) 2018-2019	7%	11%	5%	22%	3%	4%	8%	11%	4%	5%	10%	9%
VA Existing	1322 LEDs (base incandescent flood) 2018-2019	5%	16%	9%	8%	1%	4%	8%	14%	4%	4%	10%	8%
VA Existing	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	7%	22%	10%	25%	3%	5%	9%	16%	5%	6%	11%	10%
VA Existing	1331 CFLs (base incandescent flood) 2020	7%	11%	5%	22%	3%	4%	8%	11%	4%	5%	10%	9%
VA Existing	1332 LEDs (base incandescent flood) 2020	5%	16%	9%	8%	1%	4%	8%	14%	4%	4%	10%	8%
VA Existing	1400 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	4%	11%	5%	12%	1%	2%	4%	8%	2%	3%	5%	5%
VA Existing	1401 CFLs (base incandescent A-line 72W) 2014-2015	3%	5%	2%	11%	1%	2%	4%	6%	2%	3%	5%	5%
VA Existing VA Existing	1402 LEDs (base incandescent A-line 72W) 2014-2015 1410 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	2% 4%	8% 11%	5% 5%	4% 12%	1% 1%	2% 2%	4% 4%	7% 8%	2% 2%	2% 3%	5% 5%	4% 5%
VA Existing VA Existing	1410 Base Incandescent A-Line Lamp, 72vV to Screw-in Replacement 2016-2017 1411 CFLs (base incandescent A-line 72W) 2016-2017	4% 3%	5%	5% 2%	12%	1%	2% 2%	4% 4%	6%	2% 2%	3% 3%	5% 5%	5% 5%
VA Existing VA Existing	1411 CFLs (base incandescent A-line 72W) 2016-2017 1412 LEDs (base incandescent A-line 72W) 2016-2017	2%	8%	5%	4%	1%	2%	4%	7%	2%	2%	5%	4%
VA Existing VA Existing	1412 LEDS (base incandescent A-line F2W) 2010-2017 1420 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	4%	11%	5%	12%	1%	2%	4%	8%	2%	3%	5%	5%
VA Existing	1421 CFLs (base incandescent A-line 72W) 2018-2019	3%	5%	2%	11%	1%	2%	4%	6%	2%	3%	5%	5%
VA Existing	1422 LEDs (base incandescent A-line 72W) 2018-2019	2%	8%	5%	4%	1%	2%	4%	7%	2%	2%	5%	4%
VA Existing	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	4%	11%	5%	12%	1%	2%	4%	8%	2%	3%	5%	5%
VA Existing	1431 CFLs (base incandescent A-line 72W) 2020	3%	5%	2%	11%	1%	2%	4%	6%	2%	3%	5%	5%
VA Existing	1432 LEDs (base incandescent A-line 72W) 2020	2%	8%	5%	4%	1%	2%	4%	7%	2%	2%	5%	4%
VA Existing	1500 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	4%	11%	5%	12%	1%	2%	4%	8%	2%	3%	5%	5%
VA Existing	1501 CFLs (base incandescent A-line 53W) 2014-2015	3%	5%	2%	11%	1%	2%	4%	6%	2%	3%	5%	5%
VA Existing	1502 LEDs (base incandescent A-line 53W) 2014-2015	2%	8%	5%	4%	1%	2%	4%	7%	2%	2%	5%	4%
VA Existing	1510 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	4%	11%	5%	12%	1%	2%	4%	8%	2%	3%	5%	5%
VA Existing	1511 CFLs (base incandescent A-line 53W) 2016-2017	3%	5%	2%	11%	1%	2%	4%	6%	2%	3%	5%	5%
VA Existing	1512 LEDs (base incandescent A-line 53W) 2016-2017	2%	8%	5%	4%	1%	2%	4%	7%	2%	2%	5%	4%
VA Existing	1520 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	4%	11%	5%	12%	1%	2%	4%	8%	2%	3%	5%	5%
VA Existing	1521 CFLs (base incandescent A-line 53W) 2018-2019	3%	5%	2%	11%	1%	2%	4%	6%	2%	3%	5%	5%
VA Existing	1522 LEDs (base incandescent A-line 53W) 2018-2019	2%	8%	5%	4%	1%	2%	4%	7%	2%	2%	5%	4%
VA Existing VA Existing	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1531 CFLs (base incandescent A-line 53W) 2020	4% 3%	11% 5%	5% 2%	12% 11%	1% 1%	2% 2%	4% 4%	8% 6%	2% 2%	3% 3%	5% 5%	5% 5%
VA Existing VA Existing	1532 LEDs (base incandescent A-line 53W) 2020	2%	8%	2% 5%	4%	1%	2%	4%	7%	2%	2%	5%	4%
VA Existing VA Existing	1600 Base CFL 18W to screw-in replacement 2014-2015	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing VA Existing	1601 LED screw-in replacement (base CFL 18W) 2014-2015	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1610 Base CFL 18W to screw-in replacement 2016-2017	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1611 LED screw-in replacement (base CFL 18W) 2016-2017	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1620 Base CFL 18W to screw-in replacement 2018-2019	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1621 LED screw-in replacement (base CFL 18W) 2018-2019	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1630 Base CFL 18W to screw-in replacement 2020	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1631 LED screw-in replacement (base CFL 18W) 2020	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1700 Base CFL 23W to screw-in replacement 2014-2015	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1701 LED screw-in replacement (base CFL 23W) 2014-2015	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%

Commercial Elec Mea	asure Inputs	APPLICABILIT (percent)	Y*INCOMPLETE	*FEASIBILITY									
Seament	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging D	ata Centers Ion-	Lurisdiction;elia	ious Worshi	Misc
VA Existing	1710 Base CFL 23W to screw-in replacement 2016-2017	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1711 LED screw-in replacement (base CFL 23W) 2016-2017	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1720 Base CFL 23W to screw-in replacement 2018-2019	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1721 LED screw-in replacement (base CFL 23W) 2018-2019	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1730 Base CFL 23W to screw-in replacement 2020	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
/A Existing	1731 LED screw-in replacement (base CFL 23W) 2020	8%	14%	17%	1%	6%	10%	9%	19%	17%	11%	9%	11%
VA Existing	1800 BaseMetal Halide, 465W	2%	3%	4%	1%	25%	5%	2%	6%	2%	9%	2%	6%
VA Existing	1801 T5 (240W) (base metal halide)	2%	2%	3%	1%	18%	4%	1%	4%	1%	6%	1%	4%
VA Existing	1802 Induction High Bay Lighting	2%	2%	3%	1%	18%	4%	1%	4%	1%	6%	1%	4%
VA Existing	1803 PSMH + electronic ballast	2%	2%	3%	1%	18%	2%	1%	4%	1%	6%	1%	4%
VA Existing	1804 PSMH, magnetic ballast, 320 W	2%	2%	3%	1%	18%	4%	1%	4%	1%	6%	1%	4%
VA Existing VA Existing	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1806 Occupancy Sensor, High Bay T5	1% 0%	1% 0%	1% 1%	0% 0%	8% 4%	2% 1%	1% 0%	2% 1%	0% 0%	3% 1%	1% 0%	2% 1%
VA Existing	1850 Base CFL Exit Sign	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%	100%
VA Existing	1851 LED Exit Sign	35%	64%	58%	1%	100%	56%	6%	35%	35%	37%	39%	39%
VA Existing	1900 Base Outdoor High Pressure Sodium 250W Lamp	43%	62%	41%	25%	72%	85%	64%	92%	93%	79%	89%	68%
VA Existing	1901 Outdoor Lighting Controls (Photocell/Timeclock)	21%	38%	14%	11%	10%	32%	20%	30%	16%	19%	5%	19%
VA Existing	1902 LED Outdoor Area Lighting	43%	62%	41%	25%	72%	85%	64%	92%	93%	79%	89%	68%
VA Existing	1903 Bi-Level LED Outdoor Lighting	35%	50%	33%	20%	58%	68%	51%	73%	74%	63%	71%	54%
VA Existing	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	13%	15%	1%	3%	0%	40%	19%	27%	66%	44%	15%	8%
VA Existing	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	9%	10%	1%	2%	0%	27%	13%	18%	45%	30%	10%	6%
VA Existing	2002 Window Film (Standard) - Chiller	0%	0%	0%	2%	0%	5%	2%	13%	0%	14%	9%	5%
VA Existing	2003 EMS - Chiller	9%	12%	1%	3%	0%	23%	17%	20%	14%	16%	7%	7%
VA Existing	2004 Cool Roof - Chiller	2%	0%	0%	1%	0%	12%	8%	13%	11%	15%	7%	4%
VA Existing	2005 Chiller Tune Up/Diagnostics	0%	0%	0%	0%	0%	1%	0%	7%	0%	3%	0%	1%
VA Existing	2006 VSD for Chiller Pumps and Towers	1%	0%	0%	3%	0%	1%	0%	1%	4%	9%	6%	3%
VA Existing	2007 EMS Optimization - Chiller	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	2008 New Economizer - Chiller	2%	0%	0%	0%	0%	29%	10%	18%	12%	25%	14%	8%
VA Existing VA Existing	2009 Dual Enthalpy Economizer Replaced Dry Bulb Economizer - Chiller 2010 Ceiling/roof Insulation - Chiller	0% 0%	0% 8%	0% 0%	0% 0%	0% 0%	0% 0%	0% 0%	0% 0%	0% 2%	0% 3%	0% 1%	0% 1%
VA Existing	2011 Duct/Pipe Insulation - Chiller	2%	0%	0%	2%	0%	12%	11%	7%	10%	18%	10%	6%
VA Existing	2012 Duct Testing/Sealing	13%	13%	1%	3%	0%	34%	19%	27%	66%	43%	14%	8%
VA Existing	2013 High Efficiency Chiller Motors	1%	0%	0%	3%	0%	1%	2%	0%	4%	3%	0%	0%
VA Existing	2100 Base DX Packaged System, EER=10.3, 10 tons	58%	77%	50%	84%	37%	95%	65%	68%	38%	54%	47%	32%
VA Existing	2101 DX Packaged System, EER=10.9, 10 tons	58%	77%	50%	84%	37%	95%	65%	68%	38%	54%	47%	32%
VA Existing	2102 DX Packaged System, EER=13.4, 10 tons	58%	77%	50%	84%	37%	95%	65%	68%	38%	54%	47%	32%
VA Existing	2103 Geothermal Heat Pump, EER=13, 10 tons - DX	3%	4%	2%	4%	2%	5%	3%	3%	2%	3%	2%	2%
VA Existing	2104 DX Coil Cleaning	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%	0%
VA Existing	2105 DX Tune Up/ Advanced Diagnostics	2%	2%	4%	2%	0%	3%	1%	18%	0%	4%	0%	2%
VA Existing	2106 Prog. Thermostat - DX	24%	33%	28%	23%	25%	18%	24%	36%	34%	36%	21%	12%
VA Existing	2107 Cool Roof - DX	27%	35%	16%	42%	14%	45%	32%	34%	18%	26%	24%	16%
VA Existing	2108 Optimize Controls - DX	19%	25%	16%	28%	12%	31%	21%	22%	12%	18%	16%	10%
VA Existing	2109 Economizer - DX	21%	12%	14%	0%	6%	11%	28%	26%	14%	16%	12%	8%
VA Existing	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	0.4%	1.4%	0.5%	2.2%	0.6%	1.9%	0.2%	0.4%	0.2%	0%	1%	1%
VA Existing VA Existing	2111 Economizer Repair - DX 2112 Aerosol Duct Sealing - DX	8.4% 19%	28.3% 23%	10.9% 16%	43.7% 27%	12.7% 11%	38.6% 26%	4.6% 21%	8.7% 22%	3.2% 12%	5% 17%	11% 15%	11% 10%
VA Existing	2112 Aerosof Duct Sealing - DX 2113 Ceiling/roof Insulation - DX	0.0%	0.2%	0.0%	0.8%	12.9%	0.4%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	2114 Duct/Pipe Insulation - DX	18.5%	46.9%	18.0%	62.7%	3.6%	56.7%	35.4%	36.8%	12.0%	17%	15%	10%
VA Existing	2115 Window Film (Standard) - DX	12.1%	53.8%	7.2%	62.1%	11.9%	21.7%	29.6%	49.5%	7.8%	15%	16%	10%
VA Existing	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	40%	24%	18%	7%	20%	75%	41%	53%	5%	23%	39%	30%
VA Existing	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	36.4%	22.2%	16.9%	6.9%	18.4%	69.1%	37.9%	48.5%	4.4%	22%	36%	28%
VA Existing	2300 Base PTAC, EER=8.3, 1 ton	6.3%	2.9%	3.2%	3.5%	0.9%	68.4%	9.2%	11.1%	0.0%	36%	38%	19%
VA Existing	2301 HE PTAC, EER=9.6, 1 ton	6%	3%	3%	3%	1%	68%	9%	11%	0%	36%	38%	19%
VA Existing	2302 Occupancy Sensor (hotels)	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	8.3%	0.0%	0%	0%	0%
VA Existing	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	42.5%	50.4%	43.3%	96.7%	30.2%	33.4%	18.8%	65.4%	18.8%	48%	54%	54%
VA Existing	3001 Fan Motor, 5hp, 1800rpm, 89.5%	31%	39%	31%	75%	24%	26%	15%	51%	14%	36%	42%	42%
VA Existing	3002 Variable Speed Drive Control, 5 HP	25.8%	49.5%	41.5%	96.6%	30.2%	28.7%	16.9%	0.0%	4.7%	29%	53%	50%
VA Existing	3003 Demand Controlled Ventilation	14.1%	46.5%	30.3%	96.7%	2.1%	30.9%	12.3%	65.4%	6.2%	11%	6%	6%
VA Existing	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	7%	0%	2%	0%	0%	89%	65%	0%	65%	25%	43%	43%
VA Existing	3101 Fan Motor, 15hp, 1800rpm, 92.4%	2.9%	0.0%	0.3%	0.0%	0.0%	57.3%	10.0%	0.0%	26.0%	17%	43%	43%
VA Existing	3102 Variable Speed Drive Control, 15 HP	4.5%	0.0%	1.4%	0.0%	0.0%	76.7%	58.8%	0.0%	16.2%	15%	42%	40%
VA Existing	3103 Air Handler Optimization, 15 HP	7%	0%	2%	0%	0%	89%	0%	0%	62%	20%	28%	28%

DNV.GL

Commercial Elec Me	Inputs	APPLICABILITY (percent)	TY*INCOMPLETE	*FEASIBILITY									
Seament	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging [Data Centers lor	n-Jurisdiction:elic	ious Worshi	Misc
VA Existing	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	3.1%	0.0%	1.5%	0.0%	0.0%	87.5%	65.4%	0.0%	27.5%	18%	43%	43%
VA Existing	3105 Energy Recovery Ventilation (ERV)	2.4%	0.0%	1.5%	0.0%	0.0%	62.1%	65.4%	0.0%	21.2%	7%	7%	7%
VA Existing	3106 Separate Makeup Air / Exhaust Hoods AC	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	3107 Demand Controlled Ventilation	2.4%	0.0%	1.1%	0.0%	0.0%	82.8%	42.6%	0.0%	21.6%	6%	5%	5%
VA Existing	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	4.6%	0.0%	1.5%	95.6%	10.0%	37.3%	69.5%	11.3%	69.5%	19%	34%	34%
VA Existing	3201 Fan Motor, 40hp, 1800rpm, 94.1%	1.8%	0.0%	0.3%	95.6%	0.0%	7.2%	0.0%	0.0%	27.6%	7%	12%	12%
VA Existing	3202 Variable Speed Drive Control, 40 HP	2.8%	0.0%	1.4%	95.5%	10.0%	32.0%	62.5%	0.0%	17.2%	12%	33%	32%
VA Existing	3203 Air Handler Optimization, 40 HP	4.4%	0.0%	1.5%	95.6%	10.0%	37.3%	0.0%	11.3%	66.1%	16%	22%	22%
VA Existing	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	1.5% 8.7%	0.0% 67.0%	1.1% 17.4%	95.6% 91.4%	0.7% 37.3%	34.5% 36.6%	45.3% 25.6%	11.3% 37.7%	23.0%	4% 40%	4% 43%	4% 18%
VA Existing VA Existing	4001 High-efficiency fan motors	3.6%	37.5%	4.9%	25.5%	8.9%	18.3%	25.6%	0.0%	0.9%	16%	15%	6%
VA Existing	4001 Filigheric Filian Holois 4002 Strip curtains for walk-ins (built-up)	8%	40%	14%	19%	4%	32%	19%	18%	0.9%	19%	43%	7%
VA Existing	4003 Auto-closer on main door to walk-in freezer (built-up)	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	4004 Night covers for display cases	6.0%	64.1%	16.9%	82.7%	37.3%	36.6%	24.8%	37.5%	2.3%	28%	43%	17%
VA Existing	4005 Evaporator fan controller for MT walk-ins	5.2%	17.7%	8.9%	20.1%	1.8%	7.6%	9.5%	11.2%	0.0%	18%	29%	10%
VA Existing	4006 Electronically commutated evaporator fan motor	5.6%	67.0%	8.3%	52.1%	17.9%	36.6%	25.6%	37.7%	1.5%	33%	43%	18%
VA Existing	4007 Efficient compressor motor	0.0%	0.0%	0.0%	2.4%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	4008 Compressor VSD retrofit	5.0%	67.0%	17.4%	91.4%	0.0%	27.7%	25.6%	37.7%	1.3%	32%	43%	18%
VA Existing	4009 Floating head pressure controls	0.0%	0.0%	0.0%	3.1%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	4010 Refrigeration Commissioning	0.9%	6.7%	5.2%	9.1%	3.7%	3.7%	2.6%	3.8%	0.2%	4%	4%	2%
VA Existing	4011 Demand Hot Gas Defrost	5.0%	67.0%	17.4%	91.4%	0.0%	27.7%	25.6%	37.7%	1.3%	32%	43%	18%
VA Existing	4012 Demand Defrost Electric	0.0%	0.0%	3.4%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	4013 Anti-sweat (humidistat) controls	0.0%	0.0%	0.0%	24.6%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	4014 Freezer-Cooler Replacement Gaskets	4.3%	33.5%	8.7%	45.7%	18.6%	18.3%	12.8%	18.9%	1.1%	20%	22%	9%
VA Existing	4015 High R-Value Glass Doors	0.0%	0.0%	17.4%	86.6%	0.0%	0.0%	0.0%	0.0%	0.0%	20%	43%	18%
VA Existing VA Existing	4016 LED Display Lighting 4017 Multiplex Compressor System	8.7% 0%	50.9% 0%	10.2% 0%	88.8% 10%	35.3% 0%	34.3% 0%	24.9% 0%	37.2% 0%	2.3% 0%	35% 0%	43% 0%	14% 0%
VA Existing VA Existing	4017 Multiplex Compressor System 4018 Oversized Air Cooled Condenser	4.3%	33.5%	8.7%	45.7%	18.6%	18.3%	12.8%	18.9%	1.1%	20%	22%	9%
VA Existing	4019 Insulated suction lines	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	4100 Base Self-Contained Refrigeration	68%	91%	71%	94%	90%	83%	77%	78%	95%	85%	96%	62%
VA Existing	4101 Strip curtains for walk-ins (self-contained)	10.8%	54.4%	14.1%	19.6%	3.5%	19.2%	19.3%	28.3%	0.0%	27%	2%	11%
VA Existing	4102 Auto-closer on main door to walk-in freezer (self-contained)	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	4103 Night covers for display cases (self-contained)	5%	46%	15%	25%	2%	32%	14%	37%	0%	23%	10%	17%
VA Existing	4104 Freezer-Cooler Replacement Gaskets (self-contained)	33.9%	45.6%	35.6%	46.9%	44.8%	41.6%	38.3%	39.0%	47.6%	42%	48%	31%
VA Existing	4105 Bi-level LED Case Lighting (self-contained units) 2014	8.7%	50.9%	10.2%	88.8%	1.4%	34.3%	24.9%	29.2%	2.3%	35%	43%	14%
VA Existing	4106 Energy-Star Refrigerator, solid door	5.6%	42.9%	11.1%	58.5%	0.9%	23.4%	16.4%	19.0%	1.5%	26%	28%	12%
VA Existing	4107 Energy-Star Freezer, solid door	5.7%	44.2%	11.5%	60.3%	1.0%	24.1%	16.9%	19.6%	1.5%	27%	29%	12%
VA Existing	4108 Energy-Star Refrigerator, glass door	5.6%	42.9%	11.1%	58.5%	0.9%	23.4%	16.4%	19.0%	1.5%	26%	28%	12%
VA Existing	4109 Energy-Star Freezer, glass door	6%	43%	11%	58%	1%	23%	16%	19%	1%	26%	28%	12%
VA Existing	4110 Energy Star Ice Machines	11.0%	56.3%	10.6%	46.8%	25.3%	53.3%	22.0%	49.9%	4.0%	43%	52%	23%
VA Existing	4111 Hydraulic-type door closer on reach-in cooler glass doors	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	4112 Reach-in unit occupancy sensors 5000 Base Desktop PC	8.7% 97.6%	67.0% 63.7%	10.7% 80.3%	88.0% 84.9%	1.5% 97.9%	36.6% 99.6%	25.2% 95.0%	29.3% 96.9%	2.3% 97.7%	35% 98%	43% 95%	14% 90%
VA Existing VA Existing	5000 Base Desktop PC 5001 PC Network Power Management Enabling	55%	36%	80.3% 45%	84.9% 48%	97.9% 55%	99.6% 56%	95.0% 53%	96.9% 55%	97.7% 55%	98% 55%	95% 54%	50%
VA Existing VA Existing	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	62.6%	63.0%	30.9%	83.1%	97.0%	82.7%	89.6%	52.2%	62.7%	76%	88%	82%
VA Existing	5003 Plug-load controls - Commercial Smart Strip (base desktop PC)	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	02 /8
VA Existing	5100 Base Laptop PC	86.9%	44.0%	60.5%	65.7%	85.5%	97.5%	68.2%	86.6%	90.1%	83%	72%	71%
VA Existing	5101 Laptop Network Power Management Enabling	25.2%	12.7%	17.5%	19.1%	24.8%	28.3%	19.8%	25.1%	26.1%	24%	21%	20%
VA Existing	5102 Energy Star or Better Laptop	47.3%	23.9%	32.9%	35.7%	46.5%	53.0%	37.1%	47.1%	49.0%	45%	39%	38%
VA Existing	5103 Plug-load controls - Commercial Smart Strip (base laptop PC)	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	5200 Base Monitor, CRT	59.8%	46.8%	41.7%	28.1%	68.3%	93.6%	64.4%	83.7%	78.9%	60%	45%	51%
VA Existing	5201 Energy Star or Better Monitor - CRT	34.6%	46.8%	41.7%	28.1%	68.3%	93.6%	61.4%	83.7%	45.7%	47%	45%	51%
VA Existing	5202 Monitor Power Management Enabling - CRT	8.5%	15.6%	7.8%	21.1%	35.7%	37.5%	31.9%	25.7%	11.2%	15%	16%	18%
VA Existing	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	29.9%	23.4%	20.8%	14.1%	34.2%	46.8%	32.2%	41.8%	39.4%	30%	23%	25%
VA Existing	5300 Base Monitor, LCD	78.6%	42.2%	48.4%	91.8%	75.3%	93.3%	77.7%	87.1%	94.9%	96%	89%	78%
VA Existing	5301 Energy Star or Better Monitor - LCD	45.8%	41.1%	30.2%	89.9%	74.3%	78.0%	73.3%	37.5%	55.3%	69%	76%	66%
VA Existing	5302 Monitor Power Management Enabling - LCD	27.1%	17.5%	8.5%	65.4%	3.8%	9.9%	17.2%	48.3%	32.6%	24%	14%	12%
VA Existing	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	39.3%	21.1%	24.2%	45.9%	37.6%	46.6%	38.9%	43.5%	47.4%	48%	45%	39%
VA Existing	5400 Base Copier	96.6%	44.8%	87.1%	29.0%	89.4%	98.6%	99.3%	93.6%	95.2%	97%	98%	86%
VA Existing	5401 Energy Star or Better Copier	41.3%	30.0%	56.3%	28.7%	47.0%	23.2%	77.9%	39.0%	40.7%	50%	59%	51%
VA Existing	5402 Copier Power Management Enabling	18% 96.6%	20% 78.2%	19%	21% 84.0%	14%	18%	29% 83.6%	17%	18%	20% 97%	22% 91%	19% 86%
VA Existing	5500 Base Multifunction	96.6%	10.2%	81.5%	04.0%	93.9%	97.9%	03.0%	93.3%	90.1%	9170	9176	00%

DNV.GL

Commercial Elec Mea	asure Inputs	APPLICABILIT (percent)	Y*INCOMPLETE	*FEASIBILITY									
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging D	ata Centers Ion-	Jurisdictionælig	ious Worshi	Misc
VA Existing	5501 Multifunction Power Management Enabling	24.0%	58.7%	15.2%	39.7%	11.7%	25.7%	15.5%	23.3%	22.4%	23%	20%	19%
VA Existing	5502 ENERGY STAR Multi-Function Printer	48.5%	39.3%	40.9%	42.1%	47.1%	49.1%	42.0%	46.8%	45.2%	49%	46%	43%
VA Existing	5600 Base Printer	95.4%	30.3%	51.1%	17.4%	83.1%	98.6%	82.5%	42.8%	69.0%	92%	53%	71%
VA Existing VA Existing	5601 Printer Power Management Enabling 5602 ENERGY STAR Printer	23.7% 76.3%	22.7% 24.2%	9.5% 40.9%	8.2% 13.9%	10.4% 66.5%	25.9% 78.9%	15.3% 66.0%	10.7% 34.3%	17.1% 55.2%	22% 73%	12% 42%	16% 57%
VA Existing VA Existing	5700 Base Data Center/Server Room	0.2%	0.1%	40.9% 0.0%	0.0%	0.1%	78.9% 0.4%	0.3%	0.2%	100.0%	73% 0%	42% 0%	57% 0%
VA Existing	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	0.2%	0.1%	0.0%	0.0%	0.1%	0.4%	0.3%	0.2%	48.0%	0%	0%	0%
VA Existing	5701 Data Center Improved Operations 5702 Data Center Best Practices	0.1%	0.0%	0.0%	0.0%	0.1%	0.1%	0.1%	0.1%	27.0%	0%	0%	0%
VA Existing	5703 Data Center State of the Art practices	0%	0.0%	0.0%	0.0%	0.0%	0.176	0.170	0.0%	10%	0%	0%	0%
VA Existing	5704 Data Center Airflow Management	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	6000 Base Water Heating	88.9%	39.3%	62.5%	77.9%	82.6%	72.5%	55.4%	31.2%	88.9%	39%	71%	51%
VA Existing	6001 Demand controlled circulating systems	52.6%	29.5%	18.7%	56.7%	31.4%	54.4%	41.6%	23.4%	52.6%	26%	54%	38%
VA Existing	6002 High Efficiency Water Heater (electric)	89%	39%	62%	78%	83%	70%	55%	31%	89%	39%	71%	51%
VA Existing	6003 Hot Water Pipe Insulation	47.2%	29.7%	51.4%	77.4%	16.1%	36.1%	24.4%	26.6%	0.0%	25%	68%	44%
VA Existing	6004 Tankless Water Heater	66.6%	29.5%	46.9%	58.4%	62.0%	54.4%	41.6%	23.4%	66.7%	29%	54%	38%
VA Existing	6005 Heat Pump Water Heater (air source)	71%	31%	50%	62%	66%	58%	44%	25%	71%	31%	57%	41%
VA Existing	6006 Heat Recovery Unit	8.9%	31.4%	3.1%	62.3%	8.3%	10.9%	44.3%	6.2%	8.9%	3%	4%	3%
VA Existing	6007 Heat Trap	50.0%	22.1%	35.2%	43.8%	46.5%	40.8%	31.2%	17.6%	50.0%	22%	40%	29%
VA Existing	6008 Solar Water Heater	68%	8%	3%	16%	40%	7%	11%	6%	68%	15%	0%	0%
VA Existing	7000 Base Refrigerated Vending Machines	99.3%	100.0%	90.1%	98.3%	98.6%	100.0%	98.6%	95.7%	100.0%	98%	100%	97%
VA Existing	7001 Vending Misers (Refrigerated units)	30.7%	34.8%	25.3%	29.4%	19.6%	32.3%	33.0%	30.8%	35.0%	29%	35%	34%
VA Existing	7002 Vending Misers (Refrigerated glass-front units)	31%	35%	25%	29%	20%	32%	33%	31%	35%	29%	35%	34%
VA Existing	7100 Base Non-Refrigerated Vending Machines	78.1%	88.4%	53.8%	11.4%	95.2%	70.9%	74.4%	31.5%	100.0%	68%	3%	47%
VA Existing	7101 Vending Misers (Non-Refrigerated)	69%	88%	43%	10%	54%	65%	71%	29%	100%	58%	3%	47%
VA Existing	7200 Base Oven	1.7%	15.1%	3.5%	55.7%	15.0%	7.6%	4.5%	20.4%	0.1%	22%	49%	5%
VA Existing	7201 Convection Oven	0.0%	15.1%	3.5%	0.0%	0.0%	7.6%	0.0%	0.0%	0.0%	0%	0%	0%
VA Existing	7300 Base Fryer	1.3%	19.1%	1.3%	49.1%	10.9%	11.2%	2.5%	19.2%	0.1%	13%	1%	4%
VA Existing	7301 Efficient Fryer	0%	19% 15.3%	1%	0% 41.9%	0%	0%	3% 4.5%	0% 7.0%	0%	7%	1% 3%	4% 2%
VA Existing VA Existing	7400 Base Steamer 7401 Efficient Steamer	1.0%	15.3%	1.3% 1.0%	41.9%	10.9%	1.1% 0.8%	4.5% 0.0%	0.0%	0.1%	16% 0%	3% 0%	2% 0%
VA Existing VA Existing	8000 Base Heating, Heat Pump (7.7 HSPF)	34.7%	7.6%	7.7%	3.1%	1.5%	17.2%	22.8%	25.4%	0.0%	6%	6%	22%
VA Existing VA Existing	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	32.0%	7.0%	7.1%	2.9%	1.4%	15.8%	21.0%	23.3%	0.0%	6%	5%	21%
VA Existing	8100 Base Heating, Other Electric	35.1%	21.1%	28.1%	76.2%	12.0%	0.0%	32.1%	20.3%	41.2%	14%	46%	21%
VA Existing	9500 Base Miscellaneous	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100%	100%	100%
VA Existing	9501 Xmisc	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100.0%	100%	100%	100%
NC Existing	1000 Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1001 ROB 4L4' High Performance T8 (86 W), 2014-2015	79%	4%	51%	61%	68%	10%	54%	2%	45%	47%	13%	9%
NC Existing	1002 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1003 ROB 4L4'T5, 2014-2015	80%	4%	51%	62%	86%	11%	54%	2%	46%	48%	13%	9%
NC Existing	1004 ROB 4L4' LED Tube, 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1005 LED Troffer (base 4L4'T8), 2014-2015	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1006 Lighting Control Tuneup (base 4L4T8), 2014-2015	0.9%	0.1%	0.0%	0.1%	0.0%	0.6%	3.8%	0.1%	0.0%	0%	0%	0%
NC Existing	1007 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	22.3%	0.3%	3.5%	4.3%	12.1%	3.5%	17.4%	0.2%	12.8%	10%	2%	1%
NC Existing	1008 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2014-2015	24%	1%	15%	18%	26%	3%	16%	1%	14%	14%	4%	3%
NC Existing	1010 Base Fluorescent Fixture, 4L4T8, 1EB, 2016-2017	80%	4%	51%	62%	86%	11%	54%	2%	46%	48%	13%	9%
NC Existing	1011 ROB 4L4' High Performance T8 (86 W), 2016-2017	79%	4%	51%	61%	68%	10%	54%	2%	45%	47%	13%	9%
NC Existing	1012 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1013 ROB 4L4'T5, 2016-2017	80%	4%	51%	62%	86%	11%	54%	2%	46%	48%	13%	9%
NC Existing	1014 ROB 4L4' LED Tube, 2016-2017 1015 LED Troffer (base 4L4'T8), 2016-2017	80.4% 80.4%	4.1% 4.1%	50.7% 50.7%	61.7% 61.7%	86.4% 86.4%	10.6% 10.6%	53.6% 53.6%	1.9%	45.8% 45.8%	48% 48%	13% 13%	9% 9%
NC Existing NC Existing	1015 LED Troffer (base 4L418), 2016-2017 1016 Lighting Control Tuneup (base 4L418), 2016-2017	80.4% 0.9%	4.1% 0.1%	0.0%	0.1%	0.0%	10.6% 0.6%	3.8%	1.9% 0.1%	45.8% 0.0%	48% 0%	13% 0%	9% 0%
NC Existing NC Existing	1016 Lighting Control Tuneup (base 4L4 18), 2016-2017 1017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	22.3%	0.1%	3.5%	4.3%	12.1%	3.5%	3.8% 17.4%	0.1%	12.8%	10%	2%	1%
NC Existing	1017 Occupancy Sensor, 4L4 Problescent Fixtures, 2016-2017 1018 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	24.1%	1.2%	15.2%	18.5%	25.9%	3.2%	16.1%	0.6%	13.7%	14%	4%	3%
NC Existing	1020 Base Fluorescent Fixture, 4L4T8, 1EB, 2018-2019	80.4%	4.1%	50.7%	61.7%	25.9% 86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1021 ROB 4L4' High Performance T8 (86 W), 2018-2019	78.6%	4.1%	50.7%	60.6%	67.6%	10.4%	53.6%	1.9%	44.7%	47%	13%	9%
NC Existing	1022 ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.4%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1023 ROB 4L4'T5, 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1024 ROB 4L4' LED Tube, 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1025 LED Troffer (base 4L4'T8), 2018-2019	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9%
NC Existing	1026 Lighting Control Tuneup (base 4L4'T8), 2018-2019	0.9%	0.1%	0.0%	0.1%	0.0%	0.6%	3.8%	0.1%	0.0%	0%	0%	0%
	, ,												
NC Existing	1027 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	22%	0%	4%	4%	12%	3%	17%	0%	13%	10%	2%	1%

DNV.GL

Commercial Elec	Measure Inputs	APPLICABILIT	Y*INCOMPLETI	*FEASIBILITY	,								
		(percent)											
Segment	Measure # Measure Description	Office	Restaurant	Retail	Grocery	Warehouse	Education	Health	Lodging	Data Centers lo	on-Jurisdiction:eligi	ious Worshi	Misc
NC Existing	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	99
IC Existing	1031 ROB 4L4' High Performance T8 (86 W), 2020	78.6%	4.1%	50.7%	60.6%	67.6%	10.4%	53.6%	1.9%	44.7%	47%	13%	99
NC Existing	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	99
NC Existing	1033 ROB 4L4'T5, 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	9
NC Existing	1034 ROB 4L4' LED Tube, 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	91
NC Existing	1035 LED Troffer (base 4L4'T8), 2020	80.4%	4.1%	50.7%	61.7%	86.4%	10.6%	53.6%	1.9%	45.8%	48%	13%	91
NC Existing	1036 Lighting Control Tuneup (base 4L4'T8), 2020	0.9%	0.1%	0.0%	0.1%	0.0%	0.6%	3.8%	0.1%	0.0%	0%	0%	09
NC Existing	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	22.3%	0.3%	3.5%	4.3%	12.1%	3.5%	17.4%	0.2%	12.8%	10%	2%	19
NC Existing	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	24.1%	1.2%	15.2%	18.5%	25.9%	3.2%	16.1%	0.6%	13.7%	14%	4%	39
NC Existing	1100 Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1101 ROB 2L4' High Performance T8 (86 W), 2014-2015	2.3%	51.0%	17.3%	0.2%	0.6%	1.0%	13.6%	10.7%	1.3%	13%	11%	89
NC Existing	1102 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	2%	51%	17%	0%	1%	1%	14%	11%	1%	14%	12%	99
NC Existing	1103 ROB 2L4'T5, 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1104 ROB 2L4' LED Tube, 2014-2015	0.7%	15.3%	5.2%	0.1%	0.2%	0.3%	4.1%	3.2%	0.4%	4%	4%	39
NC Existing	1105 LED Troffer (base 2L4'T8), 2014-2015	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1106 Lighting Control Tuneup (base 2L4T8), 2014-2015	0.0%	1.0%	0.0%	0.0%	0.0%	0.1%	1.0%	0.7%	0.0%	0%	0%	09
NC Existing	1107 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	0.6%	3.5%	1.2%	0.0%	0.1%	0.3%	4.4%	1.4%	0.4%	3%	2%	19
NC Existing	1108 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	0.7%	15.3%	5.2%	0.1%	0.2%	0.3%	4.1%	3.2%	0.4%	4%	4%	39
NC Existing	1110 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1111 ROB 2L4' High Performance T8 (86 W), 2016-2017	2.3%	51.0%	17.3%	0.2%	0.6%	1.0%	13.6%	10.7%	1.3%	13%	11%	89
NC Existing	1112 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1113 ROB 2L4'T5, 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1114 ROB 2L4' LED Tube, 2016-2017	0.7%	15.3%	5.2%	0.1%	0.2%	0.3%	4.1%	3.2%	0.4%	4%	4%	39
NC Existing	1115 LED Troffer (base 2L4'T8), 2016-2017	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1116 Lighting Control Tuneup (base 2L4'T8), 2016-2017	0%	1%	0%	0%	0%	0%	1%	1%	0%	0%	0%	09
NC Existing	1117 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	0.6%	3.5%	1.2%	0.0%	0.1%	0.3%	4.4%	1.4%	0.4%	3%	2%	19
NC Existing	1118 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	0.7%	15.3%	5.2%	0.1%	0.2%	0.3%	4.1%	3.2%	0.4%	4%	4%	39
NC Existing	1120 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1121 ROB 2L4' High Performance T8 (86 W), 2018-2019	2.3%	51.0%	17.3%	0.2%	0.6%	1.0%	13.6%	10.7%	1.3%	13%	11%	89
NC Existing	1122 ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1123 ROB 2L4'T5, 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1124 ROB 2L4' LED Tube, 2018-2019	0.7%	15.3%	5.2%	0.1%	0.2%	0.3%	4.1%	3.2%	0.4%	4%	4%	39
NC Existing	1125 LED Troffer (base 2L4'T8), 2018-2019	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99
NC Existing	1126 Lighting Control Tuneup (base 2L4'T8), 2018-2019	0.0%	1.0%	0.0%	0.0%	0.0%	0.1%	1.0%	0.7%	0.0%	0%	0%	09
NC Existing	1127 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	0.6%	3.5%	1.2%	0.0%	0.1%	0.3%	4.4%	1.4%	0.4%	3%	2%	19
NC Existing	1128 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2018-2019	0.7%	15.3%	5.2%	0.1%	0.2%	0.3%	4.1%	3.2%	0.4%	4%	4%	39
NC Existing	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	2.3%	51.0%	17.3%	0.3%	0.6%	1.0%	13.6%	10.7%	1.3%	14%	12%	99

F NON-ADDITIVE MEASURE LEVEL RESULTS

The results presented in this chapter represent the initial measure screening for the study. Results are based only on measure costs and savings and do not include any program marketing and administrative costs. As a result, the TRCs shown here will be higher (the measure will appear more cost effective) than TRCs for the same measure once program costs are added in during the achievable savings analysis. In addition, these results do not take into account any interaction between the measures; all measures are evaluated independently. In practice some of these measures compete against each other for the same market share (for example 10.8 EER room air conditioners and 13.4 EER room air conditioners) and are therefore not additive. Also, measures that affect the same base energy use, such as ceiling insulation and a high efficiency central air conditioner, are assumed to be installed independently of each other in this analysis.

Resid	lential Electric Existing Construction																
DSM ASS	YST SUMMARY										System	Levelized Cost	Levelized Cost	Total			
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Household	Base UEC	UEC	Peak Watts/ Household	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)	Revenue Test
1000	Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	Single Family	0%	0%	0.0	3,071.7	3,071.7	1,824.9	18	0	0	N/A	N/A	N/A	N/A	N/A	N/A
1001	14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	Single Family	7%	7%	252.5	3,107.2	2,885.3	1,714.1	18	129	77	0.11	187	0.91	1.04	10.68	0.86
1002 1003	15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Single Family	13% 24%	13% 24%	514.5 1,085.6	3,138.7 3,191.9	2,720.2 2,440.9	1,616.0	18	243 436	144 259	0.12 0.14	202 238	0.84 0.71	0.96 0.82	11.54 13.57	0.86 0.86
1003	17 SEER (12.28 EER) Split-System Air Conditioner (CAC) Proper Refrigerant Charging and Air Flow (CAC)	Single Family Single Family	10%	10%	159.0	3,157.5	2,440.9	1,450.1 1,693.9	18 10	152	259 91	0.14	238 85	1.12	1.57	4.87	0.86
1005	Proper Sizing and Quality Install (CAC)	Single Family	13%	13%	540.5	3.187.8	2,773.4	1,647.6	18	206	123	0.13	215	0.79	0.91	12.24	0.86
1006	AC Maintenance and/or tune-up (CAC)	Single Family	1%	1%	101.0	3,088.9	3,058.0	1,816.7	4	9	6	0.32	538	0.07	0.12	30.70	0.63
1007	AC Filter Changes (CAC)	Single Family	1%	1%	24.6	3,089.5	3,058.6	1,817.1	1	9	5	0.08	131	0.07	0.13	7.47	0.59
1008	Ceiling R-0 to R-38 Insulation (CAC)	Single Family	18%	18%	1,013.8	3,071.7	2,505.2	1,488.3	20	60	36	0.17	294	0.63	0.70	16.80	0.88
1009 1010	Ceiling R-0 to R-49 Insulation (CAC) Ceiling R-11 to R-38 Insulaton (CAC)	Single Family Single Family	19% 6%	19% 6%	1,255.1 772.7	3,071.7 3,071.7	2,494.9 2.877.9	1,482.2 1,709.7	20 20	41 44	24 26	0.21 0.39	358 656	0.51 0.28	0.58 0.31	20.43 37.42	0.88
1010	Ceiling R-11 to R-49 Insulation (CAC)	Single Family	7%	7%	1.013.8	3.071.7	2.866.0	1,702.7	20	31	19	0.48	811	0.23	0.25	46.27	0.88
1012	Ceiling R-19 to R-38 Insulation (CAC)	Single Family	3%	3%	597.2	3,071.7	2,981.6	1,771.3	20	12	7	0.65	1,090	0.17	0.19	62.18	0.88
1013	Ceiling R-19 to R-49 Insulation (CAC)	Single Family	3%	3%	838.5	3,071.7	2,969.3	1,764.0	20	9	5	0.80	1,346	0.14	0.15	76.82	0.88
1014	Crawlspace insulation (CAC)	Single Family	2%	2%	110.6	3,088.6	3,023.8	1,796.4	20	14	8	0.17	281	0.66	0.73	16.05	0.88
1015 1016	Basement insulation R-13 (CAC) Floor R-0 to R-19 Insulation-Batts (CAC)	Single Family	2% 2%	2% 2%	1,120.0	3,088.6	3,023.8	1,796.4	20 20	9	5 0	1.69 1.94	2,847 3,262	0.06	0.07	162.48 186.18	0.88 0.88
1016	Wall Blow-in R-0 to R-13 Insulation (CAC)	Single Family Single Family	2%	2%	1,283.3 781.3	3,128.9	3,023.8	1,796.4 1,819.9	20	4	3	1.94	1,960	0.06	0.06	111.88	0.88
1018	Cool Roof (CAC)	Single Family	2%	2%	390.6	3,084.2	3,019.6	1,793.9	15	36	21	0.59	994	0.15	0.18	56.75	0.82
1019	Duct Insulation (CAC)	Single Family	2%	2%	58.8	3,134.1	3,068.4	1,822.9	20	2	1	0.09	147	1.25	1.40	8.40	0.88
1020	Duct Testing and Sealing (CAC)	Single Family	2%	2%	346.9	3,124.1	3,058.6	1,817.1	18	9	5	0.52	872	0.19	0.22	49.75	0.86
1021	Return Duct Modification (CAC)	Single Family	19%	19%	430.5	3,748.3	3,036.1	1,803.7	20	12	7	0.06	99	1.85	2.07	5.67	0.88
1022 1023	Programmable Thermostat (CAC) Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	Single Family Single Family	2% 6%	2% 6%	19.2 265.6	3,116.0 3,120.8	3,053.7 2,931.9	1,814.1 1,741.8	12 10	12 97	7 57	0.03 0.14	51 231	2.31 0.42	3.01 0.58	2.89 13.20	0.78 0.73
1023	Self Install Weatherization (CAC)	Single Family	2%	2%	5.7	3.099.5	3,037.5	1,804.5	10	24	14	0.01	15	6.31	8.81	0.87	0.73
1025	Door Weatherization (CAC)	Single Family	3%	3%	23.9	3,112.3	3,021.7	1,795.2	5	35	21	0.03	43	1.08	1.78	2.48	0.63
1026	Ceiling Fans (CAC)	Single Family	6%	6%	464.3	3,229.8	3,037.4	1,804.4	15	24	14	0.24	397	0.37	0.44	22.65	0.82
1027	Whole House Fans (CAC)	Single Family	3%	3%	665.0	3,080.9	2,991.3	1,777.1	15	56	33	0.72	1,220 949	0.12	0.14	69.63	0.82
1028 1029	Window Film (CAC) WINDOWS - Default With Sunscreen (CAC)	Single Family Single Family	3% 11%	3% 11%	598.4 493.5	3,071.7	2,968.0 2,770.7	1,763.2 1,646.0	10 10	72 208	43 124	0.56 0.14	949 243	0.10 0.39	0.14 0.55	54.16 13.88	0.73 0.73
1023	WINDOWS - Default Will Sunscient (CAC) WINDOWS - Double-Glazed Clear to Energy Star (CAC)	Single Family	2%	2%	375.7	3,112.1	3,056.8	1,816.0	20	10	6	0.66	1,117	0.39	0.18	63.73	0.73
1100	Base Split-System Air Conditioner - Early Replacement (11 SEER)	Single Family	0%	0%	0.0	2,861.8	2,861.8	1,700.2	8	0	0	N/A	N/A	N/A	N/A	N/A	N/A
1101	र (12.15 EER) Split-System Air Conditioner w/ Quality Install - Early Rep		3%	3%	704.9	2,875.8	2,788.4	1,656.6	8	9	5	0.79	1,328	0.06	0.09	75.76	0.67
1102	Proper Refrigerant Charging and Air Flow (CAC early replacement)	Single Family	10%	10%	159.0	2,906.9	2,625.0	1,559.4	10	29	17	0.06	93	1.04	1.45	5.29	0.73
1103 1104	Proper Sizing and Quality Install (CAC early replacement) AC Maintenance and/or tune-up (CAC early replacement)	Single Family Single Family	13% 1%	13% 1%	540.5 101.0	2,922.6 2,877.8	2,542.7 2,849.1	1,510.6 1,692.6	18 4	39 2	23	0.14 0.34	234 577	0.72 0.07	0.83 0.11	13.35 32.96	0.86 0.63
1104	AC Filter Changes (CAC early replacement)	Single Family	1%	1%	24.6	2,878.4	2,849.6	1,692.9	1	1	1	0.08	141	0.07	0.11	8.02	0.59
1106	Ceiling R-0 to R-38 Insulation (CAC early replacement)	Single Family	18%	18%	1,013.8	2,861.8	2,334.0	1,386.6	20	10	6	0.19	316	0.58	0.65	18.03	0.88
1107	Ceiling R-0 to R-49 Insulation (CAC early replacement)	Single Family	19%	19%	1,255.1	2,861.8	2,324.4	1,380.9	20	7	4	0.23	384	0.48	0.54	21.92	0.88
1108	Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Single Family	6%	6%	772.7	2,861.8	2,681.2	1,592.9	20	7	4	0.42	704	0.26	0.29	40.17	0.88
1109 1110	Ceiling R-11 to R-49 Insulation (CAC early replacement) Ceiling R-19 to R-38 Insulation (CAC early replacement)	Single Family	7% 3%	7% 3%	1,013.8 597.2	2,861.8	2,670.2 2,777.8	1,586.3 1.650.2	20 20	5 2	3	0.52 0.69	870 1.169	0.21 0.16	0.24 0.18	49.66 66.74	0.88 0.88
1111	Ceiling R-19 to R-36 Insulation (CAC early replacement) Ceiling R-19 to R-49 Insulation (CAC early replacement)	Single Family Single Family	3% 3%	3%	838.5	2,861.8	2,777.8	1,650.2	20	1	1	0.86	1,169	0.16	0.18	82.46	0.88
1112	Crawlspace insulation (CAC early replacement)	Single Family	2%	2%	110.6	2,877.5	2,817.2	1,673.6	20	2	1	0.18	302	0.61	0.68	17.22	0.88
1113	Basement insulation R-13 (CAC early replacement)	Single Family	18%	18%	1,120.0	3,004.1	2,456.8	1,459.5	20	14	8	0.20	337	0.55	0.61	19.21	0.88
1114	Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	Single Family	2%	2%	1,283.3	2,877.5	2,817.2	1,673.6	20	0	0	2.08	3,502	0.05	0.06	199.83	0.88
1115	Wall Blow-in R-0 to R-13 Insulation (CAC early replacement)	Single Family	2%	2%	781.3	2,915.0	2,854.0	1,695.5	20	1	0	1.25	2,104	0.09	0.10	120.09	0.88
1116 1117	Cool Roof (CAC early replacement) Duct Insulation (CAC early replacement)	Single Family Single Family	13% 14%	13% 14%	390.6 58.8	2,933.3 3,305.6	2,563.0 2,838.5	1,522.6 1,686.3	15 20	36 3	22 2	0.10 0.01	174 21	0.84 8.90	1.01 9.96	9.90 1.18	0.82 0.88
1118	Duct Testing and Sealing (CAC early replacement)	Single Family	4%	5%	346.9	2,968.7	2,835.1	1,684.3	18	3	2	0.25	427	0.40	0.46	24.37	0.86
1119	Return Duct Modification (CAC early replacement)	Single Family	19%	19%	430.5	3,492.1	2,828.6	1,680.4	20	2	1	0.06	107	1.73	1.93	6.09	0.88
1120	Programmable Thermostat (CAC early replacement)	Single Family	2%	2%	19.2	2,903.0	2,845.0	1,690.2	12	2	1	0.03	54	2.15	2.80	3.10	0.78
1121	Comprehensive Shell Air Sealing - Inf. Reduction (CAC early replacement		6%	6%	265.6	2,907.6	2,731.6	1,622.8	10	16	9	0.15	248	0.39	0.54	14.17	0.73
1122 1123	Self Install Weatherization (CAC early replacement) Door Weatherization (CAC early replacement)	Single Family Single Family	2% 3%	2% 3%	5.7 23.9	2,871.0	2,813.6 2.807.6	1,671.5 1.668.0	10 5	6 7	3 4	0.01	16 40	5.84 1.17	8.16 1.93	0.94 2.29	0.73
1124	Ceiling Fans (CAC early replacement)	Single Family	5%	5%	464.3	2,984.4	2,835.2	1,684.3	15	3	2	0.30	512	0.28	0.34	29.21	0.82
1125	Whole House Fans (CAC early replacement)	Single Family	20%	20%	665.0	2,921.9	2,337.5	1,388.7	15	64	38	0.11	187	0.78	0.94	10.68	0.82
1126	Window Film (CAC early replacement)	Single Family	7%	8%	598.4	2,861.8	2,647.2	1,572.6	10	26	16	0.27	459	0.21	0.29	26.17	0.73
1127	WINDOWS - Default With Sunscreen (CAC early replacement)	Single Family	5%	5%	493.5	2,876.6	2,725.2	1,619.0	10	17	10	0.32	536	0.18	0.25	30.60	0.73
1128	/INDOWS - Double-Glazed Clear to Energy Star (CAC early replaceme		5%	5%	375.7	2,976.2	2,819.5	1,675.0	20	5 0	3	0.23	395 N/A	0.47	0.52	22.51	0.88
1200 1201	Base Heat Pump Cooling (13 SEER) Heat pump upgrade to (14.5-15.9 SEER, 8.2+ HSPF) (HP cooling)	Single Family Single Family	0% 15%	0% 15%	0.0 382.5	2,930.4 3,082.1	2,930.4 2,607.9	1,740.9 1,549.3	15 15	0 198	0 118	N/A 0.08	N/A 133	N/A 1.09	N/A 1.32	N/A 7.57	N/A 0.82
1201	Heat pump upgrade to (14.5-15.9 SEER, 6.2+ HSPF) (HP cooling)	Single Family	23%	23%	504.9	3,164.0	2,433.9	1,349.3	15	305	181	0.08	114	1.09	1.54	6.49	0.82
1203	Ground Source Heat Pump with Desuperheater (HP cooling)	Single Family	21%	21%	4,357.4	2,946.7	2,327.9	1,383.0	15	371	220	0.69	1,158	0.13	0.15	66.10	0.82
1204	Proper Refrigerant Charging and Air Flow (HP cooling)	Single Family	10%	10%	159.0	3,012.2	2,720.0	1,615.9	10	129	77	0.05	90	1.07	1.50	5.11	0.73
1205	Proper Sizing and Quality Install (HP cooling)	Single Family	13%	13%	602.0	3,041.1	2,645.7	1,571.8	18	175	104	0.15	250	0.68	0.78	14.29	0.86

Resid																	
DSM ASS	YST SUMMARY																
DOM AGO	TOT COMMANY		_														
Measure		Building				Base			Service						Participant		Revenue
Number	Measure	Type Single Femily	Fraction	Fraction	Household	UEC	UEC	Household	Life (yrs)	GWH	MW	\$/kWH	\$/kW	(TRC)	Test	(Years)	Test
1206 1207	Heat pump tune up Heat Pump Filter Replacement	Single Family Single Family	1% 1%	1% 1%	191.8 27.4	2,946.8 2,947.4	2,917.3 2,917.9	1,733.1 1,733.5	5 1	8 8	5 5	0.64 0.09	1,071 153	0.04 0.06	0.07 0.11	61.10 8.73	0.63 0.59
1208	Ceiling R-0 to R-38 Insulation (HP cooling)	Single Family	19%	19%	1,013.8	2,930.4	2,384.6	1,416.6	20	51	31	0.18	306 364	0.60	0.67	17.44	0.88
1209 1210	Ceiling R-0 to R-49 Insulation (HP cooling) Ceiling R-11 to R-38 Insulaton (HP cooling)	Single Family Single Family	19% 6%	19% 6%	1,255.1 772.7	2,930.4 2,930.4	2,362.7 2,740.8	1,403.6 1,628.3	20 20	36 39	21 23	0.22 0.40	671	0.51 0.27	0.57 0.31	20.75 38.27	0.88 0.88
1211	Ceiling R-11 to R-49 Insulation (HP cooling)	Single Family	7%	7%	1,013.8	2,930.4	2,715.7	1,613.3	20	29	17	0.46	777	0.24	0.27	44.33	0.88
1212 1213	Ceiling R-19 to R-38 Insulation (HP cooling)	Single Family	3% 4%	3% 4%	597.2 838.5	2,930.4 2,930.4	2,846.8 2,820.6	1,691.2 1,675.7	20 20	10 9	6 5	0.70 0.75	1,175	0.16 0.15	0.18 0.16	67.04 71.71	0.88 0.88
1213	Ceiling R-19 to R-49 Insulation (HP cooling) Crawlspace insulation (HP cooling)	Single Family Single Family	2%	2%	110.6	2,930.4	2,884.7	1,713.7	20	12	7	0.75	1,257 295	0.13	0.70	16.82	0.88
1215	Basement insulation R-13 (HP cooling)	Single Family	18%	18%	1,120.0	3,076.1	2,515.7	1,494.5	20	71	42	0.20	329	0.56	0.63	18.76	0.88
1216	Floor R-0 to R-19 Insulation-Batts (HP cooling)	Single Family	8%	8%	1,283.3	2,989.9	2,760.8	1,640.2	20	2	1	0.55	921	0.20	0.22	52.58	0.88
1217 1218	Wall Blow-in R-0 to R-13 Insulation (HP cooling) Cool Roof (HP cooling)	Single Family Single Family	3% 13%	3% 13%	2,504.3 390.6	3,021.9 3,003.6	2,916.9 2,624.4	1,732.9 1,559.1	20 15	6 188	4 112	2.33 0.10	3,920 169	0.05 0.86	0.05 1.04	223.73 9.67	0.88 0.82
1219	Duct Insulation (HP cooling)	Single Family	14%	14%	58.8	3,384.8	2,906.5	1,726.7	20	15	9	0.01	20	9.11	10.20	1.15	0.88
1220	Duct Testing and Sealing (HP cooling)	Single Family	4%	5%	346.9	3,039.8	2,903.0	1,724.6	18	17	10	0.25	417	0.41	0.47	23.80	0.86
1221 1222	Programmable Thermostat (HP cooling) Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)	Single Family Single Family	5% 6%	5% 6%	64.1 265.6	3,038.3 2,977.2	2,886.4 2,797.0	1,714.7 1,661.7	12 10	27 82	16 49	0.04 0.14	69 242	1.69 0.40	2.20 0.55	3.96 13.84	0.78 0.73
1223	Self Install Weatherization (HP cooling)	Single Family	2%	2%	15.0	2,956.9	2,797.0	1,721.5	10	20	12	0.02	42	2.30	3.21	2.38	0.73
1224	Door Weatherization (HP cooling)	Single Family	3%	3%	23.9	2,969.1	2,882.7	1,712.5	5	29	17	0.03	46	1.03	1.70	2.60	0.63
1225	Ceiling Fans (HP cooling)	Single Family	5%	5%	464.3	3,055.9	2,903.1	1,724.7	15	17	10	0.30	500	0.29	0.35	28.53	0.82
1226 1227	Whole House Fans (HP cooling) WINDOWS - Double-Glazed Clear to Energy Star (HP cooling)	Single Family Single Family	20% 5%	20% 5%	665.0 582.9	2,991.9 3,047.5	2,393.5 2,887.1	1,421.9 1,715.2	15 20	330 27	196 16	0.11 0.36	183 598	0.79 0.31	0.96 0.34	10.43 34.11	0.82 0.88
1300	Base Heat Pump Cooling - Early Replacement (13 SEER)	Single Family	0%	0%	0.0	2,525.3	2,525.3	1,500.2	15	0	0	N/A	N/A	N/A	N/A	N/A	N/A
1301	ump upgrade to (14.5-15.9 SEER, 8.2+ HSPF) (HP cooling Early Repla		15%	15%	382.5	2,656.1	2,247.4	1,335.2	15	30	18	0.09	154	0.94	1.14	8.79	0.82
1302 1303	It pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replace und Source Heat Pump with Desuperheater (HP cooling Early Replace)		23% 21%	23% 21%	504.9 4,357.4	2,726.7 2,539.4	2,097.4 2,006.1	1,246.1 1,191.8	15 15	46 56	28 33	0.08 0.80	132 1,344	1.10 0.11	1.33 0.13	7.53 76.70	0.82 0.82
1303	Proper Refrigerant Charging and Air Flow (HP cooling Early Replaceme		10%	10%	159.0	2,595.8	2,344.0	1,392.5	10	20	12	0.06	104	0.11	1.29	5.93	0.82
1305	Proper Sizing and Quality Install (HP cooling Early Replacement)	Single Family	13%	13%	602.0	2,620.7	2,280.0	1,354.5	18	27	16	0.17	291	0.58	0.67	16.59	0.86
1306	Heat pump tune up	Single Family	1%	1%	191.8	2,539.5	2,514.1	1,493.6	5	1	1	0.74	1,242	0.04	0.06	70.90	0.63
1307 1308	Heat Pump Filter Replacement Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	Single Family Single Family	1% 19%	1% 19%	27.4 1,013.8	2,540.0 2,525.3	2,514.6 2,055.0	1,493.9 1,220.8	1 20	8	1 5	0.11 0.21	177 355	0.06 0.52	0.10 0.58	10.13 20.23	0.59 0.88
1309	Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement)	Single Family	19%	19%	1,255.1	2,525.3	2,036.1	1,209.6	20	5	3	0.25	422	0.44	0.49	24.08	0.88
1310	Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)	Single Family		6%	772.7	2,525.3	2,362.0	1,403.2	20	6	3	0.46	778	0.24	0.26	44.41	0.88
1311 1312	Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)	Single Family Single Family	7% 3%	7% 3%	1,013.8 597.2	2,525.3 2,525.3	2,340.3 2,453.2	1,390.3 1,457.4	20 20	4	3	0.54 0.81	901 1,363	0.20 0.14	0.23 0.15	51.44 77.80	0.88 0.88
1313	Ceiling R-19 to R-39 insulation (HP cooling Early Replacement)	Single Family		4%	838.5	2,525.3	2,433.2	1,444.1	20	1	1	0.87	1,458	0.14	0.13	83.22	0.88
1314	Crawlspace insulation (HP cooling Early Replacement)	Single Family	2%	2%	110.6	2,539.1	2,485.9	1,476.9	20	2	1	0.20	342	0.54	0.60	19.52	0.88
1315	Basement insulation R-13 (HP cooling Early Replacement)	Single Family	18%	18%	1,120.0	2,650.9	2,167.9 2.379.2	1,287.9	20	11 0	6	0.23	381	0.48 0.17	0.54	21.77	0.88 0.88
1316 1317	Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement)	Single Family Single Family	8% 3%	8% 3%	1,283.3 2,504.3	2,576.6 2,604.2	2,513.7	1,413.4 1,493.3	20 20	1	1	0.64 2.70	1,069 4,549	0.17	0.19 0.05	61.02 259.61	0.88
1318	Cool Roof (HP cooling Early Replacement)	Single Family	13%	13%	390.6	2,588.4	2,261.6	1,343.6	15	29	17	0.12	197	0.74	0.89	11.22	0.82
1319	Duct Insulation (HP cooling Early Replacement)	Single Family		14%	58.8	2,916.9	2,504.7	1,488.0	20	2	1	0.01	23	7.85	8.79	1.34	0.88
1320 1321	Duct Testing and Sealing (HP cooling Early Replacement) Programmable Thermostat (HP cooling Early Replacement)	Single Family Single Family	4% 5%	5% 5%	346.9 87.8	2,619.6 2.618.3	2,501.7 2,487.4	1,486.2 1,477.7	18 12	3 4	2	0.29 0.07	484 110	0.35 1.06	0.40 1.38	27.62 6.29	0.86 0.78
1322	prehensive Shell Air Sealing - Inf. Reduction (HP cooling Early Replace		6%	6%	265.6	2,565.7	2,410.4	1,432.0	10	12	7	0.17	281	0.34	0.48	16.06	0.73
1323	Self Install Weatherization (HP cooling Early Replacement)	Single Family	2%	2%	15.0	2,548.1	2,497.2	1,483.5	10	3	2	0.03	48	1.98	2.77	2.76	0.73
1324 1325	Door Weatherization (HP cooling Early Replacement)	Single Family	3%	3%	23.9 464.3	2,564.1	2,477.5 2,501.8	1,471.8 1.486.3	5 15	5 3	3 2	0.03 0.34	45 580	1.03 0.25	1.70 0.30	2.60 33.10	0.63 0.82
1325	Ceiling Fans (HP cooling early replacement) Whole House Fans (HP cooling early replacement)	Single Family Single Family	5% 20%	5% 20%	665.0	2,578.3	2,062.7	1,486.3	15	50	30	0.34	212	0.25	0.83	12.11	0.82
1327	DOWS - Double-Glazed Clear to Energy Star (HP cooling Early Replace		5%	5%	582.9	2,626.2	2,488.0	1,478.1	20	4	2	0.41	694	0.27	0.30	39.59	0.88
1400	Base Room Air Conditioner - EER 10.6	Single Family	0%	0%	0.0	1,435.8	1,435.8	853.0	9	0	0	N/A	N/A	N/A	N/A	N/A	N/A
1401 1402	Energy Star Room Air Conditioner - EER 10.8 HE Room Air Conditioner - CEE Tier 1 EER 11.3	Single Family Single Family	2% 6%	2% 6%	61.7 127.1	1,438.4 1,444.7	1,411.8 1.355.3	838.7 805.2	9	2 6	1	0.23 0.14	381 234	0.22	0.33 0.53	21.77 13.34	0.70 0.70
1403	Room AC Filter Replacement	Single Family	1%	1%	24.7	1,444.1	1,429.7	849.3	1	0	0	0.17	281	0.03	0.06	16.05	0.59
1404	Ceiling R-0 to R-38 Insulation (RAC)	Single Family	17%	17%	1,013.8	1,435.8	1,185.9	704.6	20	3	2	0.40	667	0.28	0.31	38.09	0.88
1405	Ceiling R-0 to R-49 Insulation (RAC)	Single Family	18%	18%	1,255.1	1,435.8	1,177.0 1,353.5	699.3 804.1	20	2	1	0.47	798	0.23	0.26	45.53	0.88
1406 1407	Ceiling R-11 to R-38 Insulaton (RAC) Ceiling R-11 to R-49 Insulation (RAC)	Single Family Single Family	6% 6%	6% 6%	772.7 1,013.8	1,435.8 1,435.8	1,353.5	798.0	20 20	2	1	0.92 1.07	1,544 1,803	0.12	0.13 0.11	88.13 102.89	0.88 0.88
1408	Ceiling R-19 to R-38 Insulation (RAC)	Single Family	3%	3%	597.2	1,435.8	1,397.2	830.1	20	1	0	1.51	2,549	0.07	0.08	145.46	0.88
1409	Ceiling R-19 to R-49 Insulation (RAC)	Single Family	3%	3%	838.5	1,435.8	1,386.7	823.8	20	0	0	1.67	2,811	0.07	0.07	160.45	0.88
1410 1411	Wall Blow-in R-0 to R-13 Insulation (RAC) Cool Roof (RAC)	Single Family Single Family	4% 13%	4% 13%	781.3 390.6	1,491.0 1.471.6	1,427.5 1,285.8	848.1 763.9	20 15	0 12	0 7	1.20 0.21	2,026 346	0.09 0.42	0.10 0.51	115.60 19.74	0.88 0.82
1412	Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	Single Family	7%	7%	265.6	1,463.2	1,357.7	806.6	10	6	4	0.25	414	0.42	0.32	23.63	0.73
1413	Self Install Weatherization (RAC)	Single Family	2%	2%	5.7	1,448.8	1,419.8	843.5	10	1	1	0.02	33	2.95	4.12	1.86	0.73
1414	Door Weatherization (RAC)	Single Family		3%	23.9	1,454.7	1,412.4	839.1	5	2	1	0.06	93	0.50	0.83	5.31	0.63
1415	Ceiling Fans (RAC)	Single Family	5%	5%	464.3	1,497.3	1,422.4	845.0	15	1	1	0.61	1,020	0.14	0.17	58.22	0.82

Resid	lential Electric Existing Construction																
DSM ASS	YST SUMMARY										System	Levelized Cost	Levelized Cost	Total			
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Household	Base UEC	UEC	Peak Watts/ Household	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)	Revenue Test
1416	Whole House Fans (RAC)	Single Family	20%	20%	665.0	1,465.9	1,172.7	696.7	15	21	12	0.22	373	0.39	0.47	21.29	0.82
1417	Window Film (RAC)	Single Family	21%	21%	598.4	1,435.8	1,134.3	673.8	10	24	14	0.19	326	0.29	0.41	18.63	0.73
1418	WINDOWS - Default With Sunscreen (RAC)	Single Family	5%	5%	493.5	1,443.2	1,367.3	812.3	10	5	3	0.63	1,069	0.09	0.13	60.99	0.73
1419 1500	WINDOWS - Double-Glazed Clear to Energy Star (RAC) Base Room Air Conditioner, Early Replacement - EER 9.7	Single Family Single Family	5% 0%	5% 0%	375.7 334.5	1,493.1 1,707.8	1,414.6 1,707.8	840.4 1,014.6	20 15	2	1 0	0.47 N/A	786 N/A	0.23 N/A	0.26 N/A	44.88 N/A	0.88 N/A
1501	ER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early replacement		13%	13%	908.7	1,707.8	1,480.7	879.6	9	3	2	0.39	658	0.13	0.19	37.55	0.70
1600	Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	Single Family	0%	0%	114.2	51.7	51.7	30.7	12	0	0	N/A	N/A	N/A	N/A	N/A	N/A
1601	10% better than Energy Star Dehumidifier ROB (35-45 pints/day)	Single Family	15%	15%	11.4	51.9	43.9	26.1	12	4	2	0.14	235	0.50	0.65	13.42	0.78
1700	Base Furnace Fan - Furnace & CAC	Single Family	0%	0%	0.0	1,169.8	1,169.8	600.1	18	0	0	N/A	N/A	N/A	N/A	N/A	N/A
1701	ECM Furnace Fan (variable speed motor) - Cooling	Single Family	50%	50%	175.0	1,299.8	649.9	333.4 569.0	18	780 0	400 0	0.03	51 N/A	3.60 N/A	4.40	2.53	0.81 N/A
2000 2001	Base Heat Pump Space Heating (7.7 HSPF) Heat pump upgrade to 14.5-15.9 SEER/8.2+ HSPF (HP heating)	Single Family Single Family	0% 6%	0% 6%	0.0 264.2	4,795.4 4,897.1	4,795.4 4,579.1	543.3	18 15	113	13	N/A 0.08	N/A 684	0.71	N/A 1.29	N/A 7.80	0.55
2001	Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	Single Family	13%	13%	465.0	5.003.3	4.353.5	516.5	15	230	27	0.07	589	0.83	1.49	6.72	0.55
2003	Ground Source Heat Pump with Desuperheater (HP heating)	Single Family		21%	4,357.4	4,822.1	3,809.5	452.0	15	514	61	0.42	3,544	0.14	0.25	40.39	0.55
2004	Heat pump tune up	Single Family	1%	1%	191.8	4,822.2	4,774.0	566.4	5	11	1	0.39	3,276	0.05	0.12	37.34	0.47
2005	Heat Pump Filter Replacement	Single Family	1%	1%	27.4	4,823.2	4,774.9	566.5	1	11	1	0.06	468	0.08	0.19	5.33	0.44
2006	Ceiling R-0 to R-38 Insulation (HP heating)	Single Family		19%	1,013.8	4,795.4	3,902.2	463.0	20	71	8	0.11	935	0.65	1.10	10.66	0.58
2007 2008	Ceiling R-0 to R-49 Insulation (HP heating) Ceiling R-11 to R-38 Insulaton (HP heating)	Single Family Single Family	19% 6%	19% 6%	1,255.1 772.7	4,795.4 4,795.4	3,866.4 4.485.2	458.7 532.2	20 20	49 54	6 6	0.13 0.24	1,113 2,052	0.55	0.93 0.50	12.68 23.39	0.58 0.58
2009	Ceiling R-11 to R-49 Insulation (HP heating)	Single Family	7%	7%	1,013.8	4,795.4	4,444.0	527.3	20	40	5	0.28	2,377	0.36	0.43	27.09	0.58
2010	Ceiling R-19 to R-38 Insulation (HP heating)	Single Family	3%	3%	597.2	4,795.4	4,658.5	552.7	20	14	2	0.43	3,595	0.17	0.29	40.97	0.58
2011	Ceiling R-19 to R-49 Insulation (HP heating)	Single Family	4%	4%	838.5	4,795.4	4,615.7	547.6	20	12	1	0.46	3,845	0.16	0.27	43.82	0.58
2012	Crawlspace insulation (HP heating)	Single Family	2%	2%	110.6	4,821.6	4,720.6	560.1	20	16	2	0.11	902	0.67	1.14	10.28	0.58
2013	Basement insulation R-13 (HP heating)	Single Family		18%	1,120.0	5,033.8	4,116.7	488.4	20	99	12	0.12	1,006	0.60	1.03	11.46	0.58
2014 2015	Floor R-0 to R-19 Insulation-Batts (HP heating) Wall Blow-in R-0 to R-13 Insulation (HP heating)	Single Family Single Family	8% 3%	8% 3%	1,283.3 2,504.3	4,892.8 4,945.2	4,517.9 4,773.2	536.0 566.3	20 20	2 9	0 1	0.33 1.42	2,819 11,995	0.22 0.05	0.37 0.09	32.13 136.72	0.58 0.58
2015	Duct Insulation (HP heating)	Single Family	3% 14%	3% 14%	2,504.3 58.8	5.539.0	4,773.2	564.3	20	20	2	0.01	62	9.83	16.69	0.70	0.58
2017	Duct Testing and Sealing (HP heating)	Single Family	4%	5%	346.9	4,974.4	4,750.2	563.6	18	23	3	0.15	1,276	0.44	0.77	14.55	0.57
2018	Heat Recovery Ventilators (HP heating)	Single Family		30%	1,700.0	4,868.4	3,407.9	404.3	20	542	64	0.11	959	0.63	1.08	10.93	0.58
2019	Programmable Thermostat (HP heating)	Single Family	5%	5%	87.8	4,971.9	4,723.3	560.4	12	38	4	0.03	291	1.38	2.62	3.31	0.53
2020	Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Single Family		6%	265.6	4,872.0	4,577.1	543.1	10	114	13	0.09	742	0.46	0.91	8.46	0.51
2021 2022	Self Install Weatherization (HP heating) Door Weatherization (HP heating)	Single Family Single Family	2% 2%	2% 2%	15.0 23.9	4,838.7 4,833.8	4,741.9 4.747.9	562.6 563.3	10 5	28 25	3	0.02 0.03	128 229	2.66 0.77	5.26 1.69	1.46 2.61	0.51 0.47
2022	WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Single Family	5%	5%	582.9	4,981.0	4,747.9	560.8	20	36	4	0.03	1,888	0.77	0.55	21.51	0.58
2100	Base Heat Pump Space Heating - Early Replacement (7.7 HSPF)	Single Family	0%	0%	0.0	4.575.9	4,575.9	542.9	18	0	0	N/A	N/A	N/A	N/A	N/A	N/A
2101	pump upgrade to 14.5-15.9 SEER/8.2+ HSPF (HP heating early replace	er Single Family	6%	6%	264.2	4,673.0	4,369.6	518.4	15	19	2	0.09	717	0.68	1.23	8.17	0.55
2102	eat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early replacem		13%	13%	465.0	4,774.4	4,154.3	492.9	15	39	5	0.07	618	0.79	1.42	7.04	0.55
2103	ound Source Heat Pump with Desuperheater (HP heating early replacen		21%	21%	4,357.4	4,601.5	3,635.2	431.3	15	87	10	0.44	3,714	0.13	0.24	42.33	0.55
2104 2105	Heat pump tune up (heating) Heat Pump Filter Replacement (heating)	Single Family Single Family	1% 1%	1% 1%	191.8 27.4	4,601.6 4,602.5	4,555.6 4,556.5	540.5 540.6	5 1	2	0	0.41 0.06	3,433 490	0.05 0.07	0.11 0.18	39.13 5.59	0.47 0.44
2105	Ceiling R-0 to R-38 Insulation (HP heating early replacement)	Single Family	19%	19%	1.013.8	4,575.9	3.723.7	441.8	20	12	1	0.06	980	0.62	1.05	11.17	0.58
2107	Ceiling R-0 to R-49 Insulation (HP heating early replacement)	Single Family		19%	1,255.1	4,575.9	3,689.5	437.7	20	8	1	0.14	1,166	0.52	0.89	13.29	0.58
2108	Ceiling R-11 to R-38 Insulaton (HP heating early replacement)	Single Family	6%	6%	772.7	4,575.9	4,280.0	507.8	20	9	1	0.26	2,150	0.28	0.48	24.51	0.58
2109	Ceiling R-11 to R-49 Insulation (HP heating early replacement)	Single Family		7%	1,013.8	4,575.9	4,240.7	503.1	20	7	1	0.30	2,490	0.24	0.41	28.39	0.58
2110	Ceiling R-19 to R-38 Insulation (HP heating early replacement)	Single Family		3%	597.2	4,575.9	4,445.4	527.4	20	2	0	0.45	3,767	0.16	0.27	42.93	0.58
2111 2112	Ceiling R-19 to R-49 Insulation (HP heating early replacement) Crawlspace insulation (HP heating early replacement)	Single Family Single Family	4% 2%	4% 2%	838.5 110.6	4,575.9 4,601.0	4,404.6 4,504.6	522.6 534.5	20 20	2	0	0.48 0.11	4,029 945	0.15 0.64	0.26 1.09	45.92 10.77	0.58 0.58
2112	Basement insulation R-13 (HP heating early replacement)	Single Family		18%	1,120.0	4,803.5	3,928.3	466.1	20	17	2	0.13	1,054	0.58	0.98	12.01	0.58
2114	Floor R-0 to R-19 Insulation-Batts (HP heating early replacement)	Single Family		8%	1,283.3	4,669.0	4,311.2	511.5	20	0	0	0.35	2,954	0.21	0.35	33.67	0.58
2115	Wall Blow-in R-0 to R-13 Insulation (HP heating early replacement)	Single Family		3%	2,504.3	4,718.9	4,554.9	540.4	20	1	0	1.49	12,570	0.05	0.08	143.27	0.58
2116	Duct Insulation (HP heating early replacement)	Single Family		14%	58.8	5,285.6	4,538.6	538.5	20	3	0	0.01	65	9.38	15.93	0.74	0.58
2117	Duct Testing and Sealing (HP heating early replacement)	Single Family	4%	5%	346.9	4,746.8	4,533.2	537.9	18	4	0	0.16	1,337	0.42	0.73	15.24	0.57
2118 2119	Heat Recovery Ventilators (HP heating early replacement) Programmable Thermostat (HP heating early replacement)	Single Family Single Family	30% 5%	30% 5%	1,700.0 87.8	4,645.6 4,744.4	3,251.9 4,507.2	385.8 534.8	20 12	91 6	11 1	0.12 0.04	1,005 305	0.61 1.32	1.03 2.50	11.45 3.47	0.58 0.53
2119	prehensive Shell Air Sealing - Inf. Reduction (HP heating early replace		6%	6%	265.6	4,649.1	4,367.7	518.2	10	19	2	0.09	777	0.44	0.86	8.86	0.55
2121	Self Install Weatherization (HP heating early replacement)	Single Family	2%	2%	15.0	4,617.3	4,525.0	536.9	10	5	1	0.02	134	2.54	5.02	1.52	0.51
2122	Door Weatherization (HP heating early replacement)	Single Family	2%	2%	23.9	4,614.4	4,528.5	537.3	5	4	1	0.03	229	0.77	1.69	2.61	0.47
2123	DOWS - Double-Glazed Clear to Energy Star (HP heating early replace			5%	582.9	4,753.1	4,510.4	535.2	20	6	1	0.23	1,978	0.31	0.52	22.55	0.58
2200	Base Resistance Space Heating (Primary)	Single Family	0%	0%	0.0	5,615.0	5,615.0	666.2	15	0	0	N/A	N/A	N/A	N/A	N/A	N/A
2201	Air Source Heat Pump (resistance heating)	Single Family		20%	141.6	5,615.0	4,472.6	530.7	15 15	248 256	29	0.01	102	4.77	8.62	1.16	0.55
2202 2203	Ground Source Heat Pump with Desuperheater (resistance heating) Ceiling R-0 to R-38 Insulation (resistance heating)	Single Family Single Family		21% 20%	4,357.4 1,013.8	5,615.0 5,615.0	4,435.8 4,484.1	526.3 532.0	20	256 38	30 4	0.36 0.09	3,044 738	0.16 0.82	0.29 1.40	34.69 8.42	0.55 0.58
2203	Ceiling R-0 to R-49 Insulation (resistance heating)	Single Family		21%	1,255.1	5.615.0	4,448.9	527.9	20	26	3	0.03	886	0.69	1.16	10.10	0.58
2205	Ceiling R-11 to R-38 Insulation (resistance heating)	Single Family		7%	772.7	5,615.0	5,221.2	619.5	20	28	3	0.19	1,616	0.38	0.64	18.42	0.58
2206	Ceiling R-11 to R-49 Insulation (resistance heating)	Single Family		8%	1,013.8	5,615.0	5,180.3	614.6	20	21	2	0.23	1,921	0.32	0.54	21.89	0.58
2207	Ceiling R-19 to R-38 Insulation (resistance heating)	Single Family	3%	3%	597.2	5,615.0	5,431.4	644.4	20	8	1	0.32	2,680	0.23	0.39	30.55	0.58

Resid	ential Electric Existing Construction																
DSM ASSY	mber Measure Type Fraction Fraction Household UEC UEC Household Life (yrs) GWH MW \$/kWH \$/kW (TRC) Test (Years) Test 208 Ceiling R-19 to R-49 Insulation (resistance heating) Single Family 4% 4% 838.5 5,615.0 5,884.2 20 6 1 0.36 3,054 0.20 0.34 34.81 0.58 209 Crawlspace insulation (resistance heating) Single Family 2% 110.6 5,643.2 5,534.7 656.7 20 7 1 0.10 839 0.72 1.23 9.57 0.58 210 Basement insulation R-13 (resistance heating) Single Family 18% 1,120.0 5,894.2 4,820.3 571.9 20 74 9 0.10 859 0.71 1.20 9.79 0.58 211 Floor R-0 to R-19 Insulation-Batts (resistance heating) Single Family 11% 1,283.3 5,775.7 5,157.6 611.9 20																
Measure Number	Measure		Savings	Reduction	Costs/		UEC	Watts/		Potential	Potential	Energy	Peak Capacity	Cost Test		Payback	Revenue Test
2208	Ceiling R-19 to R-49 Insulation (resistance heating)	Single Family	4%	4%	838.5	5,615.0	5,388.9	639.4	20		1	0.36	3,054	0.20	0.34	34.81	0.58
2209										,	1						
2210																	
2211	Wall Blow-in R-0 to R-13 Insulation (resistance heating)	Single Family	5%	5%	2.504.3	5,858.9	5,157.6	661.9	20	6	1	0.20	7,369	0.36	0.60	83.99	0.58
2213	Heat Recovery Ventilators (resistance heating)	Single Family	30%	30%	1,700.0	5,700.5	3,990.3	473.4	20	265	31	0.10	819	0.74	1.26	9.33	0.58
2214	Programmable Thermostat (resistance heating)	Single Family	5%	5%	64.1	5,821.7	5,530.6	656.2	12	18	2	0.02	181	2.22	4.21	2.07	0.53
2215	Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating)		6%	6%	265.6	5,704.8	5,359.5	635.9	10	56	7	0.08	634	0.54	1.06	7.22	0.51
2216	Self Install Weatherization	Single Family	2%	2%	15.0	5,665.7	5,552.4	658.8	10	14	2	0.01	109	3.12	6.16	1.24	0.51
2217 2218	Door Weatherization (resistance heating) WINDOWS - Double-Glazed Clear to Energy Star (resistance heating)	Single Family Single Family	3% 6%	3% 6%	23.9 582.9	5,692.4 5,863.1	5,519.5 5,523.2	654.9 655.3	5 20	21 20	2	0.01 0.17	114 1,412	1.55 0.43	3.40 0.73	1.30 16.09	0.47 0.58
3000	Base Halogen Lighting - 0.5 hrs/day 2014-2015	Single Family	0%	0%	23.3	109.7	109.7	12.3	5	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3001	CFL (base Halogen 0.5 hrs/day) 2014-2015	Single Family	65%	65%	27.0	156.7	54.7	6.1	32	153	17	0.02	196	3.75	5.74	2.48	0.62
3002	LEDs (base Halogen 0.5 hrs/day) 2014-2015	Single Family	76%	76%	139.8	109.7	26.8	3.0	32	111	12	0.14	1,247	0.59	0.90	15.82	0.62
3010	Base Halogen Lighting - 0.5 hrs/day 2016-2017	Single Family	0%	0%	23.3	109.7	109.7	12.3	5	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3011	CFL (base Halogen 0.5 hrs/day) 2016-2017	Single Family	65%	65%	27.0	109.7	38.3	4.3	32	107	12	0.03	279	2.63	4.02	3.55	0.62
3012 3020	LEDs (base Halogen 0.5 hrs/day) 2016-2017 Base Halogen Lighting - 0.5 hrs/day 2018-2019	Single Family Single Family	76% 0%	76% 0%	95.3 23.3	109.7 109.7	26.8 109.7	3.0 12.3	32 5	118 0	13 0	0.10 N/A	850 N/A	0.86 N/A	1.32 N/A	10.79 N/A	0.62 N/A
3020	CFL (base Halogen 0.5 hrs/day) 2018-2019	Single Family	65%	65%	27.0	109.7	38.3	4.3	32	107	12	0.03	279	2.63	4.02	3.55	0.62
3022	LEDs (base Halogen 0.5 hrs/day) 2018-2019	Single Family	76%	76%	50.8	109.7	26.8	3.0	32	125	14	0.05	453	1.62	2.48	5.75	0.62
3030	Base Halogen Lighting - 0.5 hrs/day 2020	Single Family	0%	0%	23.3	109.7	109.7	12.3	5	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3032	LEDs (base Halogen 0.5 hrs/day) 2020	Single Family	76%	76%	36.0	109.7	26.8	3.0	32	125	14	0.04	321	2.29	3.50	4.07	0.62
3100	Base Halogen Lighting - 2.5 hrs/day 2014-2015	Single Family	0%	0%	19.2	450.6	450.6	50.5	1 9	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3101 3102	CFL (base Halogen 2.5 hrs/day) 2014-2015 LEDs (base Halogen 2.5 hrs/day) 2014-2015	Single Family Single Family	65% 76%	65% 76%	22.2 114.8	450.6 450.6	157.3 110.0	17.6 12.3	32	440 455	49 51	0.01 0.03	66 249	4.87 2.94	9.99 4.50	0.71 3.16	0.50 0.62
3110	Base Halogen Lighting - 2.5 hrs/day 2016-2017	Single Family	0%	0%	19.2	450.6	450.6	50.5	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3111	CFL (base Halogen 2.5 hrs/day) 2016-2017	Single Family	65%	65%	22.2	450.6	157.3	17.6	9	440	49	0.01	66	4.87	9.99	0.71	0.50
3112	LEDs (base Halogen 2.5 hrs/day) 2016-2017	Single Family	76%	76%	78.3	450.6	110.0	12.3	32	483	54	0.02	170	4.32	6.61	2.16	0.62
3120	Base Halogen Lighting - 2.5 hrs/day 2018-2019	Single Family	0%	0%	19.2	450.6	450.6	50.5	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3121	CFL (base Halogen 2.5 hrs/day) 2018-2019	Single Family	65%	65%	22.2	450.6 450.6	157.3 110.0	17.6 12.3	9 32	440 512	49 57	0.01	66 91	4.87 8.10	9.99 12.39	0.71	0.50
3122 3130	LEDs (base Halogen 2.5 hrs/day) 2018-2019 Base Halogen Lighting - 2.5 hrs/day 2020	Single Family Single Family	76% 0%	76% 0%	41.8 19.2	450.6	450.6	50.5	1	0	0	0.01 N/A	N/A	8.10 N/A	N/A	1.15 N/A	0.62 N/A
3132	LEDs (base Halogen 2.5 hrs/day) 2020	Single Family	82%	82%	29.6	450.6	81.1	9.1	32	555	62	0.01	59	12.40	18.97	0.75	0.62
3200	Base Halogen Lighting - 6 hrs/day 2014-2015	Single Family	0%	0%	5.3	297.8	297.8	33.3	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3201	CFL (base Halogen 6 hrs/day) 2014-2015	Single Family	65%	65%	6.1	297.8	103.9	11.6	4	291	33	0.00	27	5.44	12.33	0.30	0.46
3202	LEDs (base Halogen 6 hrs/day) 2014-2015	Single Family	76%	76%	31.6	297.8	72.7	8.1	16	300	34	0.01	123	4.38	7.90	1.32	0.55
3210 3211	Base Halogen Lighting - 6 hrs/day 2016-2017 CFL (base Halogen 6 hrs/day) 2016-2017	Single Family Single Family	0% 65%	0% 65%	5.3 6.1	297.8 297.8	297.8 103.9	33.3 11.6	1 4	0 291	0 33	N/A 0.00	N/A 27	N/A 5.44	N/A 12.33	N/A 0.30	N/A 0.46
3211	LEDs (base Halogen 6 hrs/day) 2016-2017	Single Family	76%	76%	21.6	297.8	72.7	8.1	16	319	36	0.01	84	6.42	11.59	0.90	0.46
3220	Base Halogen Lighting - 6 hrs/day 2018-2019	Single Family	0%	0%	5.3	297.8	297.8	33.3	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3221	CFL (base Halogen 6 hrs/day) 2018-2019	Single Family	65%	65%	6.1	297.8	103.9	11.6	4	291	33	0.00	27	5.44	12.33	0.30	0.46
3222	LEDs (base Halogen 6 hrs/day) 2018-2019	Single Family	76%	76%	11.5	297.8	72.7	8.1	16	338	38	0.00	45	12.05	21.74	0.48	0.55
3230	Base Halogen Lighting - 6 hrs/day 2020	Single Family	0%	0%	5.3	297.8	297.8	33.3	1	0	0	N/A	N/A 32	N/A	N/A	N/A	N/A
3232 3300	LEDs (base Halogen 6 hrs/day) 2020 Base CFL Lighting - 0.5 hrs/day 2014-2015	Single Family Single Family	76% 0%	76% 0%	8.1 13.3	297.8 21.1	72.7 21.1	8.1 2.4	16 32	338 0	38 0	0.00 N/A	N/A	17.01 N/A	30.69 N/A	0.34 N/A	0.55 N/A
3301	LEDs (base CFL 0.5 hrs/day) 2014-2015	Single Family	30%	30%	66.8	21.1	14.8	1.7	32	8	1	0.87	7,811	0.09	0.14	99.14	0.62
3310	Base CFL Lighting - 0.5 hrs/day 2016-2017	Single Family	0%	0%	13.3	21.1	21.1	2.4	32	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3311	LEDs (base CFL 0.5 hrs/day) 2016-2017	Single Family	30%	30%	45.0	21.1	14.8	1.7	32	9	1	0.59	5,259	0.14	0.21	66.74	0.62
3320	Base CFL Lighting - 0.5 hrs/day 2018-2019	Single Family	0%	0%	13.3	21.1	21.1	2.4	32	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3321 3330	LEDs (base CFL 0.5 hrs/day) 2018-2019	Single Family	30%	30%	23.2	21.1	14.8	1.7	32 32	10 0	1 0	0.30	2,706 N/A	0.27 N/A	0.41 N/A	34.34	0.62
3330	Base CFL Lighting - 0.5 hrs/day 2020 LEDs (base CFL 0.5 hrs/day) 2020	Single Family Single Family	0% 30%	0% 30%	13.3 15.9	21.1 21.1	21.1 14.8	2.4 1.7	32	10	1	N/A 0.21	1,855	0.40	0.61	N/A 23.54	N/A 0.62
3400	Base CFL Lighting - 2.5 hrs/day 2014-2015	Single Family	0%	0%	10.9	86.5	86.5	9.7	9	0	Ö	N/A	N/A	N/A	N/A	N/A	N/A
3401	LEDs (base CFL 2.5 hrs/day) 2014-2015	Single Family	30%	30%	54.9	86.5	60.5	6.8	32	35	4	0.18	1,564	0.47	0.72	19.85	0.62
3410	Base CFL Lighting - 2.5 hrs/day 2016-2017	Single Family	0%	0%	10.9	86.5	86.5	9.7	9	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3411	LEDs (base CFL 2.5 hrs/day) 2016-2017	Single Family	30%	30%	36.9	86.5	60.5	6.8	32	37	4	0.12	1,053	0.70	1.07	13.36	0.62
3420	Base CFL Lighting - 2.5 hrs/day 2018-2019	Single Family	0%	0%	10.9	86.5	86.5	9.7	9	0 39	0	N/A	N/A 542	N/A	N/A	N/A	N/A
3421 3430	LEDs (base CFL 2.5 hrs/day) 2018-2019 Base CFL Lighting - 2.5 hrs/day 2020	Single Family Single Family	30% 0%	30% 0%	19.0 10.9	86.5 86.5	60.5 86.5	6.8 9.7	32 9	39	0	0.06 N/A	542 N/A	1.36 N/A	2.07 N/A	6.88 N/A	0.62 N/A
3430	LEDs (base CFL 2.5 hrs/day) 2020	Single Family	30%	30%	13.0	86.5	60.5	6.8	32	39	4	0.04	371	1.98	3.02	4.71	0.62
3500	Base CFL Lighting - 6 hrs/day 2014-2015	Single Family	0%	0%	3.0	57.0	57.0	6.4	4	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3501	LEDs (base CFL 6 hrs/day) 2014-2015	Single Family	30%	30%	15.0	57.0	39.9	4.5	16	23	3	0.09	764	0.70	1.27	8.22	0.55
3510	Base CFL Lighting - 6 hrs/day 2016-2017	Single Family	0%	0%	3.0	57.0	57.0	6.4	4	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3511 3520	LEDs (base CFL 6 hrs/day) 2016-2017	Single Family	30%	30%	10.1	57.0	39.9 57.0	4.5	16 4	24	3	0.06 N/A	515 N/A	1.04 N/A	1.88 N/A	5.53 N/A	0.55 N/A
3520 3521	Base CFL Lighting - 6 hrs/day 2018-2019 LEDs (base CFL 6 hrs/day) 2018-2019	Single Family	0% 30%	0% 30%	3.0 5.2	57.0 57.0	57.0 39.9	6.4 4.5	4 16	0 26	3	N/A 0.03	N/A 265	N/A 2.03	N/A 3.66	N/A 2.85	N/A 0.55
3321	LEDS (Dase OFL 0 1115/0dy) 2010-2019	Single Family	3070	3076	5.2	01.0	39.9	4.0	10	20	3	0.03	200	2.03	3.00	2.00	0.00

Residen	tial Electric Existing Construction																
DSM ASSYST	SUMMARY										System	Levelized Cost	Levelized Cost	Total			
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Household	Base UEC	UEC	Peak Watts/ Household	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)	Revenue Test
3530	Base CFL Lighting - 6 hrs/day 2020	Single Family	0%	0%	3.0	57.0	57.0	6.4	4	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3531	LEDs (base CFL 6 hrs/day) 2020	Single Family		30%	3.6	57.0	39.9	4.5	16	26	3	0.02	182	2.96	5.34	1.95	0.55
3600	Base Halogen (Specialty) Lighting - 0.5 hrs/day 2014-2015	Single Family	0%	0%	16.1	67.7	67.7	7.6	5	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3601 3602	CFL (base Halogen (Specialty) 0.5 hrs/day 2014-2015 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2014-2015	Single Family Single Family		65% 76%	29.3 48.4	80.8 67.7	28.2 16.5	3.2 1.8	32 32	59 43	7 5	0.05 0.08	412 699	1.78 1.05	2.73 1.61	5.23 8.88	0.62 0.62
3610	Base Halogen (Specialty) Lighting - 0.5 hrs/day 2014-2017	Single Family		0%	16.1	67.7	67.7	7.6	5	0	0	N/A	N/A	N/A	N/A	0.00 N/A	0.62 N/A
3611	CFL (base Halogen (Specialty) 0.5 hrs/day) 2016-2017	Single Family		65%	29.3	80.8	28.2	3.2	32	59	7	0.05	412	1.78	2.73	5.23	0.62
3612	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2016-2017	Single Family		76%	30.8	67.7	16.5	1.8	32	51	6	0.05	445	1.65	2.52	5.65	0.62
3620	Base Halogen (Specialty) Lighting - 0.5 hrs/day 2018-2019	Single Family		0%	16.1	67.7	67.7	7.6	5	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3621	CFL (base Halogen (Specialty) 0.5 hrs/day) 2018-2019	Single Family		65%	29.3	8.08	28.2	3.2	32	59	7	0.05	412	1.78	2.73	5.23	0.62
3622 3630	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2018-2019 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	Single Family Single Family		76% 0%	13.2 16.1	67.7 67.7	16.5 67.7	1.8 7.6	32 5	60 0	7 0	0.02 N/A	191 N/A	3.84 N/A	5.87 N/A	2.43 N/A	0.62 N/A
3631	CFL (base Halogen (Specialty) 0.5 hrs/day) 2020	Single Family		65%	29.3	80.8	28.2	3.2	32	59	7	0.05	412	1.78	2.73	5.23	0.62
3632	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Single Family		76%	7.4	67.7	16.5	1.8	32	68	8	0.01	107	6.89	10.54	1.35	0.62
3700	Base Halogen (Specialty) Lighting - 2.5 hrs/day 2014-2015	Single Family	0%	0%	13.3	280.3	280.3	31.4	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3701	CFL (base Halogen (Specialty) 2.5 hrs/day) 2014-2015	Single Family		65%	24.3	334.8	116.9	13.1	9	245	27	0.01	97	3.31	6.78	1.05	0.50
3702	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2014-2015	Single Family		76%	40.1	280.3	68.4	7.7	32	177	20	0.02	140	5.25	8.03	1.78	0.62
3710 3711	Base Halogen (Specialty) Lighting - 2.5 hrs/day 2016-2017 CFL (base Halogen (Specialty) 2.5 hrs/day) 2016-2017	Single Family Single Family		0% 65%	13.3 24.3	280.3 334.8	280.3 116.9	31.4 13.1	1 9	0 245	0 27	N/A 0.01	N/A 97	N/A 3.31	N/A 6.78	N/A 1.05	N/A 0.50
3712	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2016-2017	Single Family		76%	25.5	280.3	68.4	7.7	32	212	24	0.01	89	8.24	12.61	1.13	0.62
3720	Base Halogen (Specialty) Lighting - 2.5 hrs/day 2018-2019	Single Family	0%	0%	13.3	280.3	280.3	31.4	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3721	CFL (base Halogen (Specialty) 2.5 hrs/day) 2018-2019	Single Family		65%	24.3	334.8	116.9	13.1	9	245	27	0.01	97	3.31	6.78	1.05	0.50
3722	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2018-2019	Single Family		76%	11.0	280.3	68.4	7.7	32	247	28	0.00	38	19.20	29.36	0.49	0.62
3730	Base Halogen (Specialty) Lighting - 2.5 hrs/day 2020	Single Family		0%	13.3	280.3	280.3	31.4	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3731 3732	CFL (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family		65%	24.3	334.8	116.9	13.1	9 32	245 283	27 32	0.01	97	3.31	6.78	1.05	0.50
3732	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020 Base Halogen (Specialty) Lighting - 6 hrs/day 2014-2015	Single Family Single Family		76% 0%	6.1 3.7	280.3 185.6	68.4 185.6	7.7 20.8	32 1	283	0	0.00 N/A	21 N/A	34.46 N/A	52.71 N/A	0.27 N/A	0.62 N/A
3801	CFL (base Halogen (Specialty) 6 hrs/day) 2014-2015	Single Family		65%	6.7	221.7	77.4	8.7	4	163	18	0.00	40	3.69	8.37	0.44	0.46
3802	LEDs (base Halogen (Specialty) 6 hrs/day) 2014-2015	Single Family		76%	11.1	185.6	45.3	5.1	16	117	13	0.01	69	7.81	14.09	0.74	0.55
3810	Base Halogen (Specialty) Lighting - 6 hrs/day 2016-2017	Single Family		0%	3.7	185.6	185.6	20.8	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3811	CFL (base Halogen (Specialty) 6 hrs/day) 2016-2017	Single Family		65%	6.7	221.7	77.4	8.7	4	163	18	0.00	40	3.69	8.37	0.44	0.46
3812	LEDs (base Halogen (Specialty) 6 hrs/day) 2016-2017	Single Family		76%	7.0	185.6	45.3	5.1	16	140	16	0.00	44	12.26	22.12	0.47	0.55
3820 3821	Base Halogen (Specialty) Lighting - 6 hrs/day 2018-2019 CFL (base Halogen (Specialty) 6 hrs/day) 2018-2019	Single Family Single Family		0% 65%	3.7 6.7	185.6 221.7	185.6 77.4	20.8 8.7	1 4	0 163	0 18	N/A 0.00	N/A 40	N/A 3.69	N/A 8.37	N/A 0.44	N/A 0.46
3822	LEDs (base Halogen (Specialty) 6 hrs/day) 2016-2019	Single Family		76%	3.0	185.6	45.3	5.1	16	164	18	0.00	19	28.55	51.52	0.44	0.46
3830	Base Halogen (Specialty) Lighting - 6 hrs/day 2020	Single Family		0%	3.7	185.6	185.6	20.8	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3831	CFL (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	65%	65%	6.7	221.7	77.4	8.7	4	163	18	0.00	40	3.69	8.37	0.44	0.46
3832	LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family		76%	1.7	185.6	45.3	5.1	16	187	21	0.00	10	51.26	92.50	0.11	0.55
3900	Base Fluorescent Fixture 1.8 hrs/day	Single Family	0%	0%	372.5	466.2	466.2	52.2	32	0	0	N/A	N/A	N/A	N/A	N/A	N/A
3901 3902	RET 2L4'T8, 1EB ROB 2L4'T8, 1EB	Single Family Single Family	28% 28%	28% 28%	429.8 57.3	472.9 472.9	340.5 340.5	38.1 38.1	32 32	210 210	23 23	0.27 0.04	2,401 320	0.31 2.29	0.47 3.51	30.48 4.06	0.62 0.62
4000	Base Refrigerator	Single Family	0%	0%	537.8	699.4	699.4	113.4	18	0	0	N/A	N/A	N/A	N/A	4.06 N/A	0.62 N/A
4001	Refrigerator (Energy Star)	Single Family	26%	26%	616.8	793.1	589.3	95.5	18	156	25	0.30	1,824	0.23	0.39	28.40	0.59
4002	Refrigerator (CEE Tier 2)	Single Family	25%	25%	716.8	790.2	592.7	96.1	18	151	25	0.35	2,187	0.19	0.33	34.06	0.59
4100	Base RefrigeratorEarly Replacement	Single Family	0%	0%	0.0	562.2	562.2	91.1	18	0	0	N/A	N/A	N/A	N/A	N/A	N/A
4101	Refrigerator - Early Replacement (Energy Star)	Single Family	60%	60%	204.2	776.6	310.6	50.3	6	63 0	10 0	0.04	264 N/A	0.59 N/A	1.25	4.11	0.48 N/A
4200 4201	Base 2nd Refrigerator - Recycling 2nd Refrigerator Recycling	Single Family Single Family	0% 99%	0% 99%	1.2 153.5	977.8 977.8	977.8 9.8	158.5 1.6	18 8	460	74	N/A 0.02	96	2.13	N/A 4.35	N/A 1.49	0.50
4500	Base Freezer	Single Family	0%	0%	329.0	824.6	824.6	133.6	11	0	0	N/A	N/A	N/A	N/A	N/A	N/A
4501	Freezer (Energy Star)	Single Family		10%	33.0	835.4	751.9	121.9	11	37	6	0.04	238	1.17	2.21	3.71	0.53
4600	Base Early Replacement Freezer	Single Family	0%	0%	0.0	1,165.6	1,165.6	184.5	11	0	0	N/A	N/A	N/A	N/A	N/A	N/A
4601	Freezer - Early Replacement (Energy Star)	Single Family	58%	58%	110.7	1,259.8	535.4	84.8	5	56	9	0.01	94	1.41	3.08	1.43	0.48
4700	Base 2nd Freezer Recycling	Single Family	0%	0%	0.0	1,161.4	1,161.4	183.8	11	0	0	N/A	N/A	N/A	N/A	N/A	N/A
4701 5000	2nd Freezer Recycling Base Water Heating (40 gal, EF=0.88)	Single Family Single Family	99% 0%	99% 0%	132.0 279.5	1,161.4 3,732.1	11.6 3,732.1	1.8 459.7	8 15	16 0	3	0.01 N/A	71 N/A	2.94 N/A	6.01 N/A	1.08 N/A	0.50 N/A
5001	HE Water Heater (EF=0.93)	Single Family	3%	3%	350.9	3,754.1	3,649.2	449.4	15	61	8	0.33	2,653	0.18	0.32	31.38	0.55
5002	Tankless Water Heater	Single Family	15%	15%	843.0	3,742.5	3,181.1	391.8	20	306	38	0.15	1,191	0.49	0.83	14.10	0.58
5003	Heat Pump Water Heater - Energy Star	Single Family		60%	1,410.8	4,002.3	1,600.9	197.2	15	394	49	0.06	466	1.00	1.82	5.52	0.55
5004	Solar Domestic Water Heating	Single Family		85%	4,103.0	3,757.7	563.6	69.4	20	1,757	216	0.13	1,019	0.57	0.98	12.06	0.58
5005	DHW Tank Wrap	Single Family	7%	7%	45.9	3,781.9	3,514.7	432.9	5	161	20	0.02	136	1.24	2.74	1.61	0.47
5006	Pipe Wrap	Single Family	4%	4%	22.4	3,747.1	3,597.2	443.0	15	85	10 1	0.01	119	3.93	7.15	1.40	0.55
5007 5008	Hot water turndown 5 degrees Hot water turndown 10 degrees	Single Family Single Family	4% 4%	4% 4%	5.1 5.1	3,802.2 3,802.2	3,638.7 3,638.7	448.2 448.2	2	10 13	1 2	0.00	25 25	2.81 2.81	6.62 6.62	0.29 0.29	0.45 0.45
5009	Hot water turndown 15 degrees	Single Family		4%	5.1	3,802.2	3,638.7	448.2	2	3	0	0.00	25	2.81	6.62	0.29	0.45
5010	Hot water turndown 20 degrees	Single Family		4%	5.1	3,802.2	3,638.7	448.2	2	1	Ö	0.00	25	2.81	6.62	0.29	0.45
5011	Drain Water Heat Recovery (GFX)	Single Family	38%	38%	670.0	3,732.1	2,329.2	286.9	20	104	13	0.05	379	1.54	2.62	4.48	0.58

Resid	ential Electric Existing Construction										_				_		
DSM ASSY	Number Measure Type Fraction Fraction Household UEC Household Life (yrs) GWH MW \$/kWH \$/kW (TRC) Test (Years) Test 5012 Energy Star CW CEE Tier 2 (MEF=2.0) Single Family 0% 0% 187.0 3,737.9 3,722.1 458.4 14 7 1 1.16 9,427 0.05 0.09 111.55 0.1 5013 Energy Star Dishwasher (EF=0.72) Single Family 0% 0% 99.9 2,687.7 2,681.2 330.2 13 4 1 1.51 12,293 0.03 0.06 145.45 0.0 5014 Faucent Aerators Single Family 3% 3% 30.6 3,653.0 449.9 9 58 7 0.03 215 1.36 2.79 2.54 0.0																
Measure Number	Measure		Savings	Reduction	Costs/		UEC	Watts/		Potential	Potential	Energy	Peak Capacity	Cost Test		Payback	Revenue Test
5012					187.0				14	7	1		9,427		0.09	111.53	0.54
											1_						0.54
																	0.50
5100	Base Water Heating Early Replacement to Heat Pump Water Heater	Single Family	0%	0%	0.0	3,732.1	3,620.5	445.9 459.7	15	0	0	0.02 N/A	N/A	2.58 N/A	5.14 N/A	N/A	0.51 N/A
5101	Heat Pump Water Heater - Energy Star - Early Replacement	Single Family	60%	60%	1,410.8	4,002.3	1,600.9	197.2	15	70	9	0.06	466	1.00	1.82	5.52	0.55
5500	Base Clotheswasher (MEF=1.26)	Single Family	0%	0%	659.0	48.5	48.5	8.8	14	0	0	N/A	N/A	N/A	N/A	N/A	N/A
5501	Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family	34%	34%	187.0	55.4	36.8	6.7	14	18	3	0.98	5,451	0.06	0.10	94.62	0.58
5600	Base Clothes Dryer (EF=3.01)	Single Family	0%	0% 60%	326.9	735.2	735.2 294.1	124.4	12	0	0 107	N/A	N/A	N/A	N/A	N/A 39.42	N/A
5601 5602	Heat Pump Dryer High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family Single Family	60% 20%	20%	1,852.4 54.5	735.2 750.2	600.2	49.8 101.6	12 12	634 194	33	0.41 0.04	2,425 210	0.12 1.40	0.22 2.55	39.42	0.55 0.55
5700	Base Dishwasher (EF=0.65)	Single Family	0%	0%	314.5	197.5	197.5	32.4	13	0	0	N/A	N/A	N/A	N/A	N/A	N/A
5701	Energy Star Dishwasher (EF=0.72)	Single Family	4%	4%	99.9	198.2	190.4	31.2	13	9	1	1.26	7,706	0.04	0.08	121.40	0.57
6000	Base Single Speed Pool Pump (RET)	Single Family	0%	0%	345.0	2,283.8	2,283.8	271.6	10	0	0	N/A	N/A	N/A	N/A	N/A	N/A
6001	PV-Powered Pool Pumps	Single Family	99%	99%	4,655.0	2,283.8	22.8	2.7	10	275	33	0.20	1,692	0.20	0.40	19.33	0.51
6002 7000	Variable-Speed Pool Pump (<1 hp) Base Plasma TV	Single Family	75% 0%	75% 0%	413.0 0.0	2,530.5 356.5	632.6 356.5	75.2 51.4	10 7	201	24 0	0.02 N/A	179 N/A	1.90 N/A	3.75 N/A	2.04 N/A	0.51 N/A
7000	Energy Star Plasma TV	Single Family Single Family	9%	9%	1.4	358.9	325.5	47.0	7	12	2	0.00	29	6.96	14.52	0.40	0.49
7002	Plug Load Controls - Smart Power Strip (base plasma TV)	Single Family	1%	1%	35.7	356.7	353.8	51.0	4	1	0	1.22	8,467	0.01	0.03	117.35	0.47
7100	Base LCD TV	Single Family	0%	0%	0.0	231.0	231.0	33.3	7	0	0	N/A	N/A	N/A	N/A	N/A	N/A
7101	Energy Star LCD TV	Single Family	40%	40%	2.0	252.2	151.3	21.8	7	109	16	0.00	13	15.36	32.07	0.18	0.49
7102	Plug Load Controls - Smart Power Strip (base LCD TV)	Single Family	2%	2%	48.9	231.3	226.2	32.6	4	7	1	0.94	6,509	0.02	0.04	90.22	0.47
7200 7202	Base CRT TV Plug Load Controls - Smart Power Strip (base CRT TV)	Single Family Single Family	0% 6%	0% 6%	0.0 40.8	165.6 166.1	165.6 156.0	23.9 22.5	9	0 6	0	N/A 0.39	N/A 2.724	N/A 0.04	N/A 0.10	N/A 37.76	N/A 0.47
7300	Base Set-Top Box	Single Family	0%	0%	0.0	315.4	315.4	45.5	7	0	0	0.39 N/A	N/A	N/A	N/A	N/A	N/A
7400	Base DVD Player	Single Family	0%	0%	0.0	36.9	36.9	5.3	7	0	0	N/A	N/A	N/A	N/A	N/A	N/A
7401	Energy Star DVD Player	Single Family	55%	55%	1.6	38.6	17.4	2.5	7	25	4	0.01	52	3.89	8.12	0.72	0.49
7402	Plug Load Controls - Smart Power Strip (base DVD player)	Single Family	90%	90%	40.6	38.7	4.0	0.6	4	42	6	0.11	794	0.15	0.33	11.01	0.47
7500 7501	Base Desktop PC Energy Star Desktop PC	Single Family	0% 13%	0% 13%	0.0	450.4 459.0	450.4 397.4	59.3 52.4	7	0 50	0 7	N/A 0.00	N/A 15	N/A 14.43	N/A 30.49	N/A 0.19	N/A 0.49
7501	Plug Load Controls - Smart Power Strip (base Desktop PC)	Single Family Single Family	29%	29%	1.3 31.4	459.0 457.1	397.4	52.4 42.7	4	119	16	0.02	175	0.73	1.64	2.22	0.49
7600	Base Laptop PC	Single Family	0%	0%	0.0	64.3	64.3	8.5	7	0	0	N/A	N/A	N/A	N/A	N/A	N/A
7601	Energy Star Laptop PC	Single Family	18%	18%	1.6	65.9	54.1	7.1	7	12	2	0.01	101	2.16	4.57	1.28	0.49
8000	Base Cooking	Single Family	0%	0%	0.0	738.4	738.4	235.7	15	0	0	N/A	N/A	N/A	N/A	N/A	N/A
9000	Base Miscellaneous	Single Family	0%	0%	0.0	339.1	339.1	44.7	1	0	0	N/A	N/A	N/A	N/A	N/A	N/A
9900 9901	Base House Use Indirect Feedback	Single Family Single Family	0% 1%	0% 2%	0.0 9.3	15,034.6 15,036.9	15,034.6 14.811.3	3,722.9 3,667.6	1	0 373	0 92	N/A 57.10	N/A 0	N/A 16.18	N/A 1.17	N/A 2.60	N/A 0.38
9902	Direct Feedback	Single Family	5%	5%	145.0	15,030.9	14,325.9	3,547.4	4	1,182	293	0.02	76	0.97	2.02	1.81	0.50
1000	Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	Multi-Family	0%	0%	0.0	998.9	998.9	593.5	18	0	0	N/A	N/A	N/A	N/A	N/A	N/A
1001	14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	Multi-Family	7%	7%	121.2	1,006.9	934.9	555.4	18	10	6	0.16	277	0.61	0.70	15.82	0.86
1002	15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Multi-Family	13%	13%	247.0	1,013.8	878.6	522.0	18	19	11	0.18	301	0.56	0.65	17.15	0.86
1003	17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Multi-Family	24%	24%	521.1	1,025.5	784.2	465.9	18	34	20	0.21	355	0.48	0.55	20.27	0.86
1004 1005	Proper Refrigerant Charging and Air Flow (CAC) Proper Sizing and Quality Install (CAC)	Multi-Family Multi-Family	10% 13%	10% 13%	76.3 479.0	1,026.8 1,036.7	927.2 901.9	550.9 535.8	10 18	11 15	7 9	0.07 0.35	126 585	0.76 0.29	1.06 0.33	7.19 33.36	0.73 0.86
1006	AC Maintenance and/or tune-up (CAC)	Multi-Family	1%	1%	89.5	1,005.9	995.8	591.6	4	0	0	0.87	1,464	0.03	0.04	83.56	0.63
1007	AC Filter Changes (CAC)	Multi-Family	1%	1%	21.8	1,006.0	995.9	591.7	1	0	0	0.21	356	0.03	0.05	20.34	0.59
1008	Ceiling R-0 to R-38 Insulation (CAC)	Multi-Family	18%	18%	762.9	998.9	814.7	484.0	20	13	8	0.40	681	0.27	0.30	38.87	0.88
1009	Ceiling R-0 to R-49 Insulation (CAC)	Multi-Family	19%	19%	944.4	998.9	811.4	482.0	20	9	5	0.49	828	0.22	0.25	47.26	0.88
1010 1011	Ceiling R-11 to R-38 Insulaton (CAC) Ceiling R-11 to R-49 Insulation (CAC)	Multi-Family Multi-Family	6% 7%	6% 7%	581.5 762.9	998.9 998.9	935.9 932.0	556.0 553.7	20 20	2	1	0.90 1.11	1,517 1,876	0.12 0.10	0.14 0.11	86.59 107.05	0.88 0.88
1011	Ceiling R-11 to R-49 insulation (CAC)	Multi-Family	3%	3%	762.9 449.4	998.9	969.6	576.0	20	0	0	1.50	2,521	0.10	0.11	143.88	0.88
1013	Ceiling R-19 to R-49 Insulation (CAC)	Multi-Family	3%	3%	630.9	998.9	965.6	573.7	20	0	0	1.85	3,115	0.06	0.07	177.75	0.88
1014	Crawlspace insulation (CAC)	Multi-Family	4%	4%	96.1	1,009.2	969.7	576.1	20	1	0	0.24	400	0.46	0.52	22.82	0.88
1015	Basement insulation R-13 (CAC)	Multi-Family	4%	4%	972.7	1,009.2	969.7	576.1	20	0	0	2.41	4,050	0.05	0.05	231.12	0.88
1016	Floor R-0 to R-19 Insulation-Batts (CAC)	Multi-Family	4%	4%	965.7	1,009.2	969.7	576.1	20	1	0	2.39	4,021	0.05	0.05	229.46	0.88
1017 1018	Wall Blow-in R-0 to R-13 Insulation (CAC) Cool Roof (CAC)	Multi-Family Multi-Family	4% 4%	4% 4%	429.9 293.9	1,026.8 1,006.5	986.6 967.1	586.1 574.6	20 15	1 5	1	1.05 0.73	1,759 1,227	0.10 0.12	0.12 0.14	100.40 70.03	0.88 0.82
1018	Duct Insulation (CAC)	Multi-Family	4%	4%	293.9 64.8	1,006.5	996.9	574.6 592.2	20	0	0	0.73	262	0.12	0.14	14.97	0.82
1020	Duct Testing and Sealing (CAC)	Multi-Family	4%	4%	166.5	1,012.8	973.2	578.1	18	4	2	0.41	691	0.25	0.28	39.42	0.86
1021	Return Duct Modification (CAC)	Multi-Family	19%	19%	381.5	1,219.0	987.4	586.6	20	1	1	0.16	271	0.68	0.76	15.46	0.88
1022	Programmable Thermostat (CAC)	Multi-Family	2%	2%	17.0	1,011.4	991.2	588.8	12	1	1	0.08	138	0.85	1.10	7.89	0.78
1023	Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	Multi-Family	6%	6%	127.5	1,014.9	953.5	566.4	10	7	4	0.20	341 23	0.28	0.39	19.48	0.73
1024 1025	Self Install Weatherization (CAC) Door Weatherization (CAC)	Multi-Family Multi-Family	2% 6%	2% 6%	2.8 18.0	1,003.1 1,011.6	983.0 950.5	584.0 564.7	10 5	3 8	1 5	0.01	23 48	4.25 0.97	5.94 1.60	1.29 2.76	0.73
1025	Ceiling Fans (CAC)	Multi-Family	10%	10%	247.0	1,011.6	945.7	561.8	15	8	5	0.03	388	0.97	0.45	22.16	0.82
1027	Whole House Fans (CAC)	Multi-Family	6%	6%	512.9	1,000.8	940.4	558.7	15	9	5	0.83	1,396	0.10	0.13	79.69	0.82

Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)

NON-ADDITIVE MEASURE LEVEL RESULTS

Residential Electric Existing Construction DSM ASSYST SUMMARY System Levelized Cost Levelized Cost Total Energy Peak Total Peak Technical Peak Tech. of Conserved of Avoided Resource Custome Measure Savings Reduction Costs/ Watts/ Potential Energy **Peak Capacity** Cost Test Participant Payback Revenue UEC UEC \$/kWi \$/kW Measure usehol (TRC) (Years) Window Film (CAC) Multi-Family 6% 329.3 998.9 940.0 558.4 0.55 918 0.10 0.15 52.41 0.73 6% 10 1029 WINDOWS - Default With Sunscreen (CAC) Multi-Family 8% 271.6 1,006.5 929.8 552.4 10 11 0.35 583 0.16 0.23 33.24 0.73 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 5% 5% 206.7 1,025.1 976.7 580.2 20 0.42 702 0.26 40.05 0.88 1030 0.29 Base Split-System Air Conditioner - Early Replacement (11 SEER) 0% 0% 1,712.0 1,712.0 1,017.1 N/A N/A N/A N/A 1100 Multi-Family 0.0 N/A N/A 1101 ₹ (12.15 EER) Split-System Air Conditioner w/ Quality Install - Early Repl Multi-Family 6% 6% 546.4 1,624.8 965.3 0.54 917 0.08 0.12 52.34 0.67 1.722.8 Proper Refrigerant Charging and Air Flow (CAC early replacement) 1,562.6 928.3 10% 10% 76.3 1.730.5 0.04 75 1.28 4.27 0.73 1102 Multi-Family 10 1.79 13% 13% 479 N 1 511 1 0.21 349 0.56 1103 Proper Sizing and Quality Install (CAC early replacement) Multi-Family 1 736 9 897 7 0.49 19 91 0.86 18 89.5 1.706.7 1.013.9 854 0.04 0.07 48.75 0.63 1104 AC Maintenance and/or tune-up (CAC early replacement) Multi-Family 1% 1% 1.723.9 0.51 AC Filter Changes (CAC early replacement) 1% 1.706.9 1.014.0 0.12 208 0.05 11.87 0.59 1105 Multi-Family 1% 21.8 1.724.1 0.08 1106 Ceiling R-0 to R-38 Insulation (CAC early replacement) Multi-Family 18% 18% 762 9 1.712.0 1 396 3 829 5 20 0.24 397 0.46 0.52 22 68 0.88 1107 Ceiling R-0 to R-49 Insulation (CAC early replacement) Multi-Family 19% 19% 944 4 1 712 0 1 390 5 826.1 20 0.29 483 0.38 0.43 27.58 0.88 1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement) Multi-Family 6% 581.5 1,712.0 1.604.0 952.9 20 0.53 885 0.21 0.23 50.52 0.88 1109 Ceiling R-11 to R-49 Insulation (CAC early replacement) Multi-Family 7% 762.9 1.712.0 1 597 4 949 0 20 0.65 1.095 0.17 0.19 62 46 0.88 1110 Ceiling R-19 to R-38 Insulation (CAC early replacement) Multi-Family 3% 3% 449 4 1.712.0 1 661 8 987 2 20 0.87 1,471 0.13 0.14 83.95 0.88 1111 Ceiling R-19 to R-49 Insulation (CAC early replacement) Multi-Family 3% 3% 630.9 1,712.0 1,654.9 983.2 20 1.08 1,817 0.10 0.11 103.72 0.88 1112 Crawlspace insulation (CAC early replacement) Multi-Family 4% 1,661.9 0.14 233 0.79 0.88 1.729.6 1113 Basement insulation R-13 (CAC early replacement) Multi-Family 18% 18% 972.7 1,797.2 1,469.7 873.1 20 0.29 489 0.38 0.42 27.89 0.88 1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement) Multi-Family 4% 965.7 1,729.6 1.661.9 987.3 20 1.39 2,346 0.08 0.09 133.89 0.88 1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement) Multi-Family 4% 1,759.8 1.690.9 1,004.5 20 0.61 1,026 0.20 58.58 1116 Cool Roof (CAC early replacement) Multi-Family 13% 1,757.8 1.520.7 903.4 0.12 204 0.71 0.86 11.64 1117 Duct Insulation (CAC early replacement) Multi-Family 14% 14% 64.8 1,977.5 1,698.0 1,008.8 20 0.02 38 4.83 5.41 2.18 0.88 1118 Duct Testing and Sealing (CAC early replacement) Multi-Family 4% 5% 166.5 1,739.4 1,661. 0.21 350 0.48 0.56 19.97 0.86 986.9 Return Duct Modification (CAC early replacement) 19% 19% 1.692.2 1.005.3 0.09 158 0.88 1119 Multi-Family 381.5 2.089.1 20 1.16 1.30 9.02 Programmable Thermostat (CAC early replacement) Multi-Family 2% 17.0 1.733.4 1.698.7 1.009.2 12 0.05 81 1.45 0.78 1120 2% 1.89 4.60 comprehensive Shell Air Sealing - Inf. Reduction (CAC early replacement Multi-Family 199 1121 6% 6% 127.5 1.739.4 1.634.1 970.8 10 0.12 0.48 0.67 11.37 0.73 Self Install Weatherization (CAC early replacement) 13 1122 Multi-Family 2% 2% 28 1 717 5 1 683 2 999 9 10 0.01 7 28 10 17 0.75 0.73 1123 Door Weatherization (CAC early replacement) Multi-Family 6% 18.0 1,733.3 1.630.9 968.9 0.02 29 1.63 2.68 1.65 0.63 1124 Ceiling Fans (CAC early replacement) Multi-Family 5% 5% 247.0 1.755.1 1.667.3 990.5 15 0.28 463 0.31 0.38 26.42 0.82 1125 Whole House Fans (CAC early replacement) Multi-Family 20% 20% 512 9 1 722 7 1 378 1 818 7 15 0.15 245 0.59 0.72 13 97 0.82 1126 Window Film (CAC early replacement) Multi-Family 5% 5% 329.3 1.712.0 1.633.3 970.3 10 0.41 688 0.14 0.20 39 25 0.73 1127 WINDOWS - Default With Sunscreen (CAC early replacement) Multi-Family 271.6 1,720.9 1.630.3 968.5 0.29 493 0.19 0.27 28.14 0.73 1128 /INDOWS - Double-Glazed Clear to Energy Star (CAC early replacement Multi-Family 5% 5% 206.7 1,762.1 1,669.4 991.7 0.22 367 0.50 0.56 20.92 0.88 1200 Base Heat Pump Cooling (13 SEER) Multi-Family 0% 0% 1,412.4 1,412.4 839.1 N/A N/A N/A N/A N/A N/A 1201 Heat pump upgrade to (14.5-15.9 SEER, 8.2+ HSPF) (HP cooling) 15% 183.6 1,485.6 1,257.0 746.8 0.08 132 1.10 1.33 7.54 0.82

DNV·GL **NON-ADDITIVE MEASURE LEVEL RESULTS**

Residential Electric New Construction

DSM ASSYST SUMMARY

			Energy	Peak	Total			Peak		Technical	System Peak Tech.	Levelized Cost of Conserved	Levelized Cost of Avoided	Total Resource		Customer
Measure		Building	Savings	Reduction	Costs/	Base		Watts/	Service	Potential	Potential	Energy	Peak Capacity	Cost Test	Participant	Payback
Number	Measure	Type	Fraction	Fraction	Household	UEC	UEC	Household	Life (yrs)	GWH	MW	\$/kWH	\$/kW	(TRC)	Test	(Years)
100	Base Code Home - IECC 2006	Single Family	0%	0%	0.0	15,034.8	15,034.8	3,723.0	20	0	0	N/A	N/A	N/A	N/A	N/A
101	Energy Star Home	Single Family	22%	8%	2,176.0	15,034.8	11,721.3	3,425.1	20	53	5	0.06	714	1.07	1.91	6.16
200	Base Dummy Measure	Single Family	0%	0%	0.0	0.0	0.0	0.0	20	0	0	N/A	N/A	N/A	N/A	N/A
201	Dummy Measure	Single Family	0%	0%	0.0	0.0	0.0	0.0	20	0	0	N/A	N/A	99,999.00	99,999.00	N/A

Commo	ercial Electric Existing Construction															
DSM ASSYS	TSUMMARY															
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1000	Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	Office	0%	0%	0.0	7.7	7.7	1.4	18	0	0	N/A	N/A	N/A	N/A	N/A
1001 1002	ROB 4L4' High Performance T8 (86 W), 2014-2015 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	Office Office	10% 22%	10% 22%	0.1	7.7 7.7	6.9	1.3	8	111 237	21 44	0.01 0.02	52 82	3.54 2.25	4.88 3.10	1.33 2.09
1002	ROB 4L4 LOW Watt High Performance 18 (75 W), 2014-2015	Office	12%	12%	1.0	7.7	6.8	1.3	5	126	23	0.02	572	0.21	0.31	14.50
1004	ROB 4L4' LED Tube, 2014-2015	Office	34%	34%	3.4	7.7	5.0	0.9	14	373	70	0.12	670	0.47	0.57	16.99
1005	LED Troffer (base 4L4'T8), 2014-2015	Office	40%	40%	4.3	7.7	4.6	0.9	14	434	81	0.14	736	0.43	0.51	18.67
1006 1007	Lighting Control Tuneup (base 4L4'T8), 2014-2015 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	Office Office	5% 30%	3% 8%	0.0	7.7 8.1	7.3 5.7	1.4	6 10	8 80	1	0.00	39 545	6.42 1.39	10.35 2.21	0.50 3.46
1007	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	Office	25%	20%	0.0	7.7	5.8	1.1	15	81	12	0.03	68	5.80	7.24	1.38
1010	Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	Office	0%	0%	0.0	7.7	7.7	1.4	18	0	0	N/A	N/A	N/A	N/A	N/A
1011	ROB 4L4' High Performance T8 (86 W), 2016-2017	Office	10%	10%	0.1	7.7	6.9	1.3	8	111	21	0.01	52	3.54	4.88	1.33
1012 1013	ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017 ROB 4L4'T5, 2016-2017	Office Office	22% 12%	22% 12%	0.3	7.7	6.0	1.1	8	237 126	44 23	0.02	82 572	2.25 0.21	3.10 0.31	2.09 14.50
1013	ROB 4L4' LED Tube, 2016-2017	Office	34%	34%	2.3	7.7	5.0	0.9	14	373	70	0.09	460	0.68	0.82	11.67
1015	LED Troffer (base 4L4 ¹ T8), 2016-2017	Office	40%	40%	3.0	7.7	4.6	0.9	14	434	81	0.10	517	0.61	0.73	13.10
1016	Lighting Control Tuneup (base 4L4'T8), 2016-2017	Office	5%	3%	0.0	7.7	7.3	1.4	6	8	1	0.00	39	6.42	10.35	0.50
1017 1018	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	Office Office	30% 25%	8% 20%	0.6	8.1 7.7	5.7 5.8	1.4	10 15	80 81	4 12	0.03	545 68	1.39 5.80	2.21 7.24	3.46 1.38
1020	Base Fluorescent Fixture, 4L4/T8, 1EB, 2018-2019	Office	0%	0%	0.0	7.7	7.7	1.4	18	0	0	N/A	N/A	N/A	N/A	N/A
1021	ROB 4L4' High Performance T8 (86 W), 2018-2019	Office	10%	10%	0.1	7.7	6.9	1.3	8	111	21	0.01	52	3.54	4.88	1.33
1022	ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	Office	22%	22%	0.3	7.7	6.0	1.1	8	237	44	0.02	82	2.25	3.10	2.09
1023 1024	ROB 4L4'T5, 2018-2019 ROB 4L4' LED Tube, 2018-2019	Office Office	12% 34%	12% 34%	1.0 2.1	7.7 7.7	6.8 5.0	1.3 0.9	5 14	126 373	23 70	0.11	572 414	0.21	0.31 0.91	14.50 10.50
1024	LED Troffer (base 4L4'T8), 2018-2019	Office	40%	40%	2.7	7.7	4.6	0.9	14	434	81	0.09	469	0.70	0.51	11.88
1026	Lighting Control Tuneup (base 4L4'T8), 2018-2019	Office	5%	3%	0.0	7.7	7.3	1.4	6	8	1	0.00	39	6.42	10.35	0.50
1027	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	Office	30%	8%	0.6	8.1	5.7	1.4	10	80	4	0.03	545	1.39	2.21	3.46
1028	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Office Office	25% 0%	20% 0%	0.2	7.7 7.7	5.8 7.7	1.1	15 18	81 0	12 0	0.01 N/A	68 N/A	5.80 N/A	7.24 N/A	1.38 N/A
1030	ROB 4L4' High Performance T8 (86 W), 2020	Office	10%	10%	0.0	7.7	6.9	1.4	8	111	21	0.01	52	3.54	4.88	1.33
1032	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	22%	22%	0.3	7.7	6.0	1.1	8	237	44	0.02	82	2.25	3.10	2.09
1033	ROB 4L4'T5, 2020	Office	12%	12%	1.0	7.7	6.8	1.3	5	126	23	0.11	572	0.21	0.31	14.50
1034 1035	ROB 4L4' LED Tube, 2020	Office	34% 40%	34% 40%	2.0	7.7 7.7	5.0	0.9	14 14	373 434	70	0.07	391 444	0.81 0.71	0.97 0.85	9.90 11.24
1035	LED Troffer (base 4L4'T8), 2020 Lighting Control Tuneup (base 4L4'T8), 2020	Office Office	40% 5%	3%	0.0	7.7	4.6 7.3	1.4	6	8	81 1	0.08	39	6.42	10.35	0.50
1037	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	30%	8%	0.6	8.1	5.7	1.4	10	80	4	0.03	545	1.39	2.21	3.46
1038	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Office	25%	20%	0.2	7.7	5.8	1.1	15	81	12	0.01	68	5.80	7.24	1.38
1100 1101	Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	Office Office	0% 10%	0% 10%	0.0	4.5 4.5	4.5	0.8	18 8	0	0	N/A 0.01	N/A 67	N/A 2.79	N/A 3.84	N/A 1.69
1101	ROB 2L4' High Performance T8 (86 W), 2014-2015 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	Office	22%	22%	0.1	4.5	3.5	0.7	8	4	1	0.01	104	1.78	2.45	2.64
1103	ROB 2L4'T5, 2014-2015	Office	12%	12%	0.6	4.5	4.0	0.7	5	2	0	0.12	656	0.18	0.27	16.63
1104	ROB 2L4' LED Tube, 2014-2015	Office	34%	34%	1.7	4.5	2.9	0.5	14	2	0	0.11	568	0.55	0.67	14.40
1105 1106	LED Troffer (base 2L4'T8), 2014-2015 Lighting Control Tuneup (base 2L4'T8), 2014-2015	Office Office	40% 5%	40% 3%	2.4 0.0	4.5 4.5	2.7 4.2	0.5	14 6	7	1 0	0.13 0.01	707 68	0.45 3.73	0.54 6.01	17.91 0.86
1106	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	Office	30%	576 8%	0.6	4.5	3.3	0.8	10	1	0	0.01	966	0.79	1.25	6.12
1108	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	Office	25%	20%	0.2	4.5	3.4	0.7	15	1	0	0.02	117	3.37	4.21	2.38
1110	Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	Office	0%	0%	0.0	4.5	4.5	8.0	18	0	0	N/A	N/A	N/A	N/A	N/A
1111 1112	ROB 2L4' High Performance T8 (86 W), 2016-2017 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	Office Office	10% 22%	10% 22%	0.1	4.5 4.5	4.0 3.5	0.7 0.7	8	2	0 1	0.01	67 104	2.79 1.78	3.84 2.45	1.69 2.64
1113	ROB 2L4 LOW Watt High Performance 18 (73 W), 2010-2017	Office	12%	12%	0.6	4.5	4.0	0.7	5	2	0	0.12	656	0.18	0.27	16.63
1114	ROB 2L4' LED Tube, 2016-2017	Office	34%	34%	1.2	4.5	2.9	0.5	14	2	0	0.08	404	0.78	0.94	10.23
1115	LED Troffer (base 2L4'T8), 2016-2017	Office	40%	40%	1.8	4.5	2.7	0.5	14	7	1	0.10	515	0.61	0.74	13.06
1116 1117	Lighting Control Tuneup (base 2L4'T8), 2016-2017	Office Office	5% 30%	3% 8%	0.0	4.5 4.7	4.2 3.3	0.8	6 10	0 1	0	0.01	68 966	3.73 0.79	6.01 1.25	0.86 6.12
1117	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	Office	25%	20%	0.6	4.7	3.4	0.8	15	1	0	0.02	117	3.37	4.21	2.38
1120	Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	Office	0%	0%	0.0	4.5	4.5	0.8	18	0	0	N/A	N/A	N/A	N/A	N/A
1121	ROB 2L4' High Performance T8 (86 W), 2018-2019	Office	10%	10%	0.1	4.5	4.0	0.7	8	2	0	0.01	67	2.79	3.84	1.69
1122 1123	ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019 ROB 2L4'T5, 2018-2019	Office Office	22% 12%	22% 12%	0.2	4.5 4.5	3.5 4.0	0.7 0.7	8 5	4 2	1 0	0.02 0.12	104 656	1.78 0.18	2.45 0.27	2.64 16.63
1123	ROB 2L4'T5, 2018-2019 ROB 2L4' LED Tube, 2018-2019	Office	12% 34%	12% 34%	1.1	4.5	4.0 2.9	0.7	5 14	2	0	0.12	656 363	0.18	1.04	16.63 9.20
1125	LED Troffer (base 2L4'T8), 2018-2019	Office	40%	40%	1.6	4.5	2.7	0.5	14	7	1	0.09	469	0.67	0.81	11.89
1126	Lighting Control Tuneup (base 2L4'T8), 2018-2019	Office	5%	3%	0.0	4.5	4.2	8.0	6	0	0	0.01	68	3.73	6.01	0.86
1127	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	Office	30%	8%	0.6	4.7	3.3	0.8	10	1	0	0.04	966	0.79	1.25	6.12
1128 1130	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Office Office	25% 0%	20%	0.2	4.5 4.5	3.4 4.5	0.7	15 18	1	0	0.02 N/A	117 N/A	3.37 N/A	4.21 N/A	2.38 N/A
1131	ROB 2L4' High Performance T8 (86 W), 2020	Office	10%	10%	0.0	4.5	4.0	0.7	8	2	0	0.01	67	2.79	3.84	1.69
1132	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Office	22%	22%	0.2	4.5	3.5	0.7	8	4	1	0.02	104	1.78	2.45	2.64
1133	ROB 2L4'T5, 2020	Office	12%	12%	0.6	4.5	4.0	0.7	5	2	0	0.12	656	0.18	0.27	16.63
1134 1135	ROB 2L4' LED Tube, 2020 LED Troffer (base 2L4'T8), 2020	Office Office	34% 40%	34% 40%	1.0	4.5 4.5	2.9	0.5 0.5	14 14	2 7	0	0.06	342 445	0.92 0.71	1.11 0.85	8.66 11.29
1135	Lighting Control Tuneup (base 2L4'T8), 2020	Office	5%	3%	0.0	4.5	4.2	0.8	6	0	0	0.08	68	3.73	6.01	0.86

Comm	ercial Electric Existing Construction															
DSM ASSYS	T SUMMARY															
Measure Number	Measure	Building	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1137	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Type Office	30%	8%	0.6	4.7	3.3	0.8	Life (yrs) 10	1	0	0.04	966	0.79	1.25	6.12
1138	High Performance Lighting R/R - 25% Savings (base 2L4 T8), 2020	Office	25%	20%	0.2	4.5	3.4	0.7	15	1	0	0.02	117	3.37	4.21	2.38
1200	Base Other Fluorescent Fixture	Office	0%	0%	0.0	3.6	3.6	0.7	18	0	0	N/A	N/A	N/A	N/A	N/A
1201 1202	ROB High Performance T8 (base other fluorescent) ROB Low Watt High Performance T8 (base other fluorescent)	Office Office	10% 22%	10% 22%	0.2	3.6	3.2 2.8	0.6	8	4	1 2	0.04	213 334	0.87	1.20 0.77	5.40 8.46
1202	Lighting Control Tuneup (base other fluorescent fixture)	Office	30%	15%	0.0	3.6	2.5	0.5	6	2	0	0.00	14	18.04	29.10	0.18
1204	Occupancy Sensor, 4L8' Fluorescent Fixtures	Office	52%	13%	1.0	3.9	1.9	0.6	10	5	0	0.05	1,074	0.71	1.12	6.81
1205	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	25%	20%	0.2	3.6	2.7	0.5	15	3	0	0.02	146	2.72	3.40	2.95
1300	Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	Office	0%	0%	0.5	22.2		4.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1301 1302	CFLs (base incandescent flood) 2014-2015 LEDs (base incandescent flood) 2014-2015	Office Office	77% 83%	77% 83%	0.0	22.2	5.1 5.4	1.0	3 7	255 280	48 52	0.00	0	3,504.30 36.38	5,296.82 51.32	0.00 0.11
1310	Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	Office	0%	0%	0.5	22.2		4.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1311	CFLs (base incandescent flood) 2016-2017	Office	77%	77%	0.0	22.2	5.1	1.0	3	255	48	0.00	Ó	3,504.30	5,296.82	0.00
1312	LEDs (base incandescent flood) 2016-2017	Office	83%	83%	0.0	31.5	5.4	1.0	7	280	52	0.00	0	11,876.08	16,750.97	0.00
1320	Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	Office	0%	0%	0.5	22.2	22.2	4.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1321 1322	CFLs (base incandescent flood) 2018-2019 LEDs (base incandescent flood) 2018-2019	Office Office	77% 83%	77% 83%	0.0	22.2 31.5	5.1 5.4	1.0	3 7	255 280	48 52	0.00	0	3,504.30 11,876.08	5,296.82 16,750.97	0.00
1330	Base Incandescent Flood, 100W to Screw-in Replacement 2020	Office	0%	0%	0.5	22.2	22.2	4.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1331	CFLs (base incandescent flood) 2020	Office	77%	77%	0.0	22.2	5.1	1.0	3	255	48	0.00	Ó	3,504.30	5,296.82	0.00
1332	LEDs (base incandescent flood) 2020	Office	83%	83%	0.0	31.5	5.4	1.0	7	280	52	0.00	0	11,876.08	16,750.97	0.00
1400	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	Office	0%	0% 74%	0.5	16.0	16.0	3.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1401 1402	CFLs (base incandescent A-line 72W) 2014-2015 LEDs (base incandescent A-line 72W) 2014-2015	Office Office	74% 82%	74% 82%	0.0	16.0 22.5	4.2	0.8	7	88 98	16 18	0.00	0 6	2,411.69 25.53	3,645.31 36.01	0.00 0.16
1410	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	Office	0%	0%	0.5	16.0	16.0	3.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1411	CFLs (base incandescent A-line 72W) 2016-2017	Office	74%	74%	0.0	16.0	4.2	0.8	3	88	16	0.00	0	2,411.69	3,645.31	0.00
1412	LEDs (base incandescent A-line 72W) 2016-2017	Office	82%	82%	0.0	22.5	4.2	0.8	7	98	18	0.00	0	8,333.39	11,754.08	0.00
1420 1421	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019 CFLs (base incandescent A-line 72W) 2018-2019	Office Office	0% 74%	0% 74%	0.5	16.0 16.0	16.0 4.2	3.0 0.8	1	0 88	0 16	N/A 0.00	N/A 0	N/A 2.411.69	N/A 3.645.31	N/A 0.00
1421	LEDs (base incandescent A-line 72W) 2018-2019	Office	82%	82%	0.0	22.5	4.2	0.8	7	98	18	0.00	0	8,333.39	11,754.08	0.00
1430	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Office	0%	0%	0.5	16.0	16.0	3.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1431	CFLs (base incandescent A-line 72W) 2020	Office	74%	74%	0.0	16.0	4.2	0.8	3	88	16	0.00	0	2,411.69	3,645.31	0.00
1432	LEDs (base incandescent A-line 72W) 2020	Office	82%	82%	0.0	22.5	4.2	0.8	7	98	18	0.00	0	8,333.39	11,754.08	0.00
1500 1501	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015 CFLs (base incandescent A-line 53W) 2014-2015	Office Office	0% 66%	0% 66%	0.5	11.8 11.8	11.8 4.0	0.7	1	0 58	0 11	N/A 0.00	N/A 0	N/A 1,591.95	N/A 2.406.27	N/A 0.00
1502	LEDs (base incandescent A-line 53W) 2014-2015	Office	75%	75%	0.0	16.0	4.1	0.7	7	64	12	0.00	10	16.60	23.41	0.00
1510	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	Office	0%	0%	0.5	11.8	11.8	2.2	1	0	0	N/A	N/A	N/A	N/A	N/A
1511	CFLs (base incandescent A-line 53W) 2016-2017	Office	66%	66%	0.0	11.8	4.0	0.7	3	58	11	0.00	0	1,591.95	2,406.27	0.00
1512	LEDs (base incandescent A-line 53W) 2016-2017	Office	75%	75%	0.0	16.0	4.1	0.8	7	64 0	12	0.00	0	5,418.15	7,642.19	0.00
1520 1521	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019 CFLs (base incandescent A-line 53W) 2018-2019	Office Office	0% 66%	0% 66%	0.5	11.8 11.8	11.8 4.0	2.2 0.7	1	58	0 11	N/A 0.00	N/A 0	N/A 1,591.95	N/A 2,406.27	N/A 0.00
1522	LEDs (base incandescent A-line 53W) 2018-2019	Office	75%	75%	0.0	16.0	4.1	0.8	7	64	12	0.00	0	5,418.15	7,642.19	0.00
1530	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	0%	0%	0.5	11.8	11.8	2.2	1	0	0	N/A	N/A	N/A	N/A	N/A
1531	CFLs (base incandescent A-line 53W) 2020	Office	66%	66%	0.0	11.8	4.0	0.7	3	58	11	0.00	0	1,591.95	2,406.27	0.00
1532 1600	LEDs (base incandescent A-line 53W) 2020 Base CFL 18W to screw-in replacement 2014-2015	Office Office	75% 0%	75% 0%	0.0	16.0	4.1 1.3	0.8	7	64 0	12 0	0.00 N/A	0 N/A	5,418.15 N/A	7,642.19 N/A	0.00 N/A
1601	LED screw-in replacement (base CFL 18W) 2014-2015	Office	28%	28%	0.4	1.3	1.0	0.2	7	7	1	0.11	569	0.29	0.41	14.41
1610	Base CFL 18W to screw-in replacement 2016-2017	Office	0%	0%	0.2	1.3	1.3	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1611	LED screw-in replacement (base CFL 18W) 2016-2017	Office	28%	28%	0.2	1.3	1.0	0.2	7	7	1	0.06	296	0.55	0.78	7.50
1620	Base CFL 18W to screw-in replacement 2018-2019	Office	0%	0%	0.2	1.3	1.3	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1621 1630	LED screw-in replacement (base CFL 18W) 2018-2019 Base CFL 18W to screw-in replacement 2020	Office Office	28% 0%	28% 0%	0.2	1.3	1.0	0.2	7	7	1	0.04 N/A	236 N/A	0.69 N/A	0.98 N/A	5.99 N/A
1631	LED screw-in replacement (base CFL 18W) 2020	Office	28%	28%	0.2	1.3	1.0	0.2	7	7	1	0.04	205	0.80	1.12	5.20
1700	Base CFL 23W to screw-in replacement 2014-2015	Office	0%	0%	0.2	1.7	1.7	0.3	3	0	0	N/A	N/A	N/A	N/A	N/A
1701	LED screw-in replacement (base CFL 23W) 2014-2015	Office	26%	26%	0.4	1.7	1.2	0.2	7	8	1	0.09	474	0.34	0.49	12.02
1710	Base CFL 23W to screw-in replacement 2016-2017	Office	0%	0% 26%	0.2	1.7	1.7	0.3	3	0	0	N/A	N/A	N/A	N/A	N/A
1711 1720	LED screw-in replacement (base CFL 23W) 2016-2017 Base CFL 23W to screw-in replacement 2018-2019	Office	26%	26%	0.2	1.7	1.2	0.2	7	8	1	0.05 N/A	247 N/A	0.66 N/A	0.93 N/A	6.26 N/A
1721	LED screw-in replacement (base CFL 23W) 2018-2019	Office	26%	26%	0.2	1.7	1.2	0.2	7	8	1	0.04	197	0.83	1.17	4.99
1730	Base CFL 23W to screw-in replacement 2020	Office	0%	0%	0.2	1.7	1.7	0.3	3	0	0	N/A	N/A	N/A	N/A	N/A
1731	LED screw-in replacement (base CFL 23W) 2020	Office	26%	26%	0.1	1.7	1.2	0.2	7	8	1	0.03	171	0.95	1.35	4.34
1800	BaseMetal Halide, 465W	Office	0%	0%	0.0	0.0	0.0	0.0	18	0	0	N/A	N/A	N/A	N/A	N/A
1850 1851	Base CFL Exit Sign LED Exit Sign	Office Office	0% 69%	0% 69%	0.0	0.1	0.1	0.0	18 7	0 6	0	N/A 0.01	N/A 66	N/A 2.49	N/A 3.51	N/A 1.66
1900	Base Outdoor High Pressure Sodium 250W Lamp	Office	0%	0%	0.0	0.1	0.0	0.0	15	0	0	0.01 N/A	N/A	2.49 N/A	3.51 N/A	1.66 N/A
1901	Outdoor Lighting Controls (Photocell/Timeclock)	Office	22%	73%	0.1	1.0	0.8	0.0	18	11	0	0.04	853	1.70	2.11	5.28
1902	LED Outdoor Area Lighting	Office	52%	52%	0.3	0.9	0.4	0.0	18	46	1	0.07	5,068	0.82	1.17	9.49
1903	Bi-Level LED Outdoor Lighting	Office	70%	63%	1.1	0.9	0.3	0.0	18	49	1	0.17	13,482	0.34	0.49	22.72
2000 2001	Base Centrifugal Chiller, 0.58 kW/ton, 500 tons Centrifugal Chiller, 0.51 kW/ton, 500 tons	Office Office	0% 12%	0% 12%	0.7	4.7 4.8	4.7 4.3	3.3	20 20	0 12	0	N/A 0.03	N/A 39	N/A 4.37	N/A 3.19	N/A 3.69
2001	Window Film (Standard) - Chiller	Office	9%	12% 9%	0.2	4.8 5.1	4.3	3.0	20 10	0	0	0.03	39 67	1.30	1.20	6.39
2002	Trinos Trining (Stationary) - Chines	Since	270	270	U.2	3.1	-4.7	5.5	20			0.00	37	1.50	1.20	0.33

Comme	rcial Electric Existing Construction															
DSM ASSYST	SUMMARY															
Measure		Building	Energy Savings	Peak Reduction	Total Costs/	Base		Peak Watts/	Service	Technical Potential	System Peak Tech. Potential	Levelized Cost of Conserved Energy	Levelized Cost of Avoided Peak Capacity	Total Resource Cost Test	Participant	Customer Payback
Number 2003	Measure EMS - Chiller	Type Office	Fraction 10%	Fraction 3%	0.2	EUI 4.8	EUI 4.3	Sq Ft 3.3	Life (yrs) 15	GWH 10	MW 2	\$/kWH 0.04	\$/kW 209	(TRC) 1.61	2.02	(Years) 4.97
2003	Cool Roof - Chiller	Office	2%	2%	0.2	4.8	4.5	3.2	10	0	0	0.10	136	0.64	0.59	12.95
2005	Chiller Tune Up/Diagnostics	Office	8%	4%	0.1	5.0	4.6	3.4	10	0	0	0.01	35	3.85	4.56	1.68
2006	VSD for Chiller Pumps and Towers	Office	10%	5%	0.1	5.0	4.5	3.3	15	1	0	0.02	71	2.83	2.97	3.38
2008	New Economizer - Chiller	Office	27%	7%	0.5	6.0	4.4	3.9	10	9	2	0.03	177	1.31	1.82	4.21
2010	Ceiling/roof Insulation - Chiller	Office	12%	12%	0.0	5.2	4.6	3.2	20	1	0	0.01	9	19.11	13.96	0.84
2011 2012	Duct/Pipe Insulation - Chiller Duct Testing/Sealing - Chiller	Office Office	2% 19%	2% 19%	0.8	4.7 4.7	4.6 3.8	3.2 2.6	10 18	26	0 18	0.79 0.11	1,135 160	0.08 0.97	0.07 0.73	108.08 15.25
2012	High Efficiency Chiller Motors	Office	3%	3%	0.1	4.8	4.6	3.2	20	0	0	0.04	54	3.12	2.28	5.16
2100	Base DX Packaged System, EER=10.3, 10 tons	Office	0%	0%	2.0	4.7	4.7	3.3	15	0	0	N/A	N/A	N/A	N/A	N/A
2101	DX Packaged System, EER=10.9, 10 tons	Office	6%	6%	0.2	4.7	4.4	3.1	15	34	24	0.06	90	1.48	1.18	8.53
2102	DX Packaged System, EER=13.4, 10 tons	Office	23%	23%	0.2	4.7	3.6	2.5	15	142	99	0.02	29	4.57	3.62	2.77
2103 2105	Geothermal Heat Pump, EER=13, 10 tons - DX DX Tune Up/ Advanced Diagnostics	Office Office	21% 5%	21% 3%	2.4 0.1	4.7 4.9	3.7 4.6	2.6 3.3	15 10	6 1	4	0.24	345 116	0.38 1.17	0.30 1.38	32.89 5.55
2105	Prog. Thermostat - DX	Office	5%	1%	0.1	4.8	4.6	3.3	8	13	2	0.03	196	0.95	1.39	4.66
2107	Cool Roof - DX	Office	2%	2%	0.1	4.7	4.6	3.2	10	5	4	0.10	137	0.64	0.58	13.09
2108	Optimize Controls - DX	Office	5%	1%	0.0	4.8	4.6	3.3	5	11	2	0.02	93	1.28	2.00	2.21
2109	Economizer - DX	Office	28%	7%	0.5	5.0	3.6	3.3	10	68	12	0.04	202	1.15	1.59	4.80
2110	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office	3% 28%	1% 42%	0.1	4.7	4.6 3.7	3.3	10	0	0 29	0.08	440	0.53	0.73	10.47
2111 2112	Economizer Repair - DX Duct Testing/Sealing - DX	Office	28% 19%	42% 19%	0.2 1.0	5.1 4.7	3.7	2.1	5 18	28 38	29 26	0.02 0.11	16 160	2.15 0.97	2.00 0.73	2.22 15.25
2114	Duct/Pipe Insulation - DX	Office	2%	2%	0.8	4.7	4.6	3.2	10	4	3	0.80	1,140	0.08	0.07	108.57
2115	Window Film (Standard) - DX	Office	9%	9%	0.2	5.0	4.5	3.2	10	13	9	0.05	69	1.27	1.17	6.57
2200	Base Heat Pump (13 SEER, 7.7 HSPF)	Office	0%	0%	0.0	4.7	4.7	3.3	15	0	0	N/A	N/A	N/A	N/A	N/A
2201	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	13%	13%	0.1	4.7	4.1	2.9	15	52	36	0.01	21	6.41	5.07	1.98
2300	Base PTAC, EER=8.3, 1 ton	Office	0%	0%	0.0	4.7	4.7	3.3	15	0	0	N/A	N/A	N/A	N/A	N/A
3000 3001	Base Fan Motor, 5hp, 1800rpm, 87.5% Fan Motor, 5hp, 1800rpm, 89.5%	Office Office	0% 2%	0% 2%	0.0	3.4	3.4	1.0	20 20	0 5	0	N/A 0.02	N/A 64	N/A 4.49	N/A 4.49	N/A 2.62
3002	Variable Speed Drive Control. 5 HP	Office	30%	8%	0.1	3.7	2.6	1.0	15	66	5	0.02	155	4.58	6.31	1.59
3003	Demand Controlled Ventilation	Office	15%	29%	2.4	3.8	3.2	0.8	15	18	10	0.41	712	0.21	0.18	55.60
3100	Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	0%	0%	0.0	3.4	3.4	1.0	20	0	0	N/A	N/A	N/A	N/A	N/A
3101	Fan Motor, 15hp, 1800rpm, 92.4%	Office	2%	2%	0.0	3.5	3.4	1.0	20	0	0	0.01	29	9.89	9.90	1.19
3102	Variable Speed Drive Control, 15 HP	Office	30%	8% 3%	0.0	3.7	2.6 3.1	1.0	15	11	1	0.00	43	16.57	22.83	0.44
3103 3104	Air Handler Optimization, 15 HP Electronically Commutated Motors (ECM) on an Air Handler Unit	Office Office	10% 14%	13%	0.0	3.5	3.1	1.0	8 15	6 4	0	0.01	113 55	3.59 4.40	5.61 4.88	1.16 2.05
3105	Energy Recovery Ventilation (ERV)	Office	7%	13%	0.4	3.5	3.3	0.9	20	1	1	0.15	270	0.71	0.56	21.09
3107	Demand Controlled Ventilation	Office	15%	29%	2.4	3.8	3.2	0.8	15	3	2	0.41	712	0.21	0.18	55.60
3200	Base Fan Motor, 40hp, 1800rpm, 93.0%	Office	0%	0%	0.0	3.4	3.4	1.0	20	0	0	N/A	N/A	N/A	N/A	N/A
3201	Fan Motor, 40hp, 1800rpm, 94.1%	Office	1%	1%	0.0	3.5	3.4	1.0	20	0	0	0.07	232	1.23	1.23	9.54
3202 3203	Variable Speed Drive Control, 40 HP	Office Office	30% 10%	8% 3%	0.2	3.7	2.6 3.1	1.0	15 8	7	1	0.02	215 113	3.29 3.59	4.53 5.61	2.21 1.16
3203	Air Handler Optimization, 40 HP Demand Controlled Ventilation	Office	15%	376 29%	2.4	3.8	3.2	0.8	15	2	1	0.01	712	0.21	0.18	55.60
4000	Base Built-Up Refrigeration System	Office	0%	0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
4100	Base Self-Contained Refrigeration	Office	0%	0%	0.0	0.6	0.6	0.1	10	0	0	N/A	N/A	N/A	N/A	N/A
4101	Strip curtains for walk-ins (self-contained)	Office	0%	0%	0.1	0.6	0.6	0.1	4	0	0	2.09	14,900	0.01	0.01	284.51
4103	Night covers for display cases (self-contained)	Office	9%	9%	0.0	0.6	0.6	0.1	5	1	0	0.00	3 5	52.62	81.94	0.05
4104 4105	Freezer-Cooler Replacement Gaskets (self-contained) Bi-level LED Case Lighting (self-contained units) 2014	Office Office	4% 0%	4% 0%	0.0	0.6	0.6	0.1	4 8	2	0	0.00 0.17	1,216	25.09 0.19	39.91 0.28	0.09 23.22
4106	Energy-Star Refrigerator, solid door	Office	3%	3%	0.0	0.6	0.6	0.1	10	0	0	0.00	33	8.80	12.26	0.62
4107	Energy-Star Freezer, solid door	Office	1%	1%	0.0	0.6	0.6	0.1	9	0	0	0.00	24	10.89	15.60	0.45
4108	Energy-Star Refrigerator, glass door	Office	7%	7%	0.0	0.6	0.6	0.1	10	1	0	0.00	31	9.17	12.78	0.60
4109	Energy-Star Freezer, glass door	Office	2%	2%	0.0	0.6	0.6	0.1	9	0	0	0.00	10	26.67	38.21	0.19
4110	Energy Star Ice Machines	Office	2%	2% 0%	0.0	0.6	0.6	0.1	10	0	0	0.01	88	3.27	4.55	1.68
4112 5000	Reach-in unit occupancy sensors Base Desktop PC	Office Office	0% 0%	0%	0.0	0.6	0.6	0.1	10 4	0	0	0.17 N/A	1,248 N/A	0.23 N/A	0.32 N/A	23.83 N/A
5000	PC Network Power Management Enabling	Office	68%	34%	0.0	0.2	0.1	0.0	4	18	1	0.00	49	4.64	7.94	0.46
5002	Energy Star or Better PC	Office	33%	33%	0.0	0.2	0.1	0.0	4	9	1	0.00	29	4.27	6.72	0.54
5100	Base Laptop PC	Office	0%	0%	0.0	0.0	0.0	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5101	Laptop Network Power Management Enabling	Office	7%	7%	0.0	0.0	0.0	0.0	4	0	0	0.26	1,899	0.06	0.10	35.87
5102	Energy Star or Better Laptop	Office	30%	30%	0.0	0.0	0.0	0.0	4	1	0	0.00	20	6.28	9.89	0.37
5200 5201	Base Monitor, CRT Energy Star or Better Monitor - CRT	Office Office	0% 56%	0% 56%	0.0	0.1	0.1	0.0	4	0	0	N/A 0.00	N/A 2	N/A 65.45	N/A 103.02	N/A 0.04
5201	Monitor Power Management Enabling - CRT	Office	53%	27%	0.0	0.1	0.0	0.0	4	1	0	0.00	23	9.64	16.48	0.04
5203	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Office	15%	15%	0.0	0.1	0.1	0.0	4	1	0	0.02	132	0.93	1.47	2.49
5300	Base Monitor, LCD	Office	0%	0%	0.0	0.0	0.0	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5301	Energy Star or Better Monitor - LCD	Office	21%	21%	0.0	0.0	0.0	0.0	4	1	0	0.00	16	7.77	12.23	0.30
5302 5303	Monitor Power Management Enabling - LCD	Office Office	19% 15%	10% 4%	0.0	0.0	0.0	0.0	4	1	0	0.02	261 1.352	0.86 0.32	1.48 0.57	2.47 6.39
5400	Plug-load controls - Commercial Smart Strip (base monitor LCD) Base Copier	Office	0%	4% 0%	0.0	0.0	0.0	0.0	6	0	0	0.05 N/A	1,352 N/A	0.32 N/A	0.57 N/A	6.39 N/A
5401	Energy Star or Better Copier	Office	21%	21%	0.0	0.1	0.1	0.0	6	1	0	0.00	5	38.91	58.80	0.09

Comme	rcial Electric Existing Construction															
DSM ASSYST	SUMMARY															
Measure Number	Measure	Building	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base EUI	EUI	Peak Watts/ Sg Ft	Service	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
5402	Copier Power Management Enabling	Type Office	19%	10%	0.0	0.1	0.1	0.0	Life (yrs)	1	0	0.03	427	0.78	1.28	4.04
5500	Base Multifunction	Office	0%	0%	0.0	0.0	0.0	0.0	5	0	0	N/A	N/A	N/A	N/A	N/A
5501	Multifunction Power Management Enabling	Office	49%	25%	0.0	0.0	0.0	0.0	5	0	0	0.06	879	0.32	0.53	8.31
5502	ENERGY STAR Multi-Function Printer	Office	40%	40%	0.0	0.0	0.0	0.0	5	1	0	0.00	14	10.60	16.34	0.27
5600 5601	Base Printer Printer Power Management Enabling	Office Office	0% 49%	0% 25%	0.0	0.1	0.1	0.0	5 5	0	0	N/A 0.01	N/A 166	N/A 1.69	N/A 2.81	N/A 1.57
5602	ENERGY STAR Printer	Office	40%	40%	0.0	0.1	0.0	0.0	5	5	1	0.00	3	48.72	75.10	0.06
5700	Base Data Center/Server Room	Office	0%	0%	0.0		157.2	21.8	10	0	0	N/A	N/A	N/A	N/A	N/A
5701	Data Center Improved Operations	Office	20%	20%	0.1	163.8	131.0	18.2	10	7	1	0.00	2	136.37	188.43	0.04
5702	Data Center Best Practices	Office	45%	45%	0.5	164.6		12.6	10	9	1	0.00	5	61.69	85.24	0.09
5703	Data Center State of the Art practices	Office	56%	56%	1.0	157.2		9.6	10	4	1	0.00	8	36.66	50.65	0.15
6000 6001	Base Water Heating Demand controlled circulating systems	Office	0% 5%	0% 5%	0.0	0.4	0.4	0.1	15 15	0	0	N/A 0.11	N/A 789	N/A 0.55	N/A 0.69	N/A 14.52
6002	High Efficiency Water Heater (electric)	Office	2%	2%	0.0	0.4	0.4	0.1	15	2	0	0.11	170	2.53	3.20	3.13
6003	Hot Water Pipe Insulation	Office	2%	2%	0.0	0.4	0.4	0.1	15	1	0	0.04	279	1.54	1.95	5.14
6004	Tankless Water Heater	Office	10%	10%	0.0	0.4	0.4	0.0	20	6	1	0.04	293	1.84	2.18	5.39
6005	Heat Pump Water Heater (air source)	Office	20%	20%	0.0	0.4	0.3	0.0	10	13	2	0.05	391	0.77	1.06	7.20
6006	Heat Recovery Unit	Office	65%	65%	0.1	0.4	0.1	0.0	10	5	1	0.03	219	1.37	1.90	4.03
6007 6008	Heat Trap Solar Water Heater	Office Office	9% 70%	9% 70%	0.0	0.4	0.4	0.1	10 20	4	1 6	0.01	67 316	4.49 1.70	6.24 2.02	1.23 5.82
7000	Base Refrigerated Vending Machines	Office	0%	0%	0.0	0.4	0.1	0.0	10	0	0	0.04 N/A	N/A	1.70 N/A	2.02 N/A	5.82 N/A
7001	Vending Misers (Refrigerated units)	Office	46%	23%	0.0	0.1	0.0	0.0	5	2	0	0.01	134	2.01	3.34	1.32
7002	Vending Misers (Refrigerated glass-front units)	Office	30%	15%	0.0	0.1	0.0	0.0	5	1	0	0.02	209	1.29	2.14	2.07
7100	Base Non-Refrigerated Vending Machines	Office	0%	0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
7101	Vending Misers (Non-Refrigerated)	Office	46%	23%	0.0	0.0	0.0	0.0	5	0	0	0.16	2,240	0.12	0.20	22.20
7200	Base Oven	Office	0%	0%	0.0	1.2	1.2	0.2	10	0	0	N/A	N/A	N/A	N/A	N/A
7300 7400	Base Fryer Base Steamer	Office Office	0%	0% 0%	0.0	0.9	0.9 2.6	0.1	10 10	0	0	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A
8000	Base Heating, Heat Pump (7.7 HSPF)	Office	0%	0%	0.0	0.8	0.8	0.0	15	0	0	N/A	N/A	N/A	N/A	N/A
8001	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	6%	6%	0.0	0.8	0.7	0.0	15	3	0	0.01	N/A	3.48	5.08	1.97
8100	Base Heating, Other Electric	Office	0%	0%	12.0	0.8	0.8	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
9500	Base Miscellaneous	Office	0%	0%	1.3	2.3	2.3	0.3	10	0	0	N/A	N/A	N/A	N/A	N/A
9501	Xmisc	Office	0%	0%	1.3	2.3	2.3	0.3	10	0	0	N/A	N/A	0.00	0.00	N/A
1000 1001	Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015 ROB 4L4' High Performance T8 (86 W), 2014-2015	Office Office	0% 10%	0% 10%	0.0	7.4	7.4 6.6	1.4	18 8	0 6	0	N/A 0.01	N/A 55	N/A 3.39	N/A 4.68	N/A 1.38
1001	ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	Office	22%	22%	0.1	7.4	5.8	1.1	8	12	2	0.01	55 86	2.16	2.98	2.18
1003	ROB 4L4 'T5, 2014-2015	Office	12%	12%	1.0	7.4	6.5	1.2	5	7	1	0.11	596	0.20	0.29	15.11
1004	ROB 4L4' LED Tube, 2014-2015	Office	34%	34%	3.4	7.4	4.8	0.9	14	20	4	0.13	698	0.45	0.54	17.70
1005	LED Troffer (base 4L4'T8), 2014-2015	Office	40%	40%	4.3	7.4	4.4	0.8	14	23	4	0.14	767	0.41	0.49	19.44
1006	Lighting Control Tuneup (base 4L4'T8), 2014-2015	Office	5%	3%	0.0	7.4	7.0	1.3	6	0	0	0.00	41	6.16	9.94	0.52
1007 1008	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	Office Office	30% 25%	8% 20%	0.6	7.4	5.2	1.3	10 15	5 4	0	0.03	594 71	1.28 5.57	2.03 6.95	3.77 1.44
1008	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015 Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	Office	0%	0%	0.2	7.4	7.4	1.4	18	0	0	0.01 N/A	N/A	0.57 N/A	0.95 N/A	1.44 N/A
1011	ROB 4L4' High Performance T8 (86 W), 2016-2017	Office	10%	10%	0.1	7.4	6.6	1.2	8	6	1	0.01	55	3.39	4.68	1.38
1012	ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	Office	22%	22%	0.3	7.4	5.8	1.1	8	12	2	0.02	86	2.16	2.98	2.18
1013	ROB 4L4'T5, 2016-2017	Office	12%	12%	1.0	7.4	6.5	1.2	5	7	1	0.11	596	0.20	0.29	15.11
1014	ROB 4L4' LED Tube, 2016-2017	Office	34%	34%	2.3	7.4	4.8	0.9	14	20	4	0.09	480	0.66	0.79	12.16
1015 1016	LED Troffer (base 4L4'T8), 2016-2017	Office Office	40% 5%	40% 3%	3.0 0.0	7.4	4.4 7.0	0.8	14 6	23	4	0.10 0.00	538 41	0.59	0.70 9.94	13.65 0.52
1016	Lighting Control Tuneup (base 4L4'T8), 2016-2017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	Office	30%	5% 8%	0.6	7.4	5.2	1.3	10	5	0	0.00	41 594	6.16 1.28	2.03	3.77
1017	High Performance Lighting R/R - 25% Savings (base 4L4T8), 2016-2017	Office	25%	20%	0.2	7.4	5.5	1.1	15	4	1	0.01	71	5.57	6.95	1.44
1020	Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	Office	0%	0%	0.0	7.4	7.4	1.4	18	0	0	N/A	N/A	N/A	N/A	N/A
1021	ROB 4L4' High Performance T8 (86 W), 2018-2019	Office	10%	10%	0.1	7.4	6.6	1.2	8	6	1	0.01	55	3.39	4.68	1.38
1022	ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	Office	22%	22%	0.3	7.4	5.8	1.1	8	12	2	0.02	86	2.16	2.98	2.18
1023	ROB 4L4 ¹ T5, 2018-2019	Office	12% 34%	12% 34%	1.0	7.4	6.5	0.9	5	7	1	0.11	596	0.20	0.29	15.11
1024 1025	ROB 4L4' LED Tube, 2018-2019 LED Troffer (base 4L4'T8), 2018-2019	Office Office	34% 40%	34% 40%	2.1	7.4	4.8	0.9	14 14	20 23	4	0.08	432 488	0.73	0.88	10.94 12.37
1025	Lighting Control Tuneup (base 4L4'T8), 2018-2019	Office	5%	3%	0.0	7.4	7.0	1.3	6	0	0	0.00	41	6.16	9.94	0.52
1027	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	Office	30%	8%	0.6	7.4	5.2	1.3	10	5	0	0.03	594	1.28	2.03	3.77
1028	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	Office	25%	20%	0.2	7.4	5.5	1.1	15	4	1	0.01	71	5.57	6.95	1.44
1030	Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Office	0%	0%	0.0	7.4	7.4	1.4	18	0	0	N/A	N/A	N/A	N/A	N/A
1031	ROB 4L4' High Performance T8 (86 W), 2020	Office	10%	10%	0.1	7.4	6.6	1.2	8	6	1	0.01	55	3.39	4.68	1.38
1032	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	22%	22%	0.3	7.4	5.8	1.1	8	12 7	2	0.02	86 596	2.16	2.98	2.18
1033	ROB 4L4'T5, 2020 ROB 4L4' LFD Tube, 2020	Office	12% 34%	12% 34%	1.0 2.0	7.4	6.5 4.8	0.9	5 14	20	1	0.11	596 407	0.20	0.29	15.11 10.31
1034	LED Troffer (base 4L4'T8), 2020	Office	40%	40%	2.6	7.4	4.8	0.9	14	23	4	0.08	462	0.77	0.93	11.71
1036	Lighting Control Tuneup (base 4L4'T8), 2020	Office	5%	3%	0.0	7.4	7.0	1.3	6	0	0	0.00	41	6.16	9.94	0.52
1037	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	30%	8%	0.6	7.4	5.2	1.3	10	5	0	0.03	594	1.28	2.03	3.77
1038	High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Office	25%	20%	0.2	7.4	5.5	1.1	15	4	1	0.01	71	5.57	6.95	1.44
1100	Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	Office	0%	0%	0.0	4.3	4.3	0.8	18	0	0	N/A	N/A	N/A	N/A	N/A

OSM ASSYS	T SUMMARY															
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Custome Payback (Years)
1101 1102	ROB 2L4' High Performance T8 (86 W), 2014-2015 ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	Office	10% 22%	10% 22%	0.1	4.3	3.8	0.7	8	0	0	0.01	69 109	2.68	3.69 2.35	1.76 2.75
1102	ROB 2L4 LOW Watt Figit Performance 18 (73 W), 2014-2013	Office	12%	12%	0.6	4.3	3.8	0.7	5	0	0	0.13	683	0.17	0.26	17.32
1104	ROB 2L4' LED Tube, 2014-2015	Office	34%	34%	1.7	4.3	2.8	0.5	14	0	0	0.11	592	0.53	0.64	15.00
1105	LED Troffer (base 2L4'T8), 2014-2015	Office	40%	40%	2.4	4.3	2.6	0.5	14	0	0	0.14	736	0.43	0.52	18.66
1106	Lighting Control Tuneup (base 2L4'T8), 2014-2015	Office	5% 30%	3% 8%	0.0	4.3	4.1	0.8	6 10	0	0	0.01	70	3.58	5.77	0.89
1107 1108	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	Office Office	25%	20%	0.6	4.3	3.0	0.7	15	0	0	0.05	1,053 122	0.72 3.24	1.15 4.04	6.68 2.48
1110	Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	Office	0%	0%	0.0	4.3	4.3	0.8	18	0	0	N/A	N/A	N/A	N/A	N/A
1111	ROB 2L4' High Performance T8 (86 W), 2016-2017	Office	10%	10%	0.1	4.3	3.8	0.7	8	0	0	0.01	69	2.68	3.69	1.76
1112	ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	Office	22%	22%	0.2	4.3	3.4	0.6	8	0	0	0.02	109	1.71	2.35	2.75
1113 1114	ROB 2L4'T5, 2016-2017 ROB 2L4' LED Tube, 2016-2017	Office Office	12% 34%	12% 34%	0.6 1.2	4.3 4.3	3.8 2.8	0.7 0.5	5 14	0	0	0.13	683 421	0.17	0.26 0.90	17.32
1115	LED Troffer (base 2L4'T8), 2016-2017	Office	40%	40%	1.8	4.3	2.6	0.5	14	0	0	0.10	537	0.59	0.71	13.61
1116	Lighting Control Tuneup (base 2L4'T8), 2016-2017	Office	5%	3%	0.0	4.3	4.1	0.8	6	0	0	0.01	70	3.58	5.77	0.89
1117	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	Office	30%	8%	0.6	4.3	3.0	0.7	10	0	0	0.05	1,053	0.72	1.15	6.68
1118	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	Office	25% 0%	20%	0.2	4.3	3.2	0.6	15	0	0	0.02	122	3.24	4.04	2.48
1120 1121	Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019 ROB 2L4' High Performance T8 (86 W), 2018-2019	Office Office	10%	10%	0.0	4.3	4.3	0.8	18 8	0	0	N/A 0.01	N/A 69	N/A 2.68	N/A 3.69	N/A 1.76
1122	ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	Office	22%	22%	0.2	4.3	3.4	0.6	8	0	0	0.02	109	1.71	2.35	2.75
1123	ROB 2L4 ¹ T5, 2018-2019	Office	12%	12%	0.6	4.3	3.8	0.7	5	0	0	0.13	683	0.17	0.26	17.32
1124	ROB 2L4' LED Tube, 2018-2019	Office	34%	34%	1.1	4.3	2.8	0.5	14	0	0	0.07	378	0.83	1.00	9.58
1125	LED Troffer (base 2L4 ¹ T8), 2018-2019	Office	40%	40%	1.6	4.3	2.6	0.5	14	0	0	0.09	489 70	0.64	0.78	12.39
1126 1127	Lighting Control Tuneup (base 2L4'T8), 2018-2019 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	Office Office	5% 30%	3% 8%	0.0	4.3	4.1 3.0	0.8	6 10	0	0	0.01	1,053	3.58 0.72	5.77 1.15	0.89 6.68
1128	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	Office	25%	20%	0.2	4.3	3.2	0.6	15	0	0	0.02	122	3.24	4.04	2.48
1130	Base Fluorescent Fixture, 2L4 ['] T8, 1EB, 2020	Office	0%	0%	0.0	4.3	4.3	0.8	18	0	0	N/A	N/A	N/A	N/A	N/A
1131	ROB 2L4' High Performance T8 (86 W), 2020	Office	10%	10%	0.1	4.3	3.8	0.7	8	0	0	0.01	69	2.68	3.69	1.76
1132 1133	ROB 2L4' Low Watt High Performance T8 (75 W), 2020 ROB 2L4'T5, 2020	Office Office	22% 12%	22% 12%	0.2	4.3 4.3	3.4	0.6 0.7	8	0	0	0.02 0.13	109 683	1.71 0.17	2.35 0.26	2.75 17.32
1133	ROB 2L4 15, 2020 ROB 2L4 LED Tube, 2020	Office	34%	34%	1.0	4.3	2.8	0.7	14	0	0	0.13	356	0.17	1.06	9.02
1135	LED Troffer (base 2L4'T8), 2020	Office	40%	40%	1.5	4.3	2.6	0.5	14	0	0	0.09	464	0.68	0.82	11.76
1136	Lighting Control Tuneup (base 2L4'T8), 2020	Office	5%	3%	0.0	4.3	4.1	0.8	6	0	0	0.01	70	3.58	5.77	0.89
1137	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Office	30%	8%	0.6	4.3	3.0	0.7	10	0	0	0.05	1,053	0.72	1.15	6.68
1138 1200	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020 Base Other Fluorescent Fixture	Office Office	25% 0%	20%	0.2	4.3 3.5	3.2	0.6	15 18	0	0	0.02 N/A	122 N/A	3.24 N/A	4.04 N/A	2.48 N/A
1200	ROB High Performance T8 (base other fluorescent)	Office	10%	10%	0.0	3.5	3.1	0.6	8	0	0	0.04	N/A 222	0.84	1.15	5.62
1202	ROB Low Watt High Performance T8 (base other fluorescent)	Office	22%	22%	0.5	3.5	2.7	0.5	8	0	0	0.06	348	0.53	0.74	8.81
1203	Lighting Control Tuneup (base other fluorescent fixture)	Office	30%	15%	0.0	3.5	2.4	0.5	6	0	0	0.00	15	17.31	27.93	0.18
1204	Occupancy Sensor, 4L8' Fluorescent Fixtures	Office	52%	13%	1.0	3.5	1.7	0.6	10	0	0	0.06	1,212	0.63	1.00	7.69
1205 1300	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	Office Office	25% 0%	20% 0%	0.2	3.5 21.3	2.6 21.3	0.5 4.0	15 1	0	0	0.02 N/A	152 N/A	2.61 N/A	3.26 N/A	3.07 N/A
1301	CFLs (base incandescent flood) 2014-2015	Office	77%	77%	0.0	21.3	4.9	0.9	3	10	2	0.00	0	3,364.13	5,084.95	0.00
1302	LEDs (base incandescent flood) 2014-2015	Office	83%	83%	0.2	21.9	3.7	0.7	7	11	2	0.00	6	25.30	35.69	0.16
1310	Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	Office	0%	0%	0.5	21.3	21.3	4.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1311	CFLs (base incandescent flood) 2016-2017	Office	77%	77%	0.0	21.3	4.9	0.9	3	10	2	0.00	0	3,364.13	5,084.95	0.00
1312 1320	LEDs (base incandescent flood) 2016-2017 Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	Office Office	83% 0%	83%	0.0	21.9 21.3	3.7 21.3	0.7 4.0	7	11 0	2	0.00 N/A	0 N/A	8,259.12 N/A	11,649.33 N/A	0.00 N/A
1321	CFLs (base incandescent flood) 2018-2019	Office	77%	77%	0.0	21.3	4.9	0.9	3	10	2	0.00	0	3,364.13	5,084.95	0.00
1322	LEDs (base incandescent flood) 2018-2019	Office	83%	83%	0.0	21.9	3.7	0.7	7	11	2	0.00	0	8,259.12	11,649.33	0.00
1330	Base Incandescent Flood, 100W to Screw-in Replacement 2020	Office	0%	0%	0.5	21.3	21.3	4.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1331	CFLs (base incandescent flood) 2020	Office	77%	77%	0.0	21.3	4.9	0.9	3	10	2	0.00	0	3,364.13	5,084.95	0.00
1332 1400	LEDs (base incandescent flood) 2020 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	Office Office	83% 0%	83%	0.0	21.9 15.4	3.7 15.4	0.7 2.9	7	11 0	2	0.00 N/A	0 N/A	8,259.12 N/A	11,649.33 N/A	0.00 N/A
1400	CFLs (base incandescent A-line 72W) 2014-2015	Office	74%	74%	0.0	15.4	4.1	0.8	3	3	1	0.00	0	2.315.22	3,499.50	0.00
1402	LEDs (base incandescent A-line 72W) 2014-2015	Office	82%	82%	0.2	15.8	2.9	0.5	7	4	1	0.00	9	17.88	25.22	0.23
1410	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	Office	0%	0%	0.5	15.4	15.4	2.9	1	0	0	N/A	N/A	N/A	N/A	N/A
1411	CFLs (base incandescent A-line 72W) 2016-2017	Office	74%	74%	0.0	15.4	4.1	0.8	3	3	1	0.00	0	2,315.22	3,499.50	0.00
1412 1420	LEDs (base incandescent A-line 72W) 2016-2017 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	Office Office	82% 0%	82% 0%	0.0	15.8 15.4	2.9 15.4	0.5 2.9	7 1	4	1	0.00 N/A	0 N/A	5,836.28 N/A	8,231.95 N/A	0.00 N/A
1420	CFLs (base incandescent A-line 72W) 2018-2019	Office	74%	74%	0.0	15.4	4.1	0.8	3	3	1	0.00	0	2,315.22	3,499.50	0.00
1422	LEDs (base incandescent A-line 72W) 2018-2019	Office	82%	82%	0.0	15.8	2.9	0.5	7	4	1	0.00	0	5,836.28	8,231.95	0.00
1430	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Office	0%	0%	0.5	15.4	15.4	2.9	1	0	0	N/A	N/A	N/A	N/A	N/A
1431	CFLs (base incandescent A-line 72W) 2020	Office	74%	74%	0.0	15.4	4.1	0.8	3	3	1	0.00	0	2,315.22	3,499.50	0.00
1432 1500	LEDs (base incandescent A-line 72W) 2020 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	Office Office	82% 0%	82% 0%	0.0	15.8 11.3	2.9 11.3	0.5 2.1	7 1	4	1 0	0.00 N/A	0 N/A	5,836.28 N/A	8,231.95 N/A	0.00 N/A
1500	CFLs (base incandescent A-line 53W) 2014-2015	Office	66%	66%	0.5	11.3	3.8	0.7	3	2	0	0.00	N/A 0	1,528.28	N/A 2,310.02	0.00
1502	LEDs (base incandescent A-line 53W) 2014-2015	Office	75%	75%	0.2	11.6	3.0	0.5	7	3	1	0.00	14	12.00	16.93	0.34
1510	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	Office	0%	0%	0.5	11.3	11.3	2.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1511	CFLs (base incandescent A-line 53W) 2016-2017	Office	66%	66%	0.0	11.3	3.8	0.7	3	2	0	0.00	0	1,528.28	2,310.02	0.00

Comm	ercial Electric Existing Construction															
DSM ASSYS	ST SUMMARY										System	Levelized Cost	Levelized Cost	Total		
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1512	LEDs (base incandescent A-line 53W) 2016-2017	Office	75%	75%	0.0	11.6	3.0	0.5	7	3	1	0.00	0	3,918.32	5,526.71	0.00
1520	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	Office	0%	0%	0.5	11.3	11.3	2.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1521 1522	CFLs (base incandescent A-line 53W) 2018-2019 LEDs (base incandescent A-line 53W) 2018-2019	Office Office	66% 75%	66% 75%	0.0	11.3 11.6	3.8	0.7	3 7	2	0	0.00	0	1,528.28 3.918.32	2,310.02	0.00
1530	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	0%	0%	0.5	11.3	11.3	2.1	1	0	0	N/A	N/A	N/A	5,526.71 N/A	N/A
1531	CFLs (base incandescent A-line 53W) 2020	Office	66%	66%	0.0	11.3	3.8	0.7	3	2	0	0.00	0	1,528.28	2,310.02	0.00
1532	LEDs (base incandescent A-line 53W) 2020	Office	75%	75%	0.0	11.6	3.0	0.5	7	3	1	0.00	0	3,918.32	5,526.71	0.00
1600	Base CFL 18W to screw-in replacement 2014-2015	Office	0%	0%	0.2	1.3	1.3	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1601	LED screw-in replacement (base CFL 18W) 2014-2015	Office	28%	28%	0.4	1.3	0.9	0.2	7	0	0	0.11	592	0.28	0.39	15.01
1610	Base CFL 18W to screw-in replacement 2016-2017	Office	0% 28%	0% 28%	0.2	1.3	1.3	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1611 1620	LED screw-in replacement (base CFL 18W) 2016-2017 Base CFL 18W to screw-in replacement 2018-2019	Office Office	28%	28% 0%	0.2	1.3	0.9	0.2	3	0	0	0.06 N/A	308 N/A	0.53 N/A	0.75 N/A	7.82 N/A
1621	LED screw-in replacement (base CFL 18W) 2018-2019	Office	28%	28%	0.2	1.3	0.9	0.2	7	0	0	0.05	246	0.66	0.94	6.23
1630	Base CFL 18W to screw-in replacement 2020	Office	0%	0%	0.2	1.3	1.3	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1631	LED screw-in replacement (base CFL 18W) 2020	Office	28%	28%	0.1	1.3	0.9	0.2	7	0	0	0.04	214	0.76	1.08	5.42
1700	Base CFL 23W to screw-in replacement 2014-2015	Office	0%	0%	0.2	1.6	1.6	0.3	3	0	0	N/A	N/A	N/A	N/A	N/A
1701	LED screw-in replacement (base CFL 23W) 2014-2015	Office	26%	26%	0.4	1.6	1.2	0.2	7	0	0	0.09	494	0.33	0.47	12.52
1710	Base CFL 23W to screw-in replacement 2016-2017	Office	0%	0%	0.2	1.6	1.6	0.3	3	0	0	N/A	N/A	N/A	N/A	N/A
1711 1720	LED screw-in replacement (base CFL 23W) 2016-2017 Base CFL 23W to screw-in replacement 2018-2019	Office	26%	26%	0.2	1.6 1.6	1.2	0.2	7	0	0	0.05 N/A	257 N/A	0.64 N/A	0.90 N/A	6.52 N/A
1721	LED screw-in replacement (base CFL 23W) 2018-2019	Office	26%	26%	0.2	1.6	1.0	0.3	7	0	0	0.04	N/A 205	0.80	1.12	5.20
1730	Base CFL 23W to screw-in replacement 2020	Office	0%	0%	0.2	1.6	1.6	0.3	3	0	0	N/A	N/A	N/A	N/A	N/A
1731	LED screw-in replacement (base CFL 23W) 2020	Office	26%	26%	0.1	1.6	1.2	0.2	7	0	0	0.03	178	0.92	1.29	4.52
1800	BaseMetal Halide, 465W	Office	0%	0%	0.0	0.0	0.0	0.0	18	0	0	N/A	N/A	N/A	N/A	N/A
1850	Base CFL Exit Sign	Office	0%	0%	0.0	0.1	0.1	0.0	18	0	0	N/A	N/A	N/A	N/A	N/A
1851	LED Exit Sign	Office	69%	69%	0.0	0.1	0.0	0.0	7	0	0	0.01	68	2.39	3.37	1.73
1900 1901	Base Outdoor High Pressure Sodium 250W Lamp	Office Office	0% 22%	0% 73%	0.0	0.9 1.0	0.9	0.0	15 18	0	0	N/A 0.04	N/A 857	N/A 1.69	N/A 2.10	N/A 5.31
1901	Outdoor Lighting Controls (Photocell/Timeclock) LED Outdoor Area Lighting	Office	52%	73% 52%	0.1	0.9	0.4	0.0	18	1	0	0.04	5,279	0.79	1.13	9.89
1903	Bi-Level LED Outdoor Lighting	Office	70%	63%	1.1	0.9	0.3	0.0	18	1	0	0.17	14,044	0.33	0.47	23.67
2000	Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Office	0%	0%	0.7	4.5	4.5	3.1	20	0	0	N/A	N/A	N/A	N/A	N/A
2001	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Office	12%	12%	0.2	4.7	4.1	2.9	20	0	0	0.03	40	4.19	3.06	3.84
2002	Window Film (Standard) - Chiller	Office	9%	9%	0.2	4.9	4.5	3.1	10	0	0	0.05	70	1.25	1.15	6.65
2003	EMS - Chiller	Office	10%	3%	0.2	4.6	4.2	3.2	15	0	0	0.04	218	1.55	1.94	5.18
2004 2005	Cool Roof - Chiller Chiller Tune Up/Diagnostics	Office Office	2% 8%	2% 4%	0.1	4.5 4.9	4.4	3.1	10 10	0	0	0.10 0.01	142 37	0.62 3.70	0.57 4.38	13.49 1.75
2005	VSD for Chiller Pumps and Towers	Office	10%	4% 5%	0.1	4.9	4.5	3.3	15	0	0	0.01	74	2.72	4.38 2.85	3.52
2008	New Economizer - Chiller	Office	27%	7%	0.5	5.7	4.2	3.7	10	0	0	0.03	184	1.26	1.74	4.39
2010	Ceiling/roof Insulation - Chiller	Office	12%	12%	0.0	5.0	4.4	3.1	20	0	0	0.01	9	18.34	13.40	0.88
2011	Duct/Pipe Insulation - Chiller	Office	2%	2%	0.8	4.5	4.5	3.1	10	0	0	0.83	1,182	0.07	0.07	112.58
2012	Duct Testing/Sealing	Office	19%	19%	1.0	4.5	3.6	2.5	18	0	0	0.12	167	0.93	0.70	15.88
2013	High Efficiency Chiller Motors	Office	3%	3%	0.1	4.6	4.4	3.1	20	0	0	0.04	56	3.00	2.19	5.37
2100	Base DX Packaged System, EER=10.3, 10 tons	Office	0%	0% 6%	2.0	4.5	4.5	3.1	15	0	0	N/A	N/A	N/A	N/A	N/A 8.88
2101 2102	DX Packaged System, EER=10.9, 10 tons DX Packaged System, EER=13.4, 10 tons	Office Office	6% 23%	23%	0.2	4.5 4.5	4.2 3.4	3.0 2.4	15 15	1	1	0.07 0.02	93 30	1.42 4.39	1.13 3.48	2.88
2102	Geothermal Heat Pump, EER=13, 10 tons - DX	Office	21%	21%	2.4	4.5	3.5	2.5	15	0	0	0.25	360	0.37	0.29	34.27
2105	DX Tune Up/ Advanced Diagnostics	Office	5%	3%	0.1	4.7	4.5	3.2	10	0	0	0.04	121	1.12	1.33	5.77
2106	Prog. Thermostat - DX	Office	5%	1%	0.1	4.6	4.4	3.2	8	0	0	0.04	204	0.91	1.34	4.85
2107	Cool Roof - DX	Office	2%	2%	0.1	4.5	4.4	3.1	10	0	0	0.10	143	0.61	0.56	13.64
2108	Optimize Controls - DX	Office	5%	1%	0.0	4.6	4.4	3.2	5	0	0	0.02	97	1.23	1.92	2.30
2109	Economizer - DX	Office	28%	7%	0.5	4.8	3.5	3.2	10	2	0	0.04	210	1.10	1.53	5.00
2110	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office	3%	1%	0.1	4.5	4.4	3.2	10	0	0	0.08	458	0.51	0.70	10.90
2111 2112	Economizer Repair - DX Aerosol Duct Sealing - DX	Office Office	28% 19%	42% 19%	0.2 1.0	4.9 4.5	3.6	2.0	5 18	1	1	0.02 0.12	16 167	2.07 0.93	1.92 0.70	2.31 15.88
2112	Duct/Pipe Insulation - DX	Office	2%	2%	0.8	4.5	4.4	3.1	10	0	0	0.12	1,187	0.93	0.70	113.09
2115	Window Film (Standard) - DX	Office	9%	9%	0.2	4.8	4.3	3.0	10	0	0	0.05	72	1.22	1.12	6.84
2200	Base Heat Pump (13 SEER, 7.7 HSPF)	Office	0%	0%	0.0	4.5	4.5	3.1	15	0	0	N/A	N/A	N/A	N/A	N/A
2201	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	13%	13%	0.1	4.5	3.9	2.7	15	2	2	0.02	22	6.15	4.87	2.06
2300	Base PTAC, EER=8.3, 1 ton	Office	0%	0%	0.0	4.5	4.5	3.1	15	0	0	N/A	N/A	N/A	N/A	N/A
3000	Base Fan Motor, 5hp, 1800rpm, 87.5%	Office	0%	0%	0.0	3.3	3.3	1.0	20	0	0	N/A	N/A	N/A	N/A	N/A
3001	Fan Motor, 5hp, 1800rpm, 89.5%	Office	2%	2%	0.0	3.3	3.2	1.0	20	0	0	0.02	66	4.31	4.31	2.73
3002 3003	Variable Speed Drive Control, 5 HP Demand Controlled Ventilation	Office Office	30% 15%	8% 29%	0.1	3.3	2.3	0.9	15 15	3	0	0.01	174 742	4.07 0.21	5.61 0.17	1.79 57.91
3100	Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	0%	0%	0.0	3.3	3.3	1.0	20	0	0	0.43 N/A	N/A	0.21 N/A	0.17 N/A	N/A
3101	Fan Motor, 15hp, 1800rpm, 92.4%	Office	2%	2%	0.0	3.3	3.3	1.0	20	0	0	0.01	30	9.49	9.51	1.24
3102	Variable Speed Drive Control, 15 HP	Office	30%	8%	0.0	3.3	2.3	0.9	15	1	0	0.00	48	14.74	20.31	0.49
3103	Air Handler Optimization, 15 HP	Office	10%	3%	0.0	3.3	3.0	1.0	8	0	0	0.01	117	3.44	5.38	1.20
3104	Electronically Commutated Motors (ECM) on an Air Handler Unit	Office	14%	13%	0.1	3.6	3.1	0.9	15	0	0	0.02	58	4.22	4.69	2.14
3105	Energy Recovery Ventilation (ERV)	Office	7%	13%	0.4	3.4	3.2	0.9	20	0	0	0.16	281	0.69	0.54	21.97
3107	Demand Controlled Ventilation	Office	15%	29%	2.4	3.6	3.1	0.8	15	0	0	0.43	742	0.21	0.17	57.91

	T SUMMARY										System	Levelized Cost	Levelized Cost	Total		
Measure Number	Measure	Building	Energy Savings	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sg Ft	Service	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback
3200	Base Fan Motor, 40hp, 1800rpm, 93.0%	Type Office	Fraction 0%	0%	0.0	3.3	3.3	1.0	Life (yrs) 20	0	0	N/A	N/A	N/A	N/A	(Years) N/A
3201	Fan Motor, 40hp, 1800rpm, 94.1%	Office	1%	1%	0.0	3.3	3.3	1.0	20	0	0	0.07	242	1.18	1.18	9.94
3202	Variable Speed Drive Control, 40 HP	Office	30%	8%	0.2	3.3	2.3	0.9	15	0	0	0.02	242	2.93	4.03	2.49
3203	Air Handler Optimization, 40 HP	Office	10%	3% 29%	0.0	3.3	3.0	1.0	8	0	0	0.01	117 742	3.44	5.38	1.20
3204 4000	Demand Controlled Ventilation Base Built-Up Refrigeration System	Office Office	15% 0%	29% 0%	2.4 0.0	3.6	3.1 0.0	0.8	15 10	0	0	0.43 N/A	742 N/A	0.21 N/A	0.17 N/A	57.91 N/A
4100	Base Self-Contained Refrigeration	Office	0%	0%	0.0	0.6	0.6	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
4104	Freezer-Cooler Replacement Gaskets (self-contained)	Office	4%	4%	0.0	0.6	0.6	0.1	4	0	0	0.00	5	24.09	38.31	0.10
4110	Energy Star Ice Machines	Office	2%	2%	0.0	0.6	0.6	0.1	10	0	0	0.01	92	3.14	4.37	1.75
5000	Base Desktop PC	Office	0%	0%	0.0	0.9	0.9	0.1	4	0	0	N/A	N/A	N/A	N/A	N/A
5001 5002	PC Network Power Management Enabling	Office Office	68% 33%	34% 33%	0.0	1.0 0.9	0.3	0.1	4	4	0	0.00	51 30	4.46 4.10	7.62 6.45	0.48 0.57
5100	Energy Star or Better PC Base Laptop PC	Office	33% 0%	33% 0%	0.0	0.9	0.6	0.0	4	0	0	0.00 N/A	N/A	4.10 N/A	6.45 N/A	0.57 N/A
5100	Laptop Network Power Management Enabling	Office	7%	7%	0.0	0.0	0.0	0.0	4	0	0	0.27	1,978	0.06	0.10	37.37
5102	Energy Star or Better Laptop	Office	30%	30%	0.0	0.0	0.0	0.0	4	0	0	0.00	20	6.03	9.50	0.38
5200	Base Monitor, CRT	Office	0%	0%	0.0	0.5	0.5	0.1	4	0	0	N/A	N/A	N/A	N/A	N/A
5201	Energy Star or Better Monitor - CRT	Office	56%	56%	0.0	0.6	0.3	0.0	4	1	0	0.00	2	62.83	98.90	0.04
5202	Monitor Power Management Enabling - CRT	Office	53%	27%	0.0	0.8	0.4	0.1	4	0	0	0.00	24	9.25	15.82	0.23
5203	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Office	15%	15%	0.0	0.5	0.4	0.1	4	0	0	0.02	137	0.89	1.41	2.59
5300 5301	Base Monitor, LCD Energy Star or Better Monitor - LCD	Office Office	0% 21%	0% 21%	0.0	0.1	0.1	0.0	4	0	0	N/A 0.00	N/A 21	N/A 5.74	N/A 9.04	N/A 0.40
5302	Monitor Power Management Enabling - LCD	Office	19%	10%	0.0	0.2	0.1	0.0	4	0	0	0.02	353	0.64	1.09	3.34
5303	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Office	15%	4%	0.0	0.1	0.1	0.0	4	0	0	0.06	1,831	0.23	0.42	8.65
5400	Base Copier	Office	0%	0%	0.0	0.4	0.4	0.1	6	0	0	N/A	N/A	N/A	N/A	N/A
5401	Energy Star or Better Copier	Office	21%	21%	0.0	0.4	0.3	0.0	6	0	0	0.00	5	37.36	56.45	0.09
5402	Copier Power Management Enabling	Office	19%	10%	0.0	0.4	0.4	0.1	6	0	0	0.03	445	0.75	1.23	4.20
5500	Base Multifunction	Office Office	0% 49%	0% 25%	0.0	0.1	0.1	0.0	5	0	0	N/A	N/A	N/A	N/A	N/A 8.65
5501 5502	Multifunction Power Management Enabling ENERGY STAR Multi-Function Device	Office	49%	40%	0.0	0.1	0.0	0.0	5	0	0	0.06	916 15	0.31 10.18	0.51 15.69	0.28
5600	Base Printer	Office	0%	0%	0.0	0.4	0.4	0.1	5	0	0	N/A	N/A	N/A	N/A	N/A
5601	Printer Power Management Enabling	Office	49%	25%	0.0	0.7	0.3	0.1	5	1	0	0.01	173	1.62	2.70	1.64
5602	ENERGY STAR Printer	Office	40%	40%	0.0	0.5	0.3	0.0	5	1	0	0.00	3	46.78	72.10	0.06
5700	Base Data Center/Server Room	Office	0%	0%	0.0	188.7	188.7	26.2	10	0	0	N/A	N/A	N/A	N/A	N/A
5701	Data Center Improved Operations	Office	20%	20%	0.1	196.5		21.8	10	0	0	0.00	2	163.64	226.12	0.03
5702 5703	Data Center Best Practices Data Center State of the Art practices	Office Office	45% 56%	45% 56%	0.5 1.0	197.6 188.7		15.1 11.5	10 10	0	0	0.00	4 7	74.02 43.99	102.29 60.78	0.07 0.13
6000	Base Water Heating	Office	0%	0%	0.0	0.4	0.4	0.1	15	0	0	0.00 N/A	N/A	43.99 N/A	N/A	0.13 N/A
6001	Demand controlled circulating systems	Office	5%	5%	0.0	0.4	0.4	0.1	15	0	0	0.11	822	0.52	0.66	15.13
6002	High Efficiency Water Heater (electric)	Office	2%	2%	0.0	0.4	0.4	0.1	15	0	0	0.02	177	2.43	3.07	3.26
6003	Hot Water Pipe Insulation	Office	2%	2%	0.0	0.4	0.4	0.1	15	0	0	0.04	291	1.48	1.87	5.36
6004	Tankless Water Heater	Office	10%	10%	0.0	0.4	0.4	0.0	20	0	0	0.04	305	1.77	2.10	5.61
6005	Heat Pump Water Heater (air source)	Office	20%	20%	0.0	0.4	0.3	0.0	10	1	0	0.06	408	0.74	1.02	7.50
6006 6007	Heat Recovery Unit Heat Trap	Office Office	65% 9%	65% 9%	0.1	0.4	0.1	0.0	10 10	0	0	0.03	228 69	1.31 4.31	1.82 5.99	4.20 1.28
6008	Solar Water Heater	Office	70%	70%	0.1	0.4	0.1	0.0	20	2	0	0.04	329	1.64	1.94	6.06
7000	Base Refrigerated Vending Machines	Office	0%	0%	0.0	0.2	0.2	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
7001	Vending Misers (Refrigerated units)	Office	46%	23%	0.0	0.2	0.1	0.0	5	0	0	0.01	141	1.91	3.16	1.40
7002	Vending Misers (Refrigerated glass-front units)	Office	30%	15%	0.0	0.2	0.1	0.0	5	0	0	0.02	217	1.24	2.06	2.15
7100	Base Non-Refrigerated Vending Machines	Office	0%	0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
7200	Base Oven	Office	0%	0%	0.0	1.0	1.0	0.2	10	0	0	N/A	N/A	N/A	N/A	N/A
7300 7400	Base Fryer Base Steamer	Office Office	0% 0%	0% 0%	0.0	0.8 2.4	0.8 2.4	0.1	10 10	0	0	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A
8000	Base Heating, Heat Pump (7.7 HSPF)	Office	0%	0%	0.0	0.7	0.7	0.0	15	0	0	N/A	N/A	N/A	N/A	N/A
8001	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	6%	6%	0.0	0.7	0.7	0.0	15	0	0	0.02	N/A	3.34	4.88	2.06
8100	Base Heating, Other Electric	Office	0%	0%	12.0	0.7	0.7	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
9500	Base Miscellaneous	Office	0%	0%	1.3	2.3	2.3	0.3	10	0	0	N/A	N/A	N/A	N/A	N/A
9501	Xmisc	Office	0%	0%	1.3	2.3	2.3	0.3	10	0	0	N/A	N/A	0.00	0.00	N/A
1000	Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	Office	0%	0%	0.0	7.7	7.7	1.4	18	0	0	N/A	N/A	N/A	N/A	N/A
1001 1002	ROB 4L4' High Performance T8 (86 W), 2014-2015 ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	Office Office	10% 22%	10% 22%	0.1	7.7 7.7	6.9 6.0	1.3	8	15 33	3 6	0.01	52 82	3.54 2.25	4.88 3.10	1.33 2.09
1002	ROB 4L4 LOW Watt Figure Performance 18 (75 W), 2014-2015	Office	12%	12%	1.0	7.7	6.8	1.3	5	18	3	0.02	572	0.21	0.31	14.50
1003	ROB 4L4' LED Tube, 2014-2015	Office	34%	34%	3.4	7.7	5.0	0.9	14	52	10	0.12	670	0.47	0.57	16.99
1005	LED Troffer (base 4L4'T8), 2014-2015	Office	40%	40%	4.3	7.7	4.6	0.9	14	61	11	0.14	736	0.43	0.51	18.67
1006	Lighting Control Tuneup (base 4L4'T8), 2014-2015	Office	5%	3%	0.0	7.7	7.3	1.4	6	1	0	0.00	39	6.42	10.35	0.50
1007	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	Office	30%	8%	0.6	7.7	5.4	1.3	10	13	1	0.03	573	1.33	2.11	3.63
1008	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	Office	25%	20%	0.2	7.7	5.8	1.1	15	11	2	0.01	68	5.80	7.24	1.38
1010 1011	Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017 ROB 4L4' High Performance T8 (86 W), 2016-2017	Office Office	0% 10%	0% 10%	0.0	7.7 7.7	7.7 6.9	1.4	18 8	0 15	0	N/A 0.01	N/A 52	N/A 3.54	N/A 4.88	N/A 1.33
1011	ROB 4L4' High Performance 18 (86 W), 2016-2017 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	Office	10% 22%	22%	0.1	7.7	6.0	1.1	8	33	6	0.01	52 82	2.25	4.88 3.10	2.09
	ROB 4L4 'T5, 2016-2017	Office	12%	12%	1.0	7.7	0.0	4.4	0	18	3	0.02	572		0.31	2.00

Comme	rcial Electric Existing Construction															
DSM ASSYST	SUMMARY															
Measure Number	Measure	Building	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base FUI	EUI	Peak Watts/	Service	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test	Participant Test	Customer Payback
1014	ROB 4L4' LED Tube, 2016-2017	Type Office	34%	34%	2.3	7.7	5.0	Sq Ft 0.9	Life (yrs)	52	10	0.09	460	(TRC) 0.68	0.82	(Years) 11.67
1015	LED Troffer (base 4L4'T8), 2016-2017	Office	40%	40%	3.0	7.7	4.6	0.9	14	61	11	0.10	517	0.61	0.73	13.10
1016	Lighting Control Tuneup (base 4L4'T8), 2016-2017	Office	5%	3%	0.0	7.7	7.3	1.4	6	1	0	0.00	39	6.42	10.35	0.50
1017	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	Office	30%	8%	0.6	7.7	5.4	1.3	10	13	1	0.03	573	1.33	2.11	3.63
1018 1020	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	Office Office	25% 0%	20%	0.2	7.7 7.7	5.8 7.7	1.1	15 18	11 0	2	0.01 N/A	68 N/A	5.80 N/A	7.24 N/A	1.38 N/A
1020	ROB 4L4' High Performance T8 (86 W), 2018-2019	Office	10%	10%	0.1	7.7	6.9	1.3	8	15	3	0.01	52	3.54	4.88	1.33
1022	ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	Office	22%	22%	0.3	7.7	6.0	1.1	8	33	6	0.02	82	2.25	3.10	2.09
1023	ROB 4L4 ¹ T5, 2018-2019	Office	12%	12%	1.0	7.7	6.8	1.3	5	18	3	0.11	572	0.21	0.31	14.50
1024	ROB 4L4' LED Tube, 2018-2019	Office	34%	34%	2.1	7.7	5.0	0.9	14	52	10	0.08	414	0.76	0.91	10.50
1025	LED Troffer (base 4L4'T8), 2018-2019	Office	40%	40%	2.7	7.7	4.6	0.9	14	61	11	0.09	469	0.67	0.81	11.88
1026 1027	Lighting Control Tuneup (base 4L4'T8), 2018-2019 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	Office	5% 30%	3% 8%	0.0	7.7	7.3 5.4	1.4	6 10	1 13	0	0.00	39 573	6.42 1.33	10.35 2.11	0.50 3.63
1027	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	Office	25%	20%	0.0	7.7	5.8	1.1	15	11	2	0.03	68	5.80	7.24	1.38
1030	Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Office	0%	0%	0.0	7.7	7.7	1.4	18	0	0	N/A	N/A	N/A	N/A	N/A
1031	ROB 4L4' High Performance T8 (86 W), 2020	Office	10%	10%	0.1	7.7	6.9	1.3	8	15	3	0.01	52	3.54	4.88	1.33
1032	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	22%	22%	0.3	7.7	6.0	1.1	8	33	6	0.02	82	2.25	3.10	2.09
1033	ROB 4L4'T5, 2020	Office	12%	12%	1.0	7.7	6.8	1.3	5	18	3	0.11	572	0.21	0.31	14.50
1034 1035	ROB 4L4' LED Tube, 2020 LED Troffer (base 4L4'T8), 2020	Office	34% 40%	34% 40%	2.0	7.7	5.0 4.6	0.9	14 14	52 61	10 11	0.07	391 444	0.81	0.97	9.90 11.24
1035	Lighting Control Tuneup (base 4L4 T8), 2020	Office	40% 5%	3%	0.0	7.7	7.3	1.4	6	1	0	0.08	39	6.42	10.35	0.50
1037	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	30%	8%	0.6	7.7	5.4	1.3	10	13	1	0.03	573	1.33	2.11	3.63
1038	High Performance Lighting R/R - 25% Savings (base 4L4 T8), 2020	Office	25%	20%	0.2	7.7	5.8	1.1	15	11	2	0.01	68	5.80	7.24	1.38
1100	Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	Office	0%	0%	0.0	4.5	4.5	0.8	18	0	0	N/A	N/A	N/A	N/A	N/A
1101	ROB 2L4' High Performance T8 (86 W), 2014-2015	Office	10%	10%	0.1	4.5	4.0	0.7	8	0	0	0.01	67	2.79	3.84	1.69
1102	ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	Office	22%	22%	0.2	4.5	3.5	0.7	8	1	0	0.02	104	1.78	2.45	2.64
1103 1104	ROB 2L4'T5, 2014-2015 ROB 2L4' LED Tube, 2014-2015	Office	12% 34%	12% 34%	0.6 1.7	4.5 4.5	4.0 2.9	0.7	5 14	0	0	0.12 0.11	656 568	0.18 0.55	0.27 0.67	16.63 14.40
1104	LED Troffer (base 2L4'T8), 2014-2015	Office	40%	40%	2.4	4.5	2.7	0.5	14	1	0	0.11	707	0.55	0.54	17.91
1105	Lighting Control Tuneup (base 2L4/T8), 2014-2015	Office	5%	3%	0.0	4.5	4.2	0.8	6	0	0	0.01	68	3.73	6.01	0.86
1107	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	Office	30%	8%	0.6	4.5	3.1	0.8	10	0	0	0.05	1,015	0.75	1.19	6.43
1108	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	Office	25%	13%	0.2	4.5	3.4	0.7	15	0	0	0.02	188	3.10	4.21	2.38
1110	Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	Office	0%	0%	0.0	4.5	4.5	0.8	18	0	0	N/A	N/A	N/A	N/A	N/A
1111 1112	ROB 2L4' High Performance T8 (86 W), 2016-2017	Office	10% 22%	10% 22%	0.1	4.5 4.5	4.0	0.7	8	0	0	0.01	67 104	2.79 1.78	3.84 2.45	1.69 2.64
1112	ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017 ROB 2L4'T5, 2016-2017	Office	12%	12%	0.2	4.5	4.0	0.7	8 5	1	0	0.02	104 656	0.18	0.27	16.63
1114	ROB 2L4' LED Tube, 2016-2017	Office	34%	34%	1.2	4.5	2.9	0.5	14	0	0	0.08	404	0.78	0.94	10.03
1115	LED Troffer (base 2L4'T8), 2016-2017	Office	40%	40%	1.8	4.5	2.7	0.5	14	1	0	0.10	515	0.61	0.74	13.06
1116	Lighting Control Tuneup (base 2L4'T8), 2016-2017	Office	5%	3%	0.0	4.5	4.2	0.8	6	0	0	0.01	68	3.73	6.01	0.86
1117	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	Office	30%	8%	0.6	4.5	3.1	0.8	10	0	0	0.05	1,015	0.75	1.19	6.43
1118	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	Office	25%	20%	0.2	4.5	3.4	0.7	15	0	0	0.02	117	3.37	4.21	2.38
1120 1121	Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019 ROB 2L4' High Performance T8 (86 W), 2018-2019	Office Office	0% 10%	0% 10%	0.0	4.5 4.5	4.5 4.0	0.8	18 8	0	0	N/A 0.01	N/A 67	N/A 2.79	N/A 3.84	N/A 1.69
1122	ROB 2L4 Low Watt High Performance T8 (75 W), 2018-2019	Office	22%	22%	0.1	4.5	3.5	0.7	8	1	0	0.01	104	1.78	2.45	2.64
1123	ROB 2L4'T5, 2018-2019	Office	12%	12%	0.6	4.5	4.0	0.7	5	0	0	0.12	656	0.18	0.27	16.63
1124	ROB 2L4' LED Tube, 2018-2019	Office	34%	34%	1.1	4.5	2.9	0.5	14	0	0	0.07	363	0.87	1.04	9.20
1125	LED Troffer (base 2L4'T8), 2018-2019	Office	40%	40%	1.6	4.5	2.7	0.5	14	1	0	0.09	469	0.67	0.81	11.89
1126	Lighting Control Tuneup (base 2L4'T8), 2018-2019	Office	5%	3%	0.0	4.5	4.2	0.8	6	0	0	0.01	68	3.73	6.01	0.86
1127 1128	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	Office	30% 25%	8% 20%	0.6	4.5 4.5	3.1	0.8	10 15	0	0	0.05	1,015 117	0.75 3.37	1.19 4.21	6.43 2.38
1130	Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Office	0%	0%	0.2	4.5	4.5	0.7	18	0	0	0.02 N/A	N/A	3.37 N/A	4.21 N/A	2.38 N/A
1131	ROB 2L4' High Performance T8 (86 W), 2020	Office	10%	10%	0.1	4.5	4.0	0.7	8	0	0	0.01	67	2.79	3.84	1.69
1132	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Office	22%	22%	0.2	4.5	3.5	0.7	8	1	0	0.02	104	1.78	2.45	2.64
1133	ROB 2L4'T5, 2020	Office	12%	12%	0.6	4.5	4.0	0.7	5	0	0	0.12	656	0.18	0.27	16.63
1134	ROB 2L4' LED Tube, 2020	Office	34%	34%	1.0	4.5	2.9	0.5	14	0	0	0.06	342	0.92	1.11	8.66
1135	LED Troffer (base 2L4'T8), 2020	Office	40%	40%	1.5	4.5	2.7	0.5	14	1	0	0.08	445	0.71	0.85	11.29
1136 1137	Lighting Control Tuneup (base 2L4'T8), 2020 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Office Office	5% 30%	3% 8%	0.0	4.5 4.5	4.2 3.1	0.8	6 10	0	0	0.01 0.05	68 1,015	3.73 0.75	6.01 1.19	0.86 6.43
1137	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Office	25%	20%	0.0	4.5	3.4	0.8	15	0	0	0.05	1,015	3.37	4.21	2.38
1200	Base Other Fluorescent Fixture	Office	0%	0%	0.0	3.6	3.6	0.7	18	0	0	N/A	N/A	N/A	N/A	N/A
1201	ROB High Performance T8 (base other fluorescent)	Office	10%	10%	0.2	3.6	3.2	0.6	8	1	0	0.04	213	0.87	1.20	5.40
1202	ROB Low Watt High Performance T8 (base other fluorescent)	Office	22%	22%	0.5	3.6	2.8	0.5	8	1	0	0.06	334	0.56	0.77	8.46
1203	Lighting Control Tuneup (base other fluorescent fixture)	Office	30%	15%	0.0	3.6	2.5	0.6	6	0	0	0.00	14	18.04	29.10	0.18
1204	Occupancy Sensor, 4L8' Fluorescent Fixtures	Office	52%	13%	1.0	3.6	1.7	0.6	10	1	0	0.05	1,171	0.65	1.03	7.42
1205	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	25%	20%	0.2	3.6	2.7	0.5	15 1	0	0	0.02	146	2.72	3.40	2.95
1300 1301	Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015 CFLs (base incandescent flood) 2014-2015	Office Office	0% 77%	0% 77%	0.5	22.2 22.2	22.2 5.1	4.1 1.0	1	0 36	0 7	N/A 0.00	N/A 0	N/A 3,504.30	N/A 5,296.82	N/A 0.00
1301	LEDs (base incandescent flood) 2014-2015	Office	83%	83%	0.0	31.5	5.4	1.0	7	39	7	0.00	4	36.38	51.32	0.00
1310	Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	Office	0%	0%	0.5	22.2		4.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1311	CFLs (base incandescent flood) 2016-2017	Office	77%	77%	0.0	22.2	5.1	1.0	3	36	7	0.00	0	3,504.30	5,296.82	0.00

Comm	ercial Electric Existing Construction									_						
DSM ASSYS	ST SUMMARY										System	Levelized Cost	Levelized Cost	Total		
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1312	LEDs (base incandescent flood) 2016-2017	Office	83%	83%	0.0	31.5	5.4	1.0	7	39	7	0.00	0	11,876.08	16,750.97	0.00
1320	Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	Office	0%	0%	0.5	22.2	22.2	4.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1321 1322	CFLs (base incandescent flood) 2018-2019 LEDs (base incandescent flood) 2018-2019	Office Office	77% 83%	77% 83%	0.0	22.2 31.5	5.1 5.4	1.0	3 7	36 39	7	0.00	0	3,504.30 11,876.08	5,296.82 16.750.97	0.00
1330	Base Incandescent Flood, 100W to Screw-in Replacement 2020	Office	0%	0%	0.5	22.2	22.2	4.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1331	CFLs (base incandescent flood) 2020	Office	77%	77%	0.0	22.2	5.1	1.0	3	36	7	0.00	0	3,504.30	5,296.82	0.00
1332	LEDs (base incandescent flood) 2020	Office	83%	83%	0.0	31.5	5.4	1.0	7	39	7	0.00	0	11,876.08	16,750.97	0.00
1400	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	Office	0%	0%	0.5	16.0	16.0	3.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1401	CFLs (base incandescent A-line 72W) 2014-2015	Office	74%	74%	0.0	16.0	4.2	0.8	3	12	2	0.00	0	2,411.69	3,645.31	0.00
1402 1410	LEDs (base incandescent A-line 72W) 2014-2015 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	Office Office	82% 0%	82% 0%	0.2	22.5 16.0	4.2 16.0	0.8	7	14 0	3 0	0.00 N/A	6 N/A	25.53 N/A	36.01 N/A	0.16 N/A
1411	CFLs (base incandescent A-line 72W) 2016-2017	Office	74%	74%	0.0	16.0	4.2	0.8	3	12	2	0.00	0	2.411.69	3,645.31	0.00
1412	LEDs (base incandescent A-line 72W) 2016-2017	Office	82%	82%	0.0	22.5	4.2	0.8	7	14	3	0.00	0	8,333.39	11,754.08	0.00
1420	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	Office	0%	0%	0.5	16.0	16.0	3.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1421	CFLs (base incandescent A-line 72W) 2018-2019	Office	74%	74%	0.0	16.0	4.2	0.8	3	12	2	0.00	0	2,411.69	3,645.31	0.00
1422	LEDs (base incandescent A-line 72W) 2018-2019	Office	82%	82%	0.0	22.5	4.2	0.8	7	14	3	0.00	0	8,333.39	11,754.08	0.00
1430	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Office	0%	0%	0.5	16.0	16.0	3.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1431 1432	CFLs (base incandescent A-line 72W) 2020 LEDs (base incandescent A-line 72W) 2020	Office Office	74% 82%	74% 82%	0.0	16.0 22.5	4.2	0.8	3 7	12 14	2	0.00	0	2,411.69 8,333.39	3,645.31 11,754.08	0.00
1500	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	Office	0%	0%	0.5	11.8	11.8	2.2	1	0	0	N/A	N/A	N/A	N/A	N/A
1501	CFLs (base incandescent A-line 53W) 2014-2015	Office	66%	66%	0.0	11.8	4.0	0.7	3	8	2	0.00	0	1.591.95	2.406.27	0.00
1502	LEDs (base incandescent A-line 53W) 2014-2015	Office	75%	75%	0.2	16.0	4.1	0.8	7	9	2	0.00	10	16.60	23.41	0.25
1510	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	Office	0%	0%	0.5	11.8	11.8	2.2	1	0	0	N/A	N/A	N/A	N/A	N/A
1511	CFLs (base incandescent A-line 53W) 2016-2017	Office	66%	66%	0.0	11.8	4.0	0.7	3	8	2	0.00	0	1,591.95	2,406.27	0.00
1512	LEDs (base incandescent A-line 53W) 2016-2017	Office	75%	75%	0.0	16.0	4.1	0.8	7	9	2	0.00	0	5,418.15	7,642.19	0.00
1520 1521	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	Office Office	0% 66%	0% 66%	0.5	11.8	11.8	0.7	1	0	0	N/A 0.00	N/A 0	N/A 1.591.95	N/A 2.406.27	N/A 0.00
1521	CFLs (base incandescent A-line 53W) 2018-2019 LEDs (base incandescent A-line 53W) 2018-2019	Office	75%	75%	0.0	16.0	4.0	0.7	7	9	2	0.00	0	5.418.15	7.642.19	0.00
1530	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	0%	0%	0.5	11.8	11.8	2.2	1	0	0	N/A	N/A	N/A	N/A	N/A
1531	CFLs (base incandescent A-line 53W) 2020	Office	66%	66%	0.0	11.8	4.0	0.7	3	8	2	0.00	0	1,591.95	2,406.27	0.00
1532	LEDs (base incandescent A-line 53W) 2020	Office	75%	75%	0.0	16.0	4.1	0.8	7	9	2	0.00	0	5,418.15	7,642.19	0.00
1600	Base CFL 18W to screw-in replacement 2014-2015	Office	0%	0%	0.2	1.3	1.3	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1601	LED screw-in replacement (base CFL 18W) 2014-2015	Office	28%	28%	0.4	1.3	1.0	0.2	7	1	0	0.11	569	0.29	0.41	14.41
1610 1611	Base CFL 18W to screw-in replacement 2016-2017 LED screw-in replacement (base CFL 18W) 2016-2017	Office Office	0% 28%	0% 28%	0.2	1.3	1.3	0.2	3 7	0	0	N/A 0.06	N/A 296	N/A 0.55	N/A 0.78	N/A 7.50
1620	Base CFL 18W to screw-in replacement 2018-2019	Office	28% 0%	28% 0%	0.2	1.3	1.0	0.2	3	0	0	0.06 N/A	296 N/A	0.55 N/A	0.78 N/A	7.50 N/A
1621	LED screw-in replacement (base CFL 18W) 2018-2019	Office	28%	28%	0.2	1.3	1.0	0.2	7	1	0	0.04	236	0.69	0.98	5.99
1630	Base CFL 18W to screw-in replacement 2020	Office	0%	0%	0.2	1.3	1.3	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1631	LED screw-in replacement (base CFL 18W) 2020	Office	28%	28%	0.1	1.3	1.0	0.2	7	1	0	0.04	205	0.80	1.12	5.20
1700	Base CFL 23W to screw-in replacement 2014-2015	Office	0%	0%	0.2	1.7	1.7	0.3	3	0	0	N/A	N/A	N/A	N/A	N/A
1701	LED screw-in replacement (base CFL 23W) 2014-2015	Office	26%	26%	0.4	1.7	1.2	0.2	7	1	0	0.09	474	0.34	0.49	12.02
1710 1711	Base CFL 23W to screw-in replacement 2016-2017	Office Office	0% 26%	0% 26%	0.2	1.7	1.7	0.3	3 7	0	0	N/A 0.05	N/A 247	N/A 0.66	N/A 0.93	N/A 6.26
1711	LED screw-in replacement (base CFL 23W) 2016-2017 Base CFL 23W to screw-in replacement 2018-2019	Office	0%	0%	0.2	1.7	1.7	0.2	3	1	0	0.05 N/A	N/A	0.66 N/A	0.93 N/A	N/A
1721	LED screw-in replacement (base CFL 23W) 2018-2019	Office	26%	26%	0.2	1.7	1.2	0.2	7	1	0	0.04	197	0.83	1.17	4.99
1730	Base CFL 23W to screw-in replacement 2020	Office	0%	0%	0.2	1.7	1.7	0.3	3	0	0	N/A	N/A	N/A	N/A	N/A
1731	LED screw-in replacement (base CFL 23W) 2020	Office	26%	26%	0.1	1.7	1.2	0.2	7	1	0	0.03	171	0.95	1.35	4.34
1800	BaseMetal Halide, 465W	Office	0%	0%	0.0	0.0	0.0	0.0	18	0	0	N/A	N/A	N/A	N/A	N/A
1850	Base CFL Exit Sign	Office	0%	0%	0.0	0.1	0.1	0.0	18	0	0	N/A	N/A	N/A	N/A	N/A
1851	LED Exit Sign	Office	69%	69%	0.0	0.1	0.0	0.0	7	1	0	0.01	66	2.49	3.51	1.66
1900 1901	Base Outdoor High Pressure Sodium 250W Lamp Outdoor Lighting Controls (Photocell/Timeclock)	Office Office	0% 22%	0% 73%	0.0	0.9	0.9	0.0	15 18	0	0	N/A 0.04	N/A 951	N/A 1.52	N/A 1.89	N/A 5.88
1902	LED Outdoor Area Lighting	Office	52%	52%	0.1	0.9	0.7	0.0	18	6	0	0.07	5.068	0.82	1.17	9.49
1903	Bi-Level LED Outdoor Lighting	Office	70%	63%	1.1	0.9	0.3	0.0	18	7	0	0.17	13,482	0.34	0.49	22.72
2000	Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Office	0%	0%	0.7	4.7	4.7	3.3	20	0	0	N/A	N/A	N/A	N/A	N/A
2001	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Office	12%	12%	0.2	4.8	4.3	3.0	20	2	1	0.03	39	4.37	3.19	3.69
2002	Window Film (Standard) - Chiller	Office	9%	9%	0.2	5.1	4.7	3.3	10	0	0	0.05	67	1.30	1.20	6.39
2003	EMS - Chiller	Office	10%	3%	0.2	4.8	4.3	3.3	15	1	0	0.04	209	1.61	2.02	4.97
2004 2006	Cool Roof - Chiller VSD for Chiller Pumps and Towers	Office Office	2% 10%	2% 5%	0.1	4.7 5.0	4.6 4.5	3.2	10 15	0	0	0.10 0.02	136 71	0.64 2.83	0.59 2.97	12.95 3.38
2006	New Economizer - Chiller	Office	10% 27%	5% 7%	0.1	6.0	4.5	3.3	10	1	0	0.02	177	1.31	1.82	4.21
2010	Ceiling/roof Insulation - Chiller	Office	12%	12%	0.0	5.2	4.6	3.2	20	0	0	0.03	9	19.11	13.96	0.84
2011	Duct/Pipe Insulation - Chiller	Office	2%	2%	0.8	4.7	4.6	3.2	10	0	0	0.79	1,135	0.08	0.07	108.08
2012	Duct Testing/Sealing	Office	19%	19%	1.0	4.7	3.8	2.6	18	4	3	0.11	160	0.97	0.73	15.25
2013	High Efficiency Chiller Motors	Office	3%	3%	0.1	4.8	4.6	3.2	20	0	0	0.04	54	3.12	2.28	5.16
2100	Base DX Packaged System, EER=10.3, 10 tons	Office	0%	0%	2.0	4.7	4.7	3.3	15	0	0	N/A	N/A	N/A	N/A	N/A
2101	DX Packaged System, EER=10.9, 10 tons	Office	6%	6%	0.2	4.7	4.4	3.1	15	5	3	0.06	90	1.48	1.18	8.53
2102 2103	DX Packaged System, EER=13.4, 10 tons Geothermal Heat Pump, EER=13, 10 tons - DX	Office Office	23% 21%	23% 21%	0.2 2.4	4.7 4.7	3.6 3.7	2.5 2.6	15 15	20 1	14 1	0.02 0.24	29 345	4.57 0.38	3.62 0.30	2.77 32.89
2103	Prog. Thermostat - DX	Office	5%	1%	0.1	4.7	4.6	3.3	8	2	0	0.24	343 196	0.38	1.39	4.66
2200	110b. memostat - DA	JIIICE	570	1/0	J.1	0	4.0	5.5	9	-	0	0.00	130	0.55	4.33	4.00

Commer	cial Electric Existing Construction															
DSM ASSYST S	UMMARY															
Measure Number	Measure	Building	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
2107	Cool Roof - DX	Type Office	2%	2%	0.1	4.7	4.6	3.2	Life (yrs) 10	1	1	0.10	137	0.64	0.58	13.09
2108	Optimize Controls - DX	Office	5%	1%	0.0	4.8	4.6	3.3	5	1	0	0.02	93	1.28	2.00	2.21
2109	Economizer - DX	Office	28%	7%	0.5	5.0	3.6	3.3	10	9	2	0.04	202	1.15	1.59	4.80
2110	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office	3%	1%	0.1	4.7	4.6	3.3	10	0	0	0.08	440	0.53	0.73	10.47
2111 2112	Economizer Repair - DX Aerosol Duct Sealing - DX	Office Office	28% 19%	42% 19%	0.2 1.0	5.1 4.7	3.7	2.1	5 18	4 5	4	0.02 0.11	16 160	2.15 0.97	2.00 0.73	2.22 15.25
2114	Duct/Pipe Insulation - DX	Office	2%	2%	0.8	4.7	4.6	3.2	10	1	0	0.80	1,140	0.08	0.73	108.57
2115	Window Film (Standard) - DX	Office	9%	9%	0.2	5.0	4.5	3.2	10	2	1	0.05	69	1.27	1.17	6.57
2200	Base Heat Pump (13 SEER, 7.7 HSPF)	Office	0%	0%	0.0	4.7	4.7	3.3	15	0	0	N/A	N/A	N/A	N/A	N/A
2201	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	13%	13%	0.1	4.7	4.1	2.9	15	7	5	0.01	21	6.41	5.07	1.98
2300	Base PTAC, EER=8.3, 1 ton	Office	0%	0%	0.0	4.7	4.7	3.3	15	0	0	N/A	N/A	N/A	N/A	N/A
3000 3001	Base Fan Motor, 5hp, 1800rpm, 87.5% Fan Motor, 5hp, 1800rpm, 89.5%	Office	0% 2%	0% 2%	0.0	3.4	3.4	1.0	20 20	0	0	N/A 0.02	N/A 64	N/A 4.49	N/A 4.49	N/A 2.62
3002	Variable Speed Drive Control. 5 HP	Office	30%	8%	0.1	3.4	2.4	1.0	15	12	1	0.02	168	4.43	5.81	1.73
3003	Demand Controlled Ventilation	Office	15%	29%	2.4	3.8	3.2	0.8	15	3	1	0.41	712	0.21	0.18	55.60
3100	Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	0%	0%	0.0	3.4	3.4	1.0	20	0	0	N/A	N/A	N/A	N/A	N/A
3101	Fan Motor, 15hp, 1800rpm, 92.4%	Office	2%	2%	0.0	3.5	3.4	1.0	20	0	0	0.01	29	9.89	9.90	1.19
3102	Variable Speed Drive Control, 15 HP	Office	30%	8%	0.0	3.4	2.4	1.0	15	2	0	0.00	46	15.26	21.02	0.48
3103 3104	Air Handler Optimization, 15 HP	Office	10% 14%	3% 13%	0.0	3.5	3.1	1.0	8 15	1	0	0.01	113 55	3.59 4.40	5.61 4.88	1.16 2.05
3104	Electronically Commutated Motors (ECM) on an Air Handler Unit Energy Recovery Ventilation (ERV)	Office	7%	13%	0.1	3.5	3.3	0.9	20	0	0	0.02	270	0.71	0.56	21.09
3107	Demand Controlled Ventilation	Office	15%	29%	2.4	3.8	3.2	0.8	15	0	0	0.41	712	0.71	0.18	55.60
3200	Base Fan Motor, 40hp, 1800rpm, 93.0%	Office	0%	0%	0.0	3.4	3.4	1.0	20	0	0	N/A	N/A	N/A	N/A	N/A
3201	Fan Motor, 40hp, 1800rpm, 94.1%	Office	1%	1%	0.0	3.5	3.4	1.0	20	0	0	0.07	232	1.23	1.23	9.54
3202	Variable Speed Drive Control, 40 HP	Office	30%	8%	0.2	3.4	2.4	1.0	15	1	0	0.02	234	3.03	4.17	2.40
3203	Air Handler Optimization, 40 HP	Office	10%	3%	0.0	3.5	3.1	1.0	8	0	0	0.01	113	3.59	5.61	1.16
3204 4000	Demand Controlled Ventilation	Office	15% 0%	29% 0%	2.4 0.0	3.8	3.2 0.0	0.8	15 10	0	0	0.41 N/A	712 N/A	0.21 N/A	0.18 N/A	55.60 N/A
4000	Base Built-Up Refrigeration System Base Self-Contained Refrigeration	Office	0%	0%	0.0	0.0	0.6	0.0	10	0	0	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A
4101	Strip curtains for walk-ins (self-contained)	Office	0%	0%	0.0	0.6	0.6	0.1	4	0	0	2.09	14,907	0.01	0.01	284.65
4103	Night covers for display cases (self-contained)	Office	9%	9%	0.0	0.6	0.6	0.1	5	0	0	0.00	3	51.18	79.69	0.06
4104	Freezer-Cooler Replacement Gaskets (self-contained)	Office	4%	4%	0.0	0.6	0.6	0.1	4	0	0	0.00	5	25.09	39.91	0.09
4105	Bi-level LED Case Lighting (self-contained units) 2014	Office	0%	0%	0.0	0.6	0.6	0.1	8	0	0	0.17	1,216	0.19	0.28	23.22
4106	Energy-Star Refrigerator, solid door	Office	3%	3%	0.0	0.6	0.6	0.1	10	0	0	0.00	33	8.80	12.26	0.62
4107 4108	Energy-Star Freezer, solid door Energy-Star Refrigerator, glass door	Office Office	1% 7%	1% 7%	0.0	0.6	0.6	0.1	9 10	0	0	0.00	24 31	10.89 9.17	15.60 12.78	0.45
4108	Energy-Star Refrigerator, glass door Energy-Star Freezer, glass door	Office	7% 2%	2%	0.0	0.6	0.6	0.1	9	0	0	0.00	10	26.67	38.21	0.60
4110	Energy Star Ice Machines	Office	2%	2%	0.0	0.6	0.6	0.1	10	0	0	0.01	88	3.27	4.55	1.68
4112	Reach-in unit occupancy sensors	Office	0%	0%	0.0	0.6	0.6	0.1	10	0	0	0.17	1,248	0.23	0.32	23.83
5000	Base Desktop PC	Office	0%	0%	0.0	0.2	0.2	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5001	PC Network Power Management Enabling	Office	68%	34%	0.0	0.2	0.1	0.0	4	3	0	0.00	49	4.64	7.94	0.46
5002 5100	Energy Star or Better PC	Office Office	33% 0%	33% 0%	0.0	0.2	0.1	0.0	4	1 0	0	0.00 N/A	29 N/A	4.27 N/A	6.72 N/A	0.54 N/A
5100	Base Laptop PC Laptop Network Power Management Enabling	Office	7%	7%	0.0	0.0	0.0	0.0	4	0	0	N/A 0.26	N/A 1,899	0.06	0.10	N/A 35.87
5102	Energy Star or Better Laptop	Office	30%	30%	0.0	0.0	0.0	0.0	4	0	0	0.00	20	6.28	9.89	0.37
5200	Base Monitor, CRT	Office	0%	0%	0.0	0.1	0.1	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5201	Energy Star or Better Monitor - CRT	Office	56%	56%	0.0	0.1	0.0	0.0	4	1	0	0.00	2	65.45	103.02	0.04
5202	Monitor Power Management Enabling - CRT	Office	53%	27%	0.0	0.1	0.1	0.0	4	0	0	0.00	23	9.64	16.48	0.22
5203	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Office	15% 0%	15% 0%	0.0	0.1	0.1	0.0	4	0	0	0.02	132	0.93	1.47	2.49
5300 5301	Base Monitor, LCD Energy Star or Better Monitor - LCD	Office	0% 21%	0% 21%	0.0	0.0	0.0	0.0	4	0	0	N/A 0.00	N/A 16	N/A 7.77	N/A 12.23	N/A 0.30
5302	Monitor Power Management Enabling - LCD	Office	19%	10%	0.0	0.0	0.0	0.0	4	0	0	0.02	261	0.86	1.48	2.47
5303	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Office	15%	4%	0.0	0.0	0.0	0.0	4	0	0	0.05	1,352	0.32	0.57	6.39
5400	Base Copier	Office	0%	0%	0.0	0.1	0.1	0.0	6	0	0	N/A	N/A	N/A	N/A	N/A
5401	Energy Star or Better Copier	Office	21%	21%	0.0	0.1	0.1	0.0	6	0	0	0.00	5	38.91	58.80	0.09
5402	Copier Power Management Enabling	Office	19%	10%	0.0	0.1	0.1	0.0	6	0	0	0.03	427	0.78	1.28	4.04
5500	Base Multifunction	Office	0%	0%	0.0	0.0	0.0	0.0	5	0	0	N/A	N/A	N/A	N/A	N/A
5501 5502	Multifunction Power Management Enabling ENERGY STAR Multi-Function Device	Office Office	49% 40%	25% 40%	0.0	0.0	0.0	0.0	5 5	0	0	0.06 0.00	879 14	0.32 10.60	0.53 16.34	8.31 0.27
5600	Base Printer	Office	0%	0%	0.0	0.0	0.0	0.0	5	0	0	N/A	N/A	N/A	N/A	N/A
5601	Printer Power Management Enabling	Office	49%	25%	0.0	0.1	0.0	0.0	5	0	0	0.01	166	1.69	2.81	1.57
5602	ENERGY STAR Printer	Office	40%	40%	0.0	0.1	0.0	0.0	5	1	0	0.00	3	48.72	75.10	0.06
5700	Base Data Center/Server Room	Office	0%	0%	0.0	196.5		27.3	10	0	0	N/A	N/A	N/A	N/A	N/A
5701	Data Center Improved Operations	Office	20%	20%	0.1		163.8	22.7	10	1	0	0.00	2	170.46	235.54	0.03
5702	Data Center Best Practices	Office	45%	45%	0.5		113.2	15.7	10	2	0	0.00	4	77.11	106.55	0.07
5703 6000	Data Center State of the Art practices	Office	56% 0%	56%	1.0	196.5 0.4	86.5 0.4	12.0 0.1	10	1	0	0.00	6	45.82	63.31	0.12
6000	Base Water Heating Demand controlled circulating systems	Office Office	0% 5%	0% 5%	0.0	0.4	0.4	0.1	15 15	0	0	N/A 0.11	N/A 789	N/A 0.55	N/A 0.69	N/A 14.52
6002	High Efficiency Water Heater (electric)	Office	2%	2%	0.0	0.4	0.4	0.1	15	0	0	0.11	170	2.53	3.20	3.13
6003	Hot Water Pipe Insulation	Office	2%	2%	0.0	0.4	0.4	0.1	15	0	0	0.04	280	1.54	1.95	5.14
	• • • • • • • • • • • • • • • • • • • •															

Comme	ercial Electric Existing Construction								_							
DSM ASSYST	SUMMARY										System	Levelized Cost	Levelized Cost	Total		
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
6004 6005	Tankless Water Heater Heat Pump Water Heater (air source)	Office	10% 20%	10% 20%	0.0	0.4	0.4	0.0	20 10	1 2	0	0.04	293 391	1.84	2.18	5.39 7.20
6006	Heat Recovery Unit	Office	65%	65%	0.0	0.4	0.3	0.0	10	1	0	0.03	219	1.37	1.06	4.03
6007	Heat Trap	Office	9%	9%	0.0	0.4	0.4	0.1	10	1	0	0.01	67	4.49	6.24	1.23
6008	Solar Water Heater	Office	70%	70%	0.1	0.4	0.1	0.0	20	6	1	0.04	316	1.70	2.02	5.82
7000 7001	Base Refrigerated Vending Machines Vending Misers (Refrigerated units)	Office Office	0% 46%	0% 23%	0.0	0.1	0.1	0.0	10 5	0	0	N/A 0.01	N/A 141	N/A 1.91	N/A 3.16	N/A 1.40
7001	Vending Misers (Refrigerated units) Vending Misers (Refrigerated glass-front units)	Office	30%	15%	0.0	0.1	0.0	0.0	5	0	0	0.01	217	1.91	2.06	2.15
7100	Base Non-Refrigerated Vending Machines	Office	0%	0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
7101	Vending Misers (Non-Refrigerated)	Office	46%	23%	0.0	0.0	0.0	0.0	5	0	0	0.17	2,369	0.11	0.19	23.47
7200 7300	Base Oven Base Fryer	Office Office	0% 0%	0% 0%	0.0	1.2 0.9	1.2 0.9	0.2	10 10	0	0	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A
7400	Base Steamer	Office	0%	0%	0.0	2.6	2.6	0.1	10	0	0	N/A N/A	N/A N/A	N/A	N/A N/A	N/A N/A
8000	Base Heating, Heat Pump (7.7 HSPF)	Office	0%	0%	0.0	0.8	0.8	0.0	15	0	0	N/A	N/A	N/A	N/A	N/A
8001	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	6%	6%	0.0	0.8	0.7	0.0	15	0	0	0.01	N/A	3.48	5.08	1.97
8100	Base Heating, Other Electric	Office	0%	0%	12.0	0.8	0.8	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
9500 9501	Base Miscellaneous Xmisc	Office Office	0% 0%	0%	1.3	2.3	2.3	0.3	10 10	0	0	N/A N/A	N/A N/A	N/A 0.00	N/A 0.00	N/A N/A
1000	Base Fluorescent Fixture. 4L4'T8. 1EB. 2014-2015	Restaurant	0%	0%	0.0	7.6	7.6	1.5	18	0	0	N/A	N/A	N/A	N/A	N/A
1001	ROB 4L4' High Performance T8 (86 W), 2014-2015	Restaurant	10%	10%	0.1	7.6	6.8	1.3	7	2	0	0.02	79	1.95	2.76	2.12
1002	ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	Restaurant	22%	22%	0.4	7.6	5.9	1.2	7	3	1	0.02	124	1.25	1.76	3.32
1003	ROB 4L4 ¹ T5, 2014-2015	Restaurant	12%	12%	1.5	7.6	6.7	1.3	5	2	0	0.17	858	0.13	0.19	23.07
1004 1005	ROB 4L4' LED Tube, 2014-2015 LED Troffer (base 4L4'T8), 2014-2015	Restaurant Restaurant	34% 40%	34% 40%	5.3 6.7	7.6 7.6	5.0 4.5	1.0	12 12	5 6	1	0.20 0.22	1,005 1,105	0.26 0.24	0.32 0.29	27.02 29.69
1005	Lighting Control Tuneup (base 4L4'T8), 2014-2015	Restaurant	5%	3%	0.0	7.6	7.2	1.5	6	0	0	0.00	38	6.44	10.42	0.49
1007	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	Restaurant	21%	5%	1.0	7.6	6.0	1.4	10	0	0	0.06	1,280	0.58	0.92	8.33
1008	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	Restaurant	25%	20%	0.2	7.6	5.6	1.2	15	1	0	0.01	66	5.76	7.18	1.40
1010	Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	Restaurant	0%	0%	0.0	7.6	7.6	1.5	18 7	0	0	N/A	N/A	N/A	N/A	N/A
1011 1012	ROB 4L4' High Performance T8 (86 W), 2016-2017 ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	Restaurant Restaurant	10% 22%	10% 22%	0.1	7.6 7.6	6.8 5.9	1.3	7	3	0	0.02 0.02	79 124	1.95 1.25	2.76 1.76	2.12 3.32
1013	ROB 4L4'T5, 2016-2017	Restaurant	12%	12%	1.5	7.6	6.7	1.3	5	2	0	0.17	858	0.13	0.19	23.07
1014	ROB 4L4' LED Tube, 2016-2017	Restaurant	34%	34%	3.6	7.6	5.0	1.0	12	5	1	0.14	691	0.38	0.47	18.56
1015	LED Troffer (base 4L4'T8), 2016-2017	Restaurant	40%	40%	4.7	7.6	4.5	0.9	12	6	1	0.15	775	0.34	0.42	20.84
1016 1017	Lighting Control Tuneup (base 4L4'T8), 2016-2017	Restaurant Restaurant	5% 21%	3% 5%	0.0 1.0	7.6 7.6	7.2 6.0	1.5	6 10	0	0	0.00	38 1.280	6.44 0.58	10.42 0.92	0.49 8.33
1017	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	Restaurant		20%	0.2	7.6	5.6	1.4	15	1	0	0.01	66	5.76	7.18	1.40
1020	Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	Restaurant	0%	0%	0.0	7.6	7.6	1.5	18	0	0	N/A	N/A	N/A	N/A	N/A
1021	ROB 4L4' High Performance T8 (86 W), 2018-2019	Restaurant	10%	10%	0.1	7.6	6.8	1.3	7	2	0	0.02	79	1.95	2.76	2.12
1022 1023	ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	Restaurant Restaurant	22% 12%	22% 12%	0.4 1.5	7.6 7.6	5.9 6.7	1.2	7 5	3 2	1	0.02 0.17	124 858	1.25 0.13	1.76 0.19	3.32 23.07
1023	ROB 4L4'T5, 2018-2019 ROB 4L4' LED Tube, 2018-2019	Restaurant	12% 34%	12% 34%	3.3	7.6	5.0	1.3	5 12	5	1	0.17	858 621	0.13	0.19	16.70
1025	LED Troffer (base 4L4'T8), 2018-2019	Restaurant	40%	40%	4.3	7.6	4.5	0.9	12	6	1	0.14	703	0.37	0.46	18.89
1026	Lighting Control Tuneup (base 4L4'T8), 2018-2019	Restaurant	5%	3%	0.0	7.6	7.2	1.5	6	0	0	0.00	38	6.44	10.42	0.49
1027	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	Restaurant	21%	5%	1.0	7.6	6.0	1.4	10	0	0	0.06	1,280	0.58	0.92	8.33
1028	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Restaurant Restaurant	25%	20%	0.2	7.6 7.6	5.6 7.6	1.2	15 18	1	0	0.01 N/A	66 N/A	5.76 N/A	7.18 N/A	1.40 N/A
1030	ROB 4L4' High Performance T8 (86 W), 2020	Restaurant	10%	10%	0.1	7.6	6.8	1.3	7	2	0	0.02	79	1.95	2.76	2.12
1032	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Restaurant	22%	22%	0.4	7.6	5.9	1.2	7	3	1	0.02	124	1.25	1.76	3.32
1033	ROB 4L4'T5, 2020	Restaurant	12%	12%	1.5	7.6	6.7	1.3	5	2	0	0.17	858	0.13	0.19	23.07
1034	ROB 4L4' LED Tube, 2020	Restaurant	34%	34%	3.1	7.6	5.0	1.0	12	5	1	0.12	586	0.44	0.55	15.74
1035 1036	LED Troffer (base 4L4'T8), 2020 Lighting Control Tuneup (base 4L4'T8), 2020	Restaurant Restaurant	40% 5%	40% 3%	4.1 0.0	7.6 7.6	4.5 7.2	0.9 1.5	12 6	6 0	1	0.13	665 38	0.39 6.44	0.49 10.42	17.88 0.49
1030	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Restaurant	21%	5%	1.0	7.6	6.0	1.4	10	0	0	0.06	1,280	0.58	0.92	8.33
1038	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Restaurant	25%	20%	0.2	7.6	5.6	1.2	15	1	0	0.01	66	5.76	7.18	1.40
1100	Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	Restaurant	0%	0%	0.0	3.6	3.6	0.7	18	0	0	N/A	N/A	N/A	N/A	N/A
1101	ROB 2L4' High Performance T8 (86 W), 2014-2015	Restaurant	10%	10%	0.1	3.6	3.2	0.6	7	9	2	0.02	100	1.54	2.18	2.68
1102 1103	ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015 ROB 2L4'T5, 2014-2015	Restaurant Restaurant	22% 12%	22% 12%	0.2	3.6	2.8	0.6	7 5	19 10	4 2	0.03	156 984	0.99 0.11	1.39 0.17	4.20 26.45
1103	ROB 2L4 LED Tube, 2014-2015	Restaurant	34%	34%	2.1	3.6	2.4	0.5	12	9	2	0.19	852	0.11	0.17	22.91
1105	LED Troffer (base 2L4 ¹ T8), 2014-2015	Restaurant	40%	40%	3.1	3.6	2.2	0.4	12	35	7	0.21	1,060	0.25	0.31	28.49
1106	Lighting Control Tuneup (base 2L4'T8), 2014-2015	Restaurant	5%	3%	0.0	3.6	3.4	0.7	6	0	0	0.01	79	3.07	4.97	1.04
1107	Occupancy Sensor, 2L4 ¹ Fluorescent Fixtures, 2014-2015	Restaurant	21% 25%	5% 20%	0.8	3.6	2.9	0.7	10 15	1	0	0.11	2,269	0.33	0.52	14.76 2.92
1108 1110	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015 Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	Restaurant Restaurant	25% 0%	20%	0.2	3.6	2.7 3.6	0.6 0.7	15 18	7 0	1 0	0.02 N/A	137 N/A	2.76 N/A	3.44 N/A	2.92 N/A
1111	ROB 2L4' High Performance T8 (86 W), 2016-2017	Restaurant		10%	0.1	3.6	3.2	0.6	7	9	2	0.02	100	1.54	2.18	2.68
1112	ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	Restaurant	22%	22%	0.2	3.6	2.8	0.6	7	19	4	0.03	156	0.99	1.39	4.20
1113	ROB 2L4 ¹ T5, 2016-2017	Restaurant	12%	12%	0.8	3.6	3.2	0.6	5	10	2	0.19	984	0.11	0.17	26.45
1114 1115	ROB 2L4' LED Tube, 2016-2017 LED Troffer (base 2L4'T8), 2016-2017	Restaurant Restaurant	34% 40%	34% 40%	1.5 2.3	3.6 3.6	2.4	0.5	12 12	9 35	2 7	0.12 0.15	606 773	0.43	0.53	16.28 20.78
1115	Lighting Control Tuneup (base 2L4 T8), 2016-2017	Restaurant		3%	0.0	3.6	3.4	0.4	6	0	0	0.15	7/3	3.07	4.97	1.04

Comm	ercial Electric Existing Construction															
DSM ASSYS	T SUMMARY															
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1117	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	Restaurant		5%	0.8	3.6	2.9	0.7	10	1	0	0.11	2,269	0.33	0.52	14.76
1118 1120	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017 Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	Restaurant Restaurant	25% 0%	20%	0.2	3.6	2.7 3.6	0.6 0.7	15 18	7 0	1 0	0.02 N/A	137 N/A	2.76 N/A	3.44 N/A	2.92 N/A
1121	ROB 2L4' High Performance T8 (86 W), 2018-2019	Restaurant	10%	10%	0.0	3.6	3.2	0.6	7	9	2	0.02	100	1.54	2.18	2.68
1122	ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	Restaurant	22%	22%	0.2	3.6	2.8	0.6	7	19	4	0.03	156	0.99	1.39	4.20
1123	ROB 2L4 ⁺ T5, 2018-2019	Restaurant	12%	12%	0.8	3.6	3.2	0.6	5	10	2	0.19	984	0.11	0.17	26.45
1124 1125	ROB 2L4' LED Tube, 2018-2019	Restaurant	34% 40%	34% 40%	1.4 2.1	3.6	2.4	0.5	12 12	9	2 7	0.11 0.14	544 704	0.48 0.37	0.59 0.46	14.63 18.92
1125	LED Troffer (base 2L4'T8), 2018-2019 Lighting Control Tuneup (base 2L4'T8), 2018-2019	Restaurant Restaurant	40% 5%	40% 3%	0.0	3.6	3.4	0.4	6	35 0	0	0.14	704 79	3.07	4.97	18.92
1127	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	Restaurant	21%	5%	0.8	3.6	2.9	0.7	10	1	0	0.11	2,269	0.33	0.52	14.76
1128	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	Restaurant	25%	20%	0.2	3.6	2.7	0.6	15	7	1	0.02	137	2.76	3.44	2.92
1130	Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Restaurant	0%	0%	0.0	3.6	3.6	0.7	18	0	0	N/A	N/A	N/A	N/A	N/A
1131 1132	ROB 2L4' High Performance T8 (86 W), 2020 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Restaurant Restaurant	10% 22%	10% 22%	0.1	3.6	3.2 2.8	0.6	7 7	9 19	2	0.02	100 156	1.54 0.99	2.18 1.39	2.68 4.20
1133	ROB 2L4 LOW Watt right Performance 18 (73 W), 2020	Restaurant		12%	0.2	3.6	3.2	0.6	5	10	2	0.19	984	0.55	0.17	26.45
1134	ROB 2L4' LED Tube, 2020	Restaurant	34%	34%	1.3	3.6	2.4	0.5	12	9	2	0.10	513	0.51	0.63	13.78
1135	LED Troffer (base 2L4'T8), 2020	Restaurant	40%	40%	2.0	3.6	2.2	0.4	12	35	7	0.13	668	0.39	0.48	17.96
1136	Lighting Control Tuneup (base 2L4'T8), 2020	Restaurant	5%	3%	0.0	3.6	3.4	0.7	6	0	0	0.01	79	3.07	4.97	1.04
1137 1138	Occupancy Sensor, 2L4 ¹ Fluorescent Fixtures, 2020 High Performance Lighting R/R - 25% Savings (base 2L4 ¹ T8), 2020	Restaurant Restaurant	21% 25%	5% 20%	0.8	3.6	2.9	0.7	10 15	1 7	0	0.11	2,269 137	0.33 2.76	0.52 3.44	14.76 2.92
1200	Base Other Fluorescent Fixture	Restaurant	0%	0%	0.0	0.0	0.0	0.0	18	ó	0	N/A	N/A	N/A	N/A	N/A
1300	Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	Restaurant	0%	0%	0.1	3.6	3.6	0.7	1	0	0	N/A	N/A	N/A	N/A	N/A
1301	CFLs (base incandescent flood) 2014-2015	Restaurant	77%	77%	0.0	3.6	0.8	0.2	3	28	6	0.00	0	2,380.39	3,594.73	0.00
1302	LEDs (base incandescent flood) 2014-2015	Restaurant	83% 0%	83% 0%	0.1	4.4	0.8	0.1	6 1	58 0	11 0	0.00	7	18.82	27.09	0.19
1310 1311	Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017 CFLs (base incandescent flood) 2016-2017	Restaurant Restaurant	77%	77%	0.1	3.6	0.8	0.7	3	28	6	N/A 0.00	N/A 0	N/A 2.380.39	N/A 3.594.73	N/A 0.00
1312	LEDs (base incandescent flood) 2016-2017	Restaurant	83%	83%	0.0	4.4	0.8	0.1	6	58	11	0.00	0	6,141.55	8,842.08	0.00
1320	Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	Restaurant	0%	0%	0.1	3.6	3.6	0.7	1	0	0	N/A	N/A	N/A	N/A	N/A
1321	CFLs (base incandescent flood) 2018-2019	Restaurant	77%	77%	0.0	3.6	0.8	0.2	3	28	6	0.00	0	2,380.39	3,594.73	0.00
1322 1330	LEDs (base incandescent flood) 2018-2019 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Restaurant Restaurant	83% 0%	83% 0%	0.0	4.4 3.6	0.8	0.1	6 1	58 0	11 0	0.00 N/A	0 N/A	6,141.55 N/A	8,842.08 N/A	0.00 N/A
1331	CFLs (base incandescent flood) 2020	Restaurant	77%	77%	0.0	3.6	0.8	0.7	3	28	6	0.00	0	2,380.39	3,594.73	0.00
1332	LEDs (base incandescent flood) 2020	Restaurant		83%	0.0	4.4	0.8	0.1	6	58	11	0.00	0	6,141.55	8,842.08	0.00
1400	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	Restaurant	0%	0%	0.1	2.6	2.6	0.5	1	0	0	N/A	N/A	N/A	N/A	N/A
1401	CFLs (base incandescent A-line 72W) 2014-2015	Restaurant	74%	74%	0.0	2.6	0.7	0.1	3	10	2	0.00	0	1,638.20	2,473.92	0.00
1402 1410	LEDs (base incandescent A-line 72W) 2014-2015 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	Restaurant Restaurant	82% 0%	82% 0%	0.1	3.2 2.6	0.6 2.6	0.1	6 1	20	4 0	0.00 N/A	10 N/A	13.24 N/A	19.07 N/A	0.27 N/A
1411	CFLs (base incandescent A-line 72W) 2016-2017	Restaurant	74%	74%	0.0	2.6	0.7	0.1	3	10	2	0.00	0	1,638.20	2,473.92	0.00
1412	LEDs (base incandescent A-line 72W) 2016-2017	Restaurant	82%	82%	0.0	3.2	0.6	0.1	6	20	4	0.00	0	4,322.55	6,223.24	0.00
1420	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	Restaurant	0%	0%	0.1	2.6	2.6	0.5	1	0	0	N/A	N/A	N/A	N/A	N/A
1421 1422	CFLs (base incandescent A-line 72W) 2018-2019	Restaurant	74% 82%	74% 82%	0.0	2.6	0.7	0.1	3 6	10 20	2	0.00	0	1,638.20	2,473.92	0.00
1422	LEDs (base incandescent A-line 72W) 2018-2019 Base Incandescent A-line Lamp, 72W to Screw-in Replacement 2020	Restaurant Restaurant	82% 0%	82% 0%	0.0	2.6	2.6	0.1	1	0	0	0.00 N/A	N/A	4,322.55 N/A	6,223.24 N/A	0.00 N/A
1431	CFLs (base incandescent A-line 72W) 2020	Restaurant	74%	74%	0.0	2.6	0.7	0.1	3	10	2	0.00	0	1,638.20	2,473.92	0.00
1432	LEDs (base incandescent A-line 72W) 2020	Restaurant	82%	82%	0.0	3.2	0.6	0.1	6	20	4	0.00	0	4,322.55	6,223.24	0.00
1500	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	Restaurant	0%	0%	0.1	1.9	1.9	0.4	1	0	0	N/A	N/A	N/A	N/A	N/A
1501 1502	CFLs (base incandescent A-line 53W) 2014-2015 LEDs (base incandescent A-line 53W) 2014-2015	Restaurant Restaurant	66% 75%	66% 75%	0.0	1.9 2.3	0.6	0.1	3 6	6 13	1	0.00	0 15	1,081.38 8.73	1,633.03 12.57	0.00 0.41
1510	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	Restaurant	0%	0%	0.1	1.9	1.9	0.1	1	0	0	N/A	N/A	N/A	N/A	N/A
1511	CFLs (base incandescent A-line 53W) 2016-2017	Restaurant	66%	66%	0.0	1.9	0.6	0.1	3	6	1	0.00	0	1,081.38	1,633.03	0.00
1512	LEDs (base incandescent A-line 53W) 2016-2017	Restaurant	75%	75%	0.0	2.3	0.6	0.1	6	13	3	0.00	0	2,849.02	4,101.78	0.00
1520	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	Restaurant	0%	0%	0.1	1.9	1.9	0.4	1	0	0	N/A	N/A	N/A	N/A	N/A
1521 1522	CFLs (base incandescent A-line 53W) 2018-2019 LEDs (base incandescent A-line 53W) 2018-2019	Restaurant Restaurant	66% 75%	66% 75%	0.0	1.9 2.3	0.6	0.1	3 6	6 13	1	0.00	0	1,081.38 2,849.02	1,633.03 4,101.78	0.00
1530	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Restaurant	0%	0%	0.0	1.9	1.9	0.1	1	0	0	N/A	N/A	N/A	4,101.76 N/A	N/A
1531	CFLs (base incandescent A-line 53W) 2020	Restaurant	66%	66%	0.0	1.9	0.6	0.1	3	6	1	0.00	Ó	1,081.38	1,633.03	0.00
1532	LEDs (base incandescent A-line 53W) 2020	Restaurant	75%	75%	0.0	2.3	0.6	0.1	6	13	3	0.00	0	2,849.02	4,101.78	0.00
1600	Base CFL 18W to screw-in replacement 2014-2015	Restaurant	0% 28%	0%	0.2	0.9	0.9	0.2	3	0	0	N/A	N/A 790	N/A	N/A	N/A
1601 1610	LED screw-in replacement (base CFL 18W) 2014-2015 Base CFL 18W to screw-in replacement 2016-2017	Restaurant Restaurant		28% 0%	0.4	0.9	0.7	0.1	6 3	3	1	0.16 N/A	790 N/A	0.17 N/A	0.24 N/A	21.24 N/A
1611	LED screw-in replacement (base CFL 18W) 2016-2017	Restaurant	28%	28%	0.2	0.9	0.7	0.2	6	3	1	0.08	411	0.32	0.47	11.06
1620	Base CFL 18W to screw-in replacement 2018-2019	Restaurant	0%	0%	0.2	0.9	0.9	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1621	LED screw-in replacement (base CFL 18W) 2018-2019	Restaurant		28%	0.2	0.9	0.7	0.1	6	3	1	0.06	328	0.41	0.58	8.82
1630	Base CFL 18W to screw-in replacement 2020	Restaurant	0% 28%	0% 28%	0.2	0.9	0.9	0.2	3	0	0	N/A 0.06	N/A 285	N/A 0.47	N/A 0.67	N/A 7.67
1631 1700	LED screw-in replacement (base CFL 18W) 2020 Base CFL 23W to screw-in replacement 2014-2015	Restaurant Restaurant	28% 0%	28% 0%	0.1	0.9 1.2	0.7 1.2	0.1	6	3	1	0.06 N/A	285 N/A	0.47 N/A	0.67 N/A	7.67 N/A
1700	LED screw-in replacement (base CFL 23W) 2014-2015	Restaurant		26%	0.4	1.2	0.9	0.2	6	4	1	0.13	659	0.20	0.29	17.71
1710	Base CFL 23W to screw-in replacement 2016-2017	Restaurant	0%	0%	0.2	1.2	1.2	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1711	LED screw-in replacement (base CFL 23W) 2016-2017	Restaurant		26%	0.2	1.2	0.9	0.2	6	4	1	0.07	343	0.39	0.56	9.22
1720	Base CFL 23W to screw-in replacement 2018-2019	Restaurant	0%	0%	0.2	1.2	1.2	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A

Comme	rcial Electric Existing Construction															
DSM ASSYST	SUMMARY										System	Levelized Cost	Levelized Cost	Total		
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1721	LED screw-in replacement (base CFL 23W) 2018-2019	Restaurant	26%	26%	0.2	1.2	0.9	0.2	6	4	1	0.05	274	0.49	0.70	7.35
1730	Base CFL 23W to screw-in replacement 2020	Restaurant	0%	0%	0.2	1.2	1.2	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1731 1800	LED screw-in replacement (base CFL 23W) 2020 BaseMetal Halide, 465W	Restaurant Restaurant	26%	26%	0.1	1.2 0.1	0.9	0.2	6 18	4	1 0	0.05 N/A	238 N/A	0.56 N/A	0.81 N/A	6.39 N/A
1800	T5 (240W) (base metal halide)	Restaurant		48%	0.0	0.1	0.1	0.0	18	0	0	N/A 0.01	N/A 73	N/A 5.02	N/A 5.67	N/A 1.96
1802	Induction High Bay Lighting	Restaurant		37%	0.1	0.1	0.1	0.0	20	0	0	0.10	515	0.77	0.85	13.83
1803	PSMH + electronic ballast	Restaurant	43%	43%	0.0	0.1	0.1	0.0	16	0	0	0.03	167	1.99	2.32	4.50
1804	PSMH, magnetic ballast, 320 W	Restaurant	31%	31%	0.0	0.1	0.1	0.0	0	0	0	0.06	310	0.07	0.12	8.34
1805	High Performance Lighting R/R - 25% Savings (base metal halide)	Restaurant		20%	0.2	0.1	0.1	0.0	15	0	0	0.59	3,751	0.10	0.13	79.94
1806	Occupancy Sensor, High Bay T5	Restaurant		5%	0.0	0.1	0.1	0.0	10	0	0	0.02	373	1.98	3.15	2.43
1850 1851	Base CFL Exit Sign LED Exit Sign	Restaurant Restaurant		0% 69%	0.0	0.0	0.0	0.0	18 7	0	0	N/A 0.03	N/A 150	N/A 1.03	N/A 1.45	N/A 4.02
1900	Base Outdoor High Pressure Sodium 250W Lamp	Restaurant	09%	09%	0.0	1.7	1.7	0.0	15	0	0	0.03 N/A	N/A	N/A	N/A	N/A
1901	Outdoor Lighting Controls (Photocell/Timeclock)	Restaurant	25%	73%	0.3	1.9	1.4	0.0	18	17	3	0.06	325	1.20	1.27	8.74
1902	LED Outdoor Area Lighting	Restaurant	52%	52%	1.1	1.7	0.8	0.1	18	53	4	0.12	1,879	0.49	0.66	16.95
1903	Bi-Level LED Outdoor Lighting	Restaurant		63%	3.6	1.7	0.5	0.0	18	57	3	0.30	4,998	0.20	0.27	40.77
2000	Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Restaurant	0%	0%	0.7	6.1	6.1	3.8	20	0	0	N/A	N/A	N/A	N/A	N/A
2001 2003	Centrifugal Chiller, 0.51 kW/ton, 500 tons EMS - Chiller	Restaurant	12% 10%	12% 3%	0.2	6.3	5.6 5.6	3.5 3.8	20	7	5 1	0.02	33 182	5.40 2.07	4.16 2.65	2.83 3.79
2003	Chiller Tune Up/Diagnostics	Restaurant Restaurant	8%	3% 4%	0.2	6.2	6.1	4.0	15 10	0	0	0.03	30	4.92	6.03	1.27
2010	Ceiling/roof Insulation - Chiller	Restaurant	12%	12%	0.1	6.4	5.6	3.5	20	6	4	0.02	24	7.41	5.71	2.06
2012	Duct Testing/Sealing - Chiller	Restaurant	19%	19%	1.0	6.2	5.0	3.1	18	15	9	0.08	135	1.22	0.97	11.51
2100	Base DX Packaged System, EER=10.3, 10 tons	Restaurant	0%	0%	2.0	6.1	6.1	3.8	15	0	0	N/A	N/A	N/A	N/A	N/A
2101	DX Packaged System, EER=10.9, 10 tons	Restaurant	6%	6%	0.2	6.1	5.7	3.6	15	25	15	0.05	77	1.84	1.53	6.54
2102	DX Packaged System, EER=13.4, 10 tons	Restaurant	23%	23%	0.2	6.1	4.7	2.9	15	103	65	0.02	25	5.66	4.72	2.12
2103	Geothermal Heat Pump, EER=13, 10 tons - DX	Restaurant		21% 3%	2.4	6.1	4.8	3.0	15 10	5	3	0.19	296 100	0.48	0.40	25.24
2105 2106	DX Tune Up/ Advanced Diagnostics Prog. Thermostat - DX	Restaurant Restaurant	5% 5%	3% 1%	0.1	6.4	6.1 5.9	3.9 3.9	8	1 10	2	0.03	168	1.49 1.24	1.83 1.85	4.19 3.50
2100	Cool Roof - DX	Restaurant	7%	7%	0.1	6.1	5.7	3.6	10	14	9	0.05	92	1.01	0.97	7.87
2108	Optimize Controls - DX	Restaurant		1%	0.0	6.3	6.0	3.9	5	8	1	0.01	79	1.68	2.67	1.66
2109	Economizer - DX	Restaurant		3%	0.5	6.6	5.8	4.0	10	9	1	0.06	400	0.65	0.92	8.34
2110	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Restaurant	3%	1%	0.1	6.2	6.0	3.8	10	0	0	0.06	402	0.65	0.91	8.38
2111	Economizer Repair - DX	Restaurant		18%	0.2	6.3	5.6	3.2	5	21	19	0.03	33	1.09	1.06	4.16
2112	Duct Testing/Sealing - DX	Restaurant		19% 12%	1.0	6.2	5.0	3.1	18 20	25	16 0	0.08	135 22	1.22 7.99	0.97	11.51
2113 2114	Ceiling/roof Insulation - DX Duct/Pipe Insulation - DX	Restaurant Restaurant	2%	12% 2%	0.1	6.9 6.1	6.1	3.8 3.7	20 10	0	3	0.01	985	0.09	6.15 0.09	1.91 83.96
2114	Window Film (Standard) - DX	Restaurant		10%	0.8	6.1	5.5	3.4	10	33	20	0.02	18	5.10	4.91	1.56
2200	Base Heat Pump (13 SEER, 7.7 HSPF)	Restaurant	0%	0%	0.0	6.1	6.1	3.8	15	0	0	N/A	N/A	N/A	N/A	N/A
2201	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	13%	13%	0.1	6.1	5.3	3.3	15	17	11	0.01	18	7.93	6.61	1.52
2300	Base PTAC, EER=8.3, 1 ton	Restaurant	0%	0%	0.0	6.1	6.1	3.8	15	0	0	N/A	N/A	N/A	N/A	N/A
3000	Base Fan Motor, 5hp, 1800rpm, 87.5%	Restaurant		0%	0.1	3.1	3.1	0.8	20	0	0	N/A	N/A	N/A	N/A	N/A
3001	Fan Motor, 5hp, 1800rpm, 89.5%	Restaurant	2%	2%	0.1	3.1	3.1	8.0	20	3	1	0.11	432	0.74	0.78	15.16
3002 3003	Variable Speed Drive Control, 5 HP Demand Controlled Ventilation	Restaurant Restaurant		8% 29%	0.7 2.4	3.1	2.2	0.7	15 15	45 20	3 10	0.07 0.51	1,133 1,009	0.73 0.16	1.02 0.14	9.82 69.20
3100	Base Fan Motor, 15hp, 1800rpm, 91.0%	Restaurant		0%	0.0	3.1	3.1	0.8	20	0	0	N/A	N/A	N/A	N/A	N/A
3200	Base Fan Motor, 40hp, 1800rpm, 93.0%	Restaurant		0%	0.0	3.1	3.1	0.8	20	0	0	N/A	N/A	N/A	N/A	N/A
4000	Base Built-Up Refrigeration System	Restaurant	0%	0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
4100	Base Self-Contained Refrigeration	Restaurant	0%	0%	0.0	7.3	7.3	1.1	10	0	0	N/A	N/A	N/A	N/A	N/A
4101	Strip curtains for walk-ins (self-contained)	Restaurant	1%	1%	0.1	7.3	7.3	1.1	4	2	0	0.11	733	0.15	0.24	14.94
4103	Night covers for display cases (self-contained)	Restaurant	9%	9%	0.0	7.3	6.7	1.0	5	29	4	0.00	11	13.26	20.50	0.22
4104 4105	Freezer-Cooler Replacement Gaskets (self-contained) Bi-level LED Case Lighting (self-contained units) 2014	Restaurant Restaurant	3% 0%	3% 0%	0.0	7.4 7.3	7.2 7.3	1.1	4	9	1	0.00	13 1,138	8.71 0.19	13.76 0.28	0.27 23.20
4105	Energy-Star Refrigerator, solid door	Restaurant	3%	3%	0.0	7.4	7.1	1.1	10	10	2	0.17	1,138	2.51	3.47	2.20
4107	Energy-Star Freezer, solid door	Restaurant	1%	1%	0.0	7.3	7.2	1.1	9	4	1	0.01	78	3.12	4.43	1.60
4108	Energy-Star Refrigerator, glass door	Restaurant	2%	2%	0.0	7.3	7.2	1.1	10	5	1	0.02	106	2.56	3.54	2.16
4109	Energy-Star Freezer, glass door	Restaurant	3%	3%	0.0	7.4	7.1	1.1	9	10	2	0.00	32	7.62	10.83	0.65
4110	Energy Star Ice Machines	Restaurant	2%	2%	0.1	7.4	7.2	1.1	10	10	1	0.04	292	0.93	1.29	5.96
4112	Reach-in unit occupancy sensors	Restaurant	0%	0%	0.0	7.3	7.3	1.1	10	0	0	0.17	1,169	0.23	0.32	23.83
5000 5001	Base Desktop PC	Restaurant	0% 66%	0% 34%	0.0	0.1	0.1	0.0	4	0	0	N/A 0.01	N/A 62	N/A 2.61	N/A 4.33	N/A 0.84
5001	PC Network Power Management Enabling Energy Star or Better PC	Restaurant Restaurant		34%	0.0	0.1	0.0	0.0	4	2	0	0.01	38	2.61	4.33 3.59	1.01
5100	Base Laptop PC	Restaurant	0%	0%	0.0	0.0	0.0	0.0	4	0	0	N/A	N/A	N/A	3.59 N/A	N/A
5101	Laptop Network Power Management Enabling	Restaurant	7%	7%	0.0	0.0	0.0	0.0	4	0	0	0.47	2,411	0.04	0.06	64.06
5102	Energy Star or Better Laptop	Restaurant	30%	30%	0.0	0.0	0.0	0.0	4	0	0	0.00	25	3.69	5.54	0.66
5200	Base Monitor, CRT	Restaurant	0%	0%	0.0	0.1	0.1	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5201	Energy Star or Better Monitor - CRT	Restaurant		56%	0.0	0.1	0.0	0.0	4	2	0	0.00	3	29.38	44.05	0.08
5202	Monitor Power Management Enabling - CRT	Restaurant		27%	0.0	0.1	0.0	0.0	4	1	0	0.00	37	4.35	7.21	0.51
5203 5300	Plug-load controls - Commercial Smart Strip (base Monitor CRT) Base Monitor, LCD	Restaurant Restaurant	15% 0%	15% 0%	0.0	0.1	0.1	0.0	4	0	0	0.03 N/A	167 N/A	0.55 N/A	0.82 N/A	4.44 N/A
5300	Energy Star or Better Monitor - LCD	Restaurant		21%	0.0	0.0	0.0	0.0	4	0	0	0.00	22	4.20	6.30	0.58
3301	Energy star or setter monitor Les	nestadiant	2270	21/0	0.0	0.0	0.0	0.0	-			0.00			0.50	0.50

Comme	rcial Electric Existing Construction															
DSM ASSYST	SUMMARY										System	Levelized Cost	Levelized Cost	Total		
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy \$/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
5302	Monitor Power Management Enabling - LCD	Restaurant	19%	10%	0.0	0.0	0.0	0.0	4	0	0	0.03	339	0.48	0.79	4.61
5303	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Restaurant	14%	4%	0.0	0.0	0.0	0.0	4	0	0	0.09	1,722	0.17	0.31	11.86
5400 5401	Base Copier Energy Star or Better Copier	Restaurant Restaurant	0% 21%	0% 21%	0.0	0.1	0.1	0.0	6	0	0	N/A 0.00	N/A 6	N/A 21.61	N/A 31.17	N/A 0.17
5402	Copier Power Management Enabling	Restaurant		10%	0.0	0.1	0.0	0.0	6	0	0	0.06	586	0.41	0.65	7.97
5500	Base Multifunction	Restaurant	0%	0%	0.0	0.0	0.0	0.0	5	0	0	N/A	N/A	N/A	N/A	N/A
5501	Multifunction Power Management Enabling	Restaurant	48%	25%	0.0	0.0	0.0	0.0	5	0	0	0.17	1,664	0.12	0.20	22.60
5502 5600	ENERGY STAR Multi-Function Printer Base Printer	Restaurant Restaurant	40% 0%	40% 0%	0.0	0.0	0.0	0.0	5 5	0	0	0.00 N/A	18 N/A	6.22 N/A	9.15 N/A	0.48 N/A
5601	Printer Power Management Enabling	Restaurant	48%	25%	0.0	0.0	0.0	0.0	5	0	0	0.03	315	0.64	1.03	4.28
5602	ENERGY STAR Printer	Restaurant	40%	40%	0.0	0.0	0.0	0.0	5	0	0	0.00	4	28.59	42.06	0.11
5700	Base Data Center/Server Room	Restaurant	0%	0%	0.0	110.1		21.5	10	0	0	N/A	N/A	N/A	N/A	N/A
5701 5702	Data Center Improved Operations Data Center Best Practices	Restaurant Restaurant	20% 45%	20% 45%	0.1	114.6 115.2		17.9 12.4	10 10	1	0	0.00	2 5	100.89 45.64	131.90 59.67	0.06 0.13
5703	Data Center State of the Art practices	Restaurant	56%	56%	1.0	110.1	48.4	9.4	10	0	0	0.00	8	27.12	35.46	0.22
6000	Base Water Heating	Restaurant	0%	0%	0.0	1.6	1.6	0.3	15	0	0	N/A	N/A	N/A	N/A	N/A
6001	Demand controlled circulating systems	Restaurant	5%	5%	0.0	1.6	1.6	0.3	15	2	0	0.05	317	1.14	1.38	7.27
6002 6003	High Efficiency Water Heater (electric) Hot Water Pipe Insulation	Restaurant Restaurant	2% 2%	2% 2%	0.0	1.6 1.6	1.6 1.6	0.3	15 15	1	0	0.01	63 102	5.75 3.52	6.96 4.26	1.44 2.35
6003	Tankless Water Heater	Restaurant	10%	10%	0.0	1.6	1.5	0.3	20	5	1	0.02	102	4.18	4.26	2.33
6005	Heat Pump Water Heater (air source)	Restaurant	20%	20%	0.1	1.6	1.3	0.2	10	10	2	0.02	144	1.73	2.31	3.31
6006	Heat Recovery Unit	Restaurant	65%	65%	0.1	1.6	0.6	0.1	10	32	5	0.01	43	5.74	7.66	1.00
6007	Heat Trap	Restaurant	9%	9%	0.0	1.7	1.5	0.3	10	3	1	0.00	25	10.16	13.57	0.56
6008 7000	Solar Water Heater Base Refrigerated Vending Machines	Restaurant Restaurant	70% 0%	70% 0%	0.2	1.6	0.5	0.1	20 10	9	1	0.02 N/A	116 N/A	3.87 N/A	4.40 N/A	2.67 N/A
7001	Vending Misers (Refrigerated units)	Restaurant	46%	23%	0.0	0.0	0.0	0.0	5	1	0	0.01	105	1.94	3.17	1.40
7002	Vending Misers (Refrigerated glass-front units)	Restaurant	30%	15%	0.0	0.0	0.0	0.0	5	0	0	0.02	160	1.27	2.06	2.14
7100	Base Non-Refrigerated Vending Machines	Restaurant	0%	0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
7101 7200	Vending Misers (Non-Refrigerated) Base Oven	Restaurant Restaurant	46% 0%	23% 0%	0.0	0.0	0.0	0.0	5 10	0	0	0.17 N/A	1,753 N/A	0.12 N/A	0.19 N/A	23.42 N/A
7200	Convection Oven	Restaurant		23%	0.0	2.0	1.5	0.4	10	7	1	0.10	N/A 494	0.51	0.63	13.79
7300	Base Fryer	Restaurant	0%	0%	0.0	2.0	2.0	0.4	10	0	0	N/A	N/A	N/A	N/A	N/A
7301	Efficient Fryer	Restaurant	6%	6%	0.4	2.0	1.8	0.4	12	2	0	0.33	1,604	0.16	0.19	44.78
7400 7401	Base Steamer Efficient Steamer	Restaurant	0% 69%	0% 69%	0.0	3.1	3.1 0.9	0.6	10 12	0 32	0	N/A 0.05	N/A 226	N/A 1.12	N/A 1.38	N/A 6.31
7401 8000	Base Heating, Heat Pump (7.7 HSPF)	Restaurant Restaurant	0%	0%	0.0	0.3	0.9	0.2	12	32 0	6 0	0.05 N/A	226 N/A	1.12 N/A	1.38 N/A	6.31 N/A
8001	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	6%	6%	0.0	0.3	0.2	0.0	15	0	0	0.04	N/A	1.13	1.66	6.05
8100	Base Heating, Other Electric	Restaurant	0%	0%	12.0	0.3	0.3	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
9500	Base Miscellaneous	Restaurant	0%	0%	1.3	2.7	2.7	0.5	10	0	0	N/A	N/A	N/A	N/A	N/A
9501 1000	Xmisc Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	Restaurant Restaurant	0% 0%	0% 0%	1.3 0.0	2.7 7.6	2.7 7.6	0.5 1.5	10 18	0	0	N/A N/A	N/A N/A	0.00 N/A	0.00 N/A	N/A N/A
1001	ROB 4L4' High Performance T8 (86 W), 2014-2015	Restaurant	10%	10%	0.1	7.6	6.8	1.3	7	0	0	0.02	79	1.95	2.76	2.12
1002	ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	Restaurant	22%	22%	0.4	7.6	5.9	1.2	7	0	0	0.02	124	1.25	1.76	3.32
1003	ROB 4L4'T5, 2014-2015	Restaurant	12%	12%	1.5	7.6	6.7	1.3	5	0	0	0.17	858	0.13	0.19	23.07
1004 1005	ROB 4L4' LED Tube, 2014-2015 LED Troffer (base 4L4'T8), 2014-2015	Restaurant Restaurant	34% 40%	34% 40%	5.3 6.7	7.6 7.6	5.0 4.5	1.0 0.9	12 12	0	0	0.20	1,005 1.105	0.26 0.24	0.32 0.29	27.02 29.69
1006	Lighting Control Tuneup (base 4L4'T8), 2014-2015	Restaurant	5%	3%	0.0	7.6	7.2	1.5	6	0	0	0.00	38	6.44	10.42	0.49
1007	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	Restaurant	21%	5%	1.0	7.6	6.0	1.4	10	0	0	0.06	1,283	0.58	0.92	8.35
1008	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	Restaurant	25%	20%	0.2	7.6	5.6	1.2	15	0	0	0.01	66	5.76	7.18	1.40
1010 1011	Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017 ROB 4L4' High Performance T8 (86 W), 2016-2017	Restaurant Restaurant	0% 10%	0% 10%	0.0	7.6 7.6	7.6 6.8	1.5 1.3	18 7	0	0	N/A 0.02	N/A 79	N/A 1.95	N/A 2.76	N/A 2.12
1011	ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	Restaurant	22%	22%	0.1	7.6	5.9	1.2	7	0	0	0.02	124	1.25	1.76	3.32
1013	ROB 4L4'T5, 2016-2017	Restaurant	12%	12%	1.5	7.6	6.7	1.3	5	0	0	0.17	858	0.13	0.19	23.07
1014	ROB 4L4' LED Tube, 2016-2017	Restaurant	34%	34%	3.6	7.6	5.0	1.0	12	0	0	0.14	691	0.38	0.47	18.56
1015	LED Troffer (base 4L4'T8), 2016-2017	Restaurant	40% 5%	40% 3%	4.7 0.0	7.6 7.6	4.5	0.9 1.5	12 6	0	0	0.15	775 38	0.34	0.42 10.42	20.84
1016 1017	Lighting Control Tuneup (base 4L4'T8), 2016-2017 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	Restaurant Restaurant	5% 21%	5% 5%	1.0	7.6	7.2 6.0	1.5	10	0	0	0.00	1.283	6.44 0.58	0.92	0.49 8.35
1018	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017	Restaurant	25%	20%	0.2	7.6	5.6	1.2	15	0	0	0.01	66	5.76	7.18	1.40
1020	Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	Restaurant	0%	0%	0.0	7.6	7.6	1.5	18	0	0	N/A	N/A	N/A	N/A	N/A
1021	ROB 4L4' High Performance T8 (86 W), 2018-2019	Restaurant		10%	0.1	7.6	6.8	1.3	7	0	0	0.02	79	1.95	2.76	2.12
1022 1023	ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019 ROB 4L4'T5, 2018-2019	Restaurant Restaurant	22% 12%	22% 12%	0.4 1.5	7.6 7.6	5.9 6.7	1.2	7 5	0	0	0.02 0.17	124 858	1.25 0.13	1.76 0.19	3.32 23.07
1023	ROB 4L4 15, 2018-2019 ROB 4L4' LED Tube, 2018-2019	Restaurant	34%	34%	3.3	7.6	5.0	1.0	12	0	0	0.17	621	0.13	0.19	16.70
1025	LED Troffer (base 4L4'T8), 2018-2019	Restaurant	40%	40%	4.3	7.6	4.5	0.9	12	0	0	0.14	703	0.37	0.46	18.89
1026	Lighting Control Tuneup (base 4L4'T8), 2018-2019	Restaurant	5%	3%	0.0	7.6	7.2	1.5	6	0	0	0.00	38	6.44	10.42	0.49
1027 1028	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	Restaurant Restaurant	21% 25%	5% 20%	1.0 0.2	7.6 7.6	6.0 5.6	1.4	10 15	0	0	0.06 0.01	1,283 66	0.58 5.76	0.92 7.18	8.35 1.40
1028	High Performance Lighting K/K - 25% Savings (base 4L4 18), 2018-2019 Base Fluorescent Fixture, 4L4 T8, 1EB, 2020	Restaurant	25% 0%	20%	0.2	7.6	7.6	1.5	18	0	0	0.01 N/A	N/A	5.76 N/A	7.18 N/A	1.40 N/A
1031	ROB 4L4' High Performance T8 (86 W), 2020	Restaurant	10%	10%	0.1	7.6	6.8	1.3	7	0	0	0.02	79	1.95	2.76	2.12
1032	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Restaurant	22%	22%	0.4	7.6	5.9	1.2	7	0	0	0.02	124	1.25	1.76	3.32

Comm	ercial Electric Existing Construction															
DSM ASSYS	T SUMMARY															
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1033	ROB 4L4'T5, 2020	Restaurant		12%	1.5	7.6	6.7	1.3	5	0	0	0.17	858	0.13	0.19	23.07
1034	ROB 4L4' LED Tube, 2020	Restaurant	34%	34%	3.1	7.6	5.0	1.0	12	0	0	0.12	586	0.44	0.55	15.74
1035	LED Troffer (base 4L4'T8), 2020	Restaurant	40%	40%	4.1	7.6	4.5	0.9	12	0	0	0.13	665	0.39	0.49	17.88
1036 1037	Lighting Control Tuneup (base 4L4'T8), 2020 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Restaurant Restaurant	5% 21%	3% 5%	0.0 1.0	7.6 7.6	7.2 6.0	1.5	6 10	0	0	0.00	38 1,283	6.44 0.58	10.42 0.92	0.49 8.35
1037	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Restaurant		20%	0.2	7.6	5.6	1.2	15	0	0	0.01	66	5.76	7.18	1.40
1100	Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	Restaurant	0%	0%	0.0	3.6	3.6	0.7	18	0	0	N/A	N/A	N/A	N/A	N/A
1101	ROB 2L4' High Performance T8 (86 W), 2014-2015	Restaurant		10%	0.1	3.6	3.2	0.6	7	0	0	0.02	100	1.54	2.18	2.68
1102	ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	Restaurant	22%	22%	0.2	3.6	2.8	0.6	7	1	0	0.03	156	0.99	1.39	4.20
1103 1104	ROB 2L4'T5, 2014-2015 ROB 2L4' LED Tube, 2014-2015	Restaurant Restaurant	12% 34%	12% 34%	0.8	3.6	3.2 2.4	0.6	5 12	1	0	0.19	984 852	0.11 0.31	0.17 0.38	26.45 22.91
1104	LED Troffer (base 2L4'T8), 2014-2015	Restaurant	40%	40%	3.1	3.6	2.4	0.3	12	2	0	0.21	1.060	0.25	0.30	28.49
1106	Lighting Control Tuneup (base 2L4'T8), 2014-2015	Restaurant	5%	3%	0.0	3.6	3.4	0.7	6	0	0	0.01	79	3.07	4.97	1.04
1107	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	Restaurant	21%	5%	0.8	3.6	2.9	0.7	10	0	0	0.11	2,274	0.32	0.52	14.79
1108	High Performance Lighting R/R - 25% Savings (base 2L4 ^t T8), 2014-2015	Restaurant	25%	20%	0.2	3.6	2.7	0.6	15	0	0	0.02	137	2.76	3.44	2.92
1110	Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017	Restaurant	0%	0%	0.0	3.6	3.6	0.7	18	0	0	N/A	N/A	N/A	N/A	N/A
1111 1112	ROB 2L4' High Performance T8 (86 W), 2016-2017 ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	Restaurant Restaurant	10% 22%	10% 22%	0.1	3.6 3.6	3.2 2.8	0.6	7 7	1	0	0.02	100 156	1.54 0.99	2.18 1.39	2.68 4.20
1113	ROB 2L4 T5, 2016-2017	Restaurant	12%	12%	0.8	3.6	3.2	0.6	5	1	0	0.19	984	0.11	0.17	26.45
1114	ROB 2L4' LED Tube, 2016-2017	Restaurant	34%	34%	1.5	3.6	2.4	0.5	12	0	0	0.12	606	0.43	0.53	16.28
1115	LED Troffer (base 2L4'T8), 2016-2017	Restaurant	40%	40%	2.3	3.6	2.2	0.4	12	2	0	0.15	773	0.34	0.42	20.78
1116	Lighting Control Tuneup (base 2L4'T8), 2016-2017	Restaurant	5%	3%	0.0	3.6	3.4	0.7	6	0	0	0.01	79	3.07	4.97	1.04
1117 1118	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	Restaurant Restaurant	21% 25%	5% 20%	0.8	3.6	2.9	0.7	10 15	0	0	0.11	2,274 137	0.32 2.76	0.52 3.44	14.79 2.92
1120	Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	Restaurant	0%	0%	0.0	3.6	3.6	0.7	18	0	0	N/A	N/A	N/A	N/A	N/A
1121	ROB 2L4' High Performance T8 (86 W), 2018-2019	Restaurant	10%	10%	0.1	3.6	3.2	0.6	7	0	0	0.02	100	1.54	2.18	2.68
1122	ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019	Restaurant	22%	22%	0.2	3.6	2.8	0.6	7	1	0	0.03	156	0.99	1.39	4.20
1123	ROB 2L4'T5, 2018-2019	Restaurant	12%	12%	0.8	3.6	3.2	0.6	5	1	0	0.19	984	0.11	0.17	26.45
1124	ROB 2L4' LED Tube, 2018-2019	Restaurant	34%	34%	1.4	3.6	2.4	0.5	12	0	0	0.11	544	0.48	0.59	14.63
1125 1126	LED Troffer (base 2L4'T8), 2018-2019 Lighting Control Tuneup (base 2L4'T8), 2018-2019	Restaurant Restaurant	40% 5%	40% 3%	2.1 0.0	3.6	2.2 3.4	0.4	12 6	2	0	0.14	704 79	0.37 3.07	0.46 4.97	18.92 1.04
1127	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019	Restaurant	21%	5%	0.8	3.6	2.9	0.7	10	0	0	0.11	2,274	0.32	0.52	14.79
1128	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	Restaurant	25%	20%	0.2	3.6	2.7	0.6	15	0	0	0.02	137	2.76	3.44	2.92
1130	Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Restaurant	0%	0%	0.0	3.6	3.6	0.7	18	0	0	N/A	N/A	N/A	N/A	N/A
1131	ROB 2L4' High Performance T8 (86 W), 2020	Restaurant		10%	0.1	3.6	3.2	0.6	7	0	0	0.02	100	1.54	2.18	2.68
1132 1133	ROB 2L4' Low Watt High Performance T8 (75 W), 2020 ROB 2L4'T5, 2020	Restaurant Restaurant		22% 12%	0.2	3.6	2.8	0.6	5	1	0	0.03	156 984	0.99 0.11	1.39 0.17	4.20 26.45
1134	ROB 2L4 LED Tube, 2020	Restaurant	34%	34%	1.3	3.6	2.4	0.5	12	0	0	0.10	513	0.51	0.63	13.78
1135	LED Troffer (base 2L4'T8), 2020	Restaurant	40%	40%	2.0	3.6	2.2	0.4	12	2	0	0.13	668	0.39	0.48	17.96
1136	Lighting Control Tuneup (base 2L4'T8), 2020	Restaurant	5%	3%	0.0	3.6	3.4	0.7	6	0	0	0.01	79	3.07	4.97	1.04
1137	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Restaurant	21%	5%	0.8	3.6	2.9	0.7	10	0	0	0.11	2,274	0.32	0.52	14.79
1138 1200	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020 Base Other Fluorescent Fixture	Restaurant Restaurant	25% 0%	20% 0%	0.2	3.6 0.0	2.7	0.6	15 18	0	0	0.02 N/A	137 N/A	2.76 N/A	3.44 N/A	2.92 N/A
1300	Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	Restaurant	0%	0%	0.1	3.6	3.6	0.7	1	0	0	N/A	N/A	N/A	N/A	N/A
1301	CFLs (base incandescent flood) 2014-2015	Restaurant		77%	0.0	3.6	0.8	0.2	3	0	0	0.00	0	2,380.39	3,594.73	0.00
1302	LEDs (base incandescent flood) 2014-2015	Restaurant	83%	83%	0.1	4.1	0.7	0.1	6	1	0	0.00	8	17.48	25.17	0.20
1310	Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017	Restaurant	0%	0%	0.1	3.6	3.6	0.7	1	0	0	N/A	N/A	N/A	N/A	N/A
1311 1312	CFLs (base incandescent flood) 2016-2017 LEDs (base incandescent flood) 2016-2017	Restaurant Restaurant	77% 83%	77% 83%	0.0	3.6 4.1	0.8	0.2	3 6	0	0	0.00	0	2,380.39 5,705.63	3,594.73 8,214.49	0.00
1320	Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	Restaurant	0%	0%	0.0	3.6	3.6	0.7	1	0	0	N/A	N/A	N/A	N/A	N/A
1321	CFLs (base incandescent flood) 2018-2019	Restaurant	77%	77%	0.0	3.6	0.8	0.2	3	0	0	0.00	0	2,380.39	3,594.73	0.00
1322	LEDs (base incandescent flood) 2018-2019	Restaurant	83%	83%	0.0	4.1	0.7	0.1	6	1	0	0.00	0	5,705.63	8,214.49	0.00
1330	Base Incandescent Flood, 100W to Screw-in Replacement 2020	Restaurant	0%	0%	0.1	3.6	3.6	0.7	1	0	0	N/A	N/A	N/A	N/A	N/A
1331	CFLs (base incandescent flood) 2020	Restaurant	77%	77%	0.0	3.6	0.8	0.2	3	0	0	0.00	0	2,380.39	3,594.73	0.00
1332 1400	LEDs (base incandescent flood) 2020 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	Restaurant Restaurant	83%	83% 0%	0.0	4.1 2.6	0.7 2.6	0.1	6 1	1	0	0.00 N/A	0 N/A	5,705.63 N/A	8,214.49 N/A	0.00 N/A
1401	CFLs (base incandescent A-line 72W) 2014-2015	Restaurant	74%	74%	0.0	2.6	0.7	0.1	3	0	0	0.00	0	1,638.20	2.473.92	0.00
1402	LEDs (base incandescent A-line 72W) 2014-2015	Restaurant	82%	82%	0.1	3.0	0.5	0.1	6	0	0	0.00	11	12.32	17.74	0.29
1410	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	Restaurant	0%	0%	0.1	2.6	2.6	0.5	1	0	0	N/A	N/A	N/A	N/A	N/A
1411	CFLs (base incandescent A-line 72W) 2016-2017	Restaurant		74%	0.0	2.6	0.7	0.1	3	0	0	0.00	0	1,638.20	2,473.92	0.00
1412	LEDs (base incandescent A-line 72W) 2016-2017	Restaurant	82% 0%	82% 0%	0.0	3.0	0.5	0.1	6 1	0	0	0.00	0	4,022.16	5,790.76	0.00
1420 1421	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019 CFLs (base incandescent A-line 72W) 2018-2019	Restaurant Restaurant	74%	74%	0.1	2.6	2.6 0.7	0.5	3	0	0	N/A 0.00	N/A 0	N/A 1,638.20	N/A 2.473.92	N/A 0.00
1422	LEDs (base incandescent A-line 72W) 2018-2019	Restaurant		82%	0.0	3.0	0.5	0.1	6	0	0	0.00	0	4,022.16	5,790.76	0.00
1430	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Restaurant	0%	0%	0.1	2.6	2.6	0.5	1	0	0	N/A	N/A	N/A	N/A	N/A
1431	CFLs (base incandescent A-line 72W) 2020	Restaurant		74%	0.0	2.6	0.7	0.1	3	0	0	0.00	0	1,638.20	2,473.92	0.00
1432	LEDs (base incandescent A-line 72W) 2020	Restaurant	82%	82%	0.0	3.0	0.5	0.1	6	0	0	0.00	0	4,022.16	5,790.76	0.00
1500 1501	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015 CFLs (base incandescent A-line 53W) 2014-2015	Restaurant Restaurant	0% 66%	0% 66%	0.1	1.9	1.9 0.6	0.4	1	0	0	N/A 0.00	N/A 0	N/A 1,081.38	N/A 1,633.03	N/A 0.00
1502	LEDs (base incandescent A-line 53W) 2014-2015	Restaurant		75%	0.1	2.2	0.5	0.1	6	0	0	0.00	16	8.18	11.78	0.44

Comm	ercial Electric Existing Construction															
DSM ASSYS	ST SUMMARY															
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sq Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1510	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	Restaurant	0%	0%	0.1	1.9	1.9	0.4	1	0	0	N/A	N/A	N/A	N/A	N/A
1511 1512	CFLs (base incandescent A-line 53W) 2016-2017 LEDs (base incandescent A-line 53W) 2016-2017	Restaurant Restaurant	66% 75%	66% 75%	0.0	1.9 2.2	0.6	0.1	3 6	0	0	0.00	0	1,081.38 2,670.44	1,633.03 3,844.68	0.00
1512	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	Restaurant	0%	75% 0%	0.0	1.9	1.9	0.1	1	0	0	0.00 N/A	N/A	2,670.44 N/A	3,844.08 N/A	N/A
1521	CFLs (base incandescent A-line 53W) 2018-2019	Restaurant	66%	66%	0.0	1.9	0.6	0.1	3	0	0	0.00	0	1,081.38	1,633.03	0.00
1522	LEDs (base incandescent A-line 53W) 2018-2019	Restaurant		75%	0.0	2.2	0.5	0.1	6	0	0	0.00	0	2,670.44	3,844.68	0.00
1530	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Restaurant	0%	0%	0.1	1.9	1.9	0.4	1	0	0	N/A	N/A	N/A	N/A	N/A
1531 1532	CFLs (base incandescent A-line 53W) 2020 LEDs (base incandescent A-line 53W) 2020	Restaurant Restaurant		66% 75%	0.0	1.9 2.2	0.6	0.1	3 6	0	0	0.00	0	1,081.38 2.670.44	1,633.03 3,844.68	0.00
1600	Base CFL 18W to screw-in replacement 2014-2015	Restaurant	0%	0%	0.2	0.9	0.9	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1601	LED screw-in replacement (base CFL 18W) 2014-2015	Restaurant	28%	28%	0.4	0.9	0.7	0.1	6	0	0	0.16	790	0.17	0.24	21.24
1610	Base CFL 18W to screw-in replacement 2016-2017	Restaurant	0%	0%	0.2	0.9	0.9	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1611	LED screw-in replacement (base CFL 18W) 2016-2017	Restaurant		28%	0.2	0.9	0.7	0.1	6	0	0	0.08	411	0.32	0.47	11.06
1620 1621	Base CFL 18W to screw-in replacement 2018-2019 LED screw-in replacement (base CFL 18W) 2018-2019	Restaurant Restaurant	0% 28%	0% 28%	0.2	0.9	0.9	0.2	3 6	0	0	N/A 0.06	N/A 328	N/A 0.41	N/A 0.58	N/A 8.82
1630	Base CFL 18W to screw-in replacement 2020	Restaurant	0%	0%	0.2	0.9	0.7	0.1	3	0	0	N/A	N/A	N/A	N/A	N/A
1631	LED screw-in replacement (base CFL 18W) 2020	Restaurant		28%	0.1	0.9	0.7	0.1	6	0	0	0.06	285	0.47	0.67	7.67
1700	Base CFL 23W to screw-in replacement 2014-2015	Restaurant	0%	0%	0.2	1.2	1.2	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1701	LED screw-in replacement (base CFL 23W) 2014-2015	Restaurant		26%	0.4	1.2	0.9	0.2	6	0	0	0.13	659	0.20	0.29	17.71
1710 1711	Base CFL 23W to screw-in replacement 2016-2017 LED screw-in replacement (base CFL 23W) 2016-2017	Restaurant Restaurant	0% 26%	0% 26%	0.2	1.2	1.2 0.9	0.2	3 6	0	0	N/A 0.07	N/A 343	N/A 0.39	N/A 0.56	N/A 9.22
1711	Base CFL 23W to screw-in replacement 2018-2019	Restaurant	26%	26%	0.2	1.2	1.2	0.2	3	0	0	0.07 N/A	343 N/A	0.39 N/A	0.56 N/A	9.22 N/A
1721	LED screw-in replacement (base CFL 23W) 2018-2019	Restaurant		26%	0.2	1.2	0.9	0.2	6	0	0	0.05	274	0.49	0.70	7.35
1730	Base CFL 23W to screw-in replacement 2020	Restaurant	0%	0%	0.2	1.2	1.2	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1731	LED screw-in replacement (base CFL 23W) 2020	Restaurant	26%	26%	0.1	1.2	0.9	0.2	6	0	0	0.05	238	0.56	0.81	6.39
1800	BaseMetal Halide, 465W	Restaurant	0%	0%	0.0	0.1	0.1	0.0	18	0	0	N/A	N/A	N/A	N/A	N/A
1801 1802	T5 (240W) (base metal halide) Induction High Bay Lighting	Restaurant Restaurant	48% 37%	48% 37%	0.0	0.1	0.1	0.0	18 20	0	0	0.01	73 515	5.02 0.77	5.67 0.85	1.96 13.83
1803	PSMH + electronic ballast	Restaurant	43%	43%	0.0	0.1	0.1	0.0	16	0	0	0.10	167	1.99	2.32	4.50
1804	PSMH, magnetic ballast, 320 W	Restaurant		31%	0.0	0.1	0.1	0.0	0	0	0	0.06	310	0.07	0.12	8.34
1805	High Performance Lighting R/R - 25% Savings (base metal halide)	Restaurant		20%	0.2	0.1	0.1	0.0	15	0	0	0.59	3,751	0.10	0.13	79.94
1806	Occupancy Sensor, High Bay T5	Restaurant		5%	0.0	0.1	0.1	0.0	10	0	0	0.02	373	1.98	3.15	2.43
1850	Base CFL Exit Sign	Restaurant		0%	0.0	0.0	0.0	0.0	18	0	0	N/A	N/A	N/A	N/A	N/A
1851 1900	LED Exit Sign Base Outdoor High Pressure Sodium 250W Lamp	Restaurant Restaurant		69% 0%	0.0	0.1	0.0	0.0	7 15	0	0	0.03 N/A	150 N/A	1.03 N/A	1.45 N/A	4.02 N/A
1901	Outdoor Lighting Controls (Photocell/Timeclock)	Restaurant		73%	0.3	1.9	1.4	0.0	18	0	0	0.06	326	1.20	1.27	8.77
1902	LED Outdoor Area Lighting	Restaurant		52%	1.1	1.7	0.8	0.1	18	1	0	0.12	1,879	0.49	0.66	16.95
1903	Bi-Level LED Outdoor Lighting	Restaurant	69%	63%	3.6	1.7	0.5	0.0	18	1	0	0.30	4,998	0.20	0.27	40.77
2000	Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Restaurant	0%	0%	0.7	6.1	6.1	3.8	20	0	0	N/A	N/A	N/A	N/A	N/A
2001	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Restaurant		12% 3%	0.2	6.3	5.6 5.6	3.5	20	0	0	0.02	33 182	5.40 2.07	4.16	2.83 3.79
2003	EMS - Chiller Chiller Tune Up/Diagnostics	Restaurant Restaurant	8%	5% 4%	0.2	6.2	6.1	3.8 4.0	15 10	0	0	0.03	30	4.93	2.65 6.04	1.27
2010	Ceiling/roof Insulation - Chiller	Restaurant		12%	0.1	6.4	5.6	3.5	20	0	0	0.02	24	7.41	5.71	2.06
2012	Duct Testing/Sealing	Restaurant		19%	1.0	6.2	5.0	3.1	18	0	0	0.08	135	1.22	0.97	11.51
2100	Base DX Packaged System, EER=10.3, 10 tons	Restaurant		0%	2.0	6.1	6.1	3.8	15	0	0	N/A	N/A	N/A	N/A	N/A
2101	DX Packaged System, EER=10.9, 10 tons	Restaurant	6%	6%	0.2	6.1	5.7	3.6	15	0	0	0.05	77	1.84	1.53	6.54
2102 2103	DX Packaged System, EER=13.4, 10 tons Geothermal Heat Pump, EER=13, 10 tons - DX	Restaurant Restaurant	23% 21%	23% 21%	0.2 2.4	6.1 6.1	4.7	2.9 3.0	15 15	2	1	0.02 0.19	25 296	5.66 0.48	4.72 0.40	2.12 25.24
2105	DX Tune Up/ Advanced Diagnostics	Restaurant	5%	3%	0.1	6.4	6.1	3.9	10	0	0	0.03	100	1.49	1.83	4.19
2106	Prog. Thermostat - DX	Restaurant	5%	1%	0.1	6.3	5.9	3.9	8	0	0	0.03	168	1.24	1.85	3.50
2107	Cool Roof - DX	Restaurant	7%	7%	0.3	6.1	5.7	3.6	10	0	0	0.06	92	1.01	0.97	7.87
2108	Optimize Controls - DX	Restaurant	5%	1%	0.0	6.3	6.0	3.9	5	0	0	0.01	79	1.68	2.67	1.66
2109	Economizer - DX	Restaurant	12%	3% 1%	0.5	6.6	5.8	4.0 3.8	10	0	0	0.06	400	0.65	0.92	8.34
2110 2111	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX Economizer Repair - DX	Restaurant Restaurant	3% 12%	1%	0.1	6.2	6.0 5.6	3.8	10 5	0	0	0.06	402 33	0.65 1.09	0.91 1.06	8.38 4.16
2111	Aerosol Duct Sealing - DX	Restaurant	19%	19%	1.0	6.2	5.0	3.1	18	0	0	0.08	135	1.03	0.97	11.51
2113	Ceiling/roof Insulation - DX	Restaurant	12%	12%	0.1	6.9	6.1	3.8	20	0	0	0.01	22	7.99	6.15	1.91
2114	Duct/Pipe Insulation - DX	Restaurant	2%	2%	0.8	6.1	6.0	3.7	10	0	0	0.62	985	0.09	0.09	83.96
2115	Window Film (Standard) - DX	Restaurant		10%	0.1	6.1	5.5	3.4	10	1	0	0.01	18	5.10	4.91	1.56
2200 2201	Base Heat Pump (13 SEER, 7.7 HSPF) Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant Restaurant		0% 13%	0.0	6.1 6.1	6.1 5.3	3.8	15 15	0	0	N/A 0.01	N/A 18	N/A 7.93	N/A 6.61	N/A 1.52
2300	Base PTAC, EER=8.3, 1 ton	Restaurant	0%	0%	0.0	6.1	6.1	3.8	15	0	0	N/A	N/A	7.93 N/A	N/A	N/A
3000	Base Fan Motor, 5hp, 1800rpm, 87.5%	Restaurant	0%	0%	0.1	3.1	3.1	0.8	20	0	0	N/A	N/A	N/A	N/A	N/A
3001	Fan Motor, 5hp, 1800rpm, 89.5%	Restaurant		2%	0.1	3.1	3.1	8.0	20	0	0	0.11	432	0.74	0.78	15.16
3002	Variable Speed Drive Control, 5 HP	Restaurant		8%	0.7	3.1	2.2	0.7	15	1	0	0.07	1,140	0.72	1.02	9.87
3003 3100	Demand Controlled Ventilation	Restaurant	15% 0%	29% 0%	2.4 0.0	3.1	2.7	0.6	15 20	1	0	0.51	1,009	0.16	0.14	69.20
3100 3200	Base Fan Motor, 15hp, 1800rpm, 91.0% Base Fan Motor, 40hp, 1800rpm, 93.0%	Restaurant Restaurant	0%	0%	0.0	3.1	3.1	0.8	20	0	0	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A
4000	Base Built-Up Refrigeration System	Restaurant		0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
4100	Base Self-Contained Refrigeration	Restaurant		0%	0.0	7.3	7.3	1.1	10	0	0	N/A	N/A	N/A	N/A	N/A

Comme	rcial Electric Existing Construction															
DSM ASSYST	SUMMARY															
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
4101	Strip curtains for walk-ins (self-contained)	Restaurant	1%	1%	0.1	7.3	7.3	1.1	4	0	0	0.11	732	0.15	0.24	14.92
4103	Night covers for display cases (self-contained)	Restaurant	9%	9%	0.0	7.4	6.7	1.0	5	0	0	0.00	10	13.37	20.68	0.21
4104	Freezer-Cooler Replacement Gaskets (self-contained)	Restaurant	3%	3%	0.0	7.4	7.2	1.1	4	0	0	0.00	13	8.71	13.76	0.27
4105 4106	Bi-level LED Case Lighting (self-contained units) 2014 Energy-Star Refrigerator, solid door	Restaurant Restaurant	0% 3%	0% 3%	0.0	7.3	7.3 7.1	1.1	8 10	0	0	0.17	1,138 108	0.19 2.51	0.28 3.47	23.21
4107	Energy-Star Freezer, solid door	Restaurant	1%	1%	0.0	7.4	7.1	1.1	9	0	0	0.02	78	3.12	4.43	1.60
4108	Energy-Star Refrigerator, glass door	Restaurant	2%	2%	0.0	7.3	7.2	1.1	10	0	0	0.02	106	2.56	3.54	2.16
4109	Energy-Star Freezer, glass door	Restaurant	3%	3%	0.0	7.4	7.1	1.1	9	0	0	0.00	32	7.62	10.83	0.65
4110	Energy Star Ice Machines	Restaurant	2%	2%	0.1	7.4	7.2	1.1	10	0	0	0.04	292	0.93	1.29	5.96
4112	Reach-in unit occupancy sensors	Restaurant	0%	0%	0.0	7.3	7.3	1.1	10	0	0	0.17	1,169	0.23	0.32	23.82
5000 5001	Base Desktop PC	Restaurant Restaurant	0% 66%	0% 34%	0.0	0.2	0.2	0.0	4	0	0	N/A 0.01	N/A 62	N/A 2.61	N/A 4.33	N/A 0.84
5001	PC Network Power Management Enabling Energy Star or Better PC	Restaurant	33%	34%	0.0	0.2	0.1	0.0	4	0	0	0.01	38	2.40	3.59	1.01
5100	Base Laptop PC	Restaurant	0%	0%	0.0	0.0	0.0	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5101	Laptop Network Power Management Enabling	Restaurant	7%	7%	0.0	0.0	0.0	0.0	4	0	0	0.47	2,411	0.04	0.06	64.06
5102	Energy Star or Better Laptop	Restaurant		30%	0.0	0.0	0.0	0.0	4	0	0	0.00	25	3.69	5.54	0.66
5200	Base Monitor, CRT	Restaurant	0%	0%	0.0	0.1	0.1	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5201	Energy Star or Better Monitor - CRT	Restaurant	56%	56%	0.0	0.1	0.0	0.0	4	0	0	0.00	3	29.38	44.05	0.08
5202 5203	Monitor Power Management Enabling - CRT Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Restaurant Restaurant	52% 15%	27% 15%	0.0	0.1	0.1	0.0	4	0	0	0.00	37 167	4.35 0.55	7.21 0.82	0.51 4.44
5300	Base Monitor, LCD	Restaurant	0%	0%	0.0	0.1	0.1	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5301	Energy Star or Better Monitor - LCD	Restaurant	21%	21%	0.0	0.1	0.0	0.0	4	0	0	0.01	28	3.23	4.85	0.75
5302	Monitor Power Management Enabling - LCD	Restaurant	19%	10%	0.0	0.1	0.0	0.0	4	0	0	0.04	441	0.37	0.61	5.99
5303	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Restaurant	14%	4%	0.0	0.1	0.0	0.0	4	0	0	0.11	2,239	0.13	0.24	15.42
5400	Base Copier	Restaurant	0%	0%	0.0	0.1	0.1	0.0	6	0	0	N/A	N/A	N/A	N/A	N/A
5401	Energy Star or Better Copier	Restaurant	21%	21%	0.0	0.1	0.1	0.0	6	0	0	0.00	6	21.61	31.17	0.17
5402 5500	Copier Power Management Enabling Base Multifunction	Restaurant Restaurant	19% 0%	10% 0%	0.0	0.1	0.1	0.0	6 5	0	0	0.06 N/A	586 N/A	0.41 N/A	0.65 N/A	7.97 N/A
5500	Multifunction Power Management Enabling	Restaurant	48%	25%	0.0	0.0	0.0	0.0	5	0	0	0.17	1,664	0.12	0.20	22.60
5502	ENERGY STAR Multi-Function Device	Restaurant	40%	40%	0.0	0.0	0.0	0.0	5	0	0	0.00	18	6.22	9.15	0.48
5600	Base Printer	Restaurant	0%	0%	0.0	0.1	0.1	0.0	5	0	0	N/A	N/A	N/A	N/A	N/A
5601	Printer Power Management Enabling	Restaurant	48%	25%	0.0	0.1	0.0	0.0	5	0	0	0.03	315	0.64	1.03	4.28
5602	ENERGY STAR Printer	Restaurant	40%	40%	0.0	0.1	0.0	0.0	5	0	0	0.00	4	28.59	42.06	0.11
5700	Base Data Center/Server Room	Restaurant	0%	0%	0.0	110.1	110.1	21.5	10	0	0	N/A	N/A	N/A	N/A	N/A
5701 5702	Data Center Improved Operations Data Center Best Practices	Restaurant	20% 45%	20% 45%	0.1	114.6 115.2		17.9 12.4	10 10	0	0	0.00	2 5	100.89 45.64	131.90 59.67	0.06 0.13
5702	Data Center Best Practices Data Center State of the Art practices	Restaurant Restaurant	45% 56%	45% 56%	1.0	115.2		9.4	10	0	0	0.00	8	45.64 27.12	35.46	0.13
6000	Base Water Heating	Restaurant	0%	0%	0.0	1.6	1.6	0.3	15	0	0	N/A	N/A	N/A	N/A	N/A
6001	Demand controlled circulating systems	Restaurant	5%	5%	0.0	1.6	1.6	0.3	15	0	0	0.05	317	1.14	1.38	7.27
6002	High Efficiency Water Heater (electric)	Restaurant	2%	2%	0.0	1.6	1.6	0.3	15	0	0	0.01	63	5.75	6.96	1.44
6003	Hot Water Pipe Insulation	Restaurant	2%	2%	0.0	1.6	1.6	0.3	15	0	0	0.02	103	3.50	4.24	2.37
6004	Tankless Water Heater	Restaurant	10%	10%	0.0	1.6	1.5	0.2	20	0	0	0.02	108	4.18	4.75	2.48
6005	Heat Pump Water Heater (air source)	Restaurant	20%	20%	0.1	1.6	1.3	0.2	10	0	0	0.02	144	1.73	2.31	3.31
6006 6007	Heat Recovery Unit Heat Trap	Restaurant Restaurant	65% 9%	65% 9%	0.1	1.6	0.6 1.5	0.1	10 10	0	0	0.01	43 25	5.74 10.16	7.66 13.57	1.00 0.56
6008	Solar Water Heater	Restaurant	70%	70%	0.2	1.6	0.5	0.1	20	0	0	0.02	116	3.87	4.40	2.67
7000	Base Refrigerated Vending Machines	Restaurant	0%	0%	0.0	0.1	0.1	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
7001	Vending Misers (Refrigerated units)	Restaurant	46%	23%	0.0	0.1	0.0	0.0	5	0	0	0.01	105	1.94	3.16	1.40
7002	Vending Misers (Refrigerated glass-front units)	Restaurant	30%	15%	0.0	0.1	0.1	0.0	5	0	0	0.02	161	1.26	2.06	2.15
7100	Base Non-Refrigerated Vending Machines	Restaurant	0%	0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
7200 7201	Base Oven	Restaurant	0% 23%	0%	0.0	2.6	2.6	0.5	10	0	0	N/A	N/A	N/A	N/A	N/A
7201	Convection Oven Base Fryer	Restaurant Restaurant	23% 0%	23% 0%	0.5	2.6	2.0	0.4	12 10	0	0	0.08 N/A	367 N/A	0.69 N/A	0.85 N/A	10.26 N/A
7301	Efficient Fryer	Restaurant	6%	6%	0.4	2.6	2.5	0.5	12	0	0	0.24	1,193	0.21	0.26	33.30
7400	Base Steamer	Restaurant	0%	0%	0.0	4.2	4.2	0.9	10	0	0	N/A	N/A	N/A	N/A	N/A
7401	Efficient Steamer	Restaurant	69%	69%	1.0	4.2	1.3	0.3	12	1	0	0.03	168	1.50	1.85	4.69
8000	Base Heating, Heat Pump (7.7 HSPF)	Restaurant	0%	0%	0.0	0.3	0.3	0.0	15	0	0	N/A	N/A	N/A	N/A	N/A
8001	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	6%	6%	0.0	0.3	0.2	0.0	15	0	0	0.04	N/A	1.13	1.66	6.05
8100	Base Heating, Other Electric	Restaurant	0%	0%	12.0	0.3	0.3	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
9500 9501	Base Miscellaneous Xmisc	Restaurant Restaurant	0% 0%	0% 0%	1.3	2.7	2.7	0.5 0.5	10 10	0	0	N/A N/A	N/A N/A	N/A 0.00	N/A 0.00	N/A N/A
1000	xmisc Base Fluorescent Fixture, 4L4'T8, 1EB, 2014-2015	Retail	0%	0%	0.0	5.1	5.1	0.5	18	0	0	N/A N/A	N/A N/A	0.00 N/A	0.00 N/A	N/A N/A
1000	ROB 4L4' High Performance T8 (86 W), 2014-2015	Retail	10%	10%	0.0	5.1	4.6	0.8	7	93	17	0.01	67	2.49	3.55	1.64
1002	ROB 4L4' Low Watt High Performance T8 (75 W), 2014-2015	Retail	22%	22%	0.2	5.1	4.0	0.7	7	195	35	0.02	104	1.59	2.27	2.57
1003	ROB 4L4'T5, 2014-2015	Retail	12%	12%	0.8	5.1	4.5	0.8	5	104	19	0.13	726	0.17	0.25	17.88
1004	ROB 4L4' LED Tube, 2014-2015	Retail	34%	34%	2.8	5.1	3.3	0.6	12	308	56	0.15	850	0.33	0.42	20.94
1005	LED Troffer (base 4L4'T8), 2014-2015	Retail	40%	40%	3.5	5.1	3.1	0.6	12	358	65	0.17	934	0.30	0.38	23.01
1006 1007	Lighting Control Tuneup (base 4L4'T8), 2014-2015 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2014-2015	Retail Retail	5% 21%	3% 5%	0.0	5.1 5.2	4.8 4.1	0.9	6 10	2 13	0 1	0.01 0.05	61 1,079	4.32 0.75	7.04 1.20	0.73 6.40
1007	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2014-2015	Retail	21%	20%	0.5	5.2	3.8	0.9	10 15	13 68	10	0.05	1,079	3.84	4.86	2.06
1000		netan	23/0	20/0	0.2	J.1	5.0	0.7	13	Jo	10	0.02	100	3.04	4.00	2.00

Comme	ercial Electric Existing Construction															
DSM ASSYST	SUMMARY															
Measure Number	Measure	Building	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base FUI	EUI	Peak Watts/ Sq Ft	Service	Technical Potential GWH	System Peak Tech. Potential MW	Levelized Cost of Conserved Energy \$/kWH	Levelized Cost of Avoided Peak Capacity \$/kW	Total Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1010	Base Fluorescent Fixture, 4L4'T8, 1EB, 2016-2017	Type Retail	0%	0%	0.0	5.1	5.1	0.9	Life (yrs) 18	0	0	N/A	N/A	N/A	N/A	N/A
1011	ROB 4L4' High Performance T8 (86 W), 2016-2017	Retail	10%	10%	0.1	5.1	4.6	0.8	7	93	17	0.01	67	2.49	3.55	1.64
1012	ROB 4L4' Low Watt High Performance T8 (75 W), 2016-2017	Retail	22%	22%	0.2	5.1	4.0	0.7	7	195	35	0.02	104	1.59	2.27	2.57
1013 1014	ROB 4L4 ¹ T5, 2016-2017 ROB 4L4 ¹ LED Tube, 2016-2017	Retail Retail	12% 34%	12% 34%	0.8	5.1 5.1	4.5	0.8	5 12	104 308	19 56	0.13	726 584	0.17	0.25	17.88 14.39
1015	LED Troffer (base 4L4'T8), 2016-2017	Retail	40%	40%	2.5	5.1	3.1	0.6	12	358	65	0.12	655	0.43	0.54	16.15
1016	Lighting Control Tuneup (base 4L4'T8), 2016-2017	Retail	5%	3%	0.0	5.1	4.8	0.9	6	2	0	0.01	61	4.32	7.04	0.73
1017	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2016-2017	Retail	21%	5%	0.5	5.2	4.1	0.9	10	13	1	0.05	1,079	0.75	1.20	6.40
1018 1020	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2016-2017 Base Fluorescent Fixture, 4L4'T8, 1EB, 2018-2019	Retail Retail	25% 0%	20%	0.2	5.1 5.1	3.8 5.1	0.7 0.9	15 18	68 0	10 0	0.02 N/A	106 N/A	3.84 N/A	4.86 N/A	2.06 N/A
1020	ROB 4L4' High Performance T8 (86 W), 2018-2019	Retail	10%	10%	0.0	5.1	4.6	0.8	7	93	17	0.01	67	2.49	3.55	1.64
1022	ROB 4L4' Low Watt High Performance T8 (75 W), 2018-2019	Retail	22%	22%	0.2	5.1	4.0	0.7	7	195	35	0.02	104	1.59	2.27	2.57
1023	ROB 4L4'T5, 2018-2019	Retail	12%	12%	0.8	5.1	4.5	0.8	5	104	19	0.13	726	0.17	0.25	17.88
1024	ROB 4L4' LED Tube, 2018-2019	Retail Retail	34% 40%	34% 40%	1.7	5.1	3.3	0.6	12	308	56	0.10	525 594	0.53	0.67	12.95
1025 1026	LED Troffer (base 4L4'T8), 2018-2019 Lighting Control Tuneup (base 4L4'T8), 2018-2019	Retail	40% 5%	40% 3%	0.0	5.1 5.1	3.1 4.8	0.6	12 6	358 2	65 0	0.11	594 61	4.32	7.04	14.64 0.73
1027	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2018-2019	Retail	21%	5%	0.5	5.2	4.1	0.9	10	13	1	0.05	1,079	0.75	1.20	6.40
1028	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2018-2019	Retail	25%	20%	0.2	5.1	3.8	0.7	15	68	10	0.02	106	3.84	4.86	2.06
1030	Base Fluorescent Fixture, 4L4 ¹ T8, 1EB, 2020	Retail	0%	0%	0.0	5.1	5.1	0.9	18	0	0	N/A	N/A	N/A	N/A	N/A
1031 1032	ROB 4L4' High Performance T8 (86 W), 2020 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Retail Retail	10% 22%	10% 22%	0.1	5.1 5.1	4.6 4.0	0.8	7 7	93 195	17 35	0.01	67 104	2.49 1.59	3.55 2.27	1.64 2.57
1032	ROB 4L4 LOW Watt High Ferformance 18 (73 W), 2020	Retail	12%	12%	0.2	5.1	4.5	0.7	5	104	19	0.02	726	0.17	0.25	17.88
1034	ROB 4L4' LED Tube, 2020	Retail	34%	34%	1.6	5.1	3.3	0.6	12	308	56	0.09	495	0.56	0.71	12.20
1035	LED Troffer (base 4L4'T8), 2020	Retail	40%	40%	2.1	5.1	3.1	0.6	12	358	65	0.10	563	0.50	0.63	13.86
1036	Lighting Control Tuneup (base 4L4'T8), 2020	Retail	5%	3%	0.0	5.1	4.8	0.9	6	2	0	0.01	61	4.32	7.04	0.73
1037 1038	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Retail Retail	21% 25%	5% 20%	0.5	5.2	4.1	0.9	10 15	13 68	1 10	0.05	1,079 106	0.75 3.84	1.20 4.86	6.40 2.06
1100	Base Fluorescent Fixture, 2L4'T8, 1EB, 2014-2015	Retail	0%	0%	0.0	3.0	3.0	0.5	18	0	0	N/A	N/A	N/A	N/A	N/A
1101	ROB 2L4' High Performance T8 (86 W), 2014-2015	Retail	10%	10%	0.0	3.0	2.7	0.5	7	19	3	0.02	84	1.97	2.81	2.08
1102	ROB 2L4' Low Watt High Performance T8 (75 W), 2014-2015	Retail	22%	22%	0.2	3.0	2.3	0.4	7	39	7	0.02	132	1.26	1.79	3.26
1103 1104	ROB 2L4'T5, 2014-2015 ROB 2L4' LED Tube, 2014-2015	Retail Retail	12% 34%	12% 34%	0.5 1.4	3.0	2.6	0.5	5 12	21 18	4	0.15 0.13	832 721	0.15 0.39	0.22 0.49	20.50 17.76
1104	LED Troffer (base 2L4'T8), 2014-2015	Retail	40%	40%	2.0	3.0	1.8	0.4	12	71	13	0.13	721 896	0.39	0.49	22.08
1106	Lighting Control Tuneup (base 2L4/T8), 2014-2015	Retail	5%	3%	0.0	3.0	2.8	0.5	6	0	0	0.01	104	2.53	4.12	1.25
1107	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2014-2015	Retail	21%	5%	0.5	3.0	2.4	0.5	10	3	0	0.08	1,912	0.42	0.67	11.34
1108	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2014-2015	Retail	25%	20%	0.2	3.0	2.2	0.4	15	14 0	2	0.03	181	2.25	2.85	3.52
1110 1111	Base Fluorescent Fixture, 2L4'T8, 1EB, 2016-2017 ROB 2L4' High Performance T8 (86 W), 2016-2017	Retail Retail	10%	10%	0.0	3.0	3.0 2.7	0.5	18 7	19	0	N/A 0.02	N/A 84	N/A 1.97	N/A 2.81	N/A 2.08
1112	ROB 2L4' Low Watt High Performance T8 (75 W), 2016-2017	Retail	22%	22%	0.2	3.0	2.3	0.4	7	39	7	0.02	132	1.26	1.79	3.26
1113	ROB 2L4'T5, 2016-2017	Retail	12%	12%	0.5	3.0	2.6	0.5	5	21	4	0.15	832	0.15	0.22	20.50
1114	ROB 2L4' LED Tube, 2016-2017	Retail	34%	34%	1.0	3.0	2.0	0.4	12	18	3	0.09	512	0.55	0.69	12.62
1115 1116	LED Troffer (base 2L4'T8), 2016-2017	Retail Retail	40% 5%	40% 3%	1.4	3.0	1.8	0.3	12 6	71 0	13 0	0.12	654 104	0.43 2.53	0.54 4.12	16.10 1.25
1117	Lighting Control Tuneup (base 2L4'T8), 2016-2017 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2016-2017	Retail	21%	5%	0.0	3.0	2.4	0.5	10	3	0	0.01	1,912	0.42	0.67	11.34
1118	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2016-2017	Retail	25%	20%	0.2	3.0	2.2	0.4	15	14	2	0.03	181	2.25	2.85	3.52
1120	Base Fluorescent Fixture, 2L4'T8, 1EB, 2018-2019	Retail	0%	0%	0.0	3.0	3.0	0.5	18	0	0	N/A	N/A	N/A	N/A	N/A
1121	ROB 2L4' High Performance T8 (86 W), 2018-2019	Retail	10%	10%	0.0	3.0	2.7	0.5	7	19	3	0.02	84	1.97	2.81	2.08
1122 1123	ROB 2L4' Low Watt High Performance T8 (75 W), 2018-2019 ROB 2L4'T5, 2018-2019	Retail Retail	22% 12%	22% 12%	0.2	3.0	2.3	0.4	7 5	39 21	7	0.02	132 832	1.26 0.15	1.79 0.22	3.26 20.50
1124	ROB 2L4' LED Tube, 2018-2019	Retail	34%	34%	0.9	3.0	2.0	0.4	12	18	3	0.08	460	0.61	0.77	11.34
1125	LED Troffer (base 2L4'T8), 2018-2019	Retail	40%	40%	1.3	3.0	1.8	0.3	12	71	13	0.11	595	0.47	0.59	14.66
1126	Lighting Control Tuneup (base 2L4'T8), 2018-2019	Retail	5%	3%	0.0	3.0	2.8	0.5	6	0	0	0.01	104	2.53	4.12	1.25
1127 1128	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2018-2019 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2018-2019	Retail Retail	21% 25%	5% 20%	0.5	3.0	2.4	0.5	10 15	3 14	0	0.08	1,912 181	0.42 2.25	0.67 2.85	11.34 3.52
1130	Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Retail	0%	0%	0.0	3.0	3.0	0.4	18	0	0	N/A	N/A	N/A	N/A	N/A
1131	ROB 2L4' High Performance T8 (86 W), 2020	Retail	10%	10%	0.0	3.0	2.7	0.5	7	19	3	0.02	84	1.97	2.81	2.08
1132	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Retail	22%	22%	0.2	3.0	2.3	0.4	7	39	7	0.02	132	1.26	1.79	3.26
1133	ROB 2L4'T5, 2020	Retail	12%	12%	0.5	3.0	2.6	0.5	5	21	4	0.15	832	0.15	0.22	20.50
1134 1135	ROB 2L4' LED Tube, 2020 LED Troffer (base 2L4'T8), 2020	Retail Retail	34% 40%	34% 40%	0.8	3.0	2.0 1.8	0.4	12 12	18 71	3 13	0.08	433 565	0.64	0.81	10.68 13.92
1136	Lighting Control Tuneup (base 2L4T8), 2020	Retail	5%	3%	0.0	3.0	2.8	0.5	6	0	0	0.10	104	2.53	4.12	1.25
1137	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Retail	21%	5%	0.5	3.0	2.4	0.5	10	3	0	0.08	1,912	0.42	0.67	11.34
1138	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Retail	25%	20%	0.2	3.0	2.2	0.4	15	14	2	0.03	181	2.25	2.85	3.52
1200 1201	Base Other Fluorescent Fixture ROB High Performance T8 (base other fluorescent)	Retail	0% 10%	0% 10%	0.0	1.5	1.5	0.3	18 7	0	0	N/A 0.05	N/A 270	N/A 0.62	N/A 0.88	N/A 6.65
1201 1202	ROB High Performance T8 (base other fluorescent) ROB Low Watt High Performance T8 (base other fluorescent)	Retail Retail	10% 22%	10% 22%	0.1	1.5	1.4	0.2	7	0	0	0.05	270 423	0.62	0.88 0.56	6.65 10.43
1202	Lighting Control Tuneup (base other fluorescent fixture)	Retail	31%	15%	0.0	1.5	1.1	0.2	6	0	0	0.00	34	7.82	12.73	0.40
1204	Occupancy Sensor, 4L8' Fluorescent Fixtures	Retail	54%	13%	0.6	1.6	0.7	0.2	10	0	0	0.06	1,448	0.56	0.89	8.59
1205	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Retail	25%	20%	0.2	1.5	1.1	0.2	15	0	0	0.05	351	1.16	1.46	6.85
1300	Base Incandescent Flood, 100W to Screw-in Replacement 2014-2015	Retail	0%	0%	0.2	5.8	5.8	1.0	1	0	0	N/A	N/A	N/A	N/A	N/A

Comm	ercial Electric Existing Construction															
DSM ASSYS	ST SUMMARY										System	Levelized Cost	Levelized Cost	Total		
Measure Number	Measure	Building Type	Energy Savings Fraction	Peak Reduction Fraction	Total Costs/ Sg Ft	Base EUI	EUI	Peak Watts/ Sq Ft	Service Life (yrs)	Technical Potential GWH	Peak Tech. Potential MW	of Conserved Energy S/kWH	of Avoided Peak Capacity \$/kW	Resource Cost Test (TRC)	Participant Test	Customer Payback (Years)
1301	CFLs (base incandescent flood) 2014-2015	Retail	77%	77%	0.0	5.8	1.3	0.2	3	130	24	0.00	0	3,127.02	4,786.66	0.00
1302	LEDs (base incandescent flood) 2014-2015	Retail	83%	83%	0.1	6.0	1.0	0.2	6	279	51	0.00	7	20.42	29.75	0.17
1310	Base Incandescent Flood, 100W to Screw-in Replacement 2016-2017 CFLs (base incandescent flood) 2016-2017	Retail Retail	0% 77%	0% 77%	0.2	5.8 5.8	5.8 1.3	0.2	1	0 130	0 24	N/A 0.00	N/A 0	N/A 3.127.02	N/A 4.786.66	N/A 0.00
1311	LEDs (base incandescent flood) 2016-2017	Retail	83%	83%	0.0	6.0	1.0	0.2	6	279	51	0.00	0	6.666.83	9,710.49	0.00
1320	Base Incandescent Flood, 100W to Screw-in Replacement 2018-2019	Retail	0%	0%	0.2	5.8	5.8	1.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1321	CFLs (base incandescent flood) 2018-2019	Retail	77%	77%	0.0	5.8	1.3	0.2	3	130	24	0.00	Ó	3,127.02	4,786.66	0.00
1322	LEDs (base incandescent flood) 2018-2019	Retail	83%	83%	0.0	6.0	1.0	0.2	6	279	51	0.00	0	6,666.83	9,710.49	0.00
1330	Base Incandescent Flood, 100W to Screw-in Replacement 2020	Retail	0%	0%	0.2	5.8	5.8	1.0	1	0	0	N/A	N/A	N/A	N/A	N/A
1331	CFLs (base incandescent flood) 2020	Retail	77%	77%	0.0	5.8	1.3	0.2	3	130	24	0.00	0	3,127.02	4,786.66	0.00
1332	LEDs (base incandescent flood) 2020 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2014-2015	Retail Retail	83% 0%	83% 0%	0.0	6.0 4.2	1.0	0.2	6 1	279 0	51 0	0.00 N/A	0 N/A	6,666.83 N/A	9,710.49 N/A	0.00 N/A
1400	CFLs (base incandescent A-line 72W) 2014-2015	Retail	74%	74%	0.2	4.2	1.1	0.8	3	45	8	0.00	0	2.152.04	3.294.22	0.00
1402	LEDs (base incandescent A-line 72W) 2014-2015	Retail	82%	82%	0.1	4.3	0.8	0.1	6	99	18	0.00	10	14.43	21.02	0.25
1410	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2016-2017	Retail	0%	0%	0.2	4.2	4.2	0.8	1	0	0	N/A	N/A	N/A	N/A	N/A
1411	CFLs (base incandescent A-line 72W) 2016-2017	Retail	74%	74%	0.0	4.2	1.1	0.2	3	45	8	0.00	0	2,152.04	3,294.22	0.00
1412	LEDs (base incandescent A-line 72W) 2016-2017	Retail	82%	82%	0.0	4.3	0.8	0.1	6	99	18	0.00	0	4,710.80	6,861.46	0.00
1420	Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2018-2019	Retail	0%	0%	0.2	4.2	4.2	0.8	1	0	0	N/A	N/A	N/A	N/A	N/A
1421 1422	CFLs (base incandescent A-line 72W) 2018-2019 LEDs (base incandescent A-line 72W) 2018-2019	Retail Retail	74% 82%	74% 82%	0.0	4.2	1.1 0.8	0.2	3 6	45 99	8 18	0.00	0	2,152.04 4,710.80	3,294.22 6,861.46	0.00
1430	Base Incandescent A-Line Lamp. 72W to Screw-in Replacement 2020	Retail	0%	0%	0.0	4.2	4.2	0.1	1	0	0	N/A	N/A	4,710.60 N/A	N/A	N/A
1431	CFLs (base incandescent A-line 72W) 2020	Retail	74%	74%	0.0	4.2	1.1	0.2	3	45	8	0.00	0	2,152.04	3,294.22	0.00
1432	LEDs (base incandescent A-line 72W) 2020	Retail	82%	82%	0.0	4.3	0.8	0.1	6	99	18	0.00	0	4,710.80	6,861.46	0.00
1500	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2014-2015	Retail	0%	0%	0.2	3.1	3.1	0.6	1	0	0	N/A	N/A	N/A	N/A	N/A
1501	CFLs (base incandescent A-line 53W) 2014-2015	Retail	66%	66%	0.0	3.1	1.0	0.2	3	30	5	0.00	0	1,420.56	2,174.51	0.00
1502	LEDs (base incandescent A-line 53W) 2014-2015	Retail	75%	75%	0.1	3.1	0.8	0.1	6	66	12	0.00	15	9.69	14.11	0.37
1510 1511	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2016-2017	Retail Retail	0% 66%	0% 66%	0.2	3.1	3.1 1.0	0.6	1	0 30	0	N/A 0.00	N/A 0	N/A 1.420.56	N/A 2.174.51	N/A 0.00
1511	CFLs (base incandescent A-line 53W) 2016-2017 LEDs (base incandescent A-line 53W) 2016-2017	Retail	75%	75%	0.0	3.1	0.8	0.2	6	66	12	0.00	0	3,161.81	4,605.29	0.00
1520	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2018-2019	Retail	0%	0%	0.2	3.1	3.1	0.6	1	0	0	N/A	N/A	N/A	N/A	N/A
1521	CFLs (base incandescent A-line 53W) 2018-2019	Retail	66%	66%	0.0	3.1	1.0	0.2	3	30	5	0.00	0	1,420.56	2,174.51	0.00
1522	LEDs (base incandescent A-line 53W) 2018-2019	Retail	75%	75%	0.0	3.1	0.8	0.1	6	66	12	0.00	0	3,161.81	4,605.29	0.00
1530	Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Retail	0%	0%	0.2	3.1	3.1	0.6	1	0	0	N/A	N/A	N/A	N/A	N/A
1531	CFLs (base incandescent A-line 53W) 2020	Retail	66%	66%	0.0	3.1	1.0	0.2	3	30	5	0.00	0	1,420.56	2,174.51	0.00
1532 1600	LEDs (base incandescent A-line 53W) 2020 Base CFL 18W to screw-in replacement 2014-2015	Retail Retail	75% 0%	75% 0%	0.0	3.1 1.0	0.8	0.1	6 3	66 0	12 0	0.00 N/A	0 N/A	3,161.81 N/A	4,605.29 N/A	0.00 N/A
1600	LED screw-in replacement (base CFL 18W) 2014-2015	Retail	28%	28%	0.2	1.0	0.7	0.2	6	27	5	N/A 0.12	N/A 647	0.22	0.32	N/A 15.95
1610	Base CFL 18W to screw-in replacement 2016-2017	Retail	0%	0%	0.2	1.0	1.0	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1611	LED screw-in replacement (base CFL 18W) 2016-2017	Retail	28%	28%	0.2	1.0	0.7	0.1	6	27	5	0.06	337	0.43	0.62	8.30
1620	Base CFL 18W to screw-in replacement 2018-2019	Retail	0%	0%	0.2	1.0	1.0	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1621	LED screw-in replacement (base CFL 18W) 2018-2019	Retail	28%	28%	0.1	1.0	0.7	0.1	6	27	5	0.05	269	0.53	0.78	6.62
1630	Base CFL 18W to screw-in replacement 2020	Retail	0%	0%	0.2	1.0	1.0	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1631	LED screw-in replacement (base CFL 18W) 2020	Retail	28%	28%	0.1	1.0	0.7	0.1	6	27	5	0.04	234	0.61	0.90	5.76
1700 1701	Base CFL 23W to screw-in replacement 2014-2015 LED screw-in replacement (base CFL 23W) 2014-2015	Retail Retail	0% 26%	0% 26%	0.2	1.2	1.2 0.9	0.2	3 6	0 33	0 6	N/A 0.10	N/A 540	N/A 0.27	N/A 0.39	N/A 13.30
1710	Base CFL 23W to screw-in replacement 2016-2017	Retail	0%	0%	0.3	1.2	1.2	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1711	LED screw-in replacement (base CFL 23W) 2016-2017	Retail	26%	26%	0.2	1.2	0.9	0.2	6	33	6	0.05	281	0.51	0.74	6.92
1720	Base CFL 23W to screw-in replacement 2018-2019	Retail	0%	0%	0.2	1.2	1.2	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1721	LED screw-in replacement (base CFL 23W) 2018-2019	Retail	26%	26%	0.1	1.2	0.9	0.2	6	33	6	0.04	224	0.64	0.93	5.52
1730	Base CFL 23W to screw-in replacement 2020	Retail	0%	0%	0.2	1.2	1.2	0.2	3	0	0	N/A	N/A	N/A	N/A	N/A
1731	LED screw-in replacement (base CFL 23W) 2020	Retail	26%	26%	0.1	1.2	0.9	0.2	6	33	6	0.04	195	0.74	1.07	4.80
1800 1850	BaseMetal Halide, 465W Base CFL Exit Sign	Retail Retail	0% 0%	0% 0%	0.0	0.0	0.0	0.0	18 18	0	0	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A
1851	LED Exit Sign	Retail	69%	69%	0.0	0.0	0.0	0.0	7	6	1	0.02	120	1.38	1.97	2.96
1900	Base Outdoor High Pressure Sodium 250W Lamp	Retail	0%	0%	0.0	0.7	0.7	0.0	15	0	0	N/A	N/A	N/A	N/A	N/A
1901	Outdoor Lighting Controls (Photocell/Timeclock)	Retail	25%	73%	0.1	0.9	0.7	0.0	18	18	3	0.04	234	1.71	1.82	6.10
1902	LED Outdoor Area Lighting	Retail	52%	52%	0.4	0.7	0.4	0.0	18	94	6	0.10	1,480	0.63	0.84	13.18
1903	Bi-Level LED Outdoor Lighting	Retail	69%	63%	1.2	0.7	0.2	0.0	18	101	6	0.23	3,937	0.26	0.35	31.74
2000	Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Retail	0%	0%	0.7	2.9	2.9	2.4	20	0	0	N/A	N/A	N/A	N/A	N/A
2001	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Retail	12%	12%	0.2	3.0	2.6	2.2	20	2	2	0.04	53	2.93	1.97	5.97
2003 2005	EMS - Chiller Chiller Tune Up/Diagnostics	Retail Retail	10% 8%	3% 4%	0.2	2.9 3.1	2.6	2.4 2.5	15 10	2	0	0.06 0.02	292 49	0.98 2.43	1.18 2.73	8.51 2.81
2005	Ceiling/roof Insulation - Chiller	Retail	8% 12%	4% 12%	0.1	3.1	2.9	2.5	20	0	0	0.02	49 33	4.73	3.19	3.69
2010	Duct Testing/Sealing - Chiller	Retail	19%	19%	1.0	2.9	2.3	1.9	18	5	4	0.18	219	0.65	0.45	24.69
2100	Base DX Packaged System, EER=10.3, 10 tons	Retail	0%	0%	2.0	2.9	2.9	2.4	15	0	0	N/A	N/A	N/A	N/A	N/A
2101	DX Packaged System, EER=10.9, 10 tons	Retail	6%	6%	0.2	2.9	2.7	2.2	15	47	39	0.10	123	0.99	0.73	13.81
2102	DX Packaged System, EER=13.4, 10 tons	Retail	23%	23%	0.2	2.9	2.2	1.8	15	196	162	0.03	40	3.06	2.24	4.48
2103	Geothermal Heat Pump, EER=13, 10 tons - DX	Retail	21%	21%	2.4	2.9	2.3	1.9	15	9	7	0.39	473	0.26	0.19	53.26
2105	DX Tune Up/ Advanced Diagnostics	Retail	5%	3%	0.1	3.0	2.9	2.4	10	3	1	0.07	160	0.74	0.83	9.24
2106	Prog. Thermostat - DX	Retail	5%	1%	0.1	2.9	2.8	2.4	8	24	5	0.06	270	0.58	0.82	7.89

	SUMMARY															
Measure		Building	Energy Savings	Peak Reduction	Total Costs/	Base		Peak Watts/	Service	Technical Potential	System Peak Tech. Potential	Levelized Cost of Conserved Energy	Levelized Cost of Avoided Peak Capacity	Total Resource Cost Test	Participant	Customer Payback
Number 2107	Measure Cool Roof - DX	Type	Fraction	Fraction 129/	Sq Ft	EUI 3.0	EUI 2.6	Sq Ft	Life (yrs)	GWH 38	MW 31	\$/kWH 0.06	\$/kW 68	(TRC) 1.17	Test 1.00	(Years) 7.65
2107	Optimize Controls - DX	Retail Retail	13% 5%	13% 1%	0.2	3.0	2.8	2.2	10 5	14	31	0.08	127	0.78	1.19	3.71
2108	Economizer - DX	Retail	26%	7%	0.5	3.2	2.4	2.5	10	73	16	0.05	277	0.78	0.95	8.08
2110	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Retail	4%	1%	0.3	2.9	2.8	2.4	10	0	0	0.11	504	0.71	0.53	14.70
2111	Economizer Repair - DX	Retail	29%	41%	0.1	3.2	2.3	1.6	5	60	70	0.03	22	1.43	1.26	3.50
2111	Duct Testing/Sealing - DX	Retail	19%	19%	1.0	2.9	2.3	1.9	18	52	43	0.18	219	0.65	0.45	24.69
2112	Duct/Pipe Insulation - DX	Retail	2%	2%	0.8	2.9	2.8	2.4	10	6	5	1.29	1,564	0.05	0.43	175.99
2114	Window Film (Standard) - DX	Retail	2%	2%	0.0	2.9	2.9	2.4	10	3	3	0.14	174	0.46	0.39	19.58
2200	Base Heat Pump (13 SEER, 7.7 HSPF)	Retail	0%	0%	0.0	2.9	2.9	2.4	15	0	0	N/A	N/A	N/A	N/A	N/A
2201	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	13%	13%	0.1	2.9	2.5	2.1	15	39	32	0.02	28	4.28	3.13	3.20
2300	Base PTAC, EER=8.3, 1 ton	Retail	0%	0%	0.0	2.9	2.9	2.4	15	0	0	N/A	N/A	N/A	N/A	N/A
3000	Base Fan Motor, 5hp, 1800rpm, 87.5%	Retail	0%	0%	0.0	2.2	2.2	0.6	20	0	0	N/A	N/A	N/A	N/A	N/A
3001	Fan Motor, 5hp, 1800rpm, 89.5%	Retail	2%	2%	0.0	2.2	2.2	0.6	20	9	3	0.02	84	3.59	3.67	3.21
3002	Variable Speed Drive Control, 5 HP	Retail	30%	8%	0.1	2.3	1.6	0.6	15	168	12	0.02	219	3.46	4.79	2.09
3002	Demand Controlled Ventilation	Retail	15%	29%	2.4	2.2	1.9	0.4	15	61	32	0.69	1.294	0.12	0.11	93.80
3100	Base Fan Motor, 15hp, 1800rpm, 91.0%	Retail	0%	0%	0.1	2.2	2.2	0.6	20	0.	0	N/A	N/A	N/A	N/A	N/A
3101	Fan Motor, 15hp, 1800rpm, 92.4%	Retail	2%	2%	0.0	2.3	2.2	0.6	20	0	0	0.11	398	0.76	0.77	15.19
3102	Variable Speed Drive Control, 15 HP	Retail	30%	8%	0.3	2.3	1.6	0.6	15	6	0	0.04	634	1.20	1.66	6.05
3103	Air Handler Optimization, 15 HP	Retail	10%	3%	0.0	2.2	2.0	0.6	8	2	0	0.01	188	2.30	3.62	1.79
3104	Electronically Commutated Motors (ECM) on an Air Handler Unit	Retail	14%	13%	0.1	2.2	1.9	0.5	15	3	1	0.03	100	2.57	2.91	3.45
3105	Energy Recovery Ventilation (ERV)	Retail	7%	13%	0.4	2.2	2.1	0.5	20	1	1	0.25	461	0.44	0.35	33.42
3107	Demand Controlled Ventilation	Retail	15%	29%	2.4	2.2	1.9	0.4	15	2	1	0.69	1.294	0.12	0.11	93.80
3200	Base Fan Motor, 40hp, 1800rpm, 93.0%	Retail	0%	0%	0.1	2.2	2.2	0.6	20	0	0	N/A	N/A	N/A	N/A	N/A
3201	Fan Motor, 40hp, 1800rpm, 94.1%	Retail	1%	1%	0.0	2.3	2.2	0.6	20	0	0	0.17	622	0.49	0.50	23.73
3202	Variable Speed Drive Control, 40 HP	Retail	30%	8%	0.3	2.3	1.6	0.6	15	6	0	0.04	620	1.22	1.69	5.92
3203	Air Handler Optimization, 40 HP	Retail	10%	3%	0.0	2.2	2.0	0.6	8	2	0	0.01	188	2.30	3.62	1.79
3204	Demand Controlled Ventilation	Retail	15%	29%	2.4	2.2	1.9	0.4	15	2	1	0.69	1,294	0.12	0.11	93.80
4000	Base Built-Up Refrigeration System	Retail	0%	0%	0.0	0.0	0.0	0.0	10	0	0	N/A	N/A	N/A	N/A	N/A
4100	Base Self-Contained Refrigeration	Retail	0%	0%	0.0	1.1	1.1	0.2	10	0	0	N/A	N/A	N/A	N/A	N/A
4101	Strip curtains for walk-ins (self-contained)	Retail	1%	1%	0.0	1.1	1.1	0.2	4	0	0	0.59	3,859	0.03	0.05	79.87
4103	Night covers for display cases (self-contained)	Retail	9%	9%	0.0	1.1	1.0	0.2	5	9	1	0.00	25	5.63	8.69	0.51
4104	Freezer-Cooler Replacement Gaskets (self-contained)	Retail	4%	4%	0.0	1.1	1.1	0.2	4	10	2	0.01	75	1.49	2.34	1.56
4105	Bi-level LED Case Lighting (self-contained units) 2014	Retail	3%	3%	0.1	1.1	1.1	0.2	8	2	0	0.17	1.106	0.20	0.28	22.89
4106	Energy-Star Refrigerator, solid door	Retail	2%	2%	0.0	1.1	1.1	0.2	10	1	0	0.07	489	0.55	0.76	10.13
4107	Energy-Star Freezer, solid door	Retail	1%	1%	0.0	1.1	1.1	0.2	9	1	0	0.05	355	0.68	0.96	7.36
4108	Energy-Star Refrigerator, glass door	Retail	10%	10%	0.1	1.1	1.0	0.2	10	8	1	0.07	462	0.58	0.80	9.57
4109	Energy-Star Freezer, glass door	Retail	3%	3%	0.0	1.1	1.1	0.2	9	2	0	0.02	145	1.67	2.36	3.00
4110	Energy Star Ice Machines	Retail	1%	1%	0.0	1.1	1.1	0.2	10	1	0	0.20	1.324	0.20	0.28	27.40
4112	Reach-in unit occupancy sensors	Retail	2%	2%	0.0	1.1	1.1	0.2	10	1	0	0.17	1,143	0.23	0.32	23.66
5000	Base Desktop PC	Retail	0%	0%	0.0	0.0	0.0	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5001	PC Network Power Management Enabling	Retail	67%	34%	0.0	0.1	0.0	0.0	4	10	1	0.00	53	3.35	5.59	0.65
5002	Energy Star or Better PC	Retail	33%	33%	0.0	0.1	0.0	0.0	4	3	1	0.00	27	3.61	5.49	0.66
5100	Base Laptop PC	Retail	0%	0%	0.0	0.0	0.0	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5101	Laptop Network Power Management Enabling	Retail	7%	7%	0.0	0.0	0.0	0.0	4	0	0	0.37	2.050	0.05	0.07	49.82
5102	Energy Star or Better Laptop	Retail	30%	30%	0.0	0.0	0.0	0.0	4	0	0	0.00	21	4.69	7.12	0.51
5200	Base Monitor, CRT	Retail	0%	0%	0.0	0.0	0.0	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5201	Energy Star or Better Monitor - CRT	Retail	56%	56%	0.0	0.0	0.0	0.0	4	3	0	0.00	3	37.31	56.64	0.06
5202	Monitor Power Management Enabling - CRT	Retail	52%	27%	0.0	0.0	0.0	0.0	4	1	0	0.00	27	6.52	10.89	0.34
5203	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Retail	15%	15%	0.0	0.0	0.0	0.0	4	0	0	0.03	142	0.70	1.06	3.45
5300	Base Monitor, LCD	Retail	0%	0%	0.0	0.0	0.0	0.0	4	0	0	N/A	N/A	N/A	N/A	N/A
5301	Energy Star or Better Monitor - LCD	Retail	21%	21%	0.0	0.0	0.0	0.0	4	0	0	0.00	17	5.75	8.73	0.42
5302	Monitor Power Management Enabling - LCD	Retail	19%	10%	0.0	0.0	0.0	0.0	4	0	0	0.02	269	0.66	1.10	3.33
5302	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Retail	14%	4%	0.0	0.0	0.0	0.0	4	0	0	0.02	1.464	0.22	0.40	9.17

Commercial Electric New Construction																
DSM ASS	YST SUMMARY															
			F=====	Peak	Total			Peak		Technical	System Peak Tech.	Levelized Cost of Conserved	Levelized Cost of Avoided	Total Resource		Customer
Measure		Building	Energy Savings	Reduction	Costs/	Base		Peak Watts/	Service	Potential	Peak rech. Potential	Energy	Peak Capacity	Cost Test	Participant	Payback
Number	Measure	Type	Fraction	Fraction	Sa Ft	EUI	EUI	Sq Ft	Life (yrs)	GWH	MW	\$/kWH	\$/kW	(TRC)	Test	(Years)
100	Base Bldg Design - 15%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
101	High Performance Building/Int Design - Tier 1 15% - Office	Office	15%	20%	1.7	26.1	22.1	4.8	20	7	2	0.04	145	2.04	2.04	5.76
200	Base Bldg Design - 30%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
201	High Performance Building/Int Design - Tier 2 30% - Office	Office	31%	39%	2.5	26.1	18.1	3.6	20	11	3	0.03	104	2.85	2.86	4.11
300	Base Bldg Design - 50%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
301	High Performance Building/Int Design - Tier 3 50% - Office	Office	51%	65%	4.3	26.1	12.8	2.1	20	4	1	0.03	109	2.71	2.72	4.32
400	Base Bldg Design - 70%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
401	High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	Office	71%	91%	6.8	26.1	7.5	0.5	20	1	0	0.04	122	2.42	2.43	4.85
100	Base Bldg Design - 15%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
101	High Performance Building/Int Design - Tier 1 15% - Office	Office	15%	20%	1.4	26.1	22.1	4.8	20	0	0	0.04	122	2.43	2.43	4.83
200	Base Bldg Design - 30%	Office	0%	0%	0.0	26.1	26.1	5.9	20	Ō	0	N/A	N/A	N/A	N/A	N/A
201	High Performance Building/Int Design - Tier 2 30% - Office	Office	31%	39%	2.1	26.1	18.1	3.6	20	0	0	0.03	87	3.40	3.41	3.45
300	Base Bldg Design - 50%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
301	High Performance Building/Int Design - Tier 3 50% - Office	Office	51%	65%	3.6	26.1	12.8	2.1	20	0	0	0.03	92	3.24	3.25	3.62
400	Base Bldg Design - 70%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
401	High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	Office	71%	91%	5.7	26.1	7.5	0.5	20	0	0	0.03	103	2.88	2.89	4.07
100	Base Bldg Design - 15%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
101	High Performance Building/Int Design - Tier 1 15% - Office	Office	15%	20%	1.7	26.1	22.1	4.8	20	1	0	0.04	145	2.04	2.04	5.76
200	Base Bldg Design - 30%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
201	High Performance Building/Int Design - Tier 2 30% - Office	Office	31%	39%	2.5	26.1	18.1	3.6	20	2	0	0.03	104	2.85	2.86	4.11
300	Base Bldg Design - 50%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
301	High Performance Building/Int Design - Tier 3 50% - Office	Office	51%	65%	4.3	26.1	12.8	2.1	20	1	0	0.03	109	2.71	2.72	4.32
400	Base Bldg Design - 70%	Office	0%	0%	0.0	26.1	26.1	5.9	20	0	0	N/A	N/A	N/A	N/A	N/A
401	High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	Office	71%	91%	6.8	26.1	7.5	0.5	20	0	0	0.04	122	2.42	2.43	4.85
100	Base Bldg Design - 15%	Restaurant	0%	0%	0.0	27.2	27.2	5.8	20	0	0	N/A	N/A	N/A	N/A	N/A
102	High Performance Building/Int Design - Tier 1 15% - Restaurant	Restaurant	15%	20%	2.1	27.2	23.0	4.6	20	3	1	0.05	184	1.69	1.73	6.81
200	Base Bldg Design - 30%	Restaurant	0%	0%	0.0	27.2	27.2	5.8	20	0	0	N/A	N/A	N/A	N/A	N/A
202	High Performance Building/Int Design - Tier 2 30% - Restaurant	Restaurant	30%	39%	3.0	27.2	18.9	3.5	20	5	1	0.04	132	2.36	2.42	4.86
300	Base Bldg Design - 50%	Restaurant	0%	0%	0.0	27.2	27.2	5.8	20	0	0	N/A	N/A	N/A	N/A	N/A
302	High Performance Building/Int Design - Tier 3 50% - Restaurant	Restaurant	51%	65%	5.3	27.2	13.4	2.0	20	2	0	0.04	138	2.25	2.30	5.10
400	Base Bldg Design - 70%	Restaurant	0%	0%	0.0	27.2	27.2	5.8	20	0	0	N/A	N/A	N/A	N/A	N/A
402	High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaurant	Restaurant	71%	91%	8.3	27.2	7.9	0.5	20	0	0	0.04	155	2.00	2.05	5.73
100	Base Bldg Design - 15%	Restaurant	0%	0%	0.0	27.2	27.2	5.8	20	Ō	0	N/A	N/A	N/A	N/A	N/A
102	High Performance Building/Int Design - Tier 1 15% - Restaurant	Restaurant	15%	20%	1.8	27.2	23.0	4.6	20	0	0	0.04	155	2.01	2.06	5.71
200	Base Bldg Design - 30%	Restaurant	0%	0%	0.0	27.2	27.2	5.8	20	0	0	N/A	N/A	N/A	N/A	N/A
202	High Performance Building/Int Design - Tier 2 30% - Restaurant	Restaurant	30%	39%	2.5	27.2	18.9	3.5	20	0	0	0.03	110	2.81	2.88	4.08
300	Base Bldg Design - 50%	Restaurant	0%	0%	0.0	27.2	27.2	5.8	20	0	0	N/A	N/A	N/A	N/A	N/A
302	High Performance Building/Int Design - Tier 3 50% - Restaurant	Restaurant	51%	65%	4.4	27.2	13.4	2.0	20	Ö	0	0.03	116	2.68	2.75	4.28
400	Base Bldg Design - 70%	Restaurant	0%	0%	0.0	27.2	27.2	5.8	20	0	0	N/A	N/A	N/A	N/A	N/A
402	High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaurant	Restaurant	71%	91%	7.0	27.2	7.9	0.5	20	0	0	0.04	130	2.39	2.45	4.81

G. SUPPLY-CURVE DATA

APPENDIX G

SUPPLY CURVE DATA

Residential Electric Existing Construction

Energy Supply Curve

Measure		Measure GWH	Cumulative Measure GWH	Levelized Energy Cost
Number	Measure	Savings	Savings	\$/kWH
3832	LEDs (base Halogen (Specialty) 6 hrs/day) 2020	219	219	0.00
3732	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	330	549	0.00
7101 7501	Energy Star LCD TV	135 61	684 745	0.00
3232	Energy Star Desktop PC	384	745 1,129	0.00
3232	LEDs (base Halogen 6 hrs/day) 2020	384 634	1,764	0.00
7001	LEDs (base Halogen 2.5 hrs/day) 2020 Energy Star Plasma TV	14	1,764	0.01
2116	Duct Insulation (HP heating early replacement)	4	1,783	0.01
2016	Duct Insulation (HP heating)	25	1,807	0.01
3632	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	80	1,887	0.01
1117	Duct Insulation (CAC early replacement)	3	1,891	0.01
2201	Air Source Heat Pump (resistance heating)	347	2,237	0.01
1219	Duct Insulation (HP cooling)	18	2,255	0.01
1024	Self Install Weatherization (CAC)	27	2,282	0.01
1122	Self Install Weatherization (CAC early replacement)	7	2.289	0.01
7401	Energy Star DVD Player	31	2,320	0.01
1319	Duct Insulation (HP cooling Early Replacement)	3	2,323	0.02
5006	Pipe Wrap	116	2,439	0.02
4701	2nd Freezer Recycling	19	2,458	0.02
5007	Hot water turndown 5 degrees	14	2,473	0.02
5008	Hot water turndown 10 degrees	19	2,492	0.02
5009	Hot water turndown 15 degrees	5	2,496	0.02
5010	Hot water turndown 20 degrees	2	2,498	0.02
3531	LEDs (base CFL 6 hrs/day) 2020	30	2,528	0.02
2121	Self Install Weatherization (HP heating early replacement)	7	2,535	0.02
5015	Low Flow Showerhead 1.5 Gal/Min	111	2,646	0.02
2216	Self Install Weatherization	17	2,662	0.02
2021	Self Install Weatherization (HP heating)	36	2,698	0.02
9901	Indirect Feedback	457	3,155	0.02
7601	Energy Star Laptop PC	15	3,170	0.03
1413	Self Install Weatherization (RAC)	2	3,172	0.03
4201	2nd Refrigerator Recycling	480	3,652	0.03
1701 6002	ECM Furnace Fan (variable speed motor) - Cooling	926	4,578	0.03
3032	Variable-Speed Pool Pump (<1 hp)	211 143	4,789 4,932	0.03 0.04
3902	LEDs (base Halogen 0.5 hrs/day) 2020 ROB 2L4'T8, 1EB	241	5,173	0.04
1223	Self Install Weatherization (HP cooling)	26	5,173	0.04
4601	Freezer - Early Replacement (Energy Star)	63	5,199	0.04
2217	Door Weatherization (resistance heating)	31	5,293	0.04
1323	Self Install Weatherization (HP cooling Early Replacement)	4	5,297	0.04
3431	LEDs (base CFL 2.5 hrs/day) 2020	46	5,343	0.04
4001	Refrigerator (Energy Star)	211	5,553	0.04
5602	High Efficiency CD (EF=3.01 w/moisture sensor)	253	5,806	0.04
5014	Faucent Aerators	72	5,879	0.05
2214	Programmable Thermostat (resistance heating)	21	5,900	0.05
1022	Programmable Thermostat (CAC)	14	5.914	0.05
1120	Programmable Thermostat (CAC early replacement)	2	5,916	0.05
5005	DHW Tank Wrap	191	6,107	0.05
4501	Freezer (Energy Star)	42	6,149	0.05
5011	Drain Water Heat Recovery (GFX)	132	6,280	0.05
1123	Door Weatherization (CAC early replacement)	9	6,289	0.06
2119	Programmable Thermostat (HP heating early replacement)	8	6,297	0.06
2019	Programmable Thermostat (HP heating)	47	6,344	0.06
9902	Direct Feedback	1,421	7,765	0.06
1221	Programmable Thermostat (HP cooling)	33	7,798	0.07
5003	Heat Pump Water Heater - Energy Star	443	8,240	0.07
1021	Return Duct Modification (CAC)	13	8,254	0.07
2122	Door Weatherization (HP heating early replacement)	7	8,260	0.07
2022	Door Weatherization (HP heating)	38	8,298	0.07
5101	Heat Pump Water Heater - Energy Star - Early Replacement	95	8,392	0.07
1119	Return Duct Modification (CAC early replacement)	2	8,395	0.07

Residential Electric Existing Construction	
Capacity Supply Curve	

			Cumulative	Levelized
Measure		Measure MW	Measure MW	Capacity Cost
Number	Measure	Savings	Savings	\$/kW
3832	LEDs (base Halogen (Specialty) 6 hrs/day) 2020	25	25	0.01
3732	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	37	61	0.02
1117	Duct Insulation (CAC early replacement)	2	63	0.02
1219	Duct Insulation (HP cooling)	11	74	0.02
1024	Self Install Weatherization (CAC)	16	90	0.02
1122	Self Install Weatherization (CAC early replacement)	4	94	0.02
7101	Energy Star LCD TV	19	114	0.03
1319	Duct Insulation (HP cooling Early Replacement)	2	115	0.03
7501	Energy Star Desktop PC	8 43	123 166	0.03 0.04
3232 1413	LEDs (base Halogen 6 hrs/day) 2020	43 1	166 167	0.04
1701	Self Install Weatherization (RAC) ECM Furnace Fan (variable speed motor) - Cooling	475	642	0.05
7001	Energy Star Plasma TV	2	644	0.05
3132	LEDs (base Halogen 2.5 hrs/day) 2020	71	715	0.06
1223	Self Install Weatherization (HP cooling)	15	731	0.06
1323	Self Install Weatherization (HP cooling Early Replacement)	2	733	0.07
2116	Duct Insulation (HP heating early replacement)	1	734	0.08
2016	Duct Insulation (HP heating)	3	737	0.08
1022	Programmable Thermostat (CAC)	8	745	0.08
1120	Programmable Thermostat (CAC early replacement)	1	746	0.08
1123	Door Weatherization (CAC early replacement)	5	752	0.10
9901	Indirect Feedback	113	865	0.10
7401	Energy Star DVD Player	4	869	0.10
3632	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	9	878	0.11
1221	Programmable Thermostat (HP cooling)	19	898	0.11
1021	Return Duct Modification (CAC)	8	905	0.12
2201	Air Source Heat Pump (resistance heating)	41	947	0.12
1119	Return Duct Modification (CAC early replacement)	1	948	0.12
4701	2nd Freezer Recycling	3	951 075	0.12
1025 1324	Door Weatherization (CAC) Door Weatherization (HP cooling Early Replacement)	24 4	975 979	0.12 0.12
1324 1224	Door Weatherization (HP cooling Early Replacement) Door Weatherization (HP cooling)	4 21	1,000	0.12
1004	Proper Refrigerant Charging and Air Flow (CAC)	21 97	1,000	0.13
1202	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	212	1,309	0.14
1102	Proper Refrigerant Charging and Air Flow (CAC early replacement)	19	1,328	0.14
5006	Pipe Wrap	14	1,342	0.15
	t pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replaceme	34	1,375	0.15
5007	Hot water turndown 5 degrees	2	1,377	0.16
5008	Hot water turndown 10 degrees	2	1,380	0.16
5009	Hot water turndown 15 degrees	1	1,380	0.16
5010	Hot water turndown 20 degrees	0	1,380	0.16
1204	Proper Refrigerant Charging and Air Flow (HP cooling)	74	1,455	0.17
4201	2nd Refrigerator Recycling	78	1,533	0.17
1019	Duct Insulation (CAC)	2	1,534	0.17
	Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement)	11	1,546	0.19
5015	Low Flow Showerhead 1.5 Gal/Min	14	1,559	0.19
7601	Energy Star Laptop PC	2	1,561	0.19
2121	Self Install Weatherization (HP heating early replacement)	1	1,562 1,565	0.20
1321 1414	Programmable Thermostat (HP cooling Early Replacement) Door Weatherization (RAC)	3 2	1,565 1,566	0.20 0.20
1414 2216	Self Install Weatherization	2	1,566	0.20
3531	Self install Weatherization LEDs (base CFL 6 hrs/day) 2020	3	1,568 1,572	0.20
2021	Self Install Weatherization (HP heating)	4	1,572	0.20
1001	14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	75	1,651	0.20
1116	Cool Roof (CAC early replacement)	22	1,673	0.24
4601	Freezer - Early Replacement (Energy Star)	10	1,683	0.24
9902	Direct Feedback	352	2,035	0.25
4001	Refrigerator (Energy Star)	34	2,069	0.26
5602	High Efficiency CD (EF=3.01 w/moisture sensor)	43	2,112	0.26
6002	Variable-Speed Pool Pump (<1 hp)	25	2,137	0.27
1002	15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	66	2,203	0.27

SUPPLY CURVE DATA

Residential Electric Existing Construction

Energy Supply Curve

easure	Supply Surve	Measure GWH	Cumulative Measure GWH	Levelized Energy Cost
lumber	Measure	Savings	Savings	\$/kWH
1025	Door Weatherization (CAC)	40	8,435	0.07
7502	Plug Load Controls - Smart Power Strip (base Desktop PC)	140	8,575	0.07
1324	Door Weatherization (HP cooling Early Replacement)	7	8,581	0.07
1224	Door Weatherization (HP cooling)	36	8,617	80.0
1004	Proper Refrigerant Charging and Air Flow (CAC)	163	8,781	0.08
1202	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	356	9,137	80.0
1102	Proper Refrigerant Charging and Air Flow (CAC early replacement)	32	9,169	0.09
	eat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early replacemen	48	9,217	0.09
2002	Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	270	9,487	0.09
	t pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replacement	56	9,543	0.09
1204	Proper Refrigerant Charging and Air Flow (HP cooling)	125	9,669	0.10
1019	Duct Insulation (CAC)	3	9,671	0.10
4101	Refrigerator - Early Replacement (Energy Star)	82	9,754	0.10
	Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement	19	9,773	0.11
1321	Programmable Thermostat (HP cooling Early Replacement)	4	9,777	0.12
1414	Door Weatherization (RAC)	3	9,780	0.12
2012	Crawlspace insulation (HP heating)	15	9,795	0.13
1001	14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	127	9,922	0.14
2112	Crawlspace insulation (HP heating early replacement)	3	9,925	0.14
1116	Cool Roof (CAC early replacement)	37	9,962	0.14
2203	Ceiling R-0 to R-38 Insulation (resistance heating)	54	10,017	0.15
2209	Crawlspace insulation (resistance heating)	6	10,022	0.16
1002	15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	111	10,133	0.16
2106	Ceiling R-0 to R-38 Insulation (HP heating early replacement)	17	10,150	0.16
5004	Solar Domestic Water Heating	1,068	11,218	0.16
2213	Heat Recovery Ventilators (resistance heating)	259	11,478	0.17
2118	Heat Recovery Ventilators (HP heating early replacement)	97	11,574	0.17
2018	Heat Recovery Ventilators (HP heating)	543	12,118	0.17
1218	Cool Roof (HP cooling)	168	12,285	0.17
1125	Whole House Fans (CAC early replacement)	58	12,343	0.17
2006	Ceiling R-0 to R-38 Insulation (HP heating)	88	12,432	0.18
1601	10% better than Energy Star Dehumidifier ROB (35-45 pints/day)	5	12,436	0.18
2210	Basement insulation R-13 (resistance heating)	48	12,484	0.19
2215	Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating)	45	12,529	0.19
2013	Basement insulation R-13 (HP heating)	68	12,597	0.19
1318	Cool Roof (HP cooling Early Replacement)	26	12,623	0.19
1005	Proper Sizing and Quality Install (CAC)	176	12,800	0.20
2113	Basement insulation R-13 (HP heating early replacement)	12	12,812	0.20
	nprehensive Shell Air Sealing - Inf. Reduction (HP heating early replacem	16	12,828	0.20
3331	LEDs (base CFL 0.5 hrs/day) 2020	11	12,839	0.21
2020	Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	91	12,930	0.21
1226	Whole House Fans (HP cooling)	262	13,192	0.21
1003	17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	170	13,362	0.23
1326 2117	Whole House Fans (HP cooling early replacement)	41 5	13,403	0.24
	Duct Testing and Sealing (HP heating early replacement)		13,407	0.24
1411	Cool Roof (RAC)	14	13,421	0.24
1103	Proper Sizing and Quality Install (CAC early replacement)	29	13,450	0.25
2017	Duct Testing and Sealing (HP heating)	24 9	13,474	0.27
1014	Crawlspace insulation (CAC)	-	13,483	0.27
1416	Whole House Fans (RAC)	21	13,504	0.30
1112	Crawlspace insulation (CAC early replacement)	1 18	13,506	0.30
2218	WINDOWS - Double-Glazed Clear to Energy Star (resistance heating)	10	13,523	0.31

Residential Electric Existing Construction Capacity Supply Curve

Measure		Measure MW	Cumulative Measure MW	Levelized Capacity Cost
Number	Measure	Savings	Savings	\$/kW
1218	Cool Roof (HP cooling)	100	2,302	0.29
1125	Whole House Fans (CAC early replacement)	35	2,337	0.29
1601	10% better than Energy Star Dehumidifier ROB (35-45 pints/day)	3	2,340	0.29
3032	LEDs (base Halogen 0.5 hrs/day) 2020	16	2,356	0.32
3902	ROB 2L4'T8, 1EB	27	2,383	0.32
1318	Cool Roof (HP cooling Early Replacement)	16	2,398	0.32
1005	Proper Sizing and Quality Install (CAC)	105	2,503	0.32
4501	Freezer (Energy Star)	7	2,510	0.33
2217	Door Weatherization (resistance heating)	4	2,510	0.33
1226	Whole House Fans (HP cooling)	155	2,669	0.36
5014	Faucent Aerators	9	2,678	0.37
3431	LEDs (base CFL 2.5 hrs/day) 2020	5	2,683	0.37
1003	17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	101	2,784	0.37
2214	Programmable Thermostat (resistance heating)	3	2,786	0.39
1326	Whole House Fans (HP cooling early replacement)	3 24	2,766	0.39
1411	Cool Roof (RAC)	8		0.40
5005		23	2,819	0.41
1103	DHW Tank Wrap	23 17	2,842 2,859	0.42
5011	Proper Sizing and Quality Install (CAC early replacement) Drain Water Heat Recovery (GFX)	16	2,875	0.42
1014	Crawlspace insulation (CAC)	6	2,881	0.44
	Programmable Thermostat (HP heating early replacement)	1		
2119 1416	Whole House Fans (RAC)	13	2,882	0.49
2019		6	2,894	0.50
1112	Programmable Thermostat (HP heating)	1	2,900	0.50
1402	Crawlspace insulation (CAC early replacement) HE Room Air Conditioner - CEE Tier 1 EER 11.3	3	2,901	0.51 0.52
		3 18	2,904	
7502 1205	Plug Load Controls - Smart Power Strip (base Desktop PC)	18 67	2,922	0.55
5003	Proper Sizing and Quality Install (HP cooling)	67 55	2,989	0.55
5101	Heat Pump Water Heater - Energy Star	55 12	3,044 3,055	0.56 0.57
2122	Heat Pump Water Heater - Energy Star - Early Replacement	12	3,056	0.57
1023	Door Weatherization (HP heating early replacement)	39		
2022	Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	39 4	3,095	0.58
	Door Weatherization (HP heating)	4 28	3,100	0.58
1008 1214	Ceiling R-0 to R-38 Insulation (CAC)	28 4	3,127	0.59
	Crawlspace insulation (HP cooling)	4 13	3,131	0.59
4101	Refrigerator - Early Replacement (Energy Star)	10	3,144	0.62
1305 1113	Proper Sizing and Quality Install (HP cooling Early Replacement)	5	3,155	0.63
	Basement insulation R-13 (CAC early replacement)	5 5	3,160	0.63
1106 1029	Ceiling R-0 to R-38 Insulation (CAC early replacement)	78	3,164	0.64 0.66
1314	WINDOWS - Default With Sunscreen (CAC)	76 1	3,242	0.67
	Crawlspace insulation (HP cooling Early Replacement)	6	3,243	
	comprehensive Shell Air Sealing - Inf. Reduction (CAC early replacement)	2	3,248	0.71
	INDOWS - Double-Glazed Clear to Energy Star (CAC early replacement	21	3,250	0.72
1215	Basement insulation R-13 (HP cooling)		3,271	0.73
	at pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early replacemer	6 11	3,277	0.73
1417	Window Film (RAC)		3,287	0.74
2002	Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	32 21	3,319	0.74
1208	Ceiling R-0 to R-38 Insulation (HP cooling)		3,341	0.75
1026	Ceiling Fans (CAC)	11	3,352	0.80
1222	Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)	27	3,379	0.80
1308	Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	3	3,382	0.82
1118	Duct Testing and Sealing (CAC early replacement)	1	3,383	0.83
1315	Basement insulation R-13 (HP cooling Early Replacement)	3	3,387	0.84

APPENDIX G SUPPLY CURVE DATA

Resident	ial Electric New Co	onstructio	n	
Energy Su	pply Curve			
			Cumulative	Levelized
		Measure	Measure	Energy
Measure		GWH	GWH	Cost
Number	Measure	Savings	Savings	\$/kWH
101	Energy Star Home	65	65	0.06

Residentia	Residential Electric New Construction										
Capacity Su	pply Curve										
			Cumulative	Levelized							
		Measure	Measure	Capacity							
Measure		MW	MW	Cost							
Number	Measure	Savings	Savings	\$/kW							
101	Energy Star Home	6	6	0.70							

Comm	necial Electric Existing Construction				Comm	ecial Electric Existing Construction			
Energy	Supply Curve	Measure	Cumulative Measure	Levelized Energy	Capacit	y Supply Curve	Measure	Cumulative Measure	Levelized Capacity
Measure Number	Measure	GWH Savings	GWH Savings	Cost \$/kWH	Measure Number	Measure	MW Savings	MW Savings	Cost \$/kW
5701	Data Center Improved Operations	233	233	0.00	5701	Data Center Improved Operations	39	39	0.00
5201	Energy Star or Better Monitor - CRT	32	265	0.00	5702	Data Center Best Practices	44	83	0.01
5602	ENERGY STAR Printer	25	290	0.00	5201	Energy Star or Better Monitor - CRT	5	88	0.01
5702	Data Center Best Practices	267	556	0.00	5602	ENERGY STAR Printer	4	91	0.01
5401	Energy Star or Better Copier	10	566	0.00	5401	Energy Star or Better Copier	2	93	0.01
5703	Data Center State of the Art practices	102	669	0.00	5703	Data Center State of the Art practices	17	110	0.02
4103	Night covers for display cases (self-contained)	69	738	0.00	2010	Ceiling/roof Insulation - Chiller	10	119	0.02
1332	LEDs (base incandescent flood) 2020	1,205	1,943	0.00	4103	Night covers for display cases (self-contained)	10	130	0.02
1203	Lighting Control Tuneup (base other fluorescent fixture)	4	1,947	0.01	1332	LEDs (base incandescent flood) 2020	214	344	0.03
1432	LEDs (base incandescent A-line 72W) 2020	424	2,371	0.01	1432	LEDs (base incandescent A-line 72W) 2020	75	419	0.03
5502	ENERGY STAR Multi-Function Printer	3	2,374	0.01	2201	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	221	640	0.04
1532	LEDs (base incandescent A-line 53W) 2020	279 8	2,653 2,660	0.01 0.01	5502 1532	ENERGY STAR Multi-Function Printer	1 50	641 690	0.04 0.05
5301 5102	Energy Star or Better Monitor - LCD Energy Star or Better Laptop	3	2,664	0.01	2113	LEDs (base incandescent A-line 53W) 2020 Ceiling/roof Insulation - DX	10	701	0.05
1801	T5 (240W) (base metal halide)	213	2,877	0.01	5301	Energy Star or Better Monitor - LCD	10	701	0.06
4104	Freezer-Cooler Replacement Gaskets (self-contained)	38	2,915	0.01	1203	Lighting Control Tuneup (base other fluorescent fixture)	0	702	0.06
4109	Energy-Star Freezer, glass door	19	2,934	0.01	2001	Centrifugal Chiller, 0.51 kW/ton, 500 tons	82	784	0.07
5001	PC Network Power Management Enabling	109	3,043	0.01	1801	T5 (240W) (base metal halide)	37	821	0.07
2010	Ceiling/roof Insulation - Chiller	14	3.057	0.01	5102	Energy Star or Better Laptop	0	821	0.07
1036	Lighting Control Tuneup (base 4L4'T8), 2020	39	3,096	0.02	2102	DX Packaged System, EER=13.4, 10 tons	750	1,571	0.08
4007	Efficient compressor motor	1	3,097	0.02	4104	Freezer-Cooler Replacement Gaskets (self-contained)	6	1,576	0.08
5202	Monitor Power Management Enabling - CRT	6	3,103	0.02	4109	Energy-Star Freezer, glass door	3	1,579	0.09
4011	Demand Hot Gas Defrost	13	3,116	0.02	2013	High Efficiency Chiller Motors	1	1,581	0.10
1136	Lighting Control Tuneup (base 2L4'T8), 2020	6	3,122	0.02	4007	Efficient compressor motor	0	1,581	0.10
4106	Energy-Star Refrigerator, solid door	24	3,146	0.02	2005	Chiller Tune Up/Diagnostics	3	1,583	0.11
1038	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	383	3,529	0.02	4011	Demand Hot Gas Defrost	2	1,585	0.11
4009	Floating head pressure controls	1	3,530	0.02	1031	ROB 4L4' High Performance T8 (86 W), 2020	87	1,672	0.13
1031	ROB 4L4' High Performance T8 (86 W), 2020	494	4,024	0.02	2111	Economizer Repair - DX	109	1,781	0.13
8001	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	12	4,036	0.03	4106	Energy-Star Refrigerator, solid door	4	1,785	0.14
5002	Energy Star or Better PC	37	4,074	0.03		High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	54	1,838	0.15
7001 2201	Vending Misers (Refrigerated units)	23 314	4,096 4.410	0.03 0.03	2006 3104	VSD for Chiller Pumps and Towers Electronically Commutated Motors (ECM) on an Air Handler Unit	7 30	1,845 1.875	0.15
1131	Heat Pump Upgrade (15 SEER, 8.2 HSPF) ROB 2L4' High Performance T8 (86 W), 2020	96	4,410	0.03	2301	HE PTAC, EER=9.6, 1 ton	30 48	1,875	0.16 0.16
1806	Occupancy Sensor, High Bay T5	13	4,519	0.03	3001	Fan Motor, 5hp, 1800rpm, 89.5%	11	1,934	0.10
3203	Air Handler Optimization, 40 HP	71	4,591	0.03	1131	ROB 2L4' High Performance T8 (86 W), 2020	17	1,951	0.17
1138	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	77	4.667	0.03	1036	Lighting Control Tuneup (base 4L4'T8), 2020	3	1,954	0.17
6007	Heat Trap	31	4,698	0.03	5002	Energy Star or Better PC	6	1,960	0.18
4107	Energy-Star Freezer, solid door	8	4,706	0.03	5001	PC Network Power Management Enabling	8	1,968	0.18
3002	Variable Speed Drive Control, 5 HP	643	5,349	0.03	1851	LED Exit Sign	6	1,974	0.19
1851	LED Exit Sign	35	5,384	0.03	4107	Energy-Star Freezer, solid door	1	1,975	0.22
3102	Variable Speed Drive Control, 15 HP	268	5,651	0.04	6007	Heat Trap	5	1,980	0.22
2005	Chiller Tune Up/Diagnostics	8	5,659	0.04		High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	11	1,990	0.23
3104	Electronically Commutated Motors (ECM) on an Air Handler Unit	130	5,789	0.04	5202	Monitor Power Management Enabling - CRT	0	1,991	0.24
4013	Anti-sweat (humidistat) controls	6	5,796	0.04	1136	Lighting Control Tuneup (base 2L4'T8), 2020	1	1,991	0.24
6006	Heat Recovery Unit	68	5,864	0.04	4009	Floating head pressure controls	0	1,991	0.26
2001	Centrifugal Chiller, 0.51 kW/ton, 500 tons	124	5,988	0.04	2107	Cool Roof - DX	57	2,048	0.26
1805	High Performance Lighting R/R - 25% Savings (base metal halide)	31	6,018	0.04	1731	LED screw-in replacement (base CFL 23W) 2020	20	2,068	0.27
3103 3001	Air Handler Optimization, 15 HP	56 42	6,074 6,116	0.04 0.05	1032 6006	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	96 10	2,164 2,174	0.27 0.29
1731	Fan Motor, 5hp, 1800rpm, 89.5% LED screw-in replacement (base CFL 23W) 2020	42 114	6,231	0.05	4006	Heat Recovery Unit Electronically commutated evaporator fan motor	9	2,174	0.29
4110	Energy Star Ice Machines	25	6,256	0.05	4110	Energy Star Ice Machines	4	2,187	0.29
1032	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	546	6.802	0.05		High Performance Lighting R/R - 25% Savings (base metal halide)	4	2,191	0.32
1901	Outdoor Lighting Controls (Photocell/Timeclock)	92	6,894	0.05	4108	Energy-Star Refrigerator, glass door	3	2,194	0.33
4006	Electronically commutated evaporator fan motor	54	6,948	0.05	7401	Efficient Steamer	10	2,204	0.33
4108	Energy-Star Refrigerator, glass door	21	6,969	0.05	4014	Freezer-Cooler Replacement Gaskets	3	2,207	0.34
7002	Vending Misers (Refrigerated glass-front units)	12	6,981	0.05	4018	Oversized Air Cooled Condenser	5	2,212	0.34
2113	Ceiling/roof Insulation - DX	11	6,992	0.05	1901	Outdoor Lighting Controls (Photocell/Timeclock)	13	2,225	0.35
	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	6	6,999	0.05	7001	Vending Misers (Refrigerated units)	2	2,227	0.35
4014	Freezer-Cooler Replacement Gaskets	16	7,014	0.05	2002	Window Film (Standard) - Chiller	10	2,237	0.35
2102	DX Packaged System, EER=13.4, 10 tons	1,056	8,070	0.05	2012	Duct Testing/Sealing - Chiller	143	2,380	0.35
5601	Printer Power Management Enabling	8	8,078	0.05	1631	LED screw-in replacement (base CFL 18W) 2020	17	2,397	0.35

DNV GL G-5 1/5/2015

Comm	ecial Electric Existing Construction				Comme	ecial Electric Existing Construction			
Energy	Supply Curve				Capacity	y Supply Curve			
Measure Number	Measure	Measure GWH Savings	Cumulative Measure GWH Savings	Levelized Energy Cost \$/kWH	Measure Number	Measure	Measure MW Savings	Cumulative Measure MW Savings	Levelized Capacity Cost \$/kW
2006	VSD for Chiller Pumps and Towers	18	8,097	0.06	1132	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	19	2,416	0.36
4018	Oversized Air Cooled Condenser	32	8,128	0.06	2302	Occupancy Sensor (hotels)	9	2,425	0.37
7401	Efficient Steamer	56	8,184	0.06		gh Performance Lighting R/R - 25% Savings, Base Other Fluoresce	1	2,426	0.38
1631	LED screw-in replacement (base CFL 18W) 2020	95	8,279	0.06	2105	DX Tune Up/ Advanced Diagnostics	4	2,430	0.40
1132	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	110	8,389	0.06	4002	Strip curtains for walk-ins (built-up)	1	2,431	0.41
4004	Night covers for display cases	22	8,411	0.07	2115	Window Film (Standard) - DX	56	2,487	0.45
2013	High Efficiency Chiller Motors	2	8,413	0.07	6002	High Efficiency Water Heater (electric)	2 12	2,488	0.47
6002 4002	High Efficiency Water Heater (electric) Strip curtains for walk-ins (built-up)	11 6	8,425 8,430	0.07 0.07	2003 3002	EMS - Chiller Variable Speed Drive Control, 5 HP	12 44	2,500 2.544	0.47 0.48
4002 3202	Strip curtains for waik-ins (built-up) Variable Speed Drive Control, 40 HP	6 164	8,430 8,594	0.07	3002	Air Handler Optimization, 40 HP	44 5	2,544 2,549	0.48
1037	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	163	8,757	0.07	1201	ROB High Performance T8 (base other fluorescent)	1	2,549	0.48
2003	EMS - Chiller	70	8,827	0.08	3101	Fan Motor, 15hp, 1800rpm, 92.4%	2	2,552	0.51
5302	Monitor Power Management Enabling - LCD	2	8,830	0.08	2108	Optimize Controls - DX	10	2,563	0.53
1201	ROB High Performance T8 (base other fluorescent)	8	8,837	0.09	4013	Anti-sweat (humidistat) controls	1	2,563	0.53
2108	Optimize Controls - DX	58	8,895	0.09	2112	Duct Testing/Sealing - DX	134	2,697	0.55
5402	Copier Power Management Enabling	3	8,898	0.10	3102	Variable Speed Drive Control, 15 HP	17	2,714	0.57
4008	Compressor VSD retrofit	24	8,922	0.10	7002	Vending Misers (Refrigerated glass-front units)	1	2,715	0.64
6003	Hot Water Pipe Insulation	6	8,928	0.11	3103	Air Handler Optimization, 15 HP	4	2,719	0.66
1902	LED Outdoor Area Lighting	461	9,389	0.11	4010	Refrigeration Commissioning	1	2,719	0.72
1204	Occupancy Sensor, 4L8' Fluorescent Fixtures	9	9,397	0.11	6003	Hot Water Pipe Insulation	1	2,720	0.72
2301	HE PTAC, EER=9.6, 1 ton	72	9,470	0.11	5601	Printer Power Management Enabling	1	2,721	0.75
6004	Tankless Water Heater	37	9,507	0.11	1806	Occupancy Sensor, High Bay T5	1	2,721	0.75
4010	Refrigeration Commissioning	3	9,511	0.12	6004	Tankless Water Heater	5	2,727	0.79
3101	Fan Motor, 15hp, 1800rpm, 92.4%	7	9,518	0.14	4004	Night covers for display cases	2	2,728	0.82
2105	DX Tune Up/ Advanced Diagnostics	11	9,529	0.14	7201	Convection Oven	2	2,731	0.83
2111 7201	Economizer Repair - DX	102 12	9,630 9,642	0.14 0.15	2004 3105	Cool Roof - Chiller	3 10	2,733 2,744	0.90 0.91
6008	Convection Oven Solar Water Heater	12 84	9,642 9.727	0.15 0.18	3105 2109	Energy Recovery Ventilation (ERV) Economizer - DX	10 27	2,744 2,771	0.91
1137	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	8 4 21	9,727	0.18	3202	Variable Speed Drive Control, 40 HP	11	2,771	1.02
2109	Economizer - DX	145	9,893	0.18	5302	Monitor Power Management Enabling - LCD	0	2,782	1.10
5203	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	2	9,894	0.19	1202	ROB Low Watt High Performance T8 (base other fluorescent)	1	2,783	1.16
2008	New Economizer - Chiller	112	10,006	0.19	3201	Fan Motor, 40hp, 1800rpm, 94.1%	0	2,784	1.18
2107	Cool Roof - DX	72	10,079	0.20	2008	New Economizer - Chiller	17	2,801	1.25
1202	ROB Low Watt High Performance T8 (base other fluorescent)	7	10,086	0.21	4008	Compressor VSD retrofit	2	2,803	1.26
6001	Demand controlled circulating systems	12	10,098	0.21	6008	Solar Water Heater	12	2,815	1.26
4005	Evaporator fan controller for MT walk-ins	0	10,098	0.23		Plug-load controls - Commercial Smart Strip (base Monitor CRT)	0	2,815	1.27
5303	Plug-load controls - Commercial Smart Strip (base monitor LCD)	3	10,101	0.23	5402	Copier Power Management Enabling	0	2,815	1.32
2012	Duct Testing/Sealing - Chiller	216	10,317	0.23	2106	Prog. Thermostat - DX	14	2,829	1.32
4001	High-efficiency fan motors	23	10,340	0.24	1035	LED Troffer (base 4L4'T8), 2020	46	2,875	1.37
2002	Window Film (Standard) - Chiller	14	10,354	0.24	4001	High-efficiency fan motors	4	2,879	1.37
2106	Prog. Thermostat - DX	76	10,430	0.24	1134	ROB 2L4' LED Tube, 2020	6	2,885	1.38
1134	ROB 2L4' LED Tube, 2020	36	10,467	0.24	6001	Demand controlled circulating systems	2	2,887	1.50
1035	LED Troffer (base 4L4'T8), 2020	260	10,726	0.24	4017	Multiplex Compressor System	1	2,888	1.64
4017	Multiplex Compressor System	6	10,733	0.26	1034	ROB 4L4' LED Tube, 2020	103	2,991	1.64
4112	Reach-in unit occupancy sensors	2	10,734	0.28 0.29	1037	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	7 11	2,998	1.76
1034 2302	ROB 4L4' LED Tube, 2020	586 12	11,321	0.29 0.29	1135 4112	LED Troffer (base 2L4'T8), 2020	11 0	3,008 3.009	1.77 1.86
2302 2115	Occupancy Sensor (hotels) Window Film (Standard) - DX	12 84	11,333 11,416	0.29 0.30	4112 4105	Reach-in unit occupancy sensors Bi-level LED Case Lighting (self-contained units) 2014	0 1	3,009 3,009	1.86 2.15
2115 5501	Window Film (Standard) - DX Multifunction Power Management Enabling	84 2	11,416 11,418	0.30	4105 3003	Bi-level LED Case Lighting (self-contained units) 2014 Demand Controlled Ventilation	1 78	3,009 3,087	2.15 2.17
1135	LED Troffer (base 2L4'T8), 2020	60	11,418	0.30	3204	Demand Controlled Ventilation Demand Controlled Ventilation	78 30	3,087	2.17
4105	Bi-level LED Case Lighting (self-contained units) 2014	4	11,476	0.33	1902	LED Outdoor Area Lighting	21	3,117	2.26
3201	Fan Motor, 40hp, 1800rpm, 94.1%	2	11,484	0.33	1204	Occupancy Sensor, 4L8' Fluorescent Fixtures	0	3,138	2.40
2112	Duct Testing/Sealing - DX	189	11,673	0.39	4016	LED Display Lighting	4	3,142	2.70
3105	Energy Recovery Ventilation (ERV)	23	11,696	0.41	4005	Evaporator fan controller for MT walk-ins	0	3,142	2.74

Commecial Electric New Construction

Energy Supply Curve

asure		Measure GWH	Cumulative Measure GWH	Levelized Energy Cost
ımber	Measure	Savings	Savings	\$/kWH
209	High Performance Building/Int Design - Tier 2 30% - Data Centers	3.9	4	0.01
309	High Performance Building/Int Design - Tier 3 50% - Data Centers	1.5	5	0.01
	Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Data Ce	0.2	6	0.01
109	High Performance Building/Int Design - Tier 1 15% - Data Centers	2.4	8	0.01
204	High Performance Building/Int Design - Tier 2 30% - Grocery	2.2	10	0.02
304	High Performance Building/Int Design - Tier 3 50% - Grocery	0.8	11	0.02
	h Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Groce	0.1	11	0.03
201	High Performance Building/Int Design - Tier 2 30% - Office	13.1	24	0.03
104	High Performance Building/Int Design - Tier 1 15% - Grocery	1.4	26	0.03
301	High Performance Building/Int Design - Tier 3 50% - Office	4.9	31	0.03
,	gh Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Offic	8.0	31	0.04
202	High Performance Building/Int Design - Tier 2 30% - Restaurant	4.9	36	0.04
302	High Performance Building/Int Design - Tier 3 50% - Restaurant	1.8	38	0.04
210	High Performance Building/Int Design - Tier 2 30% - Non-Jurisdictional	19.5	58	0.04
	Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restau	0.3	58	0.04
101	High Performance Building/Int Design - Tier 1 15% - Office	8.2	66	0.04
310	High Performance Building/Int Design - Tier 3 50% - Non-Jurisdictional	7.3	73	0.04
	formance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Non-Jurisd	1.1	74	0.05
102	High Performance Building/Int Design - Tier 1 15% - Restaurant	3.1	78	0.05
110	High Performance Building/Int Design - Tier 1 15% - Non-Jurisdictional	12.2	90	0.06
203	High Performance Building/Int Design - Tier 2 30% - Retail	10.5	100	0.06
208	High Performance Building/Int Design - Tier 2 30% - Lodging	4.2	104	0.07
303	High Performance Building/Int Design - Tier 3 50% - Retail	3.9	108	0.07
212	High Performance Building/Int Design - Tier 2 30% - Miscellaneous	10.4	119	0.07
308	High Performance Building/Int Design - Tier 3 50% - Lodging	1.6	120	0.07
312	High Performance Building/Int Design - Tier 3 50% - Miscellaneous	3.9	124	0.07
205	High Performance Building/Int Design - Tier 2 30% - Warehouse	4.1	128	0.07
403 li	gh Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Reta	0.6	129	0.07
408 gl	h Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodgi	0.2	129	0.08
305	High Performance Building/Int Design - Tier 3 50% - Warehouse	1.5	131	0.08
412 P	erformance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Miscellar	0.6	131	0.08
206	High Performance Building/Int Design - Tier 2 30% - School	2.8	134	0.09
405 า ไ	Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Wareho	0.2	134	0.09
207	High Performance Building/Int Design - Tier 2 30% - Health	3.7	138	0.09
103	High Performance Building/Int Design - Tier 1 15% - Retail	6.5	145	0.09
306	High Performance Building/Int Design - Tier 3 50% - School	1.0	146	0.09
108	High Performance Building/Int Design - Tier 1 15% - Lodging	2.7	148	0.09
307	High Performance Building/Int Design - Tier 3 50% - Health	1.4	150	0.09
112	High Performance Building/Int Design - Tier 1 15% - Miscellaneous	6.5	156	0.09
406 ig	h Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Scho	0.2	156	0.10
_	h Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Healt	0.2	156	0.10
105	High Performance Building/Int Design - Tier 1 15% - Warehouse	2.5	159	0.10
211	High Performance Building/Int Design - Tier 2 30% - Religious Worship	2.4	161	0.12
106	High Performance Building/Int Design - Tier 1 15% - School	1.7	163	0.12
107	High Performance Building/Int Design - Tier 1 15% - Health	2.3	165	0.12
311	High Performance Building/Int Design - Tier 3 50% - Religious Worship	0.9	166	0.13
	formance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Religious V	0.1	166	0.14
111	High Performance Building/Int Design - Tier 1 15% - Religious Worship	1.5	168	0.17

Commecial Electric New Construction

Capacity Supply Curve

		Moseure	Cumulative	Levelized
Measure		Measure MW	Measure MW	Capacity Cost
Number	Measure	Savings	Savings	\$/kW
209	High Performance Building/Int Design - Tier 2 30% - Data Centers	0.9	1	0.04
309	High Performance Building/Int Design - Tier 3 50% - Data Centers	0.3	1	0.04
	Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Data Cen	0.1	1	0.05
109	High Performance Building/Int Design - Tier 1 15% - Data Centers	0.5	2	0.06
204	High Performance Building/Int Design - Tier 2 30% - Grocery	0.5	2	0.10
201	High Performance Building/Int Design - Tier 2 30% - Office	3.8	6	0.10
304	High Performance Building/Int Design - Tier 3 50% - Grocery	0.2	6	0.11
301	High Performance Building/Int Design - Tier 3 50% - Office	1.4	8	0.11
404 Hi	gh Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Grocer	0.0	8	0.12
401 H	ligh Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	0.2	8	0.12
202	High Performance Building/Int Design - Tier 2 30% - Restaurant	1.3	9	0.13
302	High Performance Building/Int Design - Tier 3 50% - Restaurant	0.5	10	0.14
104	High Performance Building/Int Design - Tier 1 15% - Grocery	0.3	10	0.14
101	High Performance Building/Int Design - Tier 1 15% - Office	2.4	12	0.14
210	High Performance Building/Int Design - Tier 2 30% - Non-Jurisdictional	5.3	18	0.15
402 gł	h Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaura	0.1	18	0.15
310	High Performance Building/Int Design - Tier 3 50% - Non-Jurisdictional	2.0	20	0.16
410 Pe	erformance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Non-Jurisdic	0.3	20	0.18
102	High Performance Building/Int Design - Tier 1 15% - Restaurant	0.8	21	0.18
203	High Performance Building/Int Design - Tier 2 30% - Retail	3.1	24	0.21
110	High Performance Building/Int Design - Tier 1 15% - Non-Jurisdictional	3.3	27	0.22
303	High Performance Building/Int Design - Tier 3 50% - Retail	1.2	29	0.22
	ligh Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Retail	0.2	29	0.25
208	High Performance Building/Int Design - Tier 2 30% - Lodging	1.1	30	0.26
212	High Performance Building/Int Design - Tier 2 30% - Miscellaneous	2.6	32	0.27
308	High Performance Building/Int Design - Tier 3 50% - Lodging	0.4	33	0.28
312	High Performance Building/Int Design - Tier 3 50% - Miscellaneous	1.0	34	0.28
103	High Performance Building/Int Design - Tier 1 15% - Retail	2.0	36	0.30
205	High Performance Building/Int Design - Tier 2 30% - Warehouse	1.0	37	0.30
305	High Performance Building/Int Design - Tier 3 50% - Warehouse	0.4	37	0.31
	gh Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodgine	0.1	37	0.31
	Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Miscellane	0.2	37	0.31
	n Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Warehou	0.1	37	0.35
207	High Performance Building/Int Design - Tier 2 30% - Health	0.9	38	0.37
108	High Performance Building/Int Design - Tier 1 15% - Lodging	0.7	39	0.37
112	High Performance Building/Int Design - Tier 1 15% - Miscellaneous	1.6	41	0.37
307	High Performance Building/Int Design - Tier 3 50% - Health	0.3	41	0.38
105	High Performance Building/Int Design - Tier 1 15% - Warehouse	0.6	42	0.41
	ligh Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Health	0.1	42	0.43
206	High Performance Building/Int Design - Tier 2 30% - School	0.5	42	0.44
306	High Performance Building/Int Design - Tier 3 50% - School	0.2	42	0.46
211	High Performance Building/Int Design - Tier 2 30% - Religious Worship	0.6	43	0.47
311	High Performance Building/Int Design - Tier 3 50% - Religious Worship	0.2	43	0.50
107	High Performance Building/Int Design - Tier 1 15% - Health	0.6	44	0.51
	igh Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - School	0.0	44	0.52
	erformance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Religious W	0.0	44	0.56
106 111	High Performance Building/Int Design - Tier 1 15% - School	0.3 0.4	44	0.62 0.66
111	High Performance Building/Int Design - Tier 1 15% - Religious Worship	0.4	45	0.66

DNV GL 6-7 1/5/2015

H DETAILED TECHNICAL AND ECONOMIC AVOIDED COST SCENARIO RESULTS

APPENDIX H

	SYST A	ctric Existing Construction ADDITIVE SUPPLY ANALYSIS				Year	2020		Total			Total		Marring	Aver-
intage		Existing		Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Avera Energ
		Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cos
gmt No	umber 1000	Number Measure 1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	Type Single Family	Year 2014	Year 2053	GWH 2,123.48	MW 1,261.52	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kW N/A
Ά	1000	1024 Self Install Weatherization (CAC)	Single Family	2014	2053	2,123.46	1,247.47	23.66	23.66	1%	14.06	14.06	1%	0.01	0.01
Α	1000	1022 Programmable Thermostat (CAC)	Single Family	2014	2053	2,087.47	1,240.13	12.34	36.01	2%	7.33	21.39	2%	0.04	0.02
Α	1000	1021 Return Duct Modification (CAC)	Single Family	2014	2053	2,075.37	1,232.94	12.10	48.11	2%	7.19	28.58	2%	0.06	0.03
A A	1000 1000	1019 Duct Insulation (CAC) 1004 Proper Refrigerant Charging and Air Flow (CAC)	Single Family Single Family	2014 2014	2053 2053	2,073.16 1,924.33	1,231.63 1,143.21	2.22 148.83	50.32 199.16	2% 9%	1.32 88.42	29.90 118.32	2% 9%	0.09	0.03
Ά	1000	1025 Door Weatherization (CAC)	Single Family	2014	2053	1,893.00	1,124.60	31.33	230.48	11%	18.61	136.93	11%	0.08	0.0
Ά	1000	1001 14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	Single Family	2014	2053	1,778.11	1,056.34	114.89	345.38	16%	68.26	205.18	16%	0.13	0.09
Ά	1000	1002 15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Single Family	2014	2053	1,677.46	996.55	100.65	446.02	21%	59.79	264.97	21%	0.16	0.10
Α	1000	1005 Proper Sizing and Quality Install (CAC)	Single Family	2014	2053	1,514.52	899.75	162.94	608.96	29%	96.80	361.78	29%	0.17	0.12
A	1000 1000	1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC) 1014 Crawlspace insulation (CAC)	Single Family Single Family	2014 2014	2053 2053	1,361.98 1,353.27	809.13 803.95	152.54 8.70	761.51 770.21	36% 36%	90.62 5.17	452.40 457.57	36% 36%	0.22	0.1
Ä	1000	1008 Ceiling R-0 to R-38 Insulation (CAC)	Single Family	2014	2053	1,335.27	781.27	38.18	808.39	38%	22.68	480.25	38%	0.27	0.1
Ά	1000	1009 Ceiling R-0 to R-49 Insulation (CAC)	Single Family	2014	2053	1,314.53	780.94	0.55	808.95	38%	0.33	480.58	38%	3.00	0.15
Ά	1000	1023 Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	Single Family	2014	2053	1,254.71	745.40	59.82	868.77	41%	35.54	516.12	41%	0.33	0.1
Α	1000	1029 WINDOWS - Default With Sunscreen (CAC)	Single Family	2014	2053	1,131.76	672.36	122.95	991.72	47%	73.04	589.16	47%	0.36	0.1
A	1000 1000	1026 Ceiling Fans (CAC) 1010 Ceiling R-11 to R-38 Insulaton (CAC)	Single Family Single Family	2014 2014	2053 2053	1,119.10 1,095.69	664.84 650.93	12.66 23.41	1,004.38 1,027.79	47% 48%	7.52 13.91	596.68 610.59	47% 48%	0.51 0.74	0.1
Ä	1000	1011 Ceiling R-11 to R-38 Insulation (CAC)	Single Family	2014	2053	1,094.69	650.34	1.00	1,028.79	48%	0.59	611.18	48%	3.60	0.2
Ά	1000	1020 Duct Testing and Sealing (CAC)	Single Family	2014	2053	1,090.03	647.57	4.67	1,033.45	49%	2.77	613.96	49%	1.06	0.2
Α	1000	1012 Ceiling R-19 to R-38 Insulation (CAC)	Single Family	2014	2053	1,083.96	643.96	6.07	1,039.52	49%	3.61	617.56	49%	1.26	0.2
Α	1000	1030 WINDOWS - Double-Glazed Clear to Energy Star (CAC)	Single Family	2014	2053	1,078.68	640.83	5.27	1,044.80	49%	3.13	620.70	49%	1.30	0.2
A	1000 1000	1018 Cool Roof (CAC) 1013 Ceiling R-19 to R-49 Insulation (CAC)	Single Family Single Family	2014 2014	2053 2053	1,060.37 1,059.82	629.95 629.62	18.31 0.55	1,063.11 1,063.66	50% 50%	10.88 0.33	631.57 631.90	50% 50%	1.34 3.72	0.2
Ä	1000	1027 Whole House Fans (CAC)	Single Family	2014	2053	1,033.02	613.13	27.75	1.091.41	51%	16.49	648.39	51%	1.68	0.2
Ά	1000	1028 Window Film (CAC)	Single Family	2014	2053	997.22	592.43	34.85	1,126.26	53%	20.70	669.09	53%	1.73	0.3
Ά	1000	1017 Wall Blow-in R-0 to R-13 Insulation (CAC)	Single Family	2014	2053	995.17	591.21	2.05	1,128.31	53%	1.22	670.31	53%	2.48	0.3
Α	1000	1007 AC Filter Changes (CAC)	Single Family	2014	2053	990.93	588.70	4.24	1,132.55	53%	2.52	672.83	53%	1.83	0.3
A A	1000 1000	1006 AC Maintenance and/or tune-up (CAC) 1015 Basement insulation R-13 (CAC)	Single Family Single Family	2014 2014	2053 2053	986.52 982.22	586.07 583.52	4.41 4.30	1,136.96 1.141.26	54% 54%	2.62	675.45 678.00	54% 54%	2.09 3.64	0.3
Ά	1000	1016 Floor R-0 to R-19 Insulation-Batts (CAC)	Single Family	2014	2053	981.99	583.38	0.23	1,141.49	54%	0.14	678.14	54%	4.19	0.3
A	1100	1100 Base Split-System Air Conditioner - Early Replacement (11		2014	2053	349.12	207.41	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
A	1100	1117 Duct Insulation (CAC early replacement)	Single Family	2014	2053	346.27	205.72	2.85	2.85	1%	1.69	1.69	1%	0.01	0.0
A	1100	1122 Self Install Weatherization (CAC early replacement)	Single Family	2014	2053	340.44	202.25	5.84	8.69	2%	3.47	5.16	2%	0.01	0.0
A A	1100 1100	1120 Programmable Thermostat (CAC early replacement) 1119 Return Duct Modification (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	338.44 336.47	201.06 199.89	2.00 1.96	10.69 12.65	3% 4%	1.19 1.17	6.35 7.51	3% 4%	0.04	0.0
Ά	1100	1123 Door Weatherization (CAC early replacement)	Single Family	2014	2053	330.47	196.11	6.37	19.02	5%	3.78	11.30	5%	0.06	0.0
A	1100	1102 Proper Refrigerant Charging and Air Flow (CAC early replacement)		2014	2053	302.78	179.88	27.32	46.34	13%	16.23	27.53	13%	0.09	0.0
A	1100	1116 Cool Roof (CAC early replacement)	Single Family	2014	2053	271.17	161.09	31.62	77.96	22%	18.78	46.31	22%	0.14	0.1
A	1100 1100	1125 Whole House Fans (CAC early replacement)	Single Family	2014	2053	221.49 196.79	131.58	49.68	127.64	37% 44%	29.51 14.67	75.83	37% 44%	0.17	0.1
A A	1100	1103 Proper Sizing and Quality Install (CAC early replacement) 1112 Crawlspace insulation (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	196.79	116.91 116.16	24.70 1.26	152.34 153.59	44% 44%	0.75	90.50 91.25	44% 44%	0.23	0.1
A	1100	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	Single Family	2014	2053	190.01	112.88	5.52	159.11	46%	3.28	94.52	46%	0.34	0.1
A	1100	1113 Basement insulation R-13 (CAC early replacement)	Single Family	2014	2053	182.51	108.43	7.50	166.61	48%	4.46	98.98	48%	0.37	0.1
A	1100	1107 Ceiling R-0 to R-49 Insulation (CAC early replacement)	Single Family	2014	2053	182.43	108.38	0.08	166.69	48%	0.05	99.03	48%	3.82	0.1
A	1100	1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC ea		2014	2053	179.74	106.78	2.70	169.39	49%	1.60	100.63	49%	0.45	0.1
A A	1100 1100	1118 Duct Testing and Sealing (CAC early replacement) 1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC earl	Single Family	2014 2014	2053 2053	178.06 169.96	105.78 100.97	1.68 8.10	171.06 179.17	49% 51%	1.00 4.81	101.63 106.44	49% 51%	0.52 0.43	0.1
A A	1100	1121 Comprehensive Shell Air Sealing - Init. Reduction (CAC earl 1124 Ceiling Fans (CAC early replacement)	Single Family	2014	2053	168.37	100.97	1.58	180.75	52%	0.94	106.44	52%	0.43	0.1
A	1100	1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Single Family	2014	2053	164.85	97.94	3.52	184.27	53%	2.09	109.47	53%	0.87	0.2
A	1100	1109 Ceiling R-11 to R-49 Insulation (CAC early replacement)	Single Family	2014	2053	164.70	97.85	0.15	184.42	53%	0.09	109.56	53%	4.23	0.2
A	1100	1126 Window Film (CAC early replacement)	Single Family	2014	2053	152.35	90.51	12.35	196.77	56%	7.34	116.90	56%	0.86	0.2
A A	1100 1100	1127 WINDOWS - Default With Sunscreen (CAC early replacem 1110 Ceiling R-19 to R-38 Insulation (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	145.08 144.27	86.19 85.71	7.27 0.81	204.04 204.85	58% 59%	4.32 0.48	121.22 121.70	58% 59%	1.09 1.67	0.2
A	1100	1111 Ceiling R-19 to R-39 Insulation (CAC early replacement)	Single Family	2014	2053	144.20	85.66	0.08	204.83	59%	0.48	121.74	59%	4.83	0.2
Ä	1100	1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacemen		2014	2053	143.90	85.49	0.30	205.22	59%	0.18	121.92	59%	3.03	0.2
A	1100	1105 AC Filter Changes (CAC early replacement)	Single Family	2014	2053	143.29	85.12	0.61	205.84	59%	0.36	122.28	59%	2.23	0.2
A A	1100 1100	1104 AC Maintenance and/or tune-up (CAC early replacement)	Single Family	2014 2014	2053 2053	142.65 138.99	84.75 82.57	0.64 3.66	206.47 210.13	59% 60%	0.38 2.17	122.66 124.84	59% 60%	2.55 3.37	0.3
	1100	1101 14 SEER (12.15 EER) Split-System Air Conditioner w/ Qua 1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	lity I Single Family	2014	2053	138.99	82.57 82.55	0.03	210.13	60%	0.02	124.84 124.86	60%	5.23	0.3
A A	1200	1200 Base Heat Pump Cooling (13 SEER)	Single Family Single Family	2014	2053	1,802.58	1,070.88	0.03	0.00	0%	0.02	0.00	0%	5.23 N/A	N/
	1200	1219 Duct Insulation (HP cooling)	Single Family	2014	2053	1,787.87	1,062.14	14.71	14.71	1%	8.74	8.74	1%	0.01	0.
A	1200	1223 Self Install Weatherization (HP cooling)	Single Family	2014	2053	1,767.94	1,050.30	19.92	34.64	2%	11.84	20.58	2%	0.04	0.
A	1200	1221 Programmable Thermostat (HP cooling)	Single Family	2014	2053	1,741.39	1,034.53	26.56	61.19	3%	15.78	36.35	3%	0.06	0.
A A	1200 1200	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling		2014 2014	2053 2053	1,446.34	859.24 797.56	295.05 103.83	356.24 460.08	20% 26%	175.29 61.68	211.64 273.32	20% 26%	0.08	0.0
A A	1200 1200	1204 Proper Refrigerant Charging and Air Flow (HP cooling) 1224 Door Weatherization (HP cooling)	Single Family Single Family	2014 2014	2053 2053	1,342.50 1,320.65	797.56 784.57	103.83 21.86	460.08 481.93	26% 27%	61.68 12.98	273.32 286.31	26% 27%	0.10	0.
`	1200	1218 Cool Roof (HP cooling)	Single Family	2014	2053	1,182.74	702.64	137.91	619.84	34%	81.93	368.24	34%	0.09	0.
ì	1200	1226 Whole House Fans (HP cooling)	Single Family	2014	2053	966.05	573.92	216.68	836.53	46%	128.73	496.97	46%	0.19	0.
Ą	1200	1205 Proper Sizing and Quality Install (HP cooling)	Single Family	2014	2053	872.22	518.17	93.84	930.36	52%	55.75	552.71	52%	0.29	0.
A	1200	1214 Crawlspace insulation (HP cooling)	Single Family	2014	2053	866.64	514.85	5.58	935.94	52%	3.31	556.03	52%	0.36	0.
A	1200	1208 Ceiling R-0 to R-38 Insulation (HP cooling)	Single Family	2014	2053	841.94	500.18	24.70	960.64	53%	14.67	570.70	53%	0.38	0.
À	1200	1215 Basement insulation R-13 (HP cooling)	Single Family	2014	2053	808.61	480.38	33.33	993.97	55%	19.80	590.50	55%	0.42	0.

APPENDIX H

ntag		ADDITIVE : Existing	SUPPLY ANALYSIS				Year	2020		Total			Total		Marginal	l Ave
ntag	je	Existing			Measure	Measure				Energy	Percent		Capacity	Percent	Energy	En
	Base	Measure		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	C
mt	Number		Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/k
	1200			Single Family	2014	2053	800.31	475.45	7.54	1,002.27	56%	4.48	595.43	56%	0.58	0
	1200 1200			Single Family Single Family	2014 2014	2053 2053	763.89 752.60	453.82 447.11	36.42 11.29	1,038.69 1,049.98	58% 58%	21.64 6.71	617.07 623.77	58% 58%	0.48	(
	1200			Single Family	2014	2053	745.60	442.95	7.01	1,056.98	59%	4.16	627.94	59%	0.82	Ċ
	1200			Single Family	2014	2053	729.61	433.45	15.99	1,072.97	60%	9.50	637.43	60%	0.96	
	1200			Single Family	2014	2053	728.13	432.57	1.48	1,074.45	60%	0.88	638.31	60%	2.16	
	1200	1216	Floor R-0 to R-19 Insulation-Batts (HP cooling)	Single Family	2014	2053	727.50	432.19	0.63	1,075.08	60%	0.38	638.69	60%	1.36	
	1200			Single Family	2014	2053	723.56	429.85	3.94	1,079.02	60%	2.34	641.03	60%	1.73	
	1200			Single Family	2014	2053	722.72	429.35	0.84	1,079.86	60%	0.50	641.53	60%	2.18	
	1200 1200	120	Heat Pump Filter Replacement	Single Family	2014 2014	2053 2053	719.64 717.15	427.53 426.05	3.08 2.49	1,082.94	60% 60%	1.83 1.48	643.36 644.83	60% 60%	2.49 5.83	
	1200	121		Single Family Single Family	2014	2053	717.15	426.05	3.19	1,085.43	60%	1.48	646.73	60%	4.04	
	1300			Single Family	2014	2053	274.13	162.86	0.00	0.00	0%	0.00	0.00	0%	N/A	
	1300			Single Family	2014	2053	271.89	161.53	2.24	2.24	1%	1.33	1.33	1%	0.01	
	1300			Single Family	2014	2053	268.86	159.73	3.03	5.27	2%	1.80	3.13	2%	0.04	
	1300		Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Ea	Single Family	2014	2053	223.31	132.66	45.56	50.82	19%	27.06	30.19	19%	0.09	
	1300	132		Single Family	2014	2053	219.95	130.67	3.35	54.18	20%	1.99	32.19	20%	0.11	
	1300	132		Single Family	2014	2053	215.79	128.20	4.16	58.34	21%	2.47	34.66	21%	0.09	
	1300		Proper Refrigerant Charging and Air Flow (HP cooling Early Re		2014	2053	200.30	118.99	15.49	73.83	27%	9.20	43.86	27%	0.12	
	1300 1300			Single Family Single Family	2014 2014	2053 2053	179.38 146.52	106.57 87.04	20.92 32.86	94.75 127.61	35% 47%	12.43 19.52	56.29 75.81	35% 47%	0.18	
	1300		Froper Sizing and Quality Install (HP cooling Early Replacement		2014	2053	132.29	78.59	14.23	141.84	52%	8.46	84.27	52%	0.22	
	1300			Single Family	2014	2053	131.44	78.09	0.84	142.69	52%	0.50	84.77	52%	0.42	
	1300		Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)		2014	2053	127.70	75.86	3.75	146.44	53%	2.23	86.99	53%	0.44	
	1300			Single Family	2014	2053	122.65	72.86	5.05	151.48	55%	3.00	89.99	55%	0.49	
	1300			Single Family	2014	2053	122.54	72.80	0.11	151.60	55%	0.07	90.06	55%	2.27	
	1300			Single Family	2014	2053	121.39	72.12	1.14	152.74	56%	0.68	90.74	56%	0.68	
	1300		Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling E		2014	2053	115.87	68.84	5.52	158.26	58%	3.28	94.02	58%	0.56	
	1300		WINDOWS - Double-Glazed Clear to Energy Star (HP cooling I		2014	2053	114.16	67.82	1.71	159.98	58% 59%	1.02	95.04	58% 59%	0.97	
	1300 1300		6 Ceiling Fans (HP cooling early replacement) 7 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)	Single Family	2014 2014	2053 2053	113.09 110.67	67.19 65.75	1.06 2.42	161.04 163.46	59% 60%	0.63 1.44	95.67 97.11	59% 60%	1.12	
	1300		Ceiling R-11 to R-38 insulation (HP cooling Early Replacement)		2014	2053	110.44	65.61	0.22	163.69	60%	0.13	97.24	60%	2.52	
	1300		Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement		2014	2053	110.35	65.56	0.10	163.78	60%	0.06	97.30	60%	1.58	
	1300		Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)		2014	2053	109.75	65.20	0.60	164.38	60%	0.35	97.66	60%	2.01	
	1300	1313	Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)	Single Family	2014	2053	109.62	65.12	0.13	164.51	60%	0.08	97.73	60%	2.54	
	1300	130		Single Family	2014	2053	109.16	64.85	0.47	164.98	60%	0.28	98.01	60%	2.90	
	1300	1317	Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacer	Single Family	2014	2053	108.78	64.62	0.38	165.35	60%	0.22	98.23	60%	6.79	
	1300			Single Family	2014	2053	108.29	64.34	0.48	165.84	60%	0.29	98.52	60%	4.70	
	1400 1400			Single Family	2014 2014	2053 2053	112.24 110.99	66.68 65.94	0.00 1.25	0.00 1.25	0% 1%	0.00 0.74	0.00 0.74	0% 1%	N/A 0.03	
	1400			Single Family Single Family	2014	2053	109.18	64.86	1.25	3.06	3%	1.07	1.82	3%	0.03	
	1400			Single Family	2014	2053	97.78	58.09	11.40	14.46	13%	6.77	8.59	13%	0.14	
	1400			Single Family	2014	2053	79.87	47.45	17.91	32.37	29%	10.64	19.23	29%	0.29	
	1400			Single Family	2014	2053	75.39	44.79	4.48	36.85	33%	2.66	21.89	33%	0.31	
	1400	1417	Window Film (RAC)	Single Family	2014	2053	59.56	35.38	15.83	52.68	47%	9.41	31.30	47%	0.43	
	1400			Single Family	2014	2053	57.97	34.44	1.59	54.27	48%	0.94	32.24	48%	0.75	
	1400			Single Family	2014	2053	57.12	33.93	0.86	55.13	49%	0.51	32.75	49%	0.90	
	1400			Single Family	2014	2053	54.01	32.09	3.11	58.23	52%	1.85	34.59	52%	0.72	
	1400 1400			Single Family Single Family	2014 2014	2053 2053	53.97 53.47	32.06 31.76	0.04 0.50	58.27 58.77	52% 52%	0.02	34.62 34.92	52% 52%	4.53 1.46	
	1400			Single Family	2014	2053	52.45	31.76	1.02	59.79	53%	0.60	35.52	53%	1.46	
	1400			Single Family	2014	2053	52.45	31.10	0.09	59.88	53%	0.05	35.57	53%	4.67	
	1400			Single Family	2014	2053	52.14	30.97	0.23	60.10	54%	0.13	35.71	54%	2.58	
	1400			Single Family	2014	2053	49.65	29.50	2.49	62.59	56%	1.48	37.18	56%	2.03	
	1400			Single Family	2014	2053	49.40	29.35	0.25	62.84	56%	0.15	37.34	56%	3.42	
	1400			Single Family	2014	2053	49.35	29.32	0.05	62.89	56%	0.03	37.36	56%	4.96	
	1400			Single Family	2014	2053	49.14	29.19	0.21	63.10	56%	0.12	37.49	56%	4.18	
	1500 1500			Single Family	2014 2014	2053 2053	23.56	14.00	0.00	0.00	0%	0.00	0.00	0% 13%	N/A 0.63	
	1600		EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early I) Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	Single Family	2014	2053	25.36	12.14 15.07	3.13 0.00	3.13 0.00	13% 0%	1.86 0.00	1.86 0.00	0%	0.63 N/A	
	1600		10% better than Energy Star Dehumidifier ROB (35-45 pints/da		2014	2053	21.52	12.79	3.84	3.84	15%	2.28	2.28	15%	0.18	
	1700			Single Family	2014	2053	1,754.83	900.13	0.00	0.00	0%	0.00	0.00	0%	N/A	
	1700			Single Family	2014	2053	974.90	500.13	779.92	779.92	44%	400.06	400.06	44%	0.03	
	2000			Single Family	2014	2053	2,499.04	296.50	0.00	0.00	0%	0.00	0.00	0%	N/A	
	2000	2016	Duct Insulation (HP heating)	Single Family	2014	2053	2,478.64	294.08	20.40	20.40	1%	2.42	2.42	1%	0.01	
	2000	202	Self Install Weatherization (HP heating)	Single Family	2014	2053	2,451.02	290.81	27.62	48.02	2%	3.28	5.70	2%	0.02	
	2000	2019	Programmable Thermostat (HP heating)	Single Family	2014	2053	2,414.21	286.44	36.82	84.84	3%	4.37	10.07	3%	0.05	
	2000			Single Family	2014	2053	2,191.76	260.05	222.45	307.28	12%	26.39	36.46	12%	0.08	
	2000			Single Family	2014	2053	2,170.07	257.47	21.69	328.97	13%	2.57	39.03	13%	0.08	
	2000			Single Family	2014	2053	2,156.21	255.83	13.85	342.83	14%	1.64	40.68	14%	0.12	
	2000			Single Family Single Family	2014 2014	2053 2053	2,094.77 1,640.19	248.54 194.60	61.45 454.58	404.27 858.85	16% 34%	7.29 53.93	47.97 101.90	16% 34%	0.13	
	2000			Single Family Single Family	2014	2053	1,640.19	194.60 186.92	454.58 64.80	923.65	34% 37%	7.69	101.90	34% 37%	0.14	
	2000			Single Family	2014	2053	1,575.39	186.92	1.48	923.65	37%	0.18	109.59	37%	0.18	

APPENDIX H

Base Avoided Costs

SM ASSYST	ADDITIVE S	ing Construction SUPPLY ANALYSIS				Year	2020		Total			Total		Manufact	
ntage	Existing			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Aver
Base	Measure		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Co
gmt Number	Number	Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kV
A 2000		Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Single Family	2014	2053	1,502.29	178.24	71.62	996.75	40%	8.50	118.26	40%	0.21	0.1
A 2000 A 2000		Duct Testing and Sealing (HP heating) WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Single Family	2014 2014	2053 2053	1,488.27	176.58 174.05	14.03 21.31	1,010.77 1,032.08	40% 41%	1.66 2.53	119.93 122.45	40% 41%	0.26	0.1
A 2000		Ceiling R-11 to R-38 Insulaton (HP heating)	Single Family	2014	2053	1,435.50	170.32	31.45	1,063.54	43%	3.73	126.19	43%	0.41	0.1
A 2000	2009	Ceiling R-11 to R-49 Insulation (HP heating)	Single Family	2014	2053	1,432.59	169.97	2.91	1,066.45	43%	0.35	126.53	43%	0.93	0.1
2000		Floor R-0 to R-19 Insulation-Batts (HP heating)	Single Family	2014	2053	1,431.35	169.83	1.24	1,067.69	43%	0.15	126.68	43%	0.58	0.1
2000		Ceiling R-19 to R-38 Insulation (HP heating)	Single Family	2014	2053	1,423.60	168.91	7.75	1,075.44	43%	0.92	127.60	43%	0.74	0.1
2000		Ceiling R-19 to R-49 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating)	Single Family Single Family	2014 2014	2053 2053	1,421.94	168.71 153.55	1.65 127.79	1,077.10	43% 48%	0.20 15.16	127.79 142.96	43% 48%	0.94 1.75	0.1
A 2000		Heat Pump Filter Replacement	Single Family	2014	2053	1,288.64	152.89	5.51	1,210.40	48%	0.65	143.61	48%	1.18	0.3
2000		Heat pump tune up	Single Family	2014	2053	1,282.90	152.21	5.74	1,216.14	49%	0.68	144.29	49%	1.90	0.3
2000		Wall Blow-in R-0 to R-13 Insulation (HP heating)	Single Family	2014	2053	1,278.47	151.69	4.44	1,220.57	49%	0.53	144.82	49%	2.77	0.
A 2100 A 2100		Base Heat Pump Space Heating - Early Replacement (7.7 HSP		2014	2053	420.83	49.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/
A 2100 A 2100		Duct Insulation (HP heating early replacement) Self Install Weatherization (HP heating early replacement)	Single Family Single Family	2014 2014	2053 2053	417.39 412.74	49.52 48.97	3.43 4.65	3.43 8.09	1% 2%	0.41 0.55	0.41 0.96	1% 2%	0.01 0.02	0.0
2100	2119	Programmable Thermostat (HP heating early replacement)	Single Family	2014	2053	406.54	48.24	6.20	14.29	3%	0.74	1.69	3%	0.05	0.0
2100		Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early		2014	2053	369.08	43.79	37.46	51.75	12%	4.44	6.14	12%	0.09	0.0
A 2100		Door Weatherization (HP heating early replacement)	Single Family	2014	2053	365.25	43.34	3.83	55.57	13%	0.45	6.59	13%	0.08	0.0
2100		Crawlspace insulation (HP heating early replacement)	Single Family	2014	2053	362.93	43.06	2.33	57.90	14%	0.28	6.87	14%	0.13	0.
2100 2100		Ceiling R-0 to R-38 Insulation (HP heating early replacement) Heat Recovery Ventilators (HP heating early replacement)	Single Family Single Family	2014 2014	2053 2053	352.58 276.07	41.83 32.76	10.34 76.51	68.25 144.76	16% 34%	1.23 9.08	8.10 17.18	16% 34%	0.13	0.
2100		Basement insulation R-13 (HP heating early replacement)	Single Family	2014	2053	265.18	31.46	10.90	155.65	37%	1.29	18.47	37%	0.14	0.
2100			Single Family	2014	2053	264.93	31.43	0.25	155.90	37%	0.03	18.50	37%	0.89	0.
2100		Comprehensive Shell Air Sealing - Inf. Reduction (HP heating e		2014	2053	252.87	30.00	12.06	167.96	40%	1.43	19.93	40%	0.22	0.
2100 2100		Duct Testing and Sealing (HP heating early replacement)	Single Family	2014	2053	250.51	29.72	2.36	170.32	40%	0.28	20.21	40%	0.28	0.
		WINDOWS - Double-Glazed Clear to Energy Star (HP heating	Single Family Single Family	2014 2014	2053 2053	246.92 241.63	29.30 28.67	3.59 5.29	173.91 179.20	41% 43%	0.43	20.63 21.26	41% 43%	0.39	0.
2100 2100		Ceiling R-11 to R-38 Insulaton (HP heating early replacement) Ceiling R-11 to R-49 Insulation (HP heating early replacement)		2014	2053	241.63	28.61	0.49	179.20	43%	0.63	21.26	43%	0.43	0.
2100		Floor R-0 to R-19 Insulation-Batts (HP heating early replaceme		2014	2053	240.93	28.59	0.21	179.90	43%	0.02	21.34	43%	0.61	0
2100		Ceiling R-19 to R-38 Insulation (HP heating early replacement)		2014	2053	239.62	28.43	1.30	181.20	43%	0.15	21.50	43%	0.78	0
2100		Ceiling R-19 to R-49 Insulation (HP heating early replacement)		2014	2053	239.35	28.40	0.28	181.48	43%	0.03	21.53	43%	0.98	0
2100		Ground Source Heat Pump with Desuperheater (HP heating ear		2014	2053	217.84	25.85	21.51	202.99	48%	2.55	24.08	48%	1.83	0
2100 2100		Heat Pump Filter Replacement (heating) Heat pump tune up (heating)	Single Family Single Family	2014 2014	2053 2053	216.91 215.94	25.74 25.62	0.93 0.97	203.92 204.89	48% 49%	0.11 0.11	24.19 24.31	48% 49%	1.24 2.00	0
2100		Wall Blow-in R-0 to R-13 Insulation (HP heating early replacem		2014	2053	215.34	25.53	0.75	205.63	49%	0.09	24.40	49%	2.91	0
2200		Base Resistance Space Heating (Primary)	Single Family	2014	2053	1,220.36	144.79	0.00	0.00	0%	0.00	0.00	0%	N/A	١
2200	2201	Air Source Heat Pump (resistance heating)	Single Family	2014	2053	972.08	115.34	248.28	248.28	20%	29.46	29.46	20%	0.01	0
2200		Self Install Weatherization	Single Family	2014	2053	961.25	114.05	10.83	259.11	21%	1.29	30.74	21%	0.02	0
2200 2200		Programmable Thermostat (resistance heating)	Single Family	2014 2014	2053 2053	946.81 930.71	112.34 110.43	14.44 16.10	273.55 289.65	22% 24%	1.71 1.91	32.46 34.37	22% 24%	0.04	0
2200		Door Weatherization (resistance heating) Ceiling R-0 to R-38 Insulation (resistance heating)	Single Family Single Family	2014	2053	902.03	107.02	28.68	318.33	24% 26%	3.40	34.37	26%	0.04	0
2200		Heat Recovery Ventilators (resistance heating)	Single Family	2014	2053	706.29	83.80	195.75	514.07	42%	23.22	60.99	42%	0.11	0
2200		Crawlspace insulation (resistance heating)	Single Family	2014	2053	702.14	83.31	4.14	518.22	42%	0.49	61.49	42%	0.17	o
2200		Basement insulation R-13 (resistance heating)	Single Family	2014	2053	659.41	78.24	42.74	560.95	46%	5.07	66.56	46%	0.18	0
2200		Ceiling R-0 to R-49 Insulation (resistance heating)	Single Family	2014	2053	658.88	78.17	0.53	561.48	46%	0.06	66.62	46%	0.99	0
2200 2200		Comprehensive Shell Air Sealing - Inf. Reduction (resistance he		2014 2014	2053 2053	628.90 618.62	74.62 73.40	29.98 10.28	591.46 601.74	48% 49%	3.56	70.18 71.40	48% 49%	0.21	0
2200		WINDOWS - Double-Glazed Clear to Energy Star (resistance h Ceiling R-11 to R-38 Insulaton (resistance heating)	Single Family	2014	2053	604.24	73.40	14.38	616.13	49% 50%	1.22 1.71	73.10	49% 50%	0.33	0
2200		Floor R-0 to R-19 Insulation-Batts (resistance heating)	Single Family	2014	2053	603.50	71.60	0.74	616.86	51%	0.09	73.19	51%	0.41	0
2200		Ceiling R-11 to R-49 Insulation (resistance heating)	Single Family	2014	2053	602.45	71.48	1.05	617.91	51%	0.12	73.31	51%	1.08	0
2200	2207	Ceiling R-19 to R-38 Insulation (resistance heating)	Single Family	2014	2053	598.72	71.04	3.74	621.65	51%	0.44	73.76	51%	0.64	0
2200		Ceiling R-19 to R-49 Insulation (resistance heating)	Single Family	2014	2053	598.12	70.97	0.59	622.24	51%	0.07	73.83	51%	1.09	0
2200		Ground Source Heat Pump with Desuperheater (resistance heat		2014	2053	593.20	70.38	4.92	627.16	51%	0.58	74.41	51%	21.03	0
2200 3030		Wall Blow-in R-0 to R-13 Insulation (resistance heating) Base Halogen Lighting - 0.5 hrs/day 2020	Single Family Single Family	2014	2053 2053	590.35 183.04	70.04 20.49	2.85	630.01 0.00	52% 0%	0.34	74.75	52% 0%	1.80 N/A	1
3030		LEDs (base Halogen 0.5 hrs/day) 2020	Single Family	2020	2053	58.50	6.55	124.54	124.54	68%	13.94	13.94	68%	0.04	Ċ
3130		Base Halogen Lighting - 2.5 hrs/day 2020	Single Family	2020	2053	751.77	84.17	0.00	0.00	0%	0.00	0.00	0%	N/A	Ĭ
3130	3132	LEDs (base Halogen 2.5 hrs/day) 2020	Single Family	2020	2053	196.96	22.05	554.81	554.81	74%	62.12	62.12	74%	0.01	(
3230		Base Halogen Lighting - 6 hrs/day 2020	Single Family	2020	2053	496.82	55.62	0.00	0.00	0%	0.00	0.00	0%	N/A	
3230 3330		LEDs (base Halogen 6 hrs/day) 2020	Single Family	2020 2020	2053 2053	158.78 35.20	17.78 3.94	338.04	338.04	68% 0%	37.85 0.00	37.85 0.00	68% 0%	0.00 N/A	(
3330		Base CFL Lighting - 0.5 hrs/day 2020 LEDs (base CFL 0.5 hrs/day) 2020	Single Family Single Family	2020	2053	35.20 25.69	2.88	9.50	9.50	0% 27%	1.06	1.06	0% 27%	0.21	(
3430		Base CFL Lighting - 2.5 hrs/day 2020	Single Family	2020	2053	144.30	16.16	0.00	0.00	0%	0.00	0.00	0%	N/A	1
3430		LEDs (base CFL 2.5 hrs/day) 2020	Single Family	2020	2053	105.34	11.79	38.96	38.96	27%	4.36	4.36	27%	0.04	0
3530	3530	Base CFL Lighting - 6 hrs/day 2020	Single Family	2020	2053	95.03	10.64	0.00	0.00	0%	0.00	0.00	0%	N/A	1
3530		LEDs (base CFL 6 hrs/day) 2020	Single Family	2020	2053	69.37	7.77	25.66	25.66	27%	2.87	2.87	27%	0.02	0
3630		Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	Single Family	2020	2053	112.88	12.64	0.00	0.00	0%	0.00	0.00	0%	N/A	1
3630		LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Single Family	2020	2053	44.61	4.99	68.27	68.27	60%	7.64	7.64	60%	0.01 N/A	0
3730 3730		Base Halogen (Specialty) Lighting - 2.5 hrs/day 2020 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family Single Family	2020 2020	2053 2053	467.66 184.82	52.36 20.69	0.00 282.84	0.00 282.84	0% 60%	0.00 31.67	0.00 31.67	0% 60%	0.00	N 0.
3830		Base Halogen (Specialty) Lighting - 6 hrs/day 2020	Single Family	2020	2053	309.62	34.66	0.00	0.00	0%	0.00	0.00	0%	N/A	١
3830		LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	2020	2053	122.36	13.70	187.26	187.26	60%	20.97	20.97	60%	0.00	0
		Base Fluorescent Fixture 1.8 hrs/day	Single Family	2014	2053	777.81	87.08	0.00	0.00	0%	0.00	0.00	0%	N/A	Ň
3900 3900		ROB 2L4'T8, 1EB	Single Family	2014	2053	567.97	63.59	209.84	209.84	27%	23.49	23.49	27%	0.04	0

APPENDIX H

intag		ADDITIVE Existing	SUPPLY ANALYSIS				Year	2020		Total			Total		Marginal	I Ave
ntag	je	Existing			Measure	Measure	,			Energy	Percent		Capacity	Percent	Energy	Ene
	Base	Measure		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Co
mt l			Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/k
	4000		D Base Refrigerator	Single Family	2014	2053	991.68	160.73	0.00	0.00	0%	0.00	0.00	0%	N/A	١
	4000 4100		Refrigerator (Energy Star) Base RefrigeratorEarly Replacement	Single Family Single Family	2014 2014	2053 2053	835.60 140.69	135.43 22.80	156.08 0.00	156.08 0.00	16% 0%	25.30 0.00	25.30 0.00	16% 0%	0.04 N/A	0
	4100		Refrigerator - Early Replacement (Energy Star)	Single Family	2014	2053	77.73	12.60	62.96	62.96	45%	10.20	10.20	45%	0.09	0
	4200		D Base 2nd Refrigerator - Recycling	Single Family	2014	2053	618.86	100.30	0.00	0.00	0%	0.00	0.00	0%	N/A	ì
	4200		1 2nd Refrigerator Recycling	Single Family	2014	2053	159.36	25.83	459.50	459.50	74%	74.48	74.48	74%	0.03	(
	4500		0 Base Freezer	Single Family	2014	2053	417.14	67.61	0.00	0.00	0%	0.00	0.00	0%	N/A	1
	4500 4600		1 Freezer (Energy Star) 0 Base Early Replacement Freezer	Single Family Single Family	2014 2014	2053 2053	380.37 104.06	61.65 16.47	36.77 0.00	36.77 0.00	9% 0%	5.96 0.00	5.96 0.00	9% 0%	0.05 N/A	
	4600		Freezer - Early Replacement (Energy Star)	Single Family	2014	2053	47.80	7.57	56.26	56.26	54%	8.91	8.91	54%	0.04	
	4700		D Base 2nd Freezer Recycling	Single Family	2014	2053	32.02	5.07	0.00	0.00	0%	0.00	0.00	0%	N/A	
	4700		1 2nd Freezer Recycling	Single Family	2014	2053	16.17	2.56	15.85	15.85	50%	2.51	2.51	50%	0.02	
	5000		D Base Water Heating (40 gal, EF=0.88)	Single Family	2014	2053	2,760.04	339.93	0.00	0.00	0%	0.00	0.00	0%	N/A	
	5000 5000		6 Pipe Wrap 7 Hot water turndown 5 degrees	Single Family Single Family	2014 2014	2053 2053	2,675.24 2,665.88	329.49 328.34	84.80 9.36	84.80 94.16	3% 3%	10.44 1.15	10.44 11.60	3% 3%	0.02	
	5000		8 Hot water turndown 5 degrees	Single Family Single Family	2014	2053	2,653.22	328.34	12.66	106.82	3% 4%	1.15	13.16	3% 4%	0.02	
	5000		O Hot water turndown 20 degrees	Single Family	2014	2053	2,652.09	326.64	1.13	107.95	4%	0.14	13.29	4%	0.02	
	5000		9 Hot water turndown 15 degrees	Single Family	2014	2053	2,649.11	326.27	2.98	110.93	4%	0.37	13.66	4%	0.02	
	5000		5 Low Flow Showerhead 1.5 Gal/Min	Single Family	2014	2053	2,569.93	316.52	79.18	190.11	7%	9.75	23.41	7%	0.02	
	5000 5000		1 Drain Water Heat Recovery (GFX) 4 Faucent Aerators	Single Family	2014 2014	2053 2053	2,473.33 2,420.92	304.62 298.17	96.60 52.41	286.71 339.12	10% 12%	11.90 6.46	35.31 41.77	10% 12%	0.05	
	5000 5000		4 Faucent Aerators 5 DHW Tank Wrap	Single Family Single Family	2014 2014	2053 2053	2,420.92 2,279.91	298.17 280.80	52.41 141.00	339.12 480.13	12% 17%	6.46 17.37	41.77 59.13	12% 17%	0.05	
	5000		3 Heat Pump Water Heater - Energy Star	Single Family	2014	2053	1,954.44	240.71	325.48	805.60	29%	40.09	99.22	29%	0.06	
	5000	500	4 Solar Domestic Water Heating	Single Family	2014	2053	1,041.06	128.22	913.38	1,718.98	62%	112.49	211.71	62%	0.16	
	5000		2 Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family	2014	2053	1,038.30	127.88	2.77	1,721.74	62%	0.34	212.05	62%	3.70	
	5000 5100		3 Energy Star Dishwasher (EF=0.72)	Single Family	2014	2053	1,036.03	127.60 59.99	2.27	1,724.01	62% 0%	0.28	212.33	62% 0%	3.64 N/A	
	5100		Base Water Heating Early Replacement to Heat Pump Water Heat Pump Water Heater - Energy Star - Early Replacement	Single Family	2014 2014	2053 2053	487.07 417.53	51.42	0.00 69.53	0.00 69.53	14%	0.00 8.56	8.56	14%	0.07	
	5500		D Base Clotheswasher (MEF=1.26)	Single Family	2014	2053	74.50	13.46	0.00	0.00	0%	0.00	0.00	0%	N/A	
	5500		1 Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family	2014	2053	56.55	10.22	17.95	17.95	24%	3.24	3.24	24%	1.18	
	5600		D Base Clothes Dryer (EF=3.01)	Single Family	2014	2053	1,055.90	178.70	0.00	0.00	0%	0.00	0.00	0%	N/A	
	5600		2 High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family	2014	2053	861.96	145.88	193.94	193.94	18%	32.82	32.82	18%	0.05	
	5600 5700		1 Heat Pump Dryer 0 Base Dishwasher (EF=0.65)	Single Family Single Family	2014 2014	2053 2053	430.98 256.25	72.94 42.02	430.98 0.00	624.92 0.00	59% 0%	72.94 0.00	105.76 0.00	59% 0%	0.77 N/A	
	5700		1 Energy Star Dishwasher (EF=0.72)	Single Family	2014	2053	247.12	40.53	9.13	9.13	4%	1.50	1.50	4%	1.59	
	6000		0 Base Single Speed Pool Pump (RET)	Single Family	2014	2053	278.12	33.07	0.00	0.00	0%	0.00	0.00	0%	N/A	
	6000		2 Variable-Speed Pool Pump (<1 hp)	Single Family	2014	2053	77.04	9.16	201.08	201.08	72%	23.91	23.91	72%	0.03	
	6000		1 PV-Powered Pool Pumps	Single Family	2014	2053	3.08	0.37	73.96	275.04	99%	8.79	32.71	99%	1.02	
	7000 7000		Base Plasma TV Energy Star Plasma TV	Single Family Single Family	2014 2014	2053 2053	135.72 123.92	19.58 17.88	0.00 11.80	0.00 11.80	0% 9%	0.00 1.70	0.00 1.70	0% 9%	N/A 0.01	
	7000		2 Plug Load Controls - Smart Power Strip (base plasma TV)	Single Family	2014	2053	122.98	17.74	0.94	12.74	9%	0.14	1.84	9%	4.08	
	7100		0 Base LCD TV	Single Family	2014	2053	317.27	45.78	0.00	0.00	0%	0.00	0.00	0%	N/A	
	7100		1 Energy Star LCD TV	Single Family	2014	2053	207.82	29.98	109.45	109.45	34%	15.79	15.79	34%	0.00	
	7100		2 Plug Load Controls - Smart Power Strip (base LCD TV)	Single Family	2014	2053	203.47	29.36	4.35	113.80	36%	0.63	16.42	36%	4.38	
	7200 7200		Base CRT TV Plug Load Controls - Smart Power Strip (base CRT TV)	Single Family Single Family	2014 2014	2053 2053	103.11 97.12	14.88 14.01	0.00 5.99	0.00 5.99	0% 6%	0.00	0.00	0% 6%	N/A 1.20	
	7300		D Base Set-Top Box	Single Family	2014	2053	389.53	56.20	0.00	0.00	0%	0.00	0.00	0%	N/A	
	7400		D Base DVD Player	Single Family	2014	2053	47.21	6.81	0.00	0.00	0%	0.00	0.00	0%	N/A	
	7400		1 Energy Star DVD Player	Single Family	2014	2053	22.25	3.21	24.96	24.96	53%	3.60	3.60	53%	0.01	
	7400		2 Plug Load Controls - Smart Power Strip (base DVD player)	Single Family	2014	2053	2.42	0.35	19.83	44.78	95%	2.86	6.46	95%	0.74	
	7500 7500		D Base Desktop PC	Single Family	2014	2053	423.38	55.78 49.21	0.00	0.00 49.81	0% 12%	0.00 6.56	0.00	0% 12%	N/A 0.00	
	7500		Energy Star Desktop PC Plug Load Controls - Smart Power Strip (base Desktop PC)	Single Family Single Family	2014 2014	2053 2053	373.57 268.77	35.41	49.81 104.80	154.61	37%	13.81	6.56 20.37	37%	0.00	
	7600		D Base Laptop PC	Single Family	2014	2053	75.86	9.99	0.00	0.00	0%	0.00	0.00	0%	N/A	
	7600	760	1 Energy Star Laptop PC	Single Family	2014	2053	63.79	8.40	12.07	12.07	16%	1.59	1.59	16%	0.03	
	8000		0 Base Cooking	Single Family	2014	2053	929.00	296.60	0.00	0.00	0%	0.00	0.00	0%	N/A	
	9000		D Base Miscellaneous	Single Family	2014	2053	565.76	74.53	0.00	0.00	0% 0%	0.00	0.00	0%	N/A	
	9900		Base House Use Indirect Feedback	Single Family Single Family	2014 2014	2053 2053	25,081.46 24,708.94	6,210.75 6.118.50	0.00 372.52	0.00 372.52	1%	0.00 92.24	0.00 92.24	0% 1%	N/A 0.02	
	9900		2 Direct Feedback	Single Family	2014	2053	23,544.13	5,830.07	1,164.81	1,537.33	6%	288.44	380.68	6%	0.06	
	1000	100	Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	Multi-Family	2014	2053	157.52	93.58	0.00	0.00	0%	0.00	0.00	0%	N/A	
	1000	102	4 Self Install Weatherization (CAC)	Multi-Family	2014	2053	155.02	92.09	2.51	2.51	2%	1.49	1.49	2%	0.02	
	1000		5 Door Weatherization (CAC)	Multi-Family	2014	2053	147.51	87.63	7.51	10.02	6%	4.46	5.95	6%	0.07	
	1000 1000		Programmable Thermostat (CAC) Proper Refrigerant Charging and Air Flow (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	146.36 135.85	86.95 80.71	1.15 10.51	11.16 21.67	7% 14%	0.68 6.24	6.63 12.87	7% 14%	0.12 0.12	
	1000		Proper Retrigerant Charging and Air Flow (CAC) Duct Insulation (CAC)	Multi-Family	2014	2053	135.85	80.71	0.28	21.67	14%	0.16	12.87	14%	0.12	
	1000		1 Return Duct Modification (CAC)	Multi-Family	2014	2053	134.79	80.08	0.79	22.73	14%	0.47	13.51	14%	0.19	
	1000	100	1 14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	Multi-Family	2014	2053	126.15	74.95	8.64	31.37	20%	5.13	18.64	20%	0.20	
	1000	100	2 15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Multi-Family	2014	2053	118.61	70.47	7.54	38.91	25%	4.48	23.12	25%	0.24	
	1000		3 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Multi-Family	2014	2053	106.03	62.99	12.58	51.49	33%	7.48	30.59	33%	0.31	
	1000		4 Crawlspace insulation (CAC) 6 Ceiling Fans (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	105.66 100.02	62.77 59.42	0.37 5.64	51.87 57.50	33% 37%	0.22 3.35	30.81 34.16	33% 37%	0.35	
	1000		5 Proper Sizing and Quality Install (CAC)	Multi-Family	2014	2053	90.31	53.65	9.72	67.22	43%	5.77	39.93	43%	0.40	
	1000		3 Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	Multi-Family	2014	2053	86.20	51.21	4.11	71.33	45%	2.44	42.37	45%	0.53	

APPENDIX H

		Existing Construction Title SUPPLY ANALYSIS				Year	2020		Total			Total		Marginal	Average
Ва	ase Meas	sure	Building	Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy	Energy Cost
	1000		Туре	Year	Year	GWH	MW 46.93	Savings	GWH	Savings 50%	Savings	MW	Savings 50%	\$/kWH	\$/kWH 0.32
VA VA	1000	1008 Ceiling R-0 to R-38 Insulation (CAC) 1030 WINDOWS - Double-Glazed Clear to Energy Star (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	79.00 77.23	45.88	7.20 1.76	78.53 80.29	50% 51%	4.28 1.05	46.65 47.70	50%	0.74 0.83	0.32
VA	1000	1020 Duct Testing and Sealing (CAC)	Multi-Family	2014	2053	75.24	44.70	1.99	82.28	52%	1.18	48.88	52%	0.88	0.34
VA	1000	1009 Ceiling R-0 to R-49 Insulation (CAC)	Multi-Family	2014	2053	75.15	44.64	0.09	82.38	52%	0.06	48.94	52%	9.01	0.35
VA	1000	1029 WINDOWS - Default With Sunscreen (CAC)	Multi-Family	2014	2053	69.95	41.55	5.20	87.58	56%	3.09	52.03	56%	1.08	0.40
VA VA	1000	1010 Ceiling R-11 to R-38 Insulaton (CAC) 1018 Cool Roof (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	68.90 66.71	40.93 39.63	1.04	88.62 90.82	56% 58%	0.62 1.30	52.65 53.95	56% 58%	2.03 1.93	0.42
VA	1000	1017 Wall Blow-in R-0 to R-13 Insulation (CAC)	Multi-Family	2014	2053	66.09	39.63	0.62	91.43	58%	0.37	54.32	58%	2.47	0.45
VA	1000	1028 Window Film (CAC)	Multi-Family	2014	2053	62.19	36.95	3.90	95.33	61%	2.32	56.64	61%	1.93	0.53
VA	1000	1027 Whole House Fans (CAC)	Multi-Family	2014	2053	58.54	34.78	3.65	98.98	63%	2.17	58.80	63%	2.43	0.60
VA	1000	1011 Ceiling R-11 to R-49 Insulation (CAC)	Multi-Family	2014	2053	58.51	34.76	0.04	99.02	63%	0.02	58.82	63%	11.58	0.60
VA VA	1000	1012 Ceiling R-19 to R-38 Insulation (CAC) 1013 Ceiling R-19 to R-49 Insulation (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	58.40 58.39	34.70 34.69	0.11	99.12 99.13	63% 63%	0.06 0.01	58.89 58.89	63% 63%	4.03 11.61	0.60
VA	1000	1016 Floor R-0 to R-19 Insulation-Batts (CAC)	Multi-Family	2014	2053	58.08	34.59	0.01	99.13	63%	0.01	59.08	63%	6.44	0.62
VA	1000	1015 Basement insulation R-13 (CAC)	Multi-Family	2014	2053	57.95	34.43	0.13	99.57	63%	0.08	59.16	63%	6.52	0.63
VA	1000	1007 AC Filter Changes (CAC)	Multi-Family	2014	2053	57.78	34.32	0.17	99.75	63%	0.10	59.26	63%	6.33	0.64
VA	1000	1006 AC Maintenance and/or tune-up (CAC)	Multi-Family	2014	2053	57.60	34.22	0.18	99.93	63%	0.11	59.37	63%	7.24	0.65
VA VA	1100 1100	1100 Base Split-System Air Conditioner - Early Replacement (11 S		2014 2014	2053 2053	47.64 46.84	28.30	0.00	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.01	N/A 0.01
VA VA	1100	1122 Self Install Weatherization (CAC early replacement) 1117 Duct Insulation (CAC early replacement)	Multi-Family Multi-Family	2014	2053	46.46	27.83 27.60	0.80	1.19	2% 2%	0.48	0.48	2% 2%	0.01	0.01
VA	1100	1123 Door Weatherization (CAC early replacement)	Multi-Family	2014	2053	44.26	26.29	2.20	3.39	7%	1.31	2.01	7%	0.02	0.02
VA		1120 Programmable Thermostat (CAC early replacement)	Multi-Family	2014	2053	43.91	26.09	0.34	3.73	8%	0.20	2.22	8%	0.07	0.04
VA		1102 Proper Refrigerant Charging and Air Flow (CAC early replace		2014	2053	40.08	23.81	3.83	7.56	16%	2.28	4.49	16%	0.07	0.05
VA	1100	1119 Return Duct Modification (CAC early replacement)	Multi-Family	2014	2053	39.85	23.67	0.23	7.79	16%	0.14	4.63	16%	0.11	0.06
VA VA	1100 1100	1112 Crawlspace insulation (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	39.71 35.27	23.59 20.95	0.14 4.44	7.94 12.37	17% 26%	0.08 2.64	4.71 7.35	17% 26%	0.17 0.17	0.06
VA VA	1100	1116 Cool Roof (CAC early replacement) 1125 Whole House Fans (CAC early replacement)	Multi-Family Multi-Family	2014	2053	35.27 28.39	20.95 16.87	4.44 6.88	12.37 19.25	26% 40%	4.09	7.35 11.44	26% 40%	0.17	0.10
VA		1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early		2014	2053	27.68	16.45	0.71	19.25	42%	0.42	11.86	42%	0.23	0.15
VA		1103 Proper Sizing and Quality Install (CAC early replacement)	Multi-Family	2014	2053	24.43	14.52	3.25	23.21	49%	1.93	13.79	49%	0.37	0.18
VA	1100	1118 Duct Testing and Sealing (CAC early replacement)	Multi-Family	2014	2053	23.71	14.08	0.73	23.93	50%	0.43	14.22	50%	0.43	0.19
VA	1100	1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early		2014	2053	22.63	13.44	1.08	25.01	53%	0.64	14.86	53%	0.35	0.20
VA VA	1100 1100	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	Multi-Family	2014 2014	2053 2053	20.74 20.71	12.32 12.31	1.89 0.03	26.90 26.93	56% 57%	1.12 0.02	15.98 16.00	56% 57%	0.50 5.77	0.22
VA		1107 Ceiling R-0 to R-49 Insulation (CAC early replacement) 1113 Basement insulation R-13 (CAC early replacement)	Multi-Family Multi-Family	2014	2053	20.71	12.31	0.03	27.16	57%	0.02	16.00	57%	0.67	0.22
VA		1124 Ceiling Fans (CAC early replacement)	Multi-Family	2014	2053	19.95	11.85	0.53	27.69	58%	0.32	16.45	58%	0.74	0.24
VA		1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Multi-Family	2014	2053	19.65	11.67	0.30	27.99	59%	0.18	16.63	59%	1.26	0.25
VA	1100	1127 WINDOWS - Default With Sunscreen (CAC early replacement		2014	2053	18.71	11.12	0.94	28.93	61%	0.56	17.19	61%	1.06	0.27
VA	1100	1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement)		2014	2053	18.54	11.01	0.17	29.10	61%	0.10	17.29	61%	1.55	0.28
VA VA	1100 1100	1109 Ceiling R-11 to R-49 Insulation (CAC early replacement) 1126 Window Film (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	18.53 17.68	11.01 10.50	0.01 0.85	29.11 29.97	61% 63%	0.01 0.51	17.30 17.80	61% 63%	6.45 1.56	0.28
VA		1110 Ceiling R-19 to R-38 Insulation (CAC early replacement)	Multi-Family	2014	2053	17.64	10.48	0.03	30.00	63%	0.02	17.82	63%	2.36	0.32
VA		1111 Ceiling R-19 to R-49 Insulation (CAC early replacement)	Multi-Family	2014	2053	17.64	10.48	0.00	30.00	63%	0.00	17.82	63%	6.78	0.32
VA	1100	1101 14 SEER (12.15 EER) Split-System Air Conditioner w/ Qualit		2014	2053	16.74	9.95	0.90	30.90	65%	0.53	18.36	65%	2.57	0.39
VA	1100	1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	Multi-Family	2014	2053	16.65	9.89	0.09	30.99	65%	0.05	18.41	65%	3.97	0.40
VA	1100	1105 AC Filter Changes (CAC early replacement)	Multi-Family	2014	2053	16.60	9.86	0.05	31.04	65%	0.03	18.44	65%	3.89	0.40
VA VA	1100 1200	1104 AC Maintenance and/or tune-up (CAC early replacement) 1200 Base Heat Pump Cooling (13 SEER)	Multi-Family Multi-Family	2014 2014	2053 2053	16.55 245.48	9.83 145.83	0.05	31.09 0.00	65% 0%	0.03	18.47 0.00	65% 0%	4.44 N/A	0.41 N/A
VA	1200	1219 Duct Insulation (HP cooling)	Multi-Family	2014	2053	243.47	144.64	2.00	2.00	1%	1.19	1.19	1%	0.03	0.03
VA	1200	1223 Self Install Weatherization (HP cooling)	Multi-Family	2014	2053	239.60	142.34	3.88	5.88	2%	2.30	3.49	2%	0.04	0.03
VA	1200	1224 Door Weatherization (HP cooling)	Multi-Family	2014	2053	227.99	135.45	11.61	17.49	7%	6.90	10.39	7%	0.05	0.05
VA VA	1200 1200	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	189.36 175.77	112.50 104.42	38.63 13.59	56.12 69.71	23% 28%	22.95 8.08	33.34 41.41	23% 28%	0.08	0.07
VA VA	1200	1204 Proper Refrigerant Charging and Air Flow (HP cooling) 1221 Programmable Thermostat (HP cooling)	Multi-Family	2014	2053	175.77	104.42	3.48	73.19	28% 30%	2.07	43.48	28% 30%	0.10	0.08
VA	1200	1214 Crawlspace insulation (HP cooling)	Multi-Family	2014	2053	171.68	102.35	0.60	73.19	30%	0.36	43.46	30%	0.16	0.08
VA	1200	1218 Cool Roof (HP cooling)	Multi-Family	2014	2053	152.50	90.60	19.19	92.98	38%	11.40	55.24	38%	0.24	0.12
VA	1200	1226 Whole House Fans (HP cooling)	Multi-Family	2014	2053	122.76	72.93	29.74	122.72	50%	17.67	72.91	50%	0.33	0.17
VA	1200	1220 Duct Testing and Sealing (HP cooling)	Multi-Family	2014	2053	119.11	70.76	3.65	126.37	51%	2.17	75.07	51%	0.53	0.18
VA VA	1200 1200	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling		2014 2014	2053 2053	113.69 104.09	67.54 61.84	5.42 9.59	131.79 141.38	54% 58%	3.22	78.29 83.99	54% 58%	0.44 0.61	0.19
VA VA		1208 Ceiling R-0 to R-38 Insulation (HP cooling) 1205 Proper Sizing and Quality Install (HP cooling)	Multi-Family Multi-Family	2014	2053	104.09 93.98	55.83	9.59 10.11	141.38 151.49	58% 62%	5.70 6.01	90.00	58% 62%	0.61	0.22
VA	1200	1209 Ceiling R-0 to R-49 Insulation (HP cooling)	Multi-Family	2014	2053	93.72	55.68	0.26	151.49	62%	0.15	90.00	62%	3.57	0.25
VA	1200	1215 Basement insulation R-13 (HP cooling)	Multi-Family	2014	2053	92.69	55.07	1.03	152.79	62%	0.61	90.77	62%	0.92	0.26
VA	1200	1227 WINDOWS - Double-Glazed Clear to Energy Star (HP coolin	g) Multi-Family	2014	2053	90.38	53.69	2.31	155.10	63%	1.37	92.14	63%	1.08	0.28
VA	1200	1225 Ceiling Fans (HP cooling)	Multi-Family	2014	2053	88.02	52.29	2.36	157.46	64%	1.40	93.54	64%	1.05	0.29
VA VA	1200 1200	1210 Ceiling R-11 to R-38 Insulaton (HP cooling) 1211 Ceiling R-11 to R-49 Insulation (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	86.67 86.55	51.49 51.42	1.35 0.13	158.80 158.93	65% 65%	0.80	94.34 94.42	65% 65%	1.73 3.87	0.30
VA VA	1200	1211 Ceiling R-11 to R-49 Insulation (HP cooling) 1216 Floor R-0 to R-19 Insulation-Batts (HP cooling)	Multi-Family Multi-Family	2014	2053	85.65	51.42 50.88	0.13	158.93 159.83	65% 65%	0.07	94.42 94.95	65% 65%	2.42	0.30
VA	1200	1210 Ceiling R-19 to R-38 Insulation (HP cooling)	Multi-Family	2014	2053	85.50	50.66	0.90	159.63	65%	0.55	95.04	65%	3.12	0.31
VA	1200	1213 Ceiling R-19 to R-49 Insulation (HP cooling)	Multi-Family	2014	2053	85.47	50.77	0.03	160.01	65%	0.02	95.06	65%	3.93	0.32
VA	1200	1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling)	Multi-Family	2014	2053	84.77	50.36	0.70	160.71	65%	0.42	95.48	65%	7.69	0.35
VA	1200	1207 Heat Pump Filter Replacement	Multi-Family	2014	2053	84.51	50.21	0.26	160.97	66%	0.15	95.63	66%	5.86	0.36
VA	1200	1206 Heat pump tune up	Multi-Family	2014	2053	84.25	50.05	0.27	161.23	66%	0.16	95.79	66%	9.46	0.37
VA VA	1300 1300	1300 Base Heat Pump Cooling - Early Replacement (13 SEER) 1319 Duct Insulation (HP cooling Early Replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	44.29 43.93	26.31 26.10	0.00 0.36	0.00	0% 1%	0.00 0.21	0.00 0.21	0% 1%	N/A 0.03	N/A 0.03
٧A	1300	1313 Duct insulation (Fir cooling Early Replacement)	wuu-ramily	2014	2003	43.93	20.10	0.30	0.30	1 70	0.21	0.21	170	0.03	0.03

		xisting Construction													
DSM ASSYST Vintage	T ADDITI Existi	VE SUPPLY ANALYSIS			,	Year	2020		Total			Total		Marginal	Average
vintage	EXIST	ng .		Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy
Base	Measi		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost
Sgmt Number			Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH
VA 130 VA 130		323 Self Install Weatherization (HP cooling Early Replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	43.23 41.18	25.68 24.47	0.70 2.05	1.06 3.11	2% 7%	0.42 1.22	0.63 1.85	2% 7%	0.04	0.03
VA 130		1324 Door Weatherization (HP cooling Early Replacement) 1302 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Ea		2014	2053	34.20	20.32	6.98	10.09	23%	4.15	5.99	23%	0.08	0.05
VA 130		1304 Proper Refrigerant Charging and Air Flow (HP cooling Early Re		2014	2053	31.75	18.86	2.46	12.54	28%	1.46	7.45	28%	0.10	0.08
VA 130		314 Crawlspace insulation (HP cooling Early Replacement)	Multi-Family	2014	2053	31.64	18.80	0.11	12.65	29%	0.07	7.52	29%	0.23	0.08
VA 130		321 Programmable Thermostat (HP cooling Early Replacement)	Multi-Family	2014	2053	31.01	18.42	0.63	13.28	30%	0.37	7.89	30%	0.21	0.08
VA 130 VA 130		I318 Cool Roof (HP cooling Early Replacement) I326 Whole House Fans (HP cooling early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	27.55 22.17	16.36 13.17	3.47 5.37	16.74 22.12	38% 50%	2.06 3.19	9.95 13.14	38% 50%	0.24	0.12
VA 130		I320 Duct Testing and Sealing (HP cooling Early Replacement)	Multi-Family	2014	2053	21.51	12.78	0.66	22.78	51%	0.39	13.14	51%	0.52	0.17
VA 130		1322 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling E		2014	2053	20.54	12.20	0.98	23.75	54%	0.58	14.11	54%	0.43	0.19
VA 130		I308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	Multi-Family	2014	2053	18.80	11.17	1.73	25.49	58%	1.03	15.14	58%	0.60	0.21
VA 130		1305 Proper Sizing and Quality Install (HP cooling Early Replacemer	Multi-Family	2014	2053	16.98	10.09	1.83	27.31	62%	1.09	16.23	62%	0.73	0.25
VA 130 VA 130		1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) 1315 Basement insulation R-13 (HP cooling Early Replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	16.93 16.74	10.06 9.95	0.05 0.19	27.36 27.55	62% 62%	0.03	16.25 16.37	62% 62%	3.49 0.90	0.25
VA 130		1327 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling I		2014	2053	16.33	9.70	0.42	27.96	63%	0.25	16.61	63%	1.06	0.27
VA 130		325 Ceiling Fans (HP cooling early replacement)	Multi-Family	2014	2053	15.90	9.45	0.43	28.39	64%	0.25	16.87	64%	1.02	0.28
VA 130		1310 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)		2014	2053	15.66	9.30	0.24	28.63	65%	0.14	17.01	65%	1.69	0.29
VA 130 VA 130		1311 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement)		2014 2014	2053 2053	15.63 15.47	9.29	0.02	28.66 28.82	65% 65%	0.01	17.02 17.12	65% 65%	3.78 2.37	0.30
VA 130 VA 130		I316 Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replaceme I312 Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)	Multi-Family Multi-Family	2014	2053	15.47	9.19 9.18	0.16 0.03	28.82	65%	0.10	17.12	65%	3.05	0.31
VA 130		I313 Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)	Multi-Family	2014	2053	15.44	9.17	0.01	28.85	65%	0.00	17.14	65%	3.83	0.31
VA 130	00 1	1317 Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacer	Multi-Family	2014	2053	15.31	9.10	0.13	28.98	65%	0.08	17.22	65%	7.51	0.34
VA 130		307 Heat Pump Filter Replacement	Multi-Family	2014	2053	15.27	9.07	0.05	29.02	66%	0.03	17.24	66%	5.73	0.35
VA 130 VA 140		1306 Heat pump tune up	Multi-Family	2014 2014	2053 2053	15.22 13.91	9.04 8.26	0.05 0.00	29.07	66% 0%	0.03	17.27 0.00	66% 0%	9.24 N/A	0.37
VA 140		1400 Base Room Air Conditioner - EER 10.6 1413 Self Install Weatherization (RAC)	Multi-Family Multi-Family	2014	2053	13.69	8.13	0.00	0.00 0.22	2%	0.00	0.00	2%	0.01	N/A 0.01
VA 140		1414 Door Weatherization (RAC)	Multi-Family	2014	2053	13.02	7.74	0.66	0.88	6%	0.39	0.53	6%	0.04	0.03
VA 140		1411 Cool Roof (RAC)	Multi-Family	2014	2053	11.57	6.87	1.46	2.34	17%	0.86	1.39	17%	0.13	0.09
VA 140		416 Whole House Fans (RAC)	Multi-Family	2014	2053	9.31	5.53	2.26	4.60	33%	1.34	2.73	33%	0.17	0.13
VA 140 VA 140		1412 Comprehensive Shell Air Sealing - Inf. Reduction (RAC) 1419 WINDOWS - Double-Glazed Clear to Energy Star (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	8.81 8.59	5.23 5.10	0.51 0.22	5.10 5.32	37% 38%	0.30	3.03 3.16	37% 38%	0.19 0.29	0.14 0.14
VA 140		1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	Multi-Family	2014	2053	8.08	4.80	0.51	5.83	42%	0.13	3.46	42%	0.23	0.14
VA 140		1404 Ceiling R-0 to R-38 Insulation (RAC)	Multi-Family	2014	2053	7.44	4.42	0.64	6.47	46%	0.38	3.84	46%	0.36	0.17
VA 140		405 Ceiling R-0 to R-49 Insulation (RAC)	Multi-Family	2014	2053	7.43	4.41	0.02	6.48	47%	0.01	3.85	47%	2.17	0.18
VA 140		415 Ceiling Fans (RAC)	Multi-Family	2014	2053	7.23	4.30	0.19	6.68	48%	0.12	3.97	48%	0.50	0.18
VA 140 VA 140		I417 Window Film (RAC) I410 Wall Blow-in R-0 to R-13 Insulation (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	6.58 6.52	3.91 3.87	0.65 0.07	7.33 7.39	53% 53%	0.39	4.35 4.39	53% 53%	0.50 1.00	0.21
VA 140		1418 WINDOWS - Default With Sunscreen (RAC)	Multi-Family	2014	2053	6.20	3.69	0.07	7.70	55%	0.04	4.58	55%	0.79	0.22
VA 140		1406 Ceiling R-11 to R-38 Insulaton (RAC)	Multi-Family	2014	2053	6.12	3.64	0.08	7.79	56%	0.05	4.63	56%	1.10	0.25
VA 140		1407 Ceiling R-11 to R-49 Insulation (RAC)	Multi-Family	2014	2053	6.11	3.63	0.01	7.80	56%	0.00	4.63	56%	2.64	0.25
VA 140		1408 Ceiling R-19 to R-38 Insulation (RAC)	Multi-Family	2014	2053	6.10	3.63	0.01	7.81	56%	0.01	4.64	56%	1.84	0.26
VA 140 VA 140		1409 Ceiling R-19 to R-49 Insulation (RAC) 1403 Room AC Filter Replacement	Multi-Family Multi-Family	2014 2014	2053 2053	6.10 6.08	3.62 3.61	0.00 0.02	7.81 7.83	56% 56%	0.00	4.64 4.65	56% 56%	2.65 2.61	0.26 0.26
VA 150		1500 Base Room Air Conditioner, Early Replacement - EER 9.7	Multi-Family	2014	2053	1.09	0.65	0.02	0.00	0%	0.00	0.00	0%	N/A	N/A
VA 150	00 1	1501 EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early I	Multi-Family	2014	2053	0.95	0.56	0.15	0.15	13%	0.09	0.09	13%	1.05	1.05
VA 160		1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	Multi-Family	2014	2053	3.17	1.88	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
VA 160		1601 10% better than Energy Star Dehumidifier ROB (35-45 pints/da	Multi-Family	2014	2053	2.68	1.59	0.49	0.49	15%	0.29	0.29	15%	0.19	0.19
VA 170 VA 170		1700 Base Furnace Fan - Furnace & CAC 1701 ECM Furnace Fan (variable speed motor) - Cooling	Multi-Family Multi-Family	2014 2014	2053 2053	232.33 129.07	119.17 66.21	0.00 103.26	0.00 103.26	0% 44%	0.00 52.97	0.00 52.97	0% 44%	N/A 0.03	N/A 0.03
VA 200		2000 Base Heat Pump Space Heating (7.7 HSPF)	Multi-Family	2014	2053	362.58	43.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
VA 200	00 2	2016 Duct Insulation (HP heating)	Multi-Family	2014	2053	359.63	42.67	2.96	2.96	1%	0.35	0.35	1%	0.02	0.02
VA 200		2021 Self Install Weatherization (HP heating)	Multi-Family	2014	2053	353.90	41.99	5.72	8.68	2%	0.68	1.03	2%	0.03	0.03
VA 200		2022 Door Weatherization (HP heating)	Multi-Family	2014	2053	340.51	40.40	13.39	22.07	6%	1.59	2.62	6%	0.05	0.04
VA 200 VA 200		2002 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating) 2012 Crawlspace insulation (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	309.14 308.05	36.68 36.55	31.38 1.08	53.45 54.53	15% 15%	3.72 0.13	6.34 6.47	15% 15%	0.11 0.15	80.0 80.0
VA 200		2019 Programmable Thermostat (HP heating)	Multi-Family	2014	2053	301.95	35.83	6.10	60.63	17%	0.72	7.19	17%	0.13	0.09
VA 200	00 2	2020 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Multi-Family	2014	2053	288.21	34.20	13.74	74.37	21%	1.63	8.82	21%	0.20	0.11
VA 200	00 2	2017 Duct Testing and Sealing (HP heating)	Multi-Family	2014	2053	279.65	33.18	8.57	82.94	23%	1.02	9.84	23%	0.26	0.13
VA 200 VA 200		2006 Ceiling R-0 to R-38 Insulation (HP heating)	Multi-Family	2014 2014	2053	256.05	30.38	23.59	106.53	29% 30%	2.80 0.08	12.64 12.72	29% 30%	0.29	0.16
VA 200 VA 200		2007 Ceiling R-0 to R-49 Insulation (HP heating) 2013 Basement insulation R-13 (HP heating)	Multi-Family Multi-Family	2014	2053 2053	255.34 252.53	30.30 29.96	0.71 2.82	107.24 110.06	30%	0.08	12.72	30%	1.52 0.39	0.17 0.18
200		2010 Bassing, insulation it 10 (iii instilling)	au-i aiilliy	2014	2000	202.00	20.00	2.02	110.00	3070	0.00	10.00	3070	0.00	0.10

DNV·GL ADDITIVE MEASURE LEVEL RESULTS **Base Avoided Costs**

		ic New Cons	struction PLY ANALYSIS				Year	2014							
	New Cons		PLT ANALTSIS				rear	2014		Total			Total		Marginal
					Measure	Measure	9			Energy	Percent		Capacity	Percent	Energy
	Base	Measure		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost
Sgmt	Number	Number	Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH
VA	100	100	Base Code Home - IECC 2006	Single Family	2013	2054	242.08	59.94	0.00	0.00	0%	0.00	0.00	0%	N/A
1//	100	101	Energy Stor Home	Single Family	2012	2054	100 72	EE 1E	E2 2E	E2 2E	220/	4.90	4 90	00/	0.06

APPENDIX H

Vintag		DDITIVE SUPPLY ANALYSIS Existing		Year	2020				Total			Total		Margina
	Base	Measure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost
	Number	Numb Measure	Type	Year	Year	GWH		Savings	GWH	Savings	Savings		Savings	\$/kWH
/A	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB		2020	2054	1,085.70	202.10	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8)	Office Office	2020 2020	2054 2054	1,077.27 996.47	201.32 189.29	8.43 80.81	8.43 89.24	1% 8%	0.78	0.78 12.82	0% 6%	0.01
'A	1030	1038 High Performance Lighting R/R - 25% 1031 ROB 4L4' High Performance T8 (86 W		2020	2054	894.97	170.39	101.49	190.73	18%	18.89	31.71	16%	0.01
Ά	1030	1032 ROB 4L4' Low Watt High Performance		2020	2054	781.10	149.20	113.87	304.60	28%	21.20	52.91	26%	0.04
/A	1030	1037 Occupancy Sensor, 4L4' Fluorescent F		2020	2054	723.19	146.50	57.91	362.51	33%	2.70	55.60	28%	0.05
'A	1030	1034 ROB 4L4' LED Tube, 2020	Office	2020	2054	606.67	124.81	116.53	479.03	44%	21.69	77.29	38%	0.24
A	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB	Office Office	2020	2054 2054	554.88 18.36	115.17 3.42	51.79	530.82	49% 0%	9.64	86.93	43% 0%	0.20 N/A
/A	1130	1136 Lighting Control Tuneup (base 2L4'T8)		2020	2054	18.21	3.40	0.15	0.15	1%	0.00	0.01	0%	0.01
/A	1130	1138 High Performance Lighting R/R - 25%	Office	2020	2054	16.84	3.20	1.37	1.51	8%	0.20	0.22	6%	0.02
/A	1130	1131 ROB 2L4' High Performance T8 (86 W		2020	2054	15.09	2.87	1.75	3.26	18%	0.33	0.54	16%	0.02
A A	1130	1132 ROB 2L4' Low Watt High Performance		2020	2054	13.17	2.52	1.92	5.18	28%	0.36	0.90	26%	0.05
/A	1130 1130	1134 ROB 2L4' LED Tube, 2020 1137 Occupancy Sensor, 2L4' Fluorescent F	Office Office	2020	2054	12.54 11.61	2.40	0.64	5.82 6.75	32% 37%	0.12	1.02	30% 31%	0.18
/A	1130	1135 LED Troffer (base 2L4'T8), 2020	Office	2020	2054	10.62	2.17	0.99	7.74	42%	0.18	1.25	36%	0.25
/A	1200	1200 Base Other Fluorescent Fixture	Office	2014	2054	39.84	7.42	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	1200	1203 Lighting Control Tuneup (base other flu		2014	2054	37.93	7.24	1.90	1.90	5%	0.18	0.18	2%	0.00
/A /A	1200 1200	1205 High Performance Lighting R/R - 25% 1201 ROB High Performance T8 (base othe	Office Office	2014 2014	2054 2054	35.09 31.44	6.81 6.14	2.85 3.65	4.75 8.40	12% 21%	0.42	0.60 1.28	8% 17%	0.03
Λ A	1200	1204 Occupancy Sensor, 4L8' Fluorescent F		2014	2054	27.24	5.94	4.19	12.59	32%	0.00	1.48	20%	0.08
/Α	1200	1202 ROB Low Watt High Performance T8		2014	2054	23.78	5.30	3.47	16.06	40%	0.65	2.12	29%	0.19
Ά	1330	1330 Base Incandescent Flood, 100W to So		2020	2054	368.56	68.61	0.00	0.00	0%	0.00	0.00	0%	N/A
'A	1330	1332 LEDs (base incandescent flood) 2020	Office	2020	2054	88.80	16.53	279.76	279.76	76%	52.08	52.08	76%	0.00
/A /A	1430 1430	1430 Base Incandescent A-Line Lamp, 72W 1432 LEDs (base incandescent A-line 72W)		2020 2020	2054 2054	132.68 34.53	24.70 6.43	0.00 98.15	0.00 98.15	0% 74%	0.00 18.27	0.00 18.27	0% 74%	N/A 0.00
/A	1530	1530 Base Incandescent A-Line Lamp, 53W		2020	2054	97.67	18.18	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	1530	1532 LEDs (base incandescent A-line 53W)		2020	2054	33.85	6.30	63.82	63.82	65%	11.88	11.88	65%	0.01
'A	1630	1630 Base CFL 18W to screw-in replaceme		2020	2054	24.08	4.48	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	1630 1730	1631 LED screw-in replacement (base CFL 1730 Base CFL 23W to screw-in replaceme	Office Office	2020 2020	2054 2054	17.41 30.77	3.24 5.73	6.67 0.00	6.67 0.00	28% 0%	1.24 0.00	1.24 0.00	28% 0%	0.05 N/A
/A	1730	1730 base CFL 23W to screw-in replacement (base CFL	Office	2020	2054	22.77	4.24	8.00	8.00	26%	1.49	1.49	26%	0.04
/A	1800	1800 BaseMetal Halide, 465W	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	1850	1850 Base CFL Exit Sign	Office	2014	2054	12.87	2.40	0.00	0.00	0%	0.00	0.00	0%	N/A
A	1850	1851 LED Exit Sign	Office	2014	2054	7.23	1.35	5.64	5.64	44%	1.05	1.05	44%	0.02
'A 'A	1900 1900	1900 Base Outdoor High Pressure Sodium 2 1901 Outdoor Lighting Controls (Photocell/T		2014 2014	2054 2054	88.06 77.56	1.21 0.73	0.00 10.50	0.00 10.50	0% 12%	0.00	0.00	0% 39%	N/A 0.04
A	1900	1902 LED Outdoor Area Lighting	Office	2014	2054	37.32	0.18	40.24	50.74	58%	0.55	1.03	85%	0.08
Α	1900	1903 Bi-Level LED Outdoor Lighting	Office	2014	2054	26.35	0.04	10.97	61.71	70%	0.14	1.17	96%	0.54
Ά	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton,	Office	2014	2054	136.14	95.24	0.00	0.00	0%	0.00	0.00	0%	N/A
'A 'A	2000 2000	2010 Ceiling/roof Insulation - Chiller	Office Office	2014 2014	2054	135.53 123.96	94.82 86.72	0.61	0.61 12.18	0% 9%	0.42 8.09	0.42 8.52	0% 9%	0.01
/A	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 to 2005 Chiller Tune Up/Diagnostics	Office	2014	2054 2054	123.59	86.60	11.57 0.37	12.16	9%	0.13	8.65	9%	0.03
/Α	2000	2013 High Efficiency Chiller Motors	Office	2014	2054	123.37	86.44	0.22	12.77	9%	0.16	8.80	9%	0.04
/A	2000	2006 VSD for Chiller Pumps and Towers	Office	2014	2054	122.56	86.16	0.81	13.58	10%	0.28	9.09	10%	0.03
Α	2000	2003 EMS - Chiller	Office	2014	2054	113.99	84.66	8.56	22.14	16%	1.50	10.58	11%	0.05
A A	2000 2000	2008 New Economizer - Chiller 2002 Window Film (Standard) - Chiller	Office Office	2014 2014	2054 2054	106.64 106.60	83.37 83.35	7.36 0.03	29.50 29.53	22% 22%	1.29 0.02	11.87 11.89	12% 12%	0.05
Ä	2000	2012 Duct Testing/Sealing - Chiller	Office	2014	2054	86.35	69.18	20.25	49.79	37%	14.17	26.06	27%	0.05
/A	2000	2004 Cool Roof - Chiller	Office	2014	2054	86.08	68.99	0.27	50.05	37%	0.19	26.25	28%	0.22
/A	2000	2011 Duct/Pipe Insulation - Chiller	Office	2014	2054	85.82	68.81	0.27	50.32	37%	0.19	26.44	28%	1.87
/A /A	2100	2100 Base DX Packaged System, EER=10.3		2014	2054	617.70	432.16	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	2100 2100	2102 DX Packaged System, EER=13.4, 10 to 2111 Economizer Repair - DX	Office Office	2014 2014	2054 2054	475.63 454.22	332.76 310.29	142.07 21.40	142.07 163.48	23% 26%	99.40 22.47	99.40 121.87	23% 28%	0.02
/A	2100	2108 Optimize Controls - DX	Office	2014	2054	446.47	308.93	7.76	171.23	28%	1.36	123.23	29%	0.06
/A	2100	2115 Window Film (Standard) - DX	Office	2014	2054	437.24	302.47	9.23	180.46	29%	6.46	129.68	30%	0.10
/A	2100	2105 DX Tune Up/ Advanced Diagnostics	Office	2014	2054	436.45	302.20	0.79	181.25	29%	0.28	129.96	30%	0.09
/A /A	2100	2109 Economizer - DX	Office	2014	2054	388.46	293.81	47.98	229.24	37%	8.39	138.35	32%	0.07
A A	2100 2100	2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX	Office Office	2014 2014	2054 2054	364.84 357.09	277.28 275.93	23.62 7.76	252.86 260.61	41% 42%	16.52 1.36	154.87 156.23	36% 36%	0.19 0.10
/A	2100	2107 Cool Roof - DX	Office	2014	2054	354.04	273.80	3.05	263.66	43%	2.13	158.36	37%	0.10
Ά	2100	2110 Dual Enthalpy Economizer Replaces D		2014	2054	353.96	273.78	0.08	263.74	43%	0.01	158.38	37%	0.20
'A	2100	2114 Duct/Pipe Insulation - DX	Office	2014	2054	351.66	272.18	2.29	266.04	43%	1.60	159.98	37%	2.07
'A	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF		2014	2054	421.72	295.04	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 H 2300 Base PTAC, EER=8.3, 1 ton	Office Office	2014 2014	2054 2054	369.56 67.57	258.55 47.28	52.16 0.00	52.16 0.00	12% 0%	36.49 0.00	36.49 0.00	12% 0%	0.02 N/A
'A	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%		2014	2054	334.29	100.92	0.00	0.00	0%	0.00	0.00	0%	N/A
'A	3000	3002 Variable Speed Drive Control, 5 HP	Office	2014	2054	268.04	95.92	66.25	66.25	20%	5.00	5.00	5%	0.01
/A	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Office	2014	2054	263.67	94.60	4.36	70.62	21%	1.32	6.32	6%	0.02
	3000	3003 Demand Controlled Ventilation	Office	2014	2054	249.34	86.38	14.34	84.95	25%	8.22	14.54	14%	0.60
/A /A	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0	Office	2014	2054	57.92	17.49	0.00	0.00	0%	0.00	0.00	0%	N/A

APPENDIX H

/intag		DDITIVE SUPPLY ANALYSIS Existing		Year	2020				Total			Total		Margina
	Base	Measure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost
	Number	Numb Measure	Type	Year	Year	GWH	MW	Savings	GWH		Savings	s MW	Savings	\$/kWH
'A 'A	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Office	2014	2054 2054	46.16 43.11	16.53 15.70	0.28 3.06	11.76 14.81	20% 26%	0.08	0.95 1.78	5% 10%	0.01
A	3100	3104 Electronically Commutated Motors (EC 3103 Air Handler Optimization, 15 HP	Office Office	2014	2054	38.98	15.70	4.12	18.94	33%	0.83	2.09	10%	0.02
A	3100	3105 Energy Recovery Ventilation (ERV)	Office	2014	2054	38.07	14.87	0.91	19.85	34%	0.52	2.61	15%	0.23
Α	3100	3107 Demand Controlled Ventilation	Office	2014	2054	36.00	13.69	2.07	21.92	38%	1.19	3.80	22%	0.72
/A	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0	Office	2014	2054	36.51	11.02	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	3200 3200	3203 Air Handler Optimization, 40 HP 3202 Variable Speed Drive Control, 40 HP	Office Office	2014 2014	2054 2054	33.02 26.48	10.76 10.27	3.49 6.54	3.49 10.04	10% 27%	0.26	0.26 0.76	2% 7%	0.01
A A	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	Office	2014	2054	26.46	10.27	0.12	10.04	28%	0.49	0.76	7%	0.02
Ά	3200	3204 Demand Controlled Ventilation	Office	2014	2054	24.93	9.41	1.43	11.59	32%	0.82	1.61	15%	0.65
Ά	4000	4000 Base Built-Up Refrigeration System	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	4100 4100	4100 Base Self-Contained Refrigeration	Office	2014 2014	2054 2054	98.08 97.41	13.75	0.00	0.00	0%	0.00	0.00	0%	N/A 0.00
/A /A	4100	4103 Night covers for display cases (self-co 4109 Energy-Star Freezer, glass door	Office Office	2014	2054	97.41	13.66 13.64	0.66 0.16	0.66 0.82	1% 1%	0.09	0.09 0.12	1% 1%	0.00
/A	4100	4104 Freezer-Cooler Replacement Gaskets	Office	2014	2054	95.47	13.39	1.78	2.61	3%	0.25	0.37	3%	0.00
/A	4100	4107 Energy-Star Freezer, solid door	Office	2014	2054	95.40	13.38	0.07	2.67	3%	0.01	0.37	3%	0.01
Ά	4100	4108 Energy-Star Refrigerator, glass door	Office	2014	2054	94.86	13.30	0.55	3.22	3%	0.08	0.45	3%	0.01
'A 'A	4100 4100	4106 Energy-Star Refrigerator, solid door	Office	2014 2014	2054	94.61 94.28	13.27 13.22	0.24	3.46 3.80	4% 4%	0.03	0.49 0.53	4% 4%	0.01
A	4100	4110 Energy Star Ice Machines 4112 Reach-in unit occupancy sensors	Office Office	2014	2054 2054	94.26	13.22	0.04	3.81	4%	0.00	0.53	4%	0.02
/A	4100	4105 Bi-level LED Case Lighting (self-contai		2014	2054	94.25	13.22	0.02	3.83	4%	0.00	0.54	4%	0.31
/A	4100	4101 Strip curtains for walk-ins (self-contain		2014	2054	94.19	13.21	0.06	3.89	4%	0.01	0.55	4%	6.64
'A	5000	5000 Base Desktop PC	Office	2014	2054	40.10	5.56	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	5000 5000	5001 PC Network Power Management Enab 5002 Energy Star or Better PC	Office Office	2014 2014	2054 2054	21.62 16.81	4.28 3.61	18.48 4.81	18.48 23.29	46% 58%	1.28 0.67	1.28 1.95	23% 35%	0.01
/A	5100	5100 Base Laptop PC	Office	2014	2054	3.65	0.51	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	5100	5102 Energy Star or Better Laptop	Office	2014	2054	2.96	0.41	0.69	0.69	19%	0.10	0.10	19%	0.01
/A	5100	5101 Laptop Network Power Management E		2014	2054	2.90	0.40	0.06	0.75	21%	0.01	0.10	21%	0.99
A	5200 5200	5200 Base Monitor, CRT	Office Office	2014	2054 2054	8.50 4.89	1.18 0.68	0.00 3.62	0.00 3.62	0% 43%	0.00	0.00	0% 43%	N/A 0.00
A	5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling	Office	2014	2054	4.89	0.68	0.65	4.27	43% 50%	0.50	0.50	43% 46%	0.00
/A	5200	5203 Plug-load controls - Commercial Smar		2014	2054	3.90	0.59	0.33	4.60	54%	0.05	0.59	50%	0.11
Α	5300	5300 Base Monitor, LCD	Office	2014	2054	7.61	1.06	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	5300	5301 Energy Star or Better Monitor - LCD	Office	2014	2054	6.61	0.92	0.99	0.99	13%	0.14	0.14	13%	0.01
'A 'A	5300 5300	5302 Monitor Power Management Enabling	Office Office	2014	2054 2054	6.12 5.64	0.88	0.49	1.49	20% 26%	0.03	0.17	16% 18%	0.06
'A	5400	5303 Plug-load controls - Commercial Smar 5400 Base Copier	Office	2014	2054	13.93	1.93	0.48	0.00	26% 0%	0.02	0.19	0%	0.18 N/A
'A	5400	5401 Energy Star or Better Copier	Office	2014	2054	12.54	1.74	1.38	1.38	10%	0.19	0.19	10%	0.00
Ά	5400	5402 Copier Power Management Enabling	Office	2014	2054	12.00	1.70	0.54	1.93	14%	0.04	0.23	12%	0.07
A	5500	5500 Base Multifunction	Office	2014	2054	2.37	0.33	0.00	0.00	0%	0.00	0.00	0%	N/A
'A 'A	5500 5500	5502 ENERGY STAR Multi-Function Printer 5501 Multifunction Power Management Ena	Office Office	2014	2054 2054	1.77	0.25	0.59	0.59	25% 39%	0.08	0.08	25% 32%	0.01 0.21
Ά	5600	5600 Base Printer	Office	2014	2054	13.79	1.91	0.00	0.00	0%	0.02	0.00	0%	N/A
Α	5600	5602 ENERGY STAR Printer	Office	2014	2054	9.00	1.25	4.80	4.80	35%	0.67	0.67	35%	0.00
/A	5600	5601 Printer Power Management Enabling	Office	2014	2054	7.36	1.13	1.64	6.44	47%	0.11	0.78	41%	0.04
'A 'A	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Office Office	2014	2054 2054	72.12 64.91	10.01 9.01	0.00 7.21	0.00 7.21	0% 10%	0.00	0.00 1.00	0% 10%	N/A 0.00
Α	5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Office	2014	2054	56.65	7.86	8.26	15.47	21%	1.15	2.15	21%	0.00
/A	5700	5703 Data Center State of the Art practices	Office	2014	2054	53.48	7.42	3.17	18.64	26%	0.44	2.59	26%	0.00
/A	6000	6000 Base Water Heating	Office	2014	2054	82.67	11.17	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	6000	6007 Heat Trap	Office	2014	2054	78.39	10.59	4.28	4.28	5%	0.58	0.58	5%	0.01
/A /A	6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Office Office	2014	2054 2054	76.82 71.06	10.38 9.60	1.57 5.76	5.85 11.61	7% 14%	0.21	0.79 1.57	7% 14%	0.03
/A	6000	6008 Solar Water Heater	Office	2014	2054	33.25	4.49	37.80	49.41	60%	5.11	6.67	60%	0.04
/A	6000	6003 Hot Water Pipe Insulation	Office	2014	2054	32.90	4.44	0.35	49.77	60%	0.05	6.72	60%	0.11
/A	6000	6006 Heat Recovery Unit	Office	2014	2054	30.76	4.16	2.14	51.90	63%	0.29	7.01	63%	0.11
'A	6000	6001 Demand controlled circulating systems		2014	2054	29.84	4.03	0.92	52.83	64%	0.12	7.14	64%	0.33
A A	7000 7000	7000 Base Refrigerated Vending Machines	Office Office	2014	2054 2054	15.06 12.80	2.19	0.00 2.26	0.00 2.26	0% 15%	0.00	0.00 0.16	0% 8%	N/A 0.02
'A	7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-frc		2014	2054	11.57	1.94	1.23	3.49	23%	0.16	0.16	12%	0.02
Ά	7100	7100 Base Non-Refrigerated Vending Machi	Office	2014	2054	0.39	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	7100	7101 Vending Misers (Non-Refrigerated)	Office	2014	2054	0.22	0.04	0.17	0.17	43%	0.01	0.01	21%	0.41
Α	7200	7200 Base Oven	Office	2014	2054	4.43	0.66	0.00	0.00	0%	0.00	0.00	0%	N/A
A	7300 7400	7300 Base Fryer	Office Office	2014	2054 2054	2.80 5.82	0.42	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
A A	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Office	2014	2054	5.82 61.27	0.87	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
A	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 H	Office	2014	2054	57.82	0.00	3.46	3.46	6%	0.00	0.00	0%	0.02
A	8100	8100 Base Heating, Other Electric	Office	2014	2054	61.90	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
/Α	9500	9500 Base Miscellaneous	Office	2014	2054	531.51	77.37	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	9500	9501 Xmisc	Office	2014	2054	531.51	77.37	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EE	Onetoures.	2020	2054	14.87	2.94	0.00	0.00	0%	0.00	0.00	0%	N/A

APPENDIX H

inta		DDITIVE SUPPLY ANALYSIS Existing		Measure	2020 Measure				Total Energy	Percent				Margina Energy
amt	Base Number	Measure Numb Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings	GWH Savings	MW Saving:	Savings s MW	MW Savings	Cost \$/kWH
'A	1030	1038 High Performance Lighting R/R - 2	5% Restauran	2020	2054	13.73	2.76	1.12	1.15	8%	0.18	0.18	6%	0.01
A A	1030 1030	1031 ROB 4L4' High Performance T8 (8) 1032 ROB 4L4' Low Watt High Performa			2054 2054	12.30	2.48	1.43	2.57 4.14	17% 28%	0.28	0.46	16% 26%	0.03
À	1030	1037 Occupancy Sensor, 4L4' Fluoresce		2020	2054	10.58	2.16	0.15	4.29	29%	0.01	0.78	26%	0.13
١	1030	1034 ROB 4L4' LED Tube, 2020	Restauran	2020	2054	8.88	1.82	1.71	5.99	40%	0.34	1.11	38%	0.40
	1030 1130	1035 LED Troffer (base 4L4T8), 2020 1130 Base Fluorescent Fixture, 2L4T8,	Restauran	2020 2020	2054 2054	8.12 88.32	1.67 17.43	0.76	6.75 0.00	45% 0%	0.15	1.26 0.00	43% 0%	0.33 N/A
	1130	1136 Lighting Control Tuneup (base 2L4		2020	2054	88.18	17.42	0.14	0.14	0%	0.01	0.01	0%	0.02
	1130	1138 High Performance Lighting R/R - 2		2020	2054	81.51 73.03	16.38	6.67 8.48	6.81	8% 17%	1.04	1.06	6% 16%	0.02
	1130 1130	1131 ROB 2L4' High Performance T8 (8) 1132 ROB 2L4' Low Watt High Performa		2020	2054 2054	63.74	14.70 12.87	9.29	15.29 24.58	28%	1.67	2.73 4.57	26%	0.04
	1130	1134 ROB 2L4' LED Tube, 2020	Restauran	2020	2054	60.66	12.26	3.08	27.66	31%	0.61	5.17	30%	0.32
	1130	1135 LED Troffer (base 2L4'T8), 2020	Restauran	2020	2054	55.48	11.24	5.18	32.84	37%	1.02	6.20	36%	0.40
	1130 1200	1137 Occupancy Sensor, 2L4' Fluoresce 1200 Base Other Fluorescent Fixture	nt Restauran Restauran		2054 2054	54.70	11.20	0.78	33.62 0.00	38% 0%	0.04	6.23	36% 0%	0.26 N/A
	1330	1330 Base Incandescent Flood, 100W to			2054	73.49	14.51	0.00	0.00	0%	0.00	0.00	0%	N/A
	1330	1332 LEDs (base incandescent flood) 20			2054	15.60	3.08	57.89	57.89	79%	11.43	11.43	79%	0.01
	1430	1430 Base Incandescent A-Line Lamp, 7			2054	26.46	5.22	0.00	0.00	0%	0.00	0.00	0%	N/A
	1430 1530	1432 LEDs (base incandescent A-line 72 1530 Base Incandescent A-Line Lamp, 5		2020	2054 2054	6.09 19.48	1.20 3.84	20.37	20.37	77% 0%	4.02 0.00	4.02 0.00	77% 0%	0.01 N/A
	1530	1532 LEDs (base incandescent A-line 53			2054	6.05	1.19	13.43	13.43	69%	2.65	2.65	69%	0.01
	1630	1630 Base CFL 18W to screw-in replace		2020	2054	12.55	2.48	0.00	0.00	0%	0.00	0.00	0%	N/A
	1630 1730	1631 LED screw-in replacement (base C 1730 Base CFL 23W to screw-in replace		2020 2020	2054 2054	9.07 16.04	1.79 3.17	3.48 0.00	3.48 0.00	28% 0%	0.69	0.69	28% 0%	0.08 N/A
	1730	1731 LED screw-in replacement (base C		2020	2054	11.87	2.34	4.17	4.17	26%	0.00	0.00	26%	0.06
	1800	1800 BaseMetal Halide, 465W	Restauran	2014	2054	0.34	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A
	1800	1801 T5 (240W) (base metal halide)	Restauran	2014	2054	0.22	0.04	0.11	0.11	34%	0.02	0.02	34%	0.02
	1800 1800	1806 Occupancy Sensor, High Bay T5 1805 High Performance Lighting R/R - 2	Restauran		2054 2054	0.21 0.20	0.04	0.01	0.12 0.14	36% 41%	0.00	0.02	34% 38%	0.04 1.06
	1850	1850 Base CFL Exit Sign	Restauran		2054	4.21	0.83	0.00	0.00	0%	0.00	0.00	0%	N/A
	1850	1851 LED Exit Sign	Restauran	2014	2054	1.75	0.35	2.46	2.46	58%	0.49	0.49	58%	0.06
	1900 1900	1900 Base Outdoor High Pressure Sodiu			2054 2054	102.87 85.98	6.81 3.48	0.00 16.89	0.00 16.89	0% 16%	0.00	0.00	0% 49%	N/A
	1900	1901 Outdoor Lighting Controls (Photoco 1902 LED Outdoor Area Lighting	Restauran		2054	41.37	0.52	44.61	61.50	60%	2.96	6.29	49% 92%	0.07 0.16
	1900	1903 Bi-Level LED Outdoor Lighting	Restauran	2014	2054	29.27	-0.20	12.11	73.60	72%	0.73	7.02	103%	1.02
	2000	2000 Base Centrifugal Chiller, 0.58 kW/t			2054	84.79	53.08	0.00	0.00	0%	0.00	0.00	0%	N/A
	2000	2010 Ceiling/roof Insulation - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 50	Restauran	2014	2054 2054	78.62 71.91	49.22 45.02	6.17 6.71	6.17 12.88	7% 15%	3.86 4.20	3.86 8.07	7% 15%	0.02
	2000	2005 Chiller Tune Up/Diagnostics	Restauran	2014	2054	71.78	44.98	0.13	13.02	15%	0.04	8.11	15%	0.02
	2000	2003 EMS - Chiller	Restauran	2014	2054	65.68	44.04	6.09	19.11	23%	0.93	9.04	17%	0.04
	2000	2012 Duct Testing/Sealing - Chiller	Restauran	2014	2054	54.07	36.77	11.62	30.73	36%	7.27	16.31	31%	0.11
	2100 2100	2100 Base DX Packaged System, EER= 2113 Ceiling/roof Insulation - DX	10.:Restauran Restauran	2014 2014	2054 2054	449.34 449.20	281.30 281.22	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.01
	2100	2102 DX Packaged System, EER=13.4,		2014	2054	345.89	216.54	103.32	103.45	23%	64.68	64.76	23%	0.02
	2100	2115 Window Film (Standard) - DX	Restauran	2014	2054	320.80	200.83	25.09	128.53	29%	15.70	80.47	29%	0.02
	2100	2108 Optimize Controls - DX	Restauran	2014	2054	315.20	199.98	5.60	134.14	30%	0.86	81.33	29%	0.04
	2100 2100	2105 DX Tune Up/ Advanced Diagnostic 2106 Prog. Thermostat - DX	s Restauran Restauran	2014 2014	2054 2054	314.84 307.83	199.87 198.79	0.36 7.01	134.49 141.50	30% 31%	0.11	81.44 82.51	29% 29%	0.07
	2100	2112 Duct Testing/Sealing - DX	Restauran		2054	290.41	187.88	17.42	158.93	35%	10.91	93.42	33%	0.13
	2100	2111 Economizer Repair - DX	Restauran		2054	276.94	175.36	13.46	172.39	38%	12.52	105.94	38%	0.12
	2100 2100	2107 Cool Roof - DX 2109 Economizer - DX	Restauran Restauran	2014 2014	2054 2054	268.19 262.70	169.88 169.04	8.76 5.48	181.15 186.63	40% 42%	5.48 0.84	111.42 112.26	40% 40%	0.14
	2100	2110 Dual Enthalpy Economizer Replace			2054	262.55	169.01	0.15	186.78	42%	0.02	112.29	40%	0.16
	2100	2114 Duct/Pipe Insulation - DX	Restauran	2014	2054	259.35	167.01	3.20	189.99	42%	2.00	114.29	41%	1.57
	2200	2200 Base Heat Pump (13 SEER, 7.7 H			2054	140.83	88.17	0.00	0.00	0%	0.00	0.00	0%	N/A
	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 2300 Base PTAC, EER=8.3, 1 ton	Restauran	2014	2054 2054	123.41 16.99	77.26 10.64	17.42 0.00	17.42 0.00	12% 0%	10.90	10.90 0.00	12% 0%	0.01 N/A
	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87			2054	150.38	38.78	0.00	0.00	0%	0.00	0.00	0%	N/A
	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Restauran		2054	147.78	38.11	2.59	2.59	2%	0.67	0.67	2%	0.11
	3000 3000	3002 Variable Speed Drive Control, 5 HF 3003 Demand Controlled Ventilation	Restauran Restauran	2014	2054 2054	103.43 89.51	35.29 28.28	44.35 13.92	46.94 60.86	31% 40%	2.82 7.01	3.49 10.50	9% 27%	0.08
	3100	3100 Base Fan Motor, 15hp, 1800rpm, 9		2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.65 N/A
	3200	3200 Base Fan Motor, 40hp, 1800rpm, 9			2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
	4000	4000 Base Built-Up Refrigeration System		2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
	4100 4100	4100 Base Self-Contained Refrigeration	Restauran	2014 2014	2054 2054	637.81 609.06	95.50 91.20	0.00 28.75	0.00 28.75	0% 5%	0.00 4.31	0.00 4.31	0% 5%	N/A 0.00
	4100	4103 Night covers for display cases (set 4104 Freezer-Cooler Replacement Gask			2054	600.41	89.90	8.65	37.40	6%	1.29	5.60	6%	0.00
	4100	4109 Energy-Star Freezer, glass door	Restauran		2054	590.83	88.47	9.58	46.98	7%	1.43	7.03	7%	0.01
	4100	4107 Energy-Star Freezer, solid door	Restauran	2014	2054	586.86	87.87	3.97	50.95	8%	0.60	7.63	8%	0.02
	4100 4100	4108 Energy-Star Refrigerator, glass doc 4106 Energy-Star Refrigerator, solid doc		2014 2014	2054 2054	582.47 573.01	87.22 85.80	4.39 9.46	55.34 64.80	9% 10%	0.66 1.42	8.29 9.70	9% 10%	0.03
	4100	4110 Energy Star Ice Machines	Restauran		2054	564.41	84.51	8.60	73.40	12%	1.29	10.99	12%	0.03

Vinta		Existing Measure Build		sure/leas		al Tot	al GWH	Total Energy Savings	Percent GWH	MW	Total Capacity Savings	Percent MW	Marginal Energy Cost
		Numb Measure Typ	oe Ye	ear Ye				s GWH	Savings	Saving	s MW	Savings	\$/kWH
A A	4100 4100	4112 Reach-in unit occupancy sensors Restart 4105 Bi-level LED Case Lighting (self-contaRestar)14 20:)14 20:				73.65 74.74	12% 12%	0.04	11.03 11.19	12% 12%	0.29 0.34
/A	4100	4101 Strip curtains for walk-ins (self-containRestai		014 20				76.93	12%	0.10	11.52	12%	0.34
/Α	5000	5000 Base Desktop PC Restar		014 20				0.00	0%	0.00	0.00	0%	N/A
Ά	5000	5001 PC Network Power Management EnabResta		14 20				2.55	45%	0.25	0.25	23%	0.02
/A	5000	5002 Energy Star or Better PC Restar		014 20				3.58	63%	0.20	0.46	41%	0.04
/A /A	5100 5100	5100 Base Laptop PC Restail 5102 Energy Star or Better Laptop Restail		014 20				0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01
/A	5100	5101 Laptop Network Power Management Restai		014 20				0.04	21%	0.00	0.01	21%	1.77
/A	5200	5200 Base Monitor, CRT Restar	uran 20	14 20		4 0.5	9 0.00	0.00	0%	0.00	0.00	0%	N/A
/A	5200	5201 Energy Star or Better Monitor - CRT Restar		014 20				1.71	56%	0.33	0.33	56%	0.00
/A /A	5200 5200	5202 Monitor Power Management Enabling Restau 5203 Plug-load controls - Commercial SmaRestau		014 20				2.03	67% 69%	0.03	0.37	62% 64%	0.03
/A	5300	5300 Base Monitor, LCD Restai		014 20				0.00	0%	0.02	0.00	0%	N/A
/A	5300	5301 Energy Star or Better Monitor - LCD Restar		014 20				0.25	20%	0.05	0.05	20%	0.01
VΑ	5300	5302 Monitor Power Management Enabling Restar		14 20				0.34	27%	0.01	0.06	24%	0.13
/A	5300	5303 Plug-load controls - Commercial Smarkestar		014 20				0.41	32%	0.00	0.06	25%	0.36
/A /A	5400 5400	5400 Base Copier Restar 5401 Energy Star or Better Copier Restar)14 20:)14 20:				0.00	0% 15%	0.00	0.00	0% 15%	N/A 0.00
/A	5400	5401 Energy Star or Better Copier Restar 5402 Copier Power Management Enabling Restar		014 20				0.55	23%	0.07	0.07	19%	0.00
/A	5500	5500 Base Multifunction Restai		014 20				0.00	0%	0.00	0.00	0%	N/A
/A	5500	5502 ENERGY STAR Multi-Function PrinterRestar		014 20				0.23	25%	0.04	0.04	25%	0.01
/A	5500	5501 Multifunction Power Management EnaResta		014 20				0.47	52%	0.02	0.07	39%	0.56
/A /A	5600 5600	5600 Base Printer Restar 5602 ENERGY STAR Printer Restar)14 20:)14 20:				0.00	0% 35%	0.00	0.00	0% 35%	N/A 0.00
VA VA	5600	5601 Printer Power Management Enabling Restar		014 20				0.60	58%	0.07	0.07	47%	0.00
/A	5700	5700 Base Data Center/Server Room Restail		014 20				0.00	0%	0.00	0.00	0%	N/A
VΑ	5700	5701 Data Center Improved Operations Restau		014 20				0.57	10%	0.11	0.11	10%	0.00
/A	5700	5702 Data Center Best Practices Restar						1.22	21%	0.13	0.24	21%	0.00
/A /A	5700 6000	5703 Data Center State of the Art practices Restated 6000 Base Water Heating Restated Restate)14 20:)14 20:				1.46 0.00	26% 0%	0.05	0.29	26% 0%	0.00 N/A
/A	6000	6007 Heat Trap Restai		014 20				3.20	5%	0.54	0.54	5%	0.01
/A	6000	6002 High Efficiency Water Heater (electric)Restau		014 20	54 57.4	0 9.6	9 1.17	4.37	7%	0.20	0.74	7%	0.01
/A	6000	6006 Heat Recovery Unit Restar		14 20				34.22	55%	5.04	5.77	55%	0.01
/A	6000	6004 Tankless Water Heater Restai		014 20				36.28	59%	0.35	6.12	59%	0.04
/A /A	6000 6000	6008 Solar Water Heater Restar 6003 Hot Water Pipe Insulation Restar		014 20				39.85 40.18	65% 65%	0.60	6.72 6.78	65% 65%	0.05
/A	6000	6001 Demand controlled circulating system Restar		014 20				40.99	66%	0.14	6.92	66%	0.18
/A	7000	7000 Base Refrigerated Vending Machines Restar	uran 20	014 20				0.00	0%	0.00	0.00	0%	N/A
/A	7000	7001 Vending Misers (Refrigerated units) Restau		014 20				0.66	16%	0.07	0.07	8%	0.03
/A /A	7000 7100	7002 Vending Misers (Refrigerated glass-frcRestar)14 20:)14 20:				1.03	25% 0%	0.04	0.10	12% 0%	0.05 N/A
/A	7100	7100 Base Non-Refrigerated Vending MachRestat 7101 Vending Misers (Non-Refrigerated) Restat		014 20				0.00	46%	0.00	0.00	23%	0.43
/A	7200	7200 Base Oven Restai		014 20				0.00	0%	0.00	0.00	0%	N/A
/A	7200	7201 Convection Oven Restai	uran 20	14 20				6.55	23%	1.34	1.34	23%	0.13
/A	7300	7300 Base Fryer Restai		014 20				0.00	0%	0.00	0.00	0%	N/A
/A /A	7300 7400	7301 Efficient Fryer Restat 7400 Base Steamer Restat)14 20:)14 20:				2.29 0.00	6% 0%	0.47	0.47	6% 0%	0.43 N/A
/A	7400	7400 Base Steamer Restail		014 20				31.61	69%	6.48	6.48	69%	0.06
VA	8000	8000 Base Heating, Heat Pump (7.7 HSPF)Restar	uran 20	14 20	54 1.8	4 0.0	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HRestar		14 20				0.10	6%	0.00	0.00	0%	0.05
VA	8100 9500	8100 Base Heating, Other Electric Restau)14 20:)14 20:				0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
VA VA	9500	9500 Base Miscellaneous Restail		014 20				0.00	0%	0.00	0.00	0%	N/A N/A
VA.	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB Ret		20 20				0.00	0%	0.00	0.00	0%	N/A
VA.	1030	1036 Lighting Control Tuneup (base 4L4'T8) Ret		20 20				2.09	0%	0.18	0.18	0%	0.01
VΑ	1030	1038 High Performance Lighting R/R - 25% Ret		20 20				69.72	8%	9.69	9.87	6%	0.02
VA.	1030	1031 ROB 4L4' High Performance T8 (86 W Ret		20 20				155.51	17%	15.52	25.40	16%	0.03
VA VA	1030 1030	1032 ROB 4L4' Low Watt High Performance Ret 1037 Occupancy Sensor, 4L4' Fluorescent F Ret)20 20:)20 20:				249.54 258.58	28% 29%	17.02 0.39	42.41 42.81	26% 26%	0.05 0.10
/A	1030	1034 ROB 4L4' LED Tube, 2020 Ret		020 20				361.05	40%	18.54	61.35	38%	0.10
VΑ	1030	1035 LED Troffer (base 4L4'T8), 2020 Ret	ail 20	20 20	54 487.	98 92.2	8 45.55	406.60	45%	8.24	69.59	43%	0.26
/A	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB Ret		20 20	54 178.	68 32.3	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	1130	1136 Lighting Control Tuneup (base 2L4'T8) Ret		20 20				0.42	0%	0.04	0.04	0%	0.02
/A /A	1130 1130	1138 High Performance Lighting R/R - 25% Ret. 1131 ROB 2L4' High Performance T8 (86 W Ret.		020 20				13.93 31.06	8% 17%	1.94 3.10	1.97 5.07	6% 16%	0.03
/A	1130	1131 ROB 2L4' High Performance T8 (86 W Ret 1132 ROB 2L4' Low Watt High Performance Ret		20 20				49.84	28%	3.40	8.47	26%	0.03
/A	1130	1134 ROB 2L4' LED Tube, 2020 Ret		20 20				56.07	31%	1.13	9.60	30%	0.25
/A	1130	1135 LED Troffer (base 2L4'T8), 2020 Ret	ail 20	20 20	54 112.			66.54	37%	1.89	11.49	36%	0.31
VA VA	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent F Ret. 1200 Base Other Fluorescent Fixture Ret.		020 20				68.11 0.00	38% 0%	0.07	11.56 0.00	36% 0%	0.20 N/A

APPENDIX H

Vintag		DDITIVE SUPPLY ANALYSIS Existing		Year	2020				Total			Total		Margina
	Base	Measure	I Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent	Energy Cost
Sgmt	Number	Numb Measure	Type	Year	Year	GWH	MW	Savings	GWH		Savings		Savings	\$/kWH
VA VA	1200	1205 High Performance Lighting R/R - 25%	Retail	2014	2054	1.27	0.24	0.10	0.12	9%	0.01	0.02	7%	0.06
/A /A	1200 1200	1201 ROB High Performance T8 (base othe 1204 Occupancy Sensor, 4L8' Fluorescent F	Retail Retail	2014 2014	2054 2054	1.14	0.21	0.13	0.26	18% 21%	0.02	0.04	16% 17%	0.10
/A	1200	1202 ROB Low Watt High Performance T8	Retail	2014	2054	0.96	0.18	0.14	0.44	31%	0.00	0.04	27%	0.11
/A	1330	1330 Base Incandescent Flood, 100W to Sc	Retail	2020	2054	338.74	61.29	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	1330	1332 LEDs (base incandescent flood) 2020	Retail	2020	2054	59.32	10.73	279.42	279.42	82%	50.56	50.56	82%	0.01
/A /A	1430	1430 Base Incandescent A-Line Lamp, 72W	Retail	2020	2054	121.95	22.07	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	1430 1530	1432 LEDs (base incandescent A-line 72W) 1530 Base Incandescent A-Line Lamp, 53W	Retail Retail	2020	2054 2054	23.23	4.20 16.24	98.72	98.72	81% 0%	17.86	17.86	81% 0%	0.01 N/A
/A	1530	1532 LEDs (base incandescent A-line 53W)	Retail	2020	2054	23.51	4.25	66.26	66.26	74%	11.99	11.99	74%	0.01
/A	1630	1630 Base CFL 18W to screw-in replaceme	Retail	2020	2054	99.18	17.95	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	1630 1730	1631 LED screw-in replacement (base CFL	Retail Retail	2020 2020	2054 2054	71.71 126.73	12.98 22.93	27.47 0.00	27.47 0.00	28% 0%	4.97 0.00	4.97 0.00	28% 0%	0.06 N/A
/A /A	1730	1730 Base CFL 23W to screw-in replacement 1731 LED screw-in replacement (base CFL)	Retail	2020	2054	93.78	16.97	32.95	32.95	26%	5.96	5.96	26%	0.05
/A	1800	1800 BaseMetal Halide, 465W	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	1850	1850 Base CFL Exit Sign	Retail	2014	2054	11.37	2.06	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	1850	1851 LED Exit Sign	Retail	2014	2054	4.99	0.90	6.37	6.37	56%	1.15	1.15	56%	0.04
/A /A	1900 1900	1900 Base Outdoor High Pressure Sodium 2 1901 Outdoor Lighting Controls (Photocell/T		2014 2014	2054 2054	182.10 164.09	11.91 8.46	0.00 18.02	0.00 18.02	0% 10%	0.00 3.45	0.00 3.45	0% 29%	N/A 0.05
/A	1900	1902 LED Outdoor Area Lighting	Retail	2014	2054	78.96	2.89	85.13	103.14	57%	5.57	9.02	76%	0.05
/A	1900	1903 Bi-Level LED Outdoor Lighting	Retail	2014	2054	55.87	1.52	23.09	126.23	69%	1.37	10.39	87%	0.74
/A	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton,	Retail	2014	2054	24.24	20.03	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	2000	2010 Ceiling/roof Insulation - Chiller	Retail	2014	2054 2054	24.03	19.86 18.16	0.21	0.21 2.26	1% 9%	0.17	0.17 1.87	1% 9%	0.03
/A	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 to 2005 Chiller Tune Up/Diagnostics	Retail Retail	2014	2054	21.98	18.10	2.05 0.15	2.26	10%	0.06	1.87	10%	0.04
/A	2000	2003 EMS - Chiller	Retail	2014	2054	20.01	17.71	1.82	4.23	17%	0.39	2.32	12%	0.08
/A	2000	2012 Duct Testing/Sealing - Chiller	Retail	2014	2054	16.21	14.57	3.80	8.03	33%	3.14	5.46	27%	0.23
VA	2100	2100 Base DX Packaged System, EER=10.:		2014	2054	854.18	705.93	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	2100 2100	2102 DX Packaged System, EER=13.4, 101	Retail Retail	2014 2014	2054 2054	657.71 611.76	543.56 489.86	196.46 45.95	196.46 242.41	23% 28%	162.36 53.70	162.36 216.06	23% 31%	0.04
/A	2100	2111 Economizer Repair - DX 2107 Cool Roof - DX	Retail	2014	2054	584.59	467.41	27.18	269.59	32%	22.46	238.52	34%	0.08
/A	2100	2108 Optimize Controls - DX	Retail	2014	2054	574.97	465.35	9.61	279.20	33%	2.06	240.58	34%	0.10
VΑ	2100	2105 DX Tune Up/ Advanced Diagnostics	Retail	2014	2054	572.65	464.36	2.33	281.53	33%	0.99	241.57	34%	0.15
/A /A	2100 2100	2109 Economizer - DX	Retail Retail	2014 2014	2054 2054	523.89 492.03	453.91 427.59	48.76 31.85	330.29 362.14	39% 42%	10.45 26.32	252.01 278.34	36% 39%	0.13
/A	2100	2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX	Retail	2014	2054	478.43	424.67	13.60	375.74	44%	2.91	281.25	40%	0.31
VA.	2100	2115 Window Film (Standard) - DX	Retail	2014	2054	476.68	423.23	1.75	377.50	44%	1.45	282.70	40%	0.38
/A	2100	2110 Dual Enthalpy Economizer Replaces D		2014	2054	476.48	423.18	0.20	377.70	44%	0.04	282.74	40%	0.29
/A /A	2100	2114 Duct/Pipe Insulation - DX	Retail	2014	2054	472.98	420.29	3.50	381.20	45%	2.89	285.64	40%	3.45
/A /A	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF 2201 Heat Pump Upgrade (15 SEER, 8.2 H	Retail Retail	2014 2014	2054 2054	317.23 278.00	262.17 229.75	0.00 39.23	0.00 39.23	0% 12%	0.00 32.42	0.00 32.42	0% 12%	N/A 0.03
/A	2300	2300 Base PTAC, EER=8.3, 1 ton	Retail	2014	2054	55.95	46.24	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Retail	2014	2054	578.78	162.16	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Retail	2014	2054	569.62	159.59	9.16	9.16	2%	2.57	2.57	2%	0.02
/A /A	3000 3000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	403.89 361.48	147.97 125.40	165.73 42.41	174.89 217.30	30% 38%	11.62 22.57	14.18 36.76	9% 23%	0.02 1.14
/A	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0	Retail	2014	2054	20.17	5.65	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	3100	3104 Electronically Commutated Motors (EC	Retail	2014	2054	17.26	4.92	2.91	2.91	14%	0.73	0.73	13%	0.03
VΑ	3100	3103 Air Handler Optimization, 15 HP	Retail	2014	2054	15.54	4.80	1.73	4.63	23%	0.12	0.85	15%	0.03
/A	3100	3102 Variable Speed Drive Control, 15 HP	Retail	2014	2054	11.02	4.48	4.52	9.15	45%	0.32	1.17	21%	0.07
/A /A	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3105 Energy Recovery Ventilation (ERV)	Retail Retail	2014 2014	2054 2054	10.99 10.23	4.47 4.07	0.03 0.75	9.18 9.94	46% 49%	0.01	1.18 1.58	21% 28%	0.20
VA	3100	3107 Demand Controlled Ventilation	Retail	2014	2054	9.16	3.50	1.07	11.01	55%	0.57	2.15	38%	1.57
/A	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0	Retail	2014	2054	20.17	5.65	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	3200	3203 Air Handler Optimization, 40 HP	Retail	2014	2054	18.15	5.51	2.02	2.02	10%	0.14	0.14	3%	0.02
/A /A	3200 3200	3202 Variable Speed Drive Control, 40 HP	Retail	2014	2054	12.87	5.14	5.28	7.30	36% 36%	0.37	0.51	9% 9%	0.06
/A	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Retail Retail	2014	2054 2054	12.85 11.50	5.13 4.41	0.03 1.35	7.32 8.67	43%	0.01 0.72	0.52 1.24	22%	0.27 1.25
/A	4000	4000 Base Built-Up Refrigeration System	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	4100	4100 Base Self-Contained Refrigeration	Retail	2014	2054	466.01	70.84	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	4100	4103 Night covers for display cases (self-co	Retail	2014	2054	457.33	69.52	8.69	8.69	2%	1.32	1.32	2%	0.01
/A /A	4100 4100	4109 Energy-Star Freezer, glass door 4104 Freezer-Cooler Replacement Gaskets	Retail Retail	2014 2014	2054 2054	455.44 445.67	69.23 67.75	1.88 9.77	10.57 20.34	2% 4%	0.29 1.49	1.61 3.09	2% 4%	0.04
/A /A	4100	4104 Freezer-Cooler Replacement Gaskets 4107 Energy-Star Freezer, solid door	Retail	2014	2054	445.67	67.63	0.77	21.11	4% 5%	0.12	3.09	4% 5%	0.04
/A	4100	4108 Energy-Star Refrigerator, glass door	Retail	2014	2054	437.40	66.49	7.50	28.61	6%	1.14	4.35	6%	0.03
/A	4100	4106 Energy-Star Refrigerator, solid door	Retail	2014	2054	436.20	66.30	1.21	29.82	6%	0.18	4.53	6%	0.12
/A	4100	4112 Reach-in unit occupancy sensors	Retail	2014	2054	435.01	66.12	1.19	31.00	7%	0.18	4.71	7%	0.28
/A /A	4100 4100	4110 Energy Star Ice Machines	Retail Retail	2014 2014	2054 2054	434.20 432.07	66.00 65.68	0.81 2.14	31.81 33.94	7% 7%	0.12	4.84 5.16	7% 7%	0.32
/A /A	4100	4105 Bi-level LED Case Lighting (self-contain 4101 Strip curtains for walk-ins (self-contain	Retail	2014	2054	432.07	65.61	0.44	34.38	7% 7%	0.32	5.16	7% 7%	1.93
VA.	5000	5000 Base Desktop PC	Retail	2014	2054	21.51	3.84	0.00	0.00	0%	0.00	0.00	0%	N/A
VΑ	5000	5002 Energy Star or Better PC	Retail	2014	2054	18.25	3.26	3.26	3.26	15%	0.58	0.58	15%	0.01

Vintag	ge	DDITIVE SUPPLY ANALYSIS Existing		Year					Total			Total		Marginal
	Base	Measure	l Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent	Energy Cost
	Number	Numb Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings		Savings	\$/kWH
VA VA	5000 5100	5001 PC Network Power Management Enab 5100 Base Laptop PC	Retail Retail	2014 2014	2054 2054	10.03	2.51 0.16	8.22 0.00	11.48 0.00	53% 0%	0.75	1.33	35% 0%	0.02 N/A
VA	5100	5102 Energy Star or Better Laptop	Retail	2014	2054	0.72	0.10	0.17	0.00	19%	0.03	0.00	19%	0.01
VA	5100	5101 Laptop Network Power Management E	Retail	2014	2054	0.71	0.13	0.01	0.18	21%	0.00	0.03	21%	1.38
VΑ	5200	5200 Base Monitor, CRT	Retail	2014	2054	4.90	0.87	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	5200 5200	5201 Energy Star or Better Monitor - CRT	Retail Retail	2014 2014	2054 2054	2.15 1.80	0.38	2.75 0.35	2.75 3.10	56% 63%	0.49	0.49 0.52	56% 60%	0.00
VA VA	5200	5202 Monitor Power Management Enabling 5203 Plug-load controls - Commercial Smar	Retail	2014	2054	1.66	0.33	0.35	3.10	66%	0.03	0.52	63%	0.02
VA	5300	5300 Base Monitor, LCD	Retail	2014	2054	3.06	0.55	0.00	0.00	0%	0.00	0.00	0%	N/A
VΑ	5300	5301 Energy Star or Better Monitor - LCD	Retail	2014	2054	2.64	0.47	0.42	0.42	14%	0.08	0.08	14%	0.01
VA	5300	5302 Monitor Power Management Enabling	Retail	2014	2054	2.54	0.46	0.10	0.53	17%	0.01	0.09	16%	0.09
/A /A	5300 5400	5303 Plug-load controls - Commercial Smar 5400 Base Copier	Retail Retail	2014 2014	2054 2054	2.34 10.62	0.45 1.90	0.19	0.72	24% 0%	0.01	0.09	17% 0%	0.25 N/A
VA	5400	5401 Energy Star or Better Copier	Retail	2014	2054	9.10	1.62	1.52	1.52	14%	0.00	0.00	14%	0.00
VA	5400	5402 Copier Power Management Enabling	Retail	2014	2054	8.67	1.58	0.43	1.95	18%	0.04	0.31	16%	0.11
VA	5500	5500 Base Multifunction	Retail	2014	2054	1.62	0.29	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	5500	5502 ENERGY STAR Multi-Function Printer	Retail	2014	2054	1.22	0.22	0.41	0.41	25%	0.07	0.07	25%	0.01
VA VA	5500 5600	5501 Multifunction Power Management Enal	Retail	2014 2014	2054	1.05 4.65	0.20	0.17	0.58	36%	0.02	0.09	30% 0%	0.28 N/A
VA VA	5600	5600 Base Printer 5602 ENERGY STAR Printer	Retail Retail	2014	2054 2054	3.03	0.63	1.62	0.00 1.62	0% 35%	0.00	0.00	35%	0.00
VA.	5600	5601 Printer Power Management Enabling	Retail	2014	2054	2.60	0.50	0.43	2.04	44%	0.04	0.33	39%	0.06
VA	5700	5700 Base Data Center/Server Room	Retail	2014	2054	16.72	2.98	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	5700	5701 Data Center Improved Operations	Retail	2014	2054	15.05	2.69	1.67	1.67	10%	0.30	0.30	10%	0.00
VA VA	5700 5700	5702 Data Center Best Practices	Retail	2014	2054	13.13 12.40	2.34	1.91 0.74	3.59 4.32	21% 26%	0.34	0.64	21% 26%	0.00
VA VA	6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Retail Retail	2014 2014	2054 2054	88.87	2.21 14.28	0.74	0.00	0%	0.13	0.00	0%	N/A
VA.	6000	6007 Heat Trap	Retail	2014	2054	84.27	13.54	4.60	4.60	5%	0.74	0.74	5%	0.02
VA	6000	6002 High Efficiency Water Heater (electric)	Retail	2014	2054	82.61	13.27	1.66	6.26	7%	0.27	1.01	7%	0.04
VA.	6000	6004 Tankless Water Heater	Retail	2014	2054	76.41	12.28	6.20	12.46	14%	1.00	2.00	14%	0.07
VA VA	6000 6000	6008 Solar Water Heater 6003 Hot Water Pipe Insulation	Retail Retail	2014 2014	2054 2054	74.27 73.05	11.93 11.74	2.14 1.22	14.60 15.82	16% 18%	0.34	2.35 2.54	16% 18%	0.08
VA	6000	6006 Heat Recovery Unit	Retail	2014	2054	70.68	11.35	2.37	18.19	20%	0.20	2.92	20%	0.08
VΑ	6000	6001 Demand controlled circulating systems	Retail	2014	2054	69.59	11.18	1.09	19.28	22%	0.17	3.10	22%	0.13
VΑ	7000	7000 Base Refrigerated Vending Machines	Retail	2014	2054	22.16	3.96	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	7000 7000	7001 Vending Misers (Refrigerated units)	Retail Retail	2014	2054 2054	19.04 17.35	3.68	3.13 1.69	3.13 4.82	14% 22%	0.28	0.28	7% 11%	0.02
VA VA	7100	7002 Vending Misers (Refrigerated glass-frc 7100 Base Non-Refrigerated Vending Machi	Retail	2014 2014	2054	0.11	0.02	0.00	0.00	22% 0%	0.15	0.43	0%	0.04 N/A
VA	7100	7101 Vending Misers (Non-Refrigerated)	Retail	2014	2054	0.06	0.02	0.04	0.04	40%	0.00	0.00	20%	0.40
VΑ	7200	7200 Base Oven	Retail	2014	2054	14.10	2.55	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	7200	7201 Convection Oven	Retail	2014	2054	10.86	1.96	3.24	3.24	23%	0.59	0.59	23%	0.13
/A	7300 7300	7300 Base Fryer 7301 Efficient Fryer	Retail Retail	2014 2014	2054 2054	2.58	0.47	0.00	0.00	0% 6%	0.00	0.00	0% 6%	N/A 0.43
VA VA	7400	7400 Base Steamer	Retail	2014	2054	10.12	1.83	0.00	0.00	0%	0.03	0.03	0%	0.43 N/A
VA	7400	7401 Efficient Steamer	Retail	2014	2054	3.61	0.65	6.51	6.51	64%	1.18	1.18	64%	0.05
VΑ	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Retail	2014	2054	13.99	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 H	Retail	2014	2054	13.20	0.00	0.79	0.79	6%	0.00	0.00	0%	0.04
/A	8100 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	Retail Retail	2014 2014	2054 2054	51.10 1,389.43	0.00 248.50	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
/A	9500	9500 Base Miscellarieous 9501 Xmisc	Retail	2014		1,389.43	248.50	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB		2020	2054	144.92	22.11	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	1030	1036 Lighting Control Tuneup (base 4L4'T8)		2020	2054	144.77	22.10	0.15	0.15	0%	0.01	0.01	0%	0.01
VA	1030	1038 High Performance Lighting R/R - 25%		2020	2054	133.68	20.77	11.09	11.24	8%	1.33	1.34	6%	0.01
VA VA	1030 1030	1031 ROB 4L4' High Performance T8 (86 W 1032 ROB 4L4' Low Watt High Performance		2020 2020	2054 2054	119.99 104.72	18.69 16.36	13.69 15.27	24.93	17% 28%	2.09	3.42 5.75	15% 26%	0.03
VA VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent F		2020	2054	104.72	16.30	1.56	41.76	29%	0.06	5.75	26%	0.07
VA	1030		Grocery	2020	2054	86.54	13.77	16.62	58.38	40%	2.54	8.34	38%	0.42
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	Grocery	2020	2054	79.16	12.64	7.39	65.77	45%	1.13	9.47	43%	0.35
VA	1130	1130 Base Fluorescent Fixture, 2L4T8, 1EB		2020	2054	0.51	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	1130	1136 Lighting Control Tuneup (base 2L4'T8)		2020 2020	2054	0.51 0.47	0.08	0.00	0.00	0% 8%	0.00	0.00	0% 6%	0.01
VA VA	1130 1130	1138 High Performance Lighting R/R - 25% 1131 ROB 2L4' High Performance T8 (86 W		2020	2054 2054	0.47	0.07	0.04	0.04	8% 17%	0.00	0.00	15%	0.02
VA.	1130	1132 ROB 2L4' Low Watt High Performance		2020	2054	0.37	0.06	0.05	0.14	27%	0.01	0.02	26%	0.09
/A	1130	1137 Occupancy Sensor, 2L4' Fluorescent F		2020	2054	0.36	0.06	0.01	0.15	29%	0.00	0.02	26%	0.17
VΑ	1130		Grocery	2020	2054	0.35	0.05	0.02	0.16	32%	0.00	0.02	29%	0.34
VA.	1130		Grocery	2020	2054	0.32	0.05	0.03	0.19	38%	0.00	0.03	35%	0.43
/A /A	1200		Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	1330 1330	1330 Base Incandescent Flood, 100W to Sc 1332 LEDs (base incandescent flood) 2020		2020 2020	2054 2054	44.35 16.64	6.77 2.54	0.00 27.71	0.00 27.71	0% 62%	0.00 4.23	0.00 4.23	0% 62%	N/A 0.00
/A	1430	1430 Base Incandescent A-Line Lamp. 72W		2020	2054	15.97	2.44	0.00	0.00	02 %	0.00	0.00	0%	N/A
/A	1430	1432 LEDs (base incandescent A-line 72W)		2020	2054	6.38	0.97	9.59	9.59	60%	1.46	1.46	60%	0.01
VΑ	1530	1530 Base Incandescent A-Line Lamp, 53W 1532 LEDs (base incandescent A-line 53W)		2020	2054	11.75	1.79	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	1530			2020	2054	5.89	0.90	5.87	5.87	50%	0.90	0.90	50%	0.01

Vintag		DITIVE SUPPLY ANALYSIS Existing		Year	2020 eWeasure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy
		Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost
/A	Number 1630	Numb Measure 1630 Base CFL 18W to screw-in replacem	Type e Grocery	Year 2020	Year 2054	3.18	MW 0.48	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A
Α	1630	1631 LED screw-in replacement (base CF		2020	2054	2.30	0.35	0.88	0.88	28%	0.13	0.13	28%	0.10
'A 'A	1730 1730	1730 Base CFL 23W to screw-in replacem		2020	2054 2054	4.06 3.01	0.62	0.00	0.00 1.06	0% 26%	0.00	0.00 0.16	0% 26%	N/A 0.07
A A	1800	1731 LED screw-in replacement (base CF 1800 BaseMetal Halide, 465W	L. Grocery Grocery	2020	2054	7.60	0.46 1.16	1.06	0.00	0%	0.16	0.16	0%	N/A
A	1800	1805 High Performance Lighting R/R - 259		2014	2054	7.02	1.09	0.58	0.58	8%	0.07	0.07	6%	0.01
Α	1800	1801 T5 (240W) (base metal halide)	Grocery	2014	2054	4.64	0.73	2.37	2.95	39%	0.36	0.43	37%	0.01
Α	1800	1806 Occupancy Sensor, High Bay T5	Grocery	2014	2054	4.49	0.72	0.16	3.11	41%	0.01	0.44	38%	0.03
'A 'A	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Grocery Grocery	2014 2014	2054 2054	0.30	0.05 0.04	0.00	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.03
Ά	1900	1900 Base Outdoor High Pressure Sodium		2014	2054	2.31	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	1900	1901 Outdoor Lighting Controls (Photocell	√ Grocery	2014	2054	2.05	0.04	0.26	0.26	11%	0.02	0.02	36%	0.08
Ά	1900	1902 LED Outdoor Area Lighting	Grocery	2014	2054	0.99	0.01	1.07	1.33	57%	0.03	0.05	82%	0.17
'A 'A	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/tor	Grocery n, Grocery	2014 2014	2054 2054	0.70 4.02	2.62	0.29	1.62 0.00	70% 0%	0.01	0.05	94% 0%	1.12 N/A
Λ A	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500		2014	2054	3.67	2.40	0.34	0.34	9%	0.00	0.00	9%	0.04
Ά	2000	2005 Chiller Tune Up/Diagnostics	Grocery	2014	2054	3.67	2.40	0.01	0.35	9%	0.00	0.23	9%	0.03
Ά	2000	2013 High Efficiency Chiller Motors	Grocery	2014	2054	3.55	2.32	0.12	0.47	12%	0.08	0.30	12%	0.06
A	2000	2006 VSD for Chiller Pumps and Towers	Grocery	2014	2054	3.19	2.20	0.36	0.83	21%	0.12	0.42	16%	0.05
'A 'A	2000 2000	2002 Window Film (Standard) - Chiller 2003 EMS - Chiller	Grocery Grocery	2014 2014	2054 2054	2.97 2.67	2.06	0.22	1.05 1.34	26% 33%	0.14	0.56 0.61	21% 23%	0.08 0.08
'A	2000	2004 Cool Roof - Chiller	Grocery	2014	2054	2.47	1.88	0.23	1.55	39%	0.13	0.74	28%	0.12
Α	2000	2012 Duct Testing/Sealing - Chiller	Grocery	2014	2054	2.00	1.57	0.47	2.02	50%	0.31	1.05	40%	0.25
Ά	2000	2011 Duct/Pipe Insulation - Chiller	Grocery	2014	2054	1.97	1.55	0.03	2.05	51%	0.02	1.07	41%	3.91
/A /A	2000 2100	2008 New Economizer - Chiller 2100 Base DX Packaged System, EER=10	Grocery	2014 2014	2054 2054	1.97 124.62	1.55 81.40	0.00	2.05 0.00	51% 0%	0.00	1.07 0.00	41% 0%	####### N/A
Ä	2100	2113 Ceiling/roof Insulation - DX	Grocery	2014	2054	124.46	81.29	0.16	0.16	0%	0.11	0.00	0%	0.03
Α	2100	2102 DX Packaged System, EER=13.4, 10		2014	2054	95.83	62.59	28.63	28.79	23%	18.70	18.80	23%	0.03
Α	2100	2115 Window Film (Standard) - DX	Grocery	2014	2054	89.16	58.24	6.67	35.45	28%	4.36	23.16	28%	0.08
A	2100	2107 Cool Roof - DX	Grocery	2014	2054	82.27	53.74	6.89	42.34	34% 34%	4.50	27.66	34%	0.11
A A	2100 2100	2105 DX Tune Up/ Advanced Diagnostics 2108 Optimize Controls - DX	Grocery Grocery	2014	2054 2054	82.18 80.74	53.71 53.48	0.09	42.44 43.88	35%	0.03	27.69 27.92	34% 34%	0.12
A	2100	2106 Prog. Thermostat - DX	Grocery	2014	2054	79.54	53.29	1.20	45.08	36%	0.19	28.11	35%	0.12
4	2100	2112 Duct Testing/Sealing - DX	Grocery	2014	2054	74.70	50.13	4.84	49.92	40%	3.16	31.27	38%	0.24
4	2100	2110 Dual Enthalpy Economizer Replaces		2014	2054	74.68	50.12	0.02	49.94	40%	0.00	31.27	38%	0.70
Α Α	2100 2100	2111 Economizer Repair - DX 2109 Economizer - DX	Grocery Grocery	2014 2014	2054 2054	73.87 73.86	49.35 49.35	0.81	50.75 50.76	41% 41%	0.77	32.04 32.04	39% 39%	1.36 1.70
A	2100	2114 Duct/Pipe Insulation - DX	Grocery	2014	2054	72.75	48.63	1.11	51.87	42%	0.72	32.77	40%	3.28
A	2200	2200 Base Heat Pump (13 SEER, 7.7 HSF		2014	2054	11.12	7.26	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	2200	2201 Heat Pump Upgrade (15 SEER, 8.2		2014	2054	9.75	6.37	1.38	1.38	12%	0.90	0.90	12%	0.03
Ά	2300 3000	2300 Base PTAC, EER=8.3, 1 ton	Grocery	2014	2054	5.16 121.17	3.37 25.96	0.00	0.00	0% 0%	0.00	0.00	0%	N/A N/A
Ά	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5 3002 Variable Speed Drive Control, 5 HP	Grocery	2014	2054	83.66	24.01	37.51	37.51	31%	1.95	1.95	0% 7%	0.03
Ά	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Grocery	2014	2054	82.22	23.70	1.44	38.95	32%	0.31	2.25	9%	0.06
Ά	3000	3003 Demand Controlled Ventilation	Grocery	2014	2054	70.52	18.68	11.70	50.65	42%	5.02	7.27	28%	1.14
Α	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91		2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
'A 'A	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93 3203 Air Handler Optimization, 40 HP	.0 Grocery Grocery	2014 2014	2054 2054	119.80 107.44	25.66 25.02	0.00 12.37	0.00 12.37	0% 10%	0.00	0.00 0.64	0% 3%	N/A 0.02
/A	3200	3204 Demand Controlled Ventilation	Grocery	2014	2054	92.15	18.46	15.28	27.65	23%	6.56	7.20	28%	0.86
/A	4000	4000 Base Built-Up Refrigeration System	Grocery	2014	2054	504.16	81.17	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	4000	4007 Efficient compressor motor	Grocery	2014	2054	503.18	81.01	0.98	0.98	0%	0.16	0.16	0%	0.02
/A /A	4000 4000	4011 Demand Hot Gas Defrost	Grocery or Grocery	2014	2054 2054	490.60 455.70	78.98 73.36	12.58 34.90	13.56 48.46	3% 10%	2.03 5.62	2.18 7.80	3% 10%	0.02
'A	4000	4006 Electronically commutated evaporate 4009 Floating head pressure controls	Grocery	2014	2054	454.58	73.27	1.12	49.58	10%	0.09	7.89	10%	0.02
/A	4000	4002 Strip curtains for walk-ins (built-up)	Grocery	2014	2054	450.63	72.64	3.94	53.52	11%	0.63	8.53	11%	0.04
Ά	4000	4013 Anti-sweat (humidistat) controls	Grocery	2014	2054	444.35	72.13	6.29	59.81	12%	0.51	9.03	11%	0.04
/A	4000	4014 Freezer-Cooler Replacement Gasket		2014	2054	429.18	69.69	15.16	74.98	15%	2.44	11.47	14%	0.05
'A 'A	4000 4000	4018 Oversized Air Cooled Condenser	Grocery	2014 2014	2054 2054	411.11 389.44	66.78 65.04	18.07 21.67	93.05 114.72	18% 23%	2.91 1.74	14.38 16.13	18% 20%	0.08
Ά	4000	4004 Night covers for display cases 4001 High-efficiency fan motors	Grocery Grocery	2014	2054	375.71	62.83	13.73	128.45	25%	2.21	18.34	23%	0.07
Ά	4000	4008 Compressor VSD retrofit	Grocery	2014	2054	352.42	60.95	23.29	151.74	30%	1.88	20.21	25%	0.10
Α	4000	4010 Refrigeration Commissioning	Grocery	2014	2054	350.61	60.66	1.81	153.55	30%	0.29	20.50	25%	0.18
A	4000	4005 Evaporator fan controller for MT wall		2014	2054	350.36	60.64	0.25	153.80	31%	0.02	20.52	25%	0.24
'A 'A	4000 4000	4017 Multiplex Compressor System 4016 LED Display Lighting	Grocery Grocery	2014 2014	2054 2054	344.19 317.93	59.65 55.42	6.17 26.26	159.97 186.23	32% 37%	0.99 4.23	21.52 25.74	27% 32%	0.26 0.43
A A	4000	4016 LED Display Lighting 4015 High R-Value Glass Doors	Grocery	2014	2054	317.93	54.63	4.92	191.15	38%	0.79	26.54	32%	1.94
A	4100	4100 Base Self-Contained Refrigeration	Grocery	2014	2054	57.45	9.25	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	4100	4103 Night covers for display cases (self-		2014	2054	56.06	9.03	1.39	1.39	2%	0.22	0.22	2%	0.00
A	4100	4104 Freezer-Cooler Replacement Gasket		2014	2054	55.32	8.91	0.74	2.13	4%	0.12	0.34	4%	0.01
۸														
A A	4100 4100	4109 Energy-Star Freezer, glass door 4107 Energy-Star Freezer, solid door	Grocery Grocery	2014 2014	2054 2054	52.33 51.16	8.43 8.24	2.99 1.18	5.12 6.29	9% 11%	0.48 0.19	0.82 1.01	9% 11%	0.03

APPENDIX H

intag		Existing							Total			Total		Margi
amt	Base Number	Measure Numb Measure	Building Type	Measure Start Year	Measure End Year	Total GWH	Total MW	GWH Savings	Energy Savings	Percent GWH Savings	MW Saving	Capacity Savings	Percent MW Savings	Energ Cos \$/kW
Α	4100	4106 Energy-Star Refrigerator, solid door	Grocery	2014	2054	51.07	8.22	0.03	6.38	11%	0.00	1.03	11%	0.09
Α	4100	4110 Energy Star Ice Machines	Grocery	2014	2054	51.05	8.22	0.02	6.40	11%	0.00	1.03	11%	0.24
A	4100 4100	4112 Reach-in unit occupancy sensors 4105 Bi-level LED Case Lighting (self-conta	Grocery	2014 2014	2054 2054	51.04 50.70	8.22 8.16	0.01	6.41 6.75	11% 12%	0.00	1.03	11% 12%	0.2
Α .	4100	4101 Strip curtains for walk-ins (self-contai		2014	2054	50.52	8.13	0.17	6.93	12%	0.03	1.12	12%	0.6
4	5000	5000 Base Desktop PC	Grocery	2014	2054	2.29	0.41	0.00	0.00	0%	0.00	0.00	0%	N/A
Α.	5000	5001 PC Network Power Management Ena		2014	2054	1.25	0.32	1.03	1.03	45%	0.09	0.09	23%	0.0
Α Α	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	Grocery	2014	2054 2054	0.85	0.24	0.41	1.44	63% 0%	0.07	0.17	41% 0%	0.0 N/
A	5100	5102 Energy Star or Better Laptop	Grocery	2014	2054	0.06	0.01	0.01	0.01	19%	0.00	0.00	19%	0.0
A	5100	5101 Laptop Network Power Management		2014	2054	0.06	0.01	0.00	0.01	21%	0.00	0.00	21%	2.0
A A	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Grocery	2014	2054 2054	0.43	0.08	0.00	0.00 0.24	0% 56%	0.00	0.00	0% 56%	N/A 0.0
A	5200	5202 Monitor Power Management Enabling	,	2014	2054	0.19	0.03	0.24	0.24	73%	0.04	0.04	65%	0.0
A	5200	5203 Plug-load controls - Commercial Sma		2014	2054	0.11	0.03	0.01	0.33	76%	0.00	0.05	67%	0.4
Α	5300	5300 Base Monitor, LCD	Grocery	2014	2054	0.68	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A
A	5300	5301 Energy Star or Better Monitor - LCD	Grocery	2014	2054	0.54	0.10	0.14	0.14	20%	0.02	0.02	20%	0.0
A A	5300 5300	5302 Monitor Power Management Enabling		2014	2054 2054	0.47	0.09	0.07	0.21	31% 36%	0.01	0.03	26% 27%	0.1
A A	5400	5303 Plug-load controls - Commercial Sma 5400 Base Copier	Grocery	2014	2054	0.43	0.09	0.04	0.25	0%	0.00	0.03	0%	0.4 N/
A	5400	5401 Energy Star or Better Copier	Grocery	2014	2054	0.44	0.08	0.11	0.11	20%	0.02	0.02	20%	0.0
Α	5400	5402 Copier Power Management Enabling	Grocery	2014	2054	0.38	0.07	0.06	0.17	31%	0.01	0.03	26%	0.2
A	5500	5500 Base Multifunction	Grocery	2014	2054	0.22	0.04	0.00	0.00	0%	0.00	0.00	0%	N/
A A	5500 5500	5502 ENERGY STAR Multi-Function Printe 5501 Multifunction Power Management Ena		2014 2014	2054 2054	0.16 0.12	0.03	0.05	0.05 0.10	25% 46%	0.01	0.01 0.01	25% 36%	0.0
A	5600	5600 Base Printer	Grocery	2014	2054	0.12	0.03	0.00	0.00	0%	0.00	0.00	0%	N/
A	5600	5602 ENERGY STAR Printer	Grocery	2014	2054	0.12	0.02	0.06	0.06	35%	0.01	0.01	35%	0.0
A	5600	5601 Printer Power Management Enabling	Grocery	2014	2054	0.09	0.02	0.03	0.10	53%	0.00	0.01	44%	0.1
A A	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Grocery Grocery	2014 2014	2054 2054	0.45	0.08	0.00	0.00	0% 10%	0.00	0.00	0% 10%	N// 0.0
Α .	5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Grocery	2014	2054	0.40	0.06	0.05	0.10	21%	0.01	0.01	21%	0.0
4	5700	5703 Data Center State of the Art practices		2014	2054	0.33	0.06	0.02	0.12	26%	0.00	0.02	26%	0.0
A	6000	6000 Base Water Heating	Grocery	2014	2054	13.04	2.10	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	6000 6000	6007 Heat Trap 6002 High Efficiency Water Heater (electric	Grocery	2014 2014	2054 2054	12.36 12.11	1.99 1.95	0.68	0.68 0.92	5% 7%	0.11	0.11 0.15	5% 7%	0.0
A A	6000	6006 Heat Recovery Unit	Grocery	2014	2054	5.82	0.94	6.30	7.22	55%	1.01	1.16	55%	0.0
A	6000	6004 Tankless Water Heater	Grocery	2014	2054	5.38	0.87	0.44	7.66	59%	0.07	1.23	59%	0.1
Α	6000	6008 Solar Water Heater	Grocery	2014	2054	4.63	0.74	0.75	8.41	65%	0.12	1.35	65%	0.1
A	6000	6001 Demand controlled circulating system		2014	2054	4.46	0.72	0.17	8.58	66%	0.03	1.38	66%	0.2
A A	6000 7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	Grocery	2014	2054 2054	4.37 11.46	0.70 1.82	0.09	8.67	66% 0%	0.01	1.39	66% 0%	0.2 N/
A	7000	7001 Vending Misers (Refrigerated units)	Grocery	2014	2054	9.75	1.69	1.71	1.71	15%	0.13	0.13	7%	0.0
Α	7000	7002 Vending Misers (Refrigerated glass-fr	Grocery	2014	2054	8.82	1.61	0.92	2.63	23%	0.07	0.21	11%	0.0
Α	7100	7100 Base Non-Refrigerated Vending Mach		2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
A	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Grocery Grocery	2014 2014	2054 2054	0.01 12.90	0.00 1.79	0.01	0.01	43% 0%	0.00	0.00	21% 0%	0.4 N//
A	7300	7300 Base Fryer	Grocery	2014	2054	16.78	2.33	0.00	0.00	0%	0.00	0.00	0%	N/
Α	7400	7400 Base Steamer	Grocery	2014	2054	23.43	3.26	0.00	0.00	0%	0.00	0.00	0%	N/A
A	7400	7401 Efficient Steamer	Grocery	2014	2054	7.16	1.00	16.27	16.27	69%	2.26	2.26	69%	0.0
A A	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF 8001 Heat Pump Upgrade (15 SEER, 8.2 F		2014	2054 2054	0.56	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 0%	N/.
A	8100	8100 Base Heating, Other Electric	Grocery	2014	2054	13.76	0.00	0.00	0.00	0%	0.00	0.00	0%	N/
Α	9500	9500 Base Miscellaneous	Grocery	2014	2054	131.26	20.87	0.00	0.00	0%	0.00	0.00	0%	N/
A	9500	9501 Xmisc	Grocery	2014	2054	131.26	20.87	0.00	0.00	0%	0.00	0.00	0%	N/
A A	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1E 1031 ROB 4L4' High Performance T8 (86 V		2020 2020	2054 2054	448.71 411.35	79.75 73.11	0.00 37.36	0.00 37.36	0% 8%	0.00 6.64	0.00 6.64	0% 8%	N/ 0.0
A A	1030	1036 Lighting Control Tuneup (base 4L4'T8			2054	404.59	72.51	6.77	44.12	10%	0.60	7.24	9%	0.0
A	1030	1032 ROB 4L4' Low Watt High Performance			2054	353.11	63.36	51.48	95.60	21%	9.15	16.38	21%	0.0
A	1030	1038 High Performance Lighting R/R - 25%		2020	2054	326.55	59.60	26.56	122.16	27%	3.77	20.15	25%	0.0
Α	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent		2020 2020	2054 2054	319.89 268.34	59.30 50.14	6.66 51.54	128.82 180.36	29% 40%	0.29 9.16	20.44	26% 37%	0.0
A A	1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Varehous Varehous	2020	2054	268.34	46.07	22.91	203.27	40% 45%	4.07	33.67	37% 42%	0.2
Α .	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1E			2054	3.06	0.54	0.00	0.00	0%	0.00	0.00	0%	N/
A	1130	1131 ROB 2L4' High Performance T8 (86 V			2054	2.74	0.49	0.32	0.32	10%	0.06	0.06	10%	0.0
A	1130	1136 Lighting Control Tuneup (base 2L4T8			2054	2.70	0.48	0.05	0.36	12%	0.00	0.06	11%	0.0
Α	1130	1138 High Performance Lighting R/R - 25%			2054 2054	2.49	0.45	0.20	0.56	18%	0.03	0.09	16%	0.0
A A	1130 1130	1132 ROB 2L4' Low Watt High Performand 1134 ROB 2L4' LED Tube, 2020	«Varehous» Varehous		2054 2054	2.18 2.07	0.40	0.32	0.88	29% 32%	0.06	0.15	27% 30%	0.0
A.	1130	1135 LED Troffer (base 2L4'T8), 2020	Varehous	2020	2054	1.90	0.35	0.11	1.16	38%	0.02	0.16	36%	0.2
Ά	1130	1137 Occupancy Sensor, 2L4' Fluorescent	rv arenous:	2020	2054	1.86	0.35	0.04	1.20	39%	0.00	0.20	36%	0.1

Base Avoided Costs ADDITIVE MEASURE LEVEL RESULTS

DSM . Vinta		DDITIVE SUPPLY ANALYSIS Existing		Year	2020				Total			Total		Margina
	_	Manage			Measure	Total	Total	GWH	Energy	Percent GWH	MW		Percent MW	Energy
Sgmt	Base Number	Measure Numb Measure	Building Type	Start Year	End Year	GWH		Savings	Savings GWH		Savings	Savings MW	Savings	Cost \$/kWH
VA	1200	1205 High Performance Lighting R/R - 25	% Varehous	2014	2054	0.39	0.07	0.03	0.08	17%	0.00	0.01	10%	0.03
VA VA	1200 1200	1204 Occupancy Sensor, 4L8' Fluorescer 1201 ROB High Performance T8 (base ot		2014	2054 2054	0.36	0.07	0.02	0.10	22% 30%	0.00	0.01	12% 20%	0.09
VA	1200	1202 ROB Low Watt High Performance T		2014	2054	0.33	0.06	0.04	0.14	39%	0.01	0.02	29%	0.11
VΑ	1330	1330 Base Incandescent Flood, 100W to		2020	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	1430 1530	1430 Base Incandescent A-Line Lamp, 72 1530 Base Incandescent A-Line Lamp, 53		2020 2020	2054 2054	13.47 9.92	2.39 1.76	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
VA	1630	1630 Base CFL 18W to screw-in replacen		2020	2054	18.72	3.33	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	1630	1631 LED screw-in replacement (base CF	L Varehous	2020	2054	13.54	2.41	5.19	5.19	28%	0.92	0.92	28%	0.06
VA	1730	1730 Base CFL 23W to screw-in replacen		2020	2054	23.92	4.25	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	1730 1800	1731 LED screw-in replacement (base CF 1800 BaseMetal Halide, 465W	Varehous	2020 2014	2054 2054	17.70 270.51	3.15 48.08	6.22	6.22	26% 0%	1.11	1.11	26% 0%	0.05 N/A
VA	1800	1801 T5 (240W) (base metal halide)	Varehous	2014	2054	179.05	31.82	91.46	91.46	34%	16.25	16.25	34%	0.01
VA	1800 1800	1806 Occupancy Sensor, High Bay T5	Varehous	2014	2054 2054	173.36 160.31	31.57 29.72	5.70	97.16	36%	0.25 1.85	16.50	34%	0.03
VA VA	1850	1805 High Performance Lighting R/R - 25 1850 Base CFL Exit Sign	% varenous	2014	2054	1.60	0.28	13.04	110.20 0.00	41% 0%	0.00	18.35 0.00	38% 0%	0.05 N/A
VA	1850	1851 LED Exit Sign	Varehous	2014	2054	0.50	0.09	1.10	1.10	69%	0.20	0.20	69%	0.05
VA	1900	1900 Base Outdoor High Pressure Sodiur		2014	2054	100.54	1.36	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	1900 1900	1901 Outdoor Lighting Controls (Photocel 1902 LED Outdoor Area Lighting	II/TVarehous Varehous	2014 2014	2054 2054	96.70 46.53	1.19 0.51	3.84 50.17	3.84 54.01	4% 54%	0.17 0.68	0.17 0.85	13% 63%	0.05
VA	1900	1903 Bi-Level LED Outdoor Lighting	Varehous	2014	2054	32.84	0.34	13.69	67.70	67%	0.17	1.02	75%	0.62
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/to		2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	2100 2100	2100 Base DX Packaged System, EER=1 2113 Ceiling/roof Insulation - DX	0.∜arehous Varehous	2014 2014	2054 2054	227.17	216.04 206.10	0.00 10.45	0.00 10.45	0% 5%	0.00 9.94	0.00 9.94	0% 5%	N/A 0.05
VA	2100	2107 Cool Roof - DX	Varehous	2014	2054	200.59	190.77	16.12	26.58	12%	15.33	25.28	12%	0.03
VA	2100	2108 Optimize Controls - DX	Varehouse	2014	2054	197.61	189.96	2.98	29.56	13%	0.81	26.09	12%	0.15
VA VA	2100 2100	2102 DX Packaged System, EER=13.4, 1 2112 Duct Testing/Sealing - DX	0 Narehous	2014 2014	2054 2054	152.16 143.11	146.73 138.12	45.45 9.05	75.01 84.06	33% 37%	43.22 8.61	69.31 77.92	32% 36%	0.48 3.07
VA	2100	2112 Duct Testing/Sealing - DX 2115 Window Film (Standard) - DX	Varehous	2014	2054	136.95	138.12	6.16	90.22	40%	5.86	83.78	39%	2.74
VA	2100	2106 Prog. Thermostat - DX	Varehouse	2014	2054	132.85	131.15	4.10	94.33	42%	1.12	84.89	39%	2.02
VA	2100	2114 Duct/Pipe Insulation - DX	Varehous	2014	2054	132.58	130.90	0.26	94.59	42%	0.25	85.14	39%	5.62
VA VA	2100 2200	2110 Dual Enthalpy Economizer Replaces 2200 Base Heat Pump (13 SEER, 7.7 HS		2014 2014	2054 2054	132.51 122.99	130.88 116.97	0.07	94.66	42% 0%	0.02	85.16 0.00	39% 0%	3.71 N/A
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2		2014	2054	107.78	102.50	15.21	15.21	12%	14.47	14.47	12%	0.05
VA	2300	2300 Base PTAC, EER=8.3, 1 ton	Varehous	2014	2054	5.83	5.54	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87. 3001 Fan Motor, 5hp, 1800rpm, 89.5%	5%Varehous Varehous	2014 2014	2054 2054	128.07 125.86	39.55 38.87	0.00 2.21	0.00 2.21	0% 2%	0.00	0.00	0% 2%	N/A 0.05
VA	3000	3002 Variable Speed Drive Control, 5 HP	Varehous	2014	2054	88.87	35.95	36.99	39.20	31%	2.92	3.60	9%	0.04
VA	3000	3003 Demand Controlled Ventilation	Varehous	2014	2054	87.73	35.31	1.14	40.34	31%	0.65	4.25	11%	1.85
VA VA	3100 3200	3100 Base Fan Motor, 15hp, 1800rpm, 91 3200 Base Fan Motor, 40hp, 1800rpm, 93		2014 2014	2054 2054	0.00 42.48	0.00 13.12	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
VA	3200	3202 Variable Speed Drive Control, 40 HF		2014	2054	29.99	12.13	12.48	12.48	29%	0.98	0.98	8%	0.02
VA	3200	3203 Air Handler Optimization, 40 HP	Varehouse	2014	2054	27.06	11.90	2.94	15.42	36%	0.23	1.22	9%	0.06
VA VA	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Varehous Varehous	2014 2014	2054 2054	26.71 306.50	11.71 58.07	0.35	15.77 0.00	37% 0%	0.20	1.41 0.00	11% 0%	2.02 N/A
VA	4000	4018 Oversized Air Cooled Condenser	Varehous	2014	2054	293.60	55.62	12.90	12.90	4%	2.44	2.44	4%	0.03
VA	4000	4010 Refrigeration Commissioning	Varehous	2014	2054	292.09	55.34	1.51	14.41	5%	0.29	2.73	5%	0.06
VA VA	4000 4000	4006 Electronically commutated evaporat 4005 Evaporator fan controller for MT wal		2014 2014	2054 2054	274.39 274.34	51.98 51.98	17.70 0.05	32.11 32.16	10% 10%	3.35 0.01	6.08 6.09	10% 10%	0.11 0.19
VA	4000	4002 Strip curtains for walk-ins (built-up)	Varehous	2014	2054	273.17	51.76	1.17	33.33	11%	0.01	6.31	11%	0.19
VA	4000	4001 High-efficiency fan motors	Varehouse	2014	2054	264.80	50.17	8.37	41.70	14%	1.59	7.90	14%	0.45
VA VA	4100 4100	4100 Base Self-Contained Refrigeration	Varehous	2014	2054 2054	81.91	15.52 15.49	0.00	0.00	0% 0%	0.00	0.00	0%	N/A
VA VA	5000	4101 Strip curtains for walk-ins (self-conta 5000 Base Desktop PC	Varehous	2014	2054	81.78 19.15	3.19	0.13	0.13	0%	0.03	0.03	0% 0%	0.15 N/A
VA	5000	5001 PC Network Power Management En			2054	10.66	2.46	8.49	8.49	44%	0.73	0.73	23%	0.01
VA	5000	5002 Energy Star or Better PC	Varehous	2014	2054	7.16	1.88	3.49	11.98	63%	0.58	1.31	41%	0.03
VA VA	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Varehous Varehous	2014	2054 2054	1.36 1.10	0.23 0.18	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01
VA	5100	5101 Laptop Network Power Managemen		2014	2054	1.08	0.18	0.02	0.28	21%	0.00	0.04	21%	1.24
VA	5200	5200 Base Monitor, CRT	Varehouse	2014	2054	3.95	0.66	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enablir		2014	2054 2054	1.73 1.18	0.29	2.22 0.55	2.22	56% 70%	0.37	0.37	56% 63%	0.00
VA	5200	5202 Monitor Power Management Enablir 5203 Plug-load controls - Commercial Sm		2014	2054	1.18	0.24	0.09	2.77	70%	0.05	0.42	66%	0.02
VA	5300	5300 Base Monitor, LCD	Varehouse	2014	2054	3.15	0.53	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	5300	5301 Energy Star or Better Monitor - LCD		2014	2054	2.51	0.42	0.64	0.64	20%	0.11	0.11	20%	0.01
VA VA	5300 5300	5302 Monitor Power Management Enablir 5303 Plug-load controls - Commercial Sm		2014 2014	2054 2054	2.48	0.42	0.03	0.67 0.85	21% 27%	0.00	0.11 0.12	21% 22%	0.08
VA	5400	5400 Base Copier	Varehous		2054	4.86	0.81	0.00	0.00	0%	0.00	0.00	0%	N/A
	5400	5401 Energy Star or Better Copier	Varehouse	2014	2054	4.28	0.71	0.58	0.58	12%	0.10	0.10	12%	0.00
VA VA VA	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction		2014	2054 2054	4.13	0.70 0.18	0.15 0.00	0.73	15% 0%	0.01	0.11	14%	0.09 N/A

Base Avoided Costs ADDITIVE MEASURE LEVEL RESULTS

	ge	DDITIVE SUPPLY ANALYSIS Existing	,		2020 eVleasure				Total Energy	Percent		Total Capacity	Percent	Margin
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost
Sgmt VA	Number	Numb Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings 32%	Savings		Savings 29%	\$/kWF
A	5500 5600	5501 Multifunction Power Management 5600 Base Printer	Enavarenous Varehous	2014	2054 2054	0.74 4.88	0.13	0.08	0.35	32% 0%	0.01	0.05	29% 0%	0.24 N/A
Α.	5600	5602 ENERGY STAR Printer	Varehous	2014	2054	3.18	0.53	1.70	1.70	35%	0.28	0.28	35%	0.00
	5600	5601 Printer Power Management Enabli		2014	2054	2.87	0.50	0.31	2.01	41%	0.03	0.31	38%	0.05
١.	5700	5700 Base Data Center/Server Room	Varehous	2014	2054	57.03	9.51	0.00	0.00	0%	0.00	0.00	0%	N/A
4	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Varehous Varehous	2014	2054 2054	51.32 44.79	8.56 7.47	5.70 6.53	5.70 12.23	10% 21%	0.95 1.09	0.95 2.04	10% 21%	0.00
À	5700	5703 Data Center State of the Art practic		2014	2054	42.29	7.05	2.51	14.74	26%	0.42	2.46	26%	0.00
A	6000	6000 Base Water Heating	Varehous	2014	2054	21.67	3.40	0.00	0.00	0%	0.00	0.00	0%	N/A
١.	6000	6006 Heat Recovery Unit	Varehous	2014	2054	20.26	3.18	1.41	1.41	7%	0.22	0.22	7%	0.25
4	6000 6000	6007 Heat Trap 6002 High Efficiency Water Heater (elec	Varehousi	2014 2014	2054 2054	19.21 18.83	3.01 2.95	1.05 0.38	2.46 2.84	11% 13%	0.16	0.39	11% 13%	0.45 0.93
ì	6000	6004 Tankless Water Heater	Varehous	2014	2054	17.42	2.73	1.41	4.25	20%	0.22	0.43	20%	1.42
4	6000	6008 Solar Water Heater	Varehouse	2014	2054	11.44	1.80	5.97	10.23	47%	0.94	1.60	47%	1.66
4	6000	6003 Hot Water Pipe Insulation	Varehous	2014	2054	11.40	1.79	0.05	10.27	47%	0.01	1.61	47%	2.54
A A	6000 7000	6001 Demand controlled circulating syst 7000 Base Refrigerated Vending Machin		2014 2014	2054 2054	11.18 14.96	1.75 2.82	0.22	10.50 0.00	48% 0%	0.03	1.65 0.00	48% 0%	2.84 N/A
ì	7000	7000 Base Reingerated Verlding Machin 7001 Vending Misers (Refrigerated units		2014	2054	13.29	2.66	1.67	1.67	11%	0.00	0.16	6%	0.02
	7000	7002 Vending Misers (Refrigerated glass		2014	2054	12.40	2.57	0.89	2.57	17%	0.09	0.25	9%	0.04
4	7100	7100 Base Non-Refrigerated Vending M	achiVarehous	2014	2054	0.62	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A
١.	7100	7101 Vending Misers (Non-Refrigerated)		2014	2054	0.43	0.10	0.20	0.20	32%	0.02	0.02	16%	0.36
	7200 7300	7200 Base Oven 7300 Base Fryer	Varehous Varehous	2014	2054 2054	4.94 10.26	0.81 1.69	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
`	7400	7400 Base Steamer	Varehous	2014	2054	4.31	0.71	0.00	0.00	0%	0.00	0.00	0%	N/A
A	8000	8000 Base Heating, Heat Pump (7.7 HS		2014	2054	2.14	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
١.	8000	8001 Heat Pump Upgrade (15 SEER, 8.		2014	2054	2.02	0.00	0.12	0.12	6%	0.00	0.00	0%	0.03
A A	8100 9500	8100 Base Heating, Other Electric	Varehous	2014	2054	16.88	0.00 65.97	0.00	0.00	0%	0.00	0.00	0% 0%	N/A
١	9500	9500 Base Miscellaneous 9501 Xmisc	Varehous Varehous	2014	2054 2054	349.99 349.99	65.97	0.00	0.00	0% 0%	0.00	0.00	0%	N/A N/A
	1030	1030 Base Fluorescent Fixture, 4L4'T8,		2020	2054	286.28	38.69	0.00	0.00	0%	0.00	0.00	0%	N/A
١.	1030	1036 Lighting Control Tuneup (base 4L4	TR) School	2020	2054	283.96	38.53	2.33	2.33	1%	0.16	0.16	0%	0.02
١	1030	1031 ROB 4L4' High Performance T8 (8		2020	2054	254.79	34.59	29.17	31.50	11%	3.94	4.10	11%	0.02
۱ ۱	1030 1030	1038 High Performance Lighting R/R - 2 1032 ROB 4L4' Low Watt High Performance	15% School ance School	2020 2020	2054 2054	235.71 205.72	32.52 28.47	19.08 29.99	50.57 80.56	18% 28%	2.07 4.05	6.17 10.22	16% 26%	0.03
`	1030	1034 ROB 4L4' LED Tube, 2020	School	2020	2054	172.57	23.99	33.15	113.71	40%	4.48	14.70	38%	0.05
	1030	1037 Occupancy Sensor, 4L4' Fluoresce	ent F School	2020	2054	162.46	23.65	10.12	123.83	43%	0.34	15.04	39%	0.18
	1030	1035 LED Troffer (base 4L4'T8), 2020	School	2020	2054	148.59	21.77	13.87	137.70	48%	1.87	16.92	44%	0.31
١.	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1131 ROB 2L4' High Performance T8 (8		2020 2020	2054 2054	17.97 16.14	2.43 2.18	0.00 1.84	0.00 1.84	0% 10%	0.00	0.00	0% 10%	N/A 0.03
4	1130	1136 Lighting Control Tuneup (base 2L4		2020	2054	15.14	2.10	0.15	1.99	11%	0.25	0.25	11%	0.03
į.	1130	1138 High Performance Lighting R/R - 2		2020	2054	14.79	2.04	1.20	3.19	18%	0.13	0.39	16%	0.04
Ą	1130	1132 ROB 2L4' Low Watt High Performa		2020	2054	12.91	1.79	1.88	5.07	28%	0.25	0.64	26%	0.07
4	1130 1130	1134 ROB 2L4' LED Tube, 2020	School	2020	2054	12.28	1.70	0.62	5.69	32%	0.08	0.73	30%	0.28
١	1130	1135 LED Troffer (base 2L4'T8), 2020 1137 Occupancy Sensor, 2L4' Fluoresce	School ent F School	2020 2020	2054 2054	11.23 10.58	1.56 1.54	1.05 0.66	6.74 7.40	37% 41%	0.14	0.87 0.89	36% 37%	0.36
	1200	1200 Base Other Fluorescent Fixture	School	2014	2054	1.39	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A
	1200	1203 Lighting Control Tuneup (base other		2014	2054	1.33	0.18	0.06	0.06	5%	0.00	0.00	2%	0.02
	1200	1201 ROB High Performance T8 (base of		2014	2054	1.21	0.17	0.11	0.18	13%	0.02	0.02	10%	0.10
A A	1200 1200	1202 ROB Low Watt High Performance 1204 Occupancy Sensor, 4L8' Fluoresce		2014 2014	2054 2054	1.06 0.89	0.15 0.14	0.15 0.17	0.33	24% 36%	0.02	0.04	22% 25%	0.21 0.18
À	1200	1205 High Performance Lighting R/R - 2		2014	2054	0.82	0.13	0.07	0.57	41%	0.01	0.05	29%	0.33
4	1330	1330 Base Incandescent Flood, 100W to	Sc School	2020	2054	1.04	0.14	0.00	0.00	0%	0.00	0.00	0%	N/A
A	1330	1332 LEDs (base incandescent flood) 20		2020	2054	0.21	0.03	0.84	0.84	80%	0.11	0.11	80%	0.01
۱ ۱	1430 1430	1430 Base Incandescent A-Line Lamp, 7 1432 LEDs (base incandescent A-line 7)		2020 2020	2054 2054	0.38	0.05	0.00	0.00	0% 78%	0.00	0.00	0% 78%	N/A 0.01
À	1530	1530 Base Incandescent A-Line Lamp,	,	2020	2054	0.08	0.01	0.00	0.29	0%	0.00	0.00	0%	N/A
Α.	1530	1532 LEDs (base incandescent A-line 53		2020	2054	0.08	0.01	0.20	0.20	71%	0.03	0.03	71%	0.01
Ą	1630	1630 Base CFL 18W to screw-in replace		2020	2054	20.83	2.82	0.00	0.00	0%	0.00	0.00	0%	N/A
١.	1630	1631 LED screw-in replacement (base C		2020	2054	15.06	2.04	5.77	5.77	28%	0.78	0.78	28%	0.07
4	1730 1730	1730 Base CFL 23W to screw-in replace 1731 LED screw-in replacement (base C		2020 2020	2054 2054	26.62 19.70	3.60 2.66	0.00 6.92	0.00 6.92	0% 26%	0.00	0.00	0% 26%	N/A 0.05
ì	1800	1800 BaseMetal Halide, 465W	School	2014	2054	41.12	5.56	0.00	0.00	0%	0.00	0.00	0%	N/A
	1800	1801 T5 (240W) (base metal halide)	School	2014	2054	27.22	3.68	13.90	13.90	34%	1.88	1.88	34%	0.02
4	1800	1805 High Performance Lighting R/R - 2		2014	2054	25.18	3.46	2.04	15.94	39%	0.22	2.10	38%	0.03
A A		1806 Occupancy Sensor, High Bay T5	School	2014	2054 2054	24.39	3.43 0.30	0.79	16.73 0.00	41% 0%	0.03	2.13	38%	0.05
A A	1800		School											
4 4	1850	1850 Base CFL Exit Sign	School School	2014									0% 55%	N/A 0.04
4 4 4			School	2014 2014 2014	2054 2054 2054	1.00 67.16	0.14 2.68	1.22	1.22	55% 0%	0.17	0.00 0.17 0.00	0% 55% 0%	0.04 N/A
4 4 4 4 4	1850 1850 1900 1900	1850 Base CFL Exit Sign 1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodii 1901 Outdoor Lighting Controls (Photoc	School um : School ell/T School	2014 2014 2014	2054 2054 2054	1.00 67.16 60.40	0.14 2.68 1.82	1.22 0.00 6.75	1.22 0.00 6.75	55% 0% 10%	0.17 0.00 0.86	0.17 0.00 0.86	55% 0% 32%	0.04 N/A 0.05
A A A	1850 1850 1900	1850 Base CFL Exit Sign 1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodio	School um : School	2014 2014	2054 2054	1.00 67.16	0.14 2.68	1.22 0.00	1.22 0.00	55% 0%	0.17 0.00	0.17 0.00	55% 0%	0.04 N/A

Base Avoided Costs ADDITIVE MEASURE LEVEL RESULTS

Vintag		DDITIVE SUPPLY ANALYSIS Existing			2020 Measure				Total Energy	Percent		Total Capacity	Percent	Margina Energy
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost
Sgmt	Number	Numb Measure	Туре	Year	Year	GWH	MW	Savings	GWH		Savings		Savings	\$/kWH
/A /A	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 to 2005 Chiller Tune Up/Diagnostics	School School	2014 2014	2054 2054	85.39 85.17	43.84 43.78	7.97 0.22	7.97 8.19	9% 9%	4.09 0.06	4.09 4.15	9% 9%	0.07
/A	2000	2013 High Efficiency Chiller Motors	School	2014	2054	85.09	43.74	0.09	8.27	9%	0.04	4.20	9%	0.03
/A	2000	2006 VSD for Chiller Pumps and Towers	School	2014	2054	84.94	43.70	0.15	8.42	9%	0.04	4.24	9%	0.08
/A	2000	2003 EMS - Chiller	School	2014	2054	80.35	43.04	4.59	13.01	14%	0.66	4.89	10%	0.13
/A	2000	2004 Cool Roof - Chiller	School	2014	2054	78.80	42.25	1.55	14.56	16%	0.79	5.69	12%	0.21
/A	2000	2002 Window Film (Standard) - Chiller	School	2014	2054	78.40	42.04	0.40	14.96	16%	0.20	5.89	12%	0.24
VA VA	2000 2000	2012 Duct Testing/Sealing - Chiller 2008 New Economizer - Chiller	School School	2014 2014	2054 2054	65.41 58.45	35.37 34.38	12.99 6.96	27.95 34.91	30% 37%	6.67 0.99	12.56 13.56	26% 28%	0.34
/A	2000	2011 Duct/Pipe Insulation - Chiller	School	2014	2054	58.10	34.20	0.35	35.26	38%	0.18	13.74	29%	5.57
/A	2100	2100 Base DX Packaged System, EER=10.:	School	2014	2054	223.92	114.97	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	2100	2113 Ceiling/roof Insulation - DX	School	2014	2054	223.78	114.90	0.14	0.14	0%	0.07	0.07	0%	0.03
VA.	2100	2102 DX Packaged System, EER=13.4, 101		2014	2054	172.31	88.47	51.47	51.61	23%	26.43	26.50	23%	0.06
VA VA	2100 2100	2110 Dual Enthalpy Economizer Replaces © 2105 DX Tune Up/ Advanced Diagnostics	School School	2014 2014	2054 2054	172.07 171.80	88.43 88.36	0.24	51.85 52.11	23% 23%	0.03	26.53 26.60	23% 23%	0.17 0.21
VA	2100	2115 Window Film (Standard) - DX	School	2014	2054	170.22	87.55	1.58	53.69	24%	0.81	27.41	24%	0.26
/A	2100	2108 Optimize Controls - DX	School	2014	2054	167.62	87.18	2.60	56.30	25%	0.37	27.79	24%	0.18
VΑ	2100	2112 Duct Testing/Sealing - DX	School	2014	2054	158.73	82.61	8.89	65.19	29%	4.56	32.35	28%	0.38
/A	2100	2106 Prog. Thermostat - DX	School	2014	2054	157.35	82.42	1.38	66.57	30%	0.20	32.55	28%	0.23
VA VA	2100 2100	2107 Cool Roof - DX 2111 Economizer Repair - DX	School School	2014 2014	2054 2054	154.57 151.53	80.99 78.79	2.78 3.04	69.35 72.39	31% 32%	1.43 2.20	33.97 36.18	30% 31%	0.43
VA VA	2100	2109 Economizer - DX	School	2014	2054	150.79	78.68	0.74	73.13	33%	0.11	36.28	32%	1.40
/A	2100	2114 Duct/Pipe Insulation - DX	School	2014	2054	148.99	77.76	1.80	74.93	33%	0.92	37.20	32%	5.22
/A	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF	School	2014	2054	176.18	90.46	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 H		2014	2054	154.39	79.27	21.79	21.79	12%	11.19	11.19	12%	0.05
/A /A	2300 2300	2300 Base PTAC, EER=8.3, 1 ton	School School	2014 2014	2054 2054	160.46 138.73	82.38 71.23	0.00 21.73	0.00 21.73	0% 14%	0.00 11.16	0.00 11.16	0% 14%	N/A 0.12
/A	3000	2301 HE PTAC, EER=9.6, 1 ton 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%		2014	2054	52.81	10.30	0.00	0.00	0%	0.00	0.00	0%	0.12 N/A
VA	3000	3002 Variable Speed Drive Control, 5 HP	School	2014	2054	39.02	9.61	13.79	13.79	26%	0.69	0.69	7%	0.04
/A	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	School	2014	2054	38.34	9.48	0.67	14.47	27%	0.13	0.82	8%	0.08
/A	3000	3003 Demand Controlled Ventilation	School	2014	2054	32.61	7.48	5.73	20.20	38%	2.00	2.82	27%	2.13
VA.	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0		2014	2054	141.36	27.58	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	3100 3100	3104 Electronically Commutated Motors (EC 3102 Variable Speed Drive Control, 15 HP	School	2014 2014	2054 2054	121.57 89.82	24.08 22.48	19.79 31.75	19.79 51.55	14% 36%	3.51 1.59	3.51 5.10	13% 18%	0.05
/A	3100	3103 Air Handler Optimization, 15 HP	School	2014	2054	81.08	22.46	8.74	60.28	43%	0.44	5.54	20%	0.08
/A	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	School	2014	2054	80.29	21.89	0.78	61.07	43%	0.15	5.69	21%	0.20
/A	3100	3105 Energy Recovery Ventilation (ERV)	School	2014	2054	76.08	20.43	4.21	65.28	46%	1.47	7.16	26%	0.71
/A	3100	3107 Demand Controlled Ventilation	School	2014	2054	64.71	16.46	11.38	76.65	54%	3.96	11.12	40%	2.88
/A /A	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0 3202 Variable Speed Drive Control, 40 HP	School School	2014	2054 2054	58.92 43.53	11.50 10.73	0.00 15.39	0.00 15.39	0% 26%	0.00	0.00	0% 7%	N/A 0.01
/A	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	School	2014	2054	43.44	10.73	0.09	15.48	26%	0.02	0.77	7%	0.01
/A	3200	3203 Air Handler Optimization, 40 HP	School	2014	2054	39.21	10.50	4.23	19.71	33%	0.21	1.00	9%	0.07
/A	3200	3204 Demand Controlled Ventilation	School	2014	2054	33.35	8.45	5.86	25.58	43%	2.04	3.04	26%	2.33
/A	4000	4000 Base Built-Up Refrigeration System	School	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	4100	4100 Base Self-Contained Refrigeration	School	2014	2054	66.40	9.18	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	4100 4100	4103 Night covers for display cases (self-co 4104 Freezer-Cooler Replacement Gaskets	School	2014	2054 2054	64.09 63.22	8.87 8.74	2.30 0.88	2.30 3.18	3% 5%	0.32	0.32	3% 5%	0.00
VA	4100	4109 Energy-Star Freezer, glass door	School	2014	2054	62.88	8.70	0.34	3.52	5%	0.12	0.49	5%	0.00
VA	4100	4106 Energy-Star Refrigerator, solid door	School	2014	2054	62.07	8.58	0.81	4.33	7%	0.11	0.60	7%	0.01
VA	4100	4107 Energy-Star Freezer, solid door	School	2014	2054	61.93	8.57	0.14	4.47	7%	0.02	0.62	7%	0.02
VA	4100	4108 Energy-Star Refrigerator, glass door	School	2014	2054	61.68	8.53	0.25	4.72	7%	0.03	0.65	7%	0.02
VA	4100	4110 Energy Star Ice Machines	School	2014	2054	60.41	8.36	1.27	5.99	9%	0.18	0.83	9%	0.03
/A /A	4100 4100	4112 Reach-in unit occupancy sensors 4105 Bi-level LED Case Lighting (self-contain	School	2014	2054 2054	60.40 60.34	8.35 8.35	0.01	6.00	9% 9%	0.00	0.83	9% 9%	0.29
VA	4100	4101 Strip curtains for walk-ins (self-contain		2014	2054	60.29	8.34	0.05	6.11	9%	0.01	0.84	9%	1.05
/A	5000	5000 Base Desktop PC	School	2014	2054	10.42	0.90	0.00	0.00	0%	0.00	0.00	0%	N/A
VΑ	5000	5001 PC Network Power Management Enab	School	2014	2054	5.73	0.69	4.69	4.69	45%	0.21	0.21	23%	0.01
VA	5000	5002 Energy Star or Better PC	School	2014	2054	4.06	0.55	1.66	6.36	61%	0.14	0.35	39%	0.03
/A	5100	5100 Base Laptop PC	School	2014	2054	1.16	0.10	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management E	School School	2014 2014	2054 2054	0.94 0.92	0.08	0.22	0.22	19% 21%	0.02	0.02	19% 21%	0.01 1.24
/A	5200	5200 Base Monitor, CRT	School	2014	2054	4.23	0.06	0.02	0.24	0%	0.00	0.02	0%	N/A
/A	5200	5201 Energy Star or Better Monitor - CRT	School	2014	2054	1.85	0.16	2.37	2.37	56%	0.20	0.20	56%	0.00
/A	5200	5202 Monitor Power Management Enabling	School	2014	2054	1.34	0.14	0.51	2.89	68%	0.02	0.23	62%	0.02
/A	5200	5203 Plug-load controls - Commercial Smar		2014	2054	1.23	0.13	0.11	2.99	71%	0.01	0.24	65%	0.22
Ά	5300	5300 Base Monitor, LCD	School	2014	2054	2.18	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	5300 5300	5301 Energy Star or Better Monitor - LCD	School	2014	2054 2054	1.80	0.15	0.39	0.39	18%	0.03	0.03	18%	0.01
/A /A	5300	5302 Monitor Power Management Enabling 5303 Plug-load controls - Commercial Smar	School School	2014	2054	1.75 1.62	0.15 0.15	0.04	0.43	20% 26%	0.00	0.04	19% 20%	0.08
'A	5400	5400 Base Copier	School	2014	2054	2.78	0.24	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	School School	2014 2014	2054 2054	2.78 2.62	0.24	0.00	0.00	0% 6%	0.00	0.00 0.01	0% 6%	N/A 0.00

DNV·GL ADDITIVE MEASURE LEVEL RESULTS **Base Avoided Costs**

Vinta		DDITIVE SUPPLY ANALYSIS Existing		Year	2020				Total			Total		Margina
	Base	Measure	Building	Measur Start	eMeasure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy
Sgmt	Number	Numb Measure	Type	Year	Year	GWH	MW	Savings			Saving		Savings	\$/kWH
/A	5500	5500 Base Multifunction	School	2014	2054	0.34	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	5500 5500	5502 ENERGY STAR Multi-Function Print 5501 Multifunction Power Management Er		2014 2014	2054 2054	0.26	0.02	0.09	0.09	25% 39%	0.01	0.01	25% 32%	0.01
Ā	5600	5600 Base Printer	School	2014	2054	2.91	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A
١	5600	5602 ENERGY STAR Printer	School	2014	2054	1.90	0.16	1.01	1.01	35%	0.09	0.09	35%	0.00
١	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	School School	2014 2014	2054 2054	1.55 67.83	0.15 5.83	0.35	1.36 0.00	47% 0%	0.02	0.10	41% 0%	0.06 N/A
`	5700	5701 Data Center Improved Operations	School	2014	2054	61.05	5.24	6.78	6.78	10%	0.58	0.58	10%	0.00
١.	5700	5702 Data Center Best Practices	School	2014	2054	53.28	4.58	7.77	14.55	21%	0.67	1.25	21%	0.00
	5700	5703 Data Center State of the Art practice		2014	2054	50.30	4.32	2.98	17.53	26%	0.26	1.51	26%	0.00
١	6000 6000	6000 Base Water Heating 6007 Heat Trap	School School	2014 2014	2054 2054	23.82 22.58	1.85 1.76	0.00 1.23	0.00 1.23	0% 5%	0.00	0.00	0% 5%	N/A 0.04
	6000	6002 High Efficiency Water Heater (electri		2014	2054	22.14	1.72	0.44	1.67	7%	0.03	0.13	7%	0.09
	6000	6006 Heat Recovery Unit	School	2014	2054	19.99	1.55	2.16	3.83	16%	0.17	0.30	16%	0.09
	6000 6000	6001 Demand controlled circulating syster 6004 Tankless Water Heater	ns School School	2014 2014	2054 2054	19.24 17.79	1.50 1.38	0.75 1.44	4.58 6.02	19% 25%	0.06	0.36	19% 25%	0.12 0.16
	6000	6008 Solar Water Heater	School	2014	2054	16.55	1.29	1.25	7.27	31%	0.10	0.47	31%	0.18
	6000	6003 Hot Water Pipe Insulation	School	2014	2054	16.38	1.27	0.17	7.43	31%	0.01	0.58	31%	0.20
	7000	7000 Base Refrigerated Vending Machines		2014	2054	6.12	0.53	0.00	0.00	0%	0.00	0.00	0%	N/A
	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-f	School rc School	2014 2014	2054 2054	5.19 4.69	0.49	0.93	0.93 1.43	15% 23%	0.04	0.04	8% 12%	0.03
	7100	7100 Base Non-Refrigerated Vending Mac		2014	2054	0.09	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A
	7100	7101 Vending Misers (Non-Refrigerated)	School	2014	2054	0.05	0.01	0.04	0.04	43%	0.00	0.00	22%	0.43
	7200	7200 Base Oven	School	2014	2054	6.68	0.49	0.00	0.00	0%	0.00	0.00	0%	N/A
	7200 7300	7201 Convection Oven 7300 Base Fryer	School School	2014	2054	5.15 1.19	0.38	1.54 0.00	1.54 0.00	23% 0%	0.11	0.11	23% 0%	0.13 N/A
	7400	7400 Base Steamer	School	2014	2054	0.32	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A
	7400	7401 Efficient Steamer	School	2014	2054	0.12	0.01	0.21	0.21	63%	0.02	0.02	63%	0.05
	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF		2014	2054	4.30 4.06	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
	8100	8001 Heat Pump Upgrade (15 SEER, 8.2 8100 Base Heating, Other Electric	School	2014 2014	2054 2054	0.00	0.00	0.24	0.24	6% 0%	0.00	0.00	0% 0%	0.08 N/A
	9500	9500 Base Miscellaneous	School	2014	2054	93.87	8.18	0.00	0.00	0%	0.00	0.00	0%	N/A
	9500	9501 Xmisc	School	2014	2054	93.87	8.18	0.00	0.00	0%	0.00	0.00	0%	N/A
	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1E		2020 2020	2054 2054	152.78 152.55	23.25 23.23	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02
	1030	1036 Lighting Control Tuneup (base 4L4'T 1038 High Performance Lighting R/R - 25°		2020	2054	140.86	21.84	11.70	11.92	8%	1.39	1.41	6%	0.02
	1030	1031 ROB 4L4' High Performance T8 (86		2020	2054	126.21	19.61	14.65	26.57	17%	2.23	3.64	16%	0.03
	1030	1032 ROB 4L4' Low Watt High Performan		2020	2054	110.15	17.17	16.06	42.63	28%	2.44	6.08	26%	0.07
	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent 1034 ROB 4L4' LED Tube, 2020	F Health Health	2020 2020	2054 2054	101.99 85.56	16.88 14.38	8.16 16.43	50.79 67.22	33% 44%	0.29 2.50	6.37 8.87	27% 38%	0.12
	1030	1034 ROB 4L4 ELD Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Health	2020	2054	78.25	13.27	7.30	74.52	49%	1.11	9.98	43%	0.43
	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1E		2020	2054	18.41	2.80	0.00	0.00	0%	0.00	0.00	0%	N/A
	1130	1131 ROB 2L4' High Performance T8 (86		2020	2054	16.50	2.51	1.92	1.92	10%	0.29	0.29	10%	0.04
	1130 1130	1136 Lighting Control Tuneup (base 2L4'T 1138 High Performance Lighting R/R - 25°	8) Health 6 Health	2020 2020	2054 2054	16.48 15.21	2.51 2.36	0.02 1.26	1.94 3.20	11% 17%	0.00	0.29	10% 16%	0.05
	1130	1132 ROB 2L4' Low Watt High Performan		2020	2054	13.28	2.06	1.94	5.14	28%	0.13	0.74	26%	0.09
	1130	1134 ROB 2L4' LED Tube, 2020	Health	2020	2054	12.63	1.97	0.64	5.78	31%	0.10	0.84	30%	0.33
	1130	1135 LED Troffer (base 2L4'T8), 2020	Health	2020	2054	11.56	1.80	1.08	6.86	37%	0.16	1.00	36%	0.41
	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent 1200 Base Other Fluorescent Fixture	Health	2020 2014	2054 2054	10.70 4.95	1.77 0.75	0.86	7.71 0.00	42% 0%	0.03	1.03 0.00	37% 0%	0.25 N/A
	1200	1203 Lighting Control Tuneup (base other		2014	2054	4.92	0.75	0.03	0.03	1%	0.00	0.00	0%	0.01
	1200	1205 High Performance Lighting R/R - 259		2014	2054	4.54	0.71	0.38	0.40	8%	0.04	0.05	6%	0.08
	1200	1201 ROB High Performance T8 (base oth		2014	2054	4.07	0.63	0.47	0.88	18%	0.07	0.12	16%	0.14
	1200 1200	1204 Occupancy Sensor, 4L8' Fluorescen 1202 ROB Low Watt High Performance To		2014	2054 2054	3.28 2.86	0.61	0.79	1.67 2.08	34% 42%	0.03	0.15 0.21	19% 28%	0.15 0.35
	1330	1330 Base Incandescent Flood, 100W to S		2020	2054	8.93	1.36	0.00	0.00	0%	0.00	0.00	0%	N/A
	1330	1332 LEDs (base incandescent flood) 202		2020	2054	1.60	0.24	7.33	7.33	82%	1.12	1.12	82%	0.01
	1430 1430	1430 Base Incandescent A-Line Lamp, 72		2020 2020	2054	3.22	0.49	0.00 2.59	0.00 2.59	0% 81%	0.00	0.00	0% 81%	N/A
	1530	1432 LEDs (base incandescent A-line 72V 1530 Base Incandescent A-Line Lamp, 53		2020	2054 2054	0.63 2.37	0.10	0.00	0.00	0%	0.00	0.00	0%	0.01 N/A
	1530	1532 LEDs (base incandescent A-line 53V		2020	2054	0.63	0.10	1.74	1.74	73%	0.26	0.26	73%	0.01
	1630	1630 Base CFL 18W to screw-in replacem		2020	2054	3.00	0.46	0.00	0.00	0%	0.00	0.00	0%	N/A
	1630	1631 LED screw-in replacement (base CF		2020 2020	2054	2.17 3.83	0.33	0.83	0.83	28%	0.13	0.13	28%	0.09 N/A
	1730 1730	1730 Base CFL 23W to screw-in replacem 1731 LED screw-in replacement (base CF		2020	2054 2054	2.83	0.58	1.00	0.00 1.00	0% 26%	0.00	0.00	0% 26%	0.07
	1800	1800 BaseMetal Halide, 465W	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
	1850	1850 Base CFL Exit Sign	Health	2014	2054	4.72	0.72	0.00	0.00	0%	0.00	0.00	0%	N/A
	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium	Health : Health	2014 2014	2054 2054	4.17 12.58	0.63	0.55	0.55	12% 0%	0.08	0.08	12% 0%	0.03 N/A
	1900	1900 Base Outdoor High Pressure Sodium 1901 Outdoor Lighting Controls (Photocell		2014	2054	12.58	0.12	1.00	1.00	0% 8%	0.00	0.00	27%	0.07
	1900	1902 LED Outdoor Area Lighting	Health	2014	2054	5.57	0.03	6.01	7.01	56%	0.06	0.09	74%	0.14
	1900	1903 Bi-Level LED Outdoor Lighting	Health	2014	2054	3.93	0.02	1.64	8.65	69%	0.01	0.10	86%	0.92

Vinta	ge Base	Existing Measure	l Building	Measure Start	Measure End	Total	Total	GWH	Total Energy Savings	Percent GWH	MW	Total Capacity Savings	Percent MW	Marginal Energy Cost
Sgmt	Number	Numb Measure	Type	Year	Year	GWH	MW	Savings	GWH		Savings	s MW	Savings	\$/kWH
/A /A	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton,	Health	2014	2054	66.67	36.64	0.00	0.00	0%	0.00	0.00	0%	N/A
A	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 to 2005 Chiller Tune Up/Diagnostics	Health Health	2014 2014	2054 2054	60.98 60.88	33.51 33.49	5.69 0.10	5.69 5.79	9% 9%	3.13 0.03	3.13 3.15	9% 9%	0.03
Â	2000	2006 VSD for Chiller Pumps and Towers	Health	2014	2054	60.75	33.45	0.14	5.93	9%	0.03	3.19	9%	0.02
Α	2000	2013 High Efficiency Chiller Motors	Health	2014	2054	60.55	33.34	0.20	6.12	9%	0.11	3.30	9%	0.05
Ά	2000	2003 EMS - Chiller	Health	2014	2054	54.79	32.60	5.75	11.88	18%	0.74	4.04	11%	0.05
A	2000	2012 Duct Testing/Sealing - Chiller	Health	2014	2054 2054	44.38 39.35	26.88	10.41	22.29	33%	5.72	9.76	27%	0.18
A	2000	2008 New Economizer - Chiller 2002 Window Film (Standard) - Chiller	Health Health	2014	2054	39.35	26.24	5.03 0.06	27.32 27.38	41% 41%	0.65	10.41 10.44	28% 28%	0.14 0.29
A	2000	2004 Cool Roof - Chiller	Health	2014	2054	39.18	26.14	0.11	27.49	41%	0.06	10.50	29%	0.23
Α	2000	2011 Duct/Pipe Insulation - Chiller	Health	2014	2054	38.74	25.90	0.44	27.93	42%	0.24	10.74	29%	2.99
Α	2100	2100 Base DX Packaged System, EER=10.:	Health	2014	2054	223.12	122.63	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	2100	2102 DX Packaged System, EER=13.4, 101	Health	2014	2054	171.80	94.42	51.32	51.32	23%	28.20	28.20	23%	0.03
'A 'A	2100 2100	2105 DX Tune Up/ Advanced Diagnostics 2108 Optimize Controls - DX	Health Health	2014 2014	2054 2054	171.64 168.50	94.38 93.98	0.16 3.14	51.48 54.62	23% 24%	0.04	28.25 28.65	23% 23%	0.09
/A	2100	2106 Prog. Thermostat - DX	Health	2014	2054	165.02	93.53	3.48	58.10	26%	0.45	29.10	24%	0.09
Ά	2100	2112 Duct Testing/Sealing - DX	Health	2014	2054	154.98	88.01	10.03	68.14	31%	5.51	34.61	28%	0.19
Α	2100	2115 Window Film (Standard) - DX	Health	2014	2054	154.15	87.56	0.83	68.97	31%	0.46	35.07	29%	0.25
Α	2100	2107 Cool Roof - DX	Health	2014	2054	153.66	87.29	0.49	69.46	31%	0.27	35.34	29%	0.65
A	2100 2100	2114 Duct/Pipe Insulation - DX	Health Health	2014	2054 2054	151.97 151.97	86.36 86.36	1.69	71.15 71.15	32% 32%	0.93	36.27 36.27	30% 30%	2.55
A	2100	2111 Economizer Repair - DX 2109 Economizer - DX	Health	2014	2054	151.97	86.36	0.00	71.15	32%	0.00	36.27	30%	#######
Ά	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF	Health	2014	2054	142.15	78.13	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 H	Health	2014	2054	124.57	68.46	17.58	17.58	12%	9.66	9.66	12%	0.02
/Α	2300	2300 Base PTAC, EER=8.3, 1 ton	Health	2014	2054	31.81	17.48	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.59 3002 Variable Speed Drive Control, 5 HP	Health Health	2014 2014	2054 2054	63.96 45.33	12.98 12.08	0.00 18.63	0.00 18.63	0% 29%	0.00	0.00	0% 7%	N/A 0.01
'A	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Health	2014	2054	45.55	11.92	0.78	19.41	30%	0.90	1.06	8%	0.01
/A	3000	3003 Demand Controlled Ventilation	Health	2014	2054	40.31	10.16	4.24	23.65	37%	1.77	2.83	22%	0.84
Α	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0	Health	2014	2054	222.31	45.13	0.00	0.00	0%	0.00	0.00	0%	N/A
A	3100	3102 Variable Speed Drive Control, 15 HP	Health	2014	2054	157.57	41.99	64.74	64.74	29%	3.14	3.14	7%	0.00
A	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Health	2014	2054	157.20	41.91	0.37	65.11	29%	0.07	3.22	7%	0.01
A	3100 3100	3104 Electronically Commutated Motors (EC 3105 Energy Recovery Ventilation (ERV)	Health Health	2014 2014	2054 2054	134.32 125.61	37.78 34.15	22.88 8.71	87.99 96.70	40% 43%	4.14 3.63	7.36 10.98	16% 24%	0.02
A	3100	3107 Demand Controlled Ventilation	Health	2014	2054	113.65	29.17	11.96	108.66	49%	4.98	15.96	35%	1.03
A	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0		2014	2054	236.21	47.95	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	3200	3204 Demand Controlled Ventilation	Health	2014	2054	213.72	38.59	22.49	22.49	10%	9.36	9.36	20%	0.58
Α	4000	4000 Base Built-Up Refrigeration System	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
'A 'A	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-co	Health Health	2014	2054 2054	43.75 43.03	6.34	0.00	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.00
A	4100	4104 Freezer-Cooler Replacement Gaskets	Health	2014	2054	42.35	6.14	0.73	1.40	3%	0.10	0.11	3%	0.00
Ά	4100	4108 Energy-Star Refrigerator, glass door	Health	2014	2054	42.01	6.09	0.34	1.74	4%	0.05	0.25	4%	0.02
Ά	4100	4106 Energy-Star Refrigerator, solid door	Health	2014	2054	41.52	6.02	0.49	2.23	5%	0.07	0.32	5%	0.02
Α	4100	4110 Energy Star Ice Machines	Health	2014	2054	41.07	5.95	0.45	2.68	6%	0.07	0.39	6%	0.05
A A	4100 4100	4112 Reach-in unit occupancy sensors 4105 Bi-level LED Case Lighting (self-contain	Health Health	2014 2014	2054 2054	41.06 41.01	5.95 5.94	0.01	2.70 2.74	6% 6%	0.00	0.39 0.40	6% 6%	0.28
Α	5000	5000 Base Desktop PC	Health	2014	2054	9.92	1.41	0.00	0.00	0%	0.00	0.40	0%	0.32 N/A
/A	5000	5001 PC Network Power Management Enab	Health	2014	2054	5.32	1.08	4.60	4.60	46%	0.33	0.33	23%	0.02
Ά	5000	5002 Energy Star or Better PC	Health	2014	2054	3.64	0.84	1.69	6.29	63%	0.24	0.57	40%	0.04
/A	5100	5100 Base Laptop PC	Health	2014	2054	0.51	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	5100 5100	5102 Energy Star or Better Laptop	Health	2014	2054 2054	0.42	0.06	0.10	0.10	19%	0.01	0.01	19%	0.01
/A /A	5100	5101 Laptop Network Power Management E 5200 Base Monitor, CRT	Health Health	2014	2054	0.41 2.73	0.06	0.01	0.11	21% 0%	0.00	0.02	21% 0%	1.77 N/A
Λ A	5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Health	2014	2054	1.23	0.35	1.50	1.50	55%	0.00	0.00	55%	0.00
/A	5200	5202 Monitor Power Management Enabling	Health	2014	2054	0.83	0.15	0.40	1.90	70%	0.03	0.24	62%	0.03
/A	5200	5203 Plug-load controls - Commercial Smar	Health	2014	2054	0.77	0.14	0.07	1.97	72%	0.01	0.25	65%	0.33
/A	5300	5300 Base Monitor, LCD	Health	2014	2054	1.75	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A
/A /A	5300	5301 Energy Star or Better Monitor - LCD	Health	2014	2054	1.41	0.20	0.34	0.34	20%	0.05	0.05	20%	0.01
'A	5300 5300	5302 Monitor Power Management Enabling 5303 Plug-load controls - Commercial Smar	Health Health	2014 2014	2054 2054	1.34 1.23	0.20	0.07	0.41 0.52	24% 30%	0.00	0.05	22% 23%	0.12
/A	5400	5400 Base Copier	Health	2014	2054	2.77	0.39	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	5400	5401 Energy Star or Better Copier	Health	2014	2054	2.30	0.33	0.47	0.47	17%	0.07	0.07	17%	0.00
Α	5400	5402 Copier Power Management Enabling	Health	2014	2054	2.15	0.32	0.15	0.61	22%	0.01	0.08	19%	0.14
Α	5500	5500 Base Multifunction	Health	2014	2054	0.45	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	5500	5502 ENERGY STAR Multi-Function Printer	Health	2014	2054	0.33	0.05	0.11	0.11	25%	0.02	0.02	25%	0.01
A A	5500 5600	5501 Multifunction Power Management Enal	Health Health	2014 2014	2054 2054	0.29 2.25	0.04	0.05	0.16	36% 0%	0.00	0.02	31% 0%	0.34 N/A
A A	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Health	2014	2054	1.46	0.32	0.00	0.00	0% 35%	0.00	0.00	0% 35%	0.00
Ά	5600	5601 Printer Power Management Enabling	Health	2014	2054	1.25	0.19	0.78	0.78	44%	0.02	0.13	40%	0.00
A	5700	5700 Base Data Center/Server Room	Health	2014	2054	39.44	5.61	0.00	0.00	0%	0.00	0.00	0%	N/A
			Health	2014	2054	35.50	5.04	3.94	3.94	10%	0.56	0.56	10%	0.00
/A	5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Health	2014	2054	30.98	4.40	4.52	8.46	21%	0.50	0.50	21%	0.00

/inta	ge Base	Existing Measure	l Building	Measure Start	Measure End	Total	Total	GWH	Total Energy Savings	Percent GWH	MW	Total Capacity Savings	Percent MW	Margina Energy Cost
	Number	Numb Measure	Туре	Year	Year	GWH	MW	Savings	GWH		Savings	s MW	Savings	\$/kWH
A A	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Health Health	2014 2014	2054 2054	29.25 16.04	4.16 2.07	1.74 0.00	10.20 0.00	26% 0%	0.25	1.45 0.00	26% 0%	0.00 N/A
ì	6000	6001 Demand controlled circulating systems	Health	2014	2054	15.44	1.99	0.60	0.60	4%	0.08	0.08	4%	0.04
4	6000	6007 Heat Trap	Health	2014	2054	14.64	1.89	0.80	1.40	9%	0.10	0.18	9%	0.04
4	6000	6002 High Efficiency Water Heater (electric)	Health	2014	2054	14.35	1.85	0.29	1.69	11%	0.04	0.22	11%	0.08
A	6000 6000	6006 Heat Recovery Unit 6004 Tankless Water Heater	Health Health	2014	2054 2054	6.89 6.37	0.89	7.46 0.52	9.15 9.67	57% 60%	0.96	1.18 1.25	57% 60%	0.08
A	6000	6008 Solar Water Heater	Health	2014	2054	5.48	0.71	0.32	10.56	66%	0.07	1.36	66%	0.20
Α	6000	6003 Hot Water Pipe Insulation	Health	2014	2054	5.43	0.70	0.05	10.61	66%	0.01	1.37	66%	0.35
Α	7000	7000 Base Refrigerated Vending Machines	Health	2014	2054	6.16	0.86	0.00	0.00	0%	0.00	0.00	0%	N/A
A	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-frc	Health Health	2014 2014	2054 2054	5.17 4.64	0.79 0.75	0.98 0.54	0.98 1.52	16% 25%	0.07	0.07 0.10	8% 12%	0.03
A	7100	7100 Base Non-Refrigerated Vending Machi	Health	2014	2054	0.12	0.75	0.00	0.00	0%	0.04	0.00	0%	0.05 N/A
Ά	7100	7101 Vending Misers (Non-Refrigerated)	Health	2014	2054	0.07	0.01	0.06	0.06	46%	0.00	0.00	22%	0.42
Α	7200	7200 Base Oven	Health	2014	2054	9.72	1.85	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	7300	7300 Base Fryer	Health	2014	2054	9.37	1.79	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	7300 7400	7301 Efficient Fryer 7400 Base Steamer	Health Health	2014	2054 2054	8.77 8.41	1.67 1.61	0.60	0.60	6% 0%	0.11	0.11	6% 0%	0.43 N/A
A	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Health	2014	2054	17.94	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
A	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 H		2014	2054	16.93	0.00	1.01	1.01	6%	0.00	0.00	0%	0.02
A	8100	8100 Base Heating, Other Electric	Health	2014	2054	25.25	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	9500	9500 Base Miscellaneous	Health	2014	2054	378.95	52.75	0.00	0.00	0%	0.00	0.00	0%	N/A
4	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB	Health Lodging	2014 2020	2054 2054	378.95 9.24	52.75 1.31	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
Ά	1030	1031 ROB 4L4' High Performance T8 (86 W		2020	2054	8.28	1.17	0.96	0.96	10%	0.14	0.14	10%	0.02
Ά	1030	1032 ROB 4L4' Low Watt High Performance	Lodging	2020	2054	7.23	1.02	1.05	2.01	22%	0.15	0.29	22%	0.05
A	1030	1036 Lighting Control Tuneup (base 4L4'T8)		2020	2054	7.19	1.02	0.03	2.05	22%	0.00	0.29	22%	0.05
A	1030 1030	1038 High Performance Lighting R/R - 25% 1034 ROB 4L4' LED Tube, 2020		2020 2020	2054 2054	6.64 5.57	0.96 0.81	0.55 1.07	2.60 3.67	28% 40%	0.06	0.35 0.50	27% 38%	0.07 0.35
A	1030	1037 Occupancy Sensor, 4L4' Fluorescent F	Lodging Lodging	2020	2054	5.41	0.80	0.16	3.83	41%	0.13	0.51	39%	0.33
4	1030	1035 LED Troffer (base 4L4'T8), 2020	Lodging	2020	2054	4.95	0.74	0.46	4.29	46%	0.07	0.57	44%	0.30
١.	1130	1130 Base Fluorescent Fixture, 2L4T8, 1EB		2020	2054	37.39	5.29	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	1130	1131 ROB 2L4' High Performance T8 (86 W		2020	2054	33.50	4.74	3.89	3.89	10%	0.55	0.55	10%	0.03
	1130 1130	1132 ROB 2L4' Low Watt High Performance 1136 Lighting Control Tuneup (base 2L4'T8)		2020 2020	2054 2054	29.24 29.10	4.14 4.13	4.26 0.13	8.15 8.28	22% 22%	0.60	1.15 1.16	22% 22%	0.06
	1130	1138 High Performance Lighting R/R - 25%		2020	2054	26.87	3.88	2.23	10.52	28%	0.25	1.41	27%	0.10
١	1130	1134 ROB 2L4' LED Tube, 2020	Lodging	2020	2054	25.57	3.70	1.30	11.82	32%	0.18	1.59	30%	0.29
4	1130	1135 LED Troffer (base 2L4'T8), 2020	Lodging	2020	2054	23.39	3.39	2.18	14.00	37%	0.31	1.90	36%	0.37
١	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent F 1200 Base Other Fluorescent Fixture	Lodging	2020	2054 2054	22.73 0.73	3.37 0.10	0.66	14.66 0.00	39% 0%	0.02	1.92	36% 0%	0.30 N/A
ì	1200	1203 Lighting Control Tuneup (base other fle		2014	2054	0.73	0.10	0.00	0.02	3%	0.00	0.00	1%	0.02
Ą	1200	1201 ROB High Performance T8 (base othe		2014	2054	0.63	0.09	0.07	0.09	13%	0.01	0.01	11%	0.10
4	1200	1202 ROB Low Watt High Performance T8 (2014	2054	0.55	80.0	80.0	0.17	24%	0.01	0.02	22%	0.21
Ą	1200	1205 High Performance Lighting R/R - 25%		2014	2054	0.51	0.07	0.04	0.22	30%	0.00	0.03	27%	0.23
A A	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent F 1330 Base Incandescent Flood, 100W to Sc		2014 2020	2054 2054	0.47 56.01	0.07 7.93	0.04	0.25	35% 0%	0.00	0.03	28% 0%	0.20 N/A
ì	1330	1332 LEDs (base incandescent flood) 2020		2020	2054	10.81	1.53	45.20	45.20	81%	6.40	6.40	81%	0.01
A	1430	1430 Base Incandescent A-Line Lamp, 72W	Lodging	2020	2054	20.16	2.85	0.00	0.00	0%	0.00	0.00	0%	N/A
A	1430	1432 LEDs (base incandescent A-line 72W)		2020	2054	4.23	0.60	15.94	15.94	79%	2.26	2.26	79%	0.01
A A	1530 1530	1530 Base Incandescent A-Line Lamp, 53W 1532 LEDs (base incandescent A-line 53W)		2020 2020	2054 2054	14.84 4.24	2.10	0.00 10.60	0.00 10.60	0% 71%	0.00 1.50	0.00 1.50	0% 71%	N/A 0.01
A	1630	1630 Base CFL 18W to screw-in replaceme		2020	2054	11.67	1.65	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	1630	1631 LED screw-in replacement (base CFL		2020	2054	8.44	1.19	3.23	3.23	28%	0.46	0.46	28%	0.09
A	1730	1730 Base CFL 23W to screw-in replaceme		2020	2054	14.91	2.11	0.00	0.00	0%	0.00	0.00	0%	N/A
A	1730 1800	1731 LED screw-in replacement (base CFL		2020	2054 2054	11.03 29.88	1.56 4.23	3.88	3.88	26% 0%	0.55	0.55	26% 0%	0.07 N/A
A	1800	1800 BaseMetal Halide, 465W 1801 T5 (240W) (base metal halide)	Lodging Lodging	2014	2054	19.78	2.80	10.10	10.10	34%	1.43	1.43	34%	0.02
A	1800	1805 High Performance Lighting R/R - 25%		2014	2054	18.26	2.63	1.52	11.62	39%	0.17	1.60	38%	0.05
A	1800	1806 Occupancy Sensor, High Bay T5	Lodging	2014	2054	17.63	2.61	0.63	12.25	41%	0.02	1.62	38%	0.05
A	1850	1850 Base CFL Exit Sign	Lodging	2014	2054	6.70	0.95	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	1850 1900	1851 LED Exit Sign	Lodging	2014 2014	2054	3.78 43.47	0.54	2.91	2.91	44%	0.41	0.41	44%	0.03
A A	1900	1900 Base Outdoor High Pressure Sodium : 1901 Outdoor Lighting Controls (Photocell/T		2014	2054 2054	39.90	0.37	0.00 3.56	0.00 3.56	0% 8%	0.00	0.00	0% 28%	N/A 0.05
A	1900	1902 LED Outdoor Area Lighting	Lodging	2014	2054	19.20	0.09	20.70	24.27	56%	0.18	0.28	75%	0.10
Α	1900	1903 Bi-Level LED Outdoor Lighting	Lodging	2014	2054	13.55	0.05	5.65	29.92	69%	0.04	0.33	87%	0.65
A	2000		Lodging	2014	2054	150.18	90.43	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	2000 2000	2002 Window Film (Standard) - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 500 to	Lodging	2014 2014	2054 2054	144.75 132.40	87.16 79.72	5.43 12.36	5.43 17.78	4% 12%	3.27 7.44	3.27 10.71	4% 12%	0.03
A A	2000	2005 Chiller Tune Up/Diagnostics	Lodging	2014	2054	129.34	78.84	3.05	20.84	14%	0.88	11.59	13%	0.05
A	2000	2013 High Efficiency Chiller Motors	Lodging	2014	2054	129.34	78.84	0.01	20.84	14%	0.00	11.59	13%	0.04
Α	2000	2006 VSD for Chiller Pumps and Towers	Lodging	2014	2054	128.83	78.69	0.51	21.35	14%	0.15	11.74	13%	0.06
/A	2000	2008 New Economizer - Chiller	Lodging	2014	2054	81.45	72.03	47.38	68.73	46%	6.66	18.40	20%	0.06

DNV·GL ADDITIVE MEASURE LEVEL RESULTS **Base Avoided Costs**

DSM	ASSYST A	ctric Existing Construction DDITIVE SUPPLY ANALYSIS		Year	2020									
Vinta	ige	Existing		Measur	eVleasure	,			Total Energy	Percent		Total Capacity	Percent	Marginal Energy
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost
Sgm [*] VA	2000	Numb Measure 2003 EMS - Chiller	Type Lodging	Year 2014	Year 2054	74.71	71.08	Savings 6.74	75.47	Savings 50%	Savings 0.95	19.35	Savings 21%	\$/kWH 0.13
VA	2000	2012 Duct Testing/Sealing - Chiller	Lodging	2014	2054	60.52	62.53	14.20	89.66	60%	8.55	27.90	31%	0.43
VA	2000	2004 Cool Roof - Chiller	Lodging	2014	2054	60.40	62.46	0.12	89.78	60%	0.07	27.97	31%	1.93
VA VA	2000 2100	2011 Duct/Pipe Insulation - Chiller 2100 Base DX Packaged System, EER=10.	Lodging	2014 2014	2054 2054	60.09 383.60	62.28 230.99	0.30	90.09	60% 0%	0.18	28.15 0.00	31% 0%	4.61 N/A
VA	2100	2115 Window Film (Standard) - DX	Lodging	2014	2054	363.95	219.16	19.65	19.65	5%	11.83	11.83	5%	0.03
VA	2100	2102 DX Packaged System, EER=13.4, 10 to		2014	2054	280.25	168.75	83.71	103.36	27%	50.41	62.24	27%	0.05
VA	2100	2108 Optimize Controls - DX	Lodging	2014	2054	275.11	168.03	5.13	108.49	28%	0.72	62.96	27%	0.08
VA VA	2100 2100	2105 DX Tune Up/ Advanced Diagnostics 2106 Prog. Thermostat - DX	Lodging Lodging	2014 2014	2054 2054	271.25 263.28	166.91 165.79	3.87 7.97	112.36 120.32	29% 31%	1.11 1.12	64.07 65.19	28% 28%	0.15 0.14
VA	2100	2112 Duct Testing/Sealing - DX	Lodging	2014	2054	247.27	156.16	16.01	136.33	36%	9.64	74.83	32%	0.31
VA	2100	2111 Economizer Repair - DX	Lodging	2014	2054	246.00	155.00	1.27	137.60	36%	1.15	75.98	33%	0.89
VA VA	2100 2100	2107 Cool Roof - DX	Lodging	2014	2054 2054	245.52	154.71	0.48 4.03	138.08 142.12	36% 37%	0.29	76.27	33% 33%	1.21
VA	2100	2109 Economizer - DX 2110 Dual Enthalpy Economizer Replaces D	Lodging	2014	2054	241.48	154.15 154.14	4.03 0.01	142.12	37% 37%	0.57	76.84 76.84	33%	1.05 1.77
VA	2100	2114 Duct/Pipe Insulation - DX	Lodging	2014	2054	238.85	152.57	2.62	144.75	38%	1.58	78.42	34%	2.97
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF		2014	2054	297.25	178.99	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 H		2014	2054	260.49	156.85	36.76	36.76	12%	22.14	22.14	12%	0.03
VA VA	2300	2300 Base PTAC, EER=8.3, 1 ton 2301 HE PTAC, EER=9.6, 1 ton	Lodging Lodging	2014	2054	62.42 53.96	37.58 32.49	0.00 8.45	0.00 8.45	0% 14%	0.00 5.09	0.00 5.09	0% 14%	N/A 0.08
VA	2300	2302 Occupancy Sensor (hotels)	Lodging	2014	2054	48.11	27.74	5.85	14.31	23%	4.75	9.84	26%	0.26
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%		2014	2054	250.99	53.08	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	Lodging	2014 2014	2054 2054	246.66 212.47	52.17 37.30	4.33 34.19	4.33 38.52	2% 15%	0.92 14.87	0.92 15.78	2% 30%	0.03 0.97
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0	Lodging	2014	2054	0.00	0.00	0.00	0.00	15%	0.00	0.00	0%	0.97 N/A
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0		2014	2054	43.39	9.18	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	3200	3203 Air Handler Optimization, 40 HP	Lodging	2014	2054	38.86	8.95	4.53	4.53	10%	0.23	0.23	3%	0.02
VA VA	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Lodging Lodging	2014 2014	2054 2054	33.47 0.00	6.61 0.00	5.39 0.00	9.92 0.00	23% 0%	2.34 0.00	2.57 0.00	28% 0%	1.06 N/A
VA	4100	4100 Base Self-Contained Refrigeration	Lodging	2014	2054	141.67	20.71	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	4100	4103 Night covers for display cases (self-co	Lodging	2014	2054	135.53	19.81	6.14	6.14	4%	0.90	0.90	4%	0.00
VA	4100	4104 Freezer-Cooler Replacement Gaskets		2014	2054	133.81	19.56	1.72	7.85	6%	0.25	1.15	6%	0.00
VA VA	4100 4100	4109 Energy-Star Freezer, glass door 4107 Energy-Star Freezer, solid door	Lodging Lodging	2014 2014	2054 2054	131.77 130.94	19.27 19.14	2.04 0.84	9.89 10.73	7% 8%	0.30 0.12	1.45 1.57	7% 8%	0.00
VA	4100	4106 Energy-Star Refrigerator, solid door	Lodging	2014	2054	130.36	19.06	0.57	11.30	8%	0.08	1.65	8%	0.01
VA	4100	4110 Energy Star Ice Machines	Lodging	2014	2054	129.30	18.90	1.06	12.37	9%	0.16	1.81	9%	0.02
VA	4100	4105 Bi-level LED Case Lighting (self-conta		2014	2054	129.26	18.90	0.04	12.40	9%	0.01	1.81	9%	0.33
VA VA	4100 5000	4101 Strip curtains for walk-ins (self-contain 5000 Base Desktop PC	Lodging	2014 2014	2054 2054	128.70 9.10	18.82 1.35	0.56	12.97 0.00	9% 0%	0.08	1.90 0.00	9% 0%	0.35 N/A
VA	5000	5002 Energy Star or Better PC	Lodging	2014	2054	7.19	1.07	1.91	1.91	21%	0.28	0.28	21%	0.01
VA	5000	5001 PC Network Power Management Enab		2014	2054	3.86	0.82	3.33	5.24	58%	0.25	0.53	39%	0.02
VA VA	5100 5100	5100 Base Laptop PC	Lodging	2014 2014	2054 2054	0.44	0.06	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01
VA	5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management E	Lodging	2014	2054	0.35	0.05	0.00	0.08	21%	0.00	0.01	21%	1.24
VA	5200	5200 Base Monitor, CRT	Lodging	2014	2054	4.29	0.64	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	5200	5201 Energy Star or Better Monitor - CRT	Lodging	2014	2054	1.88	0.28	2.41	2.41	56%	0.36	0.36	56%	0.00
VA VA	5200 5200	5202 Monitor Power Management Enabling 5203 Plug-load controls - Commercial Smar		2014 2014	2054 2054	1.43 1.31	0.25	0.45 0.11	2.86 2.97	67% 69%	0.03	0.39	61% 64%	0.02
VA	5300	5300 Base Monitor, LCD	Lodging	2014	2054	1.90	0.28	0.00	0.00	0%	0.02	0.00	0%	N/A
VA	5300	5301 Energy Star or Better Monitor - LCD	Lodging	2014	2054	1.71	0.25	0.19	0.19	10%	0.03	0.03	10%	0.01
VA	5300	5302 Monitor Power Management Enabling		2014	2054	1.51	0.24	0.19	0.38	20%	0.01	0.04	15%	0.08
VA VA	5300 5400	5303 Plug-load controls - Commercial Smar 5400 Base Copier	Lodging	2014	2054 2054	1.39 2.65	0.23	0.12	0.50	27% 0%	0.00	0.05	17% 0%	0.22 N/A
VA	5400	5401 Energy Star or Better Copier	Lodging	2014	2054	2.39	0.35	0.26	0.26	10%	0.04	0.04	10%	0.00
VA	5400	5402 Copier Power Management Enabling	Lodging	2014	2054	2.29	0.35	0.10	0.35	13%	0.01	0.05	12%	0.09
VA	5500	5500 Base Multifunction	Lodging	2014	2054	0.41	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	5500 5500	5502 ENERGY STAR Multi-Function Printer 5501 Multifunction Power Management Ena		2014 2014	2054 2054	0.31	0.05	0.10	0.10 0.16	25% 39%	0.02	0.02	25% 32%	0.01
VA	5600	5600 Base Printer	Lodging	2014	2054	1.15	0.17	0.00	0.00	0%	0.00	0.02	0%	N/A
VA	5600	5602 ENERGY STAR Printer	Lodging	2014	2054	0.75	0.11	0.40	0.40	35%	0.06	0.06	35%	0.00
VA	5600	5601 Printer Power Management Enabling	Lodging	2014	2054	0.61	0.10	0.14	0.54	47%	0.01	0.07	41%	0.06
VA VA	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Lodging Lodging	2014 2014	2054 2054	40.24 36.21	5.98 5.38	0.00 4.02	0.00 4.02	0% 10%	0.00	0.00	0% 10%	N/A 0.00
VA	5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Lodging	2014	2054	31.61	4.70	4.61	8.63	21%	0.68	1.28	21%	0.00
VA	5700	5703 Data Center State of the Art practices	Lodging	2014	2054	29.84	4.43	1.77	10.40	26%	0.26	1.55	26%	0.00
VA	6000	6000 Base Water Heating	Lodging	2014	2054	62.44	8.42	0.00	0.00	0%	0.00	0.00	0%	N/A
VA VA	6000 6000	6007 Heat Trap 6006 Heat Recovery Unit	Lodging Lodging	2014 2014	2054 2054	59.20 51.51	7.98 6.95	3.23 7.70	3.23 10.93	5% 18%	0.44 1.04	0.44 1.47	5% 18%	0.01
VA	6000	6001 Demand controlled circulating systems		2014	2054	49.58	6.69	1.93	12.86	21%	0.26	1.73	21%	0.02
VA	6000	6002 High Efficiency Water Heater (electric)	Lodging	2014	2054	48.58	6.55	0.99	13.85	22%	0.13	1.87	22%	0.03
VA	6000	6004 Tankless Water Heater	Lodging	2014	2054	44.94	6.06	3.64	17.50	28%	0.49	2.36	28%	0.05
VA	6000	6008 Solar Water Heater	Lodging	2014	2054	38.65	5.21	6.29	23.79	38%	0.85	3.21	38%	0.06

/inta	Base	Existing Measure	Building	Start	Measure End	Total	Total	GWH	Total Energy Savings	Percent GWH	MW	Total Capacity Savings	MW	Marginal Energy Cost
Sgmt /A	Number 6000	Numb Measure 6003 Hot Water Pipe Insulation	Type Lodging	Year 2014	Year 2054	37.99	MW 5.12	Savings 0.66	24.45	Savings 39%	Savings 0.09	s MW 3.30	Savings 39%	\$/kWH 0.07
/A	7000	7000 Base Refrigerated Vending Machines	Lodging	2014	2054	15.02	2.44	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	7000	7001 Vending Misers (Refrigerated units)	Lodging	2014	2054	12.67	2.26	2.35	2.35	16%	0.19	0.19	8%	0.02
Α	7000	7002 Vending Misers (Refrigerated glass-fro		2014	2054	11.40	2.15	1.27	3.62	24%	0.10	0.29	12%	0.05
A	7100 7100	7100 Base Non-Refrigerated Vending Machi 7101 Vending Misers (Non-Refrigerated)	Lodging	2014 2014	2054 2054	0.09	0.01	0.00	0.00	0% 45%	0.00	0.00	0% 22%	N/A 0.41
'A	7200	7200 Base Oven	Lodging	2014	2054	2.97	0.61	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	7300	7300 Base Fryer	Lodging	2014	2054	7.48	1.53	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	7400	7400 Base Steamer	Lodging	2014	2054	1.24	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A
A	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 H		2014	2054 2054	24.82	0.00	0.00 1.40	0.00 1.40	0% 6%	0.00	0.00	0% 0%	N/A 0.02
Ä	8100	8100 Base Heating, Other Electric	Lodging	2014	2054	19.91	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	9500	9500 Base Miscellaneous	Lodging	2014	2054	279.75	45.55	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	9500	9501 Xmisc	Lodging	2014	2054	279.75	45.55	0.00	0.00	0%	0.00	0.00	0%	N/A
'A 'A	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB		2020 2020	2054 2054	17.07 17.02	2.97 2.97	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.01
Ά	1030	1036 Lighting Control Tuneup (base 4L4'T8) 1038 High Performance Lighting R/R - 25%		2020	2054	15.76	2.79	1.26	1.31	8%	0.00	0.00	6%	0.01
A	1030	1031 ROB 4L4' High Performance T8 (86 W		2020	2054	14.16	2.51	1.61	2.91	17%	0.28	0.46	16%	0.02
A	1030	1032 ROB 4L4' Low Watt High Performance		2020	2054	12.35	2.19	1.80	4.72	28%	0.31	0.77	26%	0.05
A	1030	1037 Occupancy Sensor, 4L4' Fluorescent F		2020	2054	11.42	2.15	0.93	5.65	33%	0.04	0.82	28%	0.07
A A	1030 1030		ata Cente	2020	2054 2054	9.58 8.76	1.83	1.84	7.49 8.31	44% 49%	0.32	1.14	38% 43%	0.30
A	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB		2020	2054	0.29	0.05	0.02	0.00	0%	0.14	0.00	43% 0%	0.25 N/A
Α	1130	1136 Lighting Control Tuneup (base 2L4'T8)		2020	2054	0.29	0.05	0.00	0.00	0%	0.00	0.00	0%	0.02
Α	1130	1138 High Performance Lighting R/R - 25%		2020	2054	0.27	0.05	0.02	0.02	8%	0.00	0.00	6%	0.03
Α	1130	1131 ROB 2L4' High Performance T8 (86 W		2020	2054	0.24	0.04	0.03	0.05	17%	0.00	0.01	16%	0.03
A A	1130 1130	1132 ROB 2L4' Low Watt High Performance 1134 ROB 2L4' LED Tube, 2020	ata Cente	2020 2020	2054 2054	0.21	0.04	0.03	0.08	28% 31%	0.01	0.01 0.01	26% 30%	0.06
A	1130	1137 Occupancy Sensor, 2L4' Fluorescent F			2054	0.18	0.03	0.01	0.11	36%	0.00	0.02	31%	0.13
A	1130		ata Cente		2054	0.17	0.03	0.02	0.12	42%	0.00	0.02	37%	0.31
A	1200		ata Cente	2014	2054	0.63	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A
Α Α	1200 1200	1203 Lighting Control Tuneup (base other flucture 1205 High Performance Lighting R/R - 25%		2014	2054 2054	0.61 0.57	0.11	0.01	0.01 0.06	2% 9%	0.00	0.00	1% 7%	0.00
4 4	1200	1205 High Performance Lighting R/R - 25% 1201 ROB High Performance T8 (base othe		2014	2054	0.57	0.10	0.05	0.06	9% 19%	0.01	0.01	16%	0.03
A	1200	1204 Occupancy Sensor, 4L8' Fluorescent F			2054	0.44	0.09	0.07	0.18	29%	0.00	0.02	19%	0.13
Α	1200	1202 ROB Low Watt High Performance T8	ata Cente	2014	2054	0.39	0.08	0.06	0.24	38%	0.01	0.03	28%	0.23
A	1330	1330 Base Incandescent Flood, 100W to Sc		2020	2054	5.27	0.92	0.00	0.00	0%	0.00	0.00	0%	N/A
A	1330 1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W		2020	2054 2054	1.04	0.18	4.24 0.00	4.24 0.00	80% 0%	0.74	0.74	80% 0%	0.01 N/A
Ä	1430	1432 LEDs (base incandescent A-line 72W)			2054	0.40	0.07	1.49	1.49	79%	0.26	0.26	79%	0.01
Ά	1530	1530 Base Incandescent A-Line Lamp, 53W			2054	1.40	0.24	0.00	0.00	0%	0.00	0.00	0%	N/A
Ά	1530	1532 LEDs (base incandescent A-line 53W)			2054	0.41	0.07	0.99	0.99	71%	0.17	0.17	71%	0.01
'A 'A	1630 1630	1630 Base CFL 18W to screw-in replaceme		2020 2020	2054 2054	1.07 0.77	0.19	0.00	0.00	0% 28%	0.00	0.00	0% 28%	N/A 0.06
'A	1730	1631 LED screw-in replacement (base CFL 1730 Base CFL 23W to screw-in replaceme		2020	2054	1.36	0.13	0.00	0.00	0%	0.00	0.00	0%	0.06 N/A
Ά	1730	1731 LED screw-in replacement (base CFL		2020	2054	1.01	0.18	0.35	0.35	26%	0.06	0.06	26%	0.05
Α	1800		ata Cente	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
A	1850 1850		ata Cente	2014	2054 2054	0.27	0.05	0.00	0.00	0% 44%	0.00	0.00	0% 44%	N/A
'A	1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 2	ata Cente		2054	4.01	0.03	0.12	0.12	44% 0%	0.02	0.02	0%	0.03 N/A
/A	1900	1901 Outdoor Lighting Controls (Photocell/T		2014	2054	3.65	0.04	0.36	0.36	9%	0.00	0.00	18%	0.02
Ά	1900	1902 LED Outdoor Area Lighting	ata Cente	2014	2054	1.76	0.02	1.89	2.25	56%	0.02	0.03	65%	0.10
Α	1900		ata Cente	2014	2054	1.25	0.01	0.50	2.75	69%	0.01	0.03	77%	0.67
A	2000 2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 2010 Ceiling/roof Insulation - Chiller	ata Cente		2054 2054	44.99 44.79	11.07 11.02	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.00
A	2000		ata Cente		2054	44.77	11.02	0.20	0.20	0%	0.00	0.05	0%	0.00
A	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 to			2054	40.94	10.08	3.82	4.05	9%	0.94	0.99	9%	0.01
Α	2000		ata Cente	2014	2054	40.66	10.05	0.29	4.33	10%	0.03	1.03	9%	0.01
Α	2000 2000		ata Cente	2014 2014	2054 2054	40.58 39.54	10.03	0.07	4.41	10%	0.02	1.04	9%	0.02
'A 'A	2000		ata Cente ata Cente	2014	2054	36.69	9.97 9.81	1.04 2.85	5.45 8.30	12% 18%	0.06	1.10 1.26	10% 11%	0.02
Ά	2000		ata Cente		2054	36.67	9.81	0.01	8.32	18%	0.00	1.27	11%	0.02
Α	2000	2012 Duct Testing/Sealing - Chiller	ata Cente	2014	2054	29.71	8.09	6.97	15.28	34%	1.72	2.98	27%	0.06
Α	2000	2004 Cool Roof - Chiller	ata Cente		2054	29.61	8.07	0.09	15.38	34%	0.02	3.00	27%	0.09
A	2000 2100		ata Cente	2014	2054 2054	29.52 25.66	8.05	0.09	15.47 0.00	34%	0.02	3.03	27%	0.74 N/A
A A	2100	2100 Base DX Packaged System, EER=10.3 2102 DX Packaged System, EER=13.4, 10 ft			2054	19.76	6.32 4.86	0.00 5.90	5.90	0% 23%	0.00 1.45	0.00 1.45	0% 23%	0.01
Ä	2100		ata Cente		2054	19.33	4.68	0.43	6.33	25%	0.19	1.64	26%	0.03
Α.	2100		ata Cente		2054	18.97	4.66	0.36	6.69	26%	0.02	1.66	26%	0.02
A A A	2100 2100	2109 Economizer - DX	ata Cente ata Cente	2014	2054 2054	16.67 16.67	4.53 4.53	2.29	8.98 8.99	35% 35%	0.13	1.79	28% 28%	0.03

DNV·GL ADDITIVE MEASURE LEVEL RESULTS **Base Avoided Costs**

		DDITIVE SUPPLY ANALYSIS Existing Measure Numb Measure	Building Type	Year Measure Start Year	2020 Measure End Year	Total GWH	Total MW	GWH Savings	Total Energy Savings GWH	Percent GWH Savings	MW Savings	Total Capacity Savings MW	Percent MW Savings	Margina Energy Cost \$/kWH
VA VA	2100	2106 Prog. Thermostat - DX	ata Cente	2014	2054	15.52	4.40	0.80	10.14	40%	0.05	1.92	30%	0.04
/A /A	2100 2100	2112 Duct Testing/Sealing - DX 2110 Dual Enthalpy Economizer Replace	ata Cente	2014	2054 2054	14.58 14.58	4.16 4.16	0.94	11.08 11.08	43% 43%	0.23	2.15 2.15	34% 34%	0.08
A	2100	2107 Cool Roof - DX	ata Cente	2014	2054	14.45	4.13	0.12	11.21	44%	0.03	2.18	35%	0.10
A	2100	2114 Duct/Pipe Insulation - DX	ata Cente	2014	2054	14.36	4.11	0.09	11.30	44%	0.02	2.21	35%	0.87
A A	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HS		2014 2014	2054 2054	3.29 2.88	0.81	0.00	0.00	0% 12%	0.00	0.00	0% 12%	N/A 0.01
4	2300	2201 Heat Pump Upgrade (15 SEER, 8.2 2300 Base PTAC, EER=8.3, 1 ton	ata Cente	2014	2054	0.00	0.00	0.00	0.00	0%	0.10	0.10	0%	N/A
À	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87		2014	2054	6.59	1.62	0.00	0.00	0%	0.00	0.00	0%	N/A
4	3000	3002 Variable Speed Drive Control, 5 HF		2014	2054	5.97	1.58	0.61	0.61	9%	0.04	0.04	2%	0.01
A A	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	ata Cente ata Cente	2014 2014	2054 2054	5.88 5.54	1.56 1.41	0.10	0.71 1.05	11% 16%	0.02	0.06 0.21	4% 13%	0.01
À	3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 9		2014	2054	22.89	5.63	0.00	0.00	0%	0.15	0.00	0%	0.30 N/A
Α.	3100	3102 Variable Speed Drive Control, 15 H		2014	2054	20.77	5.50	2.12	2.12	9%	0.13	0.13	2%	0.00
A	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	ata Cente	2014	2054	20.64	5.47	0.12	2.25	10%	0.03	0.16	3%	0.01
A A	3100	3104 Electronically Commutated Motors		2014	2054	19.29	5.17	1.35	3.60	16%	0.30	0.47	8%	0.01
A A	3100 3100	3103 Air Handler Optimization, 15 HP 3105 Energy Recovery Ventilation (ERV)	ata Cente ata Cente	2014 2014	2054 2054	17.47 17.04	5.06 4.86	1.82 0.43	5.42 5.85	24% 26%	0.11	0.58	10% 14%	0.01 0.11
ì	3100	3107 Demand Controlled Ventilation	ata Cente	2014	2054	16.06	4.43	0.98	6.83	30%	0.13	1.21	21%	0.36
4	3200	3200 Base Fan Motor, 40hp, 1800rpm, 9	3.0ata Cente	2014	2054	24.32	5.99	0.00	0.00	0%	0.00	0.00	0%	N/A
A	3200	3202 Variable Speed Drive Control, 40 H		2014	2054	22.06	5.85	2.26	2.26	9%	0.14	0.14	2%	0.01
4 4	3200	3203 Air Handler Optimization, 40 HP	ata Cente	2014 2014	2054	19.98	5.72	2.08	4.34	18%	0.13	0.27	5%	0.01
١	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	ata Cente	2014	2054 2054	19.89 18.75	5.69 5.19	0.09	4.43 5.57	18% 23%	0.02	0.29	5% 13%	0.05
À	4000	4000 Base Built-Up Refrigeration System	n ata Cente	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	4100	4100 Base Self-Contained Refrigeration	ata Cente	2014	2054	3.64	0.68	0.00	0.00	0%	0.00	0.00	0%	N/A
A	4100	4109 Energy-Star Freezer, glass door	ata Cente		2054	3.64	0.68	0.00	0.00	0%	0.00	0.00	0%	0.00
A A	4100 4100	4104 Freezer-Cooler Replacement Gask 4107 Energy-Star Freezer, solid door	ets ata Cente ata Cente	2014	2054 2054	3.57 3.57	0.67 0.67	0.07	0.07	2% 2%	0.01	0.01 0.01	2% 2%	0.00
A	4100	4108 Energy-Star Refrigerator, glass doo		2014	2054	3.57	0.67	0.00	0.07	2%	0.00	0.01	2%	0.01
4	4100	4106 Energy-Star Refrigerator, solid doo		2014	2054	3.57	0.67	0.00	0.07	2%	0.00	0.01	2%	0.01
4	4100	4110 Energy Star Ice Machines	ata Cente	2014	2054	3.57	0.67	0.00	0.08	2%	0.00	0.01	2%	0.02
4 4	4100	4112 Reach-in unit occupancy sensors	ata Cente	2014 2014	2054	3.56	0.67	0.00	80.0	2%	0.00	0.01	2%	0.27
`	4100 5000	4105 Bi-level LED Case Lighting (self-co 5000 Base Desktop PC	ata Cente	2014	2054 2054	3.56 0.48	0.67	0.00	0.08	2% 0%	0.00	0.01	2% 0%	0.30 N/A
	5000	5001 PC Network Power Management E		2014	2054	0.27	0.06	0.21	0.21	44%	0.02	0.02	23%	0.01
	5000	5002 Energy Star or Better PC	ata Cente	2014	2054	0.21	0.05	0.06	0.27	56%	0.01	0.03	35%	0.03
	5100	5100 Base Laptop PC	ata Cente	2014	2054	0.03	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A
Д Д	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management	ata Cente	2014	2054 2054	0.03	0.00	0.01	0.01 0.01	19% 21%	0.00	0.00	19% 21%	0.01 1.24
Α .	5200	5200 Base Monitor, CRT	ata Cente	2014	2054	0.26	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A
A	5200	5201 Energy Star or Better Monitor - CR	T ata Cente	2014	2054	0.15	0.03	0.11	0.11	43%	0.02	0.02	43%	0.00
Α	5200	5202 Monitor Power Management Enabli		2014	2054	0.13	0.02	0.02	0.13	50%	0.00	0.02	46%	0.01
A A	5200 5300	5203 Plug-load controls - Commercial Si 5300 Base Monitor, LCD	maiata Cente ata Cente	2014 2014	2054 2054	0.12 0.13	0.02	0.01	0.14	54% 0%	0.00	0.02	50% 0%	0.14 N/A
Α .	5300	5301 Energy Star or Better Monitor - LCI		2014	2054	0.13	0.02	0.02	0.00	13%	0.00	0.00	13%	0.01
A	5300	5302 Monitor Power Management Enabli		2014	2054	0.10	0.02	0.01	0.02	19%	0.00	0.00	16%	0.08
4	5300	5303 Plug-load controls - Commercial Si		2014	2054	0.09	0.02	0.01	0.03	25%	0.00	0.00	18%	0.24
A A	5400 5400	5400 Base Copier	ata Cente ata Cente	2014	2054 2054	0.11 0.10	0.02	0.00	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.00
Α.	5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enablir		2014	2054	0.10	0.02	0.00	0.01	14%	0.00	0.00	12%	0.00
A	5500	5500 Base Multifunction	ata Cente	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
4	5500	5502 ENERGY STAR Multi-Function Prin		2014	2054	0.01	0.00	0.00	0.00	25%	0.00	0.00	25%	0.01
4	5500	5501 Multifunction Power Management E		2014	2054	0.01	0.00	0.00	0.01	38%	0.00	0.00	32%	0.28
A A	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	ata Cente ata Cente	2014 2014	2054 2054	0.04	0.01	0.00	0.00	0% 35%	0.00	0.00	0% 35%	N/A 0.00
ì	5600	5601 Printer Power Management Enablir		2014	2054	0.02	0.00	0.00	0.02	46%	0.00	0.00	41%	0.06
	5700	5700 Base Data Center/Server Room	ata Cente	2014	2054	762.71	132.70	0.00	0.00	0%	0.00	0.00	0%	N/A
١.	5700	5701 Data Center Improved Operations	ata Cente	2014	2054	686.44	119.43	76.27	76.27	10%	13.27	13.27	10%	0.00
١	5700 5700	5702 Data Center Best Practices	ata Cente	2014	2054 2054	599.11 565.56	104.24 98.40	87.33 33.55	163.60 197.15	21% 26%	15.19 5.84	28.46 34.30	21% 26%	0.00
١	6000	5703 Data Center State of the Art practic 6000 Base Water Heating	es ata Cente ata Cente	2014	2054	0.38	0.07	0.00	0.00	26%	0.00	0.00	26% 0%	0.00 N/A
Ä	6000	6007 Heat Trap	ata Cente	2014	2054	0.36	0.06	0.02	0.02	5%	0.00	0.00	5%	0.08
٦.	6000	6002 High Efficiency Water Heater (elect		2014	2054	0.36	0.06	0.01	0.03	7%	0.00	0.00	7%	0.16
Α	6000	6004 Tankless Water Heater	ata Cente	2014 2014	2054	0.33 0.15	0.06	0.03	0.05	14%	0.00	0.01 0.04	14% 60%	0.24
А А		COOR Color Water Lines			2054		0.03	0.18	0.23	60%	0.03			
4 4 4	6000	6008 Solar Water Heater	ata Cente				0.03	0.01						
A A A		6006 Heat Recovery Unit	ata Cente	2014 2014 2014	2054 2054	0.14	0.03	0.01	0.24 0.24	62% 64%	0.00	0.04	62% 64%	0.62
A A A A	6000 6000		ata Cente em:ata Cente	2014	2054	0.14			0.24	62%	0.00	0.04	62%	0.62
	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating syste	ata Cente emsata Cente es ata Cente) ata Cente	2014 2014 2014 2014	2054 2054	0.14 0.14	0.02	0.00	0.24 0.24	62% 64%	0.00	0.04 0.04	62% 64%	0.62 1.87

	Base	Existing Measure	Building	Start	eWeasure End	Total	Total	GWH	Total Energy Savings	Percent GWH	MW	Total Capacity Savings	MW	Marginal Energy Cost
Sgmt /A	Number 7100	Numb Measure 7101 Vending Misers (Non-Refrigerated)	Type ata Cente	Year 2014	Year 2054	0.01	0.00	Savings 0.00	0.00	Savings 44%	Savings 0.00	0.00	Savings 23%	\$/kWH 0.12
A	7200	7200 Base Oven	ata Cente	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
4	7300	7300 Base Fryer	ata Cente	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
Α Α	7400 8000	7400 Base Steamer	ata Cente	2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
4	8100	8000 Base Heating, Heat Pump (7.7 HSP 8100 Base Heating, Other Electric	ata Cente	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A N/A
A	9500	9500 Base Miscellaneous	ata Cente	2014	2054	3.84	0.67	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	9500	9501 Xmisc	ata Cente	2014	2054	3.84	0.67	0.00	0.00	0%	0.00	0.00	0%	N/A
A	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1		2020	2054	69.16	11.74	0.00	0.00	0%	0.00	0.00	0%	N/A
A	1030 1030	1031 ROB 4L4' High Performance T8 (86 1036 Lighting Control Tuneup (base 4L4')		2020	2054 2054	62.00 61.68	10.52 10.50	7.17 0.32	7.17 7.49	10% 11%	1.22	1.22	10% 11%	0.04
Α	1030	1038 High Performance Lighting R/R - 25		2020	2054	57.00	9.87	4.67	12.16	18%	0.63	1.87	16%	0.07
/A	1030	1032 ROB 4L4' Low Watt High Performan		2020	2054	49.75	8.64	7.25	19.41	28%	1.23	3.10	26%	0.09
A	1030 1030	1034 ROB 4L4' LED Tube, 2020 1037 Occupancy Sensor, 4L4' Fluorescer	gious Wor	2020	2054 2054	41.74 40.62	7.28 7.23	8.02 1.11	27.43 28.54	40% 41%	1.36	4.46 4.51	38% 38%	0.58
'A	1030	1037 Occupancy Sensor, 4L4 Fluorescer 1035 LED Troffer (base 4L4T8), 2020	gious Wor	2020	2054	37.16	6.64	3.47	32.01	46%	0.05	5.10	43%	0.49
Ά	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1		2020	2054	52.96	8.99	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	1130	1131 ROB 2L4' High Performance T8 (86		2020	2054	47.96	8.14	5.00	5.00	9%	0.85	0.85	9%	0.05
A A	1130	1136 Lighting Control Tuneup (base 2L4'		2020	2054	47.71	8.12	0.25	5.25	10%	0.02	0.87	10%	0.05
4	1130 1130	1138 High Performance Lighting R/R - 25 1132 ROB 2L4' Low Watt High Performan		2020 2020	2054 2054	44.09 38.48	7.63 6.68	3.61 5.61	8.87 14.48	17% 27%	0.49	1.36 2.31	15% 26%	0.08
A	1130	1134 ROB 2L4' LED Tube, 2020	noW suoip	2020	2054	36.62	6.36	1.86	16.34	31%	0.32	2.62	29%	0.47
A	1130	1135 LED Troffer (base 2L4'T8), 2020	gious Wor	2020	2054	33.50	5.83	3.13	19.46	37%	0.53	3.15	35%	0.59
Α	1130	1137 Occupancy Sensor, 2L4' Fluorescen		2020	2054	32.60	5.80	0.89	20.36	38%	0.04	3.19	35%	0.47
A A	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other	gious Wor	2014	2054 2054	0.72	0.12 0.12	0.00	0.00	0% 3%	0.00	0.00	0% 2%	N/A 0.03
A	1200	1201 ROB High Performance T8 (base of		2014	2054	0.65	0.12	0.02	0.02	10%	0.00	0.00	9%	0.03
Ά	1200	1202 ROB Low Watt High Performance T		2014	2054	0.57	0.10	0.08	0.16	22%	0.01	0.02	20%	0.35
A	1200	1205 High Performance Lighting R/R - 25		2014	2054	0.52	0.09	0.04	0.20	28%	0.01	0.03	25%	0.36
A A	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescer 1330 Base Incandescent Flood, 100W to		2014 2020	2054 2054	0.48 27.77	0.09 4.71	0.04	0.24	33% 0%	0.00	0.03	26% 0%	0.31 N/A
A	1330	1332 LEDs (base incandescent flood) 202		2020	2054	4.96	0.84	22.81	22.81	82%	3.87	3.87	82%	0.01
Α	1430	1430 Base Incandescent A-Line Lamp, 72	Wgious Wor	2020	2054	10.00	1.70	0.00	0.00	0%	0.00	0.00	0%	N/A
4	1430	1432 LEDs (base incandescent A-line 72)		2020	2054	1.94	0.33	8.06	8.06	81%	1.37	1.37	81%	0.01
A A	1530 1530	1530 Base Incandescent A-Line Lamp, 53 1532 LEDs (base incandescent A-line 53\)		2020	2054 2054	7.36 1.96	1.25	0.00 5.40	0.00 5.40	0% 73%	0.00	0.00	0% 73%	N/A 0.02
A A	1630	1630 Base CFL 18W to screw-in replacen		2020	2054	4.14	0.33	0.00	0.00	73% 0%	0.92	0.92	73% 0%	0.02 N/A
A	1630	1631 LED screw-in replacement (base CF		2020	2054	2.99	0.51	1.15	1.15	28%	0.19	0.19	28%	0.13
Α	1730	1730 Base CFL 23W to screw-in replacen		2020	2054	5.29	0.90	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	1730 1800	1731 LED screw-in replacement (base CF 1800 BaseMetal Halide, 465W	L gious Wor gious Wor	2020 2014	2054 2054	3.92 3.51	0.66	1.38	1.38 0.00	26% 0%	0.23	0.23	26% 0%	0.09 N/A
'A	1800	1801 T5 (240W) (base metal halide)	gious Wor	2014	2054	2.33	0.39	1.19	1.19	34%	0.00	0.20	34%	0.03
Α	1800	1806 Occupancy Sensor, High Bay T5	gious Wor	2014	2054	2.25	0.39	0.08	1.26	36%	0.00	0.20	34%	0.08
Α	1800	1805 High Performance Lighting R/R - 25		2014	2054	2.08	0.37	0.17	1.43	41%	0.02	0.23	38%	0.14
'A 'A	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	gious Wor	2014 2014	2054 2054	2.02 1.09	0.34 0.18	0.00	0.00	0% 46%	0.00	0.00 0.16	0% 46%	N/A 0.05
A	1900	1900 Base Outdoor High Pressure Sodiur		2014	2054	25.23	1.95	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	1900	1901 Outdoor Lighting Controls (Photocel		2014	2054	24.75	1.85	0.48	0.48	2%	0.11	0.11	5%	0.07
Ά	1900	1902 LED Outdoor Area Lighting	gious Wor	2014	2054	11.91	0.85	12.84	13.32	53%	0.99	1.10	56%	0.16
A	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/to	gious Wor	2014 2014	2054 2054	8.43 30.08	0.61 23.26	3.48	16.80 0.00	67% 0%	0.24	1.34 0.00	69% 0%	1.07 N/A
Λ A	2000	2010 Ceiling/roof Insulation - Chiller	gious Wor	2014	2054	29.71	22.97	0.38	0.38	1%	0.00	0.29	1%	0.04
Ά	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500		2014	2054	27.17	21.01	2.54	2.91	10%	1.96	2.25	10%	0.08
Α	2000	2005 Chiller Tune Up/Diagnostics	gious Wor	2014	2054	27.15	21.00	0.02	2.93	10%	0.01	2.26	10%	0.06
A A	2000	2013 High Efficiency Chiller Motors 2006 VSD for Chiller Pumps and Towers	gious Wor	2014 2014	2054 2054	27.13 26.07	20.99 20.57	0.02 1.05	2.95 4.01	10% 13%	0.02	2.28	10% 12%	0.12
/A	2000	2003 EMS - Chiller	gious Wor	2014	2054	24.82	20.37	1.25	5.26	17%	0.42	2.03	13%	0.03
Ά	2000	2012 Duct Testing/Sealing - Chiller	gious Wor	2014	2054	20.26	16.79	4.56	9.83	33%	3.53	6.47	28%	0.40
Α	2000	2002 Window Film (Standard) - Chiller	gious Wor	2014	2054	20.13	16.69	0.13	9.95	33%	0.10	6.57	28%	1.45
'A 'A	2000	2004 Cool Roof - Chiller	gious Wor	2014	2054	20.09	16.66	0.04	9.99	33%	0.03	6.60	28%	6.31
A	2000 2000	2011 Duct/Pipe Insulation - Chiller 2008 New Economizer - Chiller	gious Wor gious Wor	2014 2014	2054 2054	19.82 19.82	16.46 16.46	0.27	10.26 10.26	34% 34%	0.21	6.81 6.81	29% 29%	7.61
Ά	2100	2100 Base DX Packaged System, EER=1		2014	2054	96.90	74.94	0.00	0.00	0%	0.00	0.00	0%	N/A
Α	2100	2113 Ceiling/roof Insulation - DX	gious Wor	2014	2054	96.90	74.94	0.00	0.00	0%	0.00	0.00	0%	0.04
/A	2100	2102 DX Packaged System, EER=13.4, 1		2014	2054	74.61	57.70	22.29	22.29	23%	17.24	17.24	23%	0.07
	2100	2105 DX Tune Up/ Advanced Diagnostics		2014	2054 2054	74.58 70.19	57.69 54.30	0.03 4.39	22.32 26.71	23% 28%	0.01 3.39	17.25 20.64	23% 28%	0.23
A	2100	2112 Duct Tecting/Sealing - DY												
A	2100 2100	2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX	gious Wor	2014	2054	68.60	53.98	1.59	28.30	29%	0.32	20.04	28%	
A A A		2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX 2108 Optimize Controls - DX	gious Wor gious Wor						28.30 29.44					0.43 0.24 0.25
'A 'A 'A 'A	2100	2106 Prog. Thermostat - DX	gious Wor	2014 2014 2014	2054	68.60	53.98	1.59		29%	0.32	20.96	28%	0.24

/inta		Existing			eMeasure				Total Energy	Percent		Total Capacity		Margina Energy
Samt	Base Number	Measure Numb Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Saving:	Savings s MW	MW Savings	Cost \$/kWH
/A	2200	2200 Base Heat Pump (13 SEE	R, 7.7 HSPFgious Wor	2014	2054	78.85	60.98	0.00	0.00	0%	0.00	0.00	0%	N/A
A A	2200	2201 Heat Pump Upgrade (15 S		2014	2054	69.10	53.44	9.75	9.75	12%	7.54	7.54	12%	0.07
١	2300 2300	2300 Base PTAC, EER=8.3, 1 t 2301 HE PTAC, EER=9.6, 1 tor		2014 2014	2054 2054	78.27 67.67	60.53 52.33	0.00 10.60	0.00 10.60	0% 14%	0.00 8.20	0.00 8.20	0% 14%	N/A 0.16
ì	3000	3000 Base Fan Motor, 5hp, 180		2014	2054	72.92	20.72	0.00	0.00	0%	0.00	0.00	0%	N/A
	3000	3001 Fan Motor, 5hp, 1800rpm		2014	2054	71.66	20.36	1.26	1.26	2%	0.36	0.36	2%	0.13
	3000 3000	3002 Variable Speed Drive Con		2014	2054 2054	50.40 49.42	18.85 18.32	21.26	22.52	31% 32%	1.51 0.54	1.86 2.40	9% 12%	0.10 3.09
	3100	3003 Demand Controlled Ventil 3100 Base Fan Motor, 15hp, 18		2014	2054	49.42 58.13	16.52	0.98	0.00	32% 0%	0.00	0.00	0%	3.09 N/A
	3100	3104 Electronically Commutate		2014	2054	49.74	14.37	8.39	8.39	14%	2.14	2.14	13%	0.06
	3100	3103 Air Handler Optimization,		2014	2054	46.33	14.13	3.41	11.80	20%	0.24	2.38	14%	0.08
	3100 3100	3102 Variable Speed Drive Con 3101 Fan Motor, 15hp, 1800rpn		2014 2014	2054 2054	32.59 32.10	13.16 13.02	13.75 0.49	25.54 26.03	44% 45%	0.97 0.14	3.36 3.49	20% 21%	0.13 0.42
	3100	3105 Energy Recovery Ventilati		2014	2054	31.69	12.80	0.45	26.44	45%	0.14	3.72	23%	0.42
	3100	3107 Demand Controlled Ventil		2014	2054	31.07	12.46	0.62	27.06	47%	0.34	4.06	25%	3.92
	3200	3200 Base Fan Motor, 40hp, 18		2014	2054	46.13	13.11	0.00	0.00	0%	0.00	0.00	0%	N/A
	3200 3200	3203 Air Handler Optimization,		2014 2014	2054 2054	42.97 30.22	12.88 11.98	3.16 12.75	3.16 15.91	7% 34%	0.22	0.22	2% 9%	0.07
	3200	3202 Variable Speed Drive Con 3201 Fan Motor, 40hp, 1800rpn		2014	2054	30.10	11.96	0.12	16.03	35%	0.90	1.16	9%	1.02
	3200	3204 Demand Controlled Ventil		2014	2054	29.51	11.62	0.59	16.62	36%	0.32	1.48	11%	3.28
	4000	4000 Base Built-Up Refrigeration		2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
	4100 4100	4100 Base Self-Contained Refri		2014 2014	2054 2054	98.51 97.55	14.83 14.69	0.00	0.00	0% 1%	0.00	0.00 0.14	0% 1%	N/A 0.00
	4100	4103 Night covers for display co 4104 Freezer-Cooler Replacem		2014	2054	96.17	14.48	1.39	2.34	1% 2%	0.14	0.14	2%	0.00
	4100	4108 Energy-Star Refrigerator,		2014	2054	95.55	14.38	0.62	2.96	3%	0.09	0.45	3%	0.01
	4100	4106 Energy-Star Refrigerator,	solid door gious Wor	2014	2054	93.94	14.14	1.60	4.56	5%	0.24	0.69	5%	0.01
	4100 4100	4110 Energy Star Ice Machines		2014	2054 2054	91.85 91.84	13.83	2.09	6.65	7%	0.31	1.00	7%	0.03
	4100	4112 Reach-in unit occupancy s 4105 Bi-level LED Case Lighting		2014	2054	91.84	13.83	0.01	6.67 6.75	7% 7%	0.00	1.00 1.02	7% 7%	0.28
	5000	5000 Base Desktop PC	g (con contagious Wor	2014	2054	9.54	1.44	0.00	0.00	0%	0.00	0.00	0%	N/A
	5000	5001 PC Network Power Manag		2014	2054	5.24	1.11	4.30	4.30	45%	0.33	0.33	23%	0.02
	5000	5002 Energy Star or Better PC	gious Wor	2014	2054	3.61	0.87	1.63	5.93	62%	0.25	0.58	40%	0.05
	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Lap	gious Wor top gious Wor	2014 2014	2054 2054	0.66	0.10	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.02
	5100	5101 Laptop Network Power Ma		2014	2054	0.52	0.08	0.12	0.12	21%	0.02	0.02	21%	2.25
	5200	5200 Base Monitor, CRT	gious Wor	2014	2054	1.67	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A
	5200	5201 Energy Star or Better Mon		2014	2054	0.73	0.11	0.94	0.94	56%	0.14	0.14	56%	0.00
	5200 5200	5202 Monitor Power Manageme 5203 Plug-load controls - Comr		2014	2054 2054	0.55	0.10	0.19	1.12	67% 70%	0.01	0.16 0.16	62% 64%	0.03
	5300	5300 Base Monitor, LCD	nercial Sinagious Wor	2014	2054	1.99	0.30	0.00	0.00	0%	0.00	0.00	0%	N/A
	5300	5301 Energy Star or Better Mor		2014	2054	1.63	0.25	0.36	0.36	18%	0.05	0.05	18%	0.02
	5300	5302 Monitor Power Manageme		2014	2054	1.57	0.24	0.06	0.41	21%	0.00	0.06	19%	0.15
	5300 5400	5303 Plug-load controls - Comr 5400 Base Copier	nercial Smaglous Wor gious Wor	2014	2054 2054	1.45 3.87	0.24	0.12	0.53	27% 0%	0.00	0.06	21% 0%	0.42 N/A
	5400	5401 Energy Star or Better Cop		2014	2054	3.35	0.55	0.52	0.52	13%	0.00	0.08	13%	0.00
	5400	5402 Copier Power Managemen	nt Enabling gious Wor	2014	2054	3.19	0.49	0.17	0.68	18%	0.01	0.09	16%	0.17
	5500	5500 Base Multifunction	gious Wor	2014	2054	0.51	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A
	5500 5500	5502 ENERGY STAR Multi-Fur 5501 Multifunction Power Mana		2014	2054 2054	0.38	0.06	0.13	0.13	25% 37%	0.02	0.02	25% 31%	0.01
	5600	5600 Base Printer	gious Wor	2014	2054	1.56	0.24	0.00	0.00	0%	0.00	0.02	0%	N/A
	5600	5602 ENERGY STAR Printer	gious Wor	2014	2054	1.02	0.15	0.54	0.54	35%	0.08	0.08	35%	0.00
	5600	5601 Printer Power Managemen		2014	2054	0.85	0.14	0.17	0.71	45%	0.01	0.10	40%	0.10
	5700 5700	5700 Base Data Center/Server 5701 Data Center Improved Op		2014 2014	2054 2054	8.06 7.25	1.22	0.00	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.00
	5700	5702 Data Center Improved Op		2014	2054	6.33	0.96	0.92	1.73	21%	0.12	0.12	21%	0.00
	5700	5703 Data Center State of the A	Art practices gious Wor	2014	2054	5.97	0.90	0.35	2.08	26%	0.05	0.32	26%	0.00
	6000	6000 Base Water Heating	gious Wor	2014	2054	27.02	3.99	0.00	0.00	0%	0.00	0.00	0%	N/A
	6000 6000	6007 Heat Trap 6002 High Efficiency Water Hea	gious Wor	2014 2014	2054 2054	25.62 25.11	3.78	1.40 0.51	1.40 1.91	5% 7%	0.21	0.21	5% 7%	0.03
	6000	6004 Tankless Water Heater	gious Wor	2014	2054	23.22	3.43	1.88	3.79	14%	0.08	0.26	14%	0.08
	6000	6003 Hot Water Pipe Insulation		2014	2054	22.78	3.36	0.44	4.24	16%	0.07	0.63	16%	0.11
	6000	6006 Heat Recovery Unit	gious Wor	2014	2054	22.04	3.25	0.74	4.98	18%	0.11	0.73	18%	0.10
	6000	6001 Demand controlled circula		2014	2054	21.21	3.13	0.83	5.80	21%	0.12	0.86	21%	0.31
	7000 7000	7000 Base Refrigerated Vending 7001 Vending Misers (Refrigera		2014	2054 2054	4.50 3.78	0.75 0.69	0.00	0.00	0% 16%	0.00	0.00	0% 8%	N/A 0.03
	7000	7002 Vending Misers (Refrigera		2014	2054	3.38	0.65	0.39	1.11	25%	0.03	0.09	12%	0.05
	7100	7100 Base Non-Refrigerated Ve	ending Machigious Wor	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
	7100	7101 Vending Misers (Non-Refr		2014	2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	23%	0.44
	7200 7300	7200 Base Oven 7300 Base Fryer	gious Wor gious Wor	2014	2054 2054	26.99	4.38 0.23	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A
	7300	7301 Efficient Fryer	gious Wor		2054	1.31	0.21	0.09	0.09	6%	0.01	0.01	6%	0.43
	7400	7400 Base Steamer		2014	2054	1.23		0.00	0.00	0%	0.00		0%	

Com	mercial Ele	ctric Existing Construction												
DSM	ASSYST A	DDITIVE SUPPLY ANALYSIS		Year	2020									
Vinta	age	Existing							Total			Total		Marginal
				Measur	elleasure	9			Energy	Percent		Capacity	Percent	Energy
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings		Cost
	t Number	Numb Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	
VA	8000	8000 Base Heating, Heat Pump (7.7 HSPF)			2054	2.39	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 F	lgious Wor	2014	2054	2.26	0.00	0.13	0.13	6%	0.00	0.00	0%	0.06
VA	8100	8100 Base Heating, Other Electric	gious Wor	2014	2054	19.53	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	9500	9500 Base Miscellaneous	gious Wor	2014	2054	333.79	55.49	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	9500	9501 Xmisc	gious Wor	2014	2054	333.79	55.49	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1E	B Misc	2020	2054	414.67	70.38	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	1030	1036 Lighting Control Tuneup (base 4L4'T8	B) Misc	2020	2054	412.52	70.20	2.15	2.15	1%	0.18	0.18	0%	0.01
VA	1030	1038 High Performance Lighting R/R - 25%	Misc	2020	2054	381.28	66.00	31.25	33.40	8%	4.20	4.38	6%	0.02
VA	1030	1031 ROB 4L4' High Performance T8 (86 V		2020	2054	341.77	59.29	39.50	72.90	18%	6.70	11.08	16%	0.02
VA	1030	1032 ROB 4L4' Low Watt High Performance	€ Misc	2020	2054	298.29	51.91	43.48	116.38	28%	7.38	18.46	26%	0.04
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent	F Misc	2020	2054	290.34	51.59	7.94	124.33	30%	0.33	18.79	27%	0.08
VA	1030	1034 ROB 4L4' LED Tube, 2020	Misc	2020	2054	243.56	43.65	46.78	171.11	41%	7.94	26.73	38%	0.25
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	Misc	2020	2054	222.77	40.12	20.79	191.90	46%	3.53	30.26	43%	0.20
VA	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1E	B Misc	2020	2054	317.53	53.89	0.00	0.00	0%	0.00	0.00	0%	N/A
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8	B) Misc	2020	2054	315.87	53.75	1.66	1.66	1%	0.14	0.14	0%	0.02

		ric New Construction DITIVE SUPPLY ANALYSIS				Year	2014							
Vinta	ge	Existing							Total	_		Total	_	Margina
	Base	Measure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost
Samt	Number	Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH
VA	100	100 Base Bldg Design - 15%	Office	2014	2053	45.23	10.30	0.00	0.00	0%	0.00	0.00	0%	N/A
VA.	100	101 High Performance Building/Int Design - Tier 1 15% - Office	Office	2014	2053	38.32	8.29	6.91	6.91	15%	2.01	2.01	20%	0.04
VΑ	200	200 Base Bldg Design - 30%	Office	2014	2053	36.18	8.24	0.00	0.00	0%	0.00	0.00	0%	N/A
VΑ	200	201 High Performance Building/Int Design - Tier 2 30% - Office	Office	2014	2053	25.13	5.03	11.05	11.05	31%	3.21	3.21	39%	0.03
VΑ	300	300 Base Bldg Design - 50%	Office	2014	2053	8.14	1.85	0.00	0.00	0%	0.00	0.00	0%	N/A
VΑ	300	301 High Performance Building/Int Design - Tier 3 50% - Office	Office	2014	2053	4.00	0.65	4.14	4.14	51%	1.21	1.21	65%	0.03
VΑ	400	400 Base Bldg Design - 70%	Office	2014	2053	0.90	0.21	0.00	0.00	0%	0.00	0.00	0%	N/A
VΑ	400	401 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	Office	2014	2053	0.26	0.02	0.64	0.64	71%	0.19	0.19	91%	0.04
VC	100	100 Base Bldg Design - 15%	Office	2014	2053	1.89	0.43	0.00	0.00	0%	0.00	0.00	0%	N/A
ИC	100	101 High Performance Building/Int Design - Tier 1 15% - Office	Office	2014	2053	1.60	0.35	0.29	0.29	15%	0.08	0.08	20%	0.04
VC	200	200 Base Bldg Design - 30%	Office	2014	2053	1.51	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A
VC	200	201 High Performance Building/Int Design - Tier 2 30% - Office	Office	2014	2053	1.05	0.21	0.46	0.46	31%	0.13	0.13	39%	0.03
VC	300	300 Base Bldg Design - 50%	Office	2014	2053	0.34	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A
NC NC	300 400	301 High Performance Building/Int Design - Tier 3 50% - Office 400 Base Bldg Design - 70%	Office Office	2014 2014	2053 2053	0.17	0.03	0.17 0.00	0.17 0.00	51% 0%	0.05	0.05 0.00	65% 0%	0.03 N/A
VC VC	400	401 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	Office	2014	2053	0.04	0.00	0.00	0.00	71%	0.00	0.00	91%	0.03
VA	100	100 Base Bldg Design - 15%	Restaurant	2014	2053	19.73	4.18	0.00	0.00	0%	0.00	0.00	0%	N/A
VA.	100	102 High Performance Building/Int Design - Tier 1 15% - Restaurant	Restaurant	2014	2053	16.73	3.36	3.00	3.00	15%	0.81	0.81	20%	0.05
VΑ	200	200 Base Bldg Design - 30%	Restaurant	2014	2053	15.79	3.34	0.00	0.00	0%	0.00	0.00	0%	N/A
VA.	200	202 High Performance Building/Int Design - Tier 2 30% - Restaurant	Restaurant	2014	2053	10.98	2.04	4.80	4.80	30%	1.30	1.30	39%	0.04
VΑ	300	300 Base Bldg Design - 50%	Restaurant	2014	2053	3.55	0.75	0.00	0.00	0%	0.00	0.00	0%	N/A
VΑ	300	302 High Performance Building/Int Design - Tier 3 50% - Restaurant	Restaurant	2014	2053	1.75	0.26	1.80	1.80	51%	0.49	0.49	65%	0.04
VΑ	400	400 Base Bldg Design - 70%	Restaurant	2014	2053	0.39	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A
VΑ	400	402 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaurant	Restaurant	2014	2053	0.11	0.01	0.28	0.28	71%	0.08	0.08	91%	0.04
NC	100	100 Base Bldg Design - 15%	Restaurant	2014	2053	0.52	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A
VС	100	102 High Performance Building/Int Design - Tier 1 15% - Restaurant	Restaurant	2014	2053	0.44	0.09	80.0	0.08	15%	0.02	0.02	20%	0.04
VC	200	200 Base Bldg Design - 30%	Restaurant	2014	2053	0.42	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A
VC	200	202 High Performance Building/Int Design - Tier 2 30% - Restaurant	Restaurant	2014	2053	0.29	0.05	0.13	0.13	30%	0.03	0.03	39%	0.03
ИC	300	300 Base Bldg Design - 50%	Restaurant	2014	2053	0.09	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A
VC	300	302 High Performance Building/Int Design - Tier 3 50% - Restaurant	Restaurant	2014	2053	0.05	0.01	0.05	0.05	51%	0.01	0.01	65%	0.03
VC	400	400 Base Bldg Design - 70%	Restaurant	2014	2053	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A
VC.	400	402 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaurant	Restaurant	2014	2053	0.00	0.00	0.01	0.01	71%	0.00	0.00	91%	0.04
VA VA	100 100	100 Base Bldg Design - 15% 103 High Performance Building/Int Design - Tier 1 15% - Retail	Retail Retail	2014 2014	2053 2053	40.98 34.72	9.62 7.74	0.00 6.26	0.00 6.26	0% 15%	0.00 1.88	0.00 1.88	0% 20%	N/A 0.09
VA VA	200	200 Base Bldg Design - 30%	Retail	2014	2053	34.72	7.74	0.00	0.00	0%	0.00	0.00	20%	0.09 N/A
VA	200	203 High Performance Building/Int Design - Tier 2 30% - Retail	Retail	2014	2053	22.77	4.69	10.01	10.01	31%	3.00	3.00	39%	0.06
VA	300	300 Base Bldg Design - 50%	Retail	2014	2053	7.38	1.73	0.00	0.00	0%	0.00	0.00	0%	N/A
VA.	300	303 High Performance Building/Int Design - Tier 3 50% - Retail	Retail	2014	2053	3.62	0.61	3.75	3.75	51%	1.13	1.13	65%	0.07
VΑ	400	400 Base Bldg Design - 70%	Retail	2014	2053	0.82	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A
/A	400	403 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Retail	Retail	2014	2053	0.24	0.02	0.58	0.58	71%	0.18	0.18	91%	0.07

Commercia	al Opt-Out/F	xempt/Noni	urisdictional Existing													
DSM ASSY	ST ADDITIV	E SUPPLY					Year	2020								
Vintage		Existing			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy
Samt	Base Number	Measure Number	Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH
Opt-Out/Ex	1030		Base Fluorescent Fixture, 4L4T8, 1EB, 2020	Office	2020.00	2054.00	151.74	28.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex		1036	Lighting Control Tuneup (base 4L4'T8), 2020	Office	2020.00	2054.00	150.56	28.14	1.18	1.18	1%	0.11	0.11	0%	0.01	0.01
Opt-Out/Ex Opt-Out/Ex	1030 1030		High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020 ROB 4L4' High Performance T8 (86 W), 2020	Office Office	2020.00 2020.00	2054.00 2054.00	139.27 125.08	26.46 23.81	11.29 14.19	12.47 26.66	8% 18%	1.68 2.64	1.79 4.43	6% 16%	0.01 0.02	0.01 0.02
Opt-Out/Ex			ROB 4L4' High Performance T6 (66 W), 2020 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	2020.00	2054.00	113.50	21.66	11.58	38.24	25%	2.04	6.59	23%	0.02	0.02
Opt-Out/Ex		1037	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	2020.00	2054.00	103.97	21.22	9.53	47.77	31%	0.44	7.03	25%	0.05	0.03
Opt-Out/Ex			ROB 4L4' LED Tube, 2020	Office	2020.00	2054.00	87.22	18.10	16.75	64.52	43%	3.12	10.15	36%	0.24	0.08
Opt-Out/Ex Opt-Out/Ex			i LED Troffer (base 4L4'T8), 2020 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Office	2020.00 2020.00	2054.00 2054.00	79.77 2.57	16.71 0.48	7.45 0.00	71.97 0.00	47% 0%	1.39 0.00	11.54 0.00	41% 0%	0.20 N/A	0.10 N/A
Opt-Out/Ex			Lighting Control Tuneup (base 2L4'T8), 2020	Office	2020.00	2054.00	2.55	0.48	0.02	0.02	1%	0.00	0.00	0%	0.01	0.01
Opt-Out/Ex			High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Office	2020.00	2054.00	2.35	0.45	0.19	0.21	8%	0.03	0.03	6%	0.02	0.02
Opt-Out/Ex Opt-Out/Ex			ROB 2L4' High Performance T8 (86 W), 2020 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Office Office	2020.00 2020.00	2054.00 2054.00	2.11 1.84	0.40 0.35	0.24 0.27	0.46 0.72	18% 28%	0.05 0.05	0.08 0.13	16% 26%	0.02 0.05	0.02 0.03
Opt-Out/Ex			ROB 2L4' LED Tube, 2020	Office	2020.00	2054.00	1.75	0.34	0.09	0.72	32%	0.03	0.13	30%	0.03	0.05
Opt-Out/Ex	1130	1137	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Office	2020.00	2054.00	1.60	0.33	0.15	0.96	37%	0.01	0.15	31%	0.10	0.06
Opt-Out/Ex			LED Troffer (base 2L4T8), 2020	Office	2020.00	2054.00	1.47	0.30	0.14	1.10	43%	0.03	0.17	37%	0.25	0.08
Opt-Out/Ex Opt-Out/Ex			Base Other Fluorescent Fixture Lighting Control Tuneup (base other fluorescent fixture)	Office Office	2014.00 2014.00	2054.00 2054.00	5.57 5.30	1.04 1.01	0.00 0.27	0.00 0.27	0% 5%	0.00	0.00 0.02	0% 2%	N/A 0.00	N/A 0.00
Opt-Out/Ex			i High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	2014.00	2054.00	4.90	0.95	0.40	0.66	12%	0.02	0.02	8%	0.00	0.02
Opt-Out/Ex	1200	1201	ROB High Performance T8 (base other fluorescent)	Office	2014.00	2054.00	4.39	0.86	0.51	1.17	21%	0.09	0.18	17%	0.08	0.04
Opt-Out/Ex			Occupancy Sensor, 4L8' Fluorescent Fixtures	Office	2014.00	2054.00	3.75	0.83	0.64	1.81	33%	0.03	0.21	20%	0.10	0.06
Opt-Out/Ex Opt-Out/Ex			Base Incandescent Flood, 100W to Screw-in Replacement 2020 LEDs (base incandescent flood) 2020	Office Office	2020.00 2020.00	2054.00 2054.00	51.51 12.41	9.59 2.31	0.00 39.10	0.00 39.10	0% 76%	0.00 7.28	0.00 7.28	0% 76%	N/A 0.00	N/A 0.00
Opt-Out/Ex			Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Office	2020.00	2054.00	18.54	3.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex		1432	LEDs (base incandescent A-line 72W) 2020	Office	2020.00	2054.00	4.83	0.90	13.72	13.72	74%	2.55	2.55	74%	0.00	0.00
Opt-Out/Ex			Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	2020.00	2054.00	13.65	2.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex Opt-Out/Ex			LEDs (base incandescent A-line 53W) 2020 Base CFL 18W to screw-in replacement 2020	Office Office	2020.00 2020.00	2054.00 2054.00	4.73 3.37	0.88	8.92 0.00	8.92 0.00	65% 0%	1.66 0.00	1.66 0.00	65% 0%	0.01 N/A	0.01 N/A
Opt-Out/Ex			LED screw-in replacement (base CFL 18W) 2020	Office	2020.00	2054.00	2.43	0.45	0.00	0.00	28%	0.00	0.17	28%	0.05	0.05
Opt-Out/Ex			Base CFL 23W to screw-in replacement 2020	Office	2020.00	2054.00	4.30	0.80	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex			LED screw-in replacement (base CFL 23W) 2020	Office	2020.00	2054.00	3.18	0.59	1.12	1.12	26%	0.21	0.21	26%	0.04	0.04
Opt-Out/Ex Opt-Out/Ex) BaseMetal Halide, 465W) Base CFL Exit Sign	Office Office	2014.00 2014.00	2054.00 2054.00	0.00 1.80	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A
Opt-Out/Ex			LED Exit Sign	Office	2014.00	2054.00	1.01	0.33	0.79	0.79	44%	0.00	0.15	44%	0.02	0.02
Opt-Out/Ex			Base Outdoor High Pressure Sodium 250W Lamp	Office	2014.00	2054.00	12.31	0.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex			Outdoor Lighting Controls (Photocell/Timeclock)	Office	2014.00	2054.00	9.85	0.06	2.46	2.46	20%	0.11	0.11	66%	0.05	0.05
Opt-Out/Ex Opt-Out/Ex			PLED Outdoor Area Lighting Bis-Level LED Outdoor Lighting	Office Office	2014.00 2014.00	2054.00 2054.00	4.74 3.35	-0.01 -0.03	5.11 1.39	7.57 8.96	61% 73%	0.07 0.02	0.18 0.20	108% 118%	0.09 0.59	0.08 0.16
Opt-Out/Ex			Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Office	2014.00	2054.00	19.03	13.31	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex			Ceiling/roof Insulation - Chiller	Office	2014.00	2054.00	18.94	13.25	0.08	0.08	0%	0.06	0.06	0%	0.01	0.01
Opt-Out/Ex Opt-Out/Ex			Centrifugal Chiller, 0.51 kW/ton, 500 tons High Efficiency Chiller Motors	Office Office	2014.00 2014.00	2054.00 2054.00	17.32 17.29	12.12 12.10	1.62 0.03	1.70 1.73	9% 9%	1.13 0.02	1.19 1.21	9% 9%	0.03 0.04	0.03
Opt-Out/Ex			S Aigh Efficiency Chiller Motors S VSD for Chiller Pumps and Towers	Office	2014.00	2054.00	17.29	12.10	0.03	1.73	10%	0.02	1.25	9%	0.04	0.03
Opt-Out/Ex			EMS - Chiller	Office	2014.00	2054.00	15.98	11.85	1.20	3.05	16%	0.21	1.46	11%	0.05	0.03
Opt-Out/Ex			New Economizer - Chiller	Office	2014.00	2054.00	14.95	11.67	1.03	4.08	21%	0.18	1.64	12%	0.05	0.04
Opt-Out/Ex Opt-Out/Ex			P. Window Film (Standard) - Chiller P. Duct Testing/Sealing	Office Office	2014.00 2014.00	2054.00 2054.00	14.94 12.10	11.67 9.68	0.00 2.84	4.08 6.92	21% 36%	0.00 1.99	1.65 3.63	12% 27%	0.09 0.15	0.04 0.08
Opt-Out/Ex			Cool Roof - Chiller	Office	2014.00	2054.00	12.10	9.65	0.04	6.96	37%	0.03	3.66	27%	0.13	0.09
Opt-Out/Ex	2000		Duct/Pipe Insulation - Chiller	Office	2014.00	2054.00	12.03	9.63	0.04	7.00	37%	0.03	3.68	28%	1.86	0.10
Opt-Out/Ex			Base DX Packaged System, EER=10.3, 10 tons	Office	2014.00	2054.00	86.33	60.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex Opt-Out/Ex			DX Packaged System, EER=13.4, 10 tons Economizer Repair - DX	Office Office	2014.00 2014.00	2054.00 2054.00	66.48 63.48	46.51 43.37	19.86 2.99	19.86 22.85	23% 26%	13.89 3.14	13.89 17.03	23% 28%	0.02 0.05	0.02
Opt-Out/Ex			Optimize Controls - DX	Office	2014.00	2054.00	62.40	43.18	1.08	23.93	28%	0.19	17.22	29%	0.06	0.03
Opt-Out/Ex	2100	2115	Window Film (Standard) - DX	Office	2014.00	2054.00	61.11	42.27	1.29	25.22	29%	0.90	18.12	30%	0.10	0.03
Opt-Out/Ex			Economizer - DX	Office	2014.00	2054.00	54.39	41.10	6.72	31.94	37%	1.17	19.30	32%	0.07	0.04
Opt-Out/Ex Opt-Out/Ex			P. Aerosol Duct Sealing - DX Forg. Thermostat - DX	Office Office	2014.00 2014.00	2054.00 2054.00	51.08 50.00	38.79 38.60	3.31 1.09	35.25 36.33	41% 42%	2.31 0.19	21.61 21.80	36% 36%	0.19 0.10	0.05
Opt-Out/Ex			Cool Roof - DX	Office	2014.00	2054.00	49.57	38.30	0.43	36.76	43%	0.30	22.10	37%	0.25	0.06
Opt-Out/Ex			Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office	2014.00	2054.00	49.56	38.30	0.01	36.77	43%	0.00	22.10	37%	0.20	0.06
Opt-Out/Ex			Duct/Pipe Insulation - DX	Office	2014.00	2054.00	49.24	38.07	0.32	37.09	43%	0.22	22.33	37%	2.07	0.08
Opt-Out/Ex Opt-Out/Ex			Base Heat Pump (13 SEER, 7.7 HSPF) Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office Office	2014.00 2014.00	2054.00 2054.00	58.94 51.65	41.24 36.14	0.00 7.29	0.00 7.29	0% 12%	0.00 5.10	0.00 5.10	0% 12%	N/A 0.02	N/A 0.02
Opt-Out/Ex			Base PTAC, EER=8.3, 1 ton	Office	2014.00	2054.00	9.44	6.61	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex	3000		Base Fan Motor, 5hp, 1800rpm, 87.5%	Office	2014.00	2054.00	46.72	14.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex Opt-Out/Ex			Fan Motor, 5hp, 1800rpm, 89.5% Variable Speed Drive Control, 5 HP	Office Office	2014.00 2014.00	2054.00 2054.00	45.96 34.57	13.88 13.02	0.76 11.39	0.76 12.15	2% 26%	0.23 0.86	0.23 1.09	2% 8%	0.02 0.01	0.02 0.02
Opt-Out/Ex			Demand Controlled Ventilation	Office	2014.00	2054.00	34.57	13.02	11.39	14.03	30%	1.08	2.17	8% 15%	0.64	0.02
Opt-Out/Ex	3100		Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	2014.00	2054.00	8.09	2.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A
Opt-Out/Ex	3100	3102	Variable Speed Drive Control, 15 HP	Office	2014.00	2054.00	6.09	2.29	2.01	2.01	25%	0.15	0.15	6%	0.00	0.00

APPENDIX H

Base Avoided Costs

Prop. Prop			E SUPPLY ANALYSIS				Year	2014														SUPPLY	
Second Content	Vintage	Existing			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Second	0									Savings			Savings		Cost	Cost	Cost	Cost					
Column C						1001	011111								4	4111111	4	411111	1110			01111	
Second 19	Opt-Out/Ex		101 High Performance Building/Int Design - Tier 1 15% - Office														0						0.28
Change C																				5.06	1.15		
Control Cont	Opt-Out/Ex	300	300 Base Bldg Design - 50%	Office	2014	2053	1.14	0.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.14	0.26	0.00	0.00
Standard Standard																				0.40	0.00		
Second 10 10 20 20 20 20 20 20																				0.13	0.03		
			100 Base Bldg Design - 15%																	0.81	0.19		
December Control Con																				0.65	0.15		
Second S	Opt-Out/Ex	200		Retail	2014	2053	0.45	0.09	0.20	0.20	31%	0.06	0.06	39%	0.06	0.06	0	0	1.37			0.20	0.06
Second S																				0.15	0.03		
Second S																	-	-		0.02	0.00		
Content 10 10 11 11 11 12 12 13 13 13			403 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Retail	rtotan													0						
Second																				0.02	0.00		
Second Content Seco	Opt-Out/Ex	200	200 Base Bldg Design - 30%		2014	2053	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A			N/A	0.02	0.00	0.00	0.00
Control Cont																		-		0.00	0.00		
Concording Con																				0.00	0.00		
Controlled 100	Opt-Out/Ex		400 Base Bldg Design - 70%	Grocery															N/A	0.00	0.00	0.00	
Secondary 1																				0.10	0.02		
Cyc. Out. Cyc.																				0.10	0.02		
Conclusion Con																				0.08	0.02		
Conclusion Con																	-	-		0.02	0.00		
Cyc. Cut. Cyc.	Opt-Out/Ex	300	305 High Performance Building/Int Design - Tier 3 50% - Warehouse	Warehouse	2014	2053	0.01	0.00	0.01	0.01	51%	0.00	0.00	65%	0.08	0.08	0	0	1.06			0.01	0.00
Conclusion Con																				0.00	0.00		
Cyclude Cycl																				0.19	0.03		
Opt-Opt-Early Opt-Opt-Opt-Early Opt-Opt-Opt-Opt-Opt-Opt-Opt-Opt-Opt-Opt-																		1					
Spring S																				0.15	0.02		
Opt-Out-Fig 20 30 48 High Performance Buildinghor Design - Time 1 350% - School 2014 2053 0.00 0	Opt-Out/Ex																•	•		0.03	0.01		
Opt-Quille: A	Opt-Out/Ex																						
Cycl-Quife 100 100 Baine Bidg Design 15% 100 107 High Performance Buildingfirt Design - Tier 1 15% - Health 2014 2053 1.74 0.33 0.00 0.																				0.00	0.00		
CP-1-C			100 Base Bldg Design - 15%		2014	2053		0.33	0.00		0%	0.00	0.00	0%		N/A				1.74	0.33		
Cyt-Qui-Ex 207 Right Performance Buliding/Int Design - Time 2 30% - Health 2014 2053 0.7 0.16 0.42 0.45 0.00																	1	1		4.00	0.00		
Opt-OutEx SO 300 Baine Bidg Design - 50% Health 2014 2053 0.31 0.06 0.00																				1.39	0.26		
Opt-OutEx 400	Opt-Out/Ex	300	300 Base Bldg Design - 50%		2014						0%			0%	N/A	N/A				0.31	0.06		
Opt-OutEx 400																				0.03	0.01		
Opt-Out/Ex 100 108 High Performance BuildingInt Design - Tier 1 15% - Lodging 2014 2053 0.04 0.01 0.01 0.00																				0.03	0.01		
Opt-Out/Ex 200 200 Base Bildg Design - 30% Lodging 2014 2053 0.04 0.01 0.00 0.																				0.05	0.01		
Composition Composition Composition Coding Codi																				0.04	0.01		
Opt-Out/Ex 200 308 High Performance Building/Int Design - Tier 3 50% - Lodging Lodging 2014 2053 0.00 0.0	Opt-Out/Ex	200	208 High Performance Building/Int Design - Tier 2 30% - Lodging	Lodging	2014	2053	0.03	0.00	0.01	0.01	30%	0.00	0.00	39%	0.07	0.07	0	0	1.24			0.01	0.00
Chyclure 400 400 8ase Bidg Design - 70% 200 400 8ase Bidg Design - 70% 201 4053 0.00																				0.01	0.00		
Opt-Our/Ex 00 408 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodging Lodging 2014 2053 0.00 0.0																				0.00	0.00		
Opt-Qut/Ex 200 200 Base Bidg Design - 30% 200 200 Base Bidg Design - 50% 200 200 200 Base Bidg Design - 50% 200 200 200 Base Bidg Design - 50% 200	Opt-Out/Ex	400	408 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodging		2014	2053	0.00		0.00	0.00	71%	0.00	0.00		0.08		0	0	1.05			0.00	
Opt-Out/Ex 200 200 Base Bldg Design - 30% Data Centers Data Centers 2014 2053 7.07 1.23 0.00																				8.83	1.54		
Opt-Out/Ex 300 300 Base Bldg Design - 50%																	-	-		7.07	1.23		
Opt-Qut/Ex 400 400 Base Bidg Design - 70% - Data Centers Data Centers 2014 2053 0.79 0.10 0.80 0.80 50% 0.18 0.18 65% 0.01 0.01 0 0 8.62 0.80 0.18 0.00 0.00 0.00 0.00 0.00 0.00																							
Opt-Out/Ex 400 400 Base Bldg Design - 70%											- , -			-,-						1.59	0.28		
Opt-Out/Ex 100 100 Base Bidg Design - 15% Non-Jurisdictional Policy 2014 2053 0.38 0.08 0.00		400	400 Base Bldg Design - 70%					0.03	0.00	0.00	0%	0.00	0.00	0%		N/A				0.18	0.03		0.00
Opt-Out/Ex 100 110 High Performance Building/Int Design - Tier 1 15% - Non-Jurisdictional Non-Jurisdictional Non-Jurisdictional 2014 2053 0.32 0.06 0.06 0.06 15% 0.02 0.02 20% 0.06 0.06 0 0 1 1.44 0.00 0.00 0.00 0.00 0.00 0.0																				0.00	0.00		
Opt-Qut/Ex 200 200 Base Bidg Design - 30% Non-Jurisdictional 2014 2053 0.30 0.06 0.00 0.00 0.00 0.00 0.00 0.0																				0.38	0.08		
Opt-Out/Ex 300 300 Base Bidg Design - 50%	Opt-Out/Ex	200	200 Base Bldg Design - 30%	Non-Jurisdictional	2014	2053	0.30	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.30	0.06	0.00	0.00
Opt-Out/Ex 300 310 High Performance Building/Int Design - Tier 3 50% - Non-Jurisdictional Non-Jurisdictional 2014 2053 0.03 0.01 0.03 0.01 0.01 0.05 0.04 0.0 0.0 0.03 0.01 Opt-Out/Ex 400 400 Basse Bidg Design - 70% Non-Jurisdictional 2014 2053 0.01 0.00<																				0.07	0.01		
Opt-Out/Ex 400 400 Base Bidg Design - 70%														-,-						0.07	0.01		
Opt-Out/Ex 100 100 Base Bidg Design - 15% Misc 2014 2053 2.19 0.43 0.00 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A 2.19 0.43 0.00 0.00	Opt-Out/Ex		400 Base Bldg Design - 70%						0.00		0%		0.00		N/A				N/A	0.01	0.00		
					20		0.00	0.00		0.0.	, .		0.00							2.19	0.43		0.00
																				20	0. 10		

APPENDIX H

Base Avoided Costs

Commerc	ial Opt-Out/Ex	cempt/Nonjurisdictional New Construction																				
DSM ASS	YST ADDITIVE	SUPPLY ANALYSIS				Year 2	2014														SUPPLY	
Vintage	Existing								Total			Total		Marginal	Average	Marginal	Average	Total				/
				Measure	Measure	9			Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource				/
	Base M	easure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt	Number N	umber Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
Opt-Out/E	x 200	200 Base Bldg Design - 30%	Misc	2014	2053	1.75	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.75	0.34	0.00	0.00
Opt-Out/E	x 200	212 High Performance Building/Int Design - Tier 2 30% - Miscellaneous	Misc	2014	2053	1.22	0.21	0.53	0.53	30%	0.13	0.13	39%	0.07	0.07	0	0	1.23			0.53	0.13
Opt-Out/E	x 300	300 Base Bldg Design - 50%	Misc	2014	2053	0.39	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.39	0.08	0.00	0.00
Opt-Out/E	x 300	312 High Performance Building/Int Design - Tier 3 50% - Miscellaneous	Misc	2014	2053	0.19	0.03	0.20	0.20	51%	0.05	0.05	65%	0.07	0.07	0	0	1.17			0.20	0.05
Opt-Out/E	x 400	400 Base Bldg Design - 70%	Misc	2014	2053	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
Opt-Out/E	x 400	412 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Miscelland	Misc	2014	2053	0.01	0.00	0.03	0.03	71%	0.01	0.01	91%	0.08	0.08	0	0	1.04			0.03	0.01
VA	100	100 Base Bldg Design - 15%	Non-Jurisdictional	2014	2053	79.60	16.85	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	79.60	16.85	0.00	0.00
VA	100	110 High Performance Building/Int Design - Tier 1 15% - Non-Jurisdictional	Non-Jurisdictional	2014	2053	67.47	13.57	12.13	12.13	15%	3.29	3.29	20%	0.06	0.06	0	0	1.44			12.13	3.29
VA	200	200 Base Bldg Design - 30%	Non-Jurisdictional	2014	2053	63.68	13.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	63.68	13.48	0.00	0.00
VA	200	210 High Performance Building/Int Design - Tier 2 30% - Non-Jurisdictional	Non-Jurisdictional	2014	2053	44.28	8.22	19.40	19.40	30%	5.26	5.26	39%	0.04	0.04	0	0	2.02			19.40	5.26
VA	300	300 Base Bldg Design - 50%	Non-Jurisdictional	2014	2053	14.33	3.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.33	3.03	0.00	0.00
VA	300	310 High Performance Building/Int Design - Tier 3 50% - Non-Jurisdictional	Non-Jurisdictional	2014	2053	7.05	1.06	7.28	7.28	51%	1.97	1.97	65%	0.04	0.04	0	0	1.93			7.28	1.97
VA	400	400 Base Bldg Design - 70%	Non-Jurisdictional	2014	2053	1.59	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.59	0.34	0.00	0.00
VA	400	410 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Non-Juris	Non-Jurisdictional	2014	2053	0.46	0.03	1.13	1.13	71%	0.31	0.31	91%	0.05	0.05	0	0	1.72			1.13	0.31

APPENDIX H

Base Avoided Costs

	I Electric Existing Construction 'ST ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage	Existing		Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Base		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost	Cost	Cost	Cost Test	Base	Base MW	Economic	Economic
Sgmt Numb		Type Single Family	Year 2014	Year 2053	2,123.48	MW 3 1,261.52	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	GWH 2,123.48	1,261.52	0.00	0.00
	000 1024 Self Install Weatherization (CAC)	Single Family	2014	2053	2,099.82		23.66	23.66	1%	14.06	14.06	1%	0.01	0.01	0	0	6.06			23.66	14.06
		Single Family Single Family	2014 2014	2053 2053	2,087.47		12.34 12.10	36.01 48.11	2% 2%	7.33 7.19	21.39 28.58	2% 2%	0.04	0.02	0	0	2.20 1.75			12.34 12.10	7.33 7.19
		Single Family	2014	2053	2,073.16		2.22	50.32	2%	1.32	29.90	2%	0.08	0.03	0	0	1.75			2.22	1.32
	000 1004 Proper Refrigerant Charging and Air Flow (CAC)	Single Family	2014	2053	1,924.33		148.83	199.16	9%	88.42	118.32	9%	0.08	0.07	0	0	1.05			148.83	88.42
		Single Family Single Family	2014 2014	2053 2053	1,893.00		31.33 114.89	230.48 345.38	11% 16%	18.61 68.26	136.93 205.18	11% 16%	0.07 0.13	0.07	0	0	0.94 0.77			0.00	0.00
		Single Family	2014	2053	1,677.46		100.65	345.38 446.02	21%	59.79	264.97	21%	0.13	0.09	0	0	0.77			0.00	0.00
VA 10	000 1005 Proper Sizing and Quality Install (CAC)	Single Family	2014	2053	1,514.52	899.75	162.94	608.96	29%	96.80	361.78	29%	0.17	0.12	0	0	0.60			0.00	0.00
		Single Family	2014	2053	1,361.98		152.54	761.51	36%	90.62	452.40	36%	0.22	0.14	0	0	0.45			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	1,353.27		8.70 38.18	770.21 808.39	36% 38%	5.17 22.68	457.57 480.25	36% 38%	0.26 0.27	0.14 0.15	0	0	0.40			0.00	0.00
	000 1009 Ceiling R-0 to R-49 Insulation (CAC)	Single Family	2014	2053	1,314.53		0.55	808.95	38%	0.33	480.58	38%	3.00	0.15	5	Ö	0.03			0.00	0.00
		Single Family	2014	2053	1,254.71		59.82	868.77	41%	35.54	516.12	41%	0.33	0.16	1	0	0.25			0.00	0.00
		Single Family Single Family	2014	2053 2053	1,131.76		122.95 12.66	991.72 1.004.38	47% 47%	73.04 7.52	589.16 596.68	47% 47%	0.36 0.51	0.19	1	0	0.22			0.00	0.00
		Single Family	2014	2053	1,095.69		23.41	1,027.79	48%	13.91	610.59	48%	0.74	0.10	1	0	0.14			0.00	0.00
	000 1011 Ceiling R-11 to R-49 Insulation (CAC)	Single Family	2014	2053	1,094.69		1.00	1,028.79	48%	0.59	611.18	48%	3.60	0.21	6	0	0.03			0.00	0.00
		Single Family	2014	2053 2053	1,090.03		4.67 6.07	1,033.45 1.039.52	49% 49%	2.77 3.61	613.96 617.56	49% 49%	1.06	0.21	2	0	0.10			0.00	0.00
		Single Family Single Family	2014 2014	2053	1,083.96		5.27	1,039.52	49% 49%	3.61	617.56	49% 49%	1.26 1.30	0.22	2	0	0.08			0.00	0.00
VA 10		Single Family	2014	2053	1,060.37		18.31	1,063.11	50%	10.88	631.57	50%	1.34	0.24	2	ō	0.07			0.00	0.00
		Single Family	2014	2053	1,059.82		0.55	1,063.66	50%	0.33	631.90	50%	3.72	0.24	6	0	0.03			0.00	0.00
		Single Family Single Family	2014 2014	2053	1,032.07 997.22	613.13 592.43	27.75 34.85	1,091.41 1,126.26	51% 53%	16.49 20.70	648.39 669.09	51% 53%	1.68 1.73	0.28	3	0	0.06			0.00	0.00
		Single Family	2014	2053	995.17	591.21	2.05	1,128.31	53%	1.22	670.31	53%	2.48	0.33	4	1	0.03			0.00	0.00
	000 1007 AC Filter Changes (CAC)	Single Family	2014	2053	990.93	588.70	4.24	1,132.55	53%	2.52	672.83	53%	1.83	0.34	3	1	0.04			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	986.52 982.22	586.07 583.52	4.41 4.30	1,136.96 1,141.26	54% 54%	2.62 2.55	675.45 678.00	54% 54%	2.09 3.64	0.34	4 6	1	0.03			0.00	0.00
		Single Family	2014	2053	981.99	583.38	0.23	1,141.49	54%	0.14	678.14	54%	4.19	0.36	7	1	0.03			0.00	0.00
	100 1100 Base Split-System Air Conditioner - Early Replacement (11 SEI	Single Family	2014	2053	349.12	207.41	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	349.12	207.41	0.00	0.00
		Single Family	2014 2014	2053	346.27 340.44	205.72	2.85	2.85	1%	1.69	1.69	1%	0.01	0.01	0	0	8.55			2.85 5.84	1.69 3.47
	(,,	Single Family Single Family	2014	2053 2053	340.44	202.25	5.84 2.00	8.69 10.69	2% 3%	3.47 1.19	5.16 6.35	2% 3%	0.01 0.04	0.01 0.02	0	0	5.57 2.02			2.00	1.19
		Single Family	2014	2053	336.47	199.89	1.96	12.65	4%	1.17	7.51	4%	0.07	0.03	Ö	Ö	1.61			1.96	1.17
		Single Family	2014	2053	330.11	196.11	6.37	19.02	5%	3.78	11.30	5%	0.06	0.04	0	0	1.09			6.37	3.78
	 1102 Proper Refrigerant Charging and Air Flow (CAC early replacem 1106 Cool Roof (CAC early replacement) 	Single Family Single Family	2014 2014	2053 2053	302.78 271.17	179.88 161.09	27.32 31.62	46.34 77.96	13% 22%	16.23 18.78	27.53 46.31	13% 22%	0.09 0.14	0.07 0.10	0	0	0.94 0.70			0.00	0.00
		Single Family	2014	2053	221.49	131.58	49.68	127.64	37%	29.51	75.83	37%	0.17	0.10	0	0	0.58			0.00	0.00
		Single Family	2014	2053	196.79	116.91	24.70	152.34	44%	14.67	90.50	44%	0.23	0.14	0	0	0.44			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	195.53 190.01	116.16 112.88	1.26 5.52	153.59 159.11	44% 46%	0.75 3.28	91.25 94.52	44% 46%	0.32	0.14	1	0	0.33 0.31			0.00	0.00
		Single Family	2014	2053	182.51	108.43	7.50	166.61	48%	4.46	98.98	48%	0.37	0.16	1	0	0.29			0.00	0.00
	100 1107 Ceiling R-0 to R-49 Insulation (CAC early replacement)	Single Family	2014	2053	182.43	108.38	0.08	166.69	48%	0.05	99.03	48%	3.82	0.16	6	0	0.03			0.00	0.00
	 1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early re 1118 Duct Testing and Sealing (CAC early replacement) 	Single Family Single Family	2014 2014	2053 2053	179.74 178.06	106.78 105.78	2.70 1.68	169.39 171.06	49% 49%	1.60 1.00	100.63 101.63	49% 49%	0.45 0.52	0.16 0.17	1	0	0.23			0.00	0.00
	 1118 Duct Testing and Sealing (CAC early replacement) 1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early re 		2014	2053	169.96	100.78	8.10	171.06	51%	4.81	106.44	51%	0.52	0.17	1	0	0.20			0.00	0.00
	100 1124 Ceiling Fans (CAC early replacement)	Single Family	2014	2053	168.37	100.03	1.58	180.75	52%	0.94	107.38	52%	0.72	0.18	1	0	0.13			0.00	0.00
		Single Family	2014	2053	164.85	97.94	3.52	184.27	53%	2.09	109.47	53%	0.87	0.20	1	0	0.12			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	164.70 152.35	97.85 90.51	0.15 12.35	184.42 196.77	53% 56%	0.09 7.34	109.56 116.90	53% 56%	4.23 0.86	0.20	7 1	0	0.02			0.00	0.00
VA 11	100 1127 WINDOWS - Default With Sunscreen (CAC early replacement)		2014	2053	145.08	86.19	7.27	204.04	58%	4.32	121.22	58%	1.09	0.27	2	0	0.08			0.00	0.00
		Single Family	2014	2053	144.27	85.71	0.81	204.85	59%	0.48	121.70	59%	1.67	0.28	3	0	0.06			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	144.20 143.90	85.66 85.49	0.08	204.93 205.22	59% 59%	0.04 0.18	121.74 121.92	59% 59%	4.83 3.03	0.28 0.28	8 5	0	0.02			0.00	0.00
	1105 AC Filter Changes (CAC early replacement)	Single Family	2014	2053	143.90	85.49 85.12	0.61	205.22	59%	0.16	122.28	59%	2.23	0.28	4	0	0.03			0.00	0.00
	100 1104 AC Maintenance and/or tune-up (CAC early replacement)	Single Family	2014	2053	142.65	84.75	0.64	206.47	59%	0.38	122.66	59%	2.55	0.30	4	0	0.03			0.00	0.00
	 1101 14 SEER (12.15 EER) Split-System Air Conditioner w/ Quality I 1101 114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement) 	Single Family Single Family	2014 2014	2053 2053	138.99 138.96	82.57 82.55	3.66 0.03	210.13 210.16	60% 60%	2.17 0.02	124.84 124.86	60% 60%	3.37 5.23	0.35 0.35	6 9	1	0.02 0.02			0.00	0.00
		Single Family	2014	2053	1,802.58		0.03	0.00	60% 0%	0.02	0.00	60% 0%	5.23 N/A	0.35 N/A	N/A	1 N/A	0.02 N/A	1,802.58	1,070.88	0.00	0.00
VA 12	200 1219 Duct Insulation (HP cooling)	Single Family	2014	2053	1,787.87	1,062.14	14.71	14.71	1%	8.74	8.74	1%	0.01	0.01	0	0	8.75	,	,	14.71	8.74
	(Single Family	2014	2053	1,767.94		19.92	34.64	2%	11.84	20.58	2%	0.04	0.03	0	0	2.19			19.92	11.84
		Single Family Single Family	2014 2014	2053 2053	1,741.39		26.56 295.05	61.19 356.24	3% 20%	15.78 175.29	36.35 211.64	3% 20%	0.06 0.08	0.04	0	0	1.59 1.18			26.56 295.05	15.78 175.29
		Single Family	2014	2053	1,342.50		103.83	460.08	26%	61.68	273.32	26%	0.10	0.07	0	0	0.83			0.00	0.00
	200 1224 Door Weatherization (HP cooling)	Single Family	2014	2053	1,320.65		21.86	481.93	27%	12.98	286.31	27%	0.09	0.08	0	0	0.74			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	1,182.74 966.05	702.64 573.92	137.91 216.68	619.84 836.53	34% 46%	81.93 128.73	368.24 496.97	34% 46%	0.16 0.19	0.10	0	0	0.60			0.00	0.00
***		Single Family	2014	2053	872.22	518.17	93.84	930.36	52%	55.75	552.71	52%	0.19	0.12	0	0	0.35			0.00	0.00
VA 12	200 1214 Crawlspace insulation (HP cooling)	Single Family	2014	2053	866.64	514.85	5.58	935.94	52%	3.31	556.03	52%	0.36	0.14	1	0	0.29			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	841.94 808.61	500.18 480.38	24.70 33.33	960.64 993.97	53% 55%	14.67 19.80	570.70 590.50	53% 55%	0.38 0.42	0.15 0.16	1	0	0.28 0.25			0.00	0.00
		Single Family	2014	2053	808.61	480.38 479.93	0.76	993.97	55% 55%	0.45	590.50	55% 55%	1.95	0.16	3	0	0.25			0.00	0.00
12				_ 500	2200	0.00	20		2370	10	223.00	2370			-	-	2.00			2.00	

DNV GL H-1 1/5/2015

APPENDIX H

Base Avoided Costs

	Electric Existing Construction IT ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage	Existing		Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity		Total Resource				
Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	
VA 120		Type Single Family	Year 2014	Year 2053	800.31	MW 475.45	Savings 7.54	1,002.27	Savings 56%	Savings 4.48	MW 595.43	Savings 56%	\$/kWH 0.58	\$/kWH 0.16	\$/kW 1	\$/kW 0	0.17	GWH	MW	0.00	0.00
VA 120	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)		2014	2053	763.89	453.82	36.42	1,038.69	58%	21.64	617.07	58%	0.48	0.17	1	0	0.17			0.00	0.00
VA 120		Single Family Single Family	2014 2014	2053 2053	752.60 745.60	447.11 442.95	11.29 7.01	1,049.98	58% 59%	6.71 4.16	623.77 627.94	58% 59%	0.84 0.82	0.18 0.18	1	0	0.13 0.12			0.00	0.00
VA 120		Single Family	2014	2053	729.61	433.45	15.99	1,072.97	60%	9.50	637.43	60%	0.96	0.19	2	0	0.11			0.00	0.00
VA 120	3 3,	Single Family	2014	2053	728.13	432.57	1.48	1,074.45	60%	0.88	638.31	60%	2.16	0.20	4	0	0.05			0.00	0.00
VA 120 VA 120		Single Family Single Family	2014 2014	2053 2053	727.50 723.56	432.19 429.85	0.63 3.94	1,075.08 1,079.02	60% 60%	0.38 2.34	638.69 641.03	60% 60%	1.36 1.73	0.20 0.20	2	0	0.08			0.00	0.00
VA 120		Single Family	2014	2053	722.72	429.35	0.84	1,079.86	60%	0.50	641.53	60%	2.18	0.20	4	ō	0.05			0.00	0.00
VA 120 VA 120		Single Family Single Family	2014 2014	2053 2053	719.64 717.15	427.53 426.05	3.08 2.49	1,082.94	60% 60%	1.83 1.48	643.36 644.83	60% 60%	2.49 5.83	0.21	4 10	0	0.03			0.00	0.00
VA 120		Single Family	2014	2053	717.15	424.15	3.19	1,088.62	60%	1.40	646.73	60%	4.04	0.22	7	0	0.02			0.00	0.00
VA 130	1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	Single Family	2014	2053	274.13	162.86	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	274.13	162.86	0.00	0.00
VA 130 VA 130		Single Family Single Family	2014	2053 2053	271.89 268.86	161.53 159.73	2.24 3.03	2.24 5.27	1% 2%	1.33	1.33	1% 2%	0.01 0.04	0.01	0	0	7.54 1.89			2.24 3.03	1.33
VA 130			2014	2053	223.31	132.66	45.56	50.82	19%	27.06	30.19	19%	0.09	0.03	0	0	1.04			45.56	27.06
VA 130	1321 Programmable Thermostat (HP cooling Early Replacement)	Single Family	2014	2053	219.95	130.67	3.35	54.18	20%	1.99	32.19	20%	0.11	0.09	0	0	0.83			0.00	0.00
VA 130 VA 130		Single Family	2014 2014	2053 2053	215.79 200.30	128.20 118.99	4.16 15.49	58.34 73.83	21% 27%	2.47 9.20	34.66 43.86	21% 27%	0.09 0.12	0.09	0	0	0.80 0.70			0.00	0.00
VA 130		Single Family	2014	2053	179.38	106.57	20.92	94.75	35%	12.43	56.29	35%	0.18	0.11	0	0	0.52			0.00	0.00
VA 130		Single Family	2014	2053	146.52	87.04	32.86	127.61	47%	19.52	75.81	47%	0.22	0.14	0	0	0.43			0.00	0.00
VA 130 VA 130		r Single Family Single Family	2014 2014	2053 2053	132.29 131.44	78.59 78.09	14.23 0.84	141.84 142.69	52% 52%	8.46 0.50	84.27 84.77	52% 52%	0.34 0.42	0.16 0.16	1	0	0.30 0.25			0.00	0.00
VA 130			2014	2053	127.70	75.86	3.75	146.44	53%	2.23	86.99	53%	0.44	0.17	1	0	0.24			0.00	0.00
VA 130		Single Family	2014	2053	122.65	72.86	5.05	151.48	55%	3.00	89.99	55%	0.49	0.18	1	0	0.22			0.00	0.00
VA 130 VA 130		Single Family Single Family	2014 2014	2053 2053	122.54 121.39	72.80 72.12	0.11 1.14	151.60 152.74	55% 56%	0.07	90.06 90.74	55% 56%	2.27 0.68	0.18 0.19	4	0	0.05 0.15			0.00	0.00
VA 130			2014	2053	115.87	68.84	5.52	158.26	58%	3.28	94.02	58%	0.56	0.20	1	0	0.15			0.00	0.00
VA 130			2014	2053	114.16	67.82	1.71	159.98	58%	1.02	95.04	58%	0.97	0.21	2	0	0.11			0.00	0.00
VA 130 VA 130		Single Family Single Family	2014 2014	2053 2053	113.09 110.67	67.19 65.75	1.06 2.42	161.04 163.46	59% 60%	0.63	95.67 97.11	59% 60%	0.96 1.12	0.21 0.23	2	0	0.10 0.09			0.00	0.00
VA 130	1311 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement		2014	2053	110.44	65.61	0.22	163.69	60%	0.13	97.24	60%	2.52	0.23	4	0	0.04			0.00	0.00
VA 130			2014	2053	110.35	65.56	0.10	163.78	60%	0.06	97.30	60%	1.58	0.23	3	0	0.07			0.00	0.00
VA 130			2014 2014	2053 2053	109.75 109.62	65.20 65.12	0.60 0.13	164.38 164.51	60% 60%	0.35	97.66 97.73	60% 60%	2.01 2.54	0.24 0.24	3 4	0	0.05 0.04			0.00	0.00
VA 130		Single Family	2014	2053	109.16	64.85	0.47	164.98	60%	0.28	98.01	60%	2.90	0.25	5	Ö	0.02			0.00	0.00
VA 130			2014	2053 2053	108.78	64.62 64.34	0.38	165.35	60%	0.22	98.23 98.52	60% 60%	6.79	0.26	11 8	0	0.02			0.00	0.00
VA 130		Single Family Single Family	2014	2053	108.29 112.24	66.68	0.48	165.84 0.00	60% 0%	0.29	0.00	0%	4.70 N/A	0.27 N/A	N/A	N/A	0.01 N/A	112.24	66.68	0.00	0.00
VA 140	00 1413 Self Install Weatherization (RAC)	Single Family	2014	2053	110.99	65.94	1.25	1.25	1%	0.74	0.74	1%	0.03	0.03	0	0	2.83			1.25	0.74
VA 140		Single Family Single Family	2014 2014	2053 2053	109.18 97.78	64.86 58.09	1.81 11.40	3.06 14.46	3% 13%	1.07 6.77	1.82 8.59	3% 13%	0.14	0.10	0	0	0.48			0.00	0.00
VA 140		Single Family	2014	2053	79.87	47.45	17.91	32.37	29%	10.64	19.23	29%	0.24	0.26	0	0	0.33			0.00	0.00
VA 140	1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	Single Family	2014	2053	75.39	44.79	4.48	36.85	33%	2.66	21.89	33%	0.31	0.26	1	0	0.25			0.00	0.00
VA 140		Single Family Single Family	2014 2014	2053 2053	59.56 57.97	35.38 34.44	15.83 1.59	52.68 54.27	47% 48%	9.41 0.94	31.30 32.24	47% 48%	0.43 0.75	0.31 0.33	1	1	0.19 0.14			0.00	0.00
VA 140		Single Family	2014	2053	57.12	33.93	0.86	55.13	49%	0.54	32.75	49%	0.73	0.34	2	1	0.14			0.00	0.00
VA 140		Single Family	2014	2053	54.01	32.09	3.11	58.23	52%	1.85	34.59	52%	0.72	0.36	1	1	0.11			0.00	0.00
VA 140		Single Family Single Family	2014 2014	2053 2053	53.97 53.47	32.06 31.76	0.04 0.50	58.27 58.77	52% 52%	0.02	34.62 34.92	52% 52%	4.53 1.46	0.36 0.37	8 2	1	0.02 0.07			0.00	0.00
VA 140	00 1406 Ceiling R-11 to R-38 Insulaton (RAC)	Single Family	2014	2053	52.45	31.16	1.02	59.79	53%	0.60	35.52	53%	1.93	0.39	3	1	0.05			0.00	0.00
VA 140	00 1407 Ceiling R-11 to R-49 Insulation (RAC)	Single Family	2014	2053	52.36	31.11	0.09	59.88	53%	0.05	35.57	53%	4.67	0.40	8	1	0.02			0.00	0.00
VA 140		Single Family Single Family	2014 2014	2053 2053	52.14 49.65	30.97 29.50	0.23 2.49	60.10 62.59	54% 56%	0.13 1.48	35.71 37.18	54% 56%	2.58 2.03	0.41 0.47	4	1	0.04			0.00	0.00
VA 140	00 1408 Ceiling R-19 to R-38 Insulation (RAC)	Single Family	2014	2053	49.40	29.35	0.25	62.84	56%	0.15	37.34	56%	3.42	0.49	6	1	0.03			0.00	0.00
VA 140	1409 Ceiling R-19 to R-49 Insulation (RAC)	Single Family	2014	2053	49.35	29.32	0.05	62.89	56%	0.03	37.36	56%	4.96	0.49	8	1	0.02			0.00	0.00
VA 140 VA 150		Single Family Single Family	2014 2014	2053 2053	49.14 23.56	29.19 14.00	0.21	63.10 0.00	56% 0%	0.12	37.49 0.00	56% 0%	4.18 N/A	0.50 N/A	7 N/A	1 N/A	0.02 N/A	23.56	14.00	0.00	0.00
VA 150	1501 EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early		2014	2053	20.43	12.14	3.13	3.13	13%	1.86	1.86	13%	0.63	0.63	1	1	0.12			0.00	0.00
VA 160	1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	Single Family	2014	2053	25.36	15.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	25.36	15.07	0.00	0.00
VA 160 VA 170		a Single Family Single Family	2014 2014	2053 2053	21.52 1.754.83	12.79 3 900.13	3.84 0.00	3.84 0.00	15% 0%	2.28	2.28 0.00	15% 0%	0.18 N/A	0.18 N/A	0 N/A	0 N/A	0.48 N/A	1,754.83	900.13	0.00	0.00
VA 170	1701 ECM Furnace Fan (variable speed motor) - Cooling	Single Family	2014	2053	974.90	500.07	779.92	779.92	44%	400.06	400.06	44%	0.03	0.03	0	0	3.44			779.92	400.06
VA 200		Single Family	2014	2053	2,499.04		0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A		2,499.04	296.50	0.00	0.00
VA 200 VA 200		Single Family Single Family	2014 2014	2053 2053	2,478.64		20.40 27.62	20.40 48.02	1% 2%	2.42 3.28	2.42 5.70	1% 2%	0.01 0.02	0.01	0	0	9.24 2.49			20.40 27.62	2.42 3.28
VA 200	2019 Programmable Thermostat (HP heating)	Single Family	2014	2053	2,414.21	1 286.44	36.82	84.84	3%	4.37	10.07	3%	0.05	0.03	0	0	1.28			36.82	4.37
VA 200		Single Family	2014	2053	2,191.76		222.45	307.28	12%	26.39	36.46	12%	0.08	0.07	1	1	0.75			0.00	0.00
VA 200 VA 200		Single Family Single Family	2014 2014	2053 2053	2,170.07		21.69 13.85	328.97 342.83	13% 14%	2.57 1.64	39.03 40.68	13% 14%	0.08 0.12	0.07 0.07	1	1	0.65 0.55			0.00	0.00
VA 200	2006 Ceiling R-0 to R-38 Insulation (HP heating)	Single Family	2014	2053	2,094.77	7 248.54	61.45	404.27	16%	7.29	47.97	16%	0.13	0.08	1	1	0.53			0.00	0.00
VA 200 VA 200		Single Family	2014 2014	2053 2053	1,640.19		454.58 64.80	858.85 923.65	34% 37%	53.93 7.69	101.90 109.59	34% 37%	0.14 0.18	0.11 0.11	1 2	1	0.50 0.37			0.00	0.00
VA 200		Single Family Single Family	2014	2053	1,575.39		1.48	923.65 925.12	37% 37%	7.69 0.18	109.59	37%	0.18 0.85	0.11	7	1	0.37			0.00	0.00
. 200					.,																

APPENDIX H

Base Avoided Costs

	al Electric Existing Construction				Year	2014														SUPPLY	
Vintage	Existing		Measure	Measure		2014		Total	Percent		Total	Percent	Marginal			Average	Total Resource			001121	
Base		Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy	Capacity Cost	Capacity	Cost Test	Base	Base	Economic	
Sgmt Num		Type Single Family	Year 2014	2053	1.502.29	MW 9 178.24	Savings 71.62	996.75	Savings 40%	Savings 8.50	MW 118.26	Savings 40%	\$/kWH 0.21	\$/kWH 0.12	\$/kW	\$/kW	0.27	GWH	MW	0.00	0.00
	2000 2017 Duct Testing and Sealing (HP heating)	Single Family	2014	2053	1,488.27		14.03	1,010.77	40%	1.66	119.93	40%	0.26	0.12	2	1	0.25			0.00	0.00
	 2000 2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating) 2000 2008 Ceiling R-11 to R-38 Insulaton (HP heating) 	Single Family Single Family	2014 2014	2053 2053	1,466.96		21.31 31.45	1,032.08	41% 43%	2.53	122.45 126.19	41% 43%	0.38	0.13	3	1	0.18 0.16			0.00	0.00
VA 2	2000 2009 Ceiling R-11 to R-49 Insulation (HP heating)	Single Family	2014	2053	1,432.59	169.97	2.91	1,066.45	43%	0.35	126.53	43%	0.93	0.14	8	i	0.07			0.00	0.00
	2000 2014 Floor R-0 to R-19 Insulation-Batts (HP heating)	Single Family	2014 2014	2053	1,431.35		1.24	1,067.69	43%	0.15	126.68	43% 43%	0.58	0.14	5	1	0.12			0.00	0.00
	2000 2010 Ceiling R-19 to R-38 Insulation (HP heating) 2000 2011 Ceiling R-19 to R-49 Insulation (HP heating)	Single Family Single Family	2014	2053 2053	1,423.60		7.75 1.65	1,075.44	43% 43%	0.92	127.60 127.79	43%	0.74 0.94	0.15 0.15	6 8	1	0.09 0.07			0.00	0.00
	2000 2003 Ground Source Heat Pump with Desuperheater (HP heating)	Single Family	2014	2053	1,294.15		127.79	1,204.89	48%	15.16	142.96	48%	1.75	0.32	15	3	0.04			0.00	0.00
	2000 2005 Heat Pump Filter Replacement 2000 2004 Heat pump tune up	Single Family	2014 2014	2053 2053	1,288.64		5.51 5.74	1,210.40	48% 49%	0.65 0.68	143.61 144.29	48% 49%	1.18 1.90	0.32	10 16	3	0.04			0.00	0.00
VA 2	2000 2015 Wall Blow-in R-0 to R-13 Insulation (HP heating)	Single Family	2014	2053	1,278.47	7 151.69	4.44	1,220.57	49%	0.53	144.82	49%	2.77	0.34	23	3	0.02			0.00	0.00
	2100 2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSP 2100 2116 Duct Insulation (HP heating early replacement)	Single Family Single Family	2014 2014	2053 2053	420.83 417.39	49.93 49.52	0.00 3.43	0.00 3.43	0% 1%	0.00	0.00	0% 1%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.82	420.83	49.93	0.00 3.43	0.00
	2100 2110 Buck institution (HP heating early replacement) 2101 2121 Self Install Weatherization (HP heating early replacement)	Single Family	2014	2053	412.74	48.97	4.65	8.09	2%	0.55	0.96	2%	0.02	0.02	0	0	2.38			4.65	0.55
	2100 2119 Programmable Thermostat (HP heating early replacement)	Single Family	2014	2053	406.54	48.24	6.20	14.29	3%	0.74	1.69	3%	0.05	0.03	0	0	1.22			6.20	0.74
	 2100 2102 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early 2100 2122 Door Weatherization (HP heating early replacement) 	Single Family Single Family	2014 2014	2053 2053	369.08 365.25	43.79 43.34	37.46 3.83	51.75 55.57	12% 13%	4.44 0.45	6.14 6.59	12% 13%	0.09	0.07	1	1	0.72			0.00	0.00
	2100 2112 Crawlspace insulation (HP heating early replacement)	Single Family	2014	2053	362.93	43.06	2.33	57.90	14%	0.28	6.87	14%	0.13	0.07	1	1	0.52			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	352.58 276.07	41.83 32.76	10.34 76.51	68.25 144.76	16% 34%	1.23 9.08	8.10 17.18	16% 34%	0.13 0.14	0.08	1	1	0.50			0.00	0.00
	2100 2118 Heat Recovery Ventilators (HP heating early replacement) 2100 2113 Basement insulation R-13 (HP heating early replacement)	Single Family	2014	2053	265.18	31.46	10.90	155.65	37%	1.29	18.47	37%	0.14	0.11	2	1	0.46			0.00	0.00
	2100 2107 Ceiling R-0 to R-49 Insulation (HP heating early replacement)	Single Family	2014	2053	264.93	31.43	0.25	155.90	37%	0.03	18.50	37%	0.89	0.12	8	1	0.08			0.00	0.00
	 2100 2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating e 2100 2117 Duct Testing and Sealing (HP heating early replacement) 	Single Family Single Family	2014 2014	2053 2053	252.87 250.51	30.00 29.72	12.06 2.36	167.96 170.32	40% 40%	1.43 0.28	19.93 20.21	40% 40%	0.22 0.28	0.13 0.13	2	1	0.26 0.24			0.00	0.00
	2100 2123 WINDOWS - Double-Glazed Clear to Energy Star (HP heating		2014	2053	246.92	29.30	3.59	173.91	41%	0.43	20.63	41%	0.39	0.14	3	1	0.17			0.00	0.00
	2100 2108 Ceiling R-11 to R-38 Insulaton (HP heating early replacement) 2100 2109 Ceiling R-11 to R-49 Insulation (HP heating early replacement)		2014	2053 2053	241.63 241.14	28.67 28.61	5.29 0.49	179.20 179.69	43% 43%	0.63	21.26	43% 43%	0.43	0.14	4	1	0.16			0.00	0.00
	 2100 2109 Ceiling R-11 to R-49 Insulation (HP heating early replacement) 2100 2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replacement) 		2014 2014	2053	241.14	28.61	0.49	179.69	43% 43%	0.06	21.32	43% 43%	0.98	0.15	8 5	1	0.07 0.11			0.00	0.00
VA 2	2100 2110 Ceiling R-19 to R-38 Insulation (HP heating early replacement)	Single Family	2014	2053	239.62	28.43	1.30	181.20	43%	0.15	21.50	43%	0.78	0.15	7	1	0.09			0.00	0.00
	 2110 2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement) 2100 2103 Ground Source Heat Pump with Desuperheater (HP heating early 		2014	2053 2053	239.35 217.84	28.40 25.85	0.28 21.51	181.48 202.99	43% 48%	0.03 2.55	21.53 24.08	43% 48%	0.98 1.83	0.15	8 15	1	0.07			0.00	0.00
	 2100 2103 Ground Source Heat Pump with Desuperheater (HP heating ear 2100 2105 Heat Pump Filter Replacement (heating) 	Single Family	2014	2053	217.84	25.85	0.93	202.99	48% 48%	0.11	24.08	48% 48%	1.83	0.33	10	3	0.03			0.00	0.00
	2100 2104 Heat pump tune up (heating)	Single Family	2014	2053	215.94	25.62	0.97	204.89	49%	0.11	24.31	49%	2.00	0.34	17	3	0.03			0.00	0.00
	 2100 2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacem 2200 2200 Base Resistance Space Heating (Primary) 	Single Family Single Family	2014 2014	2053 2053	215.20 1,220.36	25.53 144.79	0.75 0.00	205.63 0.00	49% 0%	0.09	24.40	49% 0%	2.91 N/A	0.35 N/A	24 N/A	3 N/A	0.02 N/A	1,220.36	144.79	0.00	0.00
	2200 Base Resistance Space Heating (Filmary) 2200 2201 Air Source Heat Pump (resistance heating)	Single Family	2014	2053	972.08	115.34	248.28	248.28	20%	29.46	29.46	20%	0.01	0.01	0	0	4.49	1,220.00	144.75	248.28	29.46
	2200 2216 Self Install Weatherization 2200 2214 Programmable Thermostat (resistance heating)	Single Family	2014	2053	961.25	114.05	10.83	259.11	21%	1.29	30.74	21%	0.02	0.01	0	0	2.34			10.83	1.29
	2200 2214 Programmable Thermostat (resistance heating) 2200 2217 Door Weatherization (resistance heating)	Single Family Single Family	2014 2014	2053 2053	946.81 930.71	112.34 110.43	14.44 16.10	273.55 289.65	22% 24%	1.71 1.91	32.46 34.37	22% 24%	0.04	0.02	0	0	1.65 1.15			14.44 16.10	1.71 1.91
	2200 2203 Ceiling R-0 to R-38 Insulation (resistance heating)	Single Family	2014	2053	902.03	107.02	28.68	318.33	26%	3.40	37.77	26%	0.11	0.03	1	ō	0.59			0.00	0.00
	2200 2213 Heat Recovery Ventilators (resistance heating) 2200 2209 Crawlspace insulation (resistance heating)	Single Family Single Family	2014 2014	2053 2053	706.29 702.14	83.80 83.31	195.75 4.14	514.07 518.22	42% 42%	23.22	60.99 61.49	42% 42%	0.13 0.17	0.07	1	1	0.52 0.39			0.00	0.00
	2200 2210 Basement insulation R-13 (resistance heating)	Single Family	2014	2053	659.41	78.24	42.74	560.95	46%	5.07	66.56	46%	0.17	0.07	1	1	0.38			0.00	0.00
	2200 2204 Ceiling R-0 to R-49 Insulation (resistance heating)	Single Family	2014	2053	658.88	78.17	0.53	561.48	46%	0.06	66.62	46%	0.99	0.08	8	1	0.07			0.00	0.00
	 2200 2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance he 2200 2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance h 		2014 2014	2053 2053	628.90 618.62	74.62 73.40	29.98 10.28	591.46 601.74	48% 49%	3.56 1.22	70.18 71.40	48% 49%	0.21 0.33	0.08	2	1	0.27 0.21			0.00	0.00
VA 2	2200 2205 Ceiling R-11 to R-38 Insulaton (resistance heating)	Single Family	2014	2053	604.24	71.69	14.38	616.13	50%	1.71	73.10	50%	0.38	0.09	3	1	0.18			0.00	0.00
	2200 2211 Floor R-0 to R-19 Insulation-Batts (resistance heating) 2200 2206 Ceiling R-11 to R-49 Insulation (resistance heating)	Single Family	2014 2014	2053 2053	603.50 602.45	71.60 71.48	0.74 1.05	616.86 617.91	51% 51%	0.09	73.19 73.31	51% 51%	0.41	0.09	3 9	1	0.17 0.06			0.00	0.00
	2200 2206 Ceiling R-11 to R-49 Insulation (resistance heating) 2200 2207 Ceiling R-19 to R-38 Insulation (resistance heating)	Single Family Single Family	2014	2053	598.72	71.48	3.74	621.65	51%	0.12	73.76	51%	1.08 0.64	0.10	5	1	0.06			0.00	0.00
VA 2	2200 2208 Ceiling R-19 to R-49 Insulation (resistance heating)	Single Family	2014	2053	598.12	70.97	0.59	622.24	51%	0.07	73.83	51%	1.09	0.10	9	1	0.06			0.00	0.00
	 2200 2202 Ground Source Heat Pump with Desuperheater (resistance hea 2200 2212 Wall Blow-in R-0 to R-13 Insulation (resistance heating) 	Single Family Single Family	2014 2014	2053 2053	593.20 590.35	70.38 70.04	4.92 2.85	627.16 630.01	51% 52%	0.58	74.41 74.75	51% 52%	21.03 1.80	0.26 0.27	177 15	2	0.00 0.04			0.00	0.00
VA 3	3030 3030 Base Halogen Lighting - 0.5 hrs/day 2020	Single Family	2020	2053	183.04	20.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	183.04	20.49	0.00	0.00
	3030 3032 LEDs (base Halogen 0.5 hrs/day) 2020	Single Family	2020	2053	58.50	6.55	124.54	124.54	68%	13.94	13.94	68%	0.04	0.04	0	0	2.15	754 77	04.17	124.54	13.94
	3130 3130 Base Halogen Lighting - 2.5 hrs/day 2020 3130 3132 LEDs (base Halogen 2.5 hrs/day) 2020	Single Family Single Family	2020 2020	2053 2053	751.77 196.96	84.17 22.05	0.00 554.81	0.00 554.81	0% 74%	0.00 62.12	0.00 62.12	0% 74%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 11.68	751.77	84.17	0.00 554.81	0.00 62.12
VA 3	3230 3230 Base Halogen Lighting - 6 hrs/day 2020	Single Family	2020	2053	496.82	55.62	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	496.82	55.62	0.00	0.00
	3230 3232 LEDs (base Halogen 6 hrs/day) 2020 3330 3330 Base CFL Lighting - 0.5 hrs/day 2020	Single Family Single Family	2020 2020	2053 2053	158.78 35.20	17.78 3.94	338.04 0.00	338.04 0.00	68% 0%	37.85 0.00	37.85 0.00	68% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	15.99 N/A	35.20	3.94	338.04 0.00	37.85 0.00
	3330 3330 Base CFL Lighting - 0.5 hrs/day 2020 3330 3331 LEDs (base CFL 0.5 hrs/day) 2020	Single Family	2020	2053	25.69	2.88	9.50	9.50	27%	1.06	1.06	27%	0.21	0.21	N/A 2	N/A 2	0.37	35.20	3.94	0.00	0.00
VA 3	3430 3430 Base CFL Lighting - 2.5 hrs/day 2020	Single Family	2020	2053	144.30	16.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	144.30	16.16	0.00	0.00
	3431 LEDs (base CFL 2.5 hrs/day) 2020 3530 3530 Base CFL Lighting - 6 hrs/day 2020	Single Family Single Family	2020 2020	2053 2053	105.34 95.03	11.79 10.64	38.96 0.00	38.96 0.00	27% 0%	4.36 0.00	4.36 0.00	27% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	1.86 N/A	95.03	10.64	38.96 0.00	4.36 0.00
VA 3	3530 3531 LEDs (base CFL 6 hrs/day) 2020	Single Family	2020	2053	69.37	7.77	25.66	25.66	27%	2.87	2.87	27%	0.02	0.02	0	0	2.78			25.66	2.87
	3630 3630 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	Single Family	2020	2053	112.88	12.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	112.88	12.64	0.00	0.00
	3630 3632 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020 3730 3730 Base Halogen (Specialty) Lighting - 2.5 hrs/day 2020	Single Family Single Family	2020 2020	2053 2053	44.61 467.66	4.99 52.36	68.27 0.00	68.27 0.00	60% 0%	7.64 0.00	7.64 0.00	60% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	6.49 N/A	467.66	52.36	68.27 0.00	7.64 0.00
VA 3	3730 3732 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family	2020	2053	184.82	20.69	282.84	282.84	60%	31.67	31.67	60%	0.00	0.00	0	0	32.45			282.84	31.67
	3830 3830 Base Halogen (Specialty) Lighting - 6 hrs/day 2020 3830 3832 LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	2020	2053 2053	309.62 122.36	34.66 13.70	0.00 187.26	0.00	0% 60%	0.00 20.97	0.00 20.97	0% 60%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 48.19	309.62	34.66	0.00 187.26	0.00 20.97
	3830 3832 LEDs (base Halogen (Specialty) 6 hrs/day) 2020 3900 3900 Base Fluorescent Fixture 1.8 hrs/day	Single Family Single Family	2020	2053	777.81	87.08	0.00	187.26 0.00	0%	0.00	0.00	0%	0.00 N/A	0.00 N/A	N/A	N/A	48.19 N/A	777.81	87.08	0.00	0.00
VA 3	3900 3902 ROB 2L4'T8, 1EB	Single Family	2014	2053	567.97	63.59	209.84	209.84	27%	23.49	23.49	27%	0.04	0.04	0	0	2.16			209.84	23.49

APPENDIX H

Base Avoided Costs

Part	SUPPLY														2014	Year				esidential Electric Existing Construction SM ASSYST ADDITIVE SUPPLY ANALYSIS
Sept Part									Percent			Percent					Measure	Measure		intage Existing
March Control Contro								Cost												
Vis. 100 4100 4100 1000 1	60.73 0.00											0%							Single Family	A 4000 4000 Base Refrigerator
1.00	156.08 22.80 0.00	140.69 22.80	140																	
Value 100 400	0.00																		Single Family	A 4100 4101 Refrigerator - Early Replacement (Energy Star)
No. 400	100.30 0.00 459.50	318.86 100.30	618																	
Vis. 4000	67.61 0.00	117.14 67.61	417	N/A	N/A	N/A	N/A	N/A	0%	0.00	0.00	0%	0.00	0.00	67.61	417.14	2053	2014	Single Family	A 4500 4500 Base Freezer
Vis. 400 401 Freezes-Esh Replacement (Felley) Sample Sample Family 2014 203 27.07 65.02 62.08 64.0 63.01 63.08 64.00 60.00	36.77 16.47 0.00	104.06 16.47	10																	
Vis. 1970	56.26	104.00 10.47	104																	
Solid Solid Solid Solid Solid Emmin Solid Soli		32.02 5.07	32																,	
VA	15.85 339.93 0.00	760.04 339.93	2.7€																	
No.	84.80		-,	3.70	0	0	0.02	0.02	3%	10.44	10.44	3%	84.80	84.80	329.49	2,675.24	2053	2014	Single Family	A 5000 5006 Pipe Wrap
No.	9.36 12.66				-	-													,	
No.	1.13																			
VA	2.98																			
VA	79.18 96.60																			
VA	52.41					-										2,420.92			Single Family	A 5000 5014 Faucent Aerators
VA	141.00 0.00					-														
VA 5000 5015 Energy Start Enhances (EF-0.72) 5100 5101 5101 5100 5101	0.00																			
VA 5100 51	0.00																			
Na 5100 5101 1491 Name Planter Fleinery State - Early Registeration 5006 Baster Chinewsharer ((RF-L6) 5006 Baster Chinewsharer ((RF-L6) 5106	0.00 59.99 0.00	187.07 59.99	48"																	
5500 5500 1500	0.00			0.94	1	1	0.07	0.07	14%	8.56	8.56	14%	69.53	69.53	51.42	417.53	2053	2014	Single Family	A 5100 5101 Heat Pump Water Heater - Energy Star - Early Replacement
5600 5600	13.46 0.00 0.00	74.50 13.46	74			N/A														
NA 5600 5602 High Efficiency CD (EF-3.01 w/moisture sensor) Single Family 2014 2053 340.98 624.92 87.24 430.98 624.92 627.65 63.0 0.05 0.0		,055.90 178.70	1,05			N/A														
NA 5700 5700 5700 5800 5800 5800 5800 5800 5800 5900 5701 5800 5701 5800 5701 5800 5701 5800 5701 5800 5701 5800 5701 5800 5701 5800 5701 5800 5701 5800 5800 5701 5800 5701 5800 5800 5701 5800 5800 5701 5800 5800 5701 5800 5800 5701 5800 58	193.94															861.96				A 5600 5602 High Efficiency CD (EF=3.01 w/moisture sensor)
VA	0.00 42.02 0.00	256.25 42.02	250																	
NA	0.00																		,	
MA		278.12 33.07	278						- , .			-,-								
NA 7000 7000 Fase Plasma TV Single Family 2014 2053 123.92 11.88 11.80 1	201.08																			
VA 7000 7002 Plug Load Controls - Smart Power Strip (base plasma TV) Single Family 2014 2053 17.74 20.94 12.74 9% 0.01 1.84 9% 4.08 0.31 28 2 0.01		135.72 19.58	135																Single Family	A 7000 7000 Base Plasma TV
VA 7100 7100 Base LCD TV Single Family 2014 2053 317.27 45.78 0.00	11.80 0.00				-	-														
VA 7100 7102 Plug Load Controls - Smart Power Strip (base LCD TV Single Family 2014 2053 303.11 14.88 0.00		317.27 45.78	317																	
VA 7200 7200 Base CRT TV 7200 7200 Base CRT TV 7200 7202 Plug Load Controls - Smart Power Strip (base CRT TV) Single Family 2014 2053 97.12 14.01 5.99 5.99 6% 0.08 0.08 0.86 6% 1.20 1.20 1.20 8 8 8 0.04 1.20	109.45																			
VA 7200 7202 Plug Load Controls - Smart Power Strip (base CRT TV) Single Family 2014 2053 389.53 56.20 0.00	0.00 14.88 0.00	103.11 14.88	10:																	
VA 7400 7400 Base DVP Player Single Family 2014 2053 47.21 6.81 0.00 0.	0.00			0.04		8	1.20	1.20								97.12	2053	2014		A 7200 7202 Plug Load Controls - Smart Power Strip (base CRT TV)
VA 7400 7401 Energy Star DVD Player Single Family 2014 2053 2.24 24.96 24.96 53% 3.60 3.60 3.60 53% 0.01 0.01 0 0 3.68 3.60 7500 7500 Playe Load Controls - Smart Power Strip (base DVD player) Single Family 2014 2053 2.24 24.96																				
VA 7500 7500 Base Desktop PC Single Family 2014 2053 423.8 55.78 0.00 0.0	24.96	47.21 0.01	47.																	
VA 7500 7501 Energy Star Desktop PC Single Family 2014 2053 373.57 49.21 49.81 49.81 12% 6.56 6.56 6.56 6.56 12% 0.00 0.	0.00							0.74				95%								A 7400 7402 Plug Load Controls - Smart Power Strip (base DVD player)
VA 7500 7502 Plug Load Controls - Smart Power Strip (base Desktop PC) Single Family 2014 2033 288.77 35.41 104.80 154.61 37% 13.81 20.37 37% 0.08 0.06 1 0 0.62 VA 7600 7600 Ease Laptop PC Single Family 2014 2053 75.86 9.99 0.00	55.78 0.00 49.81	123.38 55.78	423																	
VA 7600 7601 Energy Start Laptop PC Single Family 2014 2053 63.79 8.40 12.07 16% 1.59 1.69 1.69 1.69 0.03 0.03 0.0 0 2.05 99.00 900 9000 Base Miscellaneous Single Family 2014 2053 929.00 296.60 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A N/A 99.00 99.00 Base Miscellaneous Single Family 2014 2053 555.76 74.53 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 N/A N/A N/A N/A N/A N/A 555.76 7 74.53 0.00	0.00			0.62	ō	1	0.06	0.08	37%	20.37	13.81	37%	154.61	104.80	35.41	268.77	2053	2014	Single Family	A 7500 7502 Plug Load Controls - Smart Power Strip (base Desktop PC)
VA 8000 8000 Base Cooking Single Family 2014 2053 929.00 296.60 0.00 <	9.99 0.00 12.07	75.86 9.99	75																	
VA 9000 9000 Base Miscelfaneous Single Family 2014 2053 56.76 74.53 0.00		929.00 296.60	929																	
VA 9900 9901 Indirect Feedback Single Family 2014 2053 24,708,94 6,118,50 372,52 372,52 372,52 1% 92,24 92,24 92,24 92,4 92,4 92,4 92,4 92,4 92,4 92,4 92,4 92,4 92,4 92,4 92,4 92,4 92,4 92,6 92,0 92	74.53 0.00	65.76 74.53	565	N/A	N/A	N/A	N/A	N/A	0%	0.00	0.00	0%	0.00	0.00	74.53	565.76	2053	2014	Single Family	A 9000 9000 Base Miscellaneous
VA 9900 9902 Direct Feedback Single Family 2014 2053 23,544,13 5,830,07 1,164,81 1,573,33 6% 28,44 380,88 6% 0.06 0.0 0 0 0,93 157.52 95 VA 1000 1024 Self Install Weatherization (CAC) Multi-Family 2014 2053 155.02 92.09 2.51 2.51 2.51 2.51 1.49 2.9 0.02 0 0 0 4.09 VA 1000 1025 Door Weatherization (CAC) Multi-Family 2014 2053 145.35 87.69 2.51 2.51 2.51 2.9 1.49 2.9 0.02 0.0 0 0 0 4.09 VA 1000 1025 Door Weatherization (CAC) Multi-Family 2014 2053 146.36 86.95 7.51 10.02 6% 4.46 5.95 6% 0.02 0 0 0 0 9.92 VA 1000 1025 Door Weatherization (CAC)	210.75 0.00 372.52	,081.46 6,210.7	25,08																	
VA 1000 1024 Self Install Weatherization (CAC) Multi-Family 2014 2053 15.50.2 92.09 2.51 2.51 2.9 1.49 1.49 2.9 0.02 0.0 0 4.09 VA 1000 1025 Door Weatherization (CAC) Multi-Family 2014 2053 147.51 87.63 7.51 10.02 6% 4.46 5.95 6% 0.07 0.06 0 0 0.92 VA 1000 1022 Programmable Thermostat (CAC) Multi-Family 2014 2053 146.36 86.95 1.15 11.16 7% 0.68 6.63 7% 0.12 0.07 0 0 0.76	0.00			0.93	0	0	0.05	0.06	6%	380.68	288.44	6%	1,537.33	1,164.81	5,830.07	23,544.13	2053	2014	,	A 9900 9902 Direct Feedback
VA 1000 1025 Door Weatherization (CAC) Multi-Family 2014 2053 147.51 87.63 7.51 10.02 6% 4.46 5.95 6% 0.07 0.06 0 0 0.92 VA 1000 1022 Programmable Thermostat (CAC) Multi-Family 2014 2053 146.36 86.95 1.15 11.16 7% 0.68 6.63 7% 0.12 0.07 0 0 0.76		157.52 93.58	157																	
VA 1000 1022 Programmable Thermostat (CAC) Multi-Family 2014 2053 146.36 86.95 1.15 11.16 7% 0.68 6.63 7% 0.12 0.07 0 0 0.76	2.51 0.00																			
VA 1000 1004 Proper Refrigerant Charging and Air Flow (CAC) Multi-Family 2014 2053 135.85 80.71 10.51 21.67 14% 6.24 12.87 14% 0.12 0.09 0 0 0.68	0.00			0.76	ō	Ō	0.07	0.12	7%	6.63	0.68	7%	11.16	1.15	86.95	146.36	2053	2014	Multi-Family	A 1000 1022 Programmable Thermostat (CAC)
VA 1000 1019 Duct Insulation (CAC) Multi-Family 2014 2053 135.58 80.54 0.28 21.95 14% 0.16 13.04 14% 0.18 0.09 0 0 0.58	0.00					-														
VA 1000 1012 Eutern Duck Indicification (CAC) Multi-Family 2014 2053 135.56 80.54 0.28 21.99 14% 0.16 13.04 14% 0.19 0.10 0.9 0.058 0.58 0.59 22.73 14% 0.47 13.51 14% 0.19 0.10 0 0 0.56	0.00																			
VA 1000 1011 14 SEER (12.15 EER) Split-System Air Conditioner (CAC) Multi-Family 2014 2053 126.15 74.95 8.64 31.37 20% 5.13 18.64 20% 0.20 0.13 0 0 0.50	0.00					-														A 1000 1001 14 SEER (12.15 EER) Split-System Air Conditioner (CAC)
VA 1000 1002:15 SEER (12.72 EER) Split-System Air Conditioner (CAC) Multi-Family 2014 2053 118.61 70.47 7.54 38.91 25% 4.48 23.12 25% 0.24 0.15 0 0 0.42 VA 1000 1003:17 SEER (12.82 EER) Split-System Air Conditioner (CAC) Multi-Family 2014 2053 106.03 62.99 12.55 1.149 33% 7.48 30.59 33% 0.31 0.19 1 0 0.32 20 20 20 20 20 20 20 20 20 20 20 20 20	0.00				-	0 1														
VA 1000 1014 Crawlspace insulation (CAC) Multi-Family 2014 2053 105.66 62.77 0.37 51.87 33% 0.22 30.81 33% 0.35 0.19 1 0 0.30	0.00			0.30	0	1	0.19	0.35	33%	30.81	0.22	33%	51.87	0.37	62.77	105.66	2053	2014	Multi-Family	A 1000 1014 Crawlspace insulation (CAC)
VA 1000 1026 Ceiling Fans (CAC) Multi-Family 2014 2053 100.02 59.42 5.64 57.50 37% 3.35 34.16 37% 0.40 0.21 1 0 0.24 VA 1000 1005 Proper Sizing and Quality Install (CAC) Multi-Family 2014 2053 90.31 53.65 9.72 67.22 43% 5.77 39.93 43% 0.57 0.26 1 0 0.18	0.00					1														
VA 1000 1023 Comprehensive Shell Air Sealing and Quanty Instant (I/A) Multi-Family 2014 2053 86.20 51.21 4.11 71.33 45% 2.44 42.37 45% 0.53 0.28 1 0 0.15	0.00					1														

APPENDIX H

Base Avoided Costs

Second S		lectric Existing Construction ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
The column Part P				Massura	Measure					Percent			Percent									
100 100				Start	End				Savings	GWH		Savings	MW	Cost	Cost	Cost	Cost	Cost Test				
Mathematics																\$/KW	\$/KW		GWH	MW		0.00
1.00 1.00																1	1					0.00
100 100																						0.00
100 100	VA 100	0 1029 WINDOWS - Default With Sunscreen (CAC)	Multi-Family	2014	2053	69.95	41.55	5.20	87.58	56%	3.09	52.03	56%	1.08	0.40	2	1	0.08			0.00	0.00
1969 1971 Veral Resume Front Service 1960 1971 Veral Resume Front Service 1960 Veral Resume Fro																	1					
100 100																	1					0.00
1	VA 100	0 1028 Window Film (CAC)	,	2014	2053	62.19	36.95	3.90	95.33	61%	2.32	56.64	61%	1.93	0.53		1	0.04			0.00	0.00
Mathematics																	1					
100 100																	1					0.00
Math																	1					0.00
May 100 100 A. C. F. March Enger (C. C. C																	1					
No. 100 110	VA 100	0 1007 AC Filter Changes (CAC)					34.32			63%							1					0.00
Main 110				20																		0.00
Main Fig. 1971																			47.64	28.30		
Vis. 100 1102 Degarmanic Thermostic (CAC carly registerment) Multi-Family 2014 2013 2019	VA 110	0 1117 Duct Insulation (CAC early replacement)			2053	46.46	27.60		1.19	2%			2%	0.02	0.02			4.56				0.23
Vis. 100 1162 Project Refrightent Changer and Air Prov (ChC early registenered) Mail-Family 2014 2053 38,09 20,10 7.0 50 50 1.14 50 50 50 50 50 50 50 5																						1.31
Vis. 100																						
Vis. 100	VA 110	0 1119 Return Duct Modification (CAC early replacement)		2014	2053	39.85	23.67	0.23	7.79	16%	0.14	4.63	16%	0.11	0.06	0	0	0.94			0.00	0.00
Vis. 100																						0.00
Vis. 100 1128 Wild-Droys - Double-Clasars for Early Start (Clock early Multi-Firming) 2014 2053 227.68 16.45 0.71 19.96 2.47 0.02 2.11 0.0 0.27 0.00 0																	-					
Vis. 100 118 Dut Teating and Sauling (CAC early replacement) Multi-Family 2014 2033 2231 1.44 1.05 1.94 1.05	VA 110	0 1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early remainded on the control of th	Multi-Family	2014	2053	27.68	16.45	0.71	19.96	42%	0.42	11.86	42%	0.37	0.15	1		0.29			0.00	0.00
Vis. 100 121 Comprehensive Septial Afficiation; Inc. Conf. or physical part of the ph																1	-					0.00
Vis. 100 110																1						0.00
Vis. 100 1113 Basement insulation R-13 (CAC early replacement)		0 1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	Multi-Family		2053	20.74		1.89	26.90	56%	1.12		56%	0.50	0.22			0.21			0.00	0.00
Vis. 100 1124 Colling-Famic (CAC cardy replacement)																						
Vis. 1100			,																			0.00
Vis. 1100 1115 Wall Blow-in R-O to R-13 Insulation (CAC early replacement) Mulf-Family 2014 2053 15.54 11.01 0.17 29.10 61% 0.10 17.30 61% 0.52 0.28 3 0 0.07 0.00	VA 110	0 1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Multi-Family	2014	2053			0.30	27.99	59%	0.18	16.63				_	-				0.00	0.00
VA																						0.00
VA 1100 1110 Celling F-19 in R-38 Insulation (CAC early replacement) Multi-Family 2014 2053 17.64 10.48 0.03 3.00 63% 0.02 17.22 63% 2.36 0.32 4 1 0.04 0.00		The translet in the text to modification (one carry replacement)		20																		0.00
VA 1100 1111 Calling R-19 to R-49 Insulation (CAC early replacement) Multi-Family 2014 2053 17.64 10.48 0.00 30.00 6.75 0.00 17.82 65% 6.78 0.32 11 1 0.02 0.00 0.0																-	1					0.00
VA 1100 1101 14 SEER (12/15 EER) Spill-System Air Conditioner w Countilly Multi-Family 2014 2053 16.74 9.95 9.89 0.90 30.90 65% 0.53 13.86 66% 2.57 0.39 4 1 0.03 0.00																	1					
NA 1100 1105 AC Filter Changes (CAC early replacement)																	1					0.00
VA 1100 1104 AC Maintenance and/or tune-up (CAC early replacement) Multi-Family 2014 2053 16.55 9.83 0.05 0.00 0.																	1					0.00
VA 1200 1200 Base Heat Pump Cooling (13 SEER) Multi-Family 2014 2053 245.48 145.83 0.00																						
VA 1200 1223 Self Install Weatherization (I-IP cooling)																			245.48	145.83		0.00
VA 1200 1224 Door Weatherization (HP cooling) Multi-Family 2014 2053 27.99 135.45 11.61 17.49 7% 6.90 10.39 7% 0.05 0.05 0 0 1.29 11.61 6.90 1.20																						1.19
VA 1200 1202 Heat pump ugrgrade to (16+ SEER, 8.7+ HSPF) (HP cooling) Multi-Family 2014 2053 189.36 112.50 38.63 56.12 23% 22.95 33.34 23% 0.08 0.07 0 0 1.14 38.63 22.95																						
VA 1200 1221 Programmable Thermostat (HP cooling) Multi-Family 2014 2053 172.29 102.35 3.48 73.19 30% 2.07 43.48 30% 0.16 0.08 0 0 0.56 0.00	VA 120	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Multi-Family	2014	2053	189.36	112.50	38.63	56.12	23%	22.95	33.34	23%	0.08	0.07	0	0	1.14			38.63	22.95
VA 1200 1214 Crawkspace insulation (HP cooling) Multi-Family 2014 2053 171.68 101.99 0.60 73.79 30% 0.36 43.84 30% 0.24 0.08 0 0 0 0.44 0.00 0.00 0.00 0.00 0.																						0.00
VA 1200 1218 Cool Roof (HP cooling)																-	-					0.00
VA 1200 1220 Duct Testing and Sealing (HP cooling) Multi-Family 2014 2053 113.69 67.54 5.42 131.79 54% 3.22 78.29 54% 0.44 0.19 1 0 0.19 0.00 0.00 0.00 0.00 0.00	VA 120	0 1218 Cool Roof (HP cooling)	Multi-Family	2014	2053	152.50	90.60	19.19	92.98	38%	11.40	55.24	38%	0.24	0.12		0	0.39			0.00	0.00
VA 1200 1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling) Multi-Family 2014 2053 113.69 67.54 5.42 131.79 5.4% 3.22 78.29 5.4% 0.44 0.19 1 0 0.19 0.00 0.00 0.00 0.00 0.00																1	-					0.00
VA 1200 1205 Proper Sizing and Quality Install (HP cooling) Multi-Family 2014 2053 104.09 61.84 9.59 141.38 58% 5.70 83.99 58% 0.61 0.22 1 0 0.17 0.00 0.00 0.00 0.00 0.00 0.00																1						0.00
VA 1200 1209 Celling R-0 to R-49 Insulation (HP cooling) Multi-Family 2014 2053 93.72 55.68 0.26 151.76 62% 0.15 90.16 62% 3.57 0.26 6 0 0.03 0.00 0.00 0.00 0.00 0.00 0.00	VA 120	0 1208 Ceiling R-0 to R-38 Insulation (HP cooling)	Multi-Family	2014	2053	104.09	61.84	9.59	141.38	58%	5.70	83.99	58%	0.61	0.22			0.17			0.00	0.00
VA 1200 1215 Basement insulation R-13 (HP cooling) Multi-Family 2014 2053 92.89 55.07 1.03 152.79 62% 0.61 90.77 62% 0.92 0.26 2 0 0.11 0.00 0.00 0.00 0.00 0.00 0.00																						0.00
VA 1200 1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling) Multi-Family 2014 2053 88.02 52.29 2.36 157.46 64% 1.40 93.54 64% 1.05 0.29 2 0 0.10 0.00 0.00 0.00 0.00 0.00 0.00																						0.00
VA 1200 1210 Ceiling R-11 to R-38 Insulation (HP ccoling) Multi-Family 2014 2053 86.67 51.49 1.35 158.80 65% 0.80 94.34 65% 1.73 0.30 3 1 0.06 0.00 0.00 0.00 0.00 0.00 0.00 0.	VA 120	0 1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling)	Multi-Family	2014	2053	90.38	53.69	2.31	155.10	63%	1.37	92.14	63%	1.08	0.28	2	0	0.10			0.00	0.00
VA 1200 1211 Ceiling R-11 to R-49 Insulation (HP cooling) Multi-Family 2014 2053 86.55 51.42 0.13 158.93 65% 0.07 94.42 65% 3.87 0.30 7 1 0.03 0.00 0.00 0.00 0.00 0.00 0.00 0.																						0.00
VA 1200 1212 Celling R-19 to R-38 Insulation (IHP cooling) Multi-Family 2014 2053 85.50 50.79 0.15 159.98 65% 0.09 95.04 65% 3.12 0.32 5 1 0.03 0.00 0.00 0.00 0.00 0.00 0.00 0.																	1					0.00
VA 1200 1213 Ceiling R-19 to R-49 Insulation (HP cooling) Multi-Family 2014 2053 85.47 50.77 0.03 160.01 65% 0.02 95.06 65% 3.93 0.32 7 1 0.03 0.00 0.00 0.00 0.00 0.00 0.00 0.																	1					0.00
VA 1200 1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling) Multi-Family 2014 2053 84.77 50.36 0.70 160.71 65% 0.42 95.48 65% 7.69 0.35 13 1 0.01 0.00 0.00 0.00 0.00 0.00 0.00																	1					0.00
VA 1200 1207 Heat Pump Filter Replacement Multi-Family 2014 2053 84.51 50.21 0.26 160.97 66% 0.15 95.63 66% 5.86 0.36 10 1 0.01 0.00 0.00 0.00 0.00 0.00 0.0						00											1					0.00
VA 1300 1300 Base Heat Pump Cooling - Early Replacement (13 SEER) Multi-Family 2014 2053 44.29 26.31 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A 44.29 26.31 0.00 0.00																	1					0.00
																			44 20	26 31		0.00
																			20	20.01		

APPENDIX H

Base Avoided Costs

Second			ic Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Part					Manaura			2014			Davaant			Devenue								00.12.	
1. 1. 1. 1. 1. 1. 1. 1.					Start	End				Savings	GWH		Savings	MW	Cost	Cost	Cost	Cost	Cost Test				
1. 1. 1. 1. 1. 1. 1. 1.																				GWH	MW		
1. 1. 1. 1. 1. 1. 1. 1.	VA	1300	1324 Door Weatherization (HP cooling Early Replacement)	Multi-Family	2014	2053	41.18	24.47	2.05	3.11	7%	1.22	1.85	7%	0.05	0.05	Ō	ō	1.29			2.05	1.22
Mathematics																							
Vis. 100 115 Colin Fort of Protoning Line Protoning Line 100																							
1																							
No. 150																	0						
1. 1. 1. 1. 1. 1. 1. 1.																	1	-					
No. 1909 1908 1909 1																							
1.00 100																		-					
Value 100 10			1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement)	Multi-Family		2053	16.93	10.06	0.05	27.36	62%	0.03	16.25		3.49	0.25		-				0.00	0.00
Max 100																		-					
Vis. 1900 1910 Colling Fig. 19 All Enclarish processory spring placements of processors processors and processors of processors of processors and processors of																		•					
1. 1. 1. 1. 1. 1. 1. 1.			1310 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)		2011					20.00							-						
1. 1. 1. 1. 1. 1. 1. 1.																		-					
Vis. 1,000	VA	1300																1					
Value 1,000 1,00																		1					
1.00 1.00																		1					
14 14 15 15 15 15 15 15																							
Value 14-00 14-14 Door Westherstander (RAC) Mulf-Family 11-14 2053 1.1-20 7.74 0.06 0.08 0.08 0.08 0.08 0.08 0.0 0.0 0.0 0.0 0.00																				13.91	8.26		
141 Coal Roof (PAC) MulF-Fmile 141 Coal Roof (PAC) MulF-Fmile 141 Coal Roof (PAC) MulF-Fmile 141 MulF-Fmi																		-					
VA 1400 1412 Compenhences Small Ar Seating's - IMF Reduction (RAC) Mulk-Farmly 2014 2038 8.81 5.22 3.95 5.10 2.75 3.95 5.10 3.75 2.95 5.10 3.75 3.95																							
VA 4500 1499 WINDOWS - Double-Glasseo Cierro Ferrog Sant (RAC) Mulsi-Farmly 2014 2053 8.99 8.10 0.22 5.32 289 0.13 3.16 289 0.15 0.10 0.0 0.36 0.00 0.																							
Main Harm																							
Mail-Family	VA	1400				2053	8.08	4.80	0.51	5.83	42%	0.30	3.46	42%	0.23	0.15			0.34				
Main 1410 1415 Celling Farier [RAC]																	1						
VA 1400 1417 Window Flem (RAC) Multi-Family 2014 2053 6.59 3.91 0.65 7.33 57% 0.04 4.35 58% 0.50 0.21 1 0 0.16 0.00				,														-					
VA 1400 1419 VININDOWS - Default VININ Sumscreen (RAC) Muli-Family 2014 2053 6.12 3.69 0.31 7.70 5.5% 0.18 4.58 5.5% 0.79 0.24 1 0 0.10 0.00			1417 Window Film (RAC)		2014					7.33	53%	0.39			0.50		1	-	0.16			0.00	
Mail-Family																							
Mail-Family 1408 Celling R-19 to R-38 insulation (RAC) Mail-Family 2014 2053 6.10 3.62 0.01 7.81 56% 0.01 4.64 56% 2.65 2.66 4 0 0.04 0.00 0.0	• • • •				20		0.20						1.00						0.10				
Main 1400 1409 Celling R-19 line All plausidation (RAC) Multi-Family 2014 2053 6.10 3.62 0.00 7.81 56% 0.00 4.64 56% 2.65 0.26 4 0 0.04 0.00																		-					
VA 1400 1403 Room AC Pitler Replacement 2014 2053 0.08 3.61 0.02 0.00 0.0																							
VA 1500 1501 ERR 8.5 RAC Early Replacement, CEET Tier 1 EER 11.3 (early I Multi-Family 2014 2053 0.95 0.95 0.1																							
Name																				1.09	0.65		
Math 1600 1601 10% better than Energy Star Dehumidifier ROB (354-5 pints/da Multi-Family 2014 2053 2.88 1.59 0.49 0.49 0.49 0.49 0.49 0.49 0.00																				3 17	1.88		
NA 1700 1701 EOM Furnace Fan (variable speed motor) - Cooling Multi-Family 2014 2053 32.91 40.00 0.00	VA	1600				2053	2.68	1.59	0.49	0.49	15%	0.29	0.29	15%	0.19	0.19	0	0				0.00	0.00
VA																				232.33	119.17		
VA																				362.58	43.02		
VA 2000 2002 Heat pump ugrade to 16+ SEER/R.7+ HSPF (HP heating) Multi-Family 2014 2053 30.0.51 30.8.05 30.8.05 30.8.05 30.8.05 1.0.8 54.53 15% 0.72 6.34 15% 0.15 0.08 1 1 0.54 0.00 0.00 0.00 0.00 0.00 0.00 0.00	VA	2000	2016 Duct Insulation (HP heating)	Multi-Family	2014	2053	359.63	42.67	2.96	2.96	1%	0.35	0.35	1%	0.02	0.02	0	0	3.15			2.96	0.35
VA 2000 2012 Cardwspace insulation (HP heating) Multi-Family 2014 2053 309.14 36.68 31.38 53.45 15% 0.13 6.74 15% 0.15 0.08 1 1 0.57 0.00 0.00																							
VA 2000 2012 Crawfspace insulation (IPP heating) Multi-Family 2014 2053 301.95 36.85 1.08 54.53 15% 0.13 6.47 15% 0.15 0.08 1 1 0.44 0.00																	1	1					
VA 2000 2002 Com/prehensive Shell Air Sealing - Inf. Reduction (HP heating) Multi-Family 2014 2053 278.65 33.18 8.57 82.94 23% 1.02 9.84 23% 0.26 0.13 2 1 0.28 0.00	VA	2000	2012 Crawlspace insulation (HP heating)	Multi-Family	2014	2053	308.05	36.55	1.08	54.53	15%	0.13	6.47	15%	0.15	0.08		1	0.44			0.00	0.00
VA 2000 2017 Duct Testing and Sealing (HP heating) Multi-Family 2014 2053 276.65 33.18 8.57 82.94 23% 1.02 9.84 23% 0.26 0.13 2 1 0.25 0.00 0.00 0.00 0.00 0.00 0.00 0.00																		1					
VA 2000 2007 Celling R-O to R-38 Insulation (HP heating) Multi-Family 2014 2053 255.54 30.30 2.71 107.24 30% 0.08 12.64 29% 0.29 0.16 2 1 0.24 0.00 0.	VA	2000				2053	279.65	33.18	8.57	82.94	23%	1.02	9.84	23%	0.26	0.13	2	1				0.00	
VA 2000 2013 Basement insulation R-13 (HP heating) Multi-Family 2014 2053 252.53 29.96 2.82 110.06 30% 0.33 13.06 30% 0.39 0.18 3 1 0.17 0.00 0.00 0.00 0.00 0.00 0.00 0.			2006 Ceiling R-0 to R-38 Insulation (HP heating)	Multi-Family													2						
VA 2000 2018 Heat Recovery Ventilators (HP heating) Multi-Family 2014 2053 19.73 23.46 54.80 164.86 45% 6.50 19.56 45% 0.43 0.26 4 2 0.16 U.00 0.00 0.00 VA 2000 2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating) Multi-Family 2014 2053 19.00 22.89 4.78 169.63 47% 0.57 20.13 47% 0.61 20.72 5 2 0.11 0.00 0.00 0.00 VA 2000 2008 Ceiling R-11 to R-39 Insulation (HP heating) Multi-Family 2014 2053 189.73 22.51 0.27 172.86 48% 0.03 20.11 48% 0.29 0.28 8 2 0.07 0.00 0.00 VA 2000 2014 Floor R-0 to R-19 Insulation-Relating (HP heating) Multi-Family 2014 2053 170.46 20.23 17.29 192.12 53% 2.05 22.79 53% 2.45																		1					
VA 2000 2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating) Multi-Family 2014 2053 192.95 22.89 4,78 169.63 47% 0.61 0.27 5 2 0.11 9 0.00 0.00 VA 2000 2008 Ceiling R-11 to R-49 Insulation (HP heating) Multi-Family 2014 2053 199.00 22.54 2.95 172.86 48% 0.35 20.48 48% 0.92 0.28 8 2 0.07 0.00 0.00 VA 2000 2014 Floor R-10 R-19 Insulation-Batts (HP heating) Multi-Family 2014 2053 187.75 22.28 1.97 172.86 48% 0.32 20.71 48% 0.03 10.8 2 0.03 0.00 0.00 VA 2000 2014 Floor R-19 Insulation-Batts (HP heating) Multi-Family 2014 2053 170.47 22.28 1.97 174.83 48% 0.23 20.74 48% 0.04 0.92 11 2 0.05 0.00 <td< td=""><td>VA</td><td>2000</td><td></td><td> ,</td><td></td><td></td><td>197.73</td><td>23.46</td><td></td><td>164.86</td><td>45%</td><td>6.50</td><td></td><td>45%</td><td>0.43</td><td>0.26</td><td></td><td>2</td><td></td><td></td><td></td><td></td><td></td></td<>	VA	2000		,			197.73	23.46		164.86	45%	6.50		45%	0.43	0.26		2					
VA 2000 2009 Ceiling R-11 to R-49 Insulation (HP heating) Multi-Family 2014 2053 189.73 22.51 0.27 172.86 48% 0.03 20.51 48% 2.04 4.02 17 2 0.03 3 0.00 0.00 VA 2000 2014 Floor R-0 to R-19 Insulation (HP heating) Multi-Family 2014 2053 187.75 22.28 1.97 174.83 48% 0.23 20.74 48% 1.28 0.30 11 2 0.05 0.00 0.00 VA 2000 2010 Goriund Source Heat Pump with Desugerheater (HP heating) Multi-Family 2014 2053 170.76 20.23 17.29 192.12 53% 2.05 2.05 2.05 0.00 0.00 VA 2000 2010 Ceiling R-19 to R-38 Insulation (HP heating) Multi-Family 2014 2053 170.17 20.18 0.06 192.48 53% 0.01 22.84 53% 1.81 0.49 15 4 0.03 1 0.00 <	VA		2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Multi-Family		2053	192.95	22.89		169.63	47%		20.13	47%		0.27	-	_					
VA 2000 2014 Floor R-0 to R-19 Insulation-Batts (HP heating) Multi-Family 2014 203 17.75 22.28 1.97 17.483 48% 0.23 20.74 48% 1.28 0.30 11 2 0.05 5 0.00 0.00 0.00 VA 2000 2010 Ceiling R-19 to R-38 Insulation (HP heating) Multi-Family 2014 2053 170.17 20.19 0.30 192.42 53% 0.04 22.83 53% 1.81 0.49 21 4 0.03 -0.00 0.00 0.00 VA 2000 2011 Ceiling R-19 to R-38 Insulation (HP heating) Multi-Family 2014 2053 170.17 20.19 0.30 192.42 53% 0.01 22.83 53% 0.49 15 4 0.04 0.00																							
VA 2000 2010 Ceiling R-19 to R-38 Insulation (HP heating) Multi-Family 2014 2053 170.17 20.19 0.30 192.48 53% 0.04 22.88 53% 1.81 0.49 15 4 0.04 1 0.00 0.00 VA 2000 2015 Wall Blow-in R-0 to R-13 Insulation (HP heating) Multi-Family 2014 2053 168.71 20.02 1.39 193.88 53% 0.17 22.84 53% 0.28 0.49 19 4 0.03 0.00 0.00 VA 2000 2015 Wall Blow-in R-0 to R-13 Insulation (HP heating) Multi-Family 2014 2053 168.71 20.02 1.39 193.88 53% 0.17 22.80 53% 4.7 0.52 38 4 0.02 0.00 0.00 VA 2000 2005 Heat Pump Filter Replacement Multi-Family 2014 2053 168.71 19.89 0.51 194.38 54% 0.06 23.06 54% 3.41 0.53 29	VA	2000	2014 Floor R-0 to R-19 Insulation-Batts (HP heating)	Multi-Family	2014	2053	187.75	22.28	1.97	174.83	48%	0.23	20.74	48%	1.28	0.30	11	2	0.05			0.00	0.00
VA 2000 2015 (Peling R-19 to R-49 Insulation (HP heating) Multi-Family 2014 2053 170.10 20.18 0.06 192.48 53% 0.10 22.84 53% 0.28 0.49 19 4 0.03 0.00 0.00 0.00 0.00 0.00 0.00 0.																							
VA 2000 2015 Wall Blow-in R-0 to R-13 Insulation (HP heating) Multi-Family 2014 2053 168.71 20.02 1.39 193.88 53% 0.17 23.00 53% 4.47 0.52 38 4 0.02 0.00 0.00 0.00 0.00 0.00 0.00 0.																		4					
VA 2000 2004 Heat pump tune up Multi-Family 2014 2053 167.67 19.89 0.53 194.91 54% 0.06 23.13 54% 5.50 0.54 46 5 0.01 0.00 0.00 0.00 VA 2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSP Multi-Family 2014 2053 87.04 10.33 0.00 0.00 0.00 0.00 0.00 0.00 0.0	VA				20						53%					0.10	38	4					
VA 2100 2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSP Multi-Family 2014 2053 87.04 10.33 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A N/A 87.04 10.33 0.00 0.00																							
																				87,04	10.33		

DNV GL H-6 1/5/2015

APPENDIX H

Base Avoided Costs

	al Electric Existing Construction YST ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage	Existing		Measure	Manaura	· oui	2014		Total	Percent		Total	Percent	Marginal		Marginal		Total Resource			00.12.	
Base		Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Cost Test	Base	Base	Economic	
	nber Number Measure 2100 2121 Self Install Weatherization (HP heating early replacement)	Type Multi-Family	2014	2053	84.95	MW 10.08	Savings 1.37	2.08	Savings 2%	Savings 0.16	0.25	Savings 2%	\$/kWH 0.02	\$/kWH 0.02	\$/kW	\$/kW	2.64	GWH	MW	1.37	MW 0.16
	2100 2122 Door Weatherization (HP heating early replacement)	Multi-Family	2014	2053	82.59	9.80	2.36	4.44	5%	0.28	0.53	5%	0.05	0.04	ō	ō	0.96			0.00	0.00
	2100 2102 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early 2100 2112 Crawlspace insulation (HP heating early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	74.98 74.72	8.90 8.87	7.61 0.26	12.05 12.32	14% 14%	0.90	1.43 1.46	14% 14%	0.08	0.06	1	1	0.79			0.00	0.00
		Multi-Family	2014	2053	73.24	8.69	1.48	13.79	16%	0.03	1.64	16%	0.11	0.07	1	1	0.58			0.00	0.00
	2100 2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating e		2014	2053	69.91	8.29	3.33	17.13	20%	0.40	2.03	20%	0.15	0.08	1	1	0.39			0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	67.83 62.11	8.05 7.37	2.08 5.72	19.20 24.93	22% 29%	0.25 0.68	2.28 2.96	22% 29%	0.19 0.21	0.10 0.12	2	1	0.35 0.32			0.00	0.00
		Multi-Family	2014	2053	61.94	7.35	0.17	25.10	29%	0.02	2.98	29%	1.10	0.12	9	1	0.06			0.00	0.00
		Multi-Family	2014	2053	61.25	7.27	0.69	25.79	30%	0.08	3.06	30%	0.28	0.13	2	1	0.24			0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	47.96 46.80	5.69 5.55	13.29 1.16	39.08 40.24	45% 46%	1.58 0.14	4.64 4.77	45% 46%	0.32	0.19 0.20	3	2	0.21			0.00	0.00
		Multi-Family	2014	2053	46.08	5.47	0.72	40.95	47%	0.08	4.86	47%	0.67	0.21	6	2	0.10			0.00	0.00
	2100 2109 Ceiling R-11 to R-49 Insulation (HP heating early replacement)		2014	2053	46.02	5.46	0.07	41.02	47%	0.01	4.87	47%	1.49	0.21	13	2	0.05			0.00	0.00
	2100 2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replaceme 2100 2103 Ground Source Heat Pump with Desuperheater (HP heating ear		2014 2014	2053 2053	45.54 41.34	5.40 4.91	0.48 4.19	41.50 45.69	48% 52%	0.06	4.92 5.42	48% 52%	0.93 1.78	0.22	8 15	2	0.07 0.04			0.00	0.00
	2100 2110 Ceiling R-19 to R-38 Insulation (HP heating early replacement)		2014	2053	41.27	4.90	0.07	45.76	53%	0.01	5.43	53%	1.32	0.37	11	3	0.05			0.00	0.00
	2100 2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement)		2014	2053	41.26	4.89	0.02	45.78	53%	0.00	5.43	53%	1.66	0.37	14	3	0.04			0.00	0.00
	2100 2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacem 2100 2105 Heat Pump Filter Replacement (heating)	Multi-Family Multi-Family	2014 2014	2053 2053	40.92 40.79	4.85 4.84	0.34 0.12	46.12 46.24	53% 53%	0.04	5.47 5.49	53% 53%	3.25 2.48	0.39	27 21	3	0.02 0.02			0.00	0.00
	37	Multi-Family	2014	2053	40.67	4.83	0.13	46.37	53%	0.02	5.50	53%	4.00	0.40	34	3	0.01			0.00	0.00
VA 22	2200 2200 Base Resistance Space Heating (Primary)	Multi-Family	2014	2053	374.37	44.42	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	374.37	44.42	0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	295.43 290.73	35.05 34.49	78.94 4.70	78.94 83.64	21% 22%	9.37 0.56	9.37 9.92	21% 22%	0.01 0.02	0.01	0	0	5.17 2.57			78.94 4.70	9.37 0.56
		Multi-Family	2014	2053	277.47	32.92	13.26	96.90	26%	1.57	11.50	26%	0.02	0.02	0	0	1.53			13.26	1.57
		Multi-Family	2014	2053	271.97	32.27	5.49	102.40	27%	0.65	12.15	27%	0.07	0.02	1	0	0.82			0.00	0.00
	2200 2209 Crawlspace insulation (resistance heating) 2200 2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance he	Multi-Family	2014 2014	2053 2053	270.90 258.57	32.14 30.68	1.08 12.33	103.48 115.80	28% 31%	0.13 1.46	12.28 13.74	28% 31%	0.10	0.02	1	0	0.70 0.41			0.00	0.00
		Multi-Family	2014	2053	234.98	27.88	23.59	139.39	37%	2.80	16.54	37%	0.14	0.06	2	0	0.38			0.00	0.00
VA 22	2200 2204 Ceiling R-0 to R-49 Insulation (resistance heating)	Multi-Family	2014	2053	234.42	27.81	0.56	139.95	37%	0.07	16.60	37%	1.20	0.06	10	1	0.06			0.00	0.00
	2200 2210 Basement insulation R-13 (resistance heating) 2200 2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance h	Multi-Family	2014 2014	2053 2053	230.44 224.09	27.34 26.59	3.98 6.35	143.93 150.28	38% 40%	0.47 0.75	17.08 17.83	38% 40%	0.26 0.28	0.07	2	1	0.26 0.24			0.00	0.00
	2200 2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance in 2200 2213 Heat Recovery Ventilators (resistance heating)	Multi-Family	2014	2053	175.46	20.82	48.63	198.91	53%	5.77	23.60	53%	0.20	0.08	3	1	0.24			0.00	0.00
	2200 2205 Ceiling R-11 to R-38 Insulaton (resistance heating)	Multi-Family	2014	2053	172.56	20.47	2.91	201.81	54%	0.34	23.94	54%	0.58	0.14	5	1	0.12			0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	170.03 169.82	20.17 20.15	2.53 0.21	204.34	55% 55%	0.30	24.24 24.27	55% 55%	0.62 1.66	0.14	5 14	1	0.11			0.00	0.00
	2200 Ceiling K*11 to K*45 insulation (resistance heating) 2200 2202 Ground Source Heat Pump with Desuperheater (resistance hea		2014	2053	170.00	20.13	-0.18	204.37	55%	-0.02	24.25	55%	-154.51	0.13	-1,302	2	0.00			0.00	0.00
VA 22	2200 2207 Ceiling R-19 to R-38 Insulation (resistance heating)	Multi-Family	2014	2053	169.66	20.13	0.34	204.71	55%	0.04	24.29	55%	0.99	0.29	8	2	0.07			0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	169.61 167.68	20.12 19.89	0.05 1.93	204.77 206.69	55% 55%	0.01	24.29 24.52	55% 55%	1.67 2.01	0.29	14 17	2	0.04			0.00	0.00
		Multi-Family	2020	2053	21.22	2.38	0.00	0.00	0%	0.23	0.00	0%	N/A	N/A	N/A	N/A	N/A	21.22	2.38	0.00	0.00
	3030 3032 LEDs (base Halogen 0.5 hrs/day) 2020	Multi-Family	2020	2053	5.56	0.62	15.66	15.66	74%	1.75	1.75	74%	0.03	0.03	0	0	2.34			15.66	1.75
		Multi-Family Multi-Family	2020 2020	2053 2053	88.41 23.16	9.90 2.59	0.00 65.25	0.00 65.25	0% 74%	0.00 7.30	0.00 7.30	0% 74%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 11.68	88.41	9.90	0.00 65.25	0.00 7.30
		Multi-Family	2020	2053	55.17	6.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	55.17	6.18	0.00	0.00
	3230 3232 LEDs (base Halogen 6 hrs/day) 2020	Multi-Family	2020	2053	17.63	1.97	37.54	37.54	68%	4.20	4.20	68%	0.00	0.00	0	0	15.99			37.54	4.20
		Multi-Family Multi-Family	2020 2020	2053 2053	3.97 2.90	0.44 0.32	0.00 1.07	0.00 1.07	0% 27%	0.00	0.00 0.12	0% 27%	N/A 0.21	N/A 0.21	N/A 2	N/A 2	N/A 0.37	3.97	0.44	0.00	0.00
		Multi-Family	2020	2053	16.33	1.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.33	1.83	0.00	0.00
		Multi-Family	2020	2053	11.92	1.33	4.41	4.41	27%	0.49	0.49	27%	0.04	0.04	0	0	1.84			4.41	0.49
		Multi-Family Multi-Family	2020 2020	2053 2053	11.03 8.05	1.24 0.90	0.00 2.98	0.00 2.98	0% 27%	0.00	0.00	0% 27%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.80	11.03	1.24	0.00 2.98	0.00
VA 36	3630 3630 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	Multi-Family	2020	2053	9.32	1.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.32	1.04	0.00	0.00
		Multi-Family	2020	2053	3.68	0.41	5.64	5.64	60%	0.63	0.63	60%	0.01	0.01	0	0	6.49	07.00		5.64	0.63
		Multi-Family Multi-Family	2020 2020	2053 2053	37.63 14.87	4.21 1.66	0.00 22.76	0.00 22.76	0% 60%	0.00 2.55	0.00 2.55	0% 60%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 32.45	37.63	4.21	0.00 22.76	0.00 2.55
VA 38	3830 3830 Base Halogen (Specialty) Lighting - 6 hrs/day 2020	Multi-Family	2020	2053	25.80	2.89	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	25.80	2.89	0.00	0.00
		Multi-Family	2020	2053	10.20	1.14	15.61	15.61	60%	1.75	1.75	60%	0.00	0.00	0	0	48.19	50.50	0.07	15.61	1.75
		Multi-Family Multi-Family	2014 2014	2053 2053	59.58 43.51	6.67 4.87	0.00 16.07	0.00 16.07	0% 27%	0.00 1.80	0.00 1.80	0% 27%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 2.17	59.58	6.67	0.00 16.07	0.00 1.80
VA 40	4000 Base Refrigerator	Multi-Family	2014	2053	217.96	35.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	217.96	35.33	0.00	0.00
		Multi-Family	2014	2053	173.06	28.05	44.90	44.90	21%	7.28	7.28	21%	0.05	0.05	0	0	1.41	00.50	4.00	44.90	7.28
	,,,	Multi-Family Multi-Family	2014 2014	2053 2053	29.59 13.93	4.80 2.26	0.00 15.67	0.00 15.67	0% 53%	0.00 2.54	0.00 2.54	0% 53%	N/A 0.13	N/A 0.13	N/A 1	N/A 1	N/A 0.40	29.59	4.80	0.00	0.00
VA 42	4200 Base 2nd Refrigerator - Recycling	Multi-Family	2014	2053	3.49	0.57	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.49	0.57	0.00	0.00
	1200 4201 2nd Refrigerator Recycling	Multi-Family	2014	2053	0.90	0.15	2.59	2.59	74%	0.42	0.42	74%	0.05	0.05	0	0	1.04	00.00	0.00	2.59	0.42
		Multi-Family Multi-Family	2014 2014	2053 2053	20.38 18.47	3.30 2.99	0.00 1.91	0.00 1.91	0% 9%	0.00	0.00 0.31	0% 9%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.04	20.38	3.30	0.00 1.91	0.00 0.31
VA 46	4600 Base Early Replacement Freezer	Multi-Family	2014	2053	5.04	0.80	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.04	0.80	0.00	0.00
		Multi-Family	2014	2053	2.23	0.35	2.81	2.81	56%	0.44	0.44	56%	0.04	0.04	0	0	1.23	0.00	0.00	2.81	0.44
		Multi-Family Multi-Family	2014 2014	2053 2053	0.00 795.29	0.00 97.95	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 795.29	0.00 97.95	0.00	0.00
VA 50	5000 5006 Pipe Wrap	Multi-Family	2014	2053	770.86	94.94	24.43	24.43	3%	3.01	3.01	3%	0.02	0.02	0	0	2.92		200	24.43	3.01
VA 50	5000 5015 Low Flow Showerhead 1.5 Gal/Min	Multi-Family	2014	2053	745.47	91.81	25.39	49.82	6%	3.13	6.14	6%	0.02	0.02	0	0	2.69			25.39	3.13

APPENDIX H

Base Avoided Costs

	l Electric Existing Construction (ST ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage	Existing		Mescure	Measure		20.7		Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity		Total Resource			55. TEI	
Base		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	
Sgmt Numb		Type Multi-Family	Year 2014	Year 2053	740.05	MW 91.15	Savings 5.42	55.24	Savings 7%	Savings 0.67	6.80	Savings 7%	\$/kWH 0.02	\$/kWH 0.02	\$/kW	\$/kW	2.07	GWH	MW	5.42	MW 0.67
	000 5007 Hot water turndown 5 degrees	Multi-Family	2014	2053	736.09	90.66	3.96	59.20	7%	0.49	7.29	7%	0.02	0.02	0	0	2.06			3.96	0.49
		Multi-Family Multi-Family	2014 2014	2053 2053	734.82 734.34	90.50 90.44	1.27 0.48	60.47 60.95	8% 8%	0.16	7.45 7.51	8% 8%	0.02	0.02	0	0	2.04			1.27 0.48	0.16
		Multi-Family	2014	2053	719.00	88.55	15.34	76.29	10%	1.89	9.40	10%	0.02	0.02	0	0	1.51			15.34	1.89
		Multi-Family	2014	2053	691.97	85.23	27.03	103.32	13%	3.33	12.72	13%	0.07	0.04	1	0	1.03			27.03	3.33
		Multi-Family Multi-Family	2014 2014	2053 2053	653.13 563.23	80.44 69.37	38.84 89.91	142.16 232.06	18% 29%	4.78 11.07	17.51 28.58	18% 29%	0.06 0.08	0.04	0	0	0.83 0.79			0.00	0.00
		Multi-Family	2014	2053	475.22	58.53	88.00	320.07	40%	10.84	39.42	40%	0.20	0.10	2	1	0.33			0.00	0.00
		Multi-Family	2014	2053	473.22	58.28	2.01	322.07	40%	0.25	39.67	40%	2.25	0.11	18	1	0.03			0.00	0.00
	 5013 Energy Star Dishwasher (EF=0.72) 5100 Base Water Heating Early Replacement to Heat Pump Water H 	Multi-Family Multi-Family	2014	2053 2053	472.18 140.35	58.16 17.29	1.03 0.00	323.11 0.00	41% 0%	0.13	39.79 0.00	41% 0%	2.93 N/A	0.12 N/A	24 N/A	1 N/A	0.02 N/A	140.35	17.29	0.00	0.00
VA 51	100 5101 Heat Pump Water Heater - Energy Star - Early Replacement	Multi-Family	2014	2053	121.03	14.91	19.32	19.32	14%	2.38	2.38	14%	0.08	0.08	1	1	0.78			0.00	0.00
		Multi-Family	2014	2053	13.76	2.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 7	N/A 7	N/A	13.76	2.49	0.00	0.00
	,	Multi-Family Multi-Family	2014 2014	2053 2053	9.84 258.64	1.78 43.77	3.92 0.00	3.92 0.00	28% 0%	0.71	0.71 0.00	28% 0%	1.21 N/A	1.21 N/A	N/A	N/A	0.05 N/A	258.64	43.77	0.00	0.00
VA 56	600 5602 High Efficiency CD (EF=3.01 w/moisture sensor)	Multi-Family	2014	2053	211.14	35.73	47.51	47.51	18%	8.04	8.04	18%	0.03	0.03	0	0	1.85			47.51	8.04
		Multi-Family	2014	2053	105.57	17.87	105.57	153.08	59%	17.87	25.91	59%	0.55	0.39	3	2	0.11	00.04	0.00	0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	60.34 58.19	9.90 9.54	0.00 2.15	0.00 2.15	0% 4%	0.00	0.00 0.35	0% 4%	N/A 1.59	N/A 1.59	N/A 10	N/A 10	N/A 0.04	60.34	9.90	0.00	0.00
VA 60	000 6000 Base Single Speed Pool Pump (RET)	Multi-Family	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
		Multi-Family	2014	2053	18.99	2.74	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.99	2.74	0.00	0.00
		Multi-Family Multi-Family	2014	2053 2053	17.31 17.08	2.50 2.46	1.68 0.23	1.68 1.91	9% 10%	0.24	0.24 0.28	9% 10%	0.01 2.23	0.01 0.28	0 15	0	6.90 0.02			1.68 0.00	0.24
		Multi-Family	2014	2053	56.69	8.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	56.69	8.18	0.00	0.00
		Multi-Family	2014	2053	36.03	5.20	20.66	20.66	36%	2.98	2.98	36%	0.00	0.00	0	0	14.79			20.66	2.98
		Multi-Family Multi-Family	2014 2014	2053 2053	34.66 17.04	5.00 2.46	1.37	22.03	39% 0%	0.20	3.18 0.00	39% 0%	2.36 N/A	0.15 N/A	16 N/A	1 N/A	0.02 N/A	17.04	2.46	0.00	0.00
	200 7200 Base CRT TV 200 7202 Plug Load Controls - Smart Power Strip (base CRT TV)	Multi-Family	2014	2053	15.32	2.40	1.73	1.73	10%	0.00	0.25	10%	0.66	0.66	5	5	0.08	17.04	2.40	0.00	0.00
VA 73	300 7300 Base Set-Top Box	Multi-Family	2014	2053	56.64	8.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	56.64	8.17	0.00	0.00
		Multi-Family Multi-Family	2014	2053 2053	9.64 4.52	1.39 0.65	0.00 5.12	0.00 5.12	0% 53%	0.00	0.00 0.74	0% 53%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 3.83	9.64	1.39	0.00 5.12	0.00 0.74
		Multi-Family	2014	2053	0.35	0.05	4.17	9.29	96%	0.60	1.34	96%	0.69	0.01	5	2	0.07			0.00	0.74
VA 75	500 7500 Base Desktop PC	Multi-Family	2014	2053	70.86	9.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	70.86	9.33	0.00	0.00
	500 7501 Energy Star Desktop PC 500 7502 Plug Load Controls - Smart Power Strip (base Desktop PC)	Multi-Family Multi-Family	2014 2014	2053 2053	61.76 32.35	8.14 4.26	9.10 29.41	9.10 38.51	13% 54%	1.20 3.87	1.20 5.07	13% 54%	0.00 0.05	0.00	0	0	13.52 1.05			9.10 29.41	1.20 3.87
	 7502 Plug Load Controls - Smart Power Strip (base Desktop PC) 7600 Base Laptop PC 	Multi-Family	2014	2053	14.28	1.88	0.00	0.00	0%	0.00	0.00	0%	0.05 N/A	0.04 N/A	N/A	N/A	N/A	14.28	1.88	0.00	0.00
VA 76	600 7601 Energy Star Laptop PC	Multi-Family	2014	2053	11.90	1.57	2.38	2.38	17%	0.31	0.31	17%	0.03	0.03	0	0	2.03			2.38	0.31
		Multi-Family Multi-Family	2014	2053 2053	198.97 119.20	63.52 15.70	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	198.97	63.52 15.70	0.00	0.00
		Multi-Family Multi-Family	2014	2053	4.108.27		0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	119.20 4,108.27	1,017.30		0.00
		Multi-Family	2014	2053	4,047.26		61.02	61.02	1%	15.11	15.11	1%	0.03	0.03	0	0	1.54	.,	.,	61.02	15.11
		Multi-Family	2014	2053	3,864.22		183.04	244.06	6%	45.33	60.43	6%	0.09	0.08	0	0	0.61	F0 00	00.70	0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	50.03 49.38	29.72 29.33	0.00	0.00 0.66	0% 1%	0.00	0.00	0% 1%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 5.21	50.03	29.72	0.00	0.00
		Single Family	2014	2053	48.98	29.10	0.39	1.05	2%	0.23	0.62	2%	0.06	0.03	0	0	1.52			0.39	0.23
		Single Family	2014	2053	48.70	28.93	0.28	1.33	3%	0.17	0.79	3%	0.09	0.04	0	0	1.21			0.28	0.17
		Single Family Single Family	2014 2014	2053 2053	48.65 45.16	28.90 26.83	0.05 3.49	1.39 4.88	3% 10%	0.03 2.07	0.82 2.90	3% 10%	0.10	0.05	0	0	1.01 0.90			0.05	0.03
		Single Family	2014	2053	44.29	26.31	0.87	5.75	11%	0.51	3.41	11%	0.08	0.08	0	0	0.81			0.00	0.00
		Single Family	2014	2053	41.60	24.71	2.69	8.43	17%	1.60	5.01	17%	0.15	0.10	0	0	0.66			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	39.25 35.29	23.32	2.35	10.79 14.74	22% 29%	1.40 2.35	6.41 8.76	22% 29%	0.18 0.24	0.12	0	0	0.56			0.00	0.00
	()	Single Family	2014	2053	31.87	18.93	3.43	18.17	36%	2.04	10.79	36%	0.27	0.17	0	0	0.43			0.00	0.00
NC 10	000 1014 Crawlspace insulation (CAC)	Single Family	2014	2053	31.56	18.75	0.30	18.47	37%	0.18	10.97	37%	0.33	0.18	1	0	0.32			0.00	0.00
		Single Family Single Family	2014	2053	30.95 27.92	18.39 16.58	0.62 3.03	19.09 22.12	38% 44%	0.37 1.80	11.34 13.14	38% 44%	0.37	0.18	1	0	0.28			0.00	0.00
		Single Family	2014	2053	27.92	16.58	0.01	22.12	44%	0.00	13.14	44%	4.46	0.21	8	0	0.23			0.00	0.00
NC 10	000 1023 Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	Single Family	2014	2053	26.64	15.82	1.27	23.40	47%	0.75	13.90	47%	0.43	0.22	1	0	0.19			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	26.38 25.69	15.67 15.26	0.25 0.69	23.65 24.34	47% 49%	0.15 0.41	14.05 14.46	47% 49%	0.56 0.99	0.22	1 2	0	0.17 0.11			0.00	0.00
		Single Family	2014	2053	25.69	15.25	0.03	24.34	49% 49%	0.41	14.48	49% 49%	4.84	0.24	8	0	0.11			0.00	0.00
NC 10	000 1020 Duct Testing and Sealing (CAC)	Single Family	2014	2053	25.56	15.18	0.11	24.48	49%	0.06	14.54	49%	1.23	0.25	2	0	0.08			0.00	0.00
		Single Family	2014	2053	25.43	15.11	0.12	24.60	49%	0.07	14.62	49% 49%	1.32	0.26	2	0	80.0			0.00	0.00
	()	Single Family Single Family	2014 2014	2053 2053	25.35 24.92	15.06 14.81	0.08 0.43	24.68 25.11	49% 50%	0.05 0.26	14.66 14.92	49% 50%	1.70 1.80	0.26 0.29	3	0	0.06 0.05			0.00	0.00
NC 10	000 1013 Ceiling R-19 to R-49 Insulation (CAC)	Single Family	2014	2053	24.91	14.80	0.01	25.12	50%	0.00	14.92	50%	4.99	0.29	8	ō	0.02			0.00	0.00
		Single Family	2014	2053	24.07	14.30	0.84	25.96	52%	0.50	15.42	52%	1.72	0.34	3	1	0.05			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	24.03 23.39	14.28 13.89	0.04 0.64	26.01 26.65	52% 53%	0.03	15.45 15.83	52% 53%	2.47 2.51	0.34	4	1	0.04 0.04			0.00	0.00
		Single Family	2014	2053	23.37	13.88	0.02	26.67	53%	0.01	15.84	53%	4.51	0.40	8	1	0.02			0.00	0.00
	000 1007 AC Filter Changes (CAC)	Single Family	2014	2053	23.27	13.82	0.10	26.77	53%	0.06	15.90	53%	2.63	0.41	4	1	0.02			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	23.16	13.76 13.75	0.10	26.87 26.90	54% 54%	0.06	15.96 15.98	54% 54%	3.01 5.60	0.42	5 9	1	0.02			0.00	0.00
INC 10	000 TOTO FIGOR R-0 to R-19 Illisulation-Dates (CAC)	onigle rainly	2014	2003	23.14	13.75	0.03	20.90	34%	0.02	15.96	34%	5.00	0.42	э		0.02			0.00	0.00

DNV GL H-8 1/5/2015

APPENDIX H

Base Avoided Costs

		ic Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage		xisting		Manager		· oui	20.7		Total	Devenue		Total	Deven	Marginal		Marginal	Average	Total			30. TET	
Ba	ise M	easure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	
Sgmt Nu	mber N	umber Measure 1100 Base Split-System Air Conditioner - Early Replacement (11 SE)	Type	Year 2014	Year 2053	6WH 8.38	MW 4.98	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	GWH 8.38	MW 4.98	GWH 0.00	0.00
NC	1100	1117 Duct Insulation (CAC early replacement)	Single Family	2014	2053	8.31	4.96	0.00	0.00	1%	0.04	0.00	1%	0.01	0.01	0	0	7.50	0.30	4.90	0.00	0.00
NC	1100	1122 Self Install Weatherization (CAC early replacement)	Single Family	2014	2053	8.20	4.87	0.11	0.18	2%	0.06	0.11	2%	0.02	0.02	0	0	4.90			0.11	0.06
NC NC	1100 1100	1120 Programmable Thermostat (CAC early replacement) 1119 Return Duct Modification (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	8.14 8.09	4.84 4.81	0.07	0.24 0.29	3% 3%	0.04	0.14 0.17	3% 3%	0.06	0.03	0	0	1.43 1.14			0.07	0.04
NC	1100	1102 Proper Refrigerant Charging and Air Flow (CAC early replacem		2014	2053	7.42	4.41	0.67	0.96	11%	0.40	0.57	11%	0.10	0.04	ō	0	0.84			0.00	0.00
NC	1100	1123 Door Weatherization (CAC early replacement)	Single Family	2014	2053	7.26	4.31	0.17	1.13	13%	0.10	0.67	13%	0.08	0.08	0	0	0.87			0.00	0.00
NC NC	1100 1100	1116 Cool Roof (CAC early replacement) 1125 Whole House Fans (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	6.50 5.29	3.86 3.14	0.76 1.21	1.88 3.09	22% 37%	0.45	1.12 1.84	22% 37%	0.18 0.24	0.12 0.16	0	0	0.53 0.41			0.00	0.00
NC	1100	1103 Proper Sizing and Quality Install (CAC early replacement)	Single Family	2014	2053	4.70	2.79	0.59	3.68	44%	0.35	2.19	44%	0.33	0.19	1	0	0.31			0.00	0.00
NC	1100	1112 Crawlspace insulation (CAC early replacement)	Single Family	2014	2053	4.66	2.77	0.04	3.73	44%	0.03	2.21	44%	0.39	0.19	1	0	0.27			0.00	0.00
NC NC	1100 1100	1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early n 1113 Basement insulation R-13 (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	4.59 4.55	2.73 2.70	0.07 0.04	3.80 3.83	45% 46%	0.04	2.25 2.28	45% 46%	0.42 0.45	0.20	1	0	0.25 0.23			0.00	0.00
NC	1100	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	Single Family	2014	2053	4.46	2.65	0.09	3.92	47%	0.05	2.33	47%	0.45	0.21	1	Ö	0.23			0.00	0.00
NC	1100	1107 Ceiling R-0 to R-49 Insulation (CAC early replacement)	Single Family	2014	2053	4.46	2.65	0.00	3.92	47%	0.00	2.33	47%	4.92	0.21	8	0	0.02			0.00	0.00
NC NC	1100 1100	 1118 Duct Testing and Sealing (CAC early replacement) 1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early re 	Single Family	2014 2014	2053 2053	4.42 4.22	2.63 2.51	0.04	3.96 4.16	47% 50%	0.02	2.35	47% 50%	0.57	0.21	1	0	0.18 0.17			0.00	0.00
NC	1100	1124 Ceiling Fans (CAC early replacement)	Single Family	2014	2053	4.18	2.49	0.03	4.20	50%	0.02	2.49	50%	0.76	0.23	1	0	0.13			0.00	0.00
NC	1100	1126 Window Film (CAC early replacement)	Single Family	2014	2053	3.87	2.30	0.31	4.51	54%	0.19	2.68	54%	0.81	0.27	1	0	0.10			0.00	0.00
NC NC	1100 1100	1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement) 1127 WINDOWS - Default With Sunscreen (CAC early replacement)	Single Family	2014 2014	2053 2053	3.77 3.59	2.24 2.13	0.10 0.18	4.61 4.79	55% 57%	0.06 0.11	2.74 2.85	55% 57%	1.19 1.05	0.29	2	0	0.09			0.00	0.00
NC	1100	1109 Ceiling R-11 to R-49 Insulation (CAC early replacement)	Single Family	2014	2053	3.59	2.13	0.00	4.79	57%	0.00	2.85	57%	6.12	0.32	10	1	0.08			0.00	0.00
NC	1100	1110 Ceiling R-19 to R-38 Insulation (CAC early replacement)	Single Family	2014	2053	3.57	2.12	0.01	4.81	57%	0.01	2.86	57%	2.13	0.33	4	1	0.05			0.00	0.00
NC NC	1100 1100	1111 Ceiling R-19 to R-49 Insulation (CAC early replacement) 1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	3.57 3.57	2.12 2.12	0.00 0.01	4.81 4.82	57% 57%	0.00	2.86 2.86	57% 57%	6.14 2.93	0.33	10 5	1	0.02 0.04			0.00	0.00
NC	1100	1101 14 SEER (12.15 EER) Split-System Air Conditioner w/ Quality		2014	2053	3.48	2.06	0.09	4.91	59%	0.05	2.92	59%	2.86	0.38	5	1	0.03			0.00	0.00
NC	1100	1105 AC Filter Changes (CAC early replacement)	Single Family	2014	2053	3.46	2.06	0.01	4.92	59%	0.01	2.92	59%	3.12	0.39	5	1	0.02			0.00	0.00
NC NC	1100 1100	1104 AC Maintenance and/or tune-up (CAC early replacement) 1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	3.44 3.44	2.05 2.04	0.02 0.00	4.94 4.94	59% 59%	0.01	2.93 2.94	59% 59%	3.57 6.64	0.40	6 11	1	0.02			0.00	0.00
NC	1200	1200 Base Heat Pump Cooling (13 SEER)	Single Family	2014	2053	126.33	75.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.02 N/A	126.33	75.05	0.00	0.00
NC	1200	1219 Duct Insulation (HP cooling)	Single Family	2014	2053	125.30	74.44	1.03	1.03	1%	0.61	0.61	1%	0.01	0.01	0	0	9.09			1.03	0.61
NC NC	1200 1200	1223 Self Install Weatherization (HP cooling)	Single Family Single Family	2014 2014	2053 2053	123.65 121.15	73.46 71.97	1.65 2.50	2.68 5.18	2% 4%	0.98 1.49	1.59 3.08	2% 4%	0.04	0.03	0	0	2.27 1.27			1.65 2.50	0.98 1.49
NC	1200	1221 Programmable Thermostat (HP cooling) 1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	2014	2053	100.62	59.78	20.53	25.71	20%	12.19	15.27	20%	0.07	0.05	0	0	1.22			20.53	12.19
NC	1200	1204 Proper Refrigerant Charging and Air Flow (HP cooling)	Single Family	2014	2053	93.40	55.49	7.22	32.93	26%	4.29	19.57	26%	0.10	0.08	0	0	0.85			0.00	0.00
NC	1200	1224 Door Weatherization (HP cooling)	Single Family	2014	2053	91.61	54.42	1.79	34.73	27%	1.06	20.63	27%	0.09	0.08	0	0	0.76			0.00	0.00
NC NC	1200	1218 Cool Roof (HP cooling) 1205 Proper Sizing and Quality Install (HP cooling)	Single Family Single Family	2014 2014	2053 2053	82.04 74.07	48.74 44.00	9.57 7.97	44.29 52.26	35% 41%	5.68 4.73	26.31 31.05	35% 41%	0.18 0.22	0.10	0	0	0.54			0.00	0.00
NC	1200	1226 Whole House Fans (HP cooling)	Single Family	2014	2053	60.29	35.82	13.78	66.04	52%	8.19	39.24	52%	0.26	0.15	ō	ō	0.37			0.00	0.00
NC	1200	1214 Crawlspace insulation (HP cooling)	Single Family	2014	2053	59.71	35.47	0.58	66.62	53%	0.34	39.58	53%	0.38	0.15	1	0	0.28			0.00	0.00
NC NC	1200 1200	1208 Ceiling R-0 to R-38 Insulation (HP cooling) 1215 Basement insulation R-13 (HP cooling)	Single Family Single Family	2014 2014	2053 2053	58.53 58.05	34.77 34.49	1.18 0.48	67.80 68.28	54% 54%	0.70	40.28 40.56	54% 54%	0.43 0.44	0.15 0.16	1	0	0.25			0.00	0.00
NC	1200	1209 Ceiling R-0 to R-49 Insulation (HP cooling)	Single Family	2014	2053	58.02	34.47	0.04	68.32	54%	0.02	40.59	54%	2.11	0.16	4	0	0.05			0.00	0.00
NC NC	1200 1200	1220 Duct Testing and Sealing (HP cooling)	Single Family	2014	2053 2053	57.47 54.86	34.14 32.59	0.54 2.62	68.86 71.47	55% 57%	0.32 1.55	40.91 42.46	55% 57%	0.55 0.45	0.16	1	0	0.19 0.18			0.00	0.00
NC NC	1200	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling) 1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling)		2014 2014	2053	54.86	32.59	0.81	71.47	57% 57%	0.48	42.46	57% 57%	0.45	0.17	1	0	0.18			0.00	0.00
NC	1200	1225 Ceiling Fans (HP cooling)	Single Family	2014	2053	53.62	31.86	0.43	72.71	58%	0.25	43.20	58%	0.73	0.18	1	Ö	0.13			0.00	0.00
NC	1200	1210 Ceiling R-11 to R-38 Insulaton (HP cooling)	Single Family	2014	2053	52.19	31.00	1.44	74.15	59%	0.85	44.05	59%	1.04	0.20	2	0	0.10			0.00	0.00
NC NC	1200 1200	1211 Ceiling R-11 to R-49 Insulation (HP cooling) 1216 Floor R-0 to R-19 Insulation-Batts (HP cooling)	Single Family Single Family	2014 2014	2053 2053	52.05 51.83	30.92 30.79	0.13 0.22	74.28 74.50	59% 59%	0.08	44.13 44.26	59% 59%	2.35 1.47	0.20	4 2	0	0.04 0.07			0.00	0.00
NC	1200	1212 Ceiling R-19 to R-38 Insulation (HP cooling)	Single Family	2014	2053	51.67	30.70	0.16	74.66	59%	0.09	44.35	59%	1.89	0.21	3	0	0.06			0.00	0.00
NC NC	1200 1200	1213 Ceiling R-19 to R-49 Insulation (HP cooling)	Single Family	2014 2014	2053	51.64 51.42	30.68 30.55	0.03	74.69 74.91	59%	0.02	44.37 44.50	59% 59%	2.37	0.21	4	0	0.04			0.00	0.00
NC NC	1200	1207 Heat Pump Filter Replacement 1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling)	Single Family Single Family	2014	2053 2053	51.42 51.26	30.55	0.22 0.16	74.91 75.07	59% 59%	0.13 0.10	44.50 44.60	59% 59%	2.22 4.83	0.21 0.22	4 8	0	0.03			0.00	0.00
NC	1200	1206 Heat pump tune up	Single Family	2014	2053	51.03	30.32	0.23	75.30	60%	0.14	44.74	60%	3.59	0.23	6	0	0.02			0.00	0.00
NC	1300	1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	Single Family	2014	2053	21.98	13.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	21.98	13.06	0.00	0.00
NC NC	1300 1300	1319 Duct Insulation (HP cooling Early Replacement) 1323 Self Install Weatherization (HP cooling Early Replacement)	Single Family Single Family	2014 2014	2053 2053	21.81 21.52	12.95 12.78	0.18 0.29	0.18 0.47	1% 2%	0.11 0.17	0.11 0.28	1% 2%	0.01 0.04	0.01	0	0	8.96 2.24			0.18 0.29	0.11 0.17
NC	1300	1321 Programmable Thermostat (HP cooling Early Replacement)	Single Family	2014	2053	21.08	12.52	0.44	0.90	4%	0.26	0.54	4%	0.07	0.05	0	0	1.25			0.44	0.26
NC	1300	1302 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Ea		2014	2053	17.51	10.40	3.57	4.47	20%	2.12	2.66	20%	0.08	0.07	0	0	1.20			3.57	2.12
NC NC	1300 1300	1304 Proper Refrigerant Charging and Air Flow (HP cooling Early Re 1324 Door Weatherization (HP cooling Early Replacement)	Single Family Single Family	2014 2014	2053 2053	16.25 15.89	9.66 9.44	1.26 0.36	5.73 6.09	26% 28%	0.75 0.22	3.40 3.62	26% 28%	0.10 0.08	0.08	0	0	0.84 0.87			0.00	0.00
NC	1300	1318 Cool Roof (HP cooling Early Replacement)	Single Family	2014	2053	14.23	8.45	1.66	7.75	35%	0.22	4.61	35%	0.08	0.08	0	0	0.53			0.00	0.00
NC	1300	1305 Proper Sizing and Quality Install (HP cooling Early Replacement		2014	2053	12.85	7.63	1.38	9.14	42%	0.82	5.43	42%	0.22	0.12	0	0	0.46			0.00	0.00
NC NC	1300 1300	1326 Whole House Fans (HP cooling early replacement) 1314 Crawlspace insulation (HP cooling Early Replacement)	Single Family Single Family	2014 2014	2053 2053	10.46 10.36	6.21 6.15	2.39	11.53 11.63	52% 53%	1.42	6.85 6.91	52% 53%	0.26	0.15	0	0	0.37 0.27			0.00	0.00
NC	1300	1308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)		2014	2053	10.36	6.03	0.10	11.83	54%	0.06	7.03	54%	0.39	0.15	1	0	0.24			0.00	0.00
NC	1300	1315 Basement insulation R-13 (HP cooling Early Replacement)	Single Family	2014	2053	10.07	5.98	0.08	11.91	54%	0.05	7.08	54%	0.44	0.16	1	0	0.24			0.00	0.00
NC NC	1300 1300	1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) 1320 Duct Testing and Sealing (HP cooling Early Replacement)	Single Family Single Family	2014 2014	2053 2053	10.06 9.97	5.98 5.92	0.01 0.09	11.92 12.01	54% 55%	0.00	7.08 7.14	54% 55%	2.15 0.56	0.16 0.16	4	0	0.05 0.18			0.00	0.00
NC NC	1300	1320 Duct Testing and Sealing (HP cooling Early Replacement) 1322 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling E		2014	2053	9.52	5.92 5.65	0.09	12.01	55% 57%	0.06	7.14	55% 57%	0.46	0.16	1	0	0.18			0.00	0.00
NC	1300	1327 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling	Single Family	2014	2053	9.38	5.57	0.14	12.61	57%	0.08	7.49	57%	0.70	0.18	1	Ō	0.15			0.00	0.00
NC	1300	1325 Ceiling Fans (HP cooling early replacement)	Single Family	2014	2053	9.30	5.53 5.38	0.07	12.68	58%	0.04	7.53	58% 59%	0.75	0.18	1	0	0.13			0.00	0.00
NC	1300	1310 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)	oingle Family	2014	2053	9.05	5.38	0.25	12.93	59%	0.15	7.68	59%	1.06	0.20	2	U	0.10			0.00	0.00

APPENDIX H

Base Avoided Costs

	Electric Existing Construction ST ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage	Existing		Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	
Sgmt Numb		Type Single Family	Year 2014	2053	9.03	MW 5.36	Savings 0.02	12.95	Savings 59%	Savings 0.01	7.70	Savings 59%	\$/kWH 2.39	\$/kWH 0.20	\$/kW 4	\$/kW	0.04	GWH	MW	0.00	0.00
NC 13	00 1316 Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replaceme S	Single Family	2014	2053	8.99	5.34	0.04	12.99	59%	0.02	7.72	59%	1.50	0.21	3	0	0.07			0.00	0.00
NC 13			2014 2014	2053 2053	8.96 8.96	5.33	0.03	13.02 13.03	59% 59%	0.02	7.74 7.74	59% 59%	1.92 2.42	0.21	3	0	0.05			0.00	0.00
NC 13		Single Family Single Family	2014	2053	8.96 8.92	5.32 5.30	0.01	13.03	59% 59%	0.00	7.74	59% 59%	2.42	0.21	4	0	0.04			0.00	0.00
NC 13			2014	2053	8.89	5.28	0.03	13.09	60%	0.02	7.78	60%	4.91	0.23	8	0	0.02			0.00	0.00
NC 13		Single Family	2014	2053	8.85	5.26	0.04	13.13	60%	0.02	7.80	60%	3.65	0.24	6	0	0.02			0.00	0.00
NC 14		Single Family Single Family	2014 2014	2053 2053	6.82 6.73	4.05 4.00	0.00	0.00 0.09	0% 1%	0.00	0.00 0.05	0% 1%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.77	6.82	4.05	0.00 0.09	0.00 0.05
NC 14		Single Family	2014	2053	6.60	3.92	0.13	0.22	3%	0.08	0.13	3%	0.23	0.15	0	0	0.30			0.00	0.00
NC 14		Single Family	2014	2053	5.91	3.51	0.69	0.91	13%	0.41	0.54	13%	0.45	0.38	1	1	0.21			0.00	0.00
NC 14		Single Family Single Family	2014 2014	2053 2053	5.58 4.41	3.31 2.62	0.33 1.17	1.24 2.41	18% 35%	0.20	0.74 1.43	18% 35%	0.43 0.49	0.39	1	1	0.18 0.17			0.00	0.00
NC 14	00 1416 Whole House Fans (RAC) S	Single Family	2014	2053	3.59	2.13	0.82	3.23	47%	0.49	1.92	47%	0.79	0.53	1	i	0.12			0.00	0.00
NC 14		Single Family	2014	2053	3.53	2.10	0.05	3.28	48%	0.03	1.95	48%	1.24	0.54	2	1	0.08			0.00	0.00
NC 14		Single Family Single Family	2014 2014	2053 2053	3.47	2.06 1.95	0.07	3.35 3.54	49% 52%	0.04	1.99 2.10	49% 52%	1.41	0.56	2	1	0.07			0.00	0.00
NC 14		Single Family	2014	2053	3.28	1.95	0.00	3.54	52%	0.00	2.10	52%	8.33	0.59	14	i	0.07			0.00	0.00
NC 14	00 1415 Ceiling Fans (RAC) S	Single Family	2014	2053	3.25	1.93	0.03	3.56	52%	0.02	2.12	52%	2.21	0.60	4	1	0.04			0.00	0.00
NC 14		Single Family	2014	2053	3.24	1.92	0.01	3.58	52%	0.01	2.13	52%	3.53	0.61	6	1	0.03			0.00	0.00
NC 14		Single Family Single Family	2014 2014	2053 2053	3.16 3.01	1.88 1.79	0.08 0.15	3.65 3.81	54% 56%	0.05	2.17 2.26	54% 56%	3.55 2.85	0.68	6 5	1	0.03			0.00	0.00
NC 14	00 1407 Ceiling R-11 to R-49 Insulation (RAC) S	Single Family	2014	2053	3.01	1.79	0.01	3.81	56%	0.00	2.26	56%	9.07	0.78	15	1	0.01			0.00	0.00
NC 14		Single Family	2014 2014	2053 2053	3.00	1.78 1.78	0.01 0.00	3.82 3.82	56% 56%	0.01	2.27 2.27	56% 56%	6.31 9.12	0.79 0.79	11 15	1	0.02 0.01			0.00	0.00
NC 14		Single Family	2014	2053	2.98	1.78	0.00	3.82	56%	0.00	2.27	56%	6.97	0.79	15	1	0.01			0.00	0.00
NC 15	00 1500 Base Room Air Conditioner, Early Replacement - EER 9.7 S	Single Family	2014	2053	2.03	1.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.03	1.21	0.00	0.00
NC 15			2014	2053	1.76	1.05	0.27	0.27	13%	0.16	0.16	13%	0.73	0.73	1	1	0.11			0.00	0.00
NC 16		Single Family	2014 2014	2053 2053	1.49 1.26	0.88 0.75	0.00 0.23	0.00 0.23	0% 15%	0.00	0.00 0.13	0% 15%	N/A 0.18	N/A 0.18	N/A 0	N/A 0	N/A 0.48	1.49	0.88	0.00	0.00
NC 17		Single Family	2014	2053	85.65	43.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	85.65	43.93	0.00	0.00
NC 17		Single Family	2014	2053	47.58	24.41	38.07	38.07	44%	19.53	19.53	44%	0.03	0.03	0	0	3.47			38.07	19.53
NC 200 NC 200		Single Family Single Family	2014 2014	2053 2053	167.75 166.38	19.90 19.74	0.00 1.37	0.00 1.37	0% 1%	0.00	0.00 0.16	0% 1%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.49	167.75	19.90	0.00 1.37	0.00
NC 20		Single Family	2014	2053	164.19	19.48	2.19	3.56	2%	0.26	0.42	2%	0.03	0.02	ō	0	2.01			2.19	0.26
NC 20	00 2019 Programmable Thermostat (HP heating) S	Single Family	2014	2053	160.87	19.09	3.33	6.88	4%	0.39	0.82	4%	0.05	0.04	0	0	1.09			3.33	0.39
NC 20 NC 20		Single Family Single Family	2014	2053 2053	158.99 144.34	18.86 17.13	1.88 14.65	8.76 23.41	5% 14%	0.22 1.74	1.04 2.78	5% 14%	0.09 0.11	0.05	1	0	0.57			0.00	0.00
NC 20	00 2018 Heat Recovery Ventilators (HP heating) S	Single Family	2014	2053	113.02	13.41	31.32	54.73	33%	3.72	6.49	33%	0.16	0.13	1	1	0.42			0.00	0.00
NC 20		Single Family	2014	2053	112.55	13.35	0.47	55.20	33%	0.06	6.55	33%	0.21	0.13	2	1	0.32			0.00	0.00
NC 20	00 2006 Ceiling R-0 to R-38 Insulation (HP heating) S 00 2013 Basement insulation R-13 (HP heating) S	Single Family	2014 2014	2053 2053	110.33	13.09 13.04	2.22 0.39	57.42 57.81	34% 34%	0.26	6.81 6.86	34% 34%	0.23	0.13	2	1	0.29			0.00	0.00
NC 20		Single Family	2014	2053	109.87	13.04	0.07	57.88	35%	0.03	6.87	35%	1.16	0.14	10	1	0.06			0.00	0.00
NC 20		Single Family	2014	2053	104.87	12.44	5.00	62.88	37%	0.59	7.46	37%	0.25	0.14	2	1	0.23			0.00	0.00
NC 200 NC 200		Single Family	2014 2014	2053 2053	103.89 102.40	12.33 12.15	0.98 1.49	63.86 65.35	38% 39%	0.12 0.18	7.58 7.75	38% 39%	0.31 0.39	0.15 0.15	3	1	0.21 0.17			0.00	0.00
NC 20		Single Family	2014	2053	99.66	11.82	2.74	68.09	41%	0.33	8.08	41%	0.57	0.17	5	i	0.12			0.00	0.00
NC 20		Single Family	2014	2053	99.40	11.79	0.25	68.34	41%	0.03	8.11	41%	1.28	0.17	11	1	0.05			0.00	0.00
NC 20 NC 20		Single Family Single Family	2014 2014	2053 2053	99.22 98.92	11.77 11.74	0.19 0.30	68.53 68.83	41% 41%	0.02	8.13 8.17	41% 41%	0.80 1.02	0.18 0.18	7 9	1 2	0.08			0.00	0.00
NC 20	3	Single Family	2014	2053	90.17	10.70	8.75	77.58	46%	1.04	9.20	46%	2.07	0.39	17	3	0.07			0.00	0.00
NC 20	00 2011 Ceiling R-19 to R-49 Insulation (HP heating) S	Single Family	2014	2053	90.11	10.69	0.06	77.64	46%	0.01	9.21	46%	1.41	0.39	12	3	0.05			0.00	0.00
NC 200		Single Family Single Family	2014 2014	2053 2053	89.72 89.44	10.65 10.61	0.38 0.28	78.02 78.31	47% 47%	0.05	9.26 9.29	47% 47%	1.32 2.88	0.40	11 24	3	0.04 0.02			0.00	0.00
NC 20	00 2004 Heat pump tune up S	Single Family	2014	2053	89.04	10.56	0.40	78.70	47%	0.05	9.34	47%	2.14	0.42	18	4	0.02			0.00	0.00
NC 21			2014	2053	32.77	3.89	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	32.77	3.89	0.00	0.00
NC 21		Single Family Single Family	2014 2014	2053 2053	32.50 32.07	3.86 3.81	0.27 0.43	0.27 0.69	1% 2%	0.03	0.03	1% 2%	0.01	0.01	0	0	8.29 2.23			0.27 0.43	0.03
NC 21	00 2119 Programmable Thermostat (HP heating early replacement) S	Single Family	2014	2053	31.42	3.73	0.65	1.34	4%	0.08	0.16	4%	0.05	0.03	0	0	1.21			0.65	0.08
NC 21		Single Family	2014	2053	31.04	3.68	0.38	1.73	5%	0.05	0.21	5%	0.08	0.04	1	0	0.66			0.00	0.00
NC 21		Single Family Single Family	2014 2014	2053 2053	28.18 22.06	3.34 2.62	2.86 6.11	4.59 10.70	14% 33%	0.34 0.73	0.54 1.27	14% 33%	0.10 0.15	0.08	1	1	0.66 0.46			0.00	0.00
NC 21		Single Family	2014	2053	21.54	2.56	0.52	11.22	34%	0.06	1.33	34%	0.13	0.12	2	1	0.36			0.00	0.00
NC 21		Single Family	2014	2053	21.12	2.51	0.42	11.65	36%	0.05	1.38	36%	0.22	0.12	2	1	0.31			0.00	0.00
NC 21		Single Family Single Family	2014 2014	2053 2053	20.69	2.46	0.43	12.07 12.09	37% 37%	0.05	1.43	37% 37%	0.22 1.09	0.13	2 9	1	0.31			0.00	0.00
NC 21			2014	2053	19.74	2.45	0.01	13.03	40%	0.00	1.43	40%	0.23	0.13	2	1	0.06			0.00	0.00
NC 21	00 2117 Duct Testing and Sealing (HP heating early replacement) S	Single Family	2014	2053	19.55	2.32	0.18	13.21	40%	0.02	1.57	40%	0.29	0.14	2	1	0.22			0.00	0.00
NC 21			2014 2014	2053 2053	19.27 18.76	2.29 2.23	0.28 0.52	13.49 14.01	41% 43%	0.03	1.60 1.66	41% 43%	0.37 0.53	0.14 0.16	3	1	0.18 0.13			0.00	0.00
NC 21			2014	2053	18.76	2.23	0.52	14.01	43%	0.06	1.67	43%	1.20	0.16	10	1	0.13			0.00	0.00
NC 21	00 2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replaceme S	Single Family	2014	2053	18.51	2.20	0.20	14.26	44%	0.02	1.69	44%	0.75	0.17	6	1	0.09			0.00	0.00
NC 21			2014 2014	2053	18.46 16.82	2.19	0.06 1.63	14.31	44%	0.01	1.70	44% 49%	0.97	0.17	8 17	1	0.07			0.00	0.00
NC 21	2103 Ground Source Heat Pump with Desuperheater (HP heating ear S	single Family	2014	2053	16.82	2.00	1.63	15.94	49%	0.19	1.89	49%	1.96	0.35	17	3	0.03			0.00	0.00

APPENDIX H

Base Avoided Costs

		ic Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage		xisting		Measure	Measure		20.4		Total Energy	Percent		Total Capacity	Percent	Marginal	Average Energy	Marginal Capacity	Average Capacity	Total Resource			00.121	
		easure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Energy Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	
Sgmt N	2100	umber Measure 2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement)	Type Single Family	Year 2014	2053	16.81	MW 1.99	Savings 0.01	15.96	Savings 49%	Savings 0.00	MW 1.89	Savings 49%	\$/kWH 1.34	\$/kWH 0.36	\$/kW	\$/kW	0.05	GWH	MW	0.00	0.00
NC	2100	2105 Heat Pump Filter Replacement (heating)	Single Family	2014	2053	16.74	1.99	0.07	16.03	49%	0.01	1.90	49%	1.25	0.36	11	3	0.04			0.00	0.00
NC NC	2100 2100	2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacer 2104 Heat pump tune up (heating)	Single Family Single Family	2014 2014	2053 2053	16.69 16.61	1.98 1.97	0.05	16.08 16.15	49% 49%	0.01	1.91 1.92	49% 49%	2.72	0.37 0.37	23 17	3	0.02			0.00	0.00
NC	2200	2200 Base Resistance Space Heating (Primary)	Single Family	2014	2053	78.22	9.28	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	78.22	9.28	0.00	0.00
NC NC	2200 2200	2201 Air Source Heat Pump (resistance heating)	Single Family Single Family	2014 2014	2053 2053	62.31 61.49	7.39 7.30	15.91 0.82	15.91 16.73	20% 21%	1.89 0.10	1.89 1.99	20% 21%	0.02	0.02	0	0	3.45 1.80			15.91 0.82	1.89 0.10
NC	2200	2216 Self Install Weatherization 2214 Programmable Thermostat (resistance heating)	Single Family	2014	2053	60.24	7.30	1.25	17.98	23%	0.10	2.13	23%	0.05	0.02	0	0	1.26			1.25	0.10
NC	2200	2217 Door Weatherization (resistance heating)	Single Family	2014	2053	59.04	7.00	1.21	19.19	25%	0.14	2.28	25%	0.06	0.02	0	0	0.87			0.00	0.00
NC NC	2200 2200	2213 Heat Recovery Ventilators (resistance heating) 2203 Ceiling R-0 to R-38 Insulation (resistance heating)	Single Family Single Family	2014 2014	2053 2053	46.23 45.24	5.48 5.37	12.81 0.98	32.00 32.98	41% 42%	1.52 0.12	3.80 3.91	41% 42%	0.17 0.22	0.08	1 2	1	0.41			0.00	0.00
NC	2200	2209 Crawlspace insulation (resistance heating)	Single Family	2014	2053	44.83	5.32	0.41	33.39	43%	0.05	3.96	43%	0.24	0.09	2	1	0.28			0.00	0.00
NC NC	2200 2200	2210 Basement insulation R-13 (resistance heating) 2204 Ceiling R-0 to R-49 Insulation (resistance heating)	Single Family Single Family	2014 2014	2053 2053	44.24 44.22	5.25 5.25	0.59 0.02	33.98 34.00	43% 43%	0.07	4.03 4.03	43% 43%	0.25 1.42	0.09	2 12	1	0.27 0.05			0.00	0.00
NC	2200	2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance he		2014	2053	42.21	5.01	2.01	36.02	46%	0.00	4.03	46%	0.26	0.09	2	1	0.03			0.00	0.00
NC NC	2200 2200	2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance h		2014	2053	41.52	4.93 4.78	0.69	36.71 37.91	47% 48%	0.08	4.36 4.50	47% 48%	0.35	0.10	3	1	0.19			0.00	0.00
NC NC	2200	2205 Ceiling R-11 to R-38 Insulaton (resistance heating) 2211 Floor R-0 to R-19 Insulation-Batts (resistance heating)	Single Family Single Family	2014	2053 2053	40.31 40.06	4.78 4.75	1.21 0.25	38.16	48% 49%	0.14	4.50	48% 49%	0.54	0.12	5 5	1	0.13 0.12			0.00	0.00
NC	2200	2206 Ceiling R-11 to R-49 Insulation (resistance heating)	Single Family	2014	2053	39.97	4.74	0.09	38.25	49%	0.01	4.54	49%	1.56	0.12	13	1	0.04			0.00	0.00
NC NC	2200 2200	2207 Ceiling R-19 to R-38 Insulation (resistance heating)	Single Family Single Family	2014 2014	2053 2053	39.83 39.81	4.73 4.72	0.14 0.02	38.39 38.41	49% 49%	0.02	4.55 4.56	49% 49%	0.93 1.57	0.13 0.13	8 13	1	0.07 0.04			0.00	0.00
NC	2200	2208 Ceiling R-19 to R-49 Insulation (resistance heating) 2202 Ground Source Heat Pump with Desuperheater (resistance heat		2014	2053	39.48	4.68	0.33	38.74	50%	0.04	4.60	50%	26.32	0.35	222	3	0.00			0.00	0.00
NC	2200	2212 Wall Blow-in R-0 to R-13 Insulation (resistance heating)	Single Family	2014	2053	39.31	4.66	0.17	38.91	50%	0.02	4.62	50%	1.97	0.36 N/A	17	3	0.03	4.00	0.45	0.00	0.00
NC NC	3030 3030	3030 Base Halogen Lighting - 0.5 hrs/day 2020 3032 LEDs (base Halogen 0.5 hrs/day) 2020	Single Family Single Family	2020 2020	2053 2053	4.06 1.30	0.45 0.15	0.00 2.76	0.00 2.76	0% 68%	0.00	0.00 0.31	0% 68%	N/A 0.04	0.04	N/A 0	N/A 0	N/A 2.16	4.06	0.45	0.00 2.76	0.00 0.31
NC	3130	3130 Base Halogen Lighting - 2.5 hrs/day 2020	Single Family	2020	2053	16.58	1.86	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.58	1.86	0.00	0.00
NC NC	3130 3230	3132 LEDs (base Halogen 2.5 hrs/day) 2020 3230 Base Halogen Lighting - 6 hrs/day 2020	Single Family Single Family	2020	2053 2053	4.34 10.97	0.49 1.23	12.24	12.24	74% 0%	1.37	1.37	74% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	11.68 N/A	10.97	1.23	12.24	1.37
NC	3230	3232 LEDs (base Halogen 6 hrs/day) 2020	Single Family	2020	2053	3.51	0.39	7.47	7.47	68%	0.84	0.84	68%	0.00	0.00	0	0	16.02	10.57	1.23	7.47	0.84
NC	3330 3330	3330 Base CFL Lighting - 0.5 hrs/day 2020	Single Family	2020	2053	1.87	0.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.87	0.21	0.00	0.00
NC NC	3330	3331 LEDs (base CFL 0.5 hrs/day) 2020 3430 Base CFL Lighting - 2.5 hrs/day 2020	Single Family Single Family	2020	2053 2053	1.37 7.58	0.15 0.85	0.51	0.51 0.00	27% 0%	0.06	0.06	27% 0%	0.20 N/A	0.20 N/A	2 N/A	2 N/A	0.38 N/A	7.58	0.85	0.00	0.00
NC	3430	3431 LEDs (base CFL 2.5 hrs/day) 2020	Single Family	2020	2053	5.54	0.62	2.05	2.05	27%	0.23	0.23	27%	0.04	0.04	0	0	1.87			2.05	0.23
NC NC	3530 3530	3530 Base CFL Lighting - 6 hrs/day 2020	Single Family	2020	2053 2053	4.94 3.61	0.55 0.40	0.00 1.33	0.00 1.33	0% 27%	0.00 0.15	0.00 0.15	0% 27%	N/A	N/A	N/A 0	N/A 0	N/A	4.94	0.55	0.00 1.33	0.00
NC	3630	3531 LEDs (base CFL 6 hrs/day) 2020 3630 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	Single Family Single Family	2020	2053	8.78	0.40	0.00	0.00	0%	0.00	0.00	0%	0.02 N/A	0.02 N/A	N/A	N/A	2.76 N/A	8.78	0.98	0.00	0.00
NC	3630	3632 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Single Family	2020	2053	3.47	0.39	5.31	5.31	60%	0.59	0.59	60%	0.01	0.01	0	0	6.46			5.31	0.59
NC NC	3730 3730	3730 Base Halogen (Specialty) Lighting - 2.5 hrs/day 2020 3732 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family Single Family	2020 2020	2053 2053	36.55 14.44	4.09 1.62	0.00 22.11	0.00 22.11	0% 60%	0.00 2.47	0.00 2.47	0% 60%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 32.48	36.55	4.09	0.00 22.11	0.00 2.47
NC	3830	3830 Base Halogen (Specialty) Lighting - 6 hrs/day 2020	Single Family	2020	2053	24.20	2.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	24.20	2.71	0.00	0.00
NC NC	3830 3900	3832 LEDs (base Halogen (Specialty) 6 hrs/day) 2020 3900 Base Fluorescent Fixture 1.8 hrs/day	Single Family Single Family	2020 2014	2053 2053	9.56 54.27	1.07 6.08	14.63	14.63	60% 0%	1.64	1.64 0.00	60% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	48.22 N/A	54.27	6.08	14.63	1.64
NC	3900	3902 ROB 2L4'T8, 1EB	Single Family	2014	2053	39.63	4.44	14.64	14.64	27%	1.64	1.64	27%	0.04	0.04	0	0	2.16	34.27	0.00	14.64	1.64
NC	4000	4000 Base Refrigerator	Single Family	2014	2053	47.87	7.76	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	47.87	7.76	0.00	0.00
NC NC	4000 4100	4001 Refrigerator (Energy Star) 4100 Base RefrigeratorEarly Replacement	Single Family Single Family	2014 2014	2053 2053	40.33 6.82	6.54 1.11	7.53 0.00	7.53 0.00	16% 0%	1.22 0.00	1.22 0.00	16% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	1.70 N/A	6.82	1.11	7.53 0.00	1.22 0.00
NC	4100	4101 Refrigerator - Early Replacement (Energy Star)	Single Family	2014	2053	3.77	0.61	3.05	3.05	45%	0.49	0.49	45%	0.09	0.09	1	1	0.56			0.00	0.00
NC NC	4200 4200	4200 Base 2nd Refrigerator - Recycling 4201 2nd Refrigerator Recycling	Single Family Single Family	2014 2014	2053 2053	23.56 6.07	3.82 0.98	0.00 17.49	0.00 17.49	0% 74%	0.00 2.84	0.00 2.84	0% 74%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.10	23.56	3.82	0.00 17.49	0.00 2.84
NC	4500	4500 Base Freezer	Single Family	2014	2053	31.46	5.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	31.46	5.10	0.00	0.00
NC	4500	4501 Freezer (Energy Star)	Single Family	2014	2053	28.69	4.65	2.77	2.77	9%	0.45	0.45	9%	0.05	0.05	0	0	1.31		4.04	2.77	0.45
NC NC	4600 4600	4600 Base Early Replacement Freezer 4601 Freezer - Early Replacement (Energy Star)	Single Family Single Family	2014 2014	2053 2053	6.58 3.02	1.04 0.48	0.00 3.56	0.00 3.56	0% 54%	0.00	0.00 0.56	0% 54%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.34	6.58	1.04	0.00 3.56	0.00 0.56
NC	4700	4700 Base 2nd Freezer Recycling	Single Family	2014	2053	7.09	1.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.09	1.12	0.00	0.00
NC NC	4700 5000	4701 2nd Freezer Recycling 5000 Base Water Heating (40 gal, EF=0.88)	Single Family Single Family	2014 2014	2053 2053	3.58 189.05	0.57 23.28	3.51 0.00	3.51 0.00	50% 0%	0.56	0.56 0.00	50% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	3.29 N/A	189.05	23.28	3.51 0.00	0.56 0.00
NC	5000	5000 base Water Heating (40 gai, Er=0.66) 5006 Pipe Wrap	Single Family	2014	2053	183.24	22.57	5.81	5.81	3%	0.00	0.72	3%	0.02	0.02	0	0	3.19	100.00	20.20	5.81	0.00
NC	5000	5007 Hot water turndown 5 degrees	Single Family	2014	2053	182.60	22.49	0.64	6.45	3%	0.08	0.79	3%	0.02	0.02	0	0	2.37			0.64	0.08
NC NC	5000 5000	5009 Hot water turndown 15 degrees 5010 Hot water turndown 20 degrees	Single Family Single Family	2014 2014	2053 2053	182.40 182.32	22.46 22.46	0.20 0.08	6.65 6.73	4% 4%	0.03	0.82 0.83	4% 4%	0.02	0.02	0	0	2.36 2.36			0.20 0.08	0.03 0.01
NC	5000	5008 Hot water turndown 10 degrees	Single Family	2014	2053	181.46	22.35	0.86	7.59	4%	0.11	0.94	4%	0.02	0.02	0	0	2.36			0.86	0.11
NC NC	5000 5000	5015 Low Flow Showerhead 1.5 Gal/Min 5011 Drain Water Heat Recovery (GFX)	Single Family Single Family	2014 2014	2053 2053	176.03 169.42	21.68	5.42 6.62	13.02 19.63	7% 10%	0.67	1.60 2.42	7% 10%	0.03	0.02	0	0	2.01			5.42 6.62	0.67
NC NC	5000	5011 Drain Water Heat Recovery (GFX) 5014 Faucent Aerators	Single Family	2014	2053	165.83	20.87	3.59	23.22	12%	0.81	2.42	10%	0.05	0.03	0	0	0.99			0.00	0.00
NC	5000	5005 DHW Tank Wrap	Single Family	2014	2053	156.73		9.10	32.32	17%	1.12	3.98	17%	0.05	0.04	0	0	0.91			0.00	0.00
NC NC	5000 5000	5003 Heat Pump Water Heater - Energy Star 5004 Solar Domestic Water Heating	Single Family Single Family	2014 2014	2053 2053	133.71 71.07	16.47 8.75	23.02 62.64	55.34 117.99	29% 62%	2.84 7.72	6.82 14.53	29% 62%	0.08	0.06	1 2	0	0.80			0.00	0.00
NC	5000	5012 Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family	2014	2053	70.88	8.73	0.19	118.17	63%	0.02	14.55	63%	4.86	0.13	39	1	0.01			0.00	0.00
NC	5000	5013 Energy Star Dishwasher (EF=0.72)	Single Family	2014 2014	2053	70.72	8.71	0.15	118.33	63%	0.02	14.57	63%	4.54 N/A	0.14	37	1	0.01 N/A	22.26	4 4 4	0.00	0.00
NC NC	5100 5100	5100 Base Water Heating Early Replacement to Heat Pump Water F 5101 Heat Pump Water Heater - Energy Star - Early Replacement	Single Family	2014	2053 2053	33.36 28.60	4.11 3.52	0.00 4.76	0.00 4.76	0% 14%	0.00	0.00 0.59	0% 14%	N/A 0.08	N/A 0.08	N/A 1	N/A 1	N/A 0.81	33.36	4.11	0.00	0.00
NC	5500	5500 Base Clotheswasher (MEF=1.26)	Single Family	2014	2053	3.38	0.61	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.38	0.61	0.00	0.00
NC NC	5500 5600	5501 Energy Star CW CEE Tier 2 (MEF=2.0) 5600 Base Clothes Dryer (EF=3.01)	Single Family Single Family	2014 2014	2053 2053	2.56 50.79	0.46 8.60	0.81	0.81	24% 0%	0.15	0.15 0.00	24% 0%	1.33 N/A	1.33 N/A	7 N/A	7 N/A	0.05 N/A	50.79	8.60	0.00	0.00
INC	3000	JOGO DAGO CIULIES DI YEI (ET =3.01)	Unique Faililly	2014	2000	30.79	0.00	0.00	0.00	0 /0	0.00	0.00	U /0	IN/A	13/75	IN//A	13/73	IN/A	30.13	0.00	0.00	0.00

H-11 DNV GL 1/5/2015

APPENDIX H

Base Avoided Costs

		ic Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage		disting		Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity		Total Resource				
Ba Sgmt Nu		easure umber Measure	Building Type	Start	End	Total GWH	Total MW	GWH Savings	Savings	GWH	MW Savings	Savings	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
NC	5600	5602 High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family	2014	2053	41.46	7.02	9.33	9.33	18%	1.58	1.58	18%	0.05	0.05	0	0	1.36	GWH	INIAA	9.33	1.58
NC NC	5600 5700	5601 Heat Pump Dryer 5700 Base Dishwasher (EF=0.65)	Single Family Single Family	2014 2014	2053 2053	20.73 6.77	3.51 1.11	20.73 0.00	30.06 0.00	59% 0%	3.51 0.00	5.09 0.00	59% 0%	0.75 N/A	0.53 N/A	4 N/A	3 N/A	0.08 N/A	6.77	1.11	0.00	0.00
NC	5700	5701 Energy Star Dishwasher (EF=0.72)	Single Family	2014	2053	6.53	1.07	0.24	0.24	4%	0.04	0.04	4%	1.70	1.70	10	10	0.04			0.00	0.00
NC NC	6000 6000	6000 Base Single Speed Pool Pump (RET) 6002 Variable-Speed Pool Pump (<1 hp)	Single Family Single Family	2014 2014	2053 2053	13.47 3.73	1.60 0.44	0.00 9.74	0.00 9.74	0% 72%	0.00 1.16	0.00 1.16	0% 72%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.79	13.47	1.60	0.00 9.74	0.00 1.16
NC	6000	6001 PV-Powered Pool Pumps	Single Family	2014	2053	0.15	0.02	3.58	13.32	99%	0.43	1.58	99%	1.02	0.30	9	2	0.06			0.00	0.00
NC NC	7000 7000	7000 Base Plasma TV 7001 Energy Star Plasma TV	Single Family	2014 2014	2053 2053	9.20 8.40	1.33 1.21	0.00	0.00 0.80	0% 9%	0.00	0.00 0.12	0% 9%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.16	9.20	1.33	0.00	0.00 0.12
NC	7000	7002 Plug Load Controls - Smart Power Strip (base plasma TV)	Single Family Single Family	2014	2053	8.34	1.20	0.06	0.86	9%	0.12	0.12	9%	4.37	0.01	30	2	0.01			0.00	0.12
NC	7100	7100 Base LCD TV	Single Family	2014	2053	10.93	1.58	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.93	1.58	0.00	0.00
NC NC	7100 7100	7101 Energy Star LCD TV 7102 Plug Load Controls - Smart Power Strip (base LCD TV)	Single Family Single Family	2014 2014	2053 2053	7.16 7.01	1.03 1.01	3.77 0.15	3.77 3.92	34% 36%	0.54	0.54 0.57	34% 36%	0.00 4.68	0.00 0.18	0 32	0	13.61 0.01			3.77 0.00	0.54
NC	7200	7200 Base CRT TV	Single Family	2014	2053	5.33	0.77	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.33	0.77	0.00	0.00
NC NC	7200 7300	7202 Plug Load Controls - Smart Power Strip (base CRT TV) 7300 Base Set-Top Box	Single Family Single Family	2014 2014	2053 2053	5.02 15.22	0.72 2.20	0.31	0.31 0.00	6% 0%	0.04	0.04	6% 0%	1.29 N/A	1.29 N/A	9 N/A	9 N/A	0.04 N/A	15.22	2.20	0.00	0.00
NC	7400	7400 Base DVD Player	Single Family	2014	2053	1.66	0.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.66	0.24	0.00	0.00
NC NC	7400 7400	7401 Energy Star DVD Player 7402 Plug Load Controls - Smart Power Strip (base DVD player)	Single Family	2014 2014	2053 2053	0.78	0.11 0.01	0.88	0.88 1.57	53% 95%	0.13	0.13	53% 95%	0.02	0.02	0 6	0 3	3.40			0.88	0.13
NC	7500	7500 Base Desktop PC	Single Family Single Family	2014	2053	17.75	2.34	0.70	0.00	0%	0.00	0.23	0%	0.80 N/A	0.36 N/A	N/A	N/A	0.06 N/A	17.75	2.34	0.00	0.00
NC	7500	7501 Energy Star Desktop PC	Single Family	2014	2053	15.66	2.06	2.09	2.09	12%	0.28	0.28	12%	0.00	0.00	0	0	13.68			2.09	0.28
NC NC	7500 7600	7502 Plug Load Controls - Smart Power Strip (base Desktop PC) 7600 Base Laptop PC	Single Family Single Family	2014 2014	2053 2053	11.27 2.54	1.48 0.33	4.39 0.00	6.48 0.00	37% 0%	0.58	0.85	37% 0%	0.08 N/A	0.06 N/A	1 N/A	0 N/A	0.62 N/A	2.54	0.33	0.00	0.00
NC	7600	7601 Energy Star Laptop PC	Single Family	2014	2053	2.13	0.28	0.40	0.40	16%	0.05	0.05	16%	0.03	0.03	0	0	2.05			0.40	0.05
NC NC	9000	8000 Base Cooking 9000 Base Miscellaneous	Single Family Single Family	2014 2014	2053 2053	47.21 67.94	15.07 8.95	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	47.21 67.94	15.07 8.95	0.00	0.00
NC	9900	9900 Base House Use	Single Family	2014	2053	1,379.15	341.51	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1,379.15	341.51	0.00	0.00
NC	9900	9901 Indirect Feedback	Single Family	2014	2053	1,358.66		20.48	20.48	1%	5.07	5.07	1%	0.02	0.02	0	0	2.68			20.48	5.07
NC NC	9900 1000	9902 Direct Feedback 1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	Single Family Multi-Family	2014 2014	2053 2053	1,294.61 7.75	320.58 4.60	64.05 0.00	84.53 0.00	6% 0%	15.86 0.00	20.93 0.00	6% 0%	0.05 N/A	0.04 N/A	0 N/A	N/A	1.05 N/A	7.75	4.60	64.05 0.00	15.86 0.00
NC	1000	1024 Self Install Weatherization (CAC)	Multi-Family	2014	2053	7.63	4.53	0.12	0.12	2%	0.07	0.07	2%	0.02	0.02	0	0	3.90			0.12	0.07
NC NC	1000 1000	1025 Door Weatherization (CAC) 1004 Proper Refrigerant Charging and Air Flow (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	7.26 6.74	4.31 4.00	0.37 0.52	0.49 1.01	6% 13%	0.22	0.29 0.60	6% 13%	0.07 0.12	0.06	0	0	0.94 0.65			0.00	0.00
NC	1000	1019 Duct Insulation (CAC)	Multi-Family	2014	2053	6.72	3.99	0.01	1.03	13%	0.01	0.61	13%	0.18	0.09	ō	Ö	0.59			0.00	0.00
NC NC	1000	1022 Programmable Thermostat (CAC) 1001 14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	6.67 6.24	3.96 3.71	0.05	1.08 1.51	14% 19%	0.03	0.64	14% 19%	0.15 0.21	0.10	0	0	0.58			0.00	0.00
NC	1000	1021 Return Duct Modification (CAC)	Multi-Family	2014	2053	6.21	3.69	0.43	1.54	20%	0.02	0.92	20%	0.24	0.13	0	0	0.43			0.00	0.00
NC	1000	1002 15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Multi-Family	2014	2053	5.84	3.47	0.37	1.91	25%	0.22	1.14	25%	0.25	0.16	0	0	0.40			0.00	0.00
NC NC	1000	1026 Ceiling Fans (CAC) 1014 Crawlspace insulation (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	5.53 5.51	3.28 3.27	0.31 0.02	2.23 2.25	29% 29%	0.18	1.32 1.33	29% 29%	0.28	0.17 0.17	0 1	0	0.34 0.32			0.00	0.00
NC	1000	1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Multi-Family	2014	2053	4.92	2.92	0.58	2.83	37%	0.35	1.68	37%	0.35	0.21	1	0	0.29			0.00	0.00
NC NC	1000 1000	1008 Ceiling R-0 to R-38 Insulation (CAC) 1023 Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	4.51 4.31	2.68 2.56	0.41 0.21	3.24 3.45	42% 44%	0.24	1.93 2.05	42% 44%	0.63 0.54	0.26 0.28	1	0	0.17 0.15			0.00	0.00
NC	1000	1030 WINDOWS - Double-Glazed Clear to Energy Star (CAC)	Multi-Family	2014	2053	4.21	2.50	0.10	3.54	46%	0.06	2.10	46%	0.74	0.29	1	Ö	0.14			0.00	0.00
NC NC	1000 1000	1005 Proper Sizing and Quality Install (CAC) 1020 Duct Testing and Sealing (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	3.80 3.70	2.26 2.20	0.41 0.10	3.95 4.05	51% 52%	0.24	2.35 2.41	51% 52%	0.82	0.35 0.36	1 2	1	0.12 0.11			0.00	0.00
NC	1000	1009 Ceiling R-0 to R-49 Insulation (CAC)	Multi-Family	2014	2053	3.70	2.20	0.00	4.05	52%	0.00	2.41	52%	8.89	0.37	15	1	0.01			0.00	0.00
NC	1000	1029 WINDOWS - Default With Sunscreen (CAC)	Multi-Family	2014	2053	3.44	2.04	0.26	4.31	56%	0.15	2.56	56%	1.06	0.41	2	1	0.08			0.00	0.00
NC NC	1000 1000	1010 Ceiling R-11 to R-38 Insulaton (CAC) 1018 Cool Roof (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	3.39 3.28	2.01 1.95	0.05 0.11	4.36 4.47	56% 58%	0.03	2.59 2.65	56% 58%	2.00 1.90	0.43	3	1	0.05 0.05			0.00	0.00
NC	1000	1017 Wall Blow-in R-0 to R-13 Insulation (CAC)	Multi-Family	2014	2053	3.25	1.93	0.03	4.50	58%	0.02	2.67	58%	2.44	0.48	4	1	0.04			0.00	0.00
NC NC	1000 1000	1028 Window Film (CAC) 1027 Whole House Fans (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	3.06 2.88	1.82 1.71	0.19 0.18	4.69 4.87	61% 63%	0.11 0.11	2.79 2.89	61% 63%	1.91 2.40	0.54 0.61	3 4	1	0.04 0.04			0.00	0.00
NC	1000	1011 Ceiling R-11 to R-49 Insulation (CAC)	Multi-Family	2014	2053	2.88	1.71	0.00	4.87	63%	0.00	2.89	63%	11.43	0.61	19	1	0.01			0.00	0.00
NC NC	1000 1000	1012 Ceiling R-19 to R-38 Insulation (CAC) 1013 Ceiling R-19 to R-49 Insulation (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	2.87 2.87	1.71 1.71	0.01 0.00	4.88 4.88	63% 63%	0.00	2.90 2.90	63% 63%	3.98 11.46	0.61 0.62	7 19	1	0.03 0.01			0.00	0.00
NC	1000	1016 Floor R-0 to R-19 Insulation (CAC)	Multi-Family	2014	2053	2.86	1.71	0.00	4.89	63%	0.00	2.90	63%	6.36	0.62	11	1	0.01			0.00	0.00
NC NC	1000 1000	1015 Basement insulation R-13 (CAC)	Multi-Family	2014 2014	2053 2053	2.85 2.84	1.69 1.69	0.01	4.90 4.91	63% 63%	0.00	2.91 2.92	63% 63%	6.44 7.74	0.64 0.65	11 13	1	0.02			0.00	0.00
NC NC	1000	1007 AC Filter Changes (CAC) 1006 AC Maintenance and/or tune-up (CAC)	Multi-Family Multi-Family	2014	2053	2.84	1.69	0.01	4.91 4.92	63%	0.01	2.92	63%	7.74 8.85	0.65	13 15	1 1	0.01			0.00	0.00
NC	1100	1100 Base Split-System Air Conditioner - Early Replacement (11 SE	El Multi-Family	2014	2053	2.32	1.38	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.32	1.38	0.00	0.00
NC NC	1100 1100	1122 Self Install Weatherization (CAC early replacement) 1117 Duct Insulation (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	2.28	1.36 1.35	0.04	0.04	2% 2%	0.02	0.02	2% 2%	0.01 0.02	0.01 0.02	0	0	6.61 4.58			0.04	0.02
NC	1100	1123 Door Weatherization (CAC early replacement)	Multi-Family	2014	2053	2.16	1.28	0.11	0.16	7%	0.06	0.10	7%	0.04	0.03	ō	Ō	1.54			0.11	0.06
NC NC	1100 1100	1102 Proper Refrigerant Charging and Air Flow (CAC early replacer 1120 Programmable Thermostat (CAC early replacement)	n Multi-Family Multi-Family	2014 2014	2053 2053	1.97 1.95	1.17 1.16	0.19	0.35 0.37	15% 16%	0.11	0.21 0.22	15% 16%	0.08	0.06	0	0	1.08			0.19	0.11
NC NC	1100	1120 Programmable Thermostat (CAC early replacement) 1119 Return Duct Modification (CAC early replacement)	Multi-Family Multi-Family	2014	2053	1.95	1.15	0.02	0.37	16%	0.01	0.22	16%	0.09	0.06	0	0	0.76			0.00	0.00
NC	1100	1112 Crawlspace insulation (CAC early replacement)	Multi-Family	2014	2053	1.93	1.15	0.01	0.38	17%	0.00	0.23	17%	0.17	0.06	0	0	0.64			0.00	0.00
NC NC	1100 1100	1116 Cool Roof (CAC early replacement) 1125 Whole House Fans (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	1.72 1.38	1.02 0.82	0.22 0.34	0.60 0.94	26% 40%	0.13	0.36 0.56	26% 40%	0.17 0.23	0.10 0.15	0	0	0.57 0.42			0.00	0.00
NC	1100	1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early	re Multi-Family	2014	2053	1.35	0.80	0.03	0.97	42%	0.02	0.58	42%	0.36	0.15	1	0	0.29			0.00	0.00
NC NC	1100 1100	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement) 1118 Duct Testing and Sealing (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	1.24 1.20	0.73 0.71	0.11 0.04	1.08 1.12	47% 48%	0.07	0.64 0.67	47% 48%	0.41 0.43	0.18 0.19	1	0	0.26 0.23			0.00	0.00
NC	1100	1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early r		2014	2053	1.14	0.68	0.05	1.17	51%	0.03	0.70	51%	0.36	0.20	1	0	0.23			0.00	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction IDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage		xisting		Manaura	Measure	. oui	2014		Total	Percent		Total	Percent	Marginal		Marginal		Total Resource			00.12.	
		leasure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Cost	Cost Test	Base	Base	Economic	
Sgmt N	umber N 1100	umber Measure 1103 Proper Sizing and Quality Install (CAC early replacement)	Type Multi-Family	Year 2014	2053	1.01	0.60	Savings 0.13	1.31	Savings 56%	Savings 0.08	0.78	Savings 56%	\$/kWH 0.55	\$/kWH 0.23	\$/kW 1	\$/kW	0.19	GWH	MW	0.00	0.00
NC	1100	1124 Ceiling Fans (CAC early replacement)	Multi-Family	2014	2053	0.98	0.58	0.03	1.34	58%	0.02	0.79	58%	0.58	0.24	1	Ō	0.16			0.00	0.00
NC NC	1100 1100	1107 Ceiling R-0 to R-49 Insulation (CAC early replacement) 1113 Basement insulation R-13 (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.98	0.58 0.58	0.00 0.01	1.34 1.35	58% 58%	0.00	0.79	58% 58%	5.90 0.68	0.24	10 1	0	0.02			0.00	0.00
NC	1100	1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Multi-Family	2014	2053	0.96	0.57	0.01	1.36	59%	0.01	0.81	59%	1.25	0.26	2	0	0.13			0.00	0.00
NC	1100		Multi-Family	2014	2053	0.91	0.54	0.05	1.41	61%	0.03	0.84	61%	1.05	0.28	2	0	0.08			0.00	0.00
NC NC	1100 1100	1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement) 1109 Ceiling R-11 to R-49 Insulation (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.90	0.54 0.54	0.01 0.00	1.42 1.42	61% 61%	0.01	0.84 0.84	61% 61%	1.55 6.44	0.29	3 11	0	0.07 0.02			0.00	0.00
NC	1100	1126 Window Film (CAC early replacement)	Multi-Family	2014	2053	0.86	0.51	0.04	1.46	63%	0.02	0.87	63%	1.56	0.33	3	1	0.05			0.00	0.00
NC NC	1100 1100	1110 Ceiling R-19 to R-38 Insulation (CAC early replacement) 1111 Ceiling R-19 to R-49 Insulation (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.86	0.51 0.51	0.00	1.46 1.46	63% 63%	0.00	0.87 0.87	63% 63%	2.35 6.76	0.33	4 11	1	0.04			0.00	0.00
NC	1100		Multi-Family	2014	2053	0.82	0.48	0.00	1.50	65%	0.00	0.89	65%	2.56	0.33	4	1	0.02			0.00	0.00
NC	1100	1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	Multi-Family	2014	2053	0.81	0.48	0.00	1.51	65%	0.00	0.90	65%	3.96	0.41	7	1	0.03			0.00	0.00
NC NC	1100 1100	1105 AC Filter Changes (CAC early replacement) 1104 AC Maintenance and/or tune-up (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.81	0.48 0.48	0.00	1.51 1.51	65% 65%	0.00	0.90 0.90	65% 65%	4.80 5.49	0.42	8	1	0.01 0.01			0.00	0.00
NC	1200	1200 Base Heat Pump Cooling (13 SEER)	Multi-Family	2014	2053	11.87	7.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.87	7.05	0.00	0.00
NC	1200	1219 Duct Insulation (HP cooling)	Multi-Family	2014	2053	11.77	6.99	0.10	0.10	1%	0.06	0.06	1%	0.03	0.03	0	0	3.83			0.10	0.06
NC NC	1200 1200	1223 Self Install Weatherization (HP cooling) 1224 Door Weatherization (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	11.58 11.02	6.88 6.55	0.19 0.56	0.28 0.85	2% 7%	0.11	0.17 0.50	2% 7%	0.04 0.05	0.04	0	0	2.06 1.29			0.19 0.56	0.11 0.33
NC	1200	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Multi-Family	2014	2053	9.15	5.44	1.87	2.71	23%	1.11	1.61	23%	0.09	0.08	0	0	1.08			1.87	1.11
NC	1200 1200	1204 Proper Refrigerant Charging and Air Flow (HP cooling)	Multi-Family	2014 2014	2053 2053	8.50 8.47	5.05	0.66	3.37	28%	0.39	2.00	28% 29%	0.11	0.08	0	0	0.75			0.00	0.00
NC NC	1200	1214 Crawlspace insulation (HP cooling) 1221 Programmable Thermostat (HP cooling)	Multi-Family Multi-Family	2014	2053	8.47	5.03 4.93	0.03 0.17	3.40 3.57	29% 30%	0.02	2.02 2.12	30%	0.23 0.21	0.08	0	0	0.45 0.42			0.00	0.00
NC	1200	1218 Cool Roof (HP cooling)	Multi-Family	2014	2053	7.37	4.38	0.93	4.49	38%	0.55	2.67	38%	0.24	0.12	0	0	0.39			0.00	0.00
NC NC	1200 1200	1226 Whole House Fans (HP cooling) 1208 Ceiling R-0 to R-38 Insulation (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	5.93 5.43	3.53 3.23	1.44 0.50	5.93 6.43	50% 54%	0.85	3.52 3.82	50% 54%	0.33	0.17	1	0	0.29			0.00	0.00
NC	1200	1220 Duct Testing and Sealing (HP cooling)	Multi-Family	2014	2053	5.43	3.23	0.50	6.59	56%	0.30	3.92	56%	0.61	0.20	1	0	0.19			0.00	0.00
NC	1200	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)	Multi-Family	2014	2053	5.03	2.99	0.24	6.83	58%	0.14	4.06	58%	0.51	0.22	1	0	0.16			0.00	0.00
NC NC	1200 1200	1205 Proper Sizing and Quality Install (HP cooling) 1209 Ceiling R-0 to R-49 Insulation (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	4.54 4.53	2.70 2.69	0.49 0.01	7.32 7.34	62% 62%	0.29	4.35 4.36	62% 62%	0.74 3.57	0.26	1 6	0	0.14 0.03			0.00	0.00
NC	1200	1225 Ceiling Fans (HP cooling)	Multi-Family	2014	2053	4.41	2.62	0.12	7.45	63%	0.07	4.43	63%	0.81	0.27	1	0	0.12			0.00	0.00
NC	1200	1215 Basement insulation R-13 (HP cooling)	Multi-Family	2014	2053	4.36	2.59	0.05	7.50	63%	0.03	4.46	63%	0.95	0.28	2	0	0.11			0.00	0.00
NC NC	1200 1200	1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling) 1210 Ceiling R-11 to R-38 Insulaton (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	4.26 4.19	2.53 2.49	0.11 0.07	7.61 7.68	64% 65%	0.06	4.52 4.56	64% 65%	1.11 1.74	0.29	2	0 1	0.09			0.00	0.00
NC	1200	1211 Ceiling R-11 to R-49 Insulation (HP cooling)	Multi-Family	2014	2053	4.18	2.49	0.01	7.68	65%	0.00	4.56	65%	3.87	0.30	7	1	0.03			0.00	0.00
NC NC	1200 1200	1216 Floor R-0 to R-19 Insulation-Batts (HP cooling) 1212 Ceiling R-19 to R-38 Insulation (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	4.14 4.13	2.46 2.46	0.04 0.01	7.72 7.73	65% 65%	0.03	4.59 4.59	65% 65%	2.42 3.12	0.31	4 5	1	0.04			0.00	0.00
NC	1200	1213 Ceiling R-19 to R-36 Insulation (HP cooling)	Multi-Family	2014	2053	4.13	2.46	0.00	7.73	65%	0.00	4.59	65%	3.12	0.32	7	1	0.03			0.00	0.00
NC	1200	1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling)	Multi-Family	2014	2053	4.10	2.43	0.03	7.77	65%	0.02	4.61	65%	7.69	0.35	13	1	0.01			0.00	0.00
NC NC	1200 1200	1207 Heat Pump Filter Replacement 1206 Heat pump tune up	Multi-Family Multi-Family	2014 2014	2053 2053	4.09 4.07	2.43 2.42	0.01 0.01	7.78 7.79	66% 66%	0.01 0.01	4.62 4.63	66% 66%	5.82 9.38	0.36	10 16	1	0.01 0.01			0.00	0.00
NC	1300	1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	Multi-Family	2014	2053	2.14	1.27	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.14	1.27	0.00	0.00
NC	1300 1300	1319 Duct Insulation (HP cooling Early Replacement)	Multi-Family	2014 2014	2053	2.13	1.26	0.02	0.02	1%	0.01	0.01	1% 2%	0.03	0.03	0	0	3.92			0.02	0.01 0.02
NC NC	1300	1323 Self Install Weatherization (HP cooling Early Replacement) 1324 Door Weatherization (HP cooling Early Replacement)	Multi-Family Multi-Family	2014	2053 2053	1.99	1.24 1.18	0.03	0.05 0.15	2% 7%	0.02	0.03	2% 7%	0.04 0.05	0.03	0	0	2.11 1.30			0.03 0.10	0.02
NC	1300	1302 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Ea		2014	2053	1.66	0.98	0.34	0.49	23%	0.20	0.29	23%	0.09	0.07	0	0	1.10			0.34	0.20
NC NC	1300 1300	1304 Proper Refrigerant Charging and Air Flow (HP cooling Early Re 1314 Crawlspace insulation (HP cooling Early Replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	1.54 1.53	0.91 0.91	0.12 0.01	0.61 0.61	28% 29%	0.07	0.36 0.36	28% 29%	0.11 0.23	0.08 0.08	0	0	0.77 0.46			0.00	0.00
NC	1300	1321 Programmable Thermostat (HP cooling Early Replacement)	Multi-Family	2014	2053	1.50	0.89	0.03	0.64	30%	0.02	0.38	30%	0.23	0.08	0	0	0.43			0.00	0.00
NC	1300	1318 Cool Roof (HP cooling Early Replacement)	Multi-Family	2014	2053	1.33	0.79	0.17	0.81	38%	0.10	0.48	38%	0.24	0.12	0	0	0.40			0.00	0.00
NC NC	1300 1300	1326 Whole House Fans (HP cooling early replacement) 1308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	1.07 0.98	0.64 0.58	0.26	1.07 1.16	50% 54%	0.15 0.05	0.64	50% 54%	0.32	0.17 0.20	1	0	0.30			0.00	0.00
NC	1300	1320 Duct Testing and Sealing (HP cooling Early Replacement)	Multi-Family	2014	2053	0.95	0.57	0.03	1.19	56%	0.02	0.71	56%	0.60	0.21	1	ō	0.17			0.00	0.00
NC	1300	1322 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling E		2014 2014	2053	0.91	0.54	0.04	1.23	58%	0.03	0.73	58%	0.50	0.22	1	0	0.16			0.00	0.00
NC NC	1300 1300	1305 Proper Sizing and Quality Install (HP cooling Early Replacemer 1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement)		2014	2053 2053	0.82 0.82	0.49 0.49	0.09 0.00	1.32 1.32	62% 62%	0.05	0.79 0.79	62% 62%	0.72 3.49	0.25 0.26	1 6	0	0.14			0.00	0.00
NC	1300	1325 Ceiling Fans (HP cooling early replacement)	Multi-Family	2014	2053	0.80	0.47	0.02	1.35	63%	0.01	0.80	63%	0.79	0.27	1	0	0.12			0.00	0.00
NC NC	1300 1300	1315 Basement insulation R-13 (HP cooling Early Replacement) 1327 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling I	Multi-Family	2014 2014	2053 2053	0.79 0.77	0.47 0.46	0.01	1.35 1.37	63% 64%	0.01	0.80 0.82	63% 64%	0.92 1.09	0.27	2	0	0.11			0.00	0.00
NC	1300	1310 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)		2014	2053	0.76	0.45	0.02	1.39	65%	0.01	0.82	65%	1.69	0.28	3	0	0.10			0.00	0.00
NC	1300	1311 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement)	Multi-Family	2014	2053	0.76	0.45	0.00	1.39	65%	0.00	0.82	65%	3.78	0.30	6	0	0.03			0.00	0.00
NC NC	1300 1300	1316 Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement 1312 Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)		2014 2014	2053 2053	0.75 0.75	0.45 0.44	0.01	1.39 1.40	65% 65%	0.00	0.83 0.83	65% 65%	2.36 3.05	0.31	4 5	1	0.04			0.00	0.00
NC	1300	1313 Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)		2014	2053	0.75	0.44	0.00	1.40	65%	0.00	0.83	65%	3.83	0.31	6	i	0.03			0.00	0.00
NC NC	1300 1300	1317 Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacer		2014 2014	2053 2053	0.74	0.44	0.01	1.40	65% 65%	0.00	0.83	65% 65%	7.49 5.67	0.34	13 10	1	0.01			0.00	0.00
NC NC	1300 1300	1307 Heat Pump Filter Replacement 1306 Heat pump tune up	Multi-Family Multi-Family	2014 2014	2053 2053	0.74 0.74	0.44 0.44	0.00	1.40 1.41	65% 66%	0.00	0.83 0.84	65% 66%	5.67 9.15	0.35	10 15	1	0.01 0.01			0.00	0.00
NC	1400	1400 Base Room Air Conditioner - EER 10.6	Multi-Family	2014	2053	0.67	0.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.67	0.40	0.00	0.00
NC NC	1400 1400	1413 Self Install Weatherization (RAC) 1414 Door Weatherization (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.66	0.39 0.37	0.01 0.03	0.01 0.04	2% 6%	0.01	0.01 0.03	2% 6%	0.01 0.04	0.01	0	0	7.80 1.87			0.01 0.03	0.01 0.02
NC	1400	1414 Door Weatherization (RAC) 1411 Cool Roof (RAC)	Multi-Family Multi-Family	2014	2053	0.56	0.37	0.03	0.04	17%	0.02	0.03	17%	0.04	0.03	0	0	0.76			0.03	0.02
NC	1400	1416 Whole House Fans (RAC)	Multi-Family	2014	2053	0.45	0.27	0.11	0.22	33%	0.06	0.13	33%	0.17	0.13	0	0	0.56			0.00	0.00
NC NC	1400 1400	1412 Comprehensive Shell Air Sealing - Inf. Reduction (RAC) 1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	Multi-Family Multi-Family	2014 2014	2053 2053	0.42	0.25	0.02	0.25 0.27	37% 40%	0.01 0.01	0.15 0.16	37% 40%	0.20	0.14	0	0	0.41			0.00	0.00
INC	1400	1402 HE NOOH AN CONDITIONS OF THE LEEK 11.3	widiu-i airilly	2014	2000	0.40	0.24	0.03	0.27	40 /0	0.01	0.10	40 /0	0.20	0.14	U	U	0.30			0.00	0.00

DNV GL H-13 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction IDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage		xisting		Moscuro	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
		leasure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	
Sgmt N	umber N 1400	umber Measure 1419 WINDOWS - Double-Glazed Clear to Energy Star (RAC)	Type Multi-Family	Year 2014	Year 2053	GWH 0.39	MW 0.23	Savings 0.01	0.28	Savings 42%	Savings 0.01	0.17	Savings 42%	\$/kWH 0.31	\$/kWH 0.15	\$/kW	\$/kW 0	0.34	GWH	MW	0.00	0.00
NC	1400	1404 Ceiling R-0 to R-38 Insulation (RAC)	Multi-Family	2014	2053	0.36	0.21	0.03	0.31	46%	0.02	0.18	46%	0.36	0.17	1	0	0.29			0.00	0.00
NC NC	1400 1400	1415 Ceiling Fans (RAC) 1405 Ceiling R-0 to R-49 Insulation (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.35	0.21 0.21	0.01	0.32 0.32	48% 48%	0.01	0.19 0.19	48% 48%	0.40 2.23	0.18	1 4	0	0.24			0.00	0.00
NC	1400	1417 Window Film (RAC)	Multi-Family	2014	2053	0.32	0.19	0.03	0.35	53%	0.02	0.21	53%	0.51	0.21	1	0	0.16			0.00	0.00
NC	1400 1400	1410 Wall Blow-in R-0 to R-13 Insulation (RAC)	Multi-Family	2014	2053	0.31	0.19 0.18	0.00	0.36	53%	0.00	0.21	53%	1.00 0.79	0.22	2	0	0.11			0.00	0.00
NC NC	1400	1418 WINDOWS - Default With Sunscreen (RAC) 1406 Ceiling R-11 to R-38 Insulaton (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.30	0.18	0.01 0.00	0.37 0.37	55% 56%	0.01	0.22 0.22	55% 56%	1.10	0.24	2	0	0.10			0.00	0.00
NC	1400	1407 Ceiling R-11 to R-49 Insulation (RAC)	Multi-Family	2014	2053	0.29	0.17	0.00	0.38	56%	0.00	0.22	56%	2.65	0.25	4	0	0.04			0.00	0.00
NC NC	1400 1400	1408 Ceiling R-19 to R-38 Insulation (RAC) 1409 Ceiling R-19 to R-49 Insulation (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.29	0.17 0.17	0.00	0.38	56% 56%	0.00	0.22 0.22	56% 56%	1.84 2.65	0.25 0.25	3	0	0.06 0.04			0.00	0.00
NC	1400	1403 Room AC Filter Replacement	Multi-Family	2014	2053	0.29	0.17	0.00	0.38	56%	0.00	0.22	56%	2.40	0.26	4	0	0.03			0.00	0.00
NC	1500	1500 Base Room Air Conditioner, Early Replacement - EER 9.7	Multi-Family	2014	2053	0.05	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.03	0.00	0.00
NC NC	1500 1600	1501 EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early 1 1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	Multi-Family Multi-Family	2014	2053 2053	0.05 0.19	0.03 0.11	0.01	0.01	13% 0%	0.00	0.00	13% 0%	0.96 N/A	0.96 N/A	2 N/A	2 N/A	0.08 N/A	0.19	0.11	0.00	0.00
NC	1600	1601 10% better than Energy Star Dehumidifier ROB (35-45 pints/da		2014	2053	0.16	0.09	0.03	0.03	15%	0.02	0.02	15%	0.19	0.19	0	0	0.48			0.00	0.00
NC NC	1700 1700	1700 Base Furnace Fan - Furnace & CAC	Multi-Family	2014 2014	2053 2053	11.33 6.30	5.81 3.23	0.00 5.04	0.00 5.04	0% 44%	0.00 2.58	0.00 2.58	0% 44%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.47	11.33	5.81	0.00 5.04	0.00 2.58
NC NC	2000	1701 ECM Furnace Fan (variable speed motor) - Cooling 2000 Base Heat Pump Space Heating (7.7 HSPF)	Multi-Family Multi-Family	2014	2053	17.55	2.08	0.00	0.00	0%	0.00	0.00	44% 0%	0.03 N/A	0.03 N/A	N/A	N/A	3.47 N/A	17.55	2.08	0.00	0.00
NC	2000	2016 Duct Insulation (HP heating)	Multi-Family	2014	2053	17.41	2.07	0.14	0.14	1%	0.02	0.02	1%	0.02	0.02	0	0	3.15			0.14	0.02
NC NC	2000 2000	2021 Self Install Weatherization (HP heating) 2022 Door Weatherization (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	17.13 16.49	2.03 1.96	0.28 0.65	0.42 1.07	2% 6%	0.03	0.05 0.13	2% 6%	0.03 0.05	0.03	0	0	1.83 0.96			0.28	0.03
NC	2000	2002 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	Multi-Family	2014	2053	14.97	1.78	1.52	2.59	15%	0.08	0.13	15%	0.03	0.04	1	1	0.54			0.00	0.00
NC	2000	2012 Crawlspace insulation (HP heating)	Multi-Family	2014	2053	14.93	1.77	0.04	2.63	15%	0.00	0.31	15%	0.15	0.09	1	1	0.44			0.00	0.00
NC NC	2000	2019 Programmable Thermostat (HP heating) 2020 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	14.63 13.96	1.74 1.66	0.30	2.92 3.59	17% 20%	0.04	0.35	17% 20%	0.14 0.21	0.09	1 2	1	0.43			0.00	0.00
NC	2000	2006 Ceiling R-0 to R-38 Insulation (HP heating)	Multi-Family	2014	2053	12.79	1.52	1.18	4.77	27%	0.14	0.57	27%	0.28	0.16	2	1	0.24			0.00	0.00
NC	2000	2017 Duct Testing and Sealing (HP heating)	Multi-Family	2014	2053	12.41	1.47	0.38	5.15	29%	0.05	0.61	29%	0.30	0.17	3	1	0.22			0.00	0.00
NC NC	2000 2000	2007 Ceiling R-0 to R-49 Insulation (HP heating) 2013 Basement insulation R-13 (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	12.37 12.26	1.47 1.46	0.03 0.11	5.18 5.29	30% 30%	0.00	0.61 0.63	30% 30%	1.52 0.39	0.18 0.18	13 3	1 2	0.0 4 0.17			0.00	0.00
NC	2000	2018 Heat Recovery Ventilators (HP heating)	Multi-Family	2014	2053	9.60	1.14	2.66	7.95	45%	0.32	0.94	45%	0.43	0.26	4	2	0.16			0.00	0.00
NC NC	2000 2000	2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating) 2008 Ceiling R-11 to R-38 Insulaton (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	9.37 9.23	1.11 1.09	0.23 0.14	8.18 8.33	47% 47%	0.03	0.97 0.99	47% 47%	0.61 0.91	0.27	5 8	2	0.11 0.07			0.00	0.00
NC	2000	2009 Ceiling R-11 to R-39 Insulation (HP heating)	Multi-Family	2014	2053	9.21	1.09	0.14	8.34	48%	0.02	0.99	48%	2.04	0.29	17	2	0.07			0.00	0.00
NC	2000	2014 Floor R-0 to R-19 Insulation-Batts (HP heating)	Multi-Family	2014	2053	9.14	1.08	0.08	8.42	48%	0.01	1.00	48%	1.28	0.30	11	3	0.05			0.00	0.00
NC NC	2000 2000	2003 Ground Source Heat Pump with Desuperheater (HP heating) 2010 Ceiling R-19 to R-38 Insulation (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	8.30 8.28	0.98 0.98	0.84 0.01	9.26 9.27	53% 53%	0.10	1.10 1.10	53% 53%	2.59 1.81	0.51 0.51	22 15	4	0.02 0.04			0.00	0.00
NC	2000	2011 Ceiling R-19 to R-49 Insulation (HP heating)	Multi-Family	2014	2053	8.28	0.98	0.00	9.28	53%	0.00	1.10	53%	2.27	0.51	19	4	0.03			0.00	0.00
NC	2000	2015 Wall Blow-in R-0 to R-13 Insulation (HP heating)	Multi-Family	2014	2053	8.21	0.97	0.07	9.34	53%	0.01	1.11	53%	4.44	0.54	37	5	0.02			0.00	0.00
NC NC	2000 2000	2005 Heat Pump Filter Replacement 2004 Heat pump tune up	Multi-Family Multi-Family	2014 2014	2053 2053	8.19 8.16	0.97 0.97	0.02	9.37 9.39	53% 54%	0.00	1.11 1.11	53% 54%	3.36 5.43	0.54 0.56	28 46	5 5	0.01 0.01			0.00	0.00
NC	2100	2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSP	Multi-Family	2014	2053	4.23	0.50	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.23	0.50	0.00	0.00
NC NC	2100 2100	2116 Duct Insulation (HP heating early replacement) 2121 Self Install Weatherization (HP heating early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	4.19 4.13	0.50 0.49	0.03 0.07	0.03 0.10	1% 2%	0.00	0.00 0.01	1% 2%	0.02 0.02	0.02	0	0	4.30 2.49			0.03 0.07	0.00 0.01
NC	2100	2122 Door Weatherization (HP heating early replacement)	Multi-Family	2014	2053	4.01	0.48	0.07	0.10	5%	0.01	0.03	5%	0.02	0.02	0	0	0.96			0.00	0.00
NC	2100		Multi-Family	2014	2053	3.64	0.43	0.37	0.59	14%	0.04	0.07	14%	0.08	0.07	1	1	0.74			0.00	0.00
NC NC	2100 2100	2112 Crawlspace insulation (HP heating early replacement) 2119 Programmable Thermostat (HP heating early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	3.59 3.51	0.43 0.42	0.06 0.07	0.64 0.71	15% 17%	0.01 0.01	0.08	15% 17%	0.11 0.10	0.07	1	1	0.61 0.58			0.00	0.00
NC	2100	2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating e	Multi-Family	2014	2053	3.35	0.40	0.16	0.87	21%	0.02	0.10	21%	0.16	0.09	1	1	0.36			0.00	0.00
NC NC	2100	2106 Ceiling R-0 to R-38 Insulation (HP heating early replacement) 2117 Duct Testing and Sealing (HP heating early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	3.07 2.98	0.36 0.35	0.28 0.09	1.16 1.25	27% 30%	0.03	0.14 0.15	27% 30%	0.21 0.22	0.12 0.13	2	1	0.33 0.30			0.00	0.00
NC NC	2100	2117 Duct resting and Sealing (HP heating early replacement) 2107 Ceiling R-0 to R-49 Insulation (HP heating early replacement)	Multi-Family	2014	2053	2.98	0.35	0.09	1.25	30%	0.00	0.15	30%	1.11	0.13	9	1	0.30			0.00	0.00
NC	2100	2113 Basement insulation R-13 (HP heating early replacement)	Multi-Family	2014	2053	2.82	0.34	0.15	1.40	33%	0.02	0.17	33%	0.29	0.15	2	1	0.24			0.00	0.00
NC NC	2100	2118 Heat Recovery Ventilators (HP heating early replacement) 2123 WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	2.21	0.26 0.26	0.61 0.05	2.02 2.07	48% 49%	0.07	0.24 0.25	48% 49%	0.33	0.20 0.21	3 4	2	0.20			0.00	0.00
NC	2100	2108 Ceiling R-11 to R-38 Insulaton (HP heating early replacement)	Multi-Family	2014	2053	2.13	0.25	0.03	2.10	50%	0.00	0.25	50%	0.70	0.22	6	2	0.10			0.00	0.00
NC	2100	2109 Ceiling R-11 to R-49 Insulation (HP heating early replacement)		2014	2053	2.12	0.25	0.00	2.11	50%	0.00	0.25	50%	1.56	0.22	13	2	0.04			0.00	0.00
NC NC	2100 2100	2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replaceme 2103 Ground Source Heat Pump with Desuperheater (HP heating early replacement)		2014 2014	2053 2053	2.02 1.84	0.24 0.22	0.10 0.19	2.20 2.39	52% 57%	0.01	0.26 0.28	52% 57%	0.98 2.07	0.25 0.40	8 17	2	0.07 0.03			0.00	0.00
NC	2100	2110 Ceiling R-19 to R-38 Insulation (HP heating early replacement)	Multi-Family	2014	2053	1.83	0.22	0.00	2.39	57%	0.00	0.28	57%	1.44	0.40	12	3	0.05			0.00	0.00
NC NC	2100	2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement)		2014	2053	1.83	0.22	0.00	2.40	57%	0.00	0.28	57%	1.81	0.40	15	3	0.04			0.00	0.00
NC NC	2100 2100	2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacem 2105 Heat Pump Filter Replacement (heating)	Multi-Family Multi-Family	2014 2014	2053 2053	1.82 1.81	0.22 0.22	0.02 0.01	2.41 2.42	57% 57%	0.00	0.29 0.29	57% 57%	3.54 2.68	0.42	30 23	4	0.02 0.02			0.00	0.00
NC	2100	2104 Heat pump tune up (heating)	Multi-Family	2014	2053	1.81	0.21	0.01	2.42	57%	0.00	0.29	57%	4.32	0.43	36	4	0.01			0.00	0.00
NC NC	2200 2200	2200 Base Resistance Space Heating (Primary) 2201 Air Source Heat Pump (resistance heating)	Multi-Family Multi-Family	2014 2014	2053 2053	17.86 14.10	2.12 1.67	0.00 3.77	0.00 3.77	0% 21%	0.00	0.00 0.45	0% 21%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.87	17.86	2.12	0.00 3.77	0.00
NC	2200	2216 Self Install Weatherization	Multi-Family	2014	2053	13.87	1.65	0.22	3.99	22%	0.45	0.45	22%	0.01	0.01	0	0	2.42			0.22	0.45
NC	2200	2217 Door Weatherization (resistance heating)	Multi-Family	2014	2053	13.24	1.57	0.63	4.62	26%	0.08	0.55	26%	0.03	0.02	0	0	1.53			0.63	0.08
NC NC	2200 2200	2214 Programmable Thermostat (resistance heating) 2209 Crawlspace insulation (resistance heating)	Multi-Family Multi-Family	2014 2014	2053 2053	12.98 12.91	1.54 1.53	0.26 0.07	4.89 4.95	27% 28%	0.03	0.58 0.59	27% 28%	0.07 0.10	0.02	1	0	0.82 0.70			0.00	0.00
NC	2200	2203 Ceiling R-0 to R-38 Insulation (resistance heating)	Multi-Family	2014	2053	11.73	1.39	1.18	6.13	34%	0.14	0.73	34%	0.17	0.05	1	0	0.40			0.00	0.00
NC NC	2200 2200	2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance he	Multi-Family Multi-Family	2014 2014	2053 2053	11.20 11.17	1.33 1.33	0.53 0.03	6.66 6.69	37% 37%	0.06	0.79 0.79	37% 37%	0.16 1.20	0.06	1 10	0	0.35 0.06			0.00	0.00
NC NC	2200	2204 Ceiling R-0 to R-49 Insulation (resistance heating) 2210 Basement insulation R-13 (resistance heating)	Multi-Family Multi-Family	2014	2053	11.17	1.33	0.03	6.69	37%	0.00	0.79	37%	1.20 0.27	0.06	10 2	1	0.06			0.00	0.00
		(cooldand nothing)	unniy			. 5.55	1.00	20		-570	2.00		2070		0.	-					2.00	2.50

DNV GL H-14 1/5/2015

APPENDIX H

Base Avoided Costs

		ic Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage		xisting				rear	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY	
Per			Desil diese	Measure Start	Measure	T-1-1	Total	OWILL	Energy	Percent		Capacity	Percent MW	Energy	Energy	Capacity	Capacity	Resource	B	D	F	F
Sgmt Nu		easure umber Measure	Building Type	Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	MW
	2200	2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance h		2014	2053	10.63	1.26	0.30	7.24	41%	0.04	0.86	41%	0.29	0.08	2	1	0.24			0.00	0.00
	2200 2200	2213 Heat Recovery Ventilators (resistance heating) 2205 Ceiling R-11 to R-38 Insulaton (resistance heating)	Multi-Family Multi-Family	2014 2014	2053 2053	8.32 8.18	0.99 0.97	2.31 0.14	9.54 9.68	53% 54%	0.27	1.13 1.15	53% 54%	0.31 0.58	0.13 0.14	3 5	1	0.22 0.12			0.00	0.00
NC	2200	2211 Floor R-0 to R-19 Insulation-Batts (resistance heating)	Multi-Family	2014	2053	8.03	0.95	0.16	9.84	55%	0.02	1.17	55%	0.62	0.15	5	1	0.11			0.00	0.00
	2200 2200	2206 Ceiling R-11 to R-49 Insulation (resistance heating) 2202 Ground Source Heat Pump with Desuperheater (resistance heat	Multi-Family	2014 2014	2053 2053	8.02 8.03	0.95 0.95	0.01 -0.01	9.85 9.84	55% 55%	0.00	1.17 1.17	55% 55%	1.68 -165.85	0.15	14 -1,398	1 2	0.04			0.00	0.00
	2200	2207 Ceiling R-19 to R-38 Insulation (resistance heating)	Multi-Family	2014	2053	8.01	0.95	0.02	9.85	55%	0.00	1.17	55%	1.00	0.30	-1,396	3	0.00			0.00	0.00
NC	2200	2208 Ceiling R-19 to R-49 Insulation (resistance heating)	Multi-Family	2014	2053	8.01	0.95	0.00	9.86	55%	0.00	1.17	55%	1.68	0.30	14	3	0.04			0.00	0.00
	2200 3030	2212 Wall Blow-in R-0 to R-13 Insulation (resistance heating)	Multi-Family	2014	2053 2053	7.92	0.94 0.08	0.09 0.00	9.95 0.00	56% 0%	0.01	1.18 0.00	56% 0%	2.03 N/A	0.31 N/A	17 N/A	3 N/A	0.03 N/A	0.70	0.08	0.00	0.00
	3030	3030 Base Halogen Lighting - 0.5 hrs/day 2020 3032 LEDs (base Halogen 0.5 hrs/day) 2020	Multi-Family Multi-Family	2020	2053	0.70	0.08	0.52	0.52	74%	0.06	0.06	74%	0.03	0.03	0	0	2.36	0.70	0.06	0.52	0.06
	3130	3130 Base Halogen Lighting - 2.5 hrs/day 2020	Multi-Family	2020	2053	2.90	0.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.90	0.32	0.00	0.00
	3130 3230	3132 LEDs (base Halogen 2.5 hrs/day) 2020 3230 Base Halogen Lighting - 6 hrs/day 2020	Multi-Family Multi-Family	2020 2020	2053 2053	0.76 1.81	0.09 0.20	2.14 0.00	2.14 0.00	74% 0%	0.24	0.24	74% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	11.68 N/A	1.81	0.20	2.14	0.24
	3230	3232 LEDs (base Halogen 6 hrs/day) 2020	Multi-Family	2020	2053	0.58	0.20	1.23	1.23	68%	0.14	0.14	68%	0.00	0.00	0	0	15.98	1.01	0.20	1.23	0.14
	3330	3330 Base CFL Lighting - 0.5 hrs/day 2020	Multi-Family	2020	2053	0.19	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.19	0.02	0.00	0.00
	3330 3430	3331 LEDs (base CFL 0.5 hrs/day) 2020	Multi-Family Multi-Family	2020 2020	2053 2053	0.14	0.02	0.05	0.05	27% 0%	0.01	0.01	27% 0%	0.21 N/A	0.21 N/A	2 N/A	2 N/A	0.37 N/A	0.79	0.09	0.00	0.00
	3430	3430 Base CFL Lighting - 2.5 hrs/day 2020 3431 LEDs (base CFL 2.5 hrs/day) 2020	Multi-Family	2020	2053	0.79	0.09	0.00	0.00	27%	0.00	0.00	27%	0.04	0.04	0	0	1.84	0.79	0.09	0.00	0.00
NC	3530	3530 Base CFL Lighting - 6 hrs/day 2020	Multi-Family	2020	2053	0.53	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.53	0.06	0.00	0.00
	3530 3630	3531 LEDs (base CFL 6 hrs/day) 2020 3630 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	Multi-Family Multi-Family	2020 2020	2053 2053	0.39	0.04 0.10	0.14 0.00	0.14 0.00	27% 0%	0.02	0.02	27% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	2.80 N/A	0.92	0.10	0.14	0.02
	3630	3632 LEDs (base Halogen (Specialty) 0.5 hrs/day 2020	Multi-Family Multi-Family	2020	2053	0.92	0.10	0.56	0.56	60%	0.00	0.00	60%	0.01	0.01	0 0	0 0	6.50	0.92	0.10	0.56	0.00
NC	3730	3730 Base Halogen (Specialty) Lighting - 2.5 hrs/day 2020	Multi-Family	2020	2053	3.70	0.41	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.70	0.41	0.00	0.00
	3730 3830	3732 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020 3830 Base Halogen (Specialty) Lighting - 6 hrs/day 2020	Multi-Family Multi-Family	2020	2053 2053	1.46 2.54	0.16 0.28	2.24	2.24	60% 0%	0.25	0.25	60% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	32.39 N/A	2.54	0.28	2.24	0.25
	3830	3832 LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Multi-Family	2020	2053	1.00	0.20	1.54	1.54	60%	0.00	0.00	60%	0.00	0.00	0	0	48.26	2.54	0.20	1.54	0.00
NC	3900	3900 Base Fluorescent Fixture 1.8 hrs/day	Multi-Family	2014	2053	2.88	0.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.88	0.32	0.00	0.00
	3900 4000	3902 ROB 2L4'T8, 1EB 4000 Base Refrigerator	Multi-Family Multi-Family	2014 2014	2053 2053	2.11 10.53	0.24 1.71	0.78 0.00	0.78 0.00	27% 0%	0.09	0.09	27% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	2.17 N/A	10.53	1.71	0.78 0.00	0.09
	4000	4000 Base Refrigerator 4001 Refrigerator (Energy Star)	Multi-Family Multi-Family	2014	2053	8.36	1.71	2.17	2.17	21%	0.00	0.00	21%	0.05	0.05	N/A 0	N/A 0	1.41	10.53	1.71	2.17	0.00
NC	4100	4100 Base RefrigeratorEarly Replacement	Multi-Family	2014	2053	1.43	0.23	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.43	0.23	0.00	0.00
	4100 4200	4101 Refrigerator - Early Replacement (Energy Star)	Multi-Family Multi-Family	2014 2014	2053 2053	0.67	0.11 0.03	0.76	0.76 0.00	53% 0%	0.12	0.12	53% 0%	0.13 N/A	0.13 N/A	1 N/A	1 N/A	0.40 N/A	0.17	0.03	0.00	0.00
	4200 4200	4200 Base 2nd Refrigerator - Recycling 4201 2nd Refrigerator Recycling	Multi-Family	2014	2053	0.17	0.03	0.00	0.00	74%	0.00	0.00	74%	0.05	0.05	0	0	1.04	0.17	0.03	0.00	0.00
NC	4500	4500 Base Freezer	Multi-Family	2014	2053	0.98	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.98	0.16	0.00	0.00
	4500 4600	4501 Freezer (Energy Star)	Multi-Family Multi-Family	2014	2053 2053	0.89	0.14	0.09	0.09	9% 0%	0.01	0.01	9% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.04 N/A	0.04	0.04	0.09	0.01
	4600 4600	4600 Base Early Replacement Freezer 4601 Freezer - Early Replacement (Energy Star)	Multi-Family	2014	2053	0.24	0.04	0.00	0.00	56%	0.00	0.00	56%	0.04	0.04	N/A 0	N/A 0	1.23	0.24	0.04	0.00	0.00
NC	4700	4700 Base 2nd Freezer Recycling	Multi-Family	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	5000 5000	5000 Base Water Heating (40 gal, EF=0.88) 5006 Pipe Wrap	Multi-Family Multi-Family	2014 2014	2053 2053	37.17 36.03	4.58 4.44	0.00 1.14	0.00 1.14	0% 3%	0.00	0.00 0.14	0% 3%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.89	37.17	4.58	0.00	0.00 0.14
	5000	5015 Low Flow Showerhead 1.5 Gal/Min	Multi-Family	2014	2053	34.84	4.44	1.14	2.33	5% 6%	0.14	0.14	5% 6%	0.02	0.02	0	0	2.66			1.14	0.14
NC	5000	5007 Hot water turndown 5 degrees	Multi-Family	2014	2053	34.65	4.27	0.19	2.52	7%	0.02	0.31	7%	0.02	0.02	0	ō	2.04			0.19	0.02
	5000 5000	5008 Hot water turndown 10 degrees 5009 Hot water turndown 15 degrees	Multi-Family Multi-Family	2014 2014	2053 2053	34.39 34.33	4.24 4.23	0.26 0.06	2.78 2.84	7% 8%	0.03	0.34 0.35	7% 8%	0.02	0.02	0	0	2.03 2.02			0.26	0.03 0.01
	5000	5010 Hot water turndown 15 degrees 5010 Hot water turndown 20 degrees	Multi-Family	2014	2053	34.30	4.23	0.00	2.86	8%	0.00	0.35	8%	0.02	0.02	0	0	2.02			0.08	0.00
NC	5000	5014 Faucent Aerators	Multi-Family	2014	2053	33.59	4.14	0.72	3.58	10%	0.09	0.44	10%	0.04	0.02	0	0	1.50			0.72	0.09
	5000 5000	5011 Drain Water Heat Recovery (GFX)	Multi-Family Multi-Family	2014 2014	2053 2053	32.33 30.51	3.98 3.76	1.26 1.81	4.84 6.66	13% 18%	0.16 0.22	0.60 0.82	13% 18%	0.07 0.06	0.04	1 0	0	1.02 0.82			1.26 0.00	0.16 0.00
	5000	5005 DHW Tank Wrap 5003 Heat Pump Water Heater - Energy Star	Multi-Family	2014	2053	26.31	3.76	4.20	10.86	29%	0.22	1.34	18% 29%	0.08	0.04	1	0	0.82			0.00	0.00
NC	5000	5004 Solar Domestic Water Heating	Multi-Family	2014	2053	22.20	2.73	4.11	14.97	40%	0.51	1.84	40%	0.20	0.10	2	1	0.33			0.00	0.00
	5000 5000	5012 Energy Star CW CEE Tier 2 (MEF=2.0) 5013 Energy Star Dishwasher (EF=0.72)	Multi-Family Multi-Family	2014 2014	2053 2053	22.11 22.06	2.72 2.72	0.09 0.05	15.06 15.11	41% 41%	0.01 0.01	1.85 1.86	41% 41%	2.28 2.75	0.11 0.12	19 22	1	0.03 0.02			0.00	0.00
	5000 5100	5013 Energy Star Dishwasher (EF=0.72) 5100 Base Water Heating Early Replacement to Heat Pump Water F		2014	2053	6.56	0.81	0.05	15.11 0.00	41% 0%	0.01	0.00	41% 0%	2.75 N/A	0.12 N/A	22 N/A	1 N/A	0.02 N/A	6.56	0.81	0.00	0.00
NC	5100	5101 Heat Pump Water Heater - Energy Star - Early Replacement	Multi-Family	2014	2053	5.66	0.70	0.90	0.90	14%	0.11	0.11	14%	0.08	0.08	1	1	0.77			0.00	0.00
	5500 5500	5500 Base Clotheswasher (MEF=1.26)	Multi-Family	2014 2014	2053 2053	0.67	0.12 0.09	0.00 0.19	0.00 0.19	0% 28%	0.00	0.00	0% 28%	N/A	N/A 1.21	N/A 7	N/A 7	N/A	0.67	0.12	0.00	0.00
	5600	5501 Energy Star CW CEE Tier 2 (MEF=2.0) 5600 Base Clothes Dryer (EF=3.01)	Multi-Family Multi-Family	2014	2053	12.52	2.12	0.19	0.19	28% 0%	0.03	0.03	28% 0%	1.21 N/A	1.21 N/A	N/A	N/A	0.05 N/A	12.52	2.12	0.00	0.00
NC	5600	5602 High Efficiency CD (EF=3.01 w/moisture sensor)	Multi-Family	2014	2053	10.22	1.73	2.30	2.30	18%	0.39	0.39	18%	0.03	0.03	0	0	1.99			2.30	0.39
	5600 5700	5601 Heat Pump Dryer 5700 Base Dishwasher (EF=0.65)	Multi-Family	2014 2014	2053 2053	5.11 2.92	0.86 0.48	5.11 0.00	7.41 0.00	59% 0%	0.86	1.25 0.00	59% 0%	0.51 N/A	0.36 N/A	3	2	0.12 N/A	2.02	0.40	0.00	0.00
	5700 5700	5700 Base Dishwasher (EF=0.65) 5701 Energy Star Dishwasher (EF=0.72)	Multi-Family Multi-Family	2014	2053	2.92	0.48	0.10	0.00	0% 4%	0.00	0.00	4%	1.48	1.48	N/A 9	N/A 9	N/A 0.04	2.92	0.48	0.00	0.00
NC	6000	6000 Base Single Speed Pool Pump (RET)	Multi-Family	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	7000 7000	7000 Base Plasma TV 7001 Energy Star Plasma TV	Multi-Family Multi-Family	2014 2014	2053 2053	0.70	0.10	0.00	0.00	0% 9%	0.00	0.00 0.01	0% 9%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.29	0.70	0.10	0.00	0.00
	7000	7001 Energy Star Plasma TV 7002 Plug Load Controls - Smart Power Strip (base plasma TV)	Multi-Family Multi-Family	2014	2053	0.63	0.09	0.06	0.06	10%	0.00	0.01	10%	2.90	0.01	20	2	0.02			0.00	0.00
NC	7100	7100 Base LCD TV	Multi-Family	2014	2053	2.10	0.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.10	0.30	0.00	0.00
	7100 7100	7101 Energy Star LCD TV 7102 Plug Load Controls - Smart Power Strip (base LCD TV)	Multi-Family Multi-Family	2014 2014	2053 2053	1.34 1.29	0.19 0.19	0.77 0.05	0.77 0.82	36% 39%	0.11 0.01	0.11 0.12	36% 39%	0.00 3.08	0.00	0 21	0	11.35 0.02			0.77 0.00	0.11 0.00
	7100	7102 Plug Load Controls - Smart Power Strip (base LCD TV) 7200 Base CRT TV	Multi-Family	2014	2053	0.63	0.19	0.05	0.82	39% 0%	0.01	0.12	39% 0%	3.08 N/A	0.20 N/A	N/A	N/A	0.02 N/A	0.63	0.09	0.00	0.00
NC	7200	7202 Plug Load Controls - Smart Power Strip (base CRT TV)	Multi-Family	2014	2053	0.57	0.08	0.06	0.06	10%	0.01	0.01	10%	0.85	0.85	6	6	0.06			0.00	0.00
	7300 7400	7300 Base Set-Top Box	Multi-Family	2014	2053	2.10 0.35	0.30	0.00	0.00	0%	0.00	0.00	0% 0%	N/A	N/A N/A	N/A	N/A N/A	N/A	2.10	0.30	0.00	0.00
NC	7400	7400 Base DVD Player	Multi-Family	2014	2053	0.35	0.05	0.00	0.00	0%	0.00	0.00	υ%	N/A	N/A	N/A	N/A	N/A	0.35	0.05	0.00	0.00

APPENDIX H

Base Avoided Costs

	ASSYST	ctric Existing Construction ADDITIVE SUPPLY ANALYSIS Existing				Year	2014		Total			Total				Marginal					SUPPLY	
	_				Measure				Energy	Percent		Capacity	Percent	Energy	,					_		
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base		Economic
Sgmt	Number	Number Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
NC	7400	7401 Energy Star DVD Player	Multi-Family	2014	2053	0.17	0.02	0.19	0.19	53%	0.03	0.03	53%	0.02	0.02	0	0	2.90			0.19	0.03
NC	7400	7402 Plug Load Controls - Smart Power Strip (base DVD player)	Multi-Family	2014	2053	0.01	0.00	0.15	0.34	96%	0.02	0.05	96%	0.91	0.42	6	3	0.06			0.00	0.00
NC	7500	7500 Base Desktop PC	Multi-Family	2014	2053	3.42	0.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.42	0.45	0.00	0.00
NC	7500	7501 Energy Star Desktop PC	Multi-Family	2014	2053	2.98	0.39	0.44	0.44	13%	0.06	0.06	13%	0.00	0.00	0	0	13.50			0.44	0.06
NC	7500	7502 Plug Load Controls - Smart Power Strip (base Desktop PC)	Multi-Family	2014	2053	1.56	0.21	1.42	1.86	54%	0.19	0.25	54%	0.05	0.04	0	0	1.05			1.42	0.19
NC	7600	7600 Base Laptop PC	Multi-Family	2014	2053	0.69	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.69	0.09	0.00	0.00
NC	7600	7601 Energy Star Laptop PC	Multi-Family	2014	2053	0.58	0.08	0.12	0.12	17%	0.02	0.02	17%	0.03	0.03	0	0	2.03			0.12	0.02
NC	8000	8000 Base Cooking	Multi-Family	2014	2053	9.65	3.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.65	3.08	0.00	0.00
NC	9000	9000 Base Miscellaneous	Multi-Family	2014	2053	15.81	2.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.81	2.08	0.00	0.00
NC	9900	9900 Base House Use	Multi-Family	2014	2053	205.57	50.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	205.57	50.90	0.00	0.00
NC	9900	9901 Indirect Feedback	Multi-Family	2014	2053	202.51	50.15	3.05	3.05	1%	0.76	0.76	1%	0.03	0.03	0	0	1.59			3.05	0.76
NC	9900	9902 Direct Feedback	Multi-Family	2014	2053	193.36	47.88	9.16	12.21	6%	2.27	3.02	6%	0.09	0.07	0	0	0.63			0.00	0.00

APPENDIX H

Base Avoided Costs

DSM A	SSYST AD		LY ANALYSIS				Year	2014														SUPPLY	
Vintage	e Ne	w Constructio	n							Total			Total				Marginal						
					Measure	Measure	9			Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource				/
	Base	Measure		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic I	Economic
Sgmt	Number	Number	Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA	100	100	Base Code Home - IECC 2006	Single Family	2013	2054	242.08	59.94	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	242.1	59.94	0.00	0.00
VA	100	101	Energy Star Home	Single Family	2013	2054	188.72	55.15	53.35	53.35	22%	4.80	4.80	8%	0.06	0.06	1	1	1.00			53.35	4.80
VA	100	100	Base Code Home - IECC 2006	Multi-Family	2013	2054	39.65	9.82	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	39.6	9.82	0.00	0.00
VA	100	101	Energy Star Home	Multi-Family	2013	2054	30.91	9.03	8.74	8.74	22%	0.79	0.79	8%	0.06	0.06	1	1	1.17			8.74	0.79
NC	100	100	Base Code Home - IECC 2006	Single Family	2013	2054	13.31	3.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.3	3.30	0.00	0.00
NC	100	101	Energy Star Home	Single Family	2013	2054	10.38	3.03	2.93	2.93	22%	0.26	0.26	8%	0.06	0.06	1	1	1.14			2.93	0.26
NC	100	100	Base Code Home - IECC 2006	Multi-Family	2013	2054	1.98	0.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.0	0.49	0.00	0.00
NC	100	101	Energy Star Home	Multi-Family	2013	2054	1.55	0.45	0.44	0.44	22%	0.04	0.04	8%	0.05	0.05	1	1	1.21			0.44	0.04

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint									Total			Total		Marginal	Average	Marginal						
	Base	Measure	Building	Measure Start	Measure	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	Economic
		Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA VA	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1036 Lighting Control Tuneup (base 4L4'T8), 2020	Office Office	2020 2020	2054	1,085.70		0.00 8.43	0.00 8.43	0% 1%	0.00 0.78	0.00 0.78	0% 0%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.08	1,085.70	202.10	0.00 8.43	0.00 0.78
VA	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Office	2020	2054	996.47	189.29	80.81	89.24	8%	12.03	12.82	6%	0.01	0.01	0	0	5.43			80.81	12.03
VA VA	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office Office	2020 2020	2054 2054	894.97 781.10	170.39 149.20	101.49 113.87	190.73 304.60	18% 28%	18.89 21.20	31.71 52.91	16% 26%	0.02	0.02 0.02	0	0	3.07 1.47			101.49 113.87	18.89 21.20
VA	1030	1032 ROB 4L4 Low Walt High Performance 18 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	2020	2054	723.19	146.50	57.91	362.51	33%	2.70	55.60	28%	0.04	0.02	1	0	0.94			0.00	0.00
VA	1030	1034 ROB 4L4' LED Tube, 2020	Office	2020	2054	606.67	124.81	116.53	479.03	44%	21.69	77.29	38%	0.24	0.08	1	0	0.27			0.00	0.00
VA VA	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Office Office	2020 2020	2054 2054	554.88 18.36	115.17 3.42	51.79 0.00	530.82 0.00	49% 0%	9.64 0.00	86.93 0.00	43% 0%	0.20 N/A	0.09 N/A	1 N/A	1 N/A	0.33 N/A	18.36	3.42	0.00	0.00
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Office	2020	2054	18.21	3.42	0.00	0.00	1%	0.00	0.00	0%	0.01	0.01	0	0	3.53	10.30	3.42	0.00	0.00
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Office	2020	2054	16.84	3.20	1.37	1.51	8%	0.20	0.22	6%	0.02	0.02	Ō	ō	3.16			1.37	0.20
VA VA	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Office Office	2020 2020	2054 2054	15.09 13.17	2.87 2.52	1.75 1.92	3.26 5.18	18% 28%	0.33 0.36	0.54 0.90	16% 26%	0.02 0.05	0.02 0.03	0	0	2.42 1.16			1.75 1.92	0.33 0.36
VA	1130	1132 ROB 2L4 LOW Walt High Performance 16 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	Office	2020	2054	12.54	2.52	0.64	5.82	32%	0.36	1.02	30%	0.05	0.05	1	0	0.36			0.00	0.00
VA	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Office	2020	2054	11.61	2.35	0.93	6.75	37%	0.04	1.06	31%	0.10	0.06	2	0	0.50			0.00	0.00
VA VA	1130 1200	1135 LED Troffer (base 2L4T8), 2020 1200 Base Other Fluorescent Fixture	Office Office	2020 2014	2054 2054	10.62 39.84	2.17 7.42	0.99	7.74 0.00	42% 0%	0.18	1.25 0.00	36% 0%	0.25 N/A	0.08 N/A	1 N/A	0 N/A	0.27 N/A	39.84	7.42	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Office	2014	2054	37.93	7.24	1.90	1.90	5%	0.18	0.00	2%	0.00	0.00	0	0	17.09	33.04	1.42	1.90	0.18
VA	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	2014	2054	35.09	6.81	2.85	4.75	12%	0.42	0.60	8%	0.03	0.02	0	0	2.44			2.85	0.42
VA VA	1200 1200	1201 ROB High Performance T8 (base other fluorescent) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Office Office	2014 2014	2054 2054	31.44 27.24	6.14 5.94	3.65 4.19	8.40 12.59	21% 32%	0.68 0.20	1.28 1.48	17% 20%	0.08	0.04 0.06	0 2	0	0.73 0.52			0.00	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Office	2014	2054	23.78	5.30	3.47	16.06	40%	0.20	2.12	20%	0.09	0.00	1	1	0.32			0.00	0.00
VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Office	2020	2054	368.56	68.61	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	368.56	68.61	0.00	0.00
VA VA	1330 1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Office Office	2020 2020	2054 2054	88.80 132.68	16.53 24.70	279.76 0.00	279.76 0.00	76% 0%	52.08 0.00	52.08 0.00	76% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	15.29 N/A	132.68	24.70	279.76 0.00	52.08 0.00
VA	1430	1432 LEDs (base incandescent A-line 2amp, 72W to 3clew-in Replacement 2020	Office	2020	2054	34.53	6.43	98.15	98.15	74%	18.27	18.27	74%	0.00	0.00	0	0	12.82	132.00	24.70	98.15	18.27
VA	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	2020	2054	97.67	18.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	97.67	18.18	0.00	0.00
VA VA	1530 1630	1532 LEDs (base incandescent A-line 53W) 2020 1630 Base CFL 18W to screw-in replacement 2020	Office Office	2020 2020	2054 2054	33.85 24.08	6.30 4.48	63.82 0.00	63.82 0.00	65% 0%	11.88 0.00	11.88 0.00	65% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	9.23 N/A	24.08	4.48	63.82 0.00	11.88 0.00
VA	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Office	2020	2054	17.41	3.24	6.67	6.67	28%	1.24	1.24	28%	0.05	0.05	0	0	1.11	24.00	4.40	6.67	1.24
VA	1730	1730 Base CFL 23W to screw-in replacement 2020	Office	2020	2054	30.77	5.73	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	30.77	5.73	0.00	0.00
VA VA	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Office Office	2020 2014	2054 2054	22.77 0.00	4.24 0.00	8.00 0.00	8.00 0.00	26% 0%	1.49 0.00	1.49 0.00	26% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	1.47 N/A	0.00	0.00	8.00 0.00	1.49 0.00
VA	1850	1850 Base CFL Exit Sign	Office	2014	2054	12.87	2.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A N/A	N/A	N/A	N/A	12.87	2.40	0.00	0.00
VA	1850	1851 LED Exit Sign	Office	2014	2054	7.23	1.35	5.64	5.64	44%	1.05	1.05	44%	0.02	0.02	0	0	2.36			5.64	1.05
VA VA	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Office Office	2014 2014	2054 2054	88.06 77.56	1.21 0.73	0.00 10.50	0.00 10.50	0% 12%	0.00 0.48	0.00 0.48	0% 39%	N/A 0.04	N/A 0.04	N/A 1	N/A	N/A 1.59	88.06	1.21	0.00 10.50	0.00 0.48
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Office	2014	2054	37.32	0.73	40.24	50.74	12% 58%	0.48	1.03	39% 85%	0.04	0.04	6	4	0.67			0.00	0.48
VA	1900	1903 Bi-Level LED Outdoor Lighting	Office	2014	2054	26.35	0.04	10.97	61.71	70%	0.14	1.17	96%	0.54	0.16	44	8	0.10			0.00	0.00
VA VA	2000 2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2010 Ceiling/roof Insulation - Chiller	Office Office	2014 2014	2054 2054	136.14 135.53	95.24 94.82	0.00 0.61	0.00 0.61	0% 0%	0.00 0.42	0.00 0.42	0% 0%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 18.40	136.14	95.24	0.00 0.61	0.00 0.42
VA	2000	2010 Ceiling/roor Insulation - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Office	2014	2054	123.96	94.82 86.72	11.57	12.18	9%	8.09	0.42 8.52	9%	0.01	0.01	0	0	4.19			11.57	8.09
VA	2000	2005 Chiller Tune Up/Diagnostics	Office	2014	2054	123.59	86.60	0.37	12.55	9%	0.13	8.65	9%	0.02	0.03	0	0	3.34			0.37	0.13
VA VA	2000	2013 High Efficiency Chiller Motors 2006 VSD for Chiller Pumps and Towers	Office Office	2014 2014	2054 2054	123.37 122.56	86.44 86.16	0.22 0.81	12.77 13.58	9% 10%	0.16 0.28	8.80 9.09	9% 10%	0.04 0.03	0.03	0	0	2.73			0.22 0.81	0.16 0.28
VA	2000	2006 VSD for Crimer Pumps and Towers 2003 EMS - Chiller	Office	2014	2054	113.99	84.66	8.56	22.14	16%	1.50	10.58	11%	0.05	0.03	0	0	1.37			8.56	1.50
VA	2000	2008 New Economizer - Chiller	Office	2014	2054	106.64	83.37	7.36	29.50	22%	1.29	11.87	12%	0.05	0.04	0	ō	1.04			7.36	1.29
VA	2000	2002 Window Film (Standard) - Chiller	Office	2014	2054	106.60	83.35	0.03	29.53	22%	0.02	11.89	12%	0.09	0.04	0	0	0.98			0.00	0.00
VA VA	2000 2000	2012 Duct Testing/Sealing - Chiller 2004 Cool Roof - Chiller	Office Office	2014 2014	2054 2054	86.35 86.08	69.18 68.99	20.25 0.27	49.79 50.05	37% 37%	14.17 0.19	26.06 26.25	27% 28%	0.15 0.22	0.08	0	0	0.73 0.39			0.00	0.00
VA	2000	2011 Duct/Pipe Insulation - Chiller	Office	2014	2054	85.82	68.81	0.27	50.32	37%	0.19	26.44	28%	1.87	0.09	3	0	0.05			0.00	0.00
VA VA	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Office Office	2014 2014	2054 2054	617.70 475.63	432.16 332.76	0.00 142.07	0.00 142.07	0% 23%	0.00 99.40	0.00 99.40	0% 23%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 4.41	617.70	432.16	0.00 142.07	0.00 99.40
VA VA	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2111 Economizer Repair - DX	Office	2014	2054	475.63 454.22	332.76	142.07 21.40	142.07 163.48	23%	99.40 22.47	99.40 121.87	23%	0.02	0.02	0	0	4.41 1.61			142.07 21.40	99.40 22.47
VA	2100	2108 Optimize Controls - DX	Office	2014	2054	446.47	308.93	7.76	171.23	28%	1.36	123.23	29%	0.06	0.03	ō	ō	0.90			0.00	0.00
VA VA	2100 2100	2115 Window Film (Standard) - DX 2105 DX Tune Up/ Advanced Diagnostics	Office Office	2014 2014	2054 2054	437.24 436.45	302.47 302.20	9.23 0.79	180.46 181.25	29% 29%	6.46 0.28	129.68 129.96	30% 30%	0.10 0.09	0.03	0	0	0.88 0.79			0.00	0.00
VA	2100 2100	2105 DX Tune Up/ Advanced Diagnostics 2109 Economizer - DX	Office	2014	2054	436.45 388.46	293.81	0.79 47.98	181.25 229.24	29% 37%	0.28 8.39	129.96	30%	0.09	0.03	0	0	0.79			0.00	0.00
VA	2100	2112 Duct Testing/Sealing - DX	Office	2014	2054	364.84	277.28	23.62	252.86	41%	16.52	154.87	36%	0.19	0.05	0	0	0.59			0.00	0.00
VA VA	2100 2100	2106 Prog. Thermostat - DX 2107 Cool Roof - DX	Office Office	2014 2014	2054 2054	357.09 354.04	275.93 273.80	7.76 3.05	260.61 263.66	42% 43%	1.36 2.13	156.23 158.36	36% 37%	0.10 0.25	0.06 0.06	1 0	0	0.53 0.35			0.00	0.00
VA	2100 2100	2107 Cool Roof - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office	2014	2054	354.04	273.80	0.08	263.66	43% 43%	0.01	158.36 158.38	37%	0.25	0.06	1	0	0.35			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Office	2014	2054	351.66	272.18	2.29	266.04	43%	1.60	159.98	37%	2.07	0.08	3	ō	0.04			0.00	0.00
VA VA	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Office Office	2014 2014	2054 2054	421.72 369.56	295.04 258.55	0.00 52.16	0.00	0%	0.00 36.49	0.00 36.49	0%	N/A	N/A	N/A 0	N/A 0	N/A	421.72	295.04	0.00 52.16	0.00 36.49
VA VA	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Office Office	2014 2014	2054 2054	369.56 67.57	258.55 47.28	52.16 0.00	52.16 0.00	12% 0%	36.49 0.00	36.49 0.00	12% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	6.17 N/A	67.57	47.28	52.16 0.00	36.49 0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Office	2014	2054	334.29	100.92	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	334.29	100.92	0.00	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	Office	2014	2054	268.04	95.92	66.25	66.25	20%	5.00	5.00	5%	0.01	0.01	0	0	4.29			66.25	5.00
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	Office Office	2014 2014	2054 2054	263.67 249.34	94.60 86.38	4.36 14.34	70.62 84.95	21% 25%	1.32 8.22	6.32 14.54	6% 14%	0.02	0.01 0.11	0 1	0 1	3.42 0.16			4.36 0.00	1.32 0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	2014	2054	57.92	17.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	57.92	17.49	0.00	0.00
VA	3100	3102 Variable Speed Drive Control, 15 HP	Office	2014	2054	46.44	16.62	11.48	11.48	20%	0.87	0.87	5% 5%	0.00	0.00	0	0	15.54			11.48	0.87
VA VA	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Office Office	2014 2014	2054 2054	46.16 43.11	16.53 15.70	0.28 3.06	11.76 14.81	20% 26%	0.08	0.95 1.78	5% 10%	0.01 0.02	0.00 0.01	0	0	7.53 3.33			0.28 3.06	0.08
	00															-	-					

DNV GL H-1 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Measure	Moscure				Total	Percent		Total	Percent	Marginal	Average	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt VA	Number 3100	Number Measure 3103 Air Handler Optimization, 15 HP	Type Office	Year 2014	Year 2054	38.98	MW 15.39	Savings 4.12	GWH 18.94	Savings 33%	Savings 0.31	MW 2.09	Savings 12%	\$/kWH 0.02	\$/kWH 0.01	\$/kW	\$/kW	2.51	GWH	MW	4.12	0.31
VA	3100	3105 Energy Recovery Ventilation (ERV)	Office	2014	2054	38.07	14.87	0.91	19.85	34%	0.52	2.61	15%	0.23	0.02	0	0	0.46			0.00	0.00
VA VA	3100 3200	3107 Demand Controlled Ventilation	Office Office	2014	2054 2054	36.00 36.51	13.69	2.07	21.92	38% 0%	1.19	3.80	22%	0.72 N/A	0.09 N/A	1	0	0.14	00.54	11.02	0.00	0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	Office	2014	2054	33.02	10.76	3.49	0.00 3.49	10%	0.00 0.26	0.00 0.26	0% 2%	0.01	0.01	N/A 0	N/A 0	N/A 3.38	36.51	11.02	3.49	0.00
VA	3200	3202 Variable Speed Drive Control, 40 HP	Office	2014	2054	26.48	10.27	6.54	10.04	27%	0.49	0.76	7%	0.02	0.02	0	0	2.79			6.54	0.49
VA VA	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Office Office	2014 2014	2054 2054	26.36 24.93	10.23 9.41	0.12 1.43	10.15 11.59	28% 32%	0.04 0.82	0.79 1.61	7% 15%	0.10 0.65	0.02 0.10	0	0	0.85 0.15			0.00	0.00
VA	4000	4000 Base Built-Up Refrigeration System	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Office Office	2014 2014	2054 2054	98.08 97.41	13.75 13.66	0.00 0.66	0.00 0.66	0% 1%	0.00	0.00	0% 1%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 50.26	98.08	13.75	0.00 0.66	0.00
VA	4100	4109 Energy-Star Freezer, glass door	Office	2014	2054	97.25	13.64	0.16	0.82	1%	0.02	0.12	1%	0.00	0.00	0	0	25.01			0.16	0.02
VA VA	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4107 Energy-Star Freezer, solid door	Office Office	2014 2014	2054 2054	95.47 95.40	13.39 13.38	1.78	2.61 2.67	3% 3%	0.25	0.37 0.37	3% 3%	0.00	0.00	0	0	23.99 10.01			1.78	0.25 0.01
VA	4100	4107 Energy-Star Preezer, solid door 4108 Energy-Star Refrigerator, glass door	Office	2014	2054	94.86	13.30	0.55	3.22	3%	0.01	0.37	3%	0.01	0.00	0	0	8.42			0.55	0.01
VA	4100	4106 Energy-Star Refrigerator, solid door	Office	2014	2054	94.61	13.27	0.24	3.46	4%	0.03	0.49	4%	0.01	0.00	0	0	8.03			0.24	0.03
VA VA	4100 4100	4110 Energy Star Ice Machines 4112 Reach-in unit occupancy sensors	Office Office	2014 2014	2054 2054	94.28 94.27	13.22	0.34	3.80 3.81	4% 4%	0.05	0.53	4% 4%	0.02	0.00	0	0	2.97 0.21			0.34	0.05
VA	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Office	2014	2054	94.25	13.22	0.02	3.83	4%	0.00	0.54	4%	0.31	0.01	2	0	0.17			0.00	0.00
VA VA	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Office Office	2014 2014	2054 2054	94.19 40.10	13.21 5.56	0.06 0.00	3.89 0.00	4% 0%	0.01 0.00	0.55 0.00	4% 0%	6.64 N/A	0.11 N/A	47 N/A	1 N/A	0.01 N/A	40.10	5.56	0.00	0.00
VA	5000	5001 PC Network Power Management Enabling	Office	2014	2054	21.62	4.28	18.48	18.48	46%	1.28	1.28	23%	0.01	0.01	0	0	4.47	40.10	3.30	18.48	1.28
VA VA	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	Office Office	2014 2014	2054	16.81 3.65	3.61 0.51	4.81 0.00	23.29	58% 0%	0.67	1.95	35% 0%	0.02 N/A	0.01 N/A	0 N/A	0 N/A	2.22 N/A	2.65	0.51	4.81 0.00	0.67
VA	5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Office	2014	2054	2.96	0.51	0.69	0.69	19%	0.00	0.00	19%	0.01	0.01	0 0	N/A 0	6.06	3.65	0.51	0.69	0.00
VA	5100	5101 Laptop Network Power Management Enabling	Office	2014	2054	2.90	0.40	0.06	0.75	21%	0.01	0.10	21%	0.99	0.09	7	1	0.05			0.00	0.00
VA VA	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Office Office	2014 2014	2054 2054	8.50 4.89	1.18 0.68	0.00 3.62	0.00 3.62	0% 43%	0.00 0.50	0.00 0.50	0% 43%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 63.11	8.50	1.18	0.00 3.62	0.00 0.50
VA	5200	5202 Monitor Power Management Enabling - CRT	Office	2014	2054	4.23	0.63	0.65	4.27	50%	0.05	0.55	46%	0.01	0.00	0	0	5.32			0.65	0.05
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Office Office	2014 2014	2054 2054	3.90 7.61	0.59 1.06	0.33	4.60 0.00	54% 0%	0.05 0.00	0.59 0.00	50% 0%	0.11 N/A	0.01 N/A	1 N/A	0 N/A	0.45 N/A	7.61	1.06	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Office	2014	2054	6.61	0.92	0.99	0.99	13%	0.14	0.14	13%	0.01	0.01	0	0	7.50	7.01	1.00	0.99	0.14
VA VA	5300 5300	5302 Monitor Power Management Enabling - LCD	Office Office	2014 2014	2054 2054	6.12 5.64	0.88	0.49 0.48	1.49 1.97	20% 26%	0.03	0.17	16% 18%	0.06 0.18	0.03	1 5	0	0.72			0.00	0.00
VA	5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Office	2014	2054	13.93	1.93	0.48	0.00	26% 0%	0.02	0.19	0%	0.18 N/A	0.06 N/A	N/A	N/A	0.24 N/A	13.93	1.93	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Office	2014	2054	12.54	1.74	1.38	1.38	10%	0.19	0.19	10%	0.00	0.00	0	0	36.97			1.38	0.19
VA VA	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Office Office	2014 2014	2054	12.00	1.70 0.33	0.54 0.00	1.93	14% 0%	0.04	0.23	12% 0%	0.07 N/A	0.02 N/A	1 N/A	0 N/A	0.67 N/A	2.37	0.33	0.00	0.00
VA	5500	5502 ENERGY STAR Multi-Function Printer	Office	2014	2054	1.77	0.25	0.59	0.59	25%	0.08	0.08	25%	0.01	0.01	0	0	10.13			0.59	0.08
VA VA	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Office Office	2014 2014	2054 2054	1.45 13.79	0.22 1.91	0.32 0.00	0.92	39% 0%	0.02	0.10 0.00	32% 0%	0.21 N/A	0.08 N/A	3 N/A	1 N/A	0.23 N/A	13.79	1.91	0.00	0.00
VA	5600	5602 ENERGY STAR Printer	Office	2014	2054	9.00	1.25	4.80	4.80	35%	0.67	0.67	35%	0.00	0.00	0	0	46.55	13.75	1.51	4.80	0.67
VA	5600	5601 Printer Power Management Enabling	Office	2014	2054	7.36	1.13	1.64	6.44	47%	0.11	0.78	41%	0.04	0.01	1	0	1.05	70.40	40.04	1.64	0.11
VA VA	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Office Office	2014 2014	2054 2054	72.12 64.91	10.01 9.01	0.00 7.21	0.00 7.21	0% 10%	0.00 1.00	0.00 1.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 128.71	72.12	10.01	0.00 7.21	0.00 1.00
VA	5700	5702 Data Center Best Practices	Office	2014	2054	56.65	7.86	8.26	15.47	21%	1.15	2.15	21%	0.00	0.00	0	0	52.40			8.26	1.15
VA VA	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Office Office	2014 2014	2054 2054	53.48 82.67	7.42 11.17	3.17 0.00	18.64	26% 0%	0.44	2.59	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	27.18 N/A	82.67	11.17	3.17	0.44
VA	6000	6007 Heat Trap	Office	2014	2054	78.39	10.59	4.28	4.28	5%	0.58	0.58	5%	0.01	0.01	0	0	4.24	02.01		4.28	0.58
VA VA	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Office Office	2014 2014	2054 2054	76.82 71.06	10.38 9.60	1.57 5.76	5.85 11.61	7% 14%	0.21 0.78	0.79 1.57	7% 14%	0.03 0.04	0.02	0	0	2.26 1.61			1.57 5.76	0.21 0.78
VA	6000	6008 Solar Water Heater	Office	2014	2054	33.25	4.49	37.80	49.41	60%	5.11	6.67	60%	0.04	0.05	0	0	1.38			37.80	5.11
VA	6000	6003 Hot Water Pipe Insulation	Office	2014	2054	32.90	4.44	0.35	49.77	60%	0.05	6.72	60%	0.11	0.05	1	0	0.58			0.00	0.00
VA VA	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	Office Office	2014 2014	2054 2054	30.76 29.84	4.16 4.03	2.14 0.92	51.90 52.83	63% 64%	0.29 0.12	7.01 7.14	63% 64%	0.11 0.33	0.05 0.05	1 2	0	0.51 0.19			0.00	0.00
VA	7000	7000 Base Refrigerated Vending Machines	Office	2014	2054	15.06	2.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.06	2.19	0.00	0.00
VA VA	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Office Office	2014 2014	2054 2054	12.80 11.57	2.03 1.94	2.26 1.23	2.26 3.49	15% 23%	0.16 0.09	0.16 0.25	8% 12%	0.02 0.05	0.02 0.03	0	0	1.92 1.04			2.26 1.23	0.16 0.09
VA	7100	7100 Base Non-Refrigerated Vending Machines	Office	2014	2054	0.39	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.39	0.06	0.00	0.00
VA	7100 7200	7101 Vending Misers (Non-Refrigerated)	Office Office	2014 2014	2054	0.22 4.43	0.04	0.17 0.00	0.17	43% 0%	0.01	0.01	21% 0%	0.41	0.41	6 N/A	6 N/A	0.11 N/A	1 12	0.66	0.00	0.00
VA VA	7200	7200 Base Oven 7300 Base Fryer	Office	2014	2054 2054	2.80	0.66 0.42	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	4.43 2.80	0.42	0.00	0.00
VA	7400	7400 Base Steamer	Office	2014	2054	5.82	0.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.82	0.87	0.00	0.00
VA VA	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office Office	2014 2014	2054 2054	61.27 57.82	0.00	0.00 3.46	0.00 3.46	0% 6%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A N/A	N/A N/A	N/A 3.24	61.27	0.00	0.00 3.46	0.00
VA	8100	8100 Base Heating, Other Electric	Office	2014	2054	61.90	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	61.90	0.00	0.00	0.00
VA VA	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Office Office	2014 2014	2054 2054	531.51 531.51	77.37 77.37	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	531.51	77.37	0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Restaurant	2020	2054	14.87	2.94	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.87	2.94	0.00	0.00
VA	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Restaurant	2020	2054	14.85	2.93	0.02	0.02	0%	0.00	0.00	0%	0.01	0.01	0	0	6.10			0.02	0.00
VA VA	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Restaurant Restaurant	2020 2020	2054 2054	13.73 12.30	2.76 2.48	1.12 1.43	1.15 2.57	8% 17%	0.18 0.28	0.18 0.46	6% 16%	0.01 0.03	0.01 0.02	0	0	5.43 1.71			1.12 1.43	0.18 0.28
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Restaurant	2020	2054	10.73	2.17	1.56	4.14	28%	0.31	0.77	26%	0.07	0.04	0	0	0.82			0.00	0.00
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Restaurant	2020	2054	10.58	2.16	0.15	4.29	29%	0.01	0.78	26%	0.13	0.04	3	0	0.39			0.00	0.00

APPENDIX H

Base Avoided Costs

	lectric Existing Construction ADDITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintage			Measure	Manaur				Total	Percent		Total	Percent	Marginal	Average	Marginal						
Base	Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt Number	r Number Measure 30 1034 ROB 4L4' LED Tube, 2020	Type Restaurant	Year 2020	Year 2054	6WH 8.88	MW 1.82	Savings 1.71	5,99	Savings 40%	Savings 0.34	MW 1,11	Savings 38%	\$/kWH 0.40	\$/kWH 0.14	\$/kW 2	\$/kW	0.16	GWH	MW	0.00	0.00
VA 10	30 1035 LED Troffer (base 4L4'T8), 2020	Restaurant	2020	2054	8.12	1.67	0.76	6.75	45%	0.15	1.26	43%	0.33	0.16	2	1	0.19			0.00	0.00
	30 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Restaurant	2020	2054	88.32	17.43	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	88.32	17.43	0.00	0.00
	 1136 Lighting Control Tuneup (base 2L4T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 	Restaurant Restaurant	2020 2020	2054 2054	88.18 81.51	17.42 16.38	0.14 6.67	0.14 6.81	0% 8%	0.01 1.04	0.01 1.06	0% 6%	0.02 0.02	0.02 0.02	0	0	2.91 2.60			0.14 6.67	0.01 1.04
	30 1131 ROB 2L4' High Performance T8 (86 W), 2020	Restaurant	2020	2054	73.03	14.70	8.48	15.29	17%	1.67	2.73	16%	0.04	0.03	Ö	0	1.35			8.48	1.67
	30 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Restaurant	2020	2054	63.74	12.87	9.29	24.58	28%	1.83	4.57	26%	0.09	0.05	0	0	0.65			0.00	0.00
VA 11	30 1134 ROB 2L4' LED Tube, 2020 30 1135 LED Troffer (base 2L4'T8), 2020	Restaurant Restaurant	2020	2054 2054	60.66 55.48	12.26 11.24	3.08 5.18	27.66 32.84	31% 37%	0.61 1.02	5.17 6.20	30% 36%	0.32 0.40	0.08	2	0	0.20			0.00	0.00
VA 11	30 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Restaurant	2020	2054	54.70	11.20	0.78	33.62	38%	0.04	6.23	36%	0.26	0.14	5	1	0.19			0.00	0.00
	1200 Base Other Fluorescent Fixture	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1330 1332 LEDs (base incandescent flood) 2020	Restaurant Restaurant	2020 2020	2054 2054	73.49 15.60	14.51 3.08	0.00 57.89	0.00 57.89	0% 79%	0.00 11.43	0.00 11.43	0% 79%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.93	73.49	14.51	0.00 57.89	0.00 11.43
VA 14	30 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Restaurant	2020	2054	26.46	5.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	26.46	5.22	0.00	0.00
	 1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 	Restaurant Restaurant	2020 2020	2054 2054	6.09 19.48	1.20	20.37	20.37	77% 0%	4.02	4.02 0.00	77% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	6.67 N/A	10.40	3.84	20.37	4.02
	 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020 	Restaurant	2020	2054	6.05	1.19	13.43	13.43	69%	2.65	2.65	69%	0.01	0.01	0	0	4.87	19.48	3.04	13.43	2.65
VA 16	30 1630 Base CFL 18W to screw-in replacement 2020	Restaurant	2020	2054	12.55	2.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.55	2.48	0.00	0.00
	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Restaurant Restaurant	2020 2020	2054 2054	9.07 16.04	1.79 3.17	3.48 0.00	3.48 0.00	28% 0%	0.69	0.69	28% 0%	0.08 N/A	0.08 N/A	0 N/A	0 N/A	0.65 N/A	16.04	3.17	0.00	0.00
	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Restaurant	2020	2054	11.87	2.34	4.17	4.17	26%	0.00	0.00	26%	0.06	0.06	N/A 0	0	0.87	16.04	3.17	0.00	0.00
VA 18	1800 BaseMetal Halide, 465W	Restaurant	2014	2054	0.34	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.34	0.07	0.00	0.00
	00 1801 T5 (240W) (base metal halide)	Restaurant	2014	2054	0.22	0.04	0.11	0.11	34%	0.02	0.02	34%	0.02	0.02	0	0	4.74			0.11	0.02
	1806 Occupancy Sensor, High Bay T5 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Restaurant Restaurant	2014 2014	2054 2054	0.21	0.04	0.01 0.02	0.12 0.14	36% 41%	0.00	0.02 0.03	34% 38%	0.04 1.06	0.02 0.14	1 7	0	1.23 0.06			0.01	0.00
VA 18	50 1850 Base CFL Exit Sign	Restaurant	2014	2054	4.21	0.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.21	0.83	0.00	0.00
	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Restaurant	2014 2014	2054 2054	1.75 102.87	0.35 6.81	2.46	2.46	58% 0%	0.49	0.49 0.00	58% 0%	0.06 N/A	0.06	0	0	0.98	102.87	6.81	0.00	0.00
	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Restaurant Restaurant	2014	2054	85.98	3.48	16.89	0.00 16.89	16%	0.00 3.34	3.34	49%	0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.14	102.87	6.81	0.00 16.89	0.00 3.34
VA 19	00 1902 LED Outdoor Area Lighting	Restaurant	2014	2054	41.37	0.52	44.61	61.50	60%	2.96	6.29	92%	0.16	0.13	2	1	0.39			0.00	0.00
	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Restaurant	2014 2014	2054	29.27 84.79	-0.20 53.08	12.11 0.00	73.60	72%	0.73	7.02	103%	1.02 N/A	0.28	17	3	0.06 N/A	04.70	50.00	0.00	0.00
	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2010 Ceiling/roof Insulation - Chiller	Restaurant Restaurant	2014	2054	78.62	49.22	6.17	0.00 6.17	0% 7%	0.00 3.86	0.00 3.86	0% 7%	0.02	N/A 0.02	N/A 0	N/A 0	7.13	84.79	53.08	0.00 6.17	0.00 3.86
VA 20	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Restaurant	2014	2054	71.91	45.02	6.71	12.88	15%	4.20	8.07	15%	0.02	0.02	0	0	4.81			6.71	4.20
	00 2005 Chiller Tune Up/Diagnostics 00 2003 EMS - Chiller	Restaurant Restaurant	2014 2014	2054 2054	71.78 65.68	44.98 44.04	0.13 6.09	13.02 19.11	15% 23%	0.04 0.93	8.11 9.04	15% 17%	0.02 0.04	0.02 0.02	0	0	3.97 1.65			0.13 6.09	0.04 0.93
	00 2012 Duct Testing/Sealing - Chiller	Restaurant	2014	2054	54.07	36.77	11.62	30.73	36%	7.27	16.31	31%	0.04	0.02	0	0	0.91			0.00	0.93
VA 21	00 2100 Base DX Packaged System, EER=10.3, 10 tons	Restaurant	2014	2054	449.34	281.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	449.34	281.30	0.00	0.00
	00 2113 Ceiling/roof Insulation - DX 00 2102 DX Packaged System, EER=13.4, 10 tons	Restaurant Restaurant	2014 2014	2054 2054	449.20 345.89	281.22 216.54	0.13 103.32	0.13 103.45	0% 23%	0.08 64.68	0.08 64.76	0% 23%	0.01 0.02	0.01 0.02	0	0	7.68 5.44			0.13 103.32	0.08 64.68
	00 2115 Window Film (Standard) - DX	Restaurant	2014	2054	320.80	200.83	25.09	128.53	29%	15.70	80.47	29%	0.02	0.02	0	0	3.77			25.09	15.70
	00 2108 Optimize Controls - DX	Restaurant	2014	2054	315.20	199.98	5.60	134.14	30%	0.86	81.33	29%	0.04	0.02	0	0	1.14			5.60	0.86
	00 2105 DX Tune Up/ Advanced Diagnostics 00 2106 Prog. Thermostat - DX	Restaurant Restaurant	2014 2014	2054 2054	314.84 307.83	199.87 198.79	0.36 7.01	134.49 141.50	30% 31%	0.11 1.07	81.44 82.51	29% 29%	0.07 0.06	0.02 0.02	0	0	0.99			0.00	0.00
	00 2112 Duct Testing/Sealing - DX	Restaurant	2014	2054	290.41	187.88	17.42	158.93	35%	10.91	93.42	33%	0.06	0.02	0	0	0.82			0.00	0.00
	00 2111 Economizer Repair - DX	Restaurant	2014	2054	276.94	175.36	13.46	172.39	38%	12.52	105.94	38%	0.12	0.04	0	0	0.68			0.00	0.00
	00 2107 Cool Roof - DX 00 2109 Economizer - DX	Restaurant Restaurant	2014 2014	2054 2054	268.19 262.70	169.88 169.04	8.76 5.48	181.15 186.63	40% 42%	5.48 0.84	111.42 112.26	40% 40%	0.14 0.15	0.05 0.05	0	0	0.60 0.36			0.00	0.00
	00 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Restaurant	2014	2054	262.70	169.01	0.15	186.78	42%	0.02	112.29	40%	0.15	0.05	1	0	0.36			0.00	0.00
VA 21	00 2114 Duct/Pipe Insulation - DX	Restaurant	2014	2054	259.35	167.01	3.20	189.99	42%	2.00	114.29	41%	1.57	0.07	3	0	0.05			0.00	0.00
	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant Restaurant	2014 2014	2054 2054	140.83 123.41	88.17 77.26	0.00 17.42	0.00 17.42	0% 12%	0.00 10.90	0.00 10.90	0% 12%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.63	140.83	88.17	0.00 17.42	0.00 10.90
	00 2300 Base PTAC, EER=8.3, 1 ton	Restaurant	2014	2054	16.99	10.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.99	10.64	0.00	0.00
VA 30	00 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Restaurant	2014	2054	150.38	38.78	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	150.38	38.78	0.00	0.00
	00 3001 Fan Motor, 5hp, 1800rpm, 89.5% 00 3002 Variable Speed Drive Control, 5 HP	Restaurant Restaurant	2014 2014	2054 2054	147.78 103.43	38.11 35.29	2.59 44.35	2.59 46.94	2% 31%	0.67 2.82	0.67 3.49	2% 9%	0.11 0.08	0.11 0.09	0	0	0.70 0.67			0.00	0.00
	00 3003 Demand Controlled Ventilation	Restaurant	2014	2054	89.51	28.28	13.92	60.86	40%	7.01	10.50	27%	0.85	0.09	2	2	0.67			0.00	0.00
VA 31	00 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	00 3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 00 4000 Base Built-Up Refrigeration System	Restaurant Restaurant	2014 2014	2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
	00 4100 Base Self-Contained Refrigeration	Restaurant	2014	2054	637.81	95.50	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	637.81	95.50	0.00	0.00
VA 41	00 4103 Night covers for display cases (self-contained)	Restaurant	2014	2054	609.06	91.20	28.75	28.75	5%	4.31	4.31	5%	0.00	0.00	0	0	12.67			28.75	4.31
	00 4104 Freezer-Cooler Replacement Gaskets (self-contained) 00 4109 Energy-Star Freezer, glass door	Restaurant Restaurant	2014 2014	2054 2054	600.41 590.83	89.90 88.47	8.65 9.58	37.40 46.98	6% 7%	1.29 1.43	5.60 7.03	6% 7%	0.01 0.01	0.00 0.01	0	0	8.02 6.78			8.65 9.58	1.29 1.43
	00 4107 Energy-Star Freezer, grass door 00 4107 Energy-Star Freezer, solid door	Restaurant	2014	2054	586.86	87.87	3.97	50.95	8%	0.60	7.63	8%	0.01	0.01	0	0	2.73			3.97	0.60
VA 41	00 4108 Energy-Star Refrigerator, glass door	Restaurant	2014	2054	582.47	87.22	4.39	55.34	9%	0.66	8.29	9%	0.03	0.01	0	0	2.22			4.39	0.66
	00 4106 Energy-Star Refrigerator, solid door	Restaurant	2014	2054	573.01	85.80	9.46	64.80	10%	1.42	9.70	10%	0.03	0.01	0	0	2.17			9.46	1.42
	00 4110 Energy Star Ice Machines 00 4112 Reach-in unit occupancy sensors	Restaurant Restaurant	2014 2014	2054 2054	564.41 564.16	84.51 84.48	8.60 0.25	73.40 73.65	12% 12%	1.29 0.04	10.99 11.03	12% 12%	0.07 0.29	0.02 0.02	0 2	0	0.79 0.19			0.00	0.00
VA 41	00 4105 Bi-level LED Case Lighting (self-contained units) 2014	Restaurant	2014	2054	563.06	84.31	1.10	74.74	12%	0.16	11.19	12%	0.34	0.02	2	ő	0.16			0.00	0.00
	00 4101 Strip curtains for walk-ins (self-contained)	Restaurant	2014	2054	560.87	83.98	2.19	76.93	12%	0.33	11.52	12%	0.38	0.03	3	0	0.13	F 60	4.44	0.00	0.00
	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Restaurant Restaurant	2014 2014	2054 2054	5.69 3.14	1.11 0.86	0.00 2.55	0.00 2.55	0% 45%	0.00 0.25	0.00 0.25	0% 23%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.51	5.69	1.11	0.00 2.55	0.00 0.25
	00 5002 Energy Star or Better PC	Restaurant	2014	2054	2.11	0.65	1.03	3.58	63%	0.20	0.46	41%	0.04	0.03	0	0	1.28			1.03	0.20

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

	tric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintage			Measure	Manaur				Total	Percent		Total	Percent	Marginal	Average	Marginal						
Base	Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt Number VA 5100	Number Measure 5100 Base Laptop PC	Type Restaurant	Year 2014	Year 2054	0.23	MW 0.05	Savings 0.00	GWH 0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	0.23	MW 0.05	GWH 0.00	0.00
VA 5100	5102 Energy Star or Better Laptop	Restaurant	2014	2054	0.23	0.05	0.04	0.04	19%	0.00	0.00	19%	0.01	0.01	0	0	3.57	0.23	0.05	0.00	0.00
VA 5100		Restaurant	2014	2054	0.19	0.04	0.00	0.05	21%	0.00	0.01	21%	1.77	0.16	9	1	0.03			0.00	0.00
VA 5200 VA 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Restaurant Restaurant	2014 2014	2054 2054	3.04 1.33	0.59 0.26	0.00 1.71	0.00 1.71	0% 56%	0.00	0.00	0% 56%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 28.38	3.04	0.59	0.00 1.71	0.00
VA 5200	5202 Monitor Power Management Enabling - CRT	Restaurant	2014	2054	1.01	0.23	0.33	2.03	67%	0.03	0.37	62%	0.03	0.01	0	0	1.84			0.33	0.03
VA 5200 VA 5300		Restaurant Restaurant	2014	2054 2054	0.93 1.27	0.21 0.25	0.08	2.11 0.00	69% 0%	0.02	0.38	64% 0%	0.30 N/A	0.02 N/A	2 N/A	0 N/A	0.18 N/A	1.27	0.25	0.00	0.00
VA 5300	5301 Energy Star or Better Monitor - LCD	Restaurant	2014	2054	1.02	0.20	0.25	0.25	20%	0.05	0.05	20%	0.01	0.01	0	0	4.06		0.20	0.25	0.05
VA 5300 VA 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Restaurant Restaurant	2014 2014	2054 2054	0.93	0.19 0.19	0.09 0.07	0.34 0.41	27% 32%	0.01	0.06	24% 25%	0.13 0.36	0.04	1 7	0	0.37 0.12			0.00	0.00
VA 5400	5400 Base Copier	Restaurant	2014	2054	2.37	0.46	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.37	0.46	0.00	0.00
VA 5400 VA 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	Restaurant Restaurant	2014	2054 2054	2.02 1.83	0.39	0.35	0.35 0.54	15% 23%	0.07 0.02	0.07 0.09	15% 19%	0.00	0.00 0.05	0	0	20.57 0.33			0.35 0.00	0.07
VA 5400 VA 5500		Restaurant	2014	2054	0.90	0.38	0.00	0.00	0%	0.02	0.09	0%	0.15 N/A	0.05 N/A	N/A	N/A	0.33 N/A	0.90	0.18	0.00	0.00
VA 5500		Restaurant	2014	2054	0.68	0.13	0.23	0.23	25%	0.04	0.04	25%	0.01	0.01	0	0	5.95			0.23	0.04
VA 5500 VA 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Restaurant Restaurant	2014 2014	2054 2054	0.43 1.03	0.11	0.24	0.47 0.00	52% 0%	0.02	0.07	39% 0%	0.56 N/A	0.29 N/A	6 N/A	2 N/A	0.09 N/A	1.03	0.20	0.00	0.00
VA 5600	5602 ENERGY STAR Printer	Restaurant	2014	2054	0.67	0.13	0.36	0.36	35%	0.07	0.07	35%	0.00	0.00	0	0	27.37			0.36	0.07
VA 5600 VA 5700		Restaurant Restaurant	2014	2054 2054	0.43 5.67	0.11	0.24	0.60 0.00	58% 0%	0.02	0.09	47% 0%	0.12 N/A	0.05 N/A	1 N/A	0 N/A	0.40 N/A	5.67	1.11	0.00	0.00
VA 5700	5701 Data Center Improved Operations	Restaurant	2014	2054	5.10	0.99	0.57	0.57	10%	0.11	0.11	10%	0.00	0.00	0	0	95.51	0.01		0.57	0.11
VA 5700 VA 5700		Restaurant Restaurant	2014	2054 2054	4.45 4.20	0.87	0.65 0.25	1.22 1.46	21% 26%	0.13 0.05	0.24 0.29	21% 26%	0.00	0.00	0	0	38.88 20.17			0.65 0.25	0.13 0.05
VA 6000	6000 Base Water Heating	Restaurant	2014	2054	61.77	10.42	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	61.77	10.42	0.23	0.00
VA 6000 VA 6000		Restaurant	2014 2014	2054 2054	58.57 57.40	9.88 9.69	3.20 1.17	3.20 4.37	5% 7%	0.54 0.20	0.54 0.74	5% 7%	0.01	0.01	0	0	9.61 5.15			3.20	0.54 0.20
VA 6000	6002 High Efficiency Water Heater (electric) 6006 Heat Recovery Unit	Restaurant Restaurant	2014	2054	27.55	4.65	29.85	34.22	7% 55%	5.04	5.77	7% 55%	0.01	0.01	0	0	5.15			1.17 29.85	5.04
VA 6000		Restaurant	2014	2054	25.48	4.30	2.07	36.28	59%	0.35	6.12	59%	0.04	0.01	0	0	1.76			2.07	0.35
VA 6000 VA 6000	6008 Solar Water Heater 6003 Hot Water Pipe Insulation	Restaurant Restaurant	2014 2014	2054 2054	21.92 21.58	3.70 3.64	3.57 0.33	39.85 40.18	65% 65%	0.60 0.06	6.72 6.78	65% 65%	0.05 0.06	0.02 0.02	0	0	1.51 1.18			3.57 0.33	0.60 0.06
VA 6000	6001 Demand controlled circulating systems	Restaurant	2014	2054	20.77	3.51	0.81	40.99	66%	0.14	6.92	66%	0.18	0.02	1	0	0.38			0.00	0.00
VA 7000 VA 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Restaurant Restaurant	2014	2054 2054	4.13 3.46	0.81 0.74	0.00 0.66	0.00 0.66	0% 16%	0.00 0.07	0.00 0.07	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.85	4.13	0.81	0.00 0.66	0.00 0.07
VA 7000	7002 Vending Misers (Refrigerated glass-front units)	Restaurant	2014	2054	3.10	0.71	0.36	1.03	25%	0.04	0.10	12%	0.05	0.03	0	0	1.01			0.36	0.04
VA 7100 VA 7100	7100 Base Non-Refrigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	Restaurant Restaurant	2014 2014	2054 2054	0.06	0.01	0.00	0.00	0% 46%	0.00	0.00	0% 23%	N/A 0.43	N/A 0.43	N/A 4	N/A 4	N/A 0.11	0.06	0.01	0.00	0.00
VA 7200		Restaurant	2014	2054	28.48	5.84	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	28.48	5.84	0.00	0.00
VA 7200	7201 Convection Oven	Restaurant	2014	2054	21.93	4.50	6.55	6.55	23%	1.34	1.34	23%	0.13	0.13	1	1	0.48	05.00	7.04	0.00	0.00
VA 7300 VA 7300	7300 Base Fryer 7301 Efficient Fryer	Restaurant Restaurant	2014 2014	2054 2054	35.82 33.52	7.34 6.87	0.00 2.29	0.00 2.29	0% 6%	0.00 0.47	0.00 0.47	0% 6%	N/A 0.43	N/A 0.43	N/A 2	N/A 2	N/A 0.15	35.82	7.34	0.00	0.00
VA 7400	7400 Base Steamer	Restaurant	2014	2054	45.52	9.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	45.52	9.33	0.00	0.00
VA 7400 VA 8000		Restaurant Restaurant	2014 2014	2054 2054	13.91 1.84	2.85	31.61 0.00	31.61 0.00	69% 0%	6.48 0.00	6.48 0.00	69% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.06 N/A	1.84	0.00	31.61 0.00	6.48 0.00
VA 8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	2014	2054	1.74	0.00	0.10	0.10	6%	0.00	0.00	0%	0.05	0.05	N/A	N/A	1.05			0.10	0.00
VA 8100 VA 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	Restaurant Restaurant	2014 2014	2054 2054	5.09 263.18	0.00 51.65	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	5.09 263.18	0.00 51.65	0.00	0.00
VA 9500	9501 Xmisc	Restaurant	2014	2054	263.18	51.65	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
VA 1030 VA 1030		Retail Retail	2020 2020	2054 2054	894.58 892.49	161.88 161.69	0.00 2.09	0.00 2.09	0% 0%	0.00 0.18	0.00 0.18	0% 0%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.09	894.58	161.88	0.00 2.09	0.00 0.18
VA 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Retail	2020	2054	824.86	152.00	67.63	69.72	8%	9.69	9.87	6%	0.02	0.02	0	0	3.61			67.63	9.69
VA 1030 VA 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Retail Retail	2020 2020	2054 2054	739.07 645.04	136.48 119.46	85.79 94.03	155.51 249.54	17% 28%	15.52 17.02	25.40 42.41	16% 26%	0.03	0.02	0	0	2.18 1.05			85.79 94.03	15.52 17.02
VA 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Retail	2020	2054	636.01	119.46	94.03	249.54 258.58	29%	0.39	42.81	26%	0.05	0.03	2	0	0.50			0.00	0.00
VA 1030		Retail Retail	2020	2054	533.53	100.53	102.48	361.05	40%	18.54	61.35	38% 43%	0.31	0.11	2	1	0.20			0.00	0.00
VA 1030 VA 1130		Retail Retail	2020 2020	2054 2054	487.98 178.68	92.28 32.33	45.55 0.00	406.60 0.00	45% 0%	8.24 0.00	69.59 0.00	43% 0%	0.26 N/A	0.13 N/A	1 N/A	1 N/A	0.25 N/A	178.68	32.33	0.00	0.00
VA 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Retail	2020	2054	178.26	32.30	0.42	0.42	0%	0.04	0.04	0%	0.02	0.02	0	0	2.40			0.42	0.04
VA 1130 VA 1130		Retail Retail	2020 2020	2054	164.75 147.62	30.36 27.26	13.51 17.13	13.93 31.06	8% 17%	1.94 3.10	1.97 5.07	6% 16%	0.03	0.03	0	0	2.12 1.72			13.51 17.13	1.94 3.10
VA 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Retail	2020	2054	128.84	23.86	18.78	49.84	28%	3.40	8.47	26%	0.07	0.04	0	0	0.83			0.00	0.00
VA 1130 VA 1130		Retail Retail	2020 2020	2054 2054	122.61 112.14	22.73 20.84	6.23 10.47	56.07 66.54	31% 37%	1.13 1.89	9.60 11.49	30% 36%	0.25 0.31	0.07 0.11	1 2	0	0.26 0.20			0.00	0.00
VA 1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Retail	2020	2054	110.57	20.77	1.57	68.11	38%	0.07	11.56	36%	0.20	0.11	5	1	0.25			0.00	0.00
VA 1200 VA 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Retail Retail	2014	2054 2054	1.40	0.25 0.25	0.00	0.00 0.02	0% 1%	0.00	0.00	0% 1%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.41	1.40	0.25	0.00 0.02	0.00
VA 1200 VA 1200	1203 Lighting Control Tuneup (base other fluorescent fixture) 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Retail	2014	2054	1.38	0.25	0.02	0.02	9%	0.00	0.00	7%	0.01	0.01	0	0	1.08			0.02	0.00
VA 1200	1201 ROB High Performance T8 (base other fluorescent)	Retail	2014	2054	1.14	0.21	0.13	0.26	18% 21%	0.02	0.04	16% 17%	0.10	0.08	1	0	0.53			0.00	0.00
VA 1200 VA 1200		Retail Retail	2014 2014	2054 2054	1.10 0.96	0.21 0.18	0.04 0.14	0.30 0.44	21% 31%	0.00	0.04 0.07	17% 27%	0.11 0.22	0.08 0.13	3 1	1 1	0.43 0.25			0.00	0.00
VA 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Retail	2020	2054	338.74	61.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	338.74	61.29	0.00	0.00
VA 1330 VA 1430		Retail Retail	2020 2020	2054 2054	59.32 121.95	10.73 22.07	279.42 0.00	279.42 0.00	82% 0%	50.56 0.00	50.56 0.00	82% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	8.61 N/A	121.95	22.07	279.42 0.00	50.56 0.00
VA 1430		Retail	2020	2054	23.23	4.20	98.72	98.72	81%	17.86	17.86	81%	0.01	0.01	0	0	7.27			98.72	17.86

DNV GL 1/5/2015 H-4

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	9			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
0	Base	Measure Number Measure	Building	Start	End Year	Total	Total MW	GWH	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base MW	Economic GWH	Economic MW
VA	Number 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Type Retail	2020	2054	89.77	16.24	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	N/A	\$/kWH N/A	N/A	N/A	TRC N/A	89.77	16.24	0.00	0.00
VA	1530	1532 LEDs (base incandescent A-line 53W) 2020	Retail	2020	2054	23.51	4.25	66.26	66.26	74%	11.99	11.99	74%	0.01	0.01	0	0	5.40			66.26	11.99
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Retail	2020	2054	99.18	17.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	99.18	17.95	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Retail Retail	2020 2020	2054 2054	71.71 126.73	12.98 22.93	27.47 0.00	27.47 0.00	28% 0%	4.97 0.00	4.97 0.00	28% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	0.86 N/A	126.73	22.93	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Retail	2020	2054	93.78	16.97	32.95	32.95	26%	5.96	5.96	26%	0.05	0.05	0	0	1.14	120.75	22.33	32.95	5.96
VA	1800	1800 BaseMetal Halide, 465W	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Retail Retail	2014 2014	2054 2054	11.37 4.99	2.06 0.90	0.00 6.37	0.00 6.37	0% 56%	0.00 1.15	0.00 1.15	0% 56%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A	11.37	2.06	0.00 6.37	0.00 1.15
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Retail	2014	2054	182.10	11.91	0.00	0.00	0%	0.00	0.00	0%	0.04 N/A	0.04 N/A	N/A	N/A	1.31 N/A	182.10	11.91	0.00	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Retail	2014	2054	164.09	8.46	18.02	18.02	10%	3.45	3.45	29%	0.05	0.05	0	0	1.62	102.10		18.02	3.45
VA	1900	1902 LED Outdoor Area Lighting	Retail	2014	2054	78.96	2.89	85.13	103.14	57%	5.57	9.02	76%	0.11	0.10	2	1	0.53			0.00	0.00
VA VA	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Retail Retail	2014 2014	2054 2054	55.87 24.24	1.52 20.03	23.09	126.23 0.00	69% 0%	1.37 0.00	10.39 0.00	87% 0%	0.74 N/A	0.22 N/A	12 N/A	3 N/A	0.08 N/A	24.24	20.03	0.00	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Retail	2014	2054	24.24	19.86	0.00	0.00	1%	0.17	0.00	1%	0.03	0.03	0	0	4.57	24.24	20.03	0.00	0.17
VA	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Retail	2014	2054	21.98	18.16	2.05	2.26	9%	1.70	1.87	9%	0.04	0.04	0	0	2.80			2.05	1.70
VA VA	2000 2000	2005 Chiller Tune Up/Diagnostics 2003 FMS - Chiller	Retail Retail	2014 2014	2054	21.83	18.10 17.71	0.15 1.82	2.41 4.23	10% 17%	0.06	1.93 2.32	10% 12%	0.03	0.04	0	0	2.10 0.83			0.15	0.06
VA VA	2000	2012 Duct Testing/Sealing - Chiller	Retail	2014	2054	20.01 16.21	17.71	3.80	4.23 8.03	33%	3.14	2.32 5.46	27%	0.08	0.06	0	0	0.83			0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Retail	2014	2054	854.18	705.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	854.18	705.93	0.00	0.00
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons	Retail	2014	2054	657.71	543.56	196.46	196.46	23%	162.36	162.36	23%	0.04	0.04	0	0	2.95			196.46	162.36
VA VA	2100 2100	2111 Economizer Repair - DX 2107 Cool Roof - DX	Retail Retail	2014 2014	2054 2054	611.76 584.59	489.86 467.41	45.95 27.18	242.41 269.59	28% 32%	53.70 22.46	216.06 238.52	31% 34%	0.08 0.12	0.05 0.05	0	0	1.08 0.81			45.95 0.00	53.70 0.00
VA	2100	2108 Optimize Controls - DX	Retail	2014	2054	574.97	465.35	9.61	279.20	33%	2.06	240.58	34%	0.12	0.05	0	0	0.51			0.00	0.00
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Retail	2014	2054	572.65	464.36	2.33	281.53	33%	0.99	241.57	34%	0.15	0.06	0	0	0.47			0.00	0.00
VA	2100	2109 Economizer - DX	Retail	2014	2054	523.89	453.91	48.76	330.29	39%	10.45	252.01	36%	0.13	0.07	1	0	0.45			0.00	0.00
VA VA	2100 2100	2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX	Retail Retail	2014 2014	2054 2054	492.03 478.43	427.59 424.67	31.85 13.60	362.14 375.74	42% 44%	26.32 2.91	278.34 281.25	39% 40%	0.31 0.18	0.09	0	0	0.39 0.32			0.00	0.00
VA	2100	2115 Window Film (Standard) - DX	Retail	2014	2054	476.68	423.23	1.75	377.50	44%	1.45	282.70	40%	0.18	0.09	0	0	0.25			0.00	0.00
VA	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Retail	2014	2054	476.48	423.18	0.20	377.70	44%	0.04	282.74	40%	0.29	0.09	1	0	0.21			0.00	0.00
VA VA	2100 2200	2114 Duct/Pipe Insulation - DX	Retail Retail	2014 2014	2054	472.98	420.29	3.50 0.00	381.20	45% 0%	2.89	285.64	40%	3.45 N/A	0.12 N/A	4	0	0.03	047.00	262.17	0.00	0.00
VA VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	2014	2054	317.23 278.00	262.17 229.75	39.23	0.00 39.23	12%	32.42	0.00 32.42	0% 12%	0.03	0.03	N/A 0	N/A 0	N/A 4.14	317.23	262.17	39.23	32.42
VA	2300	2300 Base PTAC, EER=8.3, 1 ton	Retail	2014	2054	55.95	46.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	55.95	46.24	0.00	0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Retail	2014	2054	578.78	162.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	578.78	162.16	0.00	0.00
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP	Retail Retail	2014 2014	2054 2054	569.62 403.89	159.59 147.97	9.16 165.73	9.16 174.89	2% 30%	2.57 11.62	2.57 14.18	2% 9%	0.02 0.02	0.02 0.02	0	0	3.41 3.19			9.16 165.73	2.57 11.62
VA	3000	3003 Demand Controlled Ventilation	Retail	2014	2054	361.48	125.40	42.41	217.30	38%	22.57	36.76	23%	1.14	0.24	2	1	0.08			0.00	0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Retail	2014	2054	20.17	5.65	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	20.17	5.65	0.00	0.00
VA VA	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Retail Retail	2014 2014	2054 2054	17.26 15.54	4.92 4.80	2.91 1.73	2.91 4.63	14% 23%	0.73 0.12	0.73 0.85	13% 15%	0.03	0.03	0	0	2.44 1.86			2.91 1.73	0.73
VA	3100	3102 Variable Speed Drive Control, 15 HP	Retail	2014	2054	11.02	4.48	4.52	9.15	45%	0.12	1.17	21%	0.03	0.05	1	0	0.86			0.00	0.12
VA	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Retail	2014	2054	10.99	4.47	0.03	9.18	46%	0.01	1.18	21%	0.20	0.05	1	0	0.39			0.00	0.00
VA	3100	3105 Energy Recovery Ventilation (ERV)	Retail	2014	2054	10.23	4.07	0.75	9.94	49%	0.40	1.58	28%	0.45	0.08	1	0	0.23			0.00	0.00
VA VA	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Retail Retail	2014 2014	2054	9.16 20.17	3.50 5.65	1.07	11.01	55% 0%	0.57	2.15 0.00	38% 0%	1.57 N/A	0.22 N/A	3 N/A	1 N/A	0.06 N/A	20.17	5.65	0.00	0.00
VA	3200	3203 Air Handler Optimization, 40 HP	Retail	2014	2054	18.15	5.51	2.02	2.02	10%	0.14	0.14	3%	0.02	0.02	0	0	2.17	20.17	5.05	2.02	0.14
VA	3200	3202 Variable Speed Drive Control, 40 HP	Retail	2014	2054	12.87	5.14	5.28	7.30	36%	0.37	0.51	9%	0.06	0.05	1	1	1.03			5.28	0.37
VA VA	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	12.85 11.50	5.13 4.41	0.03 1.35	7.32 8.67	36% 43%	0.01 0.72	0.52 1.24	9% 22%	0.27 1.25	0.05 0.23	1 2	1 2	0.29 0.08			0.00	0.00
VA	4000	4000 Base Built-Up Refrigeration System	Retail	2014	2054	0.00	0.00	0.00	0.00	43% 0%	0.72	0.00	0%	N/A	0.23 N/A	N/A	N/A	0.06 N/A	0.00	0.00	0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Retail	2014	2054	466.01	70.84	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	466.01	70.84	0.00	0.00
VA	4100	4103 Night covers for display cases (self-contained)	Retail	2014	2054	457.33	69.52	8.69 1.88	8.69	2%	1.32	1.32	2%	0.01	0.01	0	0	5.38			8.69	1.32
VA VA	4100 4100	4109 Energy-Star Freezer, glass door 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Retail Retail	2014 2014	2054 2054	455.44 445.67	69.23 67.75	1.88 9.77	10.57 20.34	2% 4%	0.29 1.49	1.61 3.09	2% 4%	0.04 0.04	0.01 0.02	0	0	1.54 1.40			1.88 9.77	0.29 1.49
VA	4100	4107 Energy-Star Freezer, solid door	Retail	2014	2054	444.90	67.63	0.77	21.11	5%	0.12	3.21	5%	0.09	0.03	1	0	0.61			0.00	0.00
VA	4100	4108 Energy-Star Refrigerator, glass door	Retail	2014	2054	437.40	66.49	7.50	28.61	6%	1.14	4.35	6%	0.11	0.05	1	0	0.52			0.00	0.00
VA VA	4100 4100	4106 Energy-Star Refrigerator, solid door 4112 Reach-in unit occupancy sensors	Retail Retail	2014 2014	2054 2054	436.20 435.01	66.30 66.12	1.21 1.19	29.82 31.00	6% 7%	0.18 0.18	4.53 4.71	6% 7%	0.12 0.28	0.05 0.06	1 2	0	0.49 0.21			0.00	0.00
VA	4100	4110 Energy Star Ice Machines	Retail	2014	2054	434.20	66.00	0.81	31.81	7%	0.18	4.71	7%	0.20	0.06	2	0	0.21			0.00	0.00
VA	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Retail	2014	2054	432.07	65.68	2.14	33.94	7%	0.32	5.16	7%	0.31	80.0	2	1	0.17			0.00	0.00
VA	4100	4101 Strip curtains for walk-ins (self-contained)	Retail	2014	2054	431.63	65.61	0.44	34.38	7%	0.07	5.23	7%	1.93	0.11	13	1	0.03	24.54	201	0.00	0.00
VA VA	5000 5000	5000 Base Desktop PC 5002 Energy Star or Better PC	Retail Retail	2014 2014	2054 2054	21.51 18.25	3.84 3.26	0.00 3.26	0.00 3.26	0% 15%	0.00 0.58	0.00 0.58	0% 15%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 3.49	21.51	3.84	0.00 3.26	0.00 0.58
VA	5000	5001 PC Network Power Management Enabling	Retail	2014	2054	10.03	2.51	8.22	11.48	53%	0.75	1.33	35%	0.02	0.02	0	0	2.73			8.22	0.75
VA	5100	5100 Base Laptop PC	Retail	2014	2054	0.89	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.89	0.16	0.00	0.00
VA	5100	5102 Energy Star or Better Laptop	Retail	2014	2054	0.72	0.13	0.17	0.17	19%	0.03	0.03	19%	0.01	0.01	0 8	0	4.53			0.17	0.03
VA VA	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Retail Retail	2014 2014	2054 2054	0.71 4.90	0.13 0.87	0.01 0.00	0.18	21% 0%	0.00	0.03	21% 0%	1.38 N/A	0.12 N/A	8 N/A	1 N/A	0.04 N/A	4.90	0.87	0.00	0.00
VA	5200	5201 Energy Star or Better Monitor - CRT	Retail	2014	2054	2.15	0.38	2.75	2.75	56%	0.49	0.49	56%	0.00	0.00	0	0	36.02			2.75	0.49
VA	5200	5202 Monitor Power Management Enabling - CRT	Retail	2014	2054	1.80	0.35	0.35	3.10	63%	0.03	0.52	60%	0.02	0.00	0	0	2.75			0.35	0.03
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, I CD	Retail Retail	2014 2014	2054 2054	1.66 3.06	0.33 0.55	0.14 0.00	3.24 0.00	66% 0%	0.03	0.55	63% 0%	0.21 N/A	0.01 N/A	1 N/A	0 N/A	0.25 N/A	3.06	0.55	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Retail	2014	2054	2.64	0.47	0.42	0.42	14%	0.08	0.08	14%	0.01	0.01	0	0	5.55	3.00	0.00	0.42	0.08
		•					-	-	-							-					-	

APPENDIX H

Base Avoided Costs

		c Existing Construction TIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	9			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
		Measure Number Measure	Building	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH	MW Savings	Savings	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic MW
VA	Number 5300	5302 Monitor Power Management Enabling - LCD	Type Retail	2014	2054	2.54	0.46	0.10	0.53	Savings 17%	0.01	0.09	Savings 16%	0.09	0.02	\$/KVV	0	0.54	GWH	IVIVV	0.00	0.00
VA	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Retail	2014	2054	2.34	0.45	0.19	0.72	24%	0.01	0.09	17%	0.25	0.08	5	1	0.18			0.00	0.00
VA VA	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Retail Retail	2014 2014	2054 2054	10.62 9.10	1.90 1.62	0.00 1.52	0.00 1.52	0% 14%	0.00 0.27	0.00 0.27	0% 14%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 26.26	10.62	1.90	0.00 1.52	0.00 0.27
VA	5400	5402 Copier Power Management Enabling	Retail	2014	2054	8.67	1.58	0.43	1.95	18%	0.04	0.31	16%	0.11	0.03	1	0	0.45			0.00	0.00
VA VA	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Printer	Retail Retail	2014 2014	2054 2054	1.62 1.22	0.29	0.00	0.00 0.41	0% 25%	0.00	0.00 0.07	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.56	1.62	0.29	0.00	0.00
VA	5500	5501 Multifunction Power Management Enabling	Retail	2014	2054	1.05	0.22	0.41	0.58	36%	0.07	0.07	30%	0.01	0.01	3	1	0.17			0.41	0.00
VA	5600	5600 Base Printer	Retail	2014	2054	4.65	0.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.65	0.83	0.00	0.00
VA VA	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Retail Retail	2014 2014	2054 2054	3.03 2.60	0.54	1.62 0.43	1.62 2.04	35% 44%	0.29 0.04	0.29 0.33	35% 39%	0.00 0.06	0.00 0.01	0	0	34.75 0.80			1.62 0.00	0.29
VA	5700	5700 Base Data Center/Server Room	Retail	2014	2054	16.72	2.98	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.72	2.98	0.00	0.00
VA VA	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Retail Retail	2014 2014	2054 2054	15.05 13.13	2.69 2.34	1.67 1.91	1.67 3.59	10% 21%	0.30 0.34	0.30 0.64	10% 21%	0.00	0.00	0	0	107.49 43.76			1.67 1.91	0.30 0.34
VA	5700	5703 Data Center State of the Art practices	Retail	2014	2054	12.40	2.34	0.74	4.32	26%	0.34	0.64	26%	0.00	0.00	0	0	22.70			0.74	0.34
VA	6000	6000 Base Water Heating	Retail	2014	2054	88.87	14.28	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	88.87	14.28	0.00	0.00
VA VA	6000 6000	6007 Heat Trap 6002 High Efficiency Water Heater (electric)	Retail Retail	2014 2014	2054 2054	84.27 82.61	13.54 13.27	4.60 1.66	4.60 6.26	5% 7%	0.74 0.27	0.74 1.01	5% 7%	0.02 0.04	0.02	0	0	2.86 1.53			4.60 1.66	0.74 0.27
VA	6000	6004 Tankless Water Heater	Retail	2014	2054	76.41	12.28	6.20	12.46	14%	1.00	2.00	14%	0.04	0.05	0	0	1.09			6.20	1.00
VA	6000	6008 Solar Water Heater	Retail	2014	2054	74.27	11.93	2.14	14.60	16%	0.34	2.35	16%	0.08	0.05	0	0	0.93			0.00	0.00
VA VA	6000 6000	6003 Hot Water Pipe Insulation 6006 Heat Recovery Unit	Retail Retail	2014 2014	2054 2054	73.05 70.68	11.74 11.35	1.22 2.37	15.82 18.19	18% 20%	0.20 0.38	2.54 2.92	18% 20%	0.08	0.05	0	0	0.82 0.64			0.00	0.00
VA	6000	6001 Demand controlled circulating systems	Retail	2014	2054	69.59	11.18	1.09	19.28	22%	0.17	3.10	22%	0.13	0.06	1	Ö	0.50			0.00	0.00
VA VA	7000 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Retail Retail	2014 2014	2054 2054	22.16 19.04	3.96 3.68	0.00 3.13	0.00 3.13	0% 14%	0.00 0.28	0.00 0.28	0% 7%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.01	22.16	3.96	0.00 3.13	0.00
VA	7000	7001 Vending Misers (Refrigerated drifts) 7002 Vending Misers (Refrigerated glass-front units)	Retail	2014	2054	17.35	3.53	1.69	4.82	22%	0.26	0.43	11%	0.02	0.02	0	0	1.09			1.69	0.28
VA	7100	7100 Base Non-Refrigerated Vending Machines	Retail	2014	2054	0.11	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.02	0.00	0.00
VA VA	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Retail Retail	2014 2014	2054 2054	0.06 14.10	0.02 2.55	0.04	0.04	40% 0%	0.00	0.00	20% 0%	0.40 N/A	0.40 N/A	4 N/A	4 N/A	0.12 N/A	14.10	2.55	0.00	0.00
VA	7200	7201 Convection Oven	Retail	2014	2054	10.86	1.96	3.24	3.24	23%	0.59	0.59	23%	0.13	0.13	1	1	0.47			0.00	0.00
VA	7300	7300 Base Fryer	Retail	2014	2054	2.58	0.47	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.58	0.47	0.00	0.00
VA VA	7300 7400	7301 Efficient Fryer 7400 Base Steamer	Retail Retail	2014 2014	2054 2054	2.41 10.12	0.44 1.83	0.16	0.16 0.00	6% 0%	0.03	0.03	6% 0%	0.43 N/A	0.43 N/A	2 N/A	2 N/A	0.15 N/A	10.12	1.83	0.00	0.00
VA	7400	7401 Efficient Steamer	Retail	2014	2054	3.61	0.65	6.51	6.51	64%	1.18	1.18	64%	0.05	0.05	0	0	1.21			6.51	1.18
VA VA	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail Retail	2014 2014	2054 2054	13.99 13.20	0.00	0.00 0.79	0.00 0.79	0% 6%	0.00	0.00	0% 0%	N/A 0.04	N/A 0.04	N/A N/A	N/A N/A	N/A 1.28	13.99	0.00	0.00 0.79	0.00
VA	8100	8100 Base Heating, Other Electric	Retail	2014	2054	51.10	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	51.10	0.00	0.00	0.00
VA	9500	9500 Base Miscellaneous	Retail	2014		1,389.43		0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1,389.43	248.50	0.00	0.00
VA VA	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Retail Grocery	2014 2020	2054	1,389.43	248.50 22.11	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	144.92	22.11	0.00	0.00
VA	1030	1036 Lighting Control Tuneup (base 4L4T8), 2020	Grocery	2020	2054	144.77	22.10	0.15	0.15	0%	0.01	0.01	0%	0.01	0.01	0	0	5.32			0.15	0.01
VA	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Grocery	2020	2054 2054	133.68 119.99	20.77 18.69	11.09 13.69	11.24 24.93	8% 17%	1.33 2.09	1.34	6% 15%	0.01 0.03	0.01 0.02	0	0	4.56			11.09 13.69	1.33 2.09
VA VA	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Grocery Grocery	2020 2020	2054	104.72	16.36	15.27	40.20	28%	2.09	3.42 5.75	26%	0.03	0.02	0	0	1.52 0.73			0.00	0.00
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Grocery	2020	2054	103.17	16.30	1.56	41.76	29%	0.06	5.81	26%	0.10	0.04	3	0	0.51			0.00	0.00
VA VA	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Grocery Grocery	2020 2020	2054 2054	86.54 79.16	13.77 12.64	16.62 7.39	58.38 65.77	40% 45%	2.54 1.13	8.34 9.47	38% 43%	0.42 0.35	0.15 0.17	3	1	0.13			0.00	0.00
VA	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Grocery	2020	2054	0.51	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.51	0.08	0.00	0.00
VA VA	1130 1130	1136 Lighting Control Tuneup (base 2L4T8), 2020	Grocery	2020	2054 2054	0.51	0.08	0.00	0.00	0% 8%	0.00	0.00	0% 6%	0.01	0.01	0	0	4.45 3.82			0.00	0.00
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Grocery Grocery	2020 2020	2054	0.47	0.07	0.04	0.04	8% 17%	0.00	0.00	15%	0.02	0.02	0	0	1.21			0.04	0.00
VA	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Grocery	2020	2054	0.37	0.06	0.05	0.14	27%	0.01	0.02	26%	0.09	0.05	1	ō	0.58			0.00	0.00
VA VA	1130 1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1134 ROB 2L4' LED Tube, 2020	Grocery Grocery	2020 2020	2054 2054	0.36 0.35	0.06	0.01 0.02	0.15	29% 32%	0.00	0.02 0.02	26% 29%	0.17 0.34	0.06 0.09	5 2	0	0.29			0.00	0.00
VA	1130	1135 LED Troffer (base 2L4T8), 2020	Grocery	2020	2054	0.32	0.05	0.03	0.19	38%	0.00	0.03	35%	0.43	0.14	3	1	0.13			0.00	0.00
VA	1200	1200 Base Other Fluorescent Fixture	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Grocery Grocery	2020 2020	2054 2054	44.35 16.64	6.77 2.54	0.00 27.71	0.00 27.71	0% 62%	0.00 4.23	0.00 4.23	0% 62%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 11.48	44.35	6.77	0.00 27.71	0.00 4.23
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Grocery	2020	2054	15.97	2.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.97	2.44	0.00	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Grocery Grocery	2020 2020	2054 2054	6.38 11.75	0.97 1.79	9.59 0.00	9.59 0.00	60% 0%	1.46 0.00	1.46 0.00	60% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	9.48 N/A	11.75	1.79	9.59 0.00	1.46 0.00
VA	1530	1530 base incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Grocery	2020	2054	5.89	0.90	5.87	5.87	50%	0.00	0.90	50%	0.01	0.01	0	0	6.43	11.75	1.79	5.87	0.90
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Grocery	2020	2054	3.18	0.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.18	0.48	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Grocery Grocery	2020 2020	2054 2054	2.30 4.06	0.35	0.88	0.88	28% 0%	0.13	0.13	28% 0%	0.10 N/A	0.10 N/A	1 N/A	1 N/A	0.53 N/A	4.06	0.62	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Grocery	2020	2054	3.01	0.46	1.06	1.06	26%	0.16	0.16	26%	0.07	0.07	0	0	0.71			0.00	0.00
VA	1800	1800 BaseMetal Halide, 465W	Grocery	2014	2054	7.60	1.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.60	1.16	0.00	0.00
VA VA	1800 1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1801 T5 (240W) (base metal halide)	Grocery Grocery	2014 2014	2054 2054	7.02 4.64	1.09 0.73	0.58 2.37	0.58 2.95	8% 39%	0.07 0.36	0.07 0.43	6% 37%	0.01 0.01	0.01 0.01	0	0	10.52 5.22			0.58 2.37	0.07
VA	1800	1806 Occupancy Sensor, High Bay T5	Grocery	2014	2054	4.49	0.72	0.16	3.11	41%	0.01	0.44	38%	0.03	0.01	1	ō	1.47			0.16	0.01
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Grocery Grocery	2014 2014	2054 2054	0.30	0.05	0.00 0.01	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.89	0.30	0.05	0.00 0.01	0.00
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Grocery	2014	2054	2.31	0.04	0.00	0.00	2% 0%	0.00	0.00	2% 0%	0.03 N/A	0.03 N/A	N/A	N/A	1.89 N/A	2.31	0.06	0.00	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Grocery	2014	2054	2.05	0.04	0.26	0.26	11%	0.02	0.02	36%	0.08	0.08	1	1	0.82			0.00	0.00

APPENDIX H

Base Avoided Costs

			c Existing Construction TIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
	/intage									Total			Total		Marginal	Average	Marginal	Average	Total			00	
	Base		leasure	Building	Measure	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy	Capacity	Capacity	Resource Cost Test	Base	Base	Economic	Economic
S	Sgmt Num		lumber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
	/A /A	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Grocery Grocery	2014	2054 2054	0.99	0.01	1.07 0.29	1.33 1.62	57% 70%	0.03 0.01	0.05 0.05	82% 94%	0.17 1.12	0.15 0.33	7 52	4 10	0.33 0.05			0.00	0.00
	/A	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Grocery	2014	2054	4.02	2.62	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.02	2.62	0.00	0.00
	/A	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Grocery	2014	2054	3.67	2.40	0.34	0.34	9%	0.22	0.22	9%	0.04	0.04	0	0	3.06			0.34	0.22
	/A /A	2000 2000	2005 Chiller Tune Up/Diagnostics 2013 High Efficiency Chiller Motors	Grocery Grocery	2014 2014	2054 2054	3.67 3.55	2.40 2.32	0.01 0.12	0.35 0.47	9% 12%	0.00 80.0	0.23 0.30	9% 12%	0.03 0.06	0.04 0.04	0	0	2.50 1.94			0.01 0.12	0.00 80.0
	/A	2000	2006 VSD for Chiller Pumps and Towers	Grocery	2014	2054	3.19	2.20	0.36	0.83	21%	0.12	0.42	16%	0.05	0.04	0	0	1.66			0.36	0.12
	/A	2000	2002 Window Film (Standard) - Chiller	Grocery	2014	2054	2.97	2.06	0.22	1.05	26%	0.14	0.56	21%	0.08	0.05	0	0	1.04			0.22	0.14
	/A /A	2000 2000	2003 EMS - Chiller 2004 Cool Roof - Chiller	Grocery Grocery	2014 2014	2054 2054	2.67 2.47	2.01 1.88	0.29 0.21	1.34 1.55	33% 39%	0.05 0.13	0.61 0.74	23% 28%	0.08 0.12	0.06 0.07	0	0	0.83 0.69			0.00	0.00
	/A	2000	2012 Duct Testing/Sealing - Chiller	Grocery	2014	2054	2.00	1.57	0.47	2.02	50%	0.31	1.05	40%	0.25	0.11	0	0	0.42			0.00	0.00
	/A	2000	2011 Duct/Pipe Insulation - Chiller	Grocery	2014	2054	1.97	1.55	0.03	2.05	51%	0.02	1.07	41%	3.91	0.16	6	0	0.02			0.00	0.00
	/A /A	2000 2100	2008 New Economizer - Chiller 2100 Base DX Packaged System, EER=10.3, 10 tons	Grocery Grocery	2014	2054 2054	1.97 124.62	1.55 81.40	0.00	2.05	51% 0%	0.00	1.07 0.00	41% 0%	41971.95 N/A	0.17 N/A	263,846 N/A	0 N/A	0.00 N/A	124.62	81.40	0.00	0.00
	/A	2100	2113 Ceiling/roof Insulation - DX	Grocery	2014	2054	124.46	81.29	0.16	0.16	0%	0.11	0.11	0%	0.03	0.03	0	0	3.70	12 1.02	01.10	0.16	0.11
	/A	2100	2102 DX Packaged System, EER=13.4, 10 tons	Grocery	2014	2054	95.83	62.59	28.63	28.79	23%	18.70	18.80	23%	0.03	0.03	0	0	3.20			28.63	18.70
		2100 2100	2115 Window Film (Standard) - DX 2107 Cool Roof - DX	Grocery Grocery	2014 2014	2054 2054	89.16 82.27	58.24 53.74	6.67 6.89	35.45 42.34	28% 34%	4.36 4.50	23.16 27.66	28% 34%	0.08 0.11	0.04 0.05	0	0	1.01 0.74			6.67 0.00	4.36 0.00
	/A	2100	2105 DX Tune Up/ Advanced Diagnostics	Grocery	2014	2054	82.18	53.71	0.09	42.44	34%	0.03	27.69	34%	0.12	0.05	Ö	Ö	0.55			0.00	0.00
		2100	2108 Optimize Controls - DX	Grocery	2014	2054	80.74	53.48	1.44	43.88	35%	0.23	27.92	34%	0.10	0.05	1	0	0.50			0.00	0.00
		2100 2100	2106 Prog. Thermostat - DX 2112 Duct Testing/Sealing - DX	Grocery Grocery	2014 2014	2054 2054	79.54 74.70	53.29 50.13	1.20 4.84	45.08 49.92	36% 40%	0.19 3.16	28.11 31.27	35% 38%	0.12	0.06 0.07	1	0	0.45			0.00	0.00
	/A	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Grocery	2014	2054	74.68	50.12	0.02	49.94	40%	0.00	31.27	38%	0.70	0.07	4	Ö	0.08			0.00	0.00
	/A	2100	2111 Economizer Repair - DX	Grocery	2014	2054	73.87	49.35	0.81	50.75	41%	0.77	32.04	39% 39%	1.36	0.10	1	0	0.06			0.00	0.00
		2100 2100	2109 Economizer - DX 2114 Duct/Pipe Insulation - DX	Grocery Grocery	2014 2014	2054 2054	73.86 72.75	49.35 48.63	0.01 1.11	50.76 51.87	41% 42%	0.00 0.72	32.04 32.77	39% 40%	1.70 3.28	0.10 0.16	11 5	0	0.03			0.00	0.00
V	/A	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Grocery	2014	2054	11.12	7.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.12	7.26	0.00	0.00
	/A	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	2014	2054	9.75	6.37	1.38	1.38	12%	0.90	0.90	12%	0.03	0.03	0	0	3.67			1.38	0.90
	/A /A	2300 3000	2300 Base PTAC, EER=8.3, 1 ton 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Grocery Grocery	2014 2014	2054 2054	5.16 121.17	3.37 25.96	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	5.16 121.17	3.37 25.96	0.00	0.00
V	/A	3000	3002 Variable Speed Drive Control, 5 HP	Grocery	2014	2054	83.66	24.01	37.51	37.51	31%	1.95	1.95	7%	0.03	0.03	1	1	1.93		20.00	37.51	1.95
	/A	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Grocery	2014	2054	82.22	23.70	1.44	38.95	32%	0.31	2.25	9%	0.06	0.03	0	1	1.31			1.44	0.31
	/A /A	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Grocery Grocery	2014 2014	2054 2054	70.52 0.00	18.68 0.00	11.70 0.00	50.65 0.00	42% 0%	5.02 0.00	7.27 0.00	28% 0%	1.14 N/A	0.29 N/A	3 N/A	2 N/A	0.08 N/A	0.00	0.00	0.00	0.00
	/A	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Grocery	2014	2054	119.80	25.66	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	119.80	25.66	0.00	0.00
	/A	3200	3203 Air Handler Optimization, 40 HP	Grocery	2014	2054	107.44	25.02	12.37	12.37	10%	0.64	0.64	3%	0.02	0.02	0	0	2.37			12.37	0.64
	/A /A	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Grocery Grocery	2014 2014	2054 2054	92.15 504.16	18.46 81.17	15.28 0.00	27.65 0.00	23% 0%	6.56 0.00	7.20 0.00	28% 0%	0.86 N/A	0.49 N/A	2 N/A	2 N/A	0.10 N/A	504.16	81.17	0.00	0.00
V	/A	4000	4007 Efficient compressor motor	Grocery	2014	2054	503.18	81.01	0.98	0.98	0%	0.16	0.16	0%	0.02	0.02	0	0	3.52		*****	0.98	0.16
	/A	4000	4011 Demand Hot Gas Defrost	Grocery	2014	2054	490.60	78.98	12.58	13.56	3%	2.03	2.18	3%	0.02	0.02	0	0	3.25			12.58	2.03
	/A /A	4000 4000	4006 Electronically commutated evaporator fan motor 4009 Floating head pressure controls	Grocery Grocery	2014 2014	2054 2054	455.70 454.58	73.36 73.27	34.90 1.12	48.46 49.58	10% 10%	5.62 0.09	7.80 7.89	10% 10%	0.02 0.02	0.02 0.02	0	0	2.96 2.73			34.90 1.12	5.62 0.09
	/A	4000	4002 Strip curtains for walk-ins (built-up)	Grocery	2014	2054	450.63	72.64	3.94	53.52	11%	0.63	8.53	11%	0.04	0.02	0	0	1.35			3.94	0.63
	/A	4000	4013 Anti-sweat (humidistat) controls	Grocery	2014	2054	444.35	72.13	6.29	59.81	12%	0.51	9.03	11%	0.04	0.02	1	0	1.29			6.29	0.51
	/A /A	4000 4000	4014 Freezer-Cooler Replacement Gaskets 4018 Oversized Air Cooled Condenser	Grocery Grocery	2014 2014	2054 2054	429.18 411.11	69.69 66.78	15.16 18.07	74.98 93.05	15% 18%	2.44 2.91	11.47 14.38	14% 18%	0.05 0.08	0.03 0.04	0	0	0.93 0.85			0.00	0.00
V	/A	4000	4004 Night covers for display cases	Grocery	2014	2054	389.44	65.04	21.67	114.72	23%	1.74	16.13	20%	0.07	0.04	1	0	0.72			0.00	0.00
	/A	4000	4001 High-efficiency fan motors	Grocery	2014	2054	375.71	62.83	13.73	128.45	25%	2.21	18.34	23%	0.11	0.05	1	0	0.64			0.00	0.00
	/A /A	4000 4000	4008 Compressor VSD retrofit 4010 Refrigeration Commissioning	Grocery Grocery	2014 2014	2054 2054	352.42 350.61	60.95 60.66	23.29 1.81	151.74 153.55	30% 30%	1.88 0.29	20.21 20.50	25% 25%	0.10 0.18	0.06	1	0	0.55 0.28			0.00	0.00
V	/A	4000	4005 Evaporator fan controller for MT walk-ins	Grocery	2014	2054	350.36	60.64	0.25	153.80	31%	0.02	20.52	25%	0.24	0.06	3	0	0.25			0.00	0.00
	/A /A	4000 4000	4017 Multiplex Compressor System 4016 LED Display Lighting	Grocery	2014 2014	2054 2054	344.19 317.93	59.65 55.42	6.17 26.26	159.97 186.23	32% 37%	0.99 4.23	21.52 25.74	27% 32%	0.26 0.43	0.07 0.12	2	1	0.24 0.13			0.00	0.00
	/A	4000	4016 LED Display Lighting 4015 High R-Value Glass Doors	Grocery	2014	2054	317.93	55.42	4.92	191.15	38%	0.79	25.74 26.54	32%	1.94	0.12	3 12	1	0.13			0.00	0.00
V	/A	4100	4100 Base Self-Contained Refrigeration	Grocery	2014	2054	57.45	9.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	57.45	9.25	0.00	0.00
	/A	4100	4103 Night covers for display cases (self-contained)	Grocery	2014	2054	56.06	9.03	1.39	1.39	2%	0.22	0.22	2%	0.00	0.00	0	0	161.00			1.39	0.22
		4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4109 Energy-Star Freezer, glass door	Grocery Grocery	2014 2014	2054 2054	55.32 52.33	8.91 8.43	0.74 2.99	2.13 5.12	4% 9%	0.12 0.48	0.34 0.82	4% 9%	0.01 0.03	0.00 0.02	0	0	3.73 2.18			0.74 2.99	0.12 0.48
V	/A	4100	4107 Energy-Star Freezer, solid door	Grocery	2014	2054	51.16	8.24	1.18	6.29	11%	0.19	1.01	11%	0.07	0.03	Ō	ō	0.83			0.00	0.00
	/A	4100	4108 Energy-Star Refrigerator, glass door	Grocery	2014	2054	51.09	8.23	0.06	6.36	11%	0.01	1.02	11%	0.09	0.03	1	0	0.65			0.00	0.00
	/A /A	4100 4100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Grocery Grocery	2014 2014	2054 2054	51.07 51.05	8.22 8.22	0.03 0.02	6.38 6.40	11% 11%	0.00	1.03 1.03	11% 11%	0.09 0.24	0.03	1	0	0.62 0.24			0.00	0.00
V	/A	4100	4112 Reach-in unit occupancy sensors	Grocery	2014	2054	51.04	8.22	0.01	6.41	11%	0.00	1.03	11%	0.29	0.03	2	ō	0.20			0.00	0.00
	/A	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Grocery	2014	2054	50.70	8.16	0.35	6.75	12%	0.06	1.09	12%	0.33	0.04	2	0	0.16			0.00	0.00
	/A /A	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Grocery Grocery	2014 2014	2054 2054	50.52 2.29	8.13 0.41	0.17 0.00	6.93 0.00	12% 0%	0.03	1.12 0.00	12% 0%	0.64 N/A	0.06 N/A	4 N/A	0 N/A	0.08 N/A	2.29	0.41	0.00	0.00
V	/A	5000	5001 PC Network Power Management Enabling	Grocery	2014	2054	1.25	0.32	1.03	1.03	45%	0.09	0.09	23%	0.02	0.02	0	0	2.15	2.20	0	1.03	0.09
	/A	5000	5002 Energy Star or Better PC	Grocery	2014	2054	0.85	0.24	0.41	1.44	63%	0.07	0.17	41%	0.05	0.03	0	0	1.08	0.07	0.04	0.41	0.07
	/A /A	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Grocery Grocery	2014 2014	2054 2054	0.07	0.01	0.00 0.01	0.00 0.01	0% 19%	0.00	0.00	0% 19%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.02	0.07	0.01	0.00 0.01	0.00
V	/A	5100	5101 Laptop Network Power Management Enabling	Grocery	2014	2054	0.06	0.01	0.00	0.01	21%	0.00	0.00	21%	2.07	0.18	12	1	0.03			0.00	0.00
	/A	5200	5200 Base Monitor, CRT	Grocery	2014	2054	0.43	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.43	0.08	0.00	0.00
	/A /A	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Grocery Grocery	2014	2054 2054	0.19 0.12	0.03	0.24	0.24	56% 73%	0.04	0.04 0.05	56% 65%	0.00	0.00	0	0	24.00 1.12			0.24	0.04
v			sintoi i onoi managomont Eliability - Otti	Jiocoiy	2017	-004	V. 12	0.00	0.07	0.02	. 5 /0	0.01	0.00	00/0	J.07	0.01	U		12			0.07	0.01

APPENDIX H

Base Avoided Costs

		ic Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ige			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
		Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm VA	Number 5200	Number Measure 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Type Grocery	Year 2014	Year 2054	0.11	MW 0.03	Savings 0.01	0.33	Savings 76%	Savings 0.00	0.05	Savings 67%	\$/kWH 0.44	\$/kWH 0.02	\$/kW 2	\$/kW 0	0.12	GWH	MW	0.00	0.00
VA	5300	5300 Base Monitor, LCD	Grocery	2014	2054	0.68	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.68	0.12	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Grocery	2014	2054	0.54	0.10	0.14	0.14	20%	0.02	0.02	20%	0.02	0.02	0	0	3.43			0.14	0.02
VA VA	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Grocery Grocery	2014 2014	2054 2054	0.47 0.43	0.09	0.07 0.04	0.21 0.25	31% 36%	0.01 0.00	0.03	26% 27%	0.16 0.45	0.07 0.12	2 10	0	0.29 0.10			0.00	0.00
VA	5400	5400 Base Copier	Grocery	2014	2054	0.43	0.09	0.04	0.25	0%	0.00	0.03	0%	0.45 N/A	0.12 N/A	N/A	N/A	N/A	0.55	0.10	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Grocery	2014	2054	0.44	0.08	0.11	0.11	20%	0.02	0.02	20%	0.00	0.00	0	0	16.27			0.11	0.02
VA	5400	5402 Copier Power Management Enabling	Grocery	2014	2054	0.38	0.07	0.06	0.17	31%	0.01	0.03	26%	0.20	0.07	2	0	0.25	0.00	0.04	0.00	0.00
VA VA	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Printer	Grocery Grocery	2014 2014	2054 2054	0.22	0.04	0.00 0.05	0.00 0.05	0% 25%	0.00 0.01	0.00 0.01	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.04	0.22	0.04	0.00 0.05	0.00 0.01
VA	5500	5501 Multifunction Power Management Enabling	Grocery	2014	2054	0.12	0.03	0.05	0.10	46%	0.00	0.01	36%	0.53	0.25	6	2	0.09			0.00	0.00
VA	5600	5600 Base Printer	Grocery	2014	2054	0.18	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.18	0.03	0.00	0.00
VA VA	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Grocery Grocery	2014 2014	2054 2054	0.12	0.02	0.06 0.03	0.06	35% 53%	0.01	0.01	35% 44%	0.00 0.12	0.00	0	0	23.16 0.41			0.06	0.01
VA	5700	5700 Base Data Center/Server Room	Grocery	2014	2054	0.05	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.45	0.08	0.00	0.00
VA	5700	5701 Data Center Improved Operations	Grocery	2014	2054	0.40	0.07	0.04	0.04	10%	0.01	0.01	10%	0.00	0.00	0	0	107.46			0.04	0.01
VA	5700	5702 Data Center Best Practices	Grocery	2014	2054	0.35	0.06	0.05	0.10	21%	0.01	0.02	21%	0.00	0.00	0	0	43.75			0.05	0.01
VA VA	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Grocery	2014 2014	2054 2054	0.33 13.04	0.06 2.10	0.02	0.12	26% 0%	0.00	0.02	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	22.69 N/A	13.04	2.10	0.02	0.00
VA	6000	6007 Heat Trap	Grocery	2014	2054	12.36	1.99	0.68	0.68	5%	0.11	0.11	5%	0.02	0.02	0	0	2.39	15.04	2.10	0.68	0.11
VA	6000	6002 High Efficiency Water Heater (electric)	Grocery	2014	2054	12.11	1.95	0.25	0.92	7%	0.04	0.15	7%	0.05	0.03	0	0	1.28			0.25	0.04
VA VA	6000 6000	6006 Heat Recovery Unit 6004 Tankless Water Heater	Grocery Grocery	2014 2014	2054 2054	5.82 5.38	0.94	6.30 0.44	7.22 7.66	55% 59%	1.01 0.07	1.16 1.23	55% 59%	0.06 0.16	0.06 0.06	0	0	0.98 0.44			0.00	0.00
VA	6000	6008 Solar Water Heater	Grocery	2014	2054	4.63	0.87	0.44	8.41	59% 65%	0.07	1.23	59% 65%	0.16	0.06	1	0	0.44			0.00	0.00
VA	6000	6001 Demand controlled circulating systems	Grocery	2014	2054	4.46	0.72	0.17	8.58	66%	0.03	1.38	66%	0.22	0.08	1	Ö	0.30			0.00	0.00
VA	6000	6003 Hot Water Pipe Insulation	Grocery	2014	2054	4.37	0.70	0.09	8.67	66%	0.01	1.39	66%	0.23	0.08	.1	0	0.28			0.00	0.00
VA VA	7000 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Grocery Grocery	2014 2014	2054 2054	11.46 9.75	1.82 1.69	0.00 1.71	0.00 1.71	0% 15%	0.00	0.00	0% 7%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 1.97	11.46	1.82	0.00 1.71	0.00
VA	7000	7002 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Grocery	2014	2054	8.82	1.61	0.92	2.63	23%	0.13	0.13	11%	0.02	0.02	1	0	1.07			0.92	0.13
VA	7100	7100 Base Non-Refrigerated Vending Machines	Grocery	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
VA	7100	7101 Vending Misers (Non-Refrigerated)	Grocery	2014	2054	0.01	0.00	0.01	0.01	43%	0.00	0.00	21%	0.40	0.40	5	5	0.12		. =-	0.00	0.00
VA VA	7200 7300	7200 Base Oven 7300 Base Fryer	Grocery Grocery	2014 2014	2054 2054	12.90 16.78	1.79 2.33	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	12.90 16.78	1.79 2.33	0.00	0.00
VA	7400	7400 Base Steamer	Grocery	2014	2054	23.43	3.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	23.43	3.26	0.00	0.00
VA	7400	7401 Efficient Steamer	Grocery	2014	2054	7.16	1.00	16.27	16.27	69%	2.26	2.26	69%	0.06	0.06	0	0	0.98			0.00	0.00
VA VA	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery Grocery	2014 2014	2054 2054	0.56	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.04	N/A 0.04	N/A N/A	N/A N/A	N/A 1.43	0.56	0.00	0.00	0.00
VA	8100	8100 Base Heating, Other Electric	Grocery	2014	2054	13.76	0.00	0.00	0.03	0%	0.00	0.00	0%	0.04 N/A	0.04 N/A	N/A	N/A	N/A	13.76	0.00	0.03	0.00
VA	9500	9500 Base Miscellaneous	Grocery	2014	2054	131.26	20.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	131.26	20.87	0.00	0.00
VA	9500	9501 Xmisc	Grocery	2014	2054	131.26	20.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
VA VA	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Warehouse Warehouse	2020	2054 2054	448.71 411.35	79.75 73.11	0.00 37.36	0.00 37.36	0% 8%	0.00 6.64	0.00 6.64	0% 8%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.64	448.71	79.75	0.00 37.36	0.00 6.64
VA	1030	1036 Lighting Control Tuneup (base 4L4T8), 2020	Warehouse	2020	2054	404.59	72.51	6.77	44.12	10%	0.60	7.24	9%	0.03	0.02	0	0	1.54			6.77	0.60
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Warehouse	2020	2054	353.11	63.36	51.48	95.60	21%	9.15	16.38	21%	0.04	0.03	0	0	1.24			51.48	9.15
VA VA	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Warehouse Warehouse	2020 2020	2054 2054	326.55 319.89	59.60 59.30	26.56 6.66	122.16 128.82	27% 29%	3.77 0.29	20.15 20.44	25% 26%	0.05 0.09	0.04 0.04	0 2	0	1.18 0.57			26.56 0.00	3.77 0.00
VA	1030	1037 Occupancy Sensor, 4L4 Problescent Fixtures, 2020	Warehouse	2020	2054	268.34	50.14	51.54	180.36	40%	9.16	29.60	37%	0.09	0.04	2	1	0.57			0.00	0.00
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	Warehouse	2020	2054	245.44	46.07	22.91	203.27	45%	4.07	33.67	42%	0.24	0.12	1	1	0.27			0.00	0.00
VA	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Warehouse	2020	2054	3.06	0.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.06	0.54	0.00	0.00
VA VA	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Warehouse Warehouse	2020 2020	2054 2054	2.74	0.49	0.32 0.05	0.32	10% 12%	0.06	0.06 0.06	10% 11%	0.03	0.03	0	0	2.04 1.45			0.32 0.05	0.06
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Warehouse	2020	2054	2.49	0.45	0.20	0.56	18%	0.03	0.09	16%	0.05	0.03	0	0	1.27			0.00	0.03
VA	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Warehouse	2020	2054	2.18	0.40	0.32	0.88	29%	0.06	0.15	27%	0.06	0.05	0	0	0.89			0.00	0.00
VA VA	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Warehouse Warehouse	2020 2020	2054 2054	2.07 1.90	0.38	0.11 0.18	0.99 1.16	32% 38%	0.02	0.16	30% 36%	0.23 0.29	0.07	1 2	0	0.27 0.22			0.00	0.00
VA	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Warehouse	2020	2054	1.86	0.35	0.18	1.20	39%	0.00	0.20	36%	0.29	0.10	4	1	0.22			0.00	0.00
VA	1200	1200 Base Other Fluorescent Fixture	Warehouse	2014	2054	0.46	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.46	0.08	0.00	0.00
VA VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Warehouse	2014 2014	2054 2054	0.42	0.08	0.05 0.03	0.05	10% 17%	0.00	0.00 0.01	5% 10%	0.00	0.00 0.01	0	0	15.20 2.04			0.05 0.03	0.00
VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Warehouse Warehouse	2014	2054	0.39	0.07	0.03	0.08	22%	0.00	0.01	10%	0.03	0.01	0	0	0.54			0.03	0.00
VA	1200	1201 ROB High Performance T8 (base other fluorescent)	Warehouse	2014	2054	0.33	0.07	0.04	0.14	30%	0.01	0.02	20%	0.11	0.05	1	0	0.50			0.00	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Warehouse	2014	2054	0.28	0.06	0.04	0.18	39%	0.01	0.02	29%	0.23	0.09	.1.	.1	0.24			0.00	0.00
VA VA	1330 1430	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Warehouse Warehouse	2020 2020	2054 2054	0.00 13.47	0.00 2.39	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 13.47	0.00 2.39	0.00	0.00
VA VA	1430 1530	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Warehouse	2020	2054	9.92	1.76	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	9.92	1.76	0.00	0.00
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Warehouse	2020	2054	18.72	3.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.72	3.33	0.00	0.00
VA	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Warehouse	2020	2054	13.54	2.41	5.19	5.19	28%	0.92	0.92	28%	0.06	0.06	0	0	0.89			0.00	0.00
VA VA	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Warehouse Warehouse	2020 2020	2054 2054	23.92 17.70	4.25 3.15	0.00 6.22	0.00 6.22	0% 26%	0.00 1.11	0.00	0% 26%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.18	23.92	4.25	0.00 6.22	0.00 1.11
VA	1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Warehouse	2020	2054	270.51	48.08	0.00	0.00	26% 0%	0.00	0.00	26% 0%	0.05 N/A	0.05 N/A	N/A	N/A	1.18 N/A	270.51	48.08	0.00	0.00
VA	1800	1801 T5 (240W) (base metal halide)	Warehouse	2014	2054	179.05	31.82	91.46	91.46	34%	16.25	16.25	34%	0.01	0.01	0	0	6.53			91.46	16.25
VA	1800	1806 Occupancy Sensor, High Bay T5	Warehouse	2014	2054	173.36	31.57	5.70	97.16	36%	0.25	16.50	34%	0.03	0.01	1	0	1.67			5.70	0.25
VA VA	1800 1850	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1850 Base CFL Exit Sign	Warehouse Warehouse	2014 2014	2054 2054	160.31 1.60	29.72 0.28	13.04	110.20	41% 0%	1.85	18.35 0.00	38% 0%	0.05 N/A	0.02 N/A	N/A	0 N/A	1.32 N/A	1.60	0.28	13.04	1.85

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Measure					Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm		Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA VA	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Warehouse Warehouse	2014 2014	2054 2054	0.50 100.54	0.09 1.36	1.10 0.00	1.10 0.00	69% 0%	0.20	0.20	69% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.04 N/A	100.54	1.36	1.10 0.00	0.20
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Warehouse	2014	2054	96.70	1.19	3.84	3.84	4%	0.17	0.17	13%	0.05	0.05	1	1	1.38			3.84	0.17
VA VA	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Warehouse Warehouse	2014	2054	46.53 32.84	0.51 0.34	50.17 13.69	54.01 67.70	54% 67%	0.68 0.17	0.85 1.02	63% 75%	0.10 0.62	0.09 0.20	7 51	6 13	0.59 0.09			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.62 N/A	0.20 N/A	N/A	N/A	0.09 N/A	0.00	0.00	0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Warehouse	2014	2054	227.17	216.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	227.17	216.04	0.00	0.00
VA VA	2100 2100	2113 Ceiling/roof Insulation - DX 2107 Cool Roof - DX	Warehouse Warehouse	2014	2054 2054	216.72 200.59	206.10 190.77	10.45 16.12	10.45 26.58	5% 12%	9.94 15.33	9.94 25.28	5% 12%	0.05 0.12	0.05 0.09	0	0	2.52 0.86			10.45 0.00	9.94 0.00
VA	2100	2108 Optimize Controls - DX	Warehouse	2014	2054	197.61	189.96	2.98	29.56	13%	0.81	26.09	12%	0.12	0.10	1	0	0.36			0.00	0.00
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons	Warehouse	2014	2054	152.16	146.73	45.45	75.01	33%	43.22	69.31	32%	0.48	0.33	0	0	0.26			0.00	0.00
VA VA	2100 2100	2112 Duct Testing/Sealing - DX 2115 Window Film (Standard) - DX	Warehouse Warehouse	2014	2054	143.11 136.95	138.12 132.27	9.05 6.16	84.06 90.22	37% 40%	8.61 5.86	77.92 83.78	36% 39%	3.07 2.74	0.62	3	1	0.04			0.00	0.00
VA	2100	2106 Prog. Thermostat - DX	Warehouse	2014	2054	132.85	131.15	4.10	94.33	42%	1.12	84.89	39%	2.02	0.82	7	1	0.04			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Warehouse	2014	2054	132.58	130.90	0.26	94.59	42%	0.25	85.14	39%	5.62	0.83	6	1	0.02			0.00	0.00
VA VA	2100 2200	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Warehouse Warehouse	2014 2014	2054 2054	132.51 122.99	130.88 116.97	0.07 0.00	94.66 0.00	42% 0%	0.02	85.16 0.00	39% 0%	3.71 N/A	0.84 N/A	14 N/A	1 N/A	0.02 N/A	122.99	116.97	0.00	0.00
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Warehouse	2014	2054	107.78	102.50	15.21	15.21	12%	14.47	14.47	12%	0.05	0.05	0	0	2.61	122.55	110.57	15.21	14.47
VA	2300	2300 Base PTAC, EER=8.3, 1 ton	Warehouse	2014	2054	5.83	5.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.83	5.54	0.00	0.00
VA VA	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Warehouse Warehouse	2014 2014	2054 2054	128.07 125.86	39.55 38.87	0.00 2.21	0.00 2.21	0% 2%	0.00 0.68	0.00 0.68	0% 2%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.83	128.07	39.55	0.00 2.21	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	Warehouse	2014	2054	88.87	35.95	36.99	39.20	31%	2.92	3.60	9%	0.05	0.03	0	0	1.63			36.99	2.92
VA	3000	3003 Demand Controlled Ventilation	Warehouse	2014	2054	87.73	35.31	1.14	40.34	31%	0.65	4.25	11%	1.85	0.09	3	1	0.05			0.00	0.00
VA VA	3100 3200	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Warehouse Warehouse	2014	2054 2054	0.00 42.48	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 42.48	0.00 13.12	0.00	0.00
VA	3200	3202 Variable Speed Drive Control, 40 HP	Warehouse	2014	2054	29.99	12.13	12.48	12.48	29%	0.00	0.00	8%	0.02	0.02	0	0	3.18	42.40	13.12	12.48	0.00
VA	3200	3203 Air Handler Optimization, 40 HP	Warehouse	2014	2054	27.06	11.90	2.94	15.42	36%	0.23	1.22	9%	0.06	0.03	1	Ō	0.78			0.00	0.00
VA	3200	3204 Demand Controlled Ventilation	Warehouse	2014	2054	26.71	11.71	0.35	15.77	37%	0.20	1.41	11%	2.02	0.07	4	1	0.05			0.00	0.00
VA VA	4000 4000	4000 Base Built-Up Refrigeration System 4018 Oversized Air Cooled Condenser	Warehouse Warehouse	2014 2014	2054 2054	306.50 293.60	58.07 55.62	0.00 12.90	0.00 12.90	0% 4%	0.00 2.44	0.00 2.44	0% 4%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.16	306.50	58.07	0.00 12.90	0.00 2.44
VA	4000	4010 Refrigeration Commissioning	Warehouse	2014	2054	292.09	55.34	1.51	14.41	5%	0.29	2.73	5%	0.06	0.03	0	0	0.84			0.00	0.00
VA	4000	4006 Electronically commutated evaporator fan motor	Warehouse	2014	2054	274.39	51.98	17.70	32.11	10%	3.35	6.08	10%	0.11	0.07	1	0	0.63			0.00	0.00
VA VA	4000 4000	4005 Evaporator fan controller for MT walk-ins 4002 Strip curtains for walk-ins (built-up)	Warehouse Warehouse	2014	2054	274.34 273.17	51.98 51.76	0.05 1.17	32.16 33.33	10% 11%	0.01 0.22	6.09 6.31	10% 11%	0.19 0.18	0.07 0.08	2	0	0.32 0.29			0.00	0.00
VA	4000	4001 High-efficiency fan motors	Warehouse	2014	2054	264.80	50.17	8.37	41.70	14%	1.59	7.90	14%	0.45	0.15	2	1	0.16			0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Warehouse	2014	2054	81.91	15.52	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	81.91	15.52	0.00	0.00
VA VA	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Warehouse Warehouse	2014	2054	81.78 19.15	15.49 3.19	0.13	0.13 0.00	0% 0%	0.03	0.03	0% 0%	0.15 N/A	0.15 N/A	1 N/A	1 N/A	0.33 N/A	19.15	3.19	0.00	0.00
VA	5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Warehouse	2014	2054	10.66	2.46	8.49	8.49	44%	0.73	0.00	23%	0.01	0.01	0	0	3.53	19.15	3.19	8.49	0.00
VA	5000	5002 Energy Star or Better PC	Warehouse	2014	2054	7.16	1.88	3.49	11.98	63%	0.58	1.31	41%	0.03	0.02	0	0	1.82			3.49	0.58
VA VA	5100 5100	5100 Base Laptop PC	Warehouse Warehouse	2014	2054	1.36 1.10	0.23	0.00 0.26	0.00 0.26	0% 19%	0.00 0.04	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.03	1.36	0.23	0.00 0.26	0.00
VA	5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Warehouse	2014	2054	1.08	0.18	0.26	0.28	21%	0.04	0.04	21%	1.24	0.01	7	1	0.04			0.26	0.04
VA	5200	5200 Base Monitor, CRT	Warehouse	2014	2054	3.95	0.66	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.95	0.66	0.00	0.00
VA VA	5200	5201 Energy Star or Better Monitor - CRT	Warehouse	2014	2054	1.73	0.29	2.22 0.55	2.22 2.77	56% 70%	0.37 0.05	0.37	56% 63%	0.00 0.02	0.00	0	0	40.01			2.22 0.55	0.37
VA	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Warehouse Warehouse	2014	2054	1.18 1.08	0.24	0.55	2.77	70%	0.05	0.42 0.43	66%	0.02	0.01	1	0	2.18 0.22			0.55	0.05
VA	5300	5300 Base Monitor, LCD	Warehouse	2014	2054	3.15	0.53	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.15	0.53	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Warehouse Warehouse	2014	2054	2.51	0.42	0.64	0.64	20%	0.11	0.11	20%	0.01	0.01	0	0	5.71			0.64	0.11
VA VA	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Warehouse	2014 2014	2054 2054	2.48	0.42	0.03 0.18	0.67 0.85	21% 27%	0.00 0.01	0.11 0.12	21% 22%	0.08 0.24	0.01 0.06	1 5	0	0.57 0.18			0.00	0.00
VA	5400	5400 Base Copier	Warehouse	2014	2054	4.86	0.81	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.86	0.81	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Warehouse	2014	2054	4.28	0.71	0.58	0.58	12%	0.10	0.10	12%	0.00	0.00	0	0	29.97			0.58	0.10
VA VA	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Warehouse Warehouse	2014 2014	2054 2054	4.13 1.09	0.70 0.18	0.15 0.00	0.73 0.00	15% 0%	0.01 0.00	0.11	14% 0%	0.09 N/A	0.02 N/A	1 N/A	0 N/A	0.52 N/A	1.09	0.18	0.00	0.00
VA	5500	5502 ENERGY STAR Multi-Function Printer	Warehouse	2014	2054	0.82	0.14	0.27	0.27	25%	0.05	0.05	25%	0.01	0.01	0	0	8.40		00	0.27	0.05
VA	5500	5501 Multifunction Power Management Enabling	Warehouse	2014	2054	0.74	0.13	0.08	0.35	32%	0.01	0.05	29%	0.24	0.06	3	0	0.20			0.00	0.00
VA VA	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Warehouse Warehouse	2014 2014	2054 2054	4.88 3.18	0.81	0.00 1.70	0.00 1.70	0% 35%	0.00 0.28	0.00 0.28	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 38.61	4.88	0.81	0.00 1.70	0.00 0.28
VA	5600	5601 Printer Power Management Enabling	Warehouse	2014	2054	2.87	0.50	0.31	2.01	41%	0.03	0.20	38%	0.05	0.01	1	0	0.93			0.00	0.00
VA	5700	5700 Base Data Center/Server Room	Warehouse	2014	2054	57.03	9.51	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	57.03	9.51	0.00	0.00
VA VA	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Warehouse Warehouse	2014 2014	2054 2054	51.32 44.79	8.56 7.47	5.70 6.53	5.70 12.23	10% 21%	0.95 1.09	0.95 2.04	10% 21%	0.00	0.00	0	0	107.17 43.63			5.70 6.53	0.95 1.09
VA	5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Warehouse	2014	2054	44.79	7.47	2.51	14.74	26%	0.42	2.04	26%	0.00	0.00	0	0	43.63 22.63			2.51	0.42
VA	6000	6000 Base Water Heating	Warehouse	2014	2054	21.67	3.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	21.67	3.40	0.00	0.00
VA	6000 6000	6006 Heat Recovery Unit	Warehouse	2014	2054 2054	20.26	3.18	1.41	1.41 2.46	7% 11%	0.22	0.22	7% 11%	0.25	0.25	2	2	0.23			0.00	0.00
VA VA	6000	6007 Heat Trap 6002 High Efficiency Water Heater (electric)	Warehouse Warehouse	2014	2054	19.21 18.83	3.01 2.95	1.05 0.38	2.46	11% 13%	0.16	0.39	11% 13%	0.45	0.33	3 6	3	0.13			0.00	0.00
VA	6000	6004 Tankless Water Heater	Warehouse	2014	2054	17.42	2.73	1.41	4.25	20%	0.22	0.67	20%	1.42	0.75	9	5	0.05			0.00	0.00
VA	6000	6008 Solar Water Heater	Warehouse	2014	2054	11.44	1.80	5.97	10.23	47%	0.94	1.60	47%	1.66	1.28	11	8	0.04			0.00	0.00
VA VA	6000 6000	6003 Hot Water Pipe Insulation 6001 Demand controlled circulating systems	Warehouse Warehouse	2014 2014	2054 2054	11.40 11.18	1.79 1.75	0.05 0.22	10.27 10.50	47% 48%	0.01 0.03	1.61 1.65	47% 48%	2.54 2.84	1.28 1.32	16 18	8 8	0.03			0.00	0.00
VA	7000	7000 Base Refrigerated Vending Machines	Warehouse	2014	2054	14.96	2.82	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.96	2.82	0.00	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	Warehouse	2014	2054	13.29	2.66	1.67	1.67	11%	0.16	0.16	6%	0.02	0.02	0	0	2.27			1.67	0.16

APPENDIX H

Base Avoided Costs

	tric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintage	5.112.55.1.21.74.0.21.00							Total	B		Total	B	Marginal	Average	Marginal					00.12.	
Base	Measure	Building	Measure Start	Measure	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	Economic
Sgmt Number	Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA 7000 VA 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Warehouse Warehouse	2014 2014	2054 2054	12.40 0.62	2.57 0.12	0.89	2.57 0.00	17% 0%	0.09	0.25	9% 0%	0.04 N/A	0.03 N/A	0 N/A	0 N/A	1.21 N/A	0.62	0.12	0.89	0.09
VA 7100	7101 Vending Misers (Non-Refrigerated)	Warehouse	2014	2054	0.43	0.10	0.20	0.20	32%	0.02	0.02	16%	0.36	0.36	4	4	0.14			0.00	0.00
VA 7200 VA 7300		Warehouse Warehouse	2014	2054 2054	4.94 10.26	0.81 1.69	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	4.94 10.26	0.81 1.69	0.00	0.00
VA 7400	7400 Base Steamer	Warehouse	2014	2054	4.31	0.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.31	0.71	0.00	0.00
VA 8000 VA 8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Warehouse	2014 2014	2054 2054	2.14	0.00	0.00 0.12	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.03	N/A 0.03	N/A N/A	N/A N/A	N/A	2.14	0.00	0.00	0.00
VA 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	Warehouse Warehouse	2014	2054	16.88	0.00	0.12	0.12 0.00	0%	0.00	0.00	0%	N/A	0.03 N/A	N/A	N/A	1.65 N/A	16.88	0.00	0.12 0.00	0.00
VA 9500		Warehouse	2014	2054	349.99	65.97	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	349.99	65.97	0.00	0.00
VA 9500 VA 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Warehouse School	2014 2020	2054 2054	349.99 286.28	65.97 38.69	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	286.28	38.69	0.00	0.00
VA 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	School	2020	2054	283.96	38.53	2.33	2.33	1%	0.16	0.16	0%	0.02	0.02	0	0	2.62			2.33	0.16
VA 1030 VA 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	School School	2020 2020	2054 2054	254.79 235.71	34.59 32.52	29.17 19.08	31.50 50.57	11% 18%	3.94 2.07	4.10 6.17	11% 16%	0.02 0.03	0.02	0	0	2.53 2.04			29.17 19.08	3.94 2.07
VA 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	School	2020	2054	205.72	28.47	29.99	80.56	28%	4.05	10.22	26%	0.05	0.04	0	0	1.12			29.99	4.05
VA 1030 VA 1030		School School	2020 2020	2054 2054	172.57 162.46	23.99 23.65	33.15 10.12	113.71 123.83	40% 43%	4.48 0.34	14.70 15.04	38% 39%	0.35 0.18	0.13 0.13	3 5	1	0.20			0.00	0.00
VA 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1035 LED Troffer (base 4L4'T8), 2020	School	2020	2054	148.59	23.65	13.87	123.83	43% 48%	1.87	16.92	39% 44%	0.18	0.13	2	1	0.27			0.00	0.00
VA 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	School	2020	2054	17.97	2.43	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	17.97	2.43	0.00	0.00
VA 1130 VA 1130		School School	2020 2020	2054 2054	16.14 15.98	2.18 2.17	1.84 0.15	1.84 1.99	10% 11%	0.25 0.01	0.25 0.26	10% 11%	0.03 0.03	0.03	0	0	2.01 1.59			1.84 0.15	0.25 0.01
VA 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	School	2020	2054	14.79	2.04	1.20	3.19	18%	0.13	0.39	16%	0.04	0.04	0	0	1.38			1.20	0.13
VA 1130 VA 1130		School School	2020 2020	2054 2054	12.91 12.28	1.79	1.88 0.62	5.07 5.69	28% 32%	0.25 0.08	0.64	26% 30%	0.07 0.28	0.05 0.07	1 2	0	0.88 0.25			0.00	0.00
VA 1130		School	2020	2054	11.23	1.56	1.05	6.74	37%	0.14	0.73	36%	0.26	0.12	3	1	0.19			0.00	0.00
VA 1130		School	2020	2054	10.58	1.54	0.66	7.40	41%	0.02	0.89	37%	0.30	0.13	9	1	0.16			0.00	0.00
VA 1200 VA 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	School School	2014 2014	2054 2054	1.39 1.33	0.19	0.00	0.00	0% 5%	0.00	0.00	0% 2%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.16	1.39	0.19	0.00	0.00
VA 1200	1201 ROB High Performance T8 (base other fluorescent)	School	2014	2054	1.21	0.17	0.11	0.18	13%	0.02	0.02	10%	0.10	0.07	1	1	0.61			0.00	0.00
VA 1200 VA 1200		School School	2014 2014	2054 2054	1.06 0.89	0.15 0.14	0.15 0.17	0.33	24% 36%	0.02	0.04	22% 25%	0.21 0.18	0.14 0.15	2 5	1 2	0.29 0.27			0.00	0.00
VA 1200		School	2014	2054	0.82	0.14	0.07	0.57	41%	0.01	0.05	29%	0.13	0.13	3	2	0.19			0.00	0.00
VA 1330 VA 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	School School	2020 2020	2054 2054	1.04 0.21	0.14	0.00	0.00	0% 80%	0.00	0.00 0.11	0% 80%	N/A 0.01	N/A 0.01	N/A 0	N/A	N/A 9.75	1.04	0.14	0.00	0.00
VA 1330 VA 1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	School	2020	2054	0.21	0.03	0.84	0.84	80% 0%	0.11	0.00	80% 0%	0.01 N/A	0.01 N/A	N/A	0 N/A	9.75 N/A	0.38	0.05	0.84 0.00	0.11
VA 1430	1432 LEDs (base incandescent A-line 72W) 2020	School	2020	2054	0.08	0.01	0.29	0.29	78%	0.04	0.04	78%	0.01	0.01	0	0	8.21			0.29	0.04
VA 1530 VA 1530		School School	2020 2020	2054 2054	0.28	0.04	0.00 0.20	0.00 0.20	0% 71%	0.00 0.03	0.00	0% 71%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.03	0.28	0.04	0.00 0.20	0.00
VA 1630	1630 Base CFL 18W to screw-in replacement 2020	School	2020	2054	20.83	2.82	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	20.83	2.82	0.00	0.00
VA 1630 VA 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	School School	2020 2020	2054 2054	15.06 26.62	2.04	5.77 0.00	5.77	28%	0.78	0.78	28% 0%	0.07 N/A	0.07 N/A	1 N/A	1 N/A	0.85 N/A	26.62	3.60	0.00	0.00
VA 1730		School	2020	2054	19.70	2.66	6.92	6.92	26%	0.94	0.94	26%	0.05	0.05	0	0	1.13	20.02	3.00	6.92	0.94
VA 1800		School	2014	2054	41.12	5.56	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	41.12	5.56	0.00	0.00
VA 1800 VA 1800	1801 T5 (240W) (base metal halide) 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	School School	2014 2014	2054 2054	27.22 25.18	3.68 3.46	13.90 2.04	13.90 15.94	34% 39%	1.88 0.22	1.88 2.10	34% 38%	0.02 0.03	0.02	0	0	3.83 2.42			13.90 2.04	1.88 0.22
VA 1800	1806 Occupancy Sensor, High Bay T5	School	2014	2054	24.39	3.43	0.79	16.73	41%	0.03	2.13	38%	0.05	0.02	2	0	0.92			0.00	0.00
VA 1850 VA 1850		School School	2014	2054 2054	2.22 1.00	0.30	0.00 1.22	0.00 1.22	0% 55%	0.00 0.17	0.00 0.17	0% 55%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.46	2.22	0.30	0.00 1.22	0.00 0.17
VA 1900		School	2014	2054	67.16	2.68	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	67.16	2.68	0.00	0.00
VA 1900 VA 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	School School	2014	2054 2054	60.40 29.07	1.82 0.57	6.75 31.34	6.75 38.09	10% 57%	0.86 1.25	0.86 2.10	32% 79%	0.05 0.10	0.05 0.09	0	0	1.50 0.57			6.75 0.00	0.86
VA 1900		School	2014	2054	20.53	0.57	8.53	46.62	69%	0.31	2.10	90%	0.10	0.09	18	4	0.09			0.00	0.00
VA 2000		School	2014	2054	93.36	47.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	93.36	47.93	0.00	0.00
VA 2000 VA 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	School School	2014 2014	2054 2054	85.39 85.17	43.84 43.78	7.97 0.22	7.97 8.19	9% 9%	4.09 0.06	4.09 4.15	9% 9%	0.07 0.05	0.07 0.07	0	0	1.49 1.19			7.97 0.22	4.09 0.06
VA 2000	2013 High Efficiency Chiller Motors	School	2014	2054	85.09	43.74	0.09	8.27	9%	0.04	4.20	9%	0.10	0.07	0	0	0.96			0.00	0.00
VA 2000 VA 2000	2006 VSD for Chiller Pumps and Towers 2003 EMS - Chiller	School School	2014 2014	2054 2054	84.94 80.35	43.70 43.04	0.15 4.59	8.42 13.01	9% 14%	0.04 0.66	4.24 4.89	9% 10%	0.08 0.13	0.07	0 1	0	0.89 0.49			0.00	0.00
VA 2000	2004 Cool Roof - Chiller	School	2014	2054	78.80	42.25	1.55	14.56	16%	0.79	5.69	12%	0.21	0.10	0	0	0.39			0.00	0.00
VA 2000 VA 2000		School	2014 2014	2054 2054	78.40 65.41	42.04 35.37	0.40 12.99	14.96 27.95	16% 30%	0.20 6.67	5.89 12.56	12% 26%	0.24	0.10	0	0	0.33			0.00	0.00
VA 2000 VA 2000	2012 Duct Testing/Sealing - Chiller 2008 New Economizer - Chiller	School School	2014	2054	58.45	34.38	6.96	27.95 34.91	30%	0.99	12.56	26%	0.34 0.39	0.21 0.25	3	0 1	0.29 0.14			0.00	0.00
VA 2000	2011 Duct/Pipe Insulation - Chiller	School	2014	2054	58.10	34.20	0.35	35.26	38%	0.18	13.74	29%	5.57	0.30	11	1	0.01			0.00	0.00
VA 2100 VA 2100		School School	2014 2014	2054 2054	223.92 223.78	114.97 114.90	0.00 0.14	0.00 0.14	0% 0%	0.00 0.07	0.00 0.07	0% 0%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.86	223.92	114.97	0.00 0.14	0.00 0.07
VA 2100	2102 DX Packaged System, EER=13.4, 10 tons	School	2014	2054	172.31	88.47	51.47	51.61	23%	26.43	26.50	23%	0.06	0.06	0	0	1.57			51.47	26.43
VA 2100 VA 2100		School School	2014 2014	2054 2054	172.07 171.80	88.43 88.36	0.24 0.27	51.85 52.11	23% 23%	0.03 0.07	26.53 26.60	23% 23%	0.17 0.21	0.06 0.06	1	0	0.32 0.30			0.00	0.00
VA 2100		School	2014	2054	171.80	87.55	1.58	53.69	24%	0.07	27.41	24%	0.21	0.06	1	0	0.30			0.00	0.00
VA 2100		School	2014	2054	167.62	87.18	2.60	56.30	25%	0.37	27.79	24%	0.18	0.07	1	0	0.28			0.00	0.00
VA 2100 VA 2100	2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX	School School	2014 2014	2054 2054	158.73 157.35	82.61 82.42	8.89 1.38	65.19 66.57	29% 30%	4.56 0.20	32.35 32.55	28% 28%	0.38 0.23	0.11 0.12	1 2	0	0.26 0.23			0.00	0.00
VA 2100		School	2014	2054	154.57	80.99	2.78	69.35	31%	1.43	33.97	30%	0.43	0.13	1	0	0.19			0.00	0.00

DNV GL H-10 1/5/2015

APPENDIX H

Base Avoided Costs

DSM	ASSYST ADD	ic Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	je			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Samt		Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic
VA	2100	2111 Economizer Repair - DX	School	2014	2054	151.53	78.79	3.04	72.39	32%	2.20	36.18	31%	0.94	0.16	1	0	0.08	OWN	101.00	0.00	0.00
VA	2100	2109 Economizer - DX	School	2014	2054	150.79	78.68	0.74	73.13	33%	0.11	36.28	32%	1.40	0.17	10	0	0.04			0.00	0.00
VA VA	2100 2200	2114 Duct/Pipe Insulation - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	School School	2014 2014	2054 2054	148.99 176.18	77.76 90.46	1.80 0.00	74.93 0.00	33% 0%	0.92	37.20 0.00	32% 0%	5.22 N/A	0.30 N/A	10 N/A	N/A	0.02 N/A	176.18	90.46	0.00	0.00
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School	2014	2054	154.39	79.27	21.79	21.79	12%	11.19	11.19	12%	0.05	0.05	0	0	1.86			21.79	11.19
VA VA	2300 2300	2300 Base PTAC, EER=8.3, 1 ton 2301 HE PTAC, EER=9.6, 1 ton	School School	2014 2014	2054 2054	160.46 138.73	82.38 71.23	0.00 21.73	0.00 21.73	0% 14%	0.00 11.16	0.00 11.16	0% 14%	N/A 0.12	N/A 0.12	N/A 0	N/A 0	N/A 0.74	160.46	82.38	0.00	0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	School	2014	2054	52.81	10.30	0.00	0.00	0%	0.00	0.00	0%	0.12 N/A	0.12 N/A	N/A	N/A	0.74 N/A	52.81	10.30	0.00	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	School	2014	2054	39.02	9.61	13.79	13.79	26%	0.69	0.69	7%	0.04	0.04	1	1	1.35			13.79	0.69
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	School School	2014 2014	2054 2054	38.34 32.61	9.48 7.48	0.67 5.73	14.47 20.20	27% 38%	0.13 2.00	0.82 2.82	8% 27%	0.08 2.13	0.04 0.64	0 6	1 5	0.98 0.04			0.00	0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	School	2014	2054	141.36	27.58	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	141.36	27.58	0.00	0.00
VA VA	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3102 Variable Speed Drive Control, 15 HP	School School	2014 2014	2054 2054	121.57 89.82	24.08 22.48	19.79 31.75	19.79 51.55	14% 36%	3.51 1.59	3.51 5.10	13% 18%	0.05 0.06	0.05 0.06	0 1	0	1.29 0.96			19.79 0.00	3.51 0.00
VA	3100	3103 Air Handler Optimization, 15 HP	School	2014	2054	81.08	22.46	8.74	60.28	43%	0.44	5.54	20%	0.08	0.06	2	1	0.64			0.00	0.00
VA	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	School	2014	2054	80.29	21.89	0.78	61.07	43%	0.15	5.69	21%	0.20	0.06	1	1	0.38			0.00	0.00
VA VA	3100 3100	3105 Energy Recovery Ventilation (ERV) 3107 Demand Controlled Ventilation	School School	2014 2014	2054 2054	76.08 64.71	20.43 16.46	4.21 11.38	65.28 76.65	46% 54%	1.47 3.96	7.16 11.12	26% 40%	0.71 2.88	0.10 0.51	2 8	1	0.13 0.03			0.00	0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	School	2014	2054	58.92	11.50	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	58.92	11.50	0.00	0.00
VA VA	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	School School	2014 2014	2054 2054	43.53 43.44	10.73 10.71	15.39 0.09	15.39 15.48	26% 26%	0.77	0.77 0.79	7% 7%	0.01	0.01	0	0	7.80 2.17			15.39 0.09	0.77
VA	3200	3203 Air Handler Optimization, 40 HP	School	2014	2054	39.21	10.71	4.23	19.71	33%	0.02	1.00	9%	0.03	0.01	1	0	0.74			0.09	0.02
VA	3200	3204 Demand Controlled Ventilation	School	2014	2054	33.35	8.45	5.86	25.58	43%	2.04	3.04	26%	2.33	0.55	7	5	0.04			0.00	0.00
VA VA	4000 4100	4000 Base Built-Up Refrigeration System 4100 Base Self-Contained Refrigeration	School School	2014 2014	2054 2054	0.00 66.40	0.00 9.18	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 66.40	0.00 9.18	0.00	0.00
VA	4100	4103 Night covers for display cases (self-contained)	School	2014	2054	64.09	8.87	2.30	2.30	3%	0.32	0.32	3%	0.00	0.00	0	0	21.10	00.10	0.10	2.30	0.32
VA VA	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	School School	2014 2014	2054 2054	63.22 62.88	8.74 8.70	0.88 0.34	3.18 3.52	5% 5%	0.12 0.05	0.44 0.49	5% 5%	0.00 0.01	0.00	0	0	13.13 8.20			0.88 0.34	0.12 0.05
VA	4100	4109 Energy-Star Freezer, glass door 4106 Energy-Star Refrigerator, solid door	School	2014	2054	62.07	8.58	0.81	4.33	7%	0.05	0.60	7%	0.01	0.00	0	0	4.96			0.81	0.05
VA	4100	4107 Energy-Star Freezer, solid door	School	2014	2054	61.93	8.57	0.14	4.47	7%	0.02	0.62	7%	0.02	0.01	0	0	3.27			0.14	0.02
VA VA	4100 4100	4108 Energy-Star Refrigerator, glass door 4110 Energy Star Ice Machines	School School	2014 2014	2054 2054	61.68 60.41	8.53 8.36	0.25 1.27	4.72 5.99	7% 9%	0.03 0.18	0.65 0.83	7% 9%	0.02	0.01 0.01	0	0	2.72 1.80			0.25 1.27	0.03 0.18
VA	4100	4112 Reach-in unit occupancy sensors	School	2014	2054	60.40	8.35	0.01	6.00	9%	0.00	0.83	9%	0.29	0.01	2	ō	0.20			0.00	0.00
VA VA	4100 4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	School School	2014 2014	2054 2054	60.34 60.29	8.35 8.34	0.05 0.05	6.06 6.11	9% 9%	0.01 0.01	0.84 0.84	9% 9%	0.33 1.05	0.01 0.02	2	0	0.16 0.05			0.00	0.00
VA	5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	School	2014	2054	10.42	0.90	0.05	0.00	9% 0%	0.00	0.84	9% 0%	1.05 N/A	0.02 N/A	N/A	N/A	0.05 N/A	10.42	0.90	0.00	0.00
VA	5000	5001 PC Network Power Management Enabling	School	2014	2054	5.73	0.69	4.69	4.69	45%	0.21	0.21	23%	0.01	0.01	0	0	3.47			4.69	0.21
VA VA	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	School School	2014 2014	2054 2054	4.06 1.16	0.55 0.10	1.66 0.00	6.36 0.00	61% 0%	0.14	0.35	39% 0%	0.03 N/A	0.02 N/A	0 N/A	0 N/A	1.78 N/A	1.16	0.10	1.66 0.00	0.14 0.00
VA	5100	5102 Energy Star or Better Laptop	School	2014	2054	0.94	0.08	0.22	0.22	19%	0.02	0.02	19%	0.01	0.01	0	0	4.73	0	0.10	0.22	0.02
VA VA	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	School School	2014 2014	2054 2054	0.92 4.23	0.08	0.02	0.24	21% 0%	0.00	0.02	21% 0%	1.24 N/A	0.11 N/A	14 N/A	1 N/A	0.04 N/A	4.23	0.36	0.00	0.00
VA	5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	School	2014	2054	1.85	0.36	2.37	2.37	56%	0.20	0.20	56%	0.00	0.00	0	0	37.58	4.23	0.36	2.37	0.00
VA	5200	5202 Monitor Power Management Enabling - CRT	School	2014	2054	1.34	0.14	0.51	2.89	68%	0.02	0.23	62%	0.02	0.00	0	0	2.37			0.51	0.02
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	School School	2014 2014	2054 2054	1.23 2.18	0.13 0.19	0.11	2.99 0.00	71% 0%	0.01 0.00	0.24	65% 0%	0.22 N/A	0.01 N/A	3 N/A	0 N/A	0.22 N/A	2.18	0.19	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	School	2014	2054	1.80	0.15	0.39	0.39	18%	0.03	0.03	18%	0.01	0.01	0	0	5.53	2.10	0.10	0.39	0.03
VA VA	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	School School	2014 2014	2054 2054	1.75 1.62	0.15 0.15	0.04 0.13	0.43 0.56	20% 26%	0.00	0.04 0.04	19% 20%	0.08 0.23	0.02 0.07	2 10	0	0.57 0.19			0.00	0.00
VA	5400	5400 Base Copier	School	2014	2054	2.78	0.15	0.00	0.00	0%	0.00	0.04	0%	0.23 N/A	N/A	N/A	N/A	0.19 N/A	2.78	0.24	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	School	2014	2054	2.62	0.23	0.16	0.16	6%	0.01	0.01	6%	0.00	0.00	0	0	30.20			0.16	0.01
VA VA	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	School School	2014 2014	2054 2054	2.52 0.34	0.22	0.11	0.27	10% 0%	0.00	0.02	8% 0%	0.09 N/A	0.04 N/A	2 N/A	1 N/A	0.54 N/A	0.34	0.03	0.00	0.00
VA	5500	5502 ENERGY STAR Multi-Function Printer	School	2014	2054	0.26	0.02	0.09	0.09	25%	0.01	0.01	25%	0.01	0.01	0	0	7.91			0.09	0.01
VA VA	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	School School	2014 2014	2054 2054	0.21 2.91	0.02 0.25	0.05 0.00	0.13 0.00	39% 0%	0.00	0.01 0.00	32% 0%	0.27 N/A	0.10 N/A	6 N/A	1 N/A	0.17 N/A	2.91	0.25	0.00	0.00
VA	5600	5602 ENERGY STAR Printer	School	2014	2054	1.90	0.25	1.01	1.01	35%	0.00	0.00	35%	0.00	0.00	0	0	36.34	2.91	0.25	1.01	0.00
VA	5600	5601 Printer Power Management Enabling	School	2014	2054	1.55	0.15	0.35	1.36	47%	0.02	0.10	41%	0.06	0.02	1	0	0.80			0.00	0.00
VA VA	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	School School	2014 2014	2054 2054	67.83 61.05	5.83 5.24	0.00 6.78	0.00 6.78	0% 10%	0.00 0.58	0.00 0.58	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 99.28	67.83	5.83	0.00 6.78	0.00 0.58
VA	5700	5702 Data Center Best Practices	School	2014	2054	53.28	4.58	7.77	14.55	21%	0.67	1.25	21%	0.00	0.00	0	o	40.42			7.77	0.67
VA	5700	5703 Data Center State of the Art practices	School	2014	2054	50.30	4.32	2.98	17.53	26%	0.26	1.51	26%	0.00	0.00	0	0	20.96			2.98	0.26
VA VA	6000 6000	6000 Base Water Heating 6007 Heat Trap	School School	2014 2014	2054 2054	23.82 22.58	1.85 1.76	0.00 1.23	0.00 1.23	0% 5%	0.00 0.10	0.00 0.10	0% 5%	N/A 0.04	N/A 0.04	N/A 1	N/A 1	N/A 1.29	23.82	1.85	0.00 1.23	0.00 0.10
VA	6000	6002 High Efficiency Water Heater (electric)	School	2014	2054	22.14	1.72	0.44	1.67	7%	0.03	0.13	7%	0.09	0.06	1	1	0.68			0.00	0.00
VA VA	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	School School	2014 2014	2054 2054	19.99 19.24	1.55 1.50	2.16 0.75	3.83 4.58	16% 19%	0.17 0.06	0.30 0.36	16% 19%	0.09 0.12	0.07	1	1	0.63 0.52			0.00	0.00
VA	6000	6004 Tankless Water Heater	School	2014	2054	17.79	1.38	1.44	6.02	25%	0.06	0.36	25%	0.12	0.10	2	1	0.52			0.00	0.00
VA	6000	6008 Solar Water Heater	School	2014	2054	16.55	1.29	1.25	7.27	31%	0.10	0.57	31%	0.18	0.11	2	1	0.36			0.00	0.00
VA VA	6000 7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	School School	2014 2014	2054 2054	16.38 6.12	1.27 0.53	0.17 0.00	7.43 0.00	31% 0%	0.01	0.58 0.00	31% 0%	0.20 N/A	0.11 N/A	3 N/A	1 N/A	0.30 N/A	6.12	0.53	0.00	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	School	2014	2054	5.19	0.49	0.93	0.93	15%	0.04	0.04	8%	0.03	0.03	1	1	1.84			0.93	0.04
VA VA	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	School School	2014 2014	2054 2054	4.69 0.09	0.47 0.01	0.51 0.00	1.43 0.00	23%	0.02	0.06 0.00	12% 0%	0.05 N/A	0.03 N/A	1 N/A	1 N/A	1.00 N/A	0.09	0.01	0.51 0.00	0.02
***	7 100		201001	2014	2004	0.00	0.01	5.50	0.00	U 70	0.00	0.00	J /0			.4/1	. 4/1		0.00	0.01	0.00	5.50

DNV GL H-11 1/5/2015

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

DSM A	SSYST ADDI	c Existing Construction TIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintag	е			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Samt		Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic
VA	7100	7101 Vending Misers (Non-Refrigerated)	School	2014	2054	0.05	0.01	0.04	0.04	43%	0.00	0.00	22%	0.43	0.43	10	10	0.11			0.00	0.00
VA VA	7200 7200	7200 Base Oven 7201 Convection Oven	School School	2014 2014	2054 2054	6.68 5.15	0.49 0.38	0.00 1.54	0.00 1.54	0% 23%	0.00 0.11	0.00 0.11	0% 23%	N/A 0.13	N/A 0.13	N/A 2	N/A	N/A 0.43	6.68	0.49	0.00	0.00
VA	7300	7300 Base Fryer	School	2014	2054	1.19	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.19	0.09	0.00	0.00
VA VA	7400 7400	7400 Base Steamer	School School	2014 2014	2054 2054	0.32	0.02	0.00 0.21	0.00 0.21	0% 63%	0.00 0.02	0.00 0.02	0% 63%	N/A 0.05	N/A 0.05	N/A 1	N/A 1	N/A 1.14	0.32	0.02	0.00 0.21	0.00 0.02
VA VA	7400 8000	7401 Efficient Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	School	2014	2054	4.30	0.01	0.21	0.21	0%	0.02	0.02	0%	0.05 N/A	0.05 N/A	N/A	N/A	1.14 N/A	4.30	0.00	0.21	0.02
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School	2014	2054	4.06	0.00	0.24	0.24	6%	0.00	0.00	0%	0.08	0.08	N/A	N/A	0.72			0.00	0.00
VA VA	8100 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	School School	2014 2014	2054 2054	0.00 93.87	0.00 8.18	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 93.87	0.00 8.18	0.00	0.00
VA	9500	9501 Xmisc	School	2014	2054	93.87	8.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00	93.07	0.10	0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Health	2020	2054	152.78	23.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	152.78	23.25	0.00	0.00
VA VA	1030 1030	1036 Lighting Control Tuneup (base 4L4T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Health Health	2020 2020	2054 2054	152.55 140.86	23.23 21.84	0.23 11.70	0.23 11.92	0% 8%	0.02 1.39	0.02 1.41	0% 6%	0.02	0.02 0.03	0	0	2.39 2.05			0.23 11.70	0.02 1.39
VA	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Health	2020	2054	126.21	19.61	14.65	26.57	17%	2.23	3.64	16%	0.03	0.03	0	0	1.61			14.65	2.23
VA VA	1030 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Health Health	2020	2054 2054	110.15 101.99	17.17 16.88	16.06 8.16	42.63 50.79	28% 33%	2.44	6.08 6.37	26% 27%	0.07	0.05	0 3	0	0.77			0.00	0.00
VA	1030	1034 ROB 4L4' LED Tube, 2020	Health	2020	2054	85.56	14.38	16.43	67.22	44%	2.50	8.87	38%	0.12	0.15	3	1	0.14			0.00	0.00
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	Health	2020	2054	78.25	13.27	7.30	74.52	49%	1.11	9.98	43%	0.36	0.17	2	.1.	0.17			0.00	0.00
VA VA	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Health Health	2020 2020	2054 2054	18.41 16.50	2.80 2.51	0.00 1.92	0.00 1.92	0% 10%	0.00 0.29	0.00 0.29	0% 10%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.38	18.41	2.80	0.00 1.92	0.00 0.29
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Health	2020	2054	16.48	2.51	0.02	1.94	11%	0.00	0.29	10%	0.05	0.04	1	ō	1.02			0.02	0.00
VA VA	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Health Health	2020 2020	2054 2054	15.21 13.28	2.36	1.26 1.94	3.20 5.14	17% 28%	0.15 0.29	0.44 0.74	16% 26%	0.07 0.09	0.05 0.07	1	0	0.87 0.61			0.00	0.00
VA	1130	1132 ROB 2L4 LOW Walt High Performance 18 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	Health	2020	2054	12.63	1.97	0.64	5.78	31%	0.29	0.74	30%	0.09	0.07	2	1	0.19			0.00	0.00
VA	1130	1135 LED Troffer (base 2L4T8), 2020	Health	2020	2054	11.56	1.80	1.08	6.86	37%	0.16	1.00	36%	0.41	0.14	3	1	0.15			0.00	0.00
VA VA	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	Health Health	2020 2014	2054 2054	10.70 4.95	1.77 0.75	0.86 0.00	7.71 0.00	42% 0%	0.03	1.03 0.00	37% 0%	0.25 N/A	0.16 N/A	7 N/A	1 N/A	0.19 N/A	4.95	0.75	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Health	2014	2054	4.92	0.75	0.03	0.03	1%	0.00	0.00	0%	0.01	0.01	0	0	6.44	4.55	0.75	0.03	0.00
VA VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Health Health	2014 2014	2054 2054	4.54 4.07	0.71	0.38 0.47	0.40 0.88	8% 18%	0.04 0.07	0.05 0.12	6% 16%	0.08 0.14	0.08 0.11	1	1	0.77 0.40			0.00	0.00
VA	1200	1201 ROB High Performance T8 (base other fluorescent) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Health	2014	2054	3.28	0.63	0.47	1.67	34%	0.07	0.12	19%	0.14	0.11	4	1	0.40			0.00	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Health	2014	2054	2.86	0.54	0.42	2.08	42%	0.06	0.21	28%	0.35	0.17	2	2	0.15			0.00	0.00
VA VA	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Health Health	2020 2020	2054 2054	8.93 1.60	1.36 0.24	0.00 7.33	0.00 7.33	0% 82%	0.00 1.12	0.00 1.12	0% 82%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.25	8.93	1.36	0.00 7.33	0.00 1.12
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Health	2020	2054	3.22	0.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.22	0.49	0.00	0.00
VA	1430	1432 LEDs (base incandescent A-line 72W) 2020	Health	2020	2054	0.63	0.10	2.59	2.59	81%	0.39	0.39	81%	0.01	0.01	0	0	5.27			2.59	0.39
VA VA	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Health Health	2020 2020	2054 2054	2.37 0.63	0.36	0.00 1.74	0.00 1.74	0% 73%	0.00 0.26	0.00 0.26	0% 73%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 3.91	2.37	0.36	0.00 1.74	0.00 0.26
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Health	2020	2054	3.00	0.46	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.00	0.46	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Health Health	2020 2020	2054 2054	2.17 3.83	0.33	0.83	0.83	28% 0%	0.13 0.00	0.13 0.00	28% 0%	0.09 N/A	0.09 N/A	1 N/A	1 N/A	0.61 N/A	3.83	0.58	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Health	2020	2054	2.83	0.43	1.00	1.00	26%	0.15	0.15	26%	0.07	0.07	0	0	0.81	3.03	0.50	0.00	0.00
VA	1800	1800 BaseMetal Halide, 465W	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Health Health	2014 2014	2054 2054	4.72 4.17	0.72	0.00	0.00 0.55	0% 12%	0.00	0.00 0.08	0% 12%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.99	4.72	0.72	0.00 0.55	0.00
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Health	2014	2054	12.58	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.58	0.12	0.00	0.00
VA VA	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Health Health	2014 2014	2054 2054	11.58 5.57	0.09	1.00 6.01	1.00 7.01	8% 56%	0.03	0.03	27% 74%	0.07 0.14	0.07 0.13	2 15	2 11	0.90 0.39			0.00	0.00
VA	1900	1903 Bi-Level LED Outdoor Lighting	Health	2014	2054	3.93	0.03	1.64	8.65	69%	0.01	0.09	86%	0.14	0.13	109	24	0.06			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Health	2014	2054	66.67	36.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	66.67	36.64	0.00	0.00
VA VA	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	Health Health	2014 2014	2054 2054	60.98 60.88	33.51 33.49	5.69 0.10	5.69 5.79	9% 9%	3.13 0.03	3.13 3.15	9% 9%	0.03 0.02	0.03	0	0	3.05 2.65			5.69 0.10	3.13 0.03
VA	2000	2006 VSD for Chiller Pumps and Towers	Health	2014	2054	60.75	33.45	0.14	5.93	9%	0.04	3.19	9%	0.04	0.03	0	0	1.98			0.14	0.04
VA VA	2000 2000	2013 High Efficiency Chiller Motors 2003 EMS - Chiller	Health Health	2014 2014	2054 2054	60.55 54.79	33.34 32.60	0.20 5.75	6.12 11.88	9% 18%	0.11 0.74	3.30 4.04	9% 11%	0.05 0.05	0.03 0.04	0	0	1.97 1.11			0.20 5.75	0.11 0.74
VA	2000	2012 Duct Testing/Sealing - Chiller	Health	2014	2054	44.38	26.88	10.41	22.29	33%	5.72	9.76	27%	0.05	0.04	0	0	0.56			0.00	0.74
VA	2000	2008 New Economizer - Chiller	Health	2014	2054	39.35	26.24	5.03	27.32	41%	0.65	10.41	28%	0.14	0.11	1	0	0.39			0.00	0.00
VA VA	2000 2000	2002 Window Film (Standard) - Chiller 2004 Cool Roof - Chiller	Health Health	2014 2014	2054 2054	39.29 39.18	26.20 26.14	0.06 0.11	27.38 27.49	41% 41%	0.03	10.44 10.50	28% 29%	0.29 0.77	0.11 0.11	1	0	0.27 0.10			0.00	0.00
VA	2000	2011 Duct/Pipe Insulation - Chiller	Health	2014	2054	38.74	25.90	0.44	27.93	42%	0.24	10.74	29%	2.99	0.16	5	0	0.03			0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Health	2014	2054	223.12	122.63	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	223.12	122.63	0.00	0.00
VA VA	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2105 DX Tune Up/ Advanced Diagnostics	Health Health	2014 2014	2054 2054	171.80 171.64	94.42 94.38	51.32 0.16	51.32 51.48	23% 23%	28.20 0.04	28.20 28.25	23% 23%	0.03	0.03	0	0	3.21 0.68			51.32 0.00	28.20 0.00
VA	2100	2108 Optimize Controls - DX	Health	2014	2054	168.50	93.98	3.14	54.62	24%	0.40	28.65	23%	0.07	0.03	1	0	0.66			0.00	0.00
VA VA	2100 2100	2106 Prog. Thermostat - DX 2112 Duct Testing/Sealing - DX	Health Health	2014 2014	2054 2054	165.02 154.98	93.53 88.01	3.48 10.03	58.10 68.14	26% 31%	0.45 5.51	29.10 34.61	24% 28%	0.09 0.19	0.04 0.06	1	0	0.57			0.00	0.00
VA	2100	2115 Window Film (Standard) - DX	Health	2014	2054	154.98	87.56	0.83	68.14	31%	0.46	35.07	28% 29%	0.19	0.06	0	0	0.32			0.00	0.00
VA	2100	2107 Cool Roof - DX	Health	2014	2054	153.66	87.29	0.49	69.46	31%	0.27	35.34	29%	0.65	0.07	1	0	0.12			0.00	0.00
VA VA	2100 2100	2114 Duct/Pipe Insulation - DX 2111 Economizer Repair - DX	Health Health	2014 2014	2054 2054	151.97 151.97	86.36 86.36	1.69 0.00	71.15 71.15	32% 32%	0.93	36.27 36.27	30% 30%	2.55 23013.76	0.12 0.13	5 27,755	0	0.03			0.00	0.00
VA	2100	2109 Economizer - DX	Health	2014	2054	151.97	86.36	0.00	71.15	32%	0.00	36.27	30%	26793.07	0.15	208,511	ō	0.00			0.00	0.00
VA VA	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Health Health	2014 2014	2054 2054	142.15	78.13	0.00 17.58	0.00 17.58	0% 12%	0.00 9.66	0.00 9.66	0% 12%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.75	142.15	78.13	0.00 17.58	0.00 9.66
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	пеаш	2014	2004	124.57	68.46	17.50	17.30	1270	9.00	9.00	1270	0.02	0.02	U	U	3.13			17.30	9.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	,			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure Number Measure	Building	Start	End Year	Total GWH	Total MW	GWH	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
VA	Number 2300	2300 Base PTAC, EER=8.3, 1 ton	Type Health	2014	2054	31.81	17.48	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	N/A	\$/kWH N/A	N/A	N/A	N/A	31.81	17.48	0.00	0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Health	2014	2054	63.96	12.98	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	63.96	12.98	0.00	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	Health	2014	2054	45.33	12.08	18.63	18.63	29%	0.90	0.90	7%	0.01	0.01	0	0	4.25			18.63	0.90
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	Health Health	2014 2014	2054 2054	44.55 40.31	11.92 10.16	0.78 4.24	19.41 23.65	30% 37%	0.16 1.77	1.06 2.83	8% 22%	0.03 0.84	0.01 0.16	0	0	2.81 0.10			0.78 0.00	0.16 0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Health	2014	2054	222.31	45.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	222.31	45.13	0.00	0.00
VA	3100	3102 Variable Speed Drive Control, 15 HP	Health	2014	2054	157.57	41.99	64.74	64.74	29%	3.14	3.14	7%	0.00	0.00	0	0	12.29			64.74	3.14
VA VA	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Health Health	2014 2014	2054 2054	157.20 134.32	41.91 37.78	0.37 22.88	65.11 87.99	29% 40%	0.07 4.14	3.22 7.36	7% 16%	0.01 0.02	0.00 0.01	0	0	4.97 2.69			0.37 22.88	0.07 4.14
VA	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3105 Energy Recovery Ventilation (ERV)	Health	2014	2054	134.32	34.15	22.88 8.71	96.70	40%	3.63	10.98	24%	0.02	0.01	1	0	0.36			0.00	0.00
VA	3100	3107 Demand Controlled Ventilation	Health	2014	2054	113.65	29.17	11.96	108.66	49%	4.98	15.96	35%	1.03	0.14	2	1	0.08			0.00	0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Health	2014	2054	236.21	47.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	236.21	47.95	0.00	0.00
VA VA	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Health Health	2014 2014	2054 2054	213.72 0.00	38.59 0.00	22.49	22.49 0.00	10%	9.36 0.00	9.36 0.00	20% 0%	0.58 N/A	0.58 N/A	1 N/A	1 N/A	0.15 N/A	0.00	0.00	0.00	0.00
VA	4100		Health	2014	2054	43.75	6.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	43.75	6.34	0.00	0.00
VA	4100	4103 Night covers for display cases (self-contained)	Health	2014	2054	43.03	6.23	0.73	0.73	2%	0.11	0.11	2%	0.00	0.00	0	0	11.99			0.73	0.11
VA	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Health Health	2014 2014	2054	42.35 42.01	6.14	0.68	1.40 1.74	3% 4%	0.10	0.20	3% 4%	0.00	0.00	0	0	10.46 3.48			0.68	0.10
VA VA	4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Health Health	2014	2054	42.01	6.09	0.49	2.23	4% 5%	0.05	0.25	4% 5%	0.02	0.01	0	0	3.48			0.49	0.05
VA	4100	4110 Energy Star Ice Machines	Health	2014	2054	41.07	5.95	0.45	2.68	6%	0.07	0.39	6%	0.05	0.02	0	0	1.23			0.45	0.07
VA	4100	4112 Reach-in unit occupancy sensors	Health	2014	2054	41.06	5.95	0.01	2.70	6%	0.00	0.39	6%	0.28	0.02	2	0	0.21			0.00	0.00
VA VA	4100 5000	4105 Bi-level LED Case Lighting (self-contained units) 2014 5000 Base Desktop PC	Health Health	2014 2014	2054 2054	41.01 9.92	5.94 1.41	0.05 0.00	2.74 0.00	6% 0%	0.01 0.00	0.40	6% 0%	0.32 N/A	0.02 N/A	2 N/A	0 N/A	0.17 N/A	9.92	1.41	0.00	0.00
VA	5000	5001 PC Network Power Management Enabling	Health	2014	2054	5.32	1.08	4.60	4.60	46%	0.33	0.00	23%	0.02	0.02	0	0	2.51	5.52	1.91	4.60	0.33
VA	5000	5002 Energy Star or Better PC	Health	2014	2054	3.64	0.84	1.69	6.29	63%	0.24	0.57	40%	0.04	0.02	0	0	1.20			1.69	0.24
VA VA	5100	5100 Base Laptop PC	Health Health	2014 2014	2054	0.51	0.07	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A	N/A 0.01	N/A 0	N/A 0	N/A	0.51	0.07	0.00	0.00
VA VA	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Health Health	2014	2054 2054	0.42	0.06	0.10	0.10	19% 21%	0.01	0.01	19% 21%	0.01 1.77	0.01	12	1	3.39 0.03			0.10	0.01
VA	5200	5200 Base Monitor, CRT	Health	2014	2054	2.73	0.39	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.73	0.39	0.00	0.00
VA	5200	5201 Energy Star or Better Monitor - CRT	Health	2014	2054	1.23	0.17	1.50	1.50	55%	0.21	0.21	55%	0.00	0.00	0	0	27.71			1.50	0.21
VA VA	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Health Health	2014 2014	2054 2054	0.83	0.15	0.40	1.90 1.97	70% 72%	0.03 0.01	0.24 0.25	62% 65%	0.03	0.01 0.02	0	0	1.63 0.15			0.40 0.00	0.03
VA	5300	5300 Base Monitor, LCD	Health	2014	2054	1.75	0.14	0.07	0.00	0%	0.00	0.25	0%	0.33 N/A	0.02 N/A	N/A	N/A	0.15 N/A	1.75	0.25	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Health	2014	2054	1.41	0.20	0.34	0.34	20%	0.05	0.05	20%	0.01	0.01	0	0	3.88			0.34	0.05
VA	5300	5302 Monitor Power Management Enabling - LCD	Health	2014	2054	1.34	0.20	0.07	0.41	24%	0.00	0.05	22%	0.12	0.03	2	0	0.39			0.00	0.00
VA VA	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Health Health	2014 2014	2054 2054	1.23 2.77	0.19 0.39	0.11	0.52 0.00	30% 0%	0.00	0.06	23% 0%	0.33 N/A	0.09 N/A	N/A	N/A	0.13 N/A	2.77	0.39	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Health	2014	2054	2.30	0.33	0.47	0.47	17%	0.07	0.07	17%	0.00	0.00	0	0	19.12	2	0.00	0.47	0.07
VA	5400	5402 Copier Power Management Enabling	Health	2014	2054	2.15	0.32	0.15	0.61	22%	0.01	0.08	19%	0.14	0.04	2	0	0.34			0.00	0.00
VA VA	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Printer	Health Health	2014 2014	2054 2054	0.45	0.06	0.00 0.11	0.00	0% 25%	0.00 0.02	0.00 0.02	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.67	0.45	0.06	0.00	0.00 0.02
VA	5500	5501 Multifunction Power Management Enabling	Health	2014	2054	0.33	0.03	0.05	0.16	36%	0.02	0.02	31%	0.01	0.01	5	1	0.14			0.00	0.02
VA	5600	5600 Base Printer	Health	2014	2054	2.25	0.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.25	0.32	0.00	0.00
VA VA	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Health Health	2014 2014	2054 2054	1.46 1.25	0.21 0.19	0.78 0.21	0.78 0.99	35% 44%	0.11 0.02	0.11 0.13	35% 40%	0.00 0.07	0.00 0.02	0	0	26.07 0.63			0.78 0.00	0.11 0.00
VA	5700	5700 Base Data Center/Server Room	Health	2014	2054	39.44	5.61	0.21	0.99	44% 0%	0.02	0.13	40% 0%	0.07 N/A	0.02 N/A	N/A	N/A	0.63 N/A	39.44	5.61	0.00	0.00
VA	5700	5701 Data Center Improved Operations	Health	2014	2054	35.50	5.04	3.94	3.94	10%	0.56	0.56	10%	0.00	0.00	0	0	103.06	00.11	0.01	3.94	0.56
VA	5700	5702 Data Center Best Practices	Health	2014	2054	30.98	4.40	4.52	8.46	21%	0.64	1.20	21%	0.00	0.00	0	0	41.96			4.52	0.64
VA VA	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Health Health	2014 2014	2054 2054	29.25 16.04	4.16 2.07	1.74 0.00	10.20 0.00	26% 0%	0.25 0.00	1.45 0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	21.76 N/A	16.04	2.07	1.74 0.00	0.25 0.00
VA	6000	6001 Demand controlled circulating systems	Health	2014	2054	15.44	1.99	0.60	0.60	4%	0.08	0.08	4%	0.04	0.04	0	0	1.65	10.04	2.01	0.60	0.08
VA	6000	6007 Heat Trap	Health	2014	2054	14.64	1.89	0.80	1.40	9%	0.10	0.18	9%	0.04	0.04	0	0	1.46			0.80	0.10
VA VA	6000 6000	6002 High Efficiency Water Heater (electric) 6006 Heat Recovery Unit	Health Health	2014 2014	2054 2054	14.35 6.89	1.85 0.89	0.29 7.46	1.69 9.15	11% 57%	0.04 0.96	0.22 1.18	11% 57%	0.08 0.08	0.05 0.07	1	0	0.78 0.75			0.00	0.00
VA	6000	6004 Tankless Water Heater	Health	2014	2054	6.89	0.89	0.52	9.15	60%	0.96	1.18	57% 60%	0.08	0.07	2	1	0.75			0.00	0.00
VA	6000	6008 Solar Water Heater	Health	2014	2054	5.48	0.71	0.89	10.56	66%	0.11	1.36	66%	0.30	0.10	2	1	0.23			0.00	0.00
VA	6000	6003 Hot Water Pipe Insulation	Health	2014	2054	5.43	0.70	0.05	10.61	66% 0%	0.01	1.37	66%	0.35	0.10	3	1	0.18	6.40	0.00	0.00	0.00
VA VA	7000 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Health Health	2014 2014	2054 2054	6.16 5.17	0.86 0.79	0.00 0.98	0.00 0.98	0% 16%	0.00 0.07	0.00 0.07	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.86	6.16	0.86	0.00 0.98	0.00 0.07
VA	7000	7002 Vending Misers (Refrigerated glass-front units)	Health	2014	2054	4.64	0.75	0.54	1.52	25%	0.04	0.10	12%	0.05	0.03	1	0	1.01			0.54	0.04
VA	7100	7100 Base Non-Refrigerated Vending Machines	Health	2014	2054	0.12	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.02	0.00	0.00
VA VA	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Health Health	2014 2014	2054 2054	0.07 9.72	0.01 1.85	0.06	0.06	46% 0%	0.00	0.00	22% 0%	0.42 N/A	0.42 N/A	6 N/A	6 N/A	0.11 N/A	9.72	1.85	0.00	0.00
VA	7200	7300 Base Oven 7300 Base Fryer	Health	2014	2054	9.72	1.85	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	9.72	1.85	0.00	0.00
VA	7300	7301 Efficient Fryer	Health	2014	2054	8.77	1.67	0.60	0.60	6%	0.11	0.11	6%	0.43	0.43	2	2	0.15			0.00	0.00
VA	7400	7400 Base Steamer	Health	2014	2054	8.41	1.61	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.41	1.61	0.00	0.00
VA VA	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health Health	2014 2014	2054 2054	17.94 16.93	0.00	0.00 1.01	0.00 1.01	0% 6%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A N/A	N/A N/A	N/A 2.98	17.94	0.00	0.00 1.01	0.00
VA	8100	8100 Base Heating, Other Electric	Health	2014	2054	25.25	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	0.02 N/A	N/A	N/A	2.96 N/A	25.25	0.00	0.00	0.00
VA	9500	9500 Base Miscellaneous	Health	2014	2054	378.95	52.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	378.95	52.75	0.00	0.00
VA	9500	9501 Xmisc	Health	2014	2054	378.95	52.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00	0.24	1.21	0.00	0.00
VA VA	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Lodging Lodging	2020 2020	2054 2054	9.24 8.28	1.31 1.17	0.00 0.96	0.00 0.96	0% 10%	0.00 0.14	0.00 0.14	0% 10%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.54	9.24	1.31	0.00 0.96	0.00 0.14
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Lodging	2020	2054	7.23	1.02	1.05	2.01	22%	0.15	0.29	22%	0.05	0.04	0	0	1.22			1.05	0.15

DNV GL 1/5/2015 H-13

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS															SUPPLY					
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
VA	Number 1030	Number Measure 1036 Lighting Control Tuneup (base 4L4'T8), 2020	Type Lodging	Year 2020	Year 2054	GWH 7.19	MW 1.02	Savings 0.03	2.05	Savings 22%	Savings 0.00	MW 0.29	Savings 22%	\$/kWH 0.05	\$/kWH 0.04	\$/kW	\$/kW	1.00	GWH	MW	0.00	0.00
VA	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Lodging	2020	2054	6.64	0.96	0.55	2.60	28%	0.06	0.35	27%	0.07	0.05	1	Ö	0.85			0.00	0.00
VA	1030	1034 ROB 4L4' LED Tube, 2020	Lodging	2020	2054	5.57	0.81	1.07	3.67	40%	0.15	0.50	38%	0.35	0.14	3	1	0.20			0.00	0.00
VA VA	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Lodging	2020 2020	2054	5.41	0.80	0.16 0.46	3.83	41% 46%	0.01 0.07	0.51	39% 44%	0.18 0.30	0.14	5 2	1	0.27			0.00	0.00
VA	1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Lodging Lodging	2020	2054 2054	4.95 37.39	5.29	0.46	4.29 0.00	0%	0.00	0.57	0%	0.30 N/A	0.15 N/A	N/A	N/A	0.23 N/A	37.39	5.29	0.00	0.00
VA	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Lodging	2020	2054	33.50	4.74	3.89	3.89	10%	0.55	0.55	10%	0.03	0.03	0	0	2.00			3.89	0.55
VA	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Lodging	2020	2054	29.24	4.14	4.26	8.15	22%	0.60	1.15	22%	0.06	0.05	0	0	0.96			0.00	0.00
VA VA	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Lodging Lodging	2020 2020	2054 2054	29.10 26.87	4.13 3.88	0.13 2.23	8.28 10.52	22% 28%	0.01 0.25	1.16 1.41	22% 27%	0.07 0.10	0.05 0.06	1	0	0.72			0.00	0.00
VA	1130	1134 ROB 2L4' LED Tube, 2020	Lodging	2020	2054	25.57	3.70	1.30	11.82	32%	0.23	1.59	30%	0.10	0.08	2	1	0.25			0.00	0.00
VA	1130	1135 LED Troffer (base 2L4T8), 2020	Lodging	2020	2054	23.39	3.39	2.18	14.00	37%	0.31	1.90	36%	0.37	0.13	3	1	0.19			0.00	0.00
VA VA	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	Lodging	2020 2014	2054 2054	22.73 0.73	3.37 0.10	0.66 0.00	14.66 0.00	39% 0%	0.02	1.92 0.00	36% 0%	0.30 N/A	0.14 N/A	9 N/A	1 N/A	0.16 N/A	0.73	0.10	0.00	0.00
VA	1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Lodging Lodging	2014	2054	0.73	0.10	0.00	0.00	3%	0.00	0.00	1%	0.02	0.02	0	0	2.44	0.73	0.10	0.00	0.00
VA	1200	1201 ROB High Performance T8 (base other fluorescent)	Lodging	2014	2054	0.63	0.09	0.07	0.09	13%	0.01	0.01	11%	0.10	0.08	1	1	0.61			0.00	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Lodging	2014	2054	0.55	0.08	0.08	0.17	24%	0.01	0.02	22%	0.21	0.14	1	1	0.29			0.00	0.00
VA VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Lodging Lodging	2014 2014	2054 2054	0.51 0.47	0.07	0.04 0.04	0.22 0.25	30% 35%	0.00	0.03	27% 28%	0.23 0.20	0.16 0.17	2 6	1	0.26 0.24			0.00	0.00
VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Lodging	2020	2054	56.01	7.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	56.01	7.93	0.00	0.00
VA	1330	1332 LEDs (base incandescent flood) 2020	Lodging	2020	2054	10.81	1.53	45.20	45.20	81%	6.40	6.40	81%	0.01	0.01	0	0	7.93			45.20	6.40
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Lodging	2020	2054	20.16	2.85	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	20.16	2.85	0.00	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Lodging Lodging	2020 2020	2054 2054	4.23 14.84	0.60 2.10	15.94 0.00	15.94 0.00	79% 0%	2.26 0.00	2.26	79% 0%	0.01 N/A	0.01 N/A	N/A	N/A	6.68 N/A	14.84	2.10	15.94 0.00	2.26 0.00
VA	1530	1532 LEDs (base incandescent A-line 53W) 2020	Lodging	2020	2054	4.24	0.60	10.60	10.60	71%	1.50	1.50	71%	0.01	0.01	0	0	4.92		20	10.60	1.50
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Lodging	2020	2054	11.67	1.65	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.67	1.65	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Lodging Lodging	2020 2020	2054 2054	8.44 14.91	1.19 2.11	3.23 0.00	3.23 0.00	28% 0%	0.46	0.46 0.00	28% 0%	0.09 N/A	0.09 N/A	1 N/A	1 N/A	0.72 N/A	14.91	2.11	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Lodging	2020	2054	11.03	1.56	3.88	3.88	26%	0.55	0.55	26%	0.07	0.07	0	0	0.95	14.51	2.11	0.00	0.00
VA	1800	1800 BaseMetal Halide, 465W	Lodging	2014	2054	29.88	4.23	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	29.88	4.23	0.00	0.00
VA	1800	1801 T5 (240W) (base metal halide)	Lodging	2014	2054	19.78	2.80	10.10	10.10	34%	1.43	1.43	34%	0.02	0.02	0	0	3.57			10.10	1.43
VA VA	1800 1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1806 Occupancy Sensor, High Bay T5	Lodging Lodging	2014 2014	2054 2054	18.26 17.63	2.63 2.61	1.52 0.63	11.62 12.25	39% 41%	0.17 0.02	1.60 1.62	38% 38%	0.05 0.05	0.02 0.02	0	0	1.25 0.94			1.52 0.00	0.17 0.00
VA	1850	1850 Base CFL Exit Sign	Lodging	2014	2054	6.70	0.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.70	0.95	0.00	0.00
VA	1850	1851 LED Exit Sign	Lodging	2014	2054	3.78	0.54	2.91	2.91	44%	0.41	0.41	44%	0.03	0.03	0	0	1.81			2.91	0.41
VA VA	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Lodging	2014 2014	2054 2054	43.47 39.90	0.37	0.00 3.56	0.00 3.56	0% 8%	0.00 0.10	0.00 0.10	0% 28%	N/A 0.05	N/A 0.05	N/A 2	N/A 2	N/A 1.28	43.47	0.37	0.00 3.56	0.00 0.10
VA	1900	1907 Outdoor Lighting Controls (Protocell/Timeclock)	Lodging Lodging	2014	2054	19.20	0.27	20.70	24.27	56%	0.10	0.10	75%	0.05	0.05	12	8	0.56			0.00	0.00
VA	1900	1903 Bi-Level LED Outdoor Lighting	Lodging	2014	2054	13.55	0.05	5.65	29.92	69%	0.04	0.33	87%	0.65	0.20	83	18	0.09			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Lodging	2014	2054	150.18	90.43	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	150.18	90.43	0.00	0.00
VA VA	2000 2000	2002 Window Film (Standard) - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Lodging Lodging	2014 2014	2054 2054	144.75 132.40	87.16 79.72	5.43 12.36	5.43 17.78	4% 12%	3.27 7.44	3.27 10.71	4% 12%	0.03	0.03	0	0	2.71			5.43 12.36	3.27 7.44
VA	2000	2005 Chiller Tune Up/Diagnostics	Lodging	2014	2054	129.34	78.84	3.05	20.84	14%	0.88	11.59	13%	0.04	0.04	0	0	1.71			3.05	0.88
VA	2000	2013 High Efficiency Chiller Motors	Lodging	2014	2054	129.34	78.84	0.01	20.84	14%	0.00	11.59	13%	0.08	0.04	0	0	1.32			0.01	0.00
VA VA	2000 2000	2006 VSD for Chiller Pumps and Towers 2008 New Economizer - Chiller	Lodging Lodging	2014 2014	2054	128.83 81.45	78.69 72.03	0.51 47.38	21.35 68.73	14% 46%	0.15 6.66	11.74 18.40	13% 20%	0.06	0.04	0	0	1.17 0.87			0.51	0.15
VA	2000	2003 EMS - Chiller	Lodging	2014	2054	74.71	71.08	6.74	75.47	50%	0.95	19.35	21%	0.00	0.06	1	0	0.46			0.00	0.00
VA	2000	2012 Duct Testing/Sealing - Chiller	Lodging	2014	2054	60.52	62.53	14.20	89.66	60%	8.55	27.90	31%	0.43	0.12	1	0	0.24			0.00	0.00
VA VA	2000 2000	2004 Cool Roof - Chiller 2011 Duct/Pipe Insulation - Chiller	Lodging	2014 2014	2054 2054	60.40 60.09	62.46 62.28	0.12 0.30	89.78 90.09	60% 60%	0.07 0.18	27.97 28.15	31% 31%	1.93 4.61	0.12 0.14	3 8	0	0.04 0.02			0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Lodging Lodging	2014	2054	383.60	230.99	0.00	0.00	0%	0.10	0.00	0%	4.61 N/A	0.14 N/A	N/A	N/A	0.02 N/A	383.60	230.99	0.00	0.00
VA	2100	2115 Window Film (Standard) - DX	Lodging	2014	2054	363.95	219.16	19.65	19.65	5%	11.83	11.83	5%	0.03	0.03	0	0	2.65			19.65	11.83
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons	Lodging	2014	2054	280.25	168.75	83.71	103.36	27%	50.41	62.24	27%	0.05	0.04	0	0	2.12			83.71	50.41
VA VA	2100 2100	2108 Optimize Controls - DX 2105 DX Tune Up/ Advanced Diagnostics	Lodging Lodging	2014 2014	2054 2054	275.11 271.25	168.03 166.91	5.13 3.87	108.49 112.36	28% 29%	0.72 1.11	62.96 64.07	27% 28%	0.08 0.15	0.04 0.05	1	0	0.59 0.43			0.00	0.00
VA	2100	2106 Prog. Thermostat - DX	Lodging	2014	2054	263.28	165.79	7.97	120.32	31%	1.12	65.19	28%	0.14	0.05	1	Ō	0.36			0.00	0.00
VA	2100	2112 Duct Testing/Sealing - DX	Lodging	2014	2054	247.27	156.16	16.01	136.33	36%	9.64	74.83	32%	0.31	0.08	1	0	0.33			0.00	0.00
VA VA	2100 2100	2111 Economizer Repair - DX 2107 Cool Roof - DX	Lodging Lodging	2014 2014	2054 2054	246.00 245.52	155.00 154.71	1.27 0.48	137.60 138.08	36% 36%	1.15 0.29	75.98 76.27	33% 33%	0.89 1.21	0.09 0.10	1 2	0	0.09 0.07			0.00	0.00
VA	2100	2109 Economizer - DX	Lodging	2014	2054	241.48	154.71	4.03	142.12	37%	0.25	76.84	33%	1.05	0.10	7	0	0.07			0.00	0.00
VA	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Lodging	2014	2054	241.48	154.14	0.01	142.13	37%	0.00	76.84	33%	1.77	0.12	13	0	0.03			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Lodging	2014	2054	238.85	152.57	2.62	144.75	38%	1.58	78.42	34%	2.97	0.17	5	0	0.03	007.05	470.00	0.00	0.00
VA VA	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging Lodging	2014 2014	2054 2054	297.25 260.49	178.99 156.85	0.00 36.76	0.00 36.76	0% 12%	0.00 22.14	0.00 22.14	0% 12%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.65	297.25	178.99	0.00 36.76	0.00 22.14
VA	2300	2300 Base PTAC, EER=8.3, 1 ton	Lodging	2014	2054	62.42	37.58	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	62.42	37.58	0.00	0.00
VA	2300	2301 HE PTAC, EER=9.6, 1 ton	Lodging	2014	2054	53.96	32.49	8.45	8.45	14%	5.09	5.09	14%	0.08	0.08	0	0	1.24			8.45	5.09
VA VA	2300 3000	2302 Occupancy Sensor (hotels)	Lodging	2014 2014	2054 2054	48.11 250.99	27.74 53.08	5.85 0.00	14.31 0.00	23% 0%	4.75 0.00	9.84 0.00	26% 0%	0.26 N/A	0.15 N/A	0 N/A	0 N/A	0.36 N/A	250.99	53.08	0.00	0.00
VA VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Lodging Lodging	2014	2054	250.99	53.08 52.17	4.33	4.33	0% 2%	0.00	0.00	0% 2%	0.03	0.03	N/A 0	N/A 0	N/A 2.37	∠50.99	53.08	0.00 4.33	0.00
VA	3000	3003 Demand Controlled Ventilation	Lodging	2014	2054	212.47	37.30	34.19	38.52	15%	14.87	15.78	30%	0.97	0.86	2	2	0.09			0.00	0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	Lodging Lodging	2014 2014	2054 2054	43.39 38.86	9.18 8.95	0.00 4.53	0.00 4.53	0% 10%	0.00 0.23	0.00 0.23	0% 3%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.00	43.39	9.18	0.00 4.53	0.00 0.23
VA	3200	3204 Demand Controlled Ventilation	Lodging	2014	2054	33.47	6.61	5.39	9.92	23%	2.34	2.57	28%	1.06	0.59	2	2	0.08			0.00	0.23

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS													SUPPLY							
Vinta				Measure	Manager				Total	Percent		Total	Percent	Marginal	Average	Marginal	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Capacity	Cost Test	Base	Base	Economic	Economic
Sgmt VA	Number 4000	Number Measure 4000 Base Built-Up Refrigeration System	Type	Year 2014	Year 2054	GWH 0.00	MW 0.00	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	0.00	MW 0.00	GWH 0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Lodging Lodging	2014	2054	141.67	20.71	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	141.67	20.71	0.00	0.00
VA	4100	4103 Night covers for display cases (self-contained)	Lodging	2014	2054	135.53	19.81	6.14	6.14	4%	0.90	0.90	4%	0.00	0.00	0	0	69.64			6.14	0.90
VA VA	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Lodging	2014 2014	2054 2054	133.81 131.77	19.56 19.27	1.72 2.04	7.85 9.89	6%	0.25 0.30	1.15	6%	0.00	0.00	0	0	26.71 19.92			1.72 2.04	0.25
VA	4100	4109 Energy-Star Freezer, glass door 4107 Energy-Star Freezer, solid door	Lodging Lodging	2014	2054	130.94	19.27	0.84	10.73	7% 8%	0.30	1.45 1.57	7% 8%	0.00	0.00	0	0	7.94			0.84	0.30
VA	4100	4106 Energy-Star Refrigerator, solid door	Lodging	2014	2054	130.36	19.06	0.57	11.30	8%	0.08	1.65	8%	0.01	0.00	0	0	6.31			0.57	0.08
VA VA	4100 4100	4110 Energy Star Ice Machines 4105 Bi-level LED Case Lighting (self-contained units) 2014	Lodging Lodging	2014 2014	2054 2054	129.30 129.26	18.90 18.90	1.06 0.04	12.37 12.40	9% 9%	0.16 0.01	1.81 1.81	9% 9%	0.02 0.33	0.00	0	0	2.34 0.17			1.06 0.00	0.16 0.00
VA	4100	4101 Strip curtains for walk-ins (self-contained)	Lodging	2014	2054	128.70	18.82	0.56	12.97	9%	0.08	1.90	9%	0.35	0.02	2	0	0.14			0.00	0.00
VA	5000	5000 Base Desktop PC	Lodging	2014	2054	9.10	1.35	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.10	1.35	0.00	0.00
VA VA	5000 5000	5002 Energy Star or Better PC 5001 PC Network Power Management Enabling	Lodging Lodging	2014 2014	2054 2054	7.19 3.86	1.07 0.82	1.91 3.33	1.91 5.24	21% 58%	0.28 0.25	0.28 0.53	21% 39%	0.01 0.02	0.01 0.02	0	0	3.72 2.85			1.91 3.33	0.28 0.25
VA	5100	5100 Base Laptop PC	Lodging	2014	2054	0.44	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.44	0.06	0.00	0.00
VA	5100	5102 Energy Star or Better Laptop	Lodging	2014	2054	0.35	0.05	0.08	0.08	19%	0.01	0.01	19%	0.01	0.01	0	0	4.87			0.08	0.01
VA VA	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Lodging Lodging	2014 2014	2054 2054	0.35 4.29	0.05 0.64	0.01 0.00	0.09	21% 0%	0.00	0.01 0.00	21% 0%	1.24 N/A	0.11 N/A	N/A	N/A	0.04 N/A	4.29	0.64	0.00	0.00
VA	5200	5201 Energy Star or Better Monitor - CRT	Lodging	2014	2054	1.88	0.28	2.41	2.41	56%	0.36	0.36	56%	0.00	0.00	0	0	38.73			2.41	0.36
VA VA	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Lodging	2014 2014	2054 2054	1.43 1.31	0.25	0.45 0.11	2.86 2.97	67% 69%	0.03 0.02	0.39 0.41	61% 64%	0.02 0.21	0.00 0.01	0	0	2.72 0.24			0.45 0.00	0.03
VA	5300	5300 Base Monitor, LCD	Lodging Lodging	2014	2054	1.90	0.23	0.00	0.00	0%	0.02	0.00	0%	N/A	N/A	N/A	N/A	0.24 N/A	1.90	0.28	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Lodging	2014	2054	1.71	0.25	0.19	0.19	10%	0.03	0.03	10%	0.01	0.01	0	0	6.24			0.19	0.03
VA VA	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Lodging	2014 2014	2054	1.51	0.24	0.19	0.38	20% 27%	0.01	0.04	15% 17%	0.08 0.22	0.05	1 6	0	0.57			0.00	0.00
VA	5400	5400 Base Copier	Lodging Lodging	2014	2054	2.65	0.23	0.12	0.00	0%	0.00	0.00	0%	0.22 N/A	0.09 N/A	N/A	N/A	0.20 N/A	2.65	0.39	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Lodging	2014	2054	2.39	0.35	0.26	0.26	10%	0.04	0.04	10%	0.00	0.00	0	0	29.79			0.26	0.04
VA VA	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Lodging Lodging	2014 2014	2054 2054	2.29 0.41	0.35	0.10 0.00	0.35 0.00	13% 0%	0.01 0.00	0.05 0.00	12% 0%	0.09 N/A	0.03 N/A	1 N/A	0 N/A	0.54 N/A	0.41	0.06	0.00	0.00
VA	5500	5502 ENERGY STAR Multi-Function Printer	Lodging	2014	2054	0.41	0.05	0.10	0.10	25%	0.02	0.02	25%	0.01	0.01	0	0	8.14	0.41	0.00	0.00	0.00
VA	5500	5501 Multifunction Power Management Enabling	Lodging	2014	2054	0.25	0.04	0.06	0.16	39%	0.00	0.02	32%	0.26	0.09	3	1	0.18			0.00	0.00
VA VA	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Lodging Lodging	2014 2014	2054 2054	1.15 0.75	0.17	0.00	0.00 0.40	0% 35%	0.00	0.00 0.06	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 37.40	1.15	0.17	0.00 0.40	0.00
VA	5600	5601 Printer Power Management Enabling	Lodging	2014	2054	0.61	0.10	0.14	0.54	47%	0.01	0.07	41%	0.06	0.02	1	0	0.84			0.00	0.00
VA	5700	5700 Base Data Center/Server Room	Lodging	2014	2054	40.24	5.98	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	40.24	5.98	0.00	0.00
VA VA	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Lodging Lodging	2014 2014	2054 2054	36.21 31.61	5.38 4.70	4.02 4.61	4.02 8.63	10% 21%	0.60 0.68	0.60 1.28	10% 21%	0.00	0.00	0	0	103.65 42.20			4.02 4.61	0.60 0.68
VA	5700	5703 Data Center State of the Art practices	Lodging	2014	2054	29.84	4.43	1.77	10.40	26%	0.26	1.55	26%	0.00	0.00	0	0	21.88			1.77	0.26
VA VA	6000 6000	6000 Base Water Heating	Lodging	2014 2014	2054	62.44 59.20	8.42 7.98	0.00 3.23	0.00 3.23	0% 5%	0.00 0.44	0.00 0.44	0% 5%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.25	62.44	8.42	0.00 3.23	0.00 0.44
VA	6000	6007 Heat Trap 6006 Heat Recovery Unit	Lodging Lodging	2014	2054 2054	59.20	6.95	7.70	10.93	5% 18%	1.04	1.47	5% 18%	0.01	0.01	0	0	4.25 3.18			3.23 7.70	1.04
VA	6000	6001 Demand controlled circulating systems	Lodging	2014	2054	49.58	6.69	1.93	12.86	21%	0.26	1.73	21%	0.03	0.02	0	ō	2.18			1.93	0.26
VA VA	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Lodging Lodging	2014 2014	2054 2054	48.58 44.94	6.55 6.06	0.99 3.64	13.85 17.50	22% 28%	0.13 0.49	1.87 2.36	22% 28%	0.03 0.05	0.02	0	0	1.90 1.35			0.99 3.64	0.13 0.49
VA	6000	6008 Solar Water Heater	Lodging	2014	2054	38.65	5.21	6.29	23.79	38%	0.49	3.21	38%	0.05	0.03	0	0	1.16			6.29	0.49
VA	6000	6003 Hot Water Pipe Insulation	Lodging	2014	2054	37.99	5.12	0.66	24.45	39%	0.09	3.30	39%	0.07	0.04	1	0	0.90			0.00	0.00
VA VA	7000 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Lodging Lodging	2014 2014	2054 2054	15.02 12.67	2.44 2.26	0.00 2.35	0.00 2.35	0% 16%	0.00 0.19	0.00 0.19	0% 8%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 1.91	15.02	2.44	0.00 2.35	0.00 0.19
VA	7000	7002 Vending Misers (Refrigerated glass-front units)	Lodging	2014	2054	11.40	2.15	1.27	3.62	24%	0.10	0.29	12%	0.05	0.02	1	0	1.04			1.27	0.10
VA	7100	7100 Base Non-Refrigerated Vending Machines	Lodging	2014	2054	0.09	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.01	0.00	0.00
VA VA	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Lodging Lodging	2014 2014	2054 2054	0.05 2.97	0.01 0.61	0.04 0.00	0.04	45% 0%	0.00	0.00	22% 0%	0.41 N/A	0.41 N/A	5 N/A	5 N/A	0.11 N/A	2.97	0.61	0.00	0.00
VA	7300	7300 Base Fryer	Lodging	2014	2054	7.48	1.53	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.48	1.53	0.00	0.00
VA	7400	7400 Base Steamer	Lodging	2014	2054	1.24	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.24	0.25	0.00	0.00
VA VA	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging Lodging	2014 2014	2054 2054	24.82 23.42	0.00	0.00	0.00 1.40	0% 6%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A N/A	N/A N/A	N/A 2.11	24.82	0.00	0.00 1.40	0.00
VA	8100	8100 Base Heating, Other Electric	Lodging	2014	2054	19.91	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	19.91	0.00	0.00	0.00
VA	9500	9500 Base Miscellaneous	Lodging	2014	2054	279.75	45.55	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	279.75	45.55	0.00	0.00
VA VA	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Lodging Data Centers	2014 2020	2054 2054	279.75 17.07	45.55 2.97	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	17.07	2.97	0.00	0.00
VA	1030	1036 Lighting Control Tuneup (base 4L4T8), 2020	Data Centers	2020	2054	17.02	2.97	0.05	0.05	0%	0.00	0.00	0%	0.01	0.01	0	0	4.72			0.05	0.00
VA VA	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Data Centers		2054	15.76 14.16	2.79	1.26 1.61	1.31 2.91	8% 17%	0.18 0.28	0.18	6% 16%	0.01 0.02	0.01 0.02	0	0	4.30 2.48			1.26	0.18 0.28
VA	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Data Centers Data Centers	2020	2054	12.35	2.51	1.80	4.72	28%	0.28	0.46 0.77	26%	0.02	0.02	0	0	1.19			1.61 1.80	0.28
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Data Centers	2020	2054	11.42	2.15	0.93	5.65	33%	0.04	0.82	28%	0.07	0.04	2	Ö	0.70			0.00	0.00
VA VA	1030 1030	1034 ROB 4L4' LED Tube, 2020	Data Centers Data Centers		2054 2054	9.58 8.76	1.83	1.84 0.82	7.49 8.31	44% 49%	0.32	1.14 1.28	38% 43%	0.30 0.25	0.10	2	1	0.22			0.00	0.00
VA VA	1030	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Data Centers Data Centers		2054	0.29	0.05	0.82	0.00	49% 0%	0.14	0.00	43% 0%	0.25 N/A	0.12 N/A	1 N/A	1 N/A	0.26 N/A	0.29	0.05	0.00	0.00
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Data Centers	2020	2054	0.29	0.05	0.00	0.00	0%	0.00	0.00	0%	0.02	0.02	0	0	2.74			0.00	0.00
VA VA	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Data Centers Data Centers	2020 2020	2054 2054	0.27 0.24	0.05	0.02 0.03	0.02 0.05	8% 17%	0.00	0.00 0.01	6% 16%	0.03	0.03	0	0	2.50 1.95			0.02 0.03	0.00
VA	1130	1131 ROB 2L4 High Performance 18 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Data Centers Data Centers		2054	0.24	0.04	0.03	0.05	28%	0.00	0.01	26%	0.03	0.03	0	0	0.94			0.03	0.00
VA	1130	1134 ROB 2L4' LED Tube, 2020	Data Centers	2020	2054	0.20	0.04	0.01	0.09	31%	0.00	0.01	30%	0.23	0.06	1	0	0.29			0.00	0.00
VA VA	1130 1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1135 LED Troffer (base 2L4'T8), 2020	Data Centers Data Centers		2054 2054	0.18 0.17	0.03	0.01 0.02	0.11 0.12	36% 42%	0.00	0.02 0.02	31% 37%	0.13 0.31	0.07 0.10	3	0	0.37			0.00	0.00
VA	1130	1100 LED 110Het (Dase 2L4 10), 2020	Data Centers	2020	∠054	0.17	0.03	0.02	0.12	42%	0.00	0.02	3/%	0.31	0.10	2	1	0.21			0.00	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS															SUPPLY					
Vinta	ge			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
Samt	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
VA	1200	1200 Base Other Fluorescent Fixture	Data Centers	2014	2054	0.63	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.63	0.11	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Data Centers	2014	2054	0.61	0.11	0.01	0.01	2%	0.00	0.00	1%	0.00	0.00	0	0	13.26			0.01	0.00
VA VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Data Centers Data Centers	2014	2054	0.57	0.10	0.05	0.06	9% 19%	0.01	0.01 0.02	7% 16%	0.03	0.03 0.06	0	0	1.99 0.60			0.05	0.01
VA	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Data Centers	2014	2054	0.44	0.09	0.07	0.18	29%	0.00	0.02	19%	0.13	0.09	3	1	0.39			0.00	0.00
VA	1200 1330	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Data Centers		2054	0.39 5.27	0.08	0.06	0.24	38% 0%	0.01	0.03	28%	0.23 N/A	0.12	1	1	0.25			0.00	0.00
VA VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Data Centers Data Centers	2020	2054	1.04	0.92	0.00 4.24	0.00 4.24	0% 80%	0.00 0.74	0.00 0.74	0% 80%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 10.00	5.27	0.92	0.00 4.24	0.00 0.74
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Data Centers	2020	2054	1.90	0.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.90	0.33	0.00	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 20201530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Data Centers Data Centers	2020 2020	2054 2054	0.40 1.40	0.07	1.49 0.00	1.49 0.00	79% 0%	0.26 0.00	0.26 0.00	79% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	8.42 N/A	1.40	0.24	1.49 0.00	0.26
VA	1530	1530 base incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Data Centers	2020	2054	0.41	0.24	0.00	0.00	71%	0.00	0.00	71%	0.01	0.01	0	0	6.20	1.40	0.24	0.00	0.00
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Data Centers	2020	2054	1.07	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.07	0.19	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Data Centers Data Centers	2020 2020	2054 2054	0.77 1.36	0.13 0.24	0.30 0.00	0.30	28% 0%	0.05 0.00	0.05	28% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	0.89 N/A	1.36	0.24	0.00	0.00
VA	1730	1730 Base CFL 23W to screw-in replacement (base CFL 23W) 2020	Data Centers	2020	2054	1.01	0.24	0.00	0.00	26%	0.06	0.06	26%	0.05	0.05	0	0	1.18	1.30	0.24	0.00	0.06
VA	1800	1800 BaseMetal Halide, 465W	Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Data Centers Data Centers	2014 2014	2054 2054	0.27	0.05	0.00 0.12	0.00 0.12	0% 44%	0.00 0.02	0.00	0% 44%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.90	0.27	0.05	0.00 0.12	0.00 0.02
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Data Centers		2054	4.01	0.03	0.00	0.00	0%	0.02	0.02	0%	N/A	N/A	N/A	N/A	N/A	4.01	0.04	0.00	0.02
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Data Centers		2054	3.65	0.04	0.36	0.36	9%	0.01	0.01	18%	0.02	0.02	1	1	2.71			0.36	0.01
VA VA	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Data Centers Data Centers	2014 2014	2054 2054	1.76 1.25	0.02	1.89 0.50	2.25 2.75	56% 69%	0.02 0.01	0.03	65% 77%	0.10 0.67	0.09 0.19	9 65	7 16	0.59 0.09			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Data Centers	2014	2054	44.99	11.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	44.99	11.07	0.00	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Data Centers	2014	2054	44.79	11.02	0.20	0.20	0%	0.05	0.05	0%	0.00	0.00	0	0	30.81			0.20	0.05
VA VA	2000	2005 Chiller Tune Up/Diagnostics 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Data Centers Data Centers		2054 2054	44.77 40.94	11.02	0.02 3.82	0.22 4.05	0% 9%	0.00	0.05	0% 9%	0.01	0.00	0	0	7.88 7.01			0.02 3.82	0.00
VA	2000	2006 VSD for Chiller Pumps and Towers	Data Centers		2054	40.66	10.05	0.29	4.33	10%	0.03	1.03	9%	0.01	0.01	0	0	5.10			0.29	0.03
VA	2000	2013 High Efficiency Chiller Motors	Data Centers	2014	2054	40.58	10.03	0.07	4.41	10%	0.02	1.04	9%	0.02	0.01	0	0	4.55			0.07	0.02
VA VA	2000 2000	2003 EMS - Chiller 2008 New Economizer - Chiller	Data Centers Data Centers		2054 2054	39.54 36.69	9.97 9.81	1.04 2.85	5.45 8.30	12% 18%	0.06 0.16	1.10 1.26	10% 11%	0.02 0.02	0.01 0.01	0	0	3.41 2.68			1.04 2.85	0.06 0.16
VA	2000	2002 Window Film (Standard) - Chiller	Data Centers		2054	36.67	9.81	0.01	8.32	18%	0.00	1.27	11%	0.02	0.01	0	0	1.82			0.01	0.00
VA	2000	2012 Duct Testing/Sealing - Chiller	Data Centers		2054	29.71	8.09	6.97	15.28	34%	1.72	2.98	27%	0.06	0.04	0	0	1.28			6.97	1.72
VA VA	2000 2000	2004 Cool Roof - Chiller 2011 Duct/Pipe Insulation - Chiller	Data Centers Data Centers	2014	2054 2054	29.61 29.52	8.07 8.05	0.09	15.38 15.47	34% 34%	0.02 0.02	3.00 3.03	27% 27%	0.09	0.04 0.04	0	0	0.73 0.09			0.00	0.00
VA	2100		Data Centers	2014	2054	25.66	6.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	25.66	6.32	0.00	0.00
VA	2100		Data Centers		2054	19.76	4.86	5.90	5.90	23%	1.45	1.45	23%	0.01	0.01	0	0	7.48			5.90	1.45
VA VA	2100 2100	2111 Economizer Repair - DX 2108 Optimize Controls - DX	Data Centers Data Centers	2014 2014	2054 2054	19.33 18.97	4.68 4.66	0.43	6.33 6.69	25% 26%	0.19 0.02	1.64 1.66	26% 26%	0.03 0.02	0.01 0.01	0	0	2.39 2.29			0.43 0.36	0.19 0.02
VA	2100	2109 Economizer - DX	Data Centers		2054	16.67	4.53	2.29	8.98	35%	0.13	1.79	28%	0.03	0.02	0	Ö	1.94			2.29	0.13
VA VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Data Centers	2014	2054	16.67	4.53 4.44	0.01	8.99 9.33	35% 36%	0.00	1.79 1.87	28% 30%	0.04	0.02	0	0	1.55 1.41			0.01	0.00
VA	2100 2100		Data Centers Data Centers	2014 2014	2054 2054	16.32 15.52	4.44	0.34	10.14	40%	0.08 0.05	1.87	30%	0.05 0.04	0.02 0.02	1	0	1.41			0.34	0.08
VA	2100	2112 Duct Testing/Sealing - DX	Data Centers	2014	2054	14.58	4.16	0.94	11.08	43%	0.23	2.15	34%	0.08	0.02	0	0	0.95			0.00	0.00
VA VA	2100 2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2107 Cool Roof - DX	Data Centers Data Centers		2054	14.58 14.45	4.16 4.13	0.00	11.08 11.21	43% 44%	0.00	2.15 2.18	34% 35%	0.08	0.02	1	0	0.68			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Data Centers		2054	14.45	4.13	0.12	11.30	44%	0.03	2.10	35%	0.10	0.02	4	0	0.02			0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Data Centers	2014	2054	3.29	0.81	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.29	0.81	0.00	0.00
VA VA	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Data Centers Data Centers	2014 2014	2054 2054	2.88	0.71	0.41 0.00	0.41 0.00	12% 0%	0.10 0.00	0.10 0.00	12% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	10.48 N/A	0.00	0.00	0.41 0.00	0.10 0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Data Centers		2054	6.59	1.62	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.59	1.62	0.00	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	Data Centers	2014	2054	5.97	1.58	0.61	0.61	9%	0.04	0.04	2%	0.01	0.01	0	0	8.33			0.61	0.04
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	Data Centers Data Centers	2014 2014	2054 2054	5.88 5.54	1.56 1.41	0.10 0.34	0.71 1.05	11% 16%	0.02 0.15	0.06 0.21	4% 13%	0.01 0.30	0.01 0.10	0	0	6.25 0.30			0.10 0.00	0.02
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Data Centers		2054	22.89	5.63	0.00	0.00	0%	0.00	0.00	0%	0.30 N/A	N/A	N/A	N/A	N/A	22.89	5.63	0.00	0.00
VA	3100	3102 Variable Speed Drive Control, 15 HP	Data Centers		2054	20.77	5.50	2.12	2.12	9%	0.13	0.13	2%	0.00	0.00	0	0	30.15			2.12	0.13
VA VA	3100 3100		Data Centers Data Centers	2014 2014	2054 2054	20.64 19.29	5.47 5.17	0.12 1.35	2.25 3.60	10% 16%	0.03	0.16 0.47	3% 8%	0.01 0.01	0.00 0.01	0	0	13.77 6.06			0.12 1.35	0.03
VA	3100	3103 Air Handler Optimization, 15 HP	Data Centers	2014	2054	17.47	5.06	1.82	5.42	24%	0.11	0.58	10%	0.01	0.01	0	0	4.79			1.82	0.11
VA	3100	3105 Energy Recovery Ventilation (ERV)	Data Centers		2054	17.04	4.86	0.43	5.85	26%	0.19	0.77	14%	0.11	0.02	0	0	0.85			0.00	0.00
VA VA	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Data Centers Data Centers		2054 2054	16.06 24.32	4.43 5.99	0.98	6.83	30% 0%	0.44	1.21	21% 0%	0.36 N/A	0.06 N/A	1 N/A	0 N/A	0.25 N/A	24.32	5.99	0.00	0.00
VA	3200	3202 Variable Speed Drive Control, 40 HP	Data Centers	2014	2054	22.06	5.85	2.26	2.26	9%	0.14	0.14	2%	0.01	0.01	0	0	5.99	24.02	5.55	2.26	0.14
VA	3200	3203 Air Handler Optimization, 40 HP	Data Centers	2014	2054	19.98	5.72	2.08	4.34	18%	0.13	0.27	5%	0.01	0.01	0	0	5.15			2.08	0.13
VA VA	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Data Centers Data Centers		2054 2054	19.89 18.75	5.69 5.19	0.09	4.43 5.57	18% 23%	0.02	0.29	5% 13%	0.05 0.32	0.01	0	0	1.55 0.28			0.09	0.02
VA	4000	4000 Base Built-Up Refrigeration System	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA	4100		Data Centers	2014	2054	3.64	0.68	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.64	0.68	0.00	0.00
VA VA	4100 4100		Data Centers Data Centers	2014 2014	2054 2054	3.64 3.57	0.68 0.67	0.00 0.07	0.00 0.07	0% 2%	0.00 0.01	0.00 0.01	0% 2%	0.00	0.00	0	0	27.20 26.09			0.00 0.07	0.00 0.01
VA	4100		Data Centers	2014	2054	3.57	0.67	0.00	0.07	2%	0.00	0.01	2%	0.01	0.00	0	0	10.90			0.00	0.00
VA	4100	4108 Energy-Star Refrigerator, glass door	Data Centers Data Centers	2014	2054 2054	3.57	0.67	0.00	0.07	2%	0.00	0.01	2%	0.01	0.00	0	0	9.19			0.00	0.00
VA VA	4100 4100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Data Centers Data Centers		2054 2054	3.57 3.57	0.67 0.67	0.00	0.07	2% 2%	0.00	0.01 0.01	2% 2%	0.01	0.00	0	0	8.80 3.27			0.00	0.00
• • • • • • • • • • • • • • • • • • • •	00	=		20.7	2001	0.0.	0.01	0.00	0.00	270	0.00	0.0.	-70	0.02	0.00	•		0.2.			0.00	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS												SUPPLY								
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Samt	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic
VA	4100	4112 Reach-in unit occupancy sensors	Data Centers	2014	2054	3.56	0.67	0.00	0.08	2%	0.00	0.01	2%	0.27	0.00	1	0	0.23	01111		0.00	0.00
VA VA	4100 5000	4105 Bi-level LED Case Lighting (self-contained units) 2014 5000 Base Desktop PC	Data Centers Data Centers	2014 2014	2054 2054	3.56 0.48	0.67 0.08	0.00	0.08	2% 0%	0.00	0.01 0.00	2% 0%	0.30 N/A	0.00 N/A	2 N/A	0 N/A	0.19 N/A	0.48	0.08	0.00	0.00
VA	5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Data Centers	2014	2054	0.46	0.06	0.00	0.00	44%	0.00	0.00	23%	0.01	0.01	0	0	3.54	0.46	0.08	0.00	0.00
VA	5000	5002 Energy Star or Better PC	Data Centers	2014	2054	0.21	0.05	0.06	0.27	56%	0.01	0.03	35%	0.03	0.02	0	0	1.96			0.06	0.01
VA VA	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Data Centers Data Centers	2014	2054	0.03	0.01	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.13	0.03	0.01	0.00 0.01	0.00
VA	5100	5102 Energy Star of Better Laptop 5101 Laptop Network Power Management Enabling	Data Centers	2014	2054	0.03	0.00	0.00	0.01	21%	0.00	0.00	21%	1.24	0.11	7	1	0.04			0.00	0.00
VA	5200	5200 Base Monitor, CRT	Data Centers	2014	2054	0.26	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.26	0.05	0.00	0.00
VA VA	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Data Centers Data Centers	2014 2014	2054 2054	0.15 0.13	0.03	0.11 0.02	0.11 0.13	43% 50%	0.02	0.02 0.02	43% 46%	0.00 0.01	0.00	0	0	53.39 4.12			0.11 0.02	0.02
VA	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Data Centers	2014	2054	0.12	0.02	0.01	0.14	54%	0.00	0.02	50%	0.14	0.01	1	0	0.38			0.00	0.00
VA VA	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Data Centers Data Centers	2014	2054 2054	0.13	0.02	0.00	0.00 0.02	0% 13%	0.00	0.00	0% 13%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.34	0.13	0.02	0.00 0.02	0.00
VA	5300	5302 Monitor Power Management Enabling - LCD	Data Centers	2014	2054	0.10	0.02	0.02	0.02	19%	0.00	0.00	16%	0.01	0.01	1	0	0.58			0.02	0.00
VA	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Data Centers	2014	2054	0.09	0.02	0.01	0.03	25%	0.00	0.00	18%	0.24	0.08	5	1	0.18			0.00	0.00
VA VA	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Data Centers Data Centers	2014	2054	0.11	0.02	0.00	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 31.22	0.11	0.02	0.00	0.00
VA	5400	5402 Copier Power Management Enabling	Data Centers	2014	2054	0.09	0.02	0.00	0.01	14%	0.00	0.00	12%	0.00	0.00	1	0	0.53			0.00	0.00
VA	5500	5500 Base Multifunction	Data Centers	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
VA VA	5500 5500	5502 ENERGY STAR Multi-Function Printer 5501 Multifunction Power Management Enabling	Data Centers Data Centers	2014 2014	2054 2054	0.01	0.00	0.00	0.00 0.01	25% 38%	0.00	0.00	25% 32%	0.01 0.28	0.01 0.10	0	0	8.55 0.18			0.00	0.00
VA	5600	5600 Base Printer	Data Centers	2014	2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
VA	5600	5602 ENERGY STAR Printer	Data Centers	2014	2054	0.03	0.00	0.01	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	39.32			0.01	0.00
VA VA	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Data Centers Data Centers	2014 2014	2054 2054	0.02 762.71	0.00 132.70	0.00	0.02	46% 0%	0.00	0.00	41% 0%	0.06 N/A	0.02 N/A	N/A	0 N/A	0.82 N/A	762.71	132.70	0.00	0.00
VA	5700	5701 Data Center Improved Operations	Data Centers	2014	2054	686.44	119.43	76.27	76.27	10%	13.27	13.27	10%	0.00	0.00	0	0	109.14			76.27	13.27
VA VA	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Data Centers Data Centers	2014 2014	2054 2054	599.11 565.56	104.24 98.40	87.33 33.55	163.60 197.15	21% 26%	15.19 5.84	28.46 34.30	21% 26%	0.00	0.00	0	0	44.43 23.04			87.33 33.55	15.19 5.84
VA	6000	6000 Base Water Heating	Data Centers	2014	2054	0.38	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.38	0.07	0.00	0.00
VA	6000	6007 Heat Trap	Data Centers	2014	2054	0.36	0.06	0.02	0.02	5%	0.00	0.00	5%	0.08	0.08	0	0	0.79			0.00	0.00
VA VA	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Data Centers Data Centers	2014 2014	2054 2054	0.36	0.06	0.01 0.03	0.03 0.05	7% 14%	0.00	0.00 0.01	7% 14%	0.16 0.24	0.10 0.17	1	1	0.42			0.00	0.00
VA	6000	6008 Solar Water Heater	Data Centers	2014	2054	0.15	0.03	0.18	0.23	60%	0.03	0.04	60%	0.28	0.26	2	1	0.26			0.00	0.00
VA	6000	6006 Heat Recovery Unit	Data Centers	2014	2054	0.14	0.03	0.01	0.24	62%	0.00	0.04	62%	0.62	0.27	4	2	0.10			0.00	0.00
VA VA	6000 7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Data Centers Data Centers	2014 2014	2054 2054	0.14 0.25	0.02	0.00	0.24	64% 0%	0.00	0.04	64% 0%	1.87 N/A	0.30 N/A	11 N/A	2 N/A	0.04 N/A	0.25	0.04	0.00	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	Data Centers	2014	2054	0.21	0.04	0.04	0.04	16%	0.00	0.00	8%	0.01	0.01	0	0	5.44			0.04	0.00
VA VA	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Data Centers Data Centers	2014 2014	2054 2054	0.19 0.01	0.04	0.02	0.06	24% 0%	0.00	0.01 0.00	12% 0%	0.02 N/A	0.01 N/A	0 N/A	0 N/A	3.00 N/A	0.01	0.00	0.02 0.00	0.00
VA	7100	7100 Base Non-Refrigerated veriding Macrimes 7101 Vending Misers (Non-Refrigerated)	Data Centers	2014	2054	0.01	0.00	0.00	0.00	44%	0.00	0.00	23%	0.12	0.12	1	1	0.41	0.01	0.00	0.00	0.00
VA	7200	7200 Base Oven	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	7300 7400	7300 Base Fryer 7400 Base Steamer	Data Centers Data Centers	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
VA	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	8100 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	Data Centers	2014 2014	2054 2054	0.42	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A	0.42	0.00	0.00	0.00
VA	9500	9500 Base Miscellaneous 9501 Xmisc	Data Centers Data Centers		2054	3.84 3.84	0.67	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	3.84	0.67	0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	eligious Worsh		2054	69.16	11.74	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	69.16	11.74	0.00	0.00
VA VA	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1036 Lighting Control Tuneup (base 4L4'T8), 2020	eligious Worsh eligious Worsh	2020 2020	2054 2054	62.00 61.68	10.52 10.50	7.17 0.32	7.17 7.49	10% 11%	1.22 0.03	1.22 1.24	10% 11%	0.04 0.05	0.04 0.04	0	0	1.48 1.06			7.17 0.32	1.22 0.03
VA	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	eligious Worsh		2054	57.00	9.87	4.67	12.16	18%	0.63	1.87	16%	0.03	0.04	1	0	0.93			0.00	0.00
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	eligious Worsh		2054	49.75	8.64	7.25	19.41	28%	1.23	3.10	26%	0.09	0.07	1	0	0.65			0.00	0.00
VA VA	1030 1030	1034 ROB 4L4' LED Tube, 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	eligious Worsh eligious Worsh		2054 2054	41.74 40.62	7.28 7.23	8.02 1.11	27.43 28.54	40% 41%	1.36 0.05	4.46 4.51	38% 38%	0.58 0.28	0.22 0.22	3 7	1	0.12			0.00	0.00
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	eligious Worsh	2020	2054	37.16	6.64	3.47	32.01	46%	0.59	5.10	43%	0.49	0.25	3	2	0.14			0.00	0.00
VA	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	eligious Worsh		2054	52.96 47.96	8.99 8.14	0.00	0.00	0% 9%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	52.96	8.99	0.00	0.00
VA VA	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	eligious Worsh eligious Worsh		2054 2054	47.71	8.14	5.00 0.25	5.00 5.25	10%	0.85 0.02	0.85 0.87	9% 10%	0.05 0.05	0.05 0.05	0 1	0	1.18 0.87			5.00 0.00	0.85 0.00
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	eligious Worsh	2020	2054	44.09	7.63	3.61	8.87	17%	0.49	1.36	15%	0.08	0.06	1	0	0.76			0.00	0.00
VA VA	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	eligious Worsh		2054	38.48 36.62	6.68 6.36	5.61 1.86	14.48 16.34	27% 31%	0.95 0.32	2.31 2.62	26% 29%	0.12 0.47	0.08 0.13	1	1	0.52 0.15			0.00	0.00
VA VA	1130	1134 ROB 2L4 LED Tube, 2020 1135 LED Troffer (base 2L4 T8), 2020	eligious Worsh eligious Worsh		2054	36.62	5.83	3.13	16.34 19.46	31% 37%	0.32	3.15	29% 35%	0.47	0.13	3	1	0.15			0.00	0.00
VA	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	eligious Worsh	2020	2054	32.60	5.80	0.89	20.36	38%	0.04	3.19	35%	0.47	0.21	12	1	0.10			0.00	0.00
VA VA	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	eligious Worsh eligious Worsh		2054 2054	0.72	0.12	0.00	0.00	0% 3%	0.00	0.00	0% 2%	N/A 0.03	N/A 0.03	N/A 0	N/A	N/A 1.51	0.72	0.12	0.00	0.00
VA	1200	1203 Eighting Control Tuneup (base other fluorescent fixture) 1201 ROB High Performance T8 (base other fluorescent)	eligious Worsh		2054	0.70	0.12	0.02	0.02	10%	0.00	0.00	2% 9%	0.03	0.03	1	1	0.36			0.02	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	eligious Worsh	2014	2054	0.57	0.10	0.08	0.16	22%	0.01	0.02	20%	0.35	0.24	2	2	0.17			0.00	0.00
VA VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	eligious Worsh eligious Worsh		2054 2054	0.52 0.48	0.09	0.04 0.04	0.20 0.24	28% 33%	0.01 0.00	0.03	25% 26%	0.36 0.31	0.27 0.27	3 8	2	0.17 0.16			0.00	0.00
VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	eligious Worsh		2054	27.77	4.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	27.77	4.71	0.00	0.00
VA VA	1330 1430	1332 LEDs (base incandescent flood) 2020	eligious Worsh		2054 2054	4.96 10.00	0.84 1.70	22.81	22.81	82% 0%	3.87	3.87 0.00	82% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	5.10 N/A	10.00	1.70	22.81	3.87 0.00
VA VA	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	eligious Worsh eligious Worsh		2054	10.00	0.33	0.00 8.06	8.06	0% 81%	1.37	1.37	0% 81%	N/A 0.01	0.01	N/A 0	N/A 0	N/A 4.30	10.00	1.70	8.06	1.37
	00															-	-					

APPENDIX H

Base Avoided Costs

		ric Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint				Manager	Measure				Total	Percent		Total	Percent	Marginal	Average	Marginal	Average					
	Base	Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Cost Test	Base	Base	Economic	Economic
Sgm VA	t Number 1530	Number Measure 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Type eligious Worsh	Year 2020	Year 2054	7.36	MW 1.25	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	7.36	MW 1.25	GWH 0.00	0.00
VA	1530	1530 Base incandescent A-Line Lamp, 55W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	eligious Worsh		2054	1.96	0.33	5.40	5.40	73%	0.00	0.92	73%	0.02	0.02	0	0	3.19	7.30	1.25	5.40	0.00
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	eligious Worsh		2054	4.14	0.70	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.14	0.70	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	eligious Worsh eligious Worsh		2054 2054	2.99 5.29	0.51 0.90	1.15 0.00	1.15 0.00	28% 0%	0.19 0.00	0.19 0.00	28% 0%	0.13 N/A	0.13 N/A	1 N/A	1 N/A	0.50 N/A	5.29	0.90	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	eligious Worsh		2054	3.92	0.66	1.38	1.38	26%	0.23	0.23	26%	0.09	0.09	1	1	0.66			0.00	0.00
VA VA	1800 1800	1800 BaseMetal Halide, 465W 1801 T5 (240W) (base metal halide)	eligious Worsh eligious Worsh		2054 2054	3.51 2.33	0.60	0.00	0.00	0% 34%	0.00	0.00 0.20	0% 34%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.43	3.51	0.60	0.00 1.19	0.00
VA	1800	1806 Occupancy Sensor, High Bay T5	eligious Worsh		2054	2.25	0.39	0.08	1.26	36%	0.00	0.20	34%	0.08	0.03	2	0	0.64			0.00	0.00
VA VA	1800 1850	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1850 Base CFL Exit Sign	eligious Worsh eligious Worsh		2054 2054	2.08	0.37	0.17	1.43	41% 0%	0.02	0.23	38% 0%	0.14 N/A	0.04 N/A	1 N/A	0 N/A	0.44 N/A	2.02	0.34	0.00	0.00
VA	1850	1851 LED Exit Sign	eligious Worsh		2054	1.09	0.34	0.00	0.00	46%	0.00	0.16	46%	0.05	0.05	0	0	1.01	2.02	0.34	0.00	0.16
VA VA	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	eligious Worsh		2054	25.23	1.95	0.00 0.48	0.00	0% 2%	0.00	0.00	0% 5%	N/A 0.07	N/A 0.07	N/A	N/A 0	N/A 1.19	25.23	1.95	0.00 0.48	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	eligious Worsh eligious Worsh		2054 2054	24.75 11.91	1.85 0.85	12.84	13.32	2% 53%	0.11	1.10	5% 56%	0.07	0.07	0 2	2	0.37			0.48	0.11
VA	1900	1903 Bi-Level LED Outdoor Lighting	eligious Worsh	2014	2054	8.43	0.61	3.48	16.80	67%	0.24	1.34	69%	1.07	0.35	15	4	0.06			0.00	0.00
VA VA	2000 2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2010 Ceiling/roof Insulation - Chiller	eligious Worsh eligious Worsh		2054 2054	30.08 29.71	23.26 22.97	0.00 0.38	0.00	0% 1%	0.00 0.29	0.00 0.29	0% 1%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 3.00	30.08	23.26	0.00 0.38	0.00 0.29
VA	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	eligious Worsh	2014	2054	27.17	21.01	2.54	2.91	10%	1.96	2.25	10%	0.08	0.07	0	0	1.54			2.54	1.96
VA VA	2000 2000	2005 Chiller Tune Up/Diagnostics 2013 High Efficiency Chiller Motors	eligious Worsh eligious Worsh		2054 2054	27.15 27.13	21.00 20.99	0.02 0.02	2.93 2.95	10% 10%	0.01 0.02	2.26 2.28	10% 10%	0.06 0.12	0.07 0.07	0	0	1.19 0.99			0.02 0.00	0.01 0.00
VA	2000	2006 VSD for Chiller Pumps and Towers	eligious Worsh		2054	26.07	20.57	1.05	4.01	13%	0.02	2.20	12%	0.12	0.07	0	0	0.99			0.00	0.00
VA	2000	2003 EMS - Chiller	eligious Worsh		2054	24.82	20.32	1.25	5.26	17%	0.25	2.94	13%	0.14	0.09	1	0	0.47			0.00	0.00
VA VA	2000 2000	2012 Duct Testing/Sealing - Chiller 2002 Window Film (Standard) - Chiller	eligious Worsh eligious Worsh		2054 2054	20.26	16.79 16.69	4.56 0.13	9.83 9.95	33% 33%	3.53 0.10	6.47 6.57	28% 28%	0.40 1.45	0.24 0.25	1 2	0	0.29 0.06			0.00	0.00
VA	2000	2004 Cool Roof - Chiller	eligious Worsh	2014	2054	20.09	16.66	0.04	9.99	33%	0.03	6.60	28%	6.31	0.28	8	0	0.01			0.00	0.00
VA VA	2000	2011 Duct/Pipe Insulation - Chiller 2008 New Economizer - Chiller	eligious Worsh eligious Worsh		2054 2054	19.82 19.82	16.46 16.46	0.27	10.26 10.26	34% 34%	0.21	6.81 6.81	29% 29%	7.61 70236.15	0.47 0.59	10 354,039	1	0.01			0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	eligious Worsh		2054	96.90	74.94	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	96.90	74.94	0.00	0.00
VA VA	2100 2100	2113 Ceiling/roof Insulation - DX	eligious Worsh eligious Worsh		2054 2054	96.90 74.61	74.94 57.70	0.00 22.29	0.00 22.29	0% 23%	0.00 17.24	0.00 17.24	0% 23%	0.04 0.07	0.04 0.07	0	0	3.08 1.63			0.00 22.29	0.00 17.24
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons 2105 DX Tune Up/ Advanced Diagnostics	eligious Worsh		2054	74.51	57.70	0.03	22.29	23%	0.01	17.24	23%	0.07	0.07	1	0	0.31			0.00	0.00
VA	2100	2112 Duct Testing/Sealing - DX	eligious Worsh		2054	70.19	54.30	4.39	26.71	28%	3.39	20.64	28%	0.43	0.13	1	0	0.27			0.00	0.00
VA VA	2100 2100	2106 Prog. Thermostat - DX 2108 Optimize Controls - DX	eligious Worsh eligious Worsh		2054 2054	68.60 67.46	53.98 53.75	1.59 1.14	28.30 29.44	29% 30%	0.32 0.23	20.96 21.18	28% 28%	0.24 0.25	0.13	1	0	0.23 0.20			0.00	0.00
VA	2100	2115 Window Film (Standard) - DX	eligious Worsh	2014	2054	67.20	53.55	0.26	29.70	31%	0.20	21.39	29%	1.19	0.15	2	ō	0.08			0.00	0.00
VA VA	2100 2100	2107 Cool Roof - DX 2114 Duct/Pipe Insulation - DX	eligious Worsh eligious Worsh		2054 2054	67.07 66.64	53.45 53.12	0.13 0.43	29.83 30.26	31% 31%	0.10 0.33	21.49 21.82	29% 29%	6.09 7.28	0.17 0.27	8	0	0.02 0.01			0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	eligious Worsh		2054	78.85	60.98	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	78.85	60.98	0.00	0.00
VA VA	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	eligious Worsh eligious Worsh		2054 2054	69.10 78.27	53.44 60.53	9.75 0.00	9.75 0.00	12% 0%	7.54 0.00	7.54 0.00	12% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.52 N/A	70.07	60.53	9.75 0.00	7.54 0.00
VA	2300	2301 HE PTAC, EER=9.6, 1 ton	eligious Worsh		2054	67.67	52.33	10.60	10.60	14%	8.20	8.20	14%	0.16	0.16	0	0	0.66	78.27	60.53	0.00	0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	eligious Worsh		2054	72.92	20.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	72.92	20.72	0.00	0.00
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP	eligious Worsh eligious Worsh		2054 2054	71.66 50.40	20.36 18.85	1.26 21.26	1.26 22.52	2% 31%	0.36 1.51	0.36 1.86	2% 9%	0.13 0.10	0.13 0.10	0 1	0 1	0.63 0.59			0.00	0.00
VA	3000	3003 Demand Controlled Ventilation	eligious Worsh		2054	49.42	18.32	0.98	23.50	32%	0.54	2.40	12%	3.09	0.22	6	2	0.03			0.00	0.00
VA VA	3100 3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	eligious Worsh eligious Worsh		2054 2054	58.13 49.74	16.52 14.37	0.00 8.39	0.00 8.39	0% 14%	0.00 2.14	0.00 2.14	0% 13%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.20	58.13	16.52	0.00 8.39	0.00 2.14
VA	3100	3103 Air Handler Optimization, 15 HP	eligious Worsh		2054	46.33	14.13	3.41	11.80	20%	0.24	2.38	14%	0.08	0.07	1	0	0.63			0.00	0.00
VA VA	3100 3100	3102 Variable Speed Drive Control, 15 HP 3101 Fan Motor, 15hp, 1800rpm, 92.4%	eligious Worsh eligious Worsh		2054 2054	32.59 32.10	13.16 13.02	13.75 0.49	25.54 26.03	44% 45%	0.97 0.14	3.36 3.49	20% 21%	0.13 0.42	0.10 0.11	2	1	0.43			0.00	0.00
VA	3100	3105 Energy Recovery Ventilation (ERV)	eligious Worsh		2054	31.69	12.80	0.49	26.44	45%	0.14	3.49	23%	0.42	0.11	2	1	0.19			0.00	0.00
VA	3100	3107 Demand Controlled Ventilation	eligious Worsh		2054	31.07	12.46	0.62	27.06	47%	0.34	4.06	25%	3.92	0.21	7	1	0.02			0.00	0.00
VA VA	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	eligious Worsh eligious Worsh		2054 2054	46.13 42.97	13.11 12.88	0.00 3.16	0.00 3.16	0% 7%	0.00 0.22	0.00 0.22	0% 2%	N/A 0.07	N/A 0.07	N/A 1	N/A 1	N/A 0.74	46.13	13.11	0.00	0.00
VA	3200	3202 Variable Speed Drive Control, 40 HP	eligious Worsh	2014	2054	30.22	11.98	12.75	15.91	34%	0.90	1.13	9%	0.21	0.18	3	3	0.28			0.00	0.00
VA VA	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	eligious Worsh eligious Worsh		2054 2054	30.10 29.51	11.94 11.62	0.12 0.59	16.03 16.62	35% 36%	0.03 0.32	1.16 1.48	9% 11%	1.02 3.28	0.19 0.29	4 6	3	0.08			0.00	0.00
VA	4000	4000 Base Built-Up Refrigeration System	eligious Worsh		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	eligious Worsh	2014	2054	98.51	14.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	98.51	14.83	0.00	0.00
VA VA	4100 4100	4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Gaskets (self-contained)	eligious Worsh eligious Worsh		2054 2054	97.55 96.17	14.69 14.48	0.95 1.39	0.95 2.34	1% 2%	0.14 0.21	0.14 0.35	1% 2%	0.00	0.00	0	0	18.19 17.61			0.95 1.39	0.14 0.21
VA	4100	4108 Energy-Star Refrigerator, glass door	eligious Worsh	2014	2054	95.55	14.38	0.62	2.96	3%	0.09	0.45	3%	0.01	0.00	0	ō	5.68			0.62	0.09
VA VA	4100 4100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	eligious Worsh eligious Worsh		2054 2054	93.94 91.85	14.14 13.83	1.60 2.09	4.56 6.65	5% 7%	0.24	0.69 1.00	5% 7%	0.01	0.01	0	0	5.57 2.03			1.60 2.09	0.24
VA	4100	4112 Reach-in unit occupancy sensors	eligious Worsh	2014	2054	91.84	13.83	0.01	6.67	7%	0.00	1.00	7%	0.28	0.01	2	ō	0.20			0.00	0.00
VA VA	4100 5000	4105 Bi-level LED Case Lighting (self-contained units) 2014 5000 Base Desktop PC	eligious Worsh eligious Worsh		2054 2054	91.76 9.54	13.81 1.44	0.08	6.75 0.00	7% 0%	0.01	1.02 0.00	7% 0%	0.32 N/A	0.02 N/A	2 N/A	0 N/A	0.17 N/A	9.54	1.44	0.00	0.00
VA	5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	eligious Worsh		2054	5.24	1.44	4.30	4.30	45%	0.33	0.00	23%	0.02	0.02	0	0	1.95	5.34	1.44	4.30	0.00
VA VA	5000 5100	5002 Energy Star or Better PC	eligious Worsh		2054 2054	3.61 0.66	0.87	1.63	5.93	62% 0%	0.25	0.58	40% 0%	0.05 N/A	0.03 N/A	0 N/A	0 N/A	0.99 N/A	0.60	0.10	0.00	0.00
VA	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	eligious Worsh eligious Worsh		2054	0.66	0.10	0.00	0.00	19%	0.00	0.00	19%	N/A 0.02	0.02	N/A 0	N/A 0	N/A 2.72	0.66	0.10	0.00	0.00
VA	5100	5101 Laptop Network Power Management Enabling	eligious Worsh	2014	2054	0.52	0.08	0.01	0.13	21%	0.00	0.02	21%	2.25	0.20	15	1	0.02			0.00	0.00
VA	5200	5200 Base Monitor, CRT	eligious Worsh	2014	2054	1.67	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.67	0.25	0.00	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Moscure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average	Marginal Capacity	Average Capacity					
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Energy Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm: VA	Number 5200	Number Measure 5201 Energy Star or Better Monitor - CRT	Type eligious Worsh	Year 2014	Year 2054	0.73	MW 0.11	Savings 0.94	0.94	Savings 56%	Savings 0.14	0.14	Savings 56%	\$/kWH 0.00	\$/kWH 0.00	\$/kW 0	\$/kW	21.63	GWH	MW	GWH 0.94	0.14
VA	5200	5201 Energy Star of Better Monitor - CR1 5202 Monitor Power Management Enabling - CRT	eligious Worsh		2054	0.75	0.11	0.19	1.12	67%	0.14	0.14	62%	0.00	0.00	0	0	1.41			0.94	0.14
VA	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	eligious Worsh	2014	2054	0.51	0.09	0.04	1.17	70%	0.01	0.16	64%	0.39	0.02	3	0	0.13			0.00	0.00
VA VA	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	eligious Worsh eligious Worsh		2054 2054	1.99 1.63	0.30 0.25	0.00 0.36	0.00 0.36	0% 18%	0.00 0.05	0.00 0.05	0% 18%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.17	1.99	0.30	0.00 0.36	0.00 0.05
VA	5300	5302 Monitor Power Management Enabling - LCD	eligious Worsh		2054	1.57	0.24	0.06	0.41	21%	0.00	0.06	19%	0.02	0.02	2	0	0.32			0.00	0.00
VA	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	eligious Worsh		2054	1.45	0.24	0.12	0.53	27%	0.00	0.06	21%	0.42	0.12	11	1	0.10			0.00	0.00
VA VA	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	eligious Worsh eligious Worsh		2054 2054	3.87 3.35	0.59 0.51	0.00 0.52	0.00 0.52	0% 13%	0.00	0.00 0.08	0% 13%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 15.93	3.87	0.59	0.00 0.52	0.00
VA	5400	5402 Copier Power Management Enabling	eligious Worsh		2054	3.19	0.49	0.17	0.68	18%	0.00	0.00	16%	0.00	0.04	2	0	0.28			0.00	0.00
VA	5500	5500 Base Multifunction	eligious Worsh	2014	2054	0.51	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.51	0.08	0.00	0.00
VA VA	5500 5500	5502 ENERGY STAR Multi-Function Printer 5501 Multifunction Power Management Enabling	eligious Worsh eligious Worsh		2054 2054	0.38	0.06	0.13 0.06	0.13 0.19	25% 37%	0.02	0.02 0.02	25% 31%	0.01 0.47	0.01 0.16	0 6	0	4.54 0.10			0.13 0.00	0.02
VA	5600	5600 Base Printer	eligious Worsh		2054	1.56	0.05	0.00	0.00	0%	0.00	0.02	0%	0.47 N/A	0.16 N/A	N/A	N/A	N/A	1.56	0.24	0.00	0.00
VA	5600	5602 ENERGY STAR Printer	eligious Worsh	2014	2054	1.02	0.15	0.54	0.54	35%	0.08	0.08	35%	0.00	0.00	0	0	20.86			0.54	0.08
VA VA	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	eligious Worsh eligious Worsh		2054 2054	0.85 8.06	0.14 1.22	0.17 0.00	0.71 0.00	45% 0%	0.01 0.00	0.10 0.00	40% 0%	0.10 N/A	0.03 N/A	1 N/A	0 N/A	0.46 N/A	8.06	1.22	0.00	0.00
VA	5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	eligious Worsh		2054	7.25	1.10	0.81	0.81	10%	0.00	0.12	10%	0.00	0.00	0	0	72.20	0.00	1.22	0.81	0.00
VA	5700	5702 Data Center Best Practices	eligious Worsh	2014	2054	6.33	0.96	0.92	1.73	21%	0.14	0.26	21%	0.00	0.00	0	0	29.39			0.92	0.14
VA	5700	5703 Data Center State of the Art practices	eligious Worsh		2054	5.97	0.90	0.35	2.08	26%	0.05	0.32	26%	0.00	0.00	0	0	15.24			0.35	0.05
VA VA	6000 6000	6000 Base Water Heating 6007 Heat Trap	eligious Worsh eligious Worsh		2054 2054	27.02 25.62	3.99	0.00 1.40	0.00 1.40	0% 5%	0.00	0.00	0% 5%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.99	27.02	3.99	0.00 1.40	0.00
VA	6000	6002 High Efficiency Water Heater (electric)	eligious Worsh		2054	25.11	3.71	0.51	1.91	7%	0.08	0.28	7%	0.06	0.04	ő	0	1.07			0.51	0.08
VA	6000	6004 Tankless Water Heater	eligious Worsh		2054	23.22	3.43	1.88	3.79	14%	0.28	0.56	14%	0.09	0.06	1	0	0.76			0.00	0.00
VA VA	6000 6000	6003 Hot Water Pipe Insulation 6006 Heat Recovery Unit	eligious Worsh eligious Worsh		2054 2054	22.78 22.04	3.36 3.25	0.44 0.74	4.24 4.98	16% 18%	0.07 0.11	0.63 0.73	16% 18%	0.11 0.10	0.07 0.07	1	0	0.59 0.55			0.00	0.00
VA	6000	6001 Demand controlled circulating systems	eligious Worsh		2054	21.21	3.13	0.74	5.80	21%	0.11	0.73	21%	0.10	0.07	2	1	0.55			0.00	0.00
VA	7000	7000 Base Refrigerated Vending Machines	eligious Worsh	2014	2054	4.50	0.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.50	0.75	0.00	0.00
VA	7000 7000	7001 Vending Misers (Refrigerated units)	eligious Worsh		2054	3.78	0.69	0.72	0.72	16% 25%	0.06	0.06	8%	0.03	0.03	0	0	1.82			0.72	0.06
VA VA	7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	eligious Worsh eligious Worsh		2054 2054	3.38	0.65	0.39 0.00	1.11 0.00	25% 0%	0.03	0.09	12% 0%	0.05 N/A	0.03 N/A	1 N/A	0 N/A	1.00 N/A	0.00	0.00	0.00	0.00
VA	7100	7101 Vending Misers (Non-Refrigerated)	eligious Worsh		2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	23%	0.44	0.44	5	5	0.11			0.00	0.00
VA	7200	7200 Base Oven	eligious Worsh	2014	2054	26.99	4.38	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	26.99	4.38	0.00	0.00
VA VA	7300 7300	7300 Base Fryer 7301 Efficient Fryer	eligious Worsh eligious Worsh		2054 2054	1.40 1.31	0.23	0.00	0.00	0% 6%	0.00 0.01	0.00 0.01	0% 6%	N/A 0.43	N/A 0.43	N/A 3	N/A 3	N/A 0.14	1.40	0.23	0.00	0.00
VA	7400	7400 Base Steamer	eligious Worsh		2054	1.23	0.20	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.23	0.20	0.00	0.00
VA	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	eligious Worsh		2054	2.39	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.39	0.00	0.00	0.00
VA VA	8000 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	eligious Worsh eligious Worsh		2054 2054	2.26 19.53	0.00	0.13 0.00	0.13	6% 0%	0.00	0.00	0% 0%	0.06 N/A	0.06 N/A	N/A N/A	N/A N/A	0.95 N/A	19.53	0.00	0.00	0.00
VA	9500	9500 Base Miscellaneous	eligious Worsh	2014	2054	333.79	55.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	333.79	55.49	0.00	0.00
VA	9500	9501 Xmisc	eligious Worsh	2014	2054	333.79	55.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Misc	2020	2054	414.67	70.38	0.00	0.00 2.15	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	414.67	70.38	0.00	0.00
VA VA	1030 1030	1036 Lighting Control Tuneup (base 4L4T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Misc Misc	2020 2020	2054 2054	412.52 381.28	70.20 66.00	2.15 31.25	33.40	1% 8%	0.18 4.20	0.18 4.38	0% 6%	0.01 0.02	0.01 0.02	0	0	3.68 3.22			2.15 31.25	4.20
VA	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Misc	2020	2054	341.77	59.29	39.50	72.90	18%	6.70	11.08	16%	0.02	0.02	ō	ō	2.74			39.50	6.70
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Misc	2020	2054	298.29	51.91	43.48	116.38	28%	7.38	18.46	26%	0.04	0.03	0	0	1.32			43.48	7.38
VA VA	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Misc Misc	2020 2020	2054 2054	290.34	51.59 43.65	7.94 46.78	124.33 171.11	30% 41%	0.33 7.94	18.79 26.73	27% 38%	0.08 0.25	0.03	2	0	0.64 0.25			0.00	0.00
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	Misc	2020	2054	222.77	40.12	20.79	191.90	46%	3.53	30.26	43%	0.20	0.10	1	1	0.30			0.00	0.00
VA	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Misc	2020	2054	317.53	53.89	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	317.53	53.89	0.00	0.00
VA VA	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Misc Misc	2020 2020	2054 2054	315.87 291.94	53.75 50.53	1.66 23.93	1.66 25.58	1% 8%	0.14 3.22	0.14 3.35	0% 6%	0.02 0.02	0.02 0.02	0	0	2.99 2.62			1.66 23.93	0.14 3.22
VA	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Misc	2020	2054	264.36	45.85	27.58	53.17	17%	4.68	8.03	15%	0.02	0.02	0	0	2.02			27.58	4.68
VA	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Misc	2020	2054	230.72	40.15	33.64	86.80	27%	5.71	13.74	26%	0.05	0.03	0	0	1.05			33.64	5.71
VA VA	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Misc Misc	2020 2020	2054 2054	219.57 200.83	38.25 35.07	11.15 18.74	97.95 116.70	31% 37%	1.89 3.18	15.64 18.82	29% 35%	0.19	0.05 0.08	1	0	0.32 0.26			0.00	0.00
VA VA	1130 1130	1135 LED Troffer (base 2L418), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Misc	2020	2054	195.48	35.07 34.85	18.74 5.35	116.70 122.05	37%	3.18 0.22	18.82 19.04	35% 35%	0.24	0.08	1 4	1	0.26			0.00	0.00
VA	1200	1200 Base Other Fluorescent Fixture	Misc	2014	2054	4.34	0.74	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.34	0.74	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Misc	2014	2054	4.20	0.72	0.14	0.14	3%	0.01	0.01	2%	0.01	0.01	0	0	4.71			0.14	0.01
VA VA	1200 1200	1201 ROB High Performance T8 (base other fluorescent) 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Misc Misc	2014 2014	2054 2054	3.88 3.59	0.67	0.32 0.29	0.45 0.75	10% 17%	0.05 0.04	0.07 0.10	9% 14%	0.07 0.10	0.06 0.07	0	0	0.74 0.62			0.00	0.00
VA	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Misc	2014	2054	3.33	0.62	0.26	1.01	23%	0.01	0.12	16%	0.09	0.08	2	1	0.56			0.00	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Misc	2014	2054	2.91	0.55	0.42	1.43	33%	0.07	0.19	25%	0.18	0.11	1	1	0.30			0.00	0.00
VA VA	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Misc Misc	2020 2020	2054 2054	261.09 57.45	44.31 9.75	0.00 203.64	0.00 203.64	0% 78%	0.00 34.56	0.00 34.56	0% 78%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 13.22	261.09	44.31	0.00 203.64	0.00 34.56
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Misc	2020	2054	93.99	15.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	93.99	15.95	0.00	0.00
VA	1430	1432 LEDs (base incandescent A-line 72W) 2020	Misc	2020	2054	22.39	3.80	71.61	71.61	76%	12.15	12.15	76%	0.00	0.00	0	0	11.10			71.61	12.15
VA VA	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Misc Misc	2020 2020	2054 2054	69.19 22.17	11.74 3.76	0.00 47.02	0.00 47.02	0% 68%	0.00 7.98	0.00 7.98	0% 68%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A	69.19	11.74	0.00 47.02	0.00 7.98
VA VA	1530 1630	1532 LEDs (base incandescent A-line 53W) 2020 1630 Base CFL 18W to screw-in replacement 2020	Misc	2020	2054	22.17 49.34	3.76 8.37	0.00	0.00	68% 0%	0.00	7.98 0.00	68% 0%	0.01 N/A	0.01 N/A	N/A	N/A	8.08 N/A	49.34	8.37	47.02 0.00	7.98 0.00
VA	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Misc	2020	2054	35.67	6.05	13.67	13.67	28%	2.32	2.32	28%	0.05	0.05	0	0	1.05			13.67	2.32
VA	1730	1730 Base CFL 23W to screw-in replacement 2020	Misc	2020	2054	63.05	10.70	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A	N/A	63.05	10.70	0.00	0.00
VA VA	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Misc Misc	2020	2054 2054	46.65 85.35	7.92 14.48	16.39 0.00	16.39 0.00	26% 0%	2.78	2.78	26% 0%	0.04 N/A	0.04 N/A	N/A	0 N/A	1.39 N/A	85.35	14.48	16.39	2.78
	. 500																					

DNV GL 1/5/2015 H-19

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Measure					Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm1 VA	Number 1800	Number Measure 1801 T5 (240W) (base metal halide)	Type Misc	Year 2014	Year 2054	GWH 56.49	MW 9.59	Savings 28.86	GWH 28.86	Savings 34%	Savings 4.90	MW 4.90	Savings 34%	\$/kWH 0.01	\$/kWH 0.01	\$/kW 0	\$/kW	7.55	GWH	MW	28.86	MW 4.90
VA	1800	1806 Occupancy Sensor, High Bay T5	Misc	2014	2054	54.65	9.51	1.85	30.70	36%	0.08	4.97	34%	0.01	0.01	1	0	2.00			1.85	0.08
VA	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Misc	2014	2054	50.51	8.96	4.14	34.84	41%	0.56	5.53	38%	0.05	0.01	0	0	1.38			4.14	0.56
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Misc Misc	2014 2014	2054 2054	9.40 5.06	1.60 0.86	0.00 4.34	0.00 4.34	0% 46%	0.00 0.74	0.00	0% 46%	N/A 0.03	N/A 0.03	N/A 0	N/A	N/A 1.95	9.40	1.60	0.00 4.34	0.00
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Misc	2014	2054	89.16	6.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	89.16	6.90	0.00	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Misc	2014	2054	81.36	5.16	7.80	7.80	9%	1.74	1.74	25%	0.04	0.04	0	0	2.12			7.80	1.74
VA VA	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Misc Misc	2014 2014	2054 2054	39.15 27.71	1.89 1.09	42.21 11.44	50.01 61.45	56% 69%	3.27 0.80	5.01 5.81	73% 84%	0.09 0.59	0.08 0.18	1 8	1 2	0.67 0.10			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Misc	2014	2054	81.13	62.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	81.13	62.75	0.00	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Misc	2014	2054	80.12	61.96	1.01	1.01	1%	0.78	0.78	1%	0.02	0.02	0	0	6.00			1.01	0.78
VA VA	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	Misc Misc	2014 2014	2054 2054	73.28 72.90	56.67 56.52	6.84 0.39	7.85 8.24	10% 10%	5.29 0.15	6.07 6.23	10% 10%	0.04	0.04	0	0	3.08 2.36			6.84 0.39	5.29 0.15
VA	2000	2013 High Efficiency Chiller Motors	Misc	2014	2054	72.83	56.47	0.06	8.30	10%	0.05	6.27	10%	0.06	0.04	0	o	1.98			0.06	0.05
VA	2000	2006 VSD for Chiller Pumps and Towers	Misc	2014	2054	70.00	55.36	2.83	11.13	14%	1.11	7.39	12%	0.05	0.04	0	0	1.70			2.83	1.11
VA VA	2000 2000	2003 EMS - Chiller 2012 Duct Testing/Sealing - Chiller	Misc Misc	2014 2014	2054 2054	63.83 52.10	54.13 45.06	6.17 11.73	17.30 29.04	21% 36%	1.22 9.07	8.61 17.69	14% 28%	0.07 0.21	0.05 0.12	0	0	0.90 0.55			0.00	0.00
VA	2000	2002 Window Film (Standard) - Chiller	Misc	2014	2054	51.76	44.80	0.33	29.37	36%	0.26	17.94	29%	0.76	0.12	1	0	0.12			0.00	0.00
VA	2000	2004 Cool Roof - Chiller	Misc	2014	2054	51.66	44.72	0.10	29.47	36%	0.08	18.02	29%	3.31	0.13	4	0	0.03			0.00	0.00
VA VA	2000 2000	2011 Duct/Pipe Insulation - Chiller 2008 New Economizer - Chiller	Misc Misc	2014 2014	2054 2054	50.97 50.97	44.19 44.19	0.69 0.00	30.16 30.16	37% 37%	0.53 0.00	18.56 18.56	30% 30%	3.99 36828.01	0.22 0.28	5 185,639	0	0.02			0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Misc	2014	2054	312.72	241.85	0.00	0.00	0%	0.00	0.00	0%	N/A	0.26 N/A	N/A	N/A	N/A	312.72	241.85	0.00	0.00
VA	2100	2113 Ceiling/roof Insulation - DX	Misc	2014	2054	312.71	241.84	0.01	0.01	0%	0.01	0.01	0%	0.02	0.02	0	0	6.16			0.01	0.01
VA VA	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2105 DX Tune Up/ Advanced Diagnostics	Misc Misc	2014 2014	2054 2054	240.79 240.02	186.22 185.91	71.92 0.77	71.93 72.70	23% 23%	55.62 0.30	55.63 55.93	23% 23%	0.03	0.03	0	0	3.27 0.61			71.92 0.00	55.62 0.00
VA	2100	2112 Duct Testing/Sealing - DX	Misc	2014	2054	225.90	174.99	14.12	86.82	28%	10.92	66.85	28%	0.11	0.03	0	0	0.54			0.00	0.00
VA	2100	2106 Prog. Thermostat - DX	Misc	2014	2054	221.59	174.14	4.31	91.13	29%	0.86	67.71	28%	0.12	0.07	1	0	0.45			0.00	0.00
VA	2100	2108 Optimize Controls - DX	Misc	2014	2054	217.91	173.41	3.68	94.82	30%	0.73	68.44	28%	0.13	0.07	1	0	0.40			0.00	0.00
VA VA	2100 2100	2115 Window Film (Standard) - DX 2107 Cool Roof - DX	Misc Misc	2014 2014	2054 2054	217.06 216.63	172.75 172.42	0.85 0.43	95.66 96.09	31% 31%	0.66 0.33	69.09 69.42	29% 29%	0.60 3.04	0.07 0.09	1	0	0.15 0.03			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Misc	2014	2054	215.25	171.35	1.38	97.47	31%	1.07	70.49	29%	3.64	0.14	5	o	0.03			0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Misc	2014	2054	297.00	229.69	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	297.00	229.69	0.00	0.00
VA VA	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Misc Misc	2014 2014	2054 2054	260.27 187.11	201.28	36.73 0.00	36.73 0.00	12% 0%	28.41	28.41 0.00	12% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	3.05 N/A	187.11	144.70	36.73 0.00	28.41
VA	2300	2301 HE PTAC, EER=9.6, 1 ton	Misc	2014	2054	161.77	125.11	25.34	25.34	14%	19.60	19.60	14%	0.08	0.08	0	0	1.33			25.34	19.60
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Misc	2014	2054	351.21	99.79	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	351.21	99.79	0.00	0.00
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP	Misc Misc	2014 2014	2054	345.15 246.37	98.06 91.07	6.06 98.78	6.06 104.83	2% 30%	1.72 7.00	1.72 8.72	2% 9%	0.06 0.05	0.06 0.05	0	0	1.26 1.19			6.06 98.78	1.72 7.00
VA	3000	3002 Variable Speed Brive Control, 3 TIP 3003 Demand Controlled Ventilation	Misc	2014	2054	241.56	88.44	4.81	109.65	31%	2.63	11.35	11%	1.52	0.03	3	1	0.06			0.00	0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Misc	2014	2054	279.97	79.55	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	279.97	79.55	0.00	0.00
VA VA	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Misc Misc	2014 2014	2054 2054	239.56 223.16	69.24 68.07	40.41 16.41	40.41 56.81	14% 20%	10.31 1.16	10.31 11.47	13% 14%	0.03 0.04	0.03	0	0	2.40 1.26			40.41 16.41	10.31 1.16
VA	3100	3102 Variable Speed Drive Control, 15 HP	Misc	2014	2054	159.29	63.55	63.86	120.68	43%	4.52	16.00	20%	0.04	0.05	i	0	0.87			0.00	0.00
VA	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Misc	2014	2054	156.91	62.87	2.38	123.06	44%	0.68	16.67	21%	0.20	0.05	1	0	0.39			0.00	0.00
VA VA	3100 3100	3105 Energy Recovery Ventilation (ERV) 3107 Demand Controlled Ventilation	Misc Misc	2014 2014	2054 2054	154.91 151.88	61.78 60.13	2.00 3.03	125.06 128.09	45% 46%	1.09 1.65	17.77 19.42	22% 24%	0.43 1.93	0.06	1	0	0.24			0.00	0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Misc	2014	2054	222.17	63.12	0.00	0.00	0%	0.00	0.00	0%	N/A	0.10 N/A	N/A	N/A	0.05 N/A	222.17	63.12	0.00	0.00
VA	3200	3203 Air Handler Optimization, 40 HP	Misc	2014	2054	206.95	62.04	15.22	15.22	7%	1.08	1.08	2%	0.03	0.03	0	0	1.47			15.22	1.08
VA VA	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	Misc Misc	2014 2014	2054 2054	147.72 147.14	57.85 57.68	59.23 0.59	74.44 75.03	34% 34%	4.20 0.17	5.27 5.44	8% 9%	0.10 0.50	0.09	1 2	1	0.56 0.16			0.00	0.00
VA	3200	3201 Fan Motor, 40np, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Misc	2014	2054	147.14	56.11	2.88	75.03	34% 35%	1.57	7.01	9% 11%	1.61	0.09	3	2	0.16			0.00	0.00
VA	4000	4000 Base Built-Up Refrigeration System	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Misc	2014	2054	306.76	46.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	306.76	46.18	0.00	0.00
VA VA	4100 4100	4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Misc Misc	2014 2014	2054 2054	299.24 294.99	45.05 44.41	7.52 4.25	7.52 11.77	2% 4%	1.13 0.64	1.13 1.77	2% 4%	0.00	0.00	0	0	36.51 34.70			7.52 4.25	1.13 0.64
VA	4100	4108 Energy-Star Refrigerator, glass door	Misc	2014	2054	293.75	44.22	1.24	13.00	4%	0.19	1.96	4%	0.01	0.00	0	Ö	11.20			1.24	0.19
VA	4100	4106 Energy-Star Refrigerator, solid door	Misc	2014	2054	290.56	43.74	3.19	16.19	5%	0.48	2.44	5%	0.01	0.00	0	0	11.00			3.19	0.48
VA VA	4100 4100	4110 Energy Star Ice Machines 4112 Reach-in unit occupancy sensors	Misc Misc	2014 2014	2054 2054	286.23 286.22	43.09 43.09	4.33 0.01	20.53 20.54	7% 7%	0.65 0.00	3.09 3.09	7% 7%	0.01 0.28	0.00 0.01	0 2	0	4.02 0.20			4.33 0.00	0.65 0.00
VA	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Misc	2014	2054	286.16	43.08	0.06	20.60	7%	0.01	3.10	7%	0.32	0.01	2	0	0.17			0.00	0.00
VA	5000	5000 Base Desktop PC	Misc	2014	2054	26.53	4.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	26.53	4.02	0.00	0.00
VA	5000	5001 PC Network Power Management Enabling	Misc	2014	2054	14.58	3.10	11.96	11.96	45%	0.92	0.92	23%	0.01	0.01	0	0	3.90			11.96	0.92
VA VA	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	Misc Misc	2014 2014	2054 2054	10.03 1.52	2.41 0.23	4.54 0.00	16.50 0.00	62% 0%	0.69 0.00	1.61 0.00	40% 0%	0.03 N/A	0.02 N/A	N/A	N/A	1.98 N/A	1.52	0.23	4.54 0.00	0.69 0.00
VA	5100	5102 Energy Star or Better Laptop	Misc	2014	2054	1.23	0.19	0.29	0.29	19%	0.04	0.04	19%	0.01	0.01	0	0	5.43	-		0.29	0.04
VA	5100 5200	5101 Laptop Network Power Management Enabling	Misc Misc	2014 2014	2054 2054	1.20	0.18	0.03	0.31	21%	0.00	0.05	21% 0%	1.13 N/A	0.10 N/A	7	1	0.05	6.12	0.93	0.00	0.00
VA VA	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Misc	2014	2054	6.13 2.69	0.93	0.00 3.44	0.00 3.44	0% 56%	0.00	0.00 0.52	0% 56%	0.00	0.00	N/A 0	N/A 0	N/A 43.26	6.13	0.93	0.00 3.44	0.00
VA	5200	5202 Monitor Power Management Enabling - CRT	Misc	2014	2054	2.01	0.35	0.68	4.12	67%	0.05	0.57	62%	0.02	0.00	0	0	2.81			0.68	0.05
VA	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Misc	2014	2054	1.85	0.33	0.16	4.27	70%	0.02	0.60	64%	0.19	0.01	1	0	0.26			0.00	0.00
VA VA	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Misc Misc	2014 2014	2054 2054	5.57 4.57	0.84	0.00 1.00	0.00 1.00	0% 18%	0.00 0.15	0.00 0.15	0% 18%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.34	5.57	0.84	0.00 1.00	0.00 0.15
VA	5300	5302 Monitor Power Management Enabling - LCD	Misc	2014	2054	4.41	0.68	0.16	1.16	21%	0.13	0.16	19%	0.07	0.02	1	0	0.63			0.00	0.00
VA	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Misc	2014	2054	4.07	0.67	0.33	1.49	27%	0.01	0.18	21%	0.21	0.06	5	1	0.21			0.00	0.00

APPENDIX H

Base Avoided Costs

No. Process Process			ric Existing Construction		Year	2020																SUPPLY	
Part																						301111	
	В	ase	Measure	Building			-	Total	GWH	Savings		MW								Base	Base	Economic	Economic
No. 1.50 1.50				71					Savings	GWH	Savings		MW	Savings	4,,,,,,,,,,,		4,,,,,	Ψ	TRC				
Mathematics																				9.83	1.49		
No. 1950 1950	VA	5400	5402 Copier Power Management Enabling	Misc				1.26	0.42	1.74	18%	0.03	0.23	16%	0.09	0.02	1					0.00	0.00
1.00 1.00																				1.46	0.22		
Mathematical Content	VA	5500	5501 Multifunction Power Management Enabling	Misc	2014	2054	0.92	0.15	0.18	0.55	37%	0.01	0.07	31%	0.23	0.08	3	1	0.20			0.00	0.00
1.																				7.65	1.16		
Second S																							
			5700 Base Data Center/Server Room																	57.89	8.77		
7. 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1																							
Marc	VA	5700	5703 Data Center State of the Art practices	Misc	2014	2054	42.93	6.50	2.55	14.96	26%	0.39	2.27	26%	0.00	0.00	0	0	22.17			2.55	0.39
Mathematical Content Mathematical Mathematical Content Mathema																				92.42	13.64		
Month Mont	VA	6000	6002 High Efficiency Water Heater (electric)	Misc	2014	2054	85.88	12.68	1.75	6.54	7%	0.26	0.97	7%	0.03	0.02	0	0	2.13			1.75	0.26
Mathematical Content Mathematical Content																							
Year 100 Year 100 Year Ye																							
Value Valu																							
VA 700 700 Varies Mainer Series Mainer Series Varies Va																				16.86	2.80		
VA 700 700 700 100	VA	7000	7002 Vending Misers (Refrigerated glass-front units)	Misc	2014	2054	12.68	2.45	1.48	4.18	25%	0.12	0.35		0.05	0.03	1	0	1.00			0.00	0.00
VA 7200 72																				0.18	0.03		
VA 700 700 Fine Fine	VA	7200		Misc	2014	2054	5.95	0.96	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A			0.00	0.00
VA 7400 74																				10.69	1.73		
VA 2000 2000 Basel-hearing, Hear Plump (77 HEPF) Marc 2014 2054 45.34 0.00																				2.65	0.43		
No.	VA	8000		Misc	2014	2054	45.34	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A			0.00	0.00
VA 9500 9500 85																				42 11	0.00		
NC 100 103	VA	9500	9500 Base Miscellaneous	Misc	2014	2054	803.83	133.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A			0.00	0.00
NC 1000 1038 Highler (Growner Juneage (4,4Tis), 2020 00166 2020 2046 2.58 0.08 0.08 0.08 0.08 0.08 0.08 0.01 0.01 0.0 0.5 5.84 0.08 0.0																				E6 9E	10.59		
NC 1030 1031 ROB 4LH High Performance T8 (80 M), 2020 10Hz 2020 2054 41,720 8,85 8,56 9,86 17% 17% 1.00 1.83 15% 0.02 0.0 0.0 2.97 1.00 1.03 103 ROB 4LH High Performance T8 (80 M), 2020 10Hz 2020 2054 41,720 7.85 6.01 1.75 0.00 1.00 1.00 1.00 1.00 1.00 1.00 1.0																				30.03	10.56		
NC 1930 1932 PCASPAR L Low Wast High Performance 1978 VI), 2020 Office 200 2054 41.20 78.8 of 1 15.65 29% 11.2 2.75 28% 0.04 0.03 0.0 0 1.43 - 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																							
NC 1930 1937 Coxpanys Semon, 4Li Fluorescent Flutures, 2020 Office 2020 254 18 37.7 8 7.8 1 9.8 8 44% 0.16 2.91 2.95 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																							
NC 130 1130 Step Turble (base 4L4T8), 2020 Office 2020 2054 28.98 0.03 270 0.00 0.00 0.00 0.00 0.00 0.00 0.00			1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020																				
NC 1130 1138 Base Fluorescent Fluture, Zul 4TB, 1EB, 2020 Office 2020 2054 0.89 0.18 0.00 0.																							
NC 1130 1131 RG 2L4 High Performance Lighting RRF. = 25% Sawings (base 2L4 TB), 2020 Office 2020 2054 0.89 0.17 0.07 0.07 0.07 0.07 0.07 0.07 0.07	NC	1130		Office	2020	2054			0.00		0%	0.00	0.00	0%	N/A	N/A				0.96	0.18	0.00	0.00
NC 1130 1131 ROB 2L4 Hugh Performance Tis (68 W), 2020																							
NC 1130 1134 ROB 2L4 LED Tube, 2/20																							
NC 1130 1137 Cocupancy Sensor, 2L4 Fluorescent Flutures, 2020 Office 2020 2054 0.51 0.05 0.41 0.06 0.00																							
NC 130 130 133 LED Tindfer (base 2L4TB), 2020 0ffice 2020 2044 0.56 0.76 0.71 0.00 0.00 0.00 0.00 0.00 0.00 0.00																							
NC 1200 1203 Lighting Control Tuneun (base other Huorescent Instrure) Office 2014 2054 1.72 0.33 0.03 0.00 0.00 0.00 0.00 0.00 0.0	NC	1130	1135 LED Troffer (base 2L4'T8), 2020	Office	2020	2054	0.55	0.11	0.05	0.41	42%	0.01	0.07		0.26	0.09	1	1	0.25			0.00	0.00
NC 1200 1205 High Performance Lighting RR - 25% Savings, Base Other Fluorescent Office 2014 2054 1.72 0.33 0.20 0.36 0.16 8% 0.02 0.02 6% 0.03 0.03 0.0 0.0 2.45 0.00 0.00 0.00 NC 1204 Occupancy Sensor, 4.8F Fluorescent Fluori, 100W 10 Screw-in Replacement 2020 0ffice 2014 2054 1.73 0.32 0.25 0.61 29% 0.01 0.07 19% 0.10 0.07 2 1 0.48 1.73 2.56 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																				2.09	0.39		
NC 1200 1204 Occupancy Sensor, 44.8 Fluorescent Fibrures Office 2014 2054 1.47 0.32 0.25 0.61 29% 0.01 0.07 19% 0.10 0.07 2 1 0.48 0.00	NC	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	2014	2054	1.92	0.36	0.16	0.16	8%	0.02	0.02	6%	0.03	0.03	ō	ō	2.45			0.16	0.02
NC 1330 1330 1330 1330 1330 1330 1330 1330 1250 1330 1332 1250 1333 1250 12																							
NC 1430 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 Office 2020 2054 4,94 0.92 0.00																				13.73	2.56		
NC 1430 1432 LEDs (base incandescent A-line 72W) 2020 Office 2020 2054 0.94 0.17 4.00 4.00 81% 0.75 0.75 81% 0.01 0.01 0.0 0.898 4.00 0.75 0.75 81% 0.01 0.01 0.01 0.0 0.898 4.00 0.75 0.75 0.75 81% 0.01 0.01 0.01 0.01 0.01 0.01 0.00 0.75 0.75 0.75 0.75 0.75 0.75 0.75																				4.04	0.00		
NC 1530 15																				4.94	0.92		
NC 1630 16	NC	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	2020	2054	3.64	0.68	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.64	0.68	0.00	0.00
NC 1630 1631 LED screw-in replacement (base CFL 18W) 2020 Office 2020 2054 0.18 0.03 0.07 0.07 28% 0.01 0.01 28% 0.05 0.05 0.0 1.06 U.00 0.00 0.00 0.00 0.00 0.00 0.00 0																				0.25	0.05		
NC 1730 1731 LED screw-in replacement (base CFL 23W) 2020 Office 2020 2054 0.23 0.04 0.08 0.08 26% 0.02 26% 0.04 0.04 0.0 0.04 0.04 0 0.14 U 0.08 0.08 0.02 0.00 0.00 0.00 0.00 0.00	NC	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Office	2020	2054	0.18	0.03	0.07	0.07	28%	0.01	0.01	28%	0.05	0.05	0	0	1.06			0.07	0.01
NC 1800 1800 BaseMetal Halide, 465W Office 2014 2054 0.00 <t< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>0.32</td><td>0.06</td><td></td><td></td></t<>																				0.32	0.06		
NC 1850 1850 Base CFL Exit Sign Office 2014 2054 0.29 0.00 0.00 0.00 0.00 0.00 0.00 0.00																				0.00	0.00		
NC 1900 1900 Base Outdoor High Pressure Sodium 250W Lamp Office 2014 2054 1.31 0.02 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A N/A N/A N/A N/A 1.31 0.02 0.00 0.00 0.00 0.00 0.00 0.00 0.0		1850	1850 Base CFL Exit Sign		2014	2054												N/A	N/A			0.00	
NC 1900 1901 Outdoor Lighting Controls (Photocell/Timeclock) Office 2014 2054 1.19 0.01 0.12 0.12 9% 0.01 0.01 30% 0.04 0.04 1 1 1 1.58 0.12 0.01 0.01 0.01 0.01 0.01 0.01 0.01																				1.31	0.02		
NC 1900 1903 Bi-Level LED Outdoor Lighting Office 2014 2054 0.40 0.00 0.17 0.90 69% 0.00 0.02 89% 0.54 0.16 44 9 0.10 0.00 0.00 0.00 NC 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons Office 2014 2054 0.75 0.53 0.00 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A N/A N/A 0.75 0.53 0.00 0.00 0.00 0.00 0.00 0.00 0.0	NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Office	2014	2054	1.19	0.01	0.12	0.12	9%	0.01	0.01	30%	0.04	0.04	1	1	1.58			0.12	0.01
NC 2000 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons Office 2014 2054 0.75 0.53 0.00 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A N/A 0.75 0.53 0.00 0.00																							
NC 2000 2010 Celling/roof Insulation - Chiller Office 2014 2054 0.75 0.52 0.00 0.00 0% 0.00 0% 0.01 0.01 0 0 17.67 0.00 0.00 0.00			2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons																	0.75	0.53		
	NC	2000	2010 Ceiling/roof Insulation - Chiller	Office	2014	2054	0.75	0.52	0.00	0.00	0%	0.00	0.00	0%	0.01	0.01	0	0	17.67			0.00	0.00

APPENDIX H

Base Avoided Costs

		ectric Existing Construction ADDITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
	itage			Manager	Measure				Total	Percent		Total Capacity	Percent	Marginal	Average	Marginal Capacity	Average	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Savings	MW	Energy Cost	Energy Cost	Cost	Capacity Cost	Cost Test	Base	Base	Economic	Economic
Sgi NC	mt Number 200		Type Office	Year 2014	Year 2054	0.68	MW 0.48	Savings 0.06	0.07	Savings 9%	Savings 0.04	0.05	Savings 9%	\$/kWH 0.03	\$/kWH 0.03	\$/kW 0	\$/kW 0	4.02	GWH	MW	0.06	MW 0.04
NC	200	00 2005 Chiller Tune Up/Diagnostics	Office	2014	2054	0.68	0.48	0.00	0.07	9%	0.00	0.05	9%	0.02	0.03	0	0	3.21			0.00	0.00
NC			Office	2014	2054	0.68	0.48	0.00	0.07	9%	0.00	0.05	9% 9%	0.04	0.03	0	0	2.62			0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	0.68	0.48 0.47	0.00 0.05	0.07 0.12	10% 16%	0.00 0.01	0.05 0.06	11%	0.03 0.05	0.03 0.04	0	0	2.35 1.32			0.00 0.05	0.00 0.01
NC	200		Office	2014	2054	0.59	0.46	0.04	0.16	22%	0.01	0.07	12%	0.06	0.04	ō	ō	1.00			0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	0.59	0.46 0.38	0.00	0.16 0.27	22% 36%	0.00	0.07	12% 27%	0.09 0.16	0.04	0	0	0.94 0.70			0.00	0.00
NC			Office	2014	2054	0.48	0.38	0.00	0.27	37%	0.00	0.14	28%	0.16	0.09	0	0	0.70			0.00	0.00
NC	200	00 2011 Duct/Pipe Insulation - Chiller	Office	2014	2054	0.47	0.38	0.00	0.28	37%	0.00	0.15	28%	1.94	0.10	3	0	0.05			0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	16.50 12.70	11.54 8.89	0.00 3.79	0.00 3.79	0% 23%	0.00 2.65	0.00 2.65	0% 23%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 4.23	16.50	11.54	0.00 3.79	0.00 2.65
NC NC			Office	2014	2054	12.70	8.89	0.62	4.42	23% 27%	0.65	3.31	23% 29%	0.02	0.02	0	0	4.23 1.55			0.62	0.65
NC	210	00 2108 Optimize Controls - DX	Office	2014	2054	11.87	8.20	0.21	4.62	28%	0.04	3.35	29%	0.06	0.03	0	0	0.86			0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	11.63 11.61	8.02 8.02	0.25 0.01	4.87 4.88	30% 30%	0.17 0.00	3.52 3.52	30% 31%	0.10	0.03 0.03	0	0	0.84 0.75			0.00	0.00
NC			Office	2014	2054	10.34	7.80	1.28	6.16	37%	0.00	3.74	32%	0.09	0.03	0	0	0.73			0.00	0.00
NC	210	00 2112 Aerosol Duct Sealing - DX	Office	2014	2054	9.71	7.36	0.63	6.79	41%	0.44	4.18	36%	0.20	0.06	0	0	0.56			0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	9.50 9.42	7.32 7.26	0.21	6.99 7.07	42% 43%	0.04	4.22 4.28	37% 37%	0.11 0.26	0.06	1	0	0.51 0.34			0.00	0.00
NC			Office	2014	2054	9.42	7.26	0.00	7.07	43%	0.00	4.28	37%	0.20	0.06	1	0	0.34			0.00	0.00
NC	210	00 2114 Duct/Pipe Insulation - DX	Office	2014	2054	9.36	7.22	0.06	7.14	43%	0.04	4.32	37%	2.16	0.08	3	0	0.04			0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	18.61 16.31	13.02 11.41	0.00 2.30	0.00 2.30	0% 12%	0.00 1.61	0.00 1.61	0% 12%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 5.93	18.61	13.02	0.00 2.30	0.00 1.61
NC			Office	2014	2054	2.08	1.45	0.00	0.00	0%	0.00	0.00	0%	0.02 N/A	0.02 N/A	N/A	N/A	5.93 N/A	2.08	1.45	0.00	0.00
NC	300	00 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Office	2014	2054	13.42	4.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.42	4.05	0.00	0.00
NC			Office Office	2014 2014	2054	13.21	3.99	0.22 3.22	0.22 3.44	2% 26%	0.07	0.07	2% 8%	0.02	0.02	0	0	4.09			0.22	0.07
NC NC			Office	2014	2054 2054	9.98 9.44	3.74	0.54	3.44	30%	0.24	0.62	15%	0.02	0.02	1	1	3.76 0.15			3.22 0.00	0.24
NC	310	00 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	2014	2054	2.33	0.70	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.33	0.70	0.00	0.00
NC			Office	2014	2054	1.76	0.66	0.57	0.57	24% 25%	0.04	0.04	6%	0.00	0.00	0	0	13.82			0.57	0.04
NC NC			Office Office	2014 2014	2054 2054	1.75 1.63	0.66 0.62	0.01 0.12	0.58 0.69	30%	0.00	0.05 0.08	7% 11%	0.01 0.02	0.00 0.01	0	0	6.81 3.01			0.01 0.12	0.00
NC	310	00 3103 Air Handler Optimization, 15 HP	Office	2014	2054	1.48	0.61	0.16	0.85	37%	0.01	0.09	13%	0.02	0.01	ō	ō	2.27			0.16	0.01
NC			Office	2014	2054	1.44	0.59	0.03	0.88	38% 41%	0.02	0.11	16%	0.25	0.02	0	0	0.42			0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	1.36 1.47	0.55	0.08	0.96 0.00	41% 0%	0.04	0.15 0.00	22% 0%	0.79 N/A	0.08 N/A	N/A	N/A	0.12 N/A	1.47	0.44	0.00	0.00
NC	320	00 3203 Air Handler Optimization, 40 HP	Office	2014	2054	1.33	0.43	0.14	0.14	10%	0.01	0.01	2%	0.02	0.02	0	0	3.24			0.14	0.01
NC NC			Office Office	2014 2014	2054 2054	1.00	0.41	0.32 0.00	0.46 0.47	32% 32%	0.02	0.04 0.04	8% 8%	0.02 0.11	0.02 0.02	0	0	2.48 0.77			0.32 0.00	0.02
NC NC			Office	2014	2054	0.94	0.41	0.00	0.47	36%	0.00	0.04	8% 15%	0.11	0.02	1	1	0.77			0.00	0.00
NC	400	00 4000 Base Built-Up Refrigeration System	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC			Office	2014	2054	4.90	0.69	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	4.90	0.69	0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	4.81 4.80	0.67 0.67	0.09 0.01	0.09 0.10	2% 2%	0.01 0.00	0.01 0.01	2% 2%	0.00 0.02	0.00	0	0	23.22 2.90			0.09 0.01	0.01 0.00
NC	500	00 5000 Base Desktop PC	Office	2014	2054	8.14	1.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.14	1.13	0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	4.39 3.41	0.87	3.75 0.98	3.75 4.72	46% 58%	0.26 0.14	0.26 0.40	23% 35%	0.01 0.02	0.01 0.01	0	0	4.29 2.13			3.75 0.98	0.26
NC			Office	2014	2054	0.20	0.73	0.98	0.00	0%	0.00	0.40	0%	0.02 N/A	N/A	N/A	N/A	2.13 N/A	0.20	0.03	0.98	0.14
NC	510	00 5102 Energy Star or Better Laptop	Office	2014	2054	0.16	0.02	0.04	0.04	19%	0.01	0.01	19%	0.01	0.01	0	0	5.82			0.04	0.01
NC NC			Office Office	2014 2014	2054 2054	0.16 2.91	0.02	0.00	0.04	21% 0%	0.00	0.01 0.00	21% 0%	1.03 N/A	0.09 N/A	7 N/A	1 N/A	0.05 N/A	2.91	0.40	0.00	0.00
NC			Office	2014	2054	1.67	0.40	1.24	1.24	43%	0.00	0.00	43%	0.00	0.00	0	0	60.59	2.91	0.40	1.24	0.17
NC	520	00 5202 Monitor Power Management Enabling - CRT	Office	2014	2054	1.45	0.22	0.22	1.46	50%	0.02	0.19	46%	0.01	0.00	0	0	5.11			0.22	0.02
NC NC			Office Office	2014 2014	2054 2054	1.34 1.20	0.20	0.11 0.00	1.58 0.00	54% 0%	0.02	0.20 0.00	50% 0%	0.12 N/A	0.01 N/A	1 N/A	0 N/A	0.43 N/A	1.20	0.17	0.00	0.00
NC			Office	2014	2054	1.04	0.17	0.00	0.16	13%	0.00	0.00	13%	0.01	0.01	0	0	5.54	1.20	0.17	0.00	0.02
NC	530	00 5302 Monitor Power Management Enabling - LCD	Office	2014	2054	0.97	0.14	0.08	0.23	20%	0.01	0.03	16%	0.09	0.03	1	ō	0.53			0.00	0.00
NC			Office	2014	2054	0.89	0.14	0.08	0.31	26%	0.00	0.03	18%	0.24	0.08	7	1	0.18	0.00	0.40	0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	3.29 2.96	0.46 0.41	0.00 0.33	0.00 0.33	0% 10%	0.00 0.05	0.00 0.05	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 35.49	3.29	0.46	0.00 0.33	0.00 0.05
NC	540	00 5402 Copier Power Management Enabling	Office	2014	2054	2.83	0.40	0.13	0.45	14%	0.01	0.05	12%	0.07	0.02	1	0	0.64			0.00	0.00
NC			Office	2014	2054	0.45	0.06	0.00	0.00	0% 25%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	0.45	0.06	0.00	0.00
NC NC			Office Office	2014 2014	2054 2054	0.34	0.05	0.11 0.06	0.11 0.18	25% 39%	0.02	0.02 0.02	25% 32%	0.01 0.21	0.01 0.08	0	1	9.72 0.22			0.11 0.00	0.02
NC	560	00 5600 Base Printer	Office	2014	2054	4.28	0.59	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.28	0.59	0.00	0.00
NC			Office	2014	2054	2.79	0.39	1.49	1.49	35%	0.21	0.21	35%	0.00	0.00	0	0	44.69			1.49	0.21
NC NC			Office Office	2014 2014	2054 2054	2.28 1.34	0.35 0.19	0.51 0.00	2.00 0.00	47% 0%	0.04	0.24	41% 0%	0.05 N/A	0.01 N/A	1 N/A	0 N/A	1.00 N/A	1.34	0.19	0.51 0.00	0.04
NC	570	00 5701 Data Center Improved Operations	Office	2014	2054	1.21	0.17	0.13	0.13	10%	0.02	0.02	10%	0.00	0.00	0	0	154.45		0.10	0.13	0.02
NC			Office	2014	2054	1.05	0.15	0.15	0.29	21%	0.02	0.04	21%	0.00	0.00	0	0	62.88			0.15	0.02
NC NC			Office Office	2014 2014	2054 2054	0.99 3.14	0.14 0.42	0.06 0.00	0.35 0.00	26% 0%	0.01 0.00	0.05 0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	32.61 N/A	3.14	0.42	0.06 0.00	0.01 0.00
NC			Office	2014	2054	2.98	0.42	0.16	0.16	5%	0.02	0.02	5%	0.01	0.01	0	0	4.07	J .	J.72	0.16	0.02

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS																SUPPLY				
Vinta	ge			Maggura	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm NC	Number 6000	Number Measure 6002 High Efficiency Water Heater (electric)	Type Office	Year 2014	Year 2054	GWH 2.92	MW 0.39	Savings 0.06	GWH 0.22	Savings 7%	Savings 0.01	0.03	Savings 7%	\$/kWH 0.03	\$/kWH 0.02	\$/kW 0	\$/kW	2.17	GWH	MW	0.06	0.01
NC	6000	6004 Tankless Water Heater	Office	2014	2054	2.70	0.36	0.22	0.44	14%	0.03	0.06	14%	0.04	0.03	0	0	1.54			0.22	0.03
NC NC	6000 6000	6008 Solar Water Heater 6003 Hot Water Pipe Insulation	Office Office	2014	2054	1.26 1.25	0.17	1.44 0.01	1.88 1.89	60% 60%	0.19 0.00	0.25 0.26	60% 60%	0.05	0.05 0.05	0	0	1.32 0.56			1.44 0.00	0.19
NC	6000	6006 Heat Recovery Unit	Office	2014	2054	1.17	0.17	0.01	1.09	63%	0.00	0.26	63%	0.11	0.05	1	0	0.49			0.00	0.00
NC	6000	6001 Demand controlled circulating systems	Office	2014	2054	1.13	0.15	0.03	2.01	64%	0.00	0.27	64%	0.35	0.06	3	0	0.18			0.00	0.00
NC NC	7000 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Office Office	2014 2014	2054 2054	1.93 1.62	0.28	0.00 0.31	0.00 0.31	0% 16%	0.00 0.02	0.00 0.02	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.81	1.93	0.28	0.00 0.31	0.00 0.02
NC	7000	7002 Vending Misers (Refrigerated glass-front units)	Office	2014	2054	1.45	0.25	0.17	0.48	25%	0.01	0.03	12%	0.05	0.03	1	0	0.99			0.00	0.00
NC NC	7100 7200	7100 Base Non-Refrigerated Vending Machines 7200 Base Oven	Office Office	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	7300	7300 Base Fryer	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Office Office	2014 2014	2054 2054	0.00 2.83	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 2.83	0.00	0.00	0.00
NC	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	2014	2054	2.67	0.00	0.16	0.16	6%	0.00	0.00	0%	0.02	0.02	N/A	N/A	3.11	2.00		0.16	0.00
NC	8100	8100 Base Heating, Other Electric	Office	2014	2054	2.65	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.65	0.00	0.00	0.00
NC NC	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Office Office	2014 2014	2054 2054	22.23 22.23	3.24	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	22.23	3.24	0.00	0.00
NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Restaurant	2020	2054	0.79	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.79	0.16	0.00	0.00
NC NC	1030 1030	1036 Lighting Control Tuneup (base 4L4T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Restaurant Restaurant	2020 2020	2054 2054	0.79 0.73	0.16	0.00	0.00	0% 8%	0.00 0.01	0.00 0.01	0% 6%	0.01 0.01	0.01 0.01	0	0	6.10 5.43			0.00 0.06	0.00 0.01
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Restaurant	2020	2054	0.65	0.13	0.08	0.14	17%	0.01	0.02	16%	0.03	0.02	0	0	1.71			0.08	0.01
NC NC	1030 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Restaurant Restaurant	2020 2020	2054 2054	0.57	0.11 0.11	0.08	0.22	28% 29%	0.02	0.04 0.04	26% 26%	0.07 0.13	0.04 0.04	0	0	0.82			0.00	0.00
NC NC	1030	1037 Occupancy Sensor, 4L4 Fluorescent Fixtures, 2020 1034 ROB 4L4 LED Tube, 2020	Restaurant	2020	2054	0.56	0.11	0.01	0.23	29% 40%	0.00	0.04	38%	0.13	0.04	2	1	0.39			0.00	0.00
NC	1030	1035 LED Troffer (base 4L4'T8), 2020	Restaurant	2020	2054	0.43	0.09	0.04	0.36	45%	0.01	0.07	43%	0.33	0.16	2	1	0.19			0.00	0.00
NC NC	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Restaurant Restaurant	2020 2020	2054 2054	4.69 4.68	0.93	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.91	4.69	0.93	0.00	0.00
NC	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Restaurant	2020	2054	4.33	0.87	0.35	0.36	8%	0.06	0.06	6%	0.02	0.02	0	0	2.60			0.35	0.06
NC NC	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Restaurant Restaurant	2020 2020	2054 2054	3.88	0.78 0.68	0.45 0.49	0.81 1.30	17% 28%	0.09 0.10	0.14 0.24	16% 26%	0.04 0.09	0.03 0.05	0	0	1.35 0.65			0.45 0.00	0.09
NC	1130	1134 ROB 2L4 LED Tube, 2020	Restaurant	2020	2054	3.22	0.65	0.16	1.47	31%	0.03	0.27	30%	0.32	0.08	2	0	0.20			0.00	0.00
NC NC	1130 1130	1135 LED Troffer (base 2L4'T8), 2020	Restaurant Restaurant	2020 2020	2054 2054	2.95 2.90	0.60 0.59	0.27	1.74 1.78	37% 38%	0.05	0.33	36% 36%	0.40	0.13 0.14	2	1	0.16 0.19			0.00	0.00
NC NC	1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	Restaurant	2020	2054	0.00	0.59	0.04	0.00	38% 0%	0.00	0.33	0%	0.26 N/A	0.14 N/A	N/A	N/A	0.19 N/A	0.00	0.00	0.00	0.00
NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Restaurant	2020	2054	1.22	0.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.22	0.24	0.00	0.00
NC NC	1330 1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Restaurant Restaurant	2020 2020	2054 2054	0.24	0.05	0.98	0.98	80% 0%	0.19	0.19	80% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	7.37 N/A	0.44	0.09	0.98	0.19 0.00
NC	1430	1432 LEDs (base incandescent A-line 72W) 2020	Restaurant	2020	2054	0.09	0.02	0.34	0.34	79%	0.07	0.07	79%	0.01	0.01	0	0	6.21	0.44	0.03	0.34	0.07
NC NC	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Restaurant Restaurant	2020	2054 2054	0.32	0.06	0.00 0.23	0.00 0.23	0% 71%	0.00 0.05	0.00 0.05	0% 71%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.57	0.32	0.06	0.00 0.23	0.00 0.05
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Restaurant	2020	2054	0.09	0.02	0.23	0.23	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	4.57 N/A	0.16	0.03	0.23	0.00
NC	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Restaurant	2020	2054	0.12	0.02	0.04	0.04	28%	0.01	0.01	28%	0.08	0.08	0	0	0.65			0.00	0.00
NC NC	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Restaurant Restaurant	2020 2020	2054 2054	0.20 0.15	0.04	0.00 0.05	0.00 0.05	0% 26%	0.00 0.01	0.00 0.01	0% 26%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 0.87	0.20	0.04	0.00	0.00
NC	1800	1800 BaseMetal Halide, 465W	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	1800 1800	1801 T5 (240W) (base metal halide) 1806 Occupancy Sensor, High Bay T5	Restaurant Restaurant	2014 2014	2054 2054	0.00	0.00	0.00	0.00	34% 36%	0.00	0.00	34% 34%	0.02	0.02	0	0	4.74 1.23			0.00	0.00
NC	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Restaurant	2014	2054	0.00	0.00	0.00	0.00	41%	0.00	0.00	38%	1.06	0.14	7	1	0.06			0.00	0.00
NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Restaurant Restaurant	2014 2014	2054 2054	0.11	0.02	0.00	0.00	0% 58%	0.00 0.01	0.00	0% 58%	N/A	N/A	N/A 0	N/A 0	N/A	0.11	0.02	0.00	0.00
NC NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Restaurant	2014	2054	0.05 1.83	0.01	0.07	0.07 0.00	58% 0%	0.01	0.01 0.00	58% 0%	0.06 N/A	0.06 N/A	N/A	N/A	0.98 N/A	1.83	0.12	0.00	0.00
NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Restaurant	2014	2054	1.52	0.06	0.31	0.31	17%	0.06	0.06	50%	0.07	0.07	0	0	1.13			0.31	0.06
NC NC	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Restaurant Restaurant	2014 2014	2054 2054	0.73 0.52	0.01	0.79 0.21	1.10 1.31	60% 72%	0.05 0.01	0.11 0.13	93% 104%	0.16 1.02	0.13 0.28	2 17	1	0.38			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Restaurant	2014	2054	0.42	0.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.42	0.26	0.00	0.00
NC NC	2000 2000	2010 Ceiling/roof Insulation - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Restaurant Restaurant	2014 2014	2054 2054	0.39 0.35	0.24	0.03	0.03	7% 15%	0.02 0.02	0.02	7% 15%	0.02 0.02	0.02	0	0	7.13 4.81			0.03	0.02 0.02
NC	2000	2005 Chiller Tune Up/Diagnostics	Restaurant	2014	2054	0.35	0.22	0.00	0.06	15%	0.02	0.04	15%	0.02	0.02	0	0	3.98			0.00	0.02
NC	2000	2003 EMS - Chiller	Restaurant	2014	2054	0.32	0.22	0.03	0.09	22%	0.00	0.04	17%	0.04	0.03	0	0	1.65			0.03	0.00
NC NC	2000 2100	2012 Duct Testing/Sealing 2100 Base DX Packaged System, EER=10.3, 10 tons	Restaurant Restaurant	2014 2014	2054 2054	0.27 6.90	0.18 4.32	0.06	0.15 0.00	36% 0%	0.04	0.08	31% 0%	0.11 N/A	0.06 N/A	0 N/A	0 N/A	0.91 N/A	6.90	4.32	0.00	0.00
NC	2100	2113 Ceiling/roof Insulation - DX	Restaurant	2014	2054	6.90	4.32	0.00	0.00	0%	0.00	0.00	0%	0.01	0.01	0	0	7.68			0.00	0.00
NC NC	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2115 Window Film (Standard) - DX	Restaurant Restaurant	2014 2014	2054 2054	5.31 4.93	3.32	1.59 0.39	1.59 1.97	23% 29%	0.99 0.24	0.99 1.24	23% 29%	0.02 0.02	0.02	0	0	5.44 3.77			1.59 0.39	0.99 0.24
NC	2100	2108 Optimize Controls - DX	Restaurant	2014	2054	4.84	3.07	0.09	2.06	30%	0.01	1.25	29%	0.04	0.02	0	0	1.14			0.09	0.01
NC NC	2100 2100	2105 DX Tune Up/ Advanced Diagnostics 2106 Prog. Thermostat - DX	Restaurant Restaurant	2014 2014	2054 2054	4.84 4.73	3.07 3.05	0.00	2.06 2.17	30% 31%	0.00 0.02	1.25 1.27	29% 29%	0.07 0.06	0.02 0.02	0	0	1.00 0.82			0.00	0.00
NC	2100	2112 Aerosol Duct Sealing - DX	Restaurant	2014	2054	4.73	2.89	0.11	2.17	35%	0.02	1.43	33%	0.06	0.02	0	0	0.82			0.00	0.00
NC	2100	2111 Economizer Repair - DX	Restaurant	2014	2054	4.32	2.75	0.14	2.58	37%	0.13	1.57	36%	0.12	0.04	0	0	0.68			0.00	0.00
NC NC	2100 2100	2107 Cool Roof - DX 2109 Economizer - DX	Restaurant Restaurant	2014 2014	2054 2054	4.18 4.10	2.67 2.65	0.14 0.09	2.72	39% 41%	0.09 0.01	1.65 1.66	38% 39%	0.14 0.15	0.04	0 1	0	0.61 0.37			0.00	0.00
NC	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Restaurant	2014	2054	4.10	2.65	0.00	2.80	41%	0.00	1.67	39%	0.15	0.05	1	0	0.36			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	Restaurant	2014	2054	4.05	2.62	0.05	2.85	41%	0.03	1.70	39%	1.55	0.07	2	0	0.05			0.00	0.00

DNV GL H-23 1/5/2015

APPENDIX H

Base Avoided Costs

	lectric Existing Construction ADDITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintage								Total	B		Total	Percent	Marginal	Average	Marginal	Average					
Base	Measure	Building	Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	Economic
Sgmt Number	or Number Measure 200 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Type Restaurant	Year 2014	Year 2054	GWH 3.42	MW 2.14	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	GWH 3.42	MW 2.14	GWH 0.00	MW 0.00
	200 2200 base near rump (13 SEER, 7.7 HSPF) 200 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	2014	2054	3.00	1.88	0.42	0.42	12%	0.00	0.00	12%	0.01	0.01	0	0	7.63	3.42	2.14	0.42	0.00
	300 2300 Base PTAC, EER=8.3, 1 ton	Restaurant	2014	2054	1.27	0.80	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.27	0.80	0.00	0.00
	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Restaurant Restaurant	2014 2014	2054 2054	3.98 3.91	1.03 1.01	0.00 0.07	0.00 0.07	0% 2%	0.00 0.02	0.00 0.02	0% 2%	N/A 0.11	N/A 0.11	N/A 0	N/A 0	N/A 0.70	3.98	1.03	0.00	0.00
NC 30	3002 Variable Speed Drive Control, 5 HP	Restaurant	2014	2054	2.72	0.93	1.19	1.26	32%	0.08	0.09	9%	0.09	0.09	1	1	0.67			0.00	0.00
	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Restaurant Restaurant	2014 2014	2054 2054	2.36 0.00	0.75	0.37	1.62 0.00	41% 0%	0.18 0.00	0.28 0.00	27% 0%	0.86 N/A	0.26 N/A	2 N/A	2 N/A	0.11 N/A	0.00	0.00	0.00	0.00
NC 32	200 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	4000 Base Built-Up Refrigeration System 4100 Base Self-Contained Refrigeration	Restaurant Restaurant	2014 2014	2054 2054	0.00 17.13	0.00 2.56	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 17.13	0.00 2.56	0.00	0.00
	100 4103 Night covers for display cases (self-contained)	Restaurant	2014	2054	16.71	2.50	0.42	0.42	2%	0.06	0.06	2%	0.00	0.00	0	0	12.78	17.13	2.50	0.42	0.06
	100 4104 Freezer-Cooler Replacement Gaskets (self-contained) 100 4109 Energy-Star Freezer, glass door	Restaurant Restaurant	2014 2014	2054 2054	16.47 16.21	2.47 2.43	0.24 0.25	0.66 0.92	4% 5%	0.04 0.04	0.10 0.14	4% 5%	0.01 0.01	0.00 0.01	0	0	8.19 6.92			0.24 0.25	0.04 0.04
	100 4109 Energy-Star Freezer, glass door 100 4107 Energy-Star Freezer, solid door	Restaurant	2014	2054	16.21	2.43	0.25	1.02	5% 6%	0.04	0.14	5% 6%	0.01	0.01	0	0	2.79			0.25	0.04
NC 41	100 4108 Energy-Star Refrigerator, glass door	Restaurant	2014	2054	15.99	2.39	0.12	1.14	7%	0.02	0.17	7%	0.03	0.01	0	0	2.27			0.12	0.02
	 4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines 	Restaurant Restaurant	2014 2014	2054 2054	15.74 15.49	2.36 2.32	0.25 0.24	1.39 1.64	8% 10%	0.04 0.04	0.21 0.24	8% 10%	0.03 0.07	0.01 0.02	0	0	2.21 0.81			0.25 0.00	0.04 0.00
NC 41	100 4112 Reach-in unit occupancy sensors	Restaurant	2014	2054	15.49	2.32	0.01	1.64	10%	0.00	0.25	10%	0.29	0.02	2	0	0.20			0.00	0.00
	 4105 Bi-level LED Case Lighting (self-contained units) 2014 4101 Strip curtains for walk-ins (self-contained) 	Restaurant Restaurant	2014 2014	2054 2054	15.45 15.42	2.31	0.04	1.68 1.71	10% 10%	0.01	0.25 0.26	10% 10%	0.33 0.37	0.03	2	0	0.16			0.00	0.00
NC 50	000 5000 Base Desktop PC	Restaurant	2014	2054	0.24	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.24	0.05	0.00	0.00
	5001 PC Network Power Management Enabling	Restaurant	2014	2054	0.13	0.04	0.11	0.11	45%	0.01	0.01	23%	0.02	0.02	0	0	2.51			0.11	0.01
	000 5002 Energy Star or Better PC 100 5100 Base Laptop PC	Restaurant Restaurant	2014 2014	2054 2054	0.09	0.03	0.04 0.00	0.15 0.00	63% 0%	0.01 0.00	0.02	41% 0%	0.04 N/A	0.03 N/A	0 N/A	0 N/A	1.28 N/A	0.01	0.00	0.04 0.00	0.01 0.00
NC 51	100 5102 Energy Star or Better Laptop	Restaurant	2014	2054	0.01	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	3.57			0.00	0.00
	100 5101 Laptop Network Power Management Enabling 200 5200 Base Monitor, CRT	Restaurant Restaurant	2014 2014	2054 2054	0.01	0.00	0.00	0.00	21% 0%	0.00	0.00	21% 0%	1.77 N/A	0.16 N/A	9 N/A	1 N/A	0.03 N/A	0.05	0.01	0.00	0.00
NC 52	200 5201 Energy Star or Better Monitor - CRT	Restaurant	2014	2054	0.02	0.00	0.03	0.03	56%	0.01	0.01	56%	0.00	0.00	0	0	28.38	0.00	0.01	0.03	0.01
	200 5202 Monitor Power Management Enabling - CRT 200 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Restaurant Restaurant	2014 2014	2054 2054	0.02	0.00	0.01	0.04	67% 69%	0.00	0.01 0.01	62% 64%	0.03	0.01	0 2	0	1.84 0.18			0.01 0.00	0.00
	5203 Flug-load controls - Confinercial Smart Strip (base Monitor CR1) 5300 Base Monitor, LCD	Restaurant	2014	2054	0.02	0.00	0.00	0.04	0%	0.00	0.00	0%	0.30 N/A	0.02 N/A	N/A	N/A	0.16 N/A	0.06	0.01	0.00	0.00
	5301 Energy Star or Better Monitor - LCD	Restaurant	2014	2054	0.05	0.01	0.01	0.01	20%	0.00	0.00	20%	0.02	0.02	0	0	3.12			0.01	0.00
	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Restaurant Restaurant	2014 2014	2054 2054	0.05 0.04	0.01	0.00	0.02 0.02	27% 32%	0.00	0.00	24% 25%	0.17 0.47	0.06 0.13	2 9	0 1	0.28 0.09			0.00	0.00
NC 54	400 5400 Base Copier	Restaurant	2014	2054	0.12	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.02	0.00	0.00
	5401 Energy Star or Better Copier Copier Power Management Enabling	Restaurant Restaurant	2014 2014	2054 2054	0.11	0.02	0.02	0.02	15% 23%	0.00	0.00	15% 19%	0.00	0.00 0.05	0	0	20.57 0.33			0.02	0.00
	500 5500 Base Multifunction	Restaurant	2014	2054	0.04	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
	500 5502 ENERGY STAR Multi-Function Device 500 5501 Multifunction Power Management Enabling	Restaurant Restaurant	2014 2014	2054 2054	0.03	0.01	0.01 0.01	0.01 0.02	25% 52%	0.00	0.00	25% 39%	0.01 0.56	0.01 0.29	0 6	0	5.95 0.09			0.01 0.00	0.00
	500 5600 Base Printer South Management Enabling	Restaurant	2014	2054	0.02	0.01	0.00	0.02	52% 0%	0.00	0.00	39% 0%	0.56 N/A	0.29 N/A	N/A	N/A	0.09 N/A	0.04	0.01	0.00	0.00
	500 5602 ENERGY STAR Printer	Restaurant	2014	2054	0.02	0.00	0.01	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	27.37			0.01	0.00
	500 5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Restaurant Restaurant	2014 2014	2054 2054	0.02	0.00	0.01	0.02	58% 0%	0.00	0.00	47% 0%	0.12 N/A	0.05 N/A	1 N/A	0 N/A	0.40 N/A	0.05	0.01	0.00	0.00
NC 57	700 5701 Data Center Improved Operations	Restaurant	2014	2054	0.05	0.01	0.01	0.01	10%	0.00	0.00	10%	0.00	0.00	0	0	95.51			0.01	0.00
	700 5702 Data Center Best Practices 700 5703 Data Center State of the Art practices	Restaurant Restaurant	2014 2014	2054 2054	0.04	0.01	0.01	0.01	21% 26%	0.00	0.00	21% 26%	0.00	0.00	0	0	38.88 20.17			0.01	0.00
NC 60	000 6000 Base Water Heating	Restaurant	2014	2054	2.97	0.50	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.97	0.50	0.00	0.00
	000 6007 Heat Trap	Restaurant	2014	2054	2.81	0.47	0.15	0.15	5%	0.03	0.03	5%	0.01	0.01	0	0	9.61			0.15	0.03
	6002 High Efficiency Water Heater (electric) 6006 Heat Recovery Unit	Restaurant Restaurant	2014 2014	2054 2054	2.76 1.32	0.47 0.22	0.06 1.43	0.21 1.64	7% 55%	0.01 0.24	0.04 0.28	7% 55%	0.01 0.01	0.01 0.01	0	0	5.15 5.04			0.06 1.43	0.01 0.24
NC 60	000 6004 Tankless Water Heater	Restaurant	2014	2054	1.22	0.21	0.10	1.74	59%	0.02	0.29	59%	0.04	0.01	0	0	1.76			0.10	0.02
	000 6008 Solar Water Heater 000 6003 Hot Water Pipe Insulation	Restaurant Restaurant	2014 2014	2054 2054	1.05	0.18 0.17	0.17 0.02	1.91 1.93	65% 65%	0.03	0.32 0.33	65% 65%	0.05 0.06	0.02 0.02	0	0	1.51 1.17			0.17 0.02	0.03
NC 60	6001 Demand controlled circulating systems	Restaurant	2014	2054	0.99	0.17	0.04	1.97	67%	0.01	0.33	67%	0.18	0.02	1	0	0.37			0.00	0.00
	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Restaurant Restaurant	2014 2014	2054 2054	0.20	0.04	0.00	0.00	0% 16%	0.00	0.00	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.85	0.20	0.04	0.00	0.00
NC 70	7002 Vending Misers (Refrigerated glass-front units)	Restaurant	2014	2054	0.15	0.04	0.02	0.05	25%	0.00	0.00	12%	0.05	0.03	0	0	1.01			0.03	0.00
	7100 Base Non-Refrigerated Vending Machines	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	200 7200 Base Oven 200 7201 Convection Oven	Restaurant Restaurant	2014 2014	2054 2054	1.06 0.81	0.22	0.00 0.24	0.00 0.24	0% 23%	0.00 0.05	0.00 0.05	0% 23%	N/A 0.10	N/A 0.10	N/A 0	N/A 0	N/A 0.65	1.06	0.22	0.00	0.00
NC 73	300 7300 Base Fryer	Restaurant	2014	2054	0.82	0.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.82	0.17	0.00	0.00
	7301 Efficient Fryer 7400 Base Steamer	Restaurant Restaurant	2014 2014	2054 2054	0.77	0.16 0.15	0.05	0.05	6% 0%	0.01	0.01	6% 0%	0.32 N/A	0.32 N/A	2 N/A	2 N/A	0.20 N/A	0.75	0.15	0.00	0.00
NC 74	7401 Efficient Steamer	Restaurant	2014	2054	0.23	0.05	0.52	0.52	69%	0.11	0.11	69%	0.05	0.05	0	0	1.42			0.52	0.11
	000 8000 Base Heating, Heat Pump (7.7 HSPF) 000 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant Restaurant	2014 2014	2054 2054	0.10	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.05	N/A 0.05	N/A N/A	N/A N/A	N/A 1.05	0.10	0.00	0.00	0.00
	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	Restaurant Restaurant	2014 2014	2054 2054	0.09	0.00	0.01	0.01	6% 0%	0.00	0.00	0% 0%	0.05 N/A	0.05 N/A	N/A N/A	N/A N/A	1.05 N/A	0.26	0.00	0.01	0.00
	500 9500 Base Miscellaneous	Restaurant	2014	2054	6.97	1.37	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.97	1.37	0.00	0.00
	500 9501 Xmisc 300 1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	Restaurant Retail	2014 2020	2054 2054	6.97 41.00	1.37 7.42	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	41.00	7.42	0.00	0.00
NC 10	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Retail	2020	2054	37.89	6.97	3.11	3.11	8%	0.45	0.45	6%	0.02	0.02	0	0	3.62			3.11	0.45
NC 10	30 1031 ROB 4L4' High Performance T8 (86 W), 2020	Retail	2020	2054	33.95	6.26	3.94	7.05	17%	0.71	1.16	16%	0.03	0.02	0	0	2.18			3.94	0.71

DNV GL H-24 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ige			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure Number Measure	Building	Start	End Year	Total GWH	Total MW	GWH Savings	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base	Economic GWH	Economic MW
NC NC	Number 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Type Retail	2020	2054	29.63	5.48	4.32	11.37	Savings 28%	Savings 0.78	1.94	Savings 26%	0.05	0.03	0	0	1.05	GWH	IVI VV	4.32	0.78
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Retail	2020	2054	29.20	5.46	0.43	11.80	29%	0.02	1.96	26%	0.10	0.04	2	0	0.50			0.00	0.00
NC NC	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Retail Retail	2020 2020	2054	24.50	4.61 4.23	4.70 2.09	16.50 18.59	40% 45%	0.85	2.81 3.19	38% 43%	0.31 0.26	0.11	2	1	0.21 0.25			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Retail	2020	2054	8.19	1.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.19	1.48	0.00	0.00
NC	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Retail	2020	2054	7.57	1.39	0.62	0.62	8%	0.09	0.09	6%	0.03	0.03	0	0	2.12			0.62	0.09
NC NC	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Retail Retail	2020 2020	2054 2054	6.78 5.92	1.25	0.79 0.86	1.41 2.27	17% 28%	0.14 0.16	0.23 0.39	16% 26%	0.03 0.07	0.03 0.04	0	0	1.73 0.83			0.79 0.00	0.14
NC	1130	1132 ROB 2L4 LOW Walt High Performance 18 (73 W), 2020	Retail	2020	2054	5.63	1.04	0.29	2.56	31%	0.05	0.39	30%	0.07	0.04	1	0	0.83			0.00	0.00
NC	1130	1135 LED Troffer (base 2L4'T8), 2020	Retail	2020	2054	5.15	0.96	0.48	3.04	37%	0.09	0.53	36%	0.31	0.11	2	1	0.20			0.00	0.00
NC NC	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 20201200 Base Other Fluorescent Fixture	Retail Retail	2020 2014	2054 2054	5.08 0.06	0.95 0.01	0.07 0.00	3.11 0.00	38% 0%	0.00	0.53	36% 0%	0.20 N/A	0.11 N/A	5 N/A	1 N/A	0.25 N/A	0.06	0.01	0.00	0.00
NC	1200	1205 Base Other Fluorescent Fixture 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Retail	2014	2054	0.06	0.01	0.00	0.00	8%	0.00	0.00	6%	0.06	0.06	0	0	1.09	0.00	0.01	0.00	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	Retail	2014	2054	0.05	0.01	0.01	0.01	17%	0.00	0.00	16%	0.10	0.08	1	1	0.54			0.00	0.00
NC NC	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Retail Retail	2014 2020	2054 2054	0.05 2.53	0.01	0.00	0.01 0.00	20%	0.00	0.00	16% 0%	0.12 N/A	0.09 N/A	3 N/A	1 N/A	0.42 N/A	2.53	0.46	0.00	0.00
NC	1330	1332 LEDs (base incandescent flood) 2020	Retail	2020	2054	0.43	0.08	2.10	2.10	83%	0.38	0.38	83%	0.01	0.01	0	0	8.36			2.10	0.38
NC	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Retail	2020	2054	0.91	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	0.91	0.16	0.00	0.00
NC NC	1530	1432 LEDs (base incandescent A-line 72W) 20201530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Retail Retail	2020 2020	2054 2054	0.17 0.67	0.03	0.74	0.74	82% 0%	0.13	0.13	82% 0%	0.01 N/A	0.01 N/A	N/A	N/A	7.06 N/A	0.67	0.12	0.74	0.13 0.00
NC	1530	1532 LEDs (base incandescent A-line 53W) 2020	Retail	2020	2054	0.17	0.03	0.50	0.50	75%	0.09	0.09	75%	0.01	0.01	0	0	5.26			0.50	0.09
NC NC	1630 1630	1630 Base CFL 18W to screw-in replacement 2020	Retail Retail	2020 2020	2054 2054	1.31 0.95	0.24	0.00	0.00 0.36	0% 28%	0.00 0.07	0.00 0.07	0% 28%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A	1.31	0.24	0.00	0.00
NC NC	1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Retail	2020	2054	1.67	0.17	0.36	0.00	28% 0%	0.07	0.07	28% 0%	0.06 N/A	0.06 N/A	N/A	N/A	0.86 N/A	1.67	0.30	0.00	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Retail	2020	2054	1.24	0.22	0.43	0.43	26%	0.08	0.08	26%	0.05	0.05	0	0	1.14			0.43	0.08
NC NC	1800 1850	1800 BaseMetal Halide, 465W 1850 Base CFL Exit Sign	Retail Retail	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00 0.05	0.00	0.00
NC NC	1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Retail	2014	2054	0.30	0.05	0.00	0.00	56%	0.00	0.00	56%	0.04	0.04	0 0	N/A 0	1.31	0.30	0.05	0.00	0.00
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Retail	2014	2054	1.36	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.36	0.09	0.00	0.00
NC NC	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Retail Retail	2014 2014	2054 2054	1.32 0.64	0.08	0.03 0.69	0.03 0.72	2% 53%	0.01 0.04	0.01 0.05	7% 58%	0.04 0.10	0.04 0.10	0	0	1.77 0.58			0.03	0.01 0.00
NC	1900	1902 EED Oddoor Area Eighting 1903 Bi-Level LED Outdoor Lighting	Retail	2014	2054	0.45	0.04	0.69	0.72	67%	0.04	0.05	70%	0.10	0.10	11	3	0.09			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons 2102 DX Packaged System, EER=13.4, 10 tons	Retail Retail	2014 2014	2054 2054	24.20 18.64	20.00 15.40	0.00 5.57	0.00 5.57	0% 23%	0.00 4.60	0.00 4.60	0% 23%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 2.95	24.20	20.00	0.00 5.57	0.00 4.60
NC NC	2100	2102 DX Packaged System, EER=13.4, 10 tons 2111 Economizer Repair - DX	Retail	2014	2054	17.33	13.88	1.30	6.87	28%	1.52	6.12	23% 31%	0.04	0.04	0	0	1.08			1.30	1.52
NC	2100	2107 Cool Roof - DX	Retail	2014	2054	16.56	13.24	0.77	7.64	32%	0.64	6.76	34%	0.12	0.05	0	0	0.81			0.00	0.00
NC NC	2100 2100	2108 Optimize Controls - DX 2109 Economizer - DX	Retail Retail	2014 2014	2054 2054	16.29 14.90	13.19 12.89	0.27 1.39	7.91 9.30	33% 38%	0.06	6.82 7.11	34% 36%	0.10 0.13	0.06	0	0	0.51 0.45			0.00	0.00
NC	2100	2112 Aerosol Duct Sealing - DX	Retail	2014	2054	14.90	12.09	0.91	10.20	42%	0.30	7.11	39%	0.13	0.07	0	0	0.45			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Retail	2014	2054	13.61	12.06	0.39	10.59	44%	0.08	7.95	40%	0.17	0.09	1	0	0.32			0.00	0.00
NC NC	2100 2100	2115 Window Film (Standard) - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Retail Retail	2014 2014	2054 2054	13.56 13.56	12.02 12.01	0.05 0.01	10.64 10.65	44% 44%	0.04	7.99 7.99	40% 40%	0.38 0.29	0.09	0 1	0	0.25 0.21			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	Retail	2014	2054	13.46	11.93	0.10	10.65	44%	0.00	8.07	40%	3.43	0.09	4	0	0.21			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Retail	2014	2054	12.96	10.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.96	10.71	0.00	0.00
NC NC	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Retail Retail	2014 2014	2054 2054	11.36 1.11	9.38 0.92	1.60 0.00	1.60 0.00	12% 0%	1.32 0.00	1.32 0.00	12% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	4.14 N/A	1.11	0.92	1.60 0.00	1.32 0.00
NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Retail	2014	2054	15.33	4.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.33	4.29	0.00	0.00
NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Retail	2014	2054	15.08	4.23	0.24	0.24	2%	0.07	0.07	2%	0.02	0.02	0	0	3.41			0.24	0.07
NC NC	3000 3000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	10.56 9.45	3.91 3.32	4.52 1.11	4.76 5.87	31% 38%	0.32 0.59	0.38 0.98	9% 23%	0.02 1.16	0.02 0.23	0	0	3.15 0.08			4.52 0.00	0.32
NC	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Retail	2014	2054	0.53	0.15	0.00	0.00	38% 0%	0.59	0.98	23% 0%	1.16 N/A	0.23 N/A	N/A	N/A	0.08 N/A	0.53	0.15	0.00	0.00
NC	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Retail	2014	2054	0.46	0.13	0.08	0.08	14%	0.02	0.02	13%	0.03	0.03	0	0	2.44			0.08	0.02
NC NC	3100 3100	3103 Air Handler Optimization, 15 HP 3102 Variable Speed Drive Control, 15 HP	Retail Retail	2014 2014	2054 2054	0.41	0.13	0.05 0.12	0.12 0.25	23% 46%	0.00	0.02	15% 21%	0.03	0.03 0.05	0	0	1.86 0.85			0.05	0.00
NC	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Retail	2014	2054	0.29	0.12	0.12	0.25	46%	0.00	0.03	21%	0.07	0.05	1	0	0.39			0.00	0.00
NC	3100	3105 Energy Recovery Ventilation (ERV)	Retail	2014	2054	0.27	0.11	0.02	0.27	50%	0.01	0.04	28%	0.46	0.08	1	0	0.23			0.00	0.00
NC NC	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Retail Retail	2014 2014	2054 2054	0.24	0.09 0.15	0.03	0.29	55% 0%	0.01 0.00	0.06	38% 0%	1.59 N/A	0.22 N/A	3 N/A	1 N/A	0.06 N/A	0.53	0.15	0.00	0.00
NC	3200	3203 Air Handler Optimization, 40 HP	Retail	2014	2054	0.48	0.15	0.05	0.05	10%	0.00	0.00	3%	0.02	0.02	0	0	2.17	0.55	0.13	0.05	0.00
NC	3200	3202 Variable Speed Drive Control, 40 HP	Retail	2014	2054	0.34	0.14	0.14	0.20	37%	0.01	0.01	9%	0.06	0.05	1	1	1.02			0.14	0.01
NC NC	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	0.34	0.14 0.12	0.00 0.04	0.20 0.23	37% 44%	0.00 0.02	0.01 0.03	9% 22%	0.28 1.27	0.05 0.23	1 2	1 2	0.29 0.07			0.00	0.00
NC	4000	4000 Base Built-Up Refrigeration System	Retail	2014	2054	0.00	0.00	0.04	0.23	0%	0.02	0.00	0%	N/A	0.23 N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	4100	4100 Base Self-Contained Refrigeration	Retail	2014	2054	5.88	0.89	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.88	0.89	0.00	0.00
NC NC	4100 4100	4109 Energy-Star Freezer, glass door 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Retail Retail	2014 2014	2054 2054	5.85 5.72	0.89	0.03 0.13	0.03 0.15	0% 3%	0.00 0.02	0.00 0.02	0% 3%	0.04 0.04	0.04 0.04	0	0	1.57 1.43			0.03 0.13	0.00 0.02
NC	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4107 Energy-Star Freezer, solid door	Retail	2014	2054	5.72	0.87	0.13	0.15	3%	0.02	0.02	3%	0.04	0.04	1	0	0.62			0.13	0.02
NC	4100	4108 Energy-Star Refrigerator, glass door	Retail	2014	2054	5.61	0.85	0.11	0.27	5%	0.02	0.04	5%	0.11	0.07	1	0	0.53			0.00	0.00
NC NC	4100 4100	4106 Energy-Star Refrigerator, solid door 4112 Reach-in unit occupancy sensors	Retail Retail	2014 2014	2054 2054	5.59 5.56	0.85 0.85	0.02	0.28 0.31	5% 5%	0.00	0.04 0.05	5% 5%	0.12 0.27	0.07 0.09	1 2	0	0.49 0.21			0.00	0.00
NC	4100	4112 Reach-in unit occupancy sensors 4110 Energy Star Ice Machines	Retail	2014	2054	5.56	0.85	0.03	0.31	5% 5%	0.00	0.05	5% 5%	0.27	0.09	2	1	0.21			0.00	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Retail	2014	2054	5.51	0.84	0.05	0.37	6%	0.01	0.06	6%	0.31	0.12	2	1	0.17			0.00	0.00
NC	4100	4101 Strip curtains for walk-ins (self-contained)	Retail	2014	2054	5.50	0.84	0.00	0.37	6%	0.00	0.06	6%	1.91	0.13	13	1	0.03			0.00	0.00

APPENDIX H

Base Avoided Costs

		ic Existing Construction		Year	2020																SUPPLY	
Vinta	ge			Maggura	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm1 NC	Number 5000	Number Measure 5000 Base Desktop PC	Type Retail	Year 2014	Year 2054	0.82	MW 0.15	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	0.82	MW 0.15	0.00	0.00
NC	5000	5002 Energy Star or Better PC	Retail	2014	2054	0.70	0.12	0.12	0.12	15%	0.02	0.02	15%	0.01	0.01	0	0	3.49	0.02	0.15	0.12	0.02
NC NC	5000 5100	5001 PC Network Power Management Enabling 5100 Base Laptop PC	Retail Retail	2014	2054	0.38	0.10	0.31	0.44	53% 0%	0.03	0.05	35% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	2.73 N/A	0.01	0.00	0.31	0.03
NC	5100	5102 Energy Star or Better Laptop	Retail	2014	2054	0.01	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	4.53	0.01	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Retail	2014	2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	1.38	0.12	8	1	0.04			0.00	0.00
NC NC	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Retail Retail	2014 2014	2054 2054	0.25 0.11	0.05	0.00 0.14	0.00 0.14	0% 56%	0.00	0.00	0% 56%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 36.02	0.25	0.05	0.00 0.14	0.00
NC	5200	5202 Monitor Power Management Enabling - CRT	Retail	2014	2054	0.09	0.02	0.02	0.16	63%	0.00	0.03	60%	0.02	0.00	0	0	2.75			0.02	0.00
NC NC	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Retail Retail	2014 2014	2054 2054	0.09	0.02	0.01 0.00	0.17	66% 0%	0.00	0.03	63% 0%	0.21 N/A	0.01 N/A	1 N/A	0 N/A	0.25 N/A	0.08	0.01	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	Retail	2014	2054	0.07	0.01	0.01	0.01	14%	0.00	0.00	14%	0.01	0.01	0	0	4.27	0.00	0.01	0.01	0.00
NC NC	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Retail Retail	2014 2014	2054 2054	0.07	0.01	0.00	0.01 0.02	17% 24%	0.00	0.00	16% 17%	0.11	0.03 0.11	1 7	0	0.42 0.14			0.00	0.00
NC	5400	5400 Base Copier	Retail	2014	2054	0.50	0.09	0.00	0.02	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.50	0.09	0.00	0.00
NC	5400	5401 Energy Star or Better Copier	Retail	2014	2054	0.43	80.0	0.07	0.07	14%	0.01	0.01	14%	0.00	0.00	0	0	26.26			0.07	0.01
NC NC	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Retail Retail	2014 2014	2054 2054	0.41	0.07	0.02	0.09	18% 0%	0.00	0.01 0.00	16% 0%	0.11 N/A	0.03 N/A	1 N/A	N/A	0.45 N/A	0.08	0.01	0.00	0.00
NC	5500	5502 ENERGY STAR Multi-Function Device	Retail	2014	2054	0.06	0.01	0.02	0.02	25%	0.00	0.00	25%	0.01	0.01	0	0	7.56			0.02	0.00
NC NC	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Retail Retail	2014 2014	2054 2054	0.05	0.01	0.01	0.03	36% 0%	0.00	0.00	30% 0%	0.28 N/A	0.09 N/A	3 N/A	1 N/A	0.17 N/A	0.08	0.01	0.00	0.00
NC	5600	5602 ENERGY STAR Printer	Retail	2014	2054	0.05	0.01	0.03	0.03	35%	0.01	0.01	35%	0.00	0.00	0	0	34.75	0.00	0.01	0.03	0.01
NC NC	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Retail Retail	2014	2054 2054	0.05	0.01	0.01	0.04	44% 0%	0.00	0.01	39% 0%	0.06 N/A	0.01 N/A	1 N/A	0 N/A	0.80 N/A	0.00	0.01	0.00	0.00
NC	5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Retail	2014	2054	0.08	0.01	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	0	0	120.93	0.08	0.01	0.00	0.00
NC	5700	5702 Data Center Best Practices	Retail	2014	2054	0.06	0.01	0.01	0.02	21%	0.00	0.00	21%	0.00	0.00	0	0	49.23			0.01	0.00
NC NC	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Retail Retail	2014 2014	2054 2054	0.06 3.11	0.01 0.50	0.00	0.02	26% 0%	0.00	0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	25.53 N/A	3.11	0.50	0.00	0.00
NC	6000	6007 Heat Trap	Retail	2014	2054	2.95	0.47	0.16	0.16	5%	0.03	0.03	5%	0.02	0.02	0	0	2.86	****		0.16	0.03
NC NC	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Retail Retail	2014 2014	2054 2054	2.89 2.68	0.47 0.43	0.06 0.22	0.22 0.44	7% 14%	0.01 0.03	0.04 0.07	7% 14%	0.04 0.07	0.03 0.05	0	0	1.53 1.09			0.06 0.22	0.01 0.03
NC	6000	6008 Solar Water Heater	Retail	2014	2054	2.60	0.42	0.07	0.51	16%	0.01	0.08	16%	0.08	0.05	0	0	0.93			0.00	0.00
NC NC	6000 6000	6003 Hot Water Pipe Insulation	Retail Retail	2014 2014	2054 2054	2.56 2.48	0.41	0.04	0.55	18% 20%	0.01	0.09	18% 20%	0.08	0.05 0.06	0	0	0.82 0.64			0.00	0.00
NC NC	6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	Retail	2014	2054	2.48	0.40	0.08	0.64	20%	0.01	0.10	20%	0.09	0.06	1	0	0.50			0.00	0.00
NC	7000	7000 Base Refrigerated Vending Machines	Retail	2014	2054	1.91	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.91	0.34	0.00	0.00
NC NC	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Retail Retail	2014 2014	2054 2054	1.61 1.44	0.31	0.30	0.30	16% 24%	0.03	0.03	8% 12%	0.03	0.03	0	0	1.85 1.01			0.30	0.03
NC	7100	7100 Base Non-Refrigerated Vending Machines	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7200 7200	7200 Base Oven 7201 Convection Oven	Retail Retail	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 23%	0.00	0.00	0% 23%	N/A 0.09	N/A 0.09	N/A 1	N/A 1	N/A 0.68	0.01	0.00	0.00	0.00
NC	7300	7300 Base Fryer	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.09 N/A	0.09 N/A	N/A	N/A	0.66 N/A	0.00	0.00	0.00	0.00
NC	7300	7301 Efficient Fryer	Retail	2014	2054	0.00	0.00	0.00	0.00	6%	0.00	0.00	6%	0.30	0.30	2	2	0.21			0.00	0.00
NC NC	7400 7400	7400 Base Steamer 7401 Efficient Steamer	Retail Retail	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 64%	0.00	0.00	0% 64%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.73	0.00	0.00	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Retail	2014	2054	1.44	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.44	0.00	0.00	0.00
NC NC	8000 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	Retail Retail	2014 2014	2054 2054	1.36 0.39	0.00	0.08	0.08	6% 0%	0.00	0.00	0% 0%	0.04 N/A	0.04 N/A	N/A N/A	N/A N/A	1.44 N/A	0.39	0.00	0.08	0.00
NC	9500	9500 Base Miscellaneous	Retail	2014	2054	36.79	6.58	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	36.79	6.58	0.00	0.00
NC	9500 1030	9501 Xmisc	Retail	2014 2020	2054 2054	36.79	6.58 0.71	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A	N/A N/A	N/A	N/A	0.00	4.04	0.74	0.00	0.00
NC NC	1030	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020 1036 Lighting Control Tuneup (base 4L4T8), 2020	Grocery Grocery	2020	2054	4.64 4.64	0.71	0.00	0.00	0%	0.00	0.00	0%	N/A 0.01	0.01	N/A 0	N/A 0	N/A 4.44	4.64	0.71	0.00	0.00
NC	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Grocery	2020	2054	4.28	0.67	0.36	0.36	8%	0.04	0.04	6%	0.02	0.02	0	0	3.81			0.36	0.04
NC NC	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Grocery Grocery	2020 2020	2054 2054	3.85 3.36	0.60 0.52	0.44 0.49	0.79 1.28	17% 28%	0.07 0.07	0.11 0.18	15% 26%	0.04 0.08	0.03	0 1	0	1.27 0.61			0.44	0.07
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Grocery	2020	2054	3.31	0.52	0.05	1.33	29%	0.00	0.19	26%	0.12	0.05	3	0	0.42			0.00	0.00
NC NC	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Grocery Grocery	2020 2020	2054 2054	2.77 2.54	0.44	0.53 0.24	1.87 2.10	40% 45%	0.08	0.27 0.30	38% 43%	0.50 0.41	0.18 0.21	3	1	0.11 0.13			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Grocery	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Grocery	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	0.01	0.01	0	0	3.71			0.00	0.00
NC NC	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Grocery Grocery	2020 2020	2054 2054	0.02	0.00	0.00	0.00	8% 17%	0.00	0.00	6% 15%	0.02 0.05	0.02 0.04	0	0	3.18 1.01			0.00	0.00
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Grocery	2020	2054	0.01	0.00	0.00	0.00	27%	0.00	0.00	26%	0.11	0.06	1	Ō	0.48			0.00	0.00
NC NC	1130 1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1134 ROB 2L4' LED Tube, 2020	Grocery Grocery	2020 2020	2054 2054	0.01 0.01	0.00	0.00	0.00	28% 32%	0.00	0.00	26% 29%	0.20 0.40	0.07 0.11	6	0	0.24 0.14			0.00	0.00
NC	1130	1135 LED Troffer (base 2L4'T8), 2020	Grocery	2020	2054	0.01	0.00	0.00	0.01	38%	0.00	0.00	35%	0.51	0.17	3	1	0.11			0.00	0.00
NC NC	1200 1330	1200 Base Other Fluorescent Fixture	Grocery	2014 2020	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Grocery	2020	2054	0.42	0.06	0.00	0.00	81%	0.00	0.00	0% 81%	0.01	0.01	0	0	4.76	0.42	0.00	0.00	0.00
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Grocery	2020	2054	0.15	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.15	0.02	0.00	0.00
NC NC	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Grocery Grocery	2020 2020	2054 2054	0.03	0.00	0.12	0.12 0.00	80% 0%	0.02	0.02	80% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	4.01 N/A	0.11	0.02	0.12 0.00	0.02
NC	1530	1532 LEDs (base incandescent A-line 53W) 2020	Grocery	2020	2054	0.03	0.00	0.08	0.08	72%	0.01	0.01	72%	0.02	0.02	0	0	2.96			0.08	0.01
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Grocery	2020	2054	0.67	0.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.67	0.10	0.00	0.00

DNV GL H-26 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm: NC	Number 1630	Number Measure 1631 LED screw-in replacement (base CFL 18W) 2020	Type Grocery	Year 2020	Year 2054	GWH 0.48	MW 0.07	Savings 0.19	GWH 0.19	Savings 28%	Savings 0.03	0.03	Savings 28%	\$/kWH 0.12	\$/kWH 0.12	\$/kW	\$/kW	0.44	GWH	MW	0.00	0.00
NC	1730	1730 Base CFL 23W to screw-in replacement 2020	Grocery	2020	2054	0.85	0.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.85	0.13	0.00	0.00
NC NC	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Grocery Grocery	2020 2014	2054 2054	0.63 0.19	0.10	0.22	0.22	26% 0%	0.03	0.03	26% 0%	0.09 N/A	0.09 N/A	1 N/A	1 N/A	0.59 N/A	0.19	0.03	0.00	0.00
NC	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Grocery	2014	2054	0.19	0.03	0.00	0.00	8%	0.00	0.00	6%	0.01	0.01	0	0	8.77	0.19	0.03	0.00	0.00
NC	1800	1801 T5 (240W) (base metal halide)	Grocery	2014	2054	0.12	0.02	0.06	0.07	39%	0.01	0.01	37%	0.02	0.01	0	0	4.35			0.06	0.01
NC NC	1800 1850	1806 Occupancy Sensor, High Bay T5 1850 Base CFL Exit Sign	Grocery Grocery	2014 2014	2054 2054	0.11	0.02	0.00	0.08	41% 0%	0.00	0.01	38% 0%	0.04 N/A	0.02 N/A	1 N/A	0 N/A	1.23 N/A	0.01	0.00	0.00	0.00
NC	1850	1851 LED Exit Sign	Grocery	2014	2054	0.01	0.00	0.00	0.00	2%	0.00	0.00	2%	0.03	0.03	0	0	1.58	0.01	0.00	0.00	0.00
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Grocery	2014	2054	0.18	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.18	0.00	0.00	0.00
NC NC	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Grocery Grocery	2014 2014	2054 2054	0.16 0.08	0.00	0.03 0.08	0.03 0.11	15% 59%	0.00	0.00	49% 93%	0.10 0.22	0.10 0.19	1	1 5	0.65 0.26			0.00	0.00
NC	1900	1903 Bi-Level LED Outdoor Lighting	Grocery	2014	2054	0.05	0.00	0.02	0.13	71%	0.00	0.00	104%	1.40	0.39	65	11	0.04			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons 2113 Ceiling/roof Insulation - DX	Grocery Grocery	2014 2014	2054 2054	1.49	0.97	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 3.08	1.49	0.97	0.00	0.00
NC	2100		Grocery	2014	2054	1.15	0.75	0.34	0.34	23%	0.22	0.22	23%	0.04	0.04	Ō	ō	2.67			0.34	0.22
NC	2100 2100	2115 Window Film (Standard) - DX	Grocery	2014	2054	1.07	0.70	0.08	0.42	28% 34%	0.05 0.05	0.28	28% 34%	0.10 0.14	0.05	0	0	0.84 0.62			0.00	0.00
NC NC	2100	2107 Cool Roof - DX 2105 DX Tune Up/ Advanced Diagnostics	Grocery Grocery	2014 2014	2054 2054	0.98	0.64 0.64	0.08	0.51 0.51	34%	0.05	0.33 0.33	34%	0.14	0.06 0.06	0	0	0.62			0.00	0.00
NC	2100	2108 Optimize Controls - DX	Grocery	2014	2054	0.96	0.64	0.02	0.53	35%	0.00	0.33	34%	0.12	0.07	1	0	0.42			0.00	0.00
NC NC	2100 2100	2106 Prog. Thermostat - DX 2112 Aerosol Duct Sealing - DX	Grocery Grocery	2014 2014	2054 2054	0.95	0.64	0.01 0.06	0.54	36% 40%	0.00 0.04	0.34 0.37	35% 38%	0.14 0.29	0.07	1	0	0.37 0.36			0.00	0.00
NC	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Grocery	2014	2054	0.89	0.60	0.00	0.60	40%	0.04	0.37	38%	0.29	0.09	5	0	0.07			0.00	0.00
NC	2100	2111 Economizer Repair - DX	Grocery	2014	2054	0.88	0.59	0.01	0.61	41%	0.01	0.38	39%	1.63	0.11	2	ō	0.05			0.00	0.00
NC	2100	2109 Economizer - DX	Grocery	2014 2014	2054 2054	0.88	0.59	0.00	0.61	41%	0.00	0.38	39% 40%	2.04 3.94	0.11	13 6	0	0.03			0.00	0.00
NC NC	2100 2200	2114 Duct/Pipe Insulation - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Grocery Grocery	2014	2054	0.87 1.02	0.58 0.67	0.01 0.00	0.62 0.00	42% 0%	0.01 0.00	0.39	40% 0%	3.94 N/A	0.20 N/A	N/A	N/A	0.02 N/A	1.02	0.67	0.00	0.00
NC	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	2014	2054	0.89	0.58	0.13	0.13	12%	0.08	80.0	12%	0.03	0.03	0	0	3.06			0.13	0.08
NC NC	2300 3000	2300 Base PTAC, EER=8.3, 1 ton	Grocery Grocery	2014 2014	2054 2054	0.17 2.67	0.11	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.17 2.67	0.11 0.57	0.00	0.00
NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3002 Variable Speed Drive Control, 5 HP	Grocery	2014	2054	1.85	0.57	0.83	0.83	31%	0.00	0.00	7%	0.03	0.03	1	1	1.61	2.07	0.57	0.83	0.00
NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Grocery	2014	2054	1.81	0.52	0.03	0.86	32%	0.01	0.05	9%	0.07	0.04	0	1	1.09			0.03	0.01
NC	3000 3100	3003 Demand Controlled Ventilation	Grocery	2014	2054	1.56	0.41	0.26 0.00	1.12	42% 0%	0.11	0.16	28%	1.37 N/A	0.34 N/A	3 N/A	2	0.06	0.00	0.00	0.00	0.00
NC NC	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Grocery Grocery	2014 2014	2054 2054	0.00 2.64	0.00	0.00	0.00	0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	2.64	0.00	0.00	0.00
NC	3200	3203 Air Handler Optimization, 40 HP	Grocery	2014	2054	2.37	0.55	0.27	0.27	10%	0.01	0.01	3%	0.02	0.02	0	0	1.98			0.27	0.01
NC NC	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Grocery Grocery	2014 2014	2054 2054	2.03 12.34	0.41 1.99	0.34 0.00	0.61 0.00	23% 0%	0.14 0.00	0.16 0.00	28% 0%	1.04 N/A	0.58 N/A	2 N/A	2 N/A	0.08 N/A	12.34	1.99	0.00	0.00
NC	4000	4007 Efficient compressor motor	Grocery	2014	2054	12.34	1.98	0.00	0.00	0%	0.00	0.00	0%	0.02	0.02	0	0	3.52	12.34	1.55	0.02	0.00
NC	4000	4011 Demand Hot Gas Defrost	Grocery	2014	2054	12.01	1.93	0.31	0.33	3%	0.05	0.05	3%	0.02	0.02	0	0	3.25			0.31	0.05
NC NC	4000 4000	4009 Floating head pressure controls 4006 Electronically commutated evaporator fan motor	Grocery	2014 2014	2054 2054	11.98 11.13	1.93 1.86	0.03 0.85	0.36 1.21	3% 10%	0.00 0.07	0.06 0.12	3% 6%	0.02	0.02	0	0	2.94 2.65			0.03 0.85	0.00 0.07
NC	4000	4013 Anti-sweat (humidistat) controls	Grocery	2014	2054	10.97	1.85	0.16	1.37	11%	0.01	0.12	7%	0.02	0.02	1	0	1.30			0.16	0.01
NC	4000	4002 Strip curtains for walk-ins (built-up)	Grocery	2014	2054	10.66	1.80	0.31	1.68	14%	0.05	0.19	9%	0.04	0.03	0	0	1.30			0.31	0.05
NC NC	4000 4000	4014 Freezer-Cooler Replacement Gaskets 4018 Oversized Air Cooled Condenser	Grocery Grocery	2014 2014	2054 2054	10.30 9.87	1.74 1.67	0.36 0.43	2.04 2.47	17% 20%	0.06 0.07	0.24 0.31	12% 16%	0.06 0.08	0.03	0	0	0.91			0.00	0.00
NC	4000	4001 High-efficiency fan motors	Grocery	2014	2054	9.52	1.62	0.35	2.82	23%	0.06	0.37	19%	0.11	0.05	1	0	0.66			0.00	0.00
NC	4000		Grocery	2014	2054	8.97	1.62	0.54	3.36	27%	0.00	0.37	19%	0.07	0.05	N/A	0	0.59			0.00	0.00
NC NC	4000 4000	4008 Compressor VSD retrofit 4010 Refrigeration Commissioning	Grocery Grocery	2014 2014	2054 2054	8.42 8.38	1.57 1.56	0.56 0.04	3.92 3.96	32% 32%	0.04 0.01	0.42 0.42	21% 21%	0.10 0.18	0.06 0.06	1	1	0.54 0.28			0.00	0.00
NC	4000	4005 Evaporator fan controller for MT walk-ins	Grocery	2014	2054	8.37	1.56	0.01	3.97	32%	0.00	0.42	21%	0.25	0.06	3	1	0.24			0.00	0.00
NC	4000	4017 Multiplex Compressor System	Grocery	2014	2054	8.22	1.54	0.15	4.12	33%	0.02	0.45	22%	0.27	0.07	2	1	0.24			0.00	0.00
NC NC	4000 4000	4016 LED Display Lighting 4015 High R-Value Glass Doors	Grocery Grocery	2014 2014	2054 2054	7.64 7.52	1.45 1.43	0.58 0.12	4.70 4.82	38% 39%	0.09 0.02	0.54 0.56	27% 28%	0.44 1.97	0.11 0.16	3 12	1	0.12 0.03			0.00	0.00
NC	4100	4100 Base Self-Contained Refrigeration	Grocery	2014	2054	1.23	0.20	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.23	0.20	0.00	0.00
NC	4100	4103 Night covers for display cases (self-contained)	Grocery	2014	2054	1.14	0.18	0.09	0.09	7%	0.01	0.01	7%	0.00	0.00	0	0	159.86			0.09	0.01
NC NC	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4109 Energy-Star Freezer, glass door	Grocery Grocery	2014 2014	2054 2054	1.13 1.06	0.18 0.17	0.02 0.07	0.10 0.17	8% 14%	0.00 0.01	0.02	8% 14%	0.01 0.03	0.00 0.01	0	0	3.56 2.08			0.02 0.07	0.00 0.01
NC	4100	4107 Energy-Star Freezer, solid door	Grocery	2014	2054	1.03	0.17	0.03	0.20	16%	0.00	0.03	16%	0.07	0.02	0	0	0.79			0.00	0.00
NC	4100	4108 Energy-Star Refrigerator, glass door	Grocery	2014	2054	1.03	0.17	0.00	0.20	16%	0.00	0.03	16%	0.09	0.02	1	0	0.61			0.00	0.00
NC NC	4100 4100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Grocery Grocery	2014 2014	2054 2054	1.03	0.17 0.17	0.00	0.20 0.20	16% 16%	0.00	0.03	16% 16%	0.10 0.25	0.02 0.02	1 2	0	0.58 0.23			0.00	0.00
NC	4100	4112 Reach-in unit occupancy sensors	Grocery	2014	2054	1.03	0.17	0.00	0.20	16%	0.00	0.03	16%	0.31	0.02	2	0	0.19			0.00	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Grocery	2014	2054	1.02	0.16	0.01	0.21	17%	0.00	0.03	17%	0.35	0.03	2	0	0.15			0.00	0.00
NC NC	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Grocery Grocery	2014 2014	2054 2054	1.01 0.06	0.16 0.01	0.01 0.00	0.22	18% 0%	0.00	0.04	18% 0%	0.68 N/A	0.07 N/A	4 N/A	0 N/A	0.07 N/A	0.06	0.01	0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	Grocery	2014	2054	0.04	0.01	0.03	0.03	45%	0.00	0.00	23%	0.03	0.03	0	0	1.80			0.03	0.00
NC	5000	5002 Energy Star or Better PC	Grocery	2014	2054	0.02	0.01	0.01	0.04	63%	0.00	0.00	41%	0.06	0.04	0	0	0.90	0.00	0.00	0.00	0.00
NC NC	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.52	0.00	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Grocery	2014	2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	2.48	0.22	14	1	0.02			0.00	0.00
NC	5200	5200 Base Monitor, CRT	Grocery	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A 0.00	N/A	N/A 0	N/A 0	N/A	0.02	0.00	0.00	0.00
NC	5200	5201 Energy Star or Better Monitor - CRT	Grocery	2014	2054	0.01	0.00	0.01	0.01	56%	0.00	0.00	56%	0.00	0.00	U	U	20.00			0.01	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ic Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintag	ge			Moseura	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt NC	Number 5200	Number Measure 5202 Monitor Power Management Enabling - CRT	Type Grocery	Year 2014	Year 2054	0.01	MW 0.00	Savings 0.00	0.02	Savings 73%	Savings 0.00	0.00	Savings 65%	\$/kWH 0.05	\$/kWH 0.01	\$/kW	\$/kW	0.93	GWH	MW	0.00	0.00
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Grocery	2014	2054	0.01	0.00	0.00	0.02	76%	0.00	0.00	67%	0.52	0.03	3	0	0.10			0.00	0.00
NC NC	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Grocery	2014	2054 2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0% 20%	N/A 0.02	N/A	N/A 0	N/A 0	N/A 2.20	0.01	0.00	0.00	0.00
NC NC	5300	5301 Energy Star of Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Grocery Grocery	2014	2054	0.01	0.00	0.00	0.00	20% 31%	0.00	0.00	26%	0.02	0.02 0.10	3	1	0.19			0.00	0.00
NC	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Grocery	2014	2054	0.01	0.00	0.00	0.00	36%	0.00	0.00	27%	0.70	0.19	15	1	0.06			0.00	0.00
NC NC	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Grocery Grocery	2014 2014	2054 2054	0.05	0.01	0.00 0.01	0.00 0.01	0% 20%	0.00	0.00	0% 20%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 13.56	0.05	0.01	0.00 0.01	0.00
NC	5400	5402 Copier Power Management Enabling	Grocery	2014	2054	0.03	0.01	0.01	0.02	31%	0.00	0.00	26%	0.24	0.09	3	1	0.20			0.00	0.00
NC NC	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Grocery Grocery	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.20	0.01	0.00	0.00	0.00
NC	5500	5501 Multifunction Power Management Enabling	Grocery	2014	2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	36%	0.64	0.30	7	2	0.07			0.00	0.00
NC NC	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Grocery Grocery	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 35%	0.00	0.00	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 19.30	0.01	0.00	0.00	0.00
NC	5600	5601 Printer Power Management Enabling	Grocery	2014	2054	0.00	0.00	0.00	0.00	53%	0.00	0.00	35% 44%	0.00	0.05	2	0	0.34			0.00	0.00
NC	5700	5700 Base Data Center/Server Room	Grocery	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC NC	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Grocery Grocery	2014	2054 2054	0.02	0.00	0.00	0.00	10% 21%	0.00	0.00	10% 21%	0.00	0.00	0	0	67.16 27.34			0.00	0.00
NC	5700	5703 Data Center State of the Art practices	Grocery	2014	2054	0.02	0.00	0.00	0.01	26%	0.00	0.00	26%	0.00	0.00	0	Ō	14.18			0.00	0.00
NC NC	6000	6000 Base Water Heating 6007 Heat Trap	Grocery Grocery	2014 2014	2054 2054	0.30	0.05	0.00 0.02	0.00	0% 5%	0.00	0.00	0% 5%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.99	0.30	0.05	0.00 0.02	0.00
NC	6000	6002 High Efficiency Water Heater (electric)	Grocery	2014	2054	0.28	0.04	0.02	0.02	7%	0.00	0.00	7%	0.06	0.04	0	0	1.07			0.02	0.00
NC	6000	6006 Heat Recovery Unit	Grocery	2014	2054	0.13	0.02	0.15	0.17	55%	0.02	0.03	55%	0.07	0.07	0	0	0.82			0.00	0.00
NC NC	6000 6000	6004 Tankless Water Heater 6008 Solar Water Heater	Grocery Grocery	2014 2014	2054 2054	0.12 0.11	0.02	0.01 0.02	0.18 0.19	59% 65%	0.00	0.03	59% 65%	0.19 0.23	0.07	1	0 1	0.36 0.31			0.00	0.00
NC	6000	6001 Demand controlled circulating systems	Grocery	2014	2054	0.10	0.02	0.00	0.20	66%	0.00	0.03	66%	0.26	0.09	2	1	0.25			0.00	0.00
NC NC	6000 7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	Grocery Grocery	2014 2014	2054 2054	0.10 0.71	0.02	0.00	0.20 0.00	66% 0%	0.00	0.03	66% 0%	0.28 N/A	0.09 N/A	2 N/A	1 N/A	0.23 N/A	0.71	0.11	0.00	0.00
NC	7000	7001 Vending Misers (Refrigerated units)	Grocery	2014	2054	0.59	0.10	0.12	0.12	16%	0.01	0.01	8%	0.03	0.03	0	0	1.83	0.7 1	0.11	0.12	0.01
NC NC	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Grocery Grocery	2014 2014	2054 2054	0.53	0.10	0.06 0.00	0.18 0.00	25% 0%	0.00	0.01 0.00	12% 0%	0.05 N/A	0.03 N/A	1 N/A	0 N/A	1.00 N/A	0.00	0.00	0.06 0.00	0.00
NC	7100	7100 Base Non-Reingerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	Grocery	2014	2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	23%	0.43	0.43	5	5	0.11	0.00	0.00	0.00	0.00
NC	7200	7200 Base Oven	Grocery	2014	2054	0.16	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.16	0.02	0.00	0.00
NC NC	7300 7400	7300 Base Fryer 7400 Base Steamer	Grocery Grocery	2014	2054 2054	0.04	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.04	0.00	0.00	0.00
NC	7400	7401 Efficient Steamer	Grocery	2014	2054	0.02	0.00	0.05	0.05	69%	0.01	0.01	69%	0.04	0.04	0	0	1.63			0.05	0.01
NC NC	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	2014	2054 2054	0.12	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.04	N/A 0.04	N/A N/A	N/A N/A	N/A 1.19	0.12	0.00	0.00	0.00
NC	8100	8100 Base Heating, Other Electric	Grocery	2014	2054	0.05	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.00	0.00	0.00
NC	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Grocery	2014	2054	3.48	0.55	0.00	0.00	0% 0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A	3.48	0.55	0.00	0.00
NC NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Grocery Warehouse	2014	2054 2054	30.12	0.55 5.35	0.00	0.00	0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	30.12	5.35	0.00	0.00
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Warehouse	2020	2054	27.61	4.91	2.51	2.51	8%	0.45	0.45	8%	0.01	0.01	0	0	4.74			2.51	0.45
NC NC	1030 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Warehouse Warehouse	2020 2020	2054 2054	24.10 22.29	4.28 4.03	3.51 1.81	6.02 7.83	20% 26%	0.62 0.26	1.07 1.33	20% 25%	0.02 0.03	0.02 0.02	0	0	2.28 2.16			3.51 1.81	0.62 0.26
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Warehouse	2020	2054	21.66	4.00	0.63	8.46	28%	0.03	1.35	25%	0.05	0.02	1	0	0.98			0.00	0.00
NC NC	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Warehouse Warehouse	2020 2020	2054 2054	18.17 16.62	3.38	3.49 1.55	11.95 13.50	40% 45%	0.62 0.28	1.97 2.25	37% 42%	0.16 0.13	0.06 0.07	1	0	0.41 0.49			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Warehouse	2020	2054	0.21	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.21	0.04	0.00	0.00
NC	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Warehouse	2020	2054	0.18	0.03	0.02	0.02	10%	0.00	0.00	10%	0.02	0.02	0	0	3.67			0.02	0.00
NC NC	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Warehouse Warehouse	2020	2054 2054	0.17	0.03	0.01	0.04	17% 28%	0.00	0.01	16% 26%	0.03	0.02	0	0	2.33 1.63			0.01	0.00
NC	1130	1134 ROB 2L4' LED Tube, 2020	Warehouse	2020	2054	0.14	0.03	0.01	0.06	31%	0.00	0.01	30%	0.13	0.04	1	0	0.50			0.00	0.00
NC NC	1130 1130	1135 LED Troffer (base 2L4'T8), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Warehouse Warehouse	2020	2054 2054	0.13	0.02	0.01	0.08 80.0	37% 39%	0.00	0.01 0.01	36% 36%	0.16 0.10	0.06 0.06	1 2	0	0.40			0.00	0.00
NC	1200	1200 Base Other Fluorescent Fixture	Warehouse	2014	2054	0.03	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.01	0.00	0.00
NC	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Warehouse	2014	2054	0.03	0.01	0.00	0.00	8%	0.00	0.00	6%	0.02	0.02	0	0	4.07			0.00	0.00
NC NC	1200 1200	1201 ROB High Performance T8 (base other fluorescent) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Warehouse Warehouse	2014 2014	2054 2054	0.03	0.00	0.00	0.01 0.01	17% 23%	0.00	0.00	16% 17%	0.05 0.06	0.04 0.04	0 1	0	1.06 0.80			0.00	0.00
NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Warehouse	2020	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	1430 1530	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Warehouse Warehouse	2020	2054 2054	1.36 1.00	0.24	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	1.36	0.24	0.00	0.00
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Warehouse	2020	2054	0.19	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.19	0.03	0.00	0.00
NC	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020	Warehouse	2020 2020	2054 2054	0.14	0.02	0.05	0.05	28% 0%	0.01	0.01	28% 0%	0.03	0.03 N/A	0	0	1.60	0.25	0.04	0.05	0.01
NC NC	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Warehouse Warehouse	2020	2054	0.25 0.18	0.04	0.00	0.00	0% 26%	0.00	0.00 0.01	0% 26%	N/A 0.03	0.03	N/A 0	N/A 0	N/A 2.13	0.25	0.04	0.00 0.06	0.00
NC	1800	1800 BaseMetal Halide, 465W	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Warehouse Warehouse	2014 2014	2054 2054	0.07	0.01	0.00 0.05	0.00 0.05	0% 69%	0.00 0.01	0.00 0.01	0% 69%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.88	0.07	0.01	0.00 0.05	0.00 0.01
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Warehouse	2014	2054	0.16	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.16	0.00	0.00	0.00
NC	1900 1900	1902 LED Outdoor Area Lighting	Warehouse	2014 2014	2054 2054	0.08	0.00	0.08	0.08	52% 66%	0.00	0.00	52% 65%	0.05 0.33	0.05 0.11	4 27	4 8	1.10			0.08	0.00
NC NC	2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Warehouse Warehouse	2014	2054	0.06	0.00	0.02	0.00	0%	0.00	0.00	0%	0.33 N/A	0.11 N/A	N/A	N/A	0.17 N/A	0.00	0.00	0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Warehouse	2014	2054	2.75	2.62	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.75	2.62	0.00	0.00

APPENDIX H

Base Avoided Costs

		Existing Construction FIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintage	01710011								Total			Total		Marginal	Average	Marginal	Average	Total			00.12.	
Bas	e M	leasure	Building	Measure	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	Economic
Sgmt Nun		lumber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
NC NC	2100 2100	2113 Ceiling/roof Insulation - DX 2107 Cool Roof - DX	Warehouse Warehouse	2014 2014	2054 2054	2.63	2.50 2.31	0.13 0.20	0.13 0.32	5% 12%	0.12 0.19	0.12 0.31	5% 12%	0.03 0.07	0.03 0.05	0	0	4.53 1.54			0.13 0.20	0.12 0.19
NC	2100	2108 Optimize Controls - DX	Warehouse	2014	2054	2.40	2.30	0.04	0.36	13%	0.01	0.32	12%	0.08	0.05	0	0	0.65			0.00	0.00
NC NC	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2112 Aerosol Duct Sealing - DX	Warehouse Warehouse	2014	2054	1.84 1.73	1.78 1.67	0.55	0.91 1.02	33% 37%	0.52	0.84	32% 36%	0.26 1.71	0.18 0.35	0 2	0	0.46			0.00	0.00
NC	2100	2115 Window Film (Standard) - DX	Warehouse	2014	2054	1.66	1.60	0.07	1.02	40%	0.10	1.02	39%	1.52	0.43	2	0	0.07			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Warehouse	2014	2054	1.61	1.59	0.05	1.14	42%	0.01	1.03	39%	1.12	0.46	4	1	0.05			0.00	0.00
NC NC	2100 2100	2114 Duct/Pipe Insulation - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Warehouse Warehouse	2014	2054 2054	1.61 1.61	1.59 1.59	0.00	1.15 1.15	42% 42%	0.00	1.03	39% 39%	3.12 2.06	0.46	3 8	1	0.03			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	Warehouse	2014	2054	1.32	1.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.32	1.25	0.00	0.00
NC NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Warehouse Warehouse	2014	2054 2054	5.72 5.62	1.77 1.74	0.00 0.10	0.00 0.10	0% 2%	0.00	0.00	0% 2%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.29	5.72	1.77	0.00 0.10	0.00
NC	3000	3002 Variable Speed Drive Control, 5 HP	Warehouse	2014	2054	3.97	1.61	1.65	1.75	31%	0.13	0.16	9%	0.02	0.02	0	o	2.93			1.65	0.13
NC	3000	3003 Demand Controlled Ventilation	Warehouse	2014	2054	3.92	1.58	0.05	1.80	31%	0.03	0.19	11%	1.03	0.05	2	0	0.09			0.00	0.00
NC NC	3100 3200	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Warehouse Warehouse	2014	2054 2054	0.00 1.90	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 1.90	0.00	0.00	0.00
NC	3200	3202 Variable Speed Drive Control, 40 HP	Warehouse	2014	2054	1.34	0.54	0.56	0.56	29%	0.04	0.04	8%	0.01	0.01	0	0	5.73	1.00	0.00	0.56	0.04
NC	3200	3203 Air Handler Optimization, 40 HP	Warehouse	2014	2054	1.21	0.53	0.13	0.69	36%	0.01	0.05	9%	0.04	0.02	0	0	1.41			0.13	0.01
NC NC	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Warehouse Warehouse	2014	2054 2054	1.19 0.96	0.52	0.02	0.70	37% 0%	0.01	0.06	11% 0%	1.12 N/A	0.04 N/A	2 N/A	0 N/A	0.09 N/A	0.96	0.18	0.00	0.00
NC	4000	4018 Oversized Air Cooled Condenser	Warehouse	2014	2054	0.92	0.17	0.04	0.04	4%	0.01	0.01	4%	0.02	0.02	0	0	3.88	3.00	00	0.04	0.01
NC	4000	4010 Refrigeration Commissioning	Warehouse	2014	2054	0.92	0.17	0.00	0.05	5%	0.00	0.01	5%	0.03	0.02	0	0	1.50			0.00	0.00
NC NC	4000 4000	4006 Electronically commutated evaporator fan motor 4005 Evaporator fan controller for MT walk-ins	Warehouse Warehouse	2014	2054	0.86	0.17 0.17	0.06	0.10 0.10	10% 11%	0.01 0.00	0.01 0.01	8% 8%	0.06 0.10	0.04 0.04	1 1	0	1.00 0.57			0.06 0.00	0.01 0.00
NC	4000	4002 Strip curtains for walk-ins (built-up)	Warehouse	2014	2054	0.82	0.16	0.03	0.14	14%	0.01	0.02	11%	0.10	0.06	1	0	0.50			0.00	0.00
NC	4000	4001 High-efficiency fan motors	Warehouse	2014	2054	0.80	0.16	0.03	0.16	17%	0.00	0.03	14%	0.26	0.09	1	1	0.28	1 42	0.27	0.00	0.00
NC NC	4100 5000	4100 Base Self-Contained Refrigeration 5000 Base Desktop PC	Warehouse Warehouse	2014 2014	2054 2054	1.43 0.02	0.27	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	1.43 0.02	0.27	0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	Warehouse	2014	2054	0.01	0.00	0.01	0.01	44%	0.00	0.00	23%	0.01	0.01	0	0	6.36			0.01	0.00
NC	5000	5002 Energy Star or Better PC	Warehouse	2014	2054	0.01	0.00	0.00	0.01	63%	0.00	0.00	41%	0.02 N/A	0.01	0	0	3.27	0.00	0.00	0.00	0.00
NC NC	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Warehouse Warehouse	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 19%	0.00	0.00	0% 19%	0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.06	0.00	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Warehouse	2014	2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	0.69	0.06	4	0	0.08			0.00	0.00
NC NC	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Warehouse Warehouse	2014	2054 2054	0.03	0.01	0.00 0.02	0.00	0% 56%	0.00	0.00	0% 56%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 72.03	0.03	0.01	0.00 0.02	0.00
NC	5200	5202 Monitor Power Management Enabling - CRT	Warehouse	2014	2054	0.01	0.00	0.02	0.02	70%	0.00	0.00	63%	0.00	0.00	0	0	3.92			0.02	0.00
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Warehouse	2014	2054	0.01	0.00	0.00	0.02	73%	0.00	0.00	66%	0.13	0.01	1	0	0.40			0.00	0.00
NC NC	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Warehouse Warehouse	2014	2054	0.00	0.00	0.00	0.00	0% 20%	0.00	0.00	0% 20%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.90	0.00	0.00	0.00	0.00
NC	5300	5302 Monitor Power Management Enabling - LCD	Warehouse	2014	2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	0.01	0.01	1	0	0.79			0.00	0.00
NC	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Warehouse	2014	2054	0.00	0.00	0.00	0.00	27%	0.00	0.00	22%	0.17	0.04	4	0	0.26			0.00	0.00
NC NC	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Warehouse Warehouse	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 12%	0.00	0.00	0% 12%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 53.95	0.01	0.00	0.00	0.00
NC	5400	5402 Copier Power Management Enabling	Warehouse	2014	2054	0.01	0.00	0.00	0.00	15%	0.00	0.00	14%	0.05	0.00	1	0	0.94			0.00	0.00
NC	5500	5500 Base Multifunction	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	5500 5500	5502 ENERGY STAR Multi-Function Device 5501 Multifunction Power Management Enabling	Warehouse Warehouse	2014	2054 2054	0.00	0.00	0.00	0.00	25% 32%	0.00	0.00	25% 29%	0.00	0.00	0	0	15.12 0.36			0.00	0.00
NC	5600	5600 Base Printer	Warehouse	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.01	0.00	0.00
NC	5600	5602 ENERGY STAR Printer	Warehouse	2014	2054	0.02	0.00	0.01	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	69.50			0.01	0.00
NC NC	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Warehouse Warehouse	2014	2054 2054	0.02	0.00	0.00	0.01	41% 0%	0.00	0.00	38% 0%	0.03 N/A	0.01 N/A	0 N/A	0 N/A	1.67 N/A	0.44	0.07	0.00	0.00
NC	5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Warehouse	2014	2054	0.40	0.07	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	0	0	107.17	U. T1	0.07	0.04	0.00
NC	5700	5702 Data Center Best Practices	Warehouse	2014	2054	0.35	0.06	0.05	0.09	21%	0.01	0.02	21%	0.00	0.00	0	0	43.63			0.05	0.01
NC NC	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Warehouse Warehouse	2014 2014	2054 2054	0.33	0.05 0.06	0.02	0.11 0.00	26% 0%	0.00	0.02	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	22.63 N/A	0.41	0.06	0.02 0.00	0.00
NC	6000	6006 Heat Recovery Unit	Warehouse	2014	2054	0.38	0.06	0.03	0.03	7%	0.00	0.00	7%	0.14	0.14	1	1	0.42	V1	0.00	0.00	0.00
NC	6000	6007 Heat Trap	Warehouse	2014	2054	0.36	0.06	0.02	0.05	11%	0.00	0.01	11%	0.25	0.19	2	1	0.24			0.00	0.00
NC NC	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Warehouse Warehouse	2014 2014	2054 2054	0.36	0.06	0.01	0.05 0.08	13% 20%	0.00	0.01 0.01	13% 20%	0.52 0.79	0.23 0.42	3 5	1 3	0.13			0.00	0.00
NC	6000	6008 Solar Water Heater	Warehouse	2014	2054	0.33	0.03	0.03	0.08	47%	0.02	0.03	47%	0.79	0.42	6	5	0.09			0.00	0.00
NC	6000	6003 Hot Water Pipe Insulation	Warehouse	2014	2054	0.21	0.03	0.00	0.20	48%	0.00	0.03	48%	1.43	0.73	9	5	0.05			0.00	0.00
NC NC	6000 7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Warehouse Warehouse	2014	2054 2054	0.21	0.03	0.00	0.20	49% 0%	0.00	0.03	49% 0%	1.60 N/A	0.74 N/A	10 N/A	5 N/A	0.04 N/A	0.00	0.00	0.00	0.00
NC	7100	7100 Base Non-Refrigerated Vending Machines	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	7200	7200 Base Oven	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7300 7400	7300 Base Fryer 7400 Base Steamer	Warehouse Warehouse	2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	8100	8100 Base Heating, Other Electric	Warehouse	2014	2054	1.39	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.39	0.00	0.00	0.00
NC NC	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Warehouse Warehouse	2014 2014	2054 2054	8.68 8.68	1.64 1.64	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	8.68	1.64	0.00	0.00
NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	School	2020	2054	5.21	0.70	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.21	0.70	0.00	0.00
NC	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	School	2020	2054	5.20	0.70	0.01	0.01	0%	0.00	0.00	0%	0.02	0.02	0	0	2.88			0.01	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
	tage	THE SOLLET ANALTSIS							Total			Total		Marginal	Average	Marginal					001121	
	Base	Measure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity	Capacity	Resource Cost Test	Base	Base	Economic	Economic
		Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
NC NC	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	School School	2020 2020	2054 2054	4.67 4.32	0.63	0.53 0.35	0.55 0.90	11% 17%	0.07 0.04	0.07 0.11	10% 16%	0.02 0.03	0.02 0.02	0	0	2.79 2.25			0.53 0.35	0.07 0.04
NC	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	School	2020	2054	3.77	0.52	0.55	1.45	28%	0.07	0.19	26%	0.05	0.03	0	0	1.24			0.55	0.07
NC NC		1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	School School	2020 2020	2054 2054	3.16 2.89	0.44	0.61 0.27	2.05 2.32	39% 45%	0.08 0.04	0.27 0.30	38% 43%	0.31 0.26	0.12 0.13	2	1	0.22 0.27			0.00	0.00
NC		1035 LED Holler (base 4L4 16), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	School	2020	2054	2.70	0.40	0.27	2.52	48%	0.04	0.30	44%	0.26	0.13	5	1	0.27			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	School	2020	2054	0.33	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.33	0.04	0.00	0.00
NC NC		1131 ROB 2L4' High Performance T8 (86 W), 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	School School	2020 2020	2054 2054	0.29	0.04	0.03	0.03	10% 11%	0.00	0.00	10% 10%	0.03	0.03	0	0	2.21 1.74			0.03	0.00
NC		1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	School	2020	2054	0.29	0.04	0.00	0.03	17%	0.00	0.00	16%	0.03	0.03	0	0	1.74			0.00	0.00
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	School	2020	2054	0.24	0.03	0.03	0.09	28%	0.00	0.01	26%	0.06	0.04	0	0	0.98			0.00	0.00
NC NC	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	School School	2020 2020	2054 2054	0.23	0.03	0.01 0.02	0.10 0.12	31% 37%	0.00	0.01 0.02	30% 36%	0.26 0.32	0.07 0.11	2	1	0.27 0.21			0.00	0.00
NC		1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	School	2020	2054	0.19	0.03	0.02	0.12	41%	0.00	0.02	37%	0.32	0.11	8	1	0.21			0.00	0.00
NC		1200 Base Other Fluorescent Fixture	School	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00	0.00
NC NC		1203 Lighting Control Tuneup (base other fluorescent fixture) 1201 ROB High Performance T8 (base other fluorescent)	School School	2014 2014	2054 2054	0.02	0.00	0.00	0.00	2% 10%	0.00	0.00	1% 9%	0.02 0.09	0.02 0.08	0 1	0	2.38 0.69			0.00	0.00
NC		1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	School	2014	2054	0.02	0.00	0.00	0.00	35%	0.00	0.00	24%	0.09	0.08	5	2	0.09			0.00	0.00
NC	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	School	2014	2054	0.02	0.00	0.00	0.01	40%	0.00	0.00	28%	0.29	0.17	3	2	0.21			0.00	0.00
NC NC	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	School School	2020 2020	2054 2054	0.43	0.06	0.00 0.36	0.00 0.36	0% 83%	0.00 0.05	0.00 0.05	0% 83%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.21	0.43	0.06	0.00 0.36	0.00 0.05
NC		1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	School	2020	2054	0.07	0.01	0.00	0.00	0%	0.05	0.00	0%	N/A	N/A	N/A	N/A	9.21 N/A	0.16	0.02	0.00	0.00
NC	1430	1432 LEDs (base incandescent A-line 72W) 2020	School	2020	2054	0.03	0.00	0.13	0.13	81%	0.02	0.02	81%	0.01	0.01	0	0	7.78			0.13	0.02
NC NC		1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	School School	2020 2020	2054 2054	0.11	0.02	0.00 0.09	0.00	0% 74%	0.00 0.01	0.00 0.01	0% 74%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.79	0.11	0.02	0.00	0.00 0.01
NC		1630 Base CFL 18W to screw-in replacement 2020	School	2020	2054	4.78	0.65	0.09	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	5.79 N/A	4.78	0.65	0.09	0.00
NC	1630	1631 LED screw-in replacement (base CFL 18W) 2020	School	2020	2054	3.46	0.47	1.32	1.32	28%	0.18	0.18	28%	0.06	0.06	0	0	0.94			0.00	0.00
NC		1730 Base CFL 23W to screw-in replacement 2020	School	2020	2054	6.11	0.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	6.11	0.83	0.00	0.00
NC NC	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	School School	2020 2014	2054 2054	4.52 0.68	0.61	1.59 0.00	1.59 0.00	26% 0%	0.21	0.21	26% 0%	0.05 N/A	0.05 N/A	0 N/A	N/A	1.25 N/A	0.68	0.09	1.59 0.00	0.21
NC	1800	1801 T5 (240W) (base metal halide)	School	2014	2054	0.45	0.06	0.23	0.23	34%	0.03	0.03	34%	0.02	0.02	0	0	4.22			0.23	0.03
NC		1805 High Performance Lighting R/R - 25% Savings (base metal halide)	School	2014	2054	0.42	0.06	0.03	0.26	39%	0.00	0.03	38%	0.02	0.02	0	0	2.67			0.03	0.00
NC NC		1806 Occupancy Sensor, High Bay T5 1850 Base CFL Exit Sign	School School	2014 2014	2054 2054	0.40	0.06	0.01 0.00	0.28 0.00	41% 0%	0.00	0.04	38% 0%	0.05 N/A	0.02 N/A	N/A	0 N/A	1.02 N/A	0.22	0.03	0.01 0.00	0.00
NC	1850	1851 LED Exit Sign	School	2014	2054	0.10	0.01	0.12	0.12	55%	0.02	0.02	55%	0.03	0.03	0	0	1.61			0.12	0.02
NC		1900 Base Outdoor High Pressure Sodium 250W Lamp	School	2014	2054	7.24	0.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.24	0.29	0.00	0.00
NC NC		1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	School School	2014 2014	2054 2054	5.86 2.82	0.11 -0.01	1.37 3.04	1.37 4.42	19% 61%	0.17 0.12	0.17	60% 102%	0.05 0.10	0.05	0	0	1.47 0.56			1.37 0.00	0.17
NC	1900	1903 Bi-Level LED Outdoor Lighting	School	2014	2054	1.99	-0.04	0.83	5.24	72%	0.03	0.33	113%	0.67	0.18	19	3	0.09			0.00	0.00
NC		2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	School	2014	2054	15.88	8.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.88	8.15	0.00	0.00
NC NC		2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	School School	2014 2014	2054 2054	14.52 14.46	7.46 7.44	1.36 0.06	1.36 1.42	9% 9%	0.70 0.02	0.70 0.71	9% 9%	0.06 0.05	0.06 0.06	0	0	1.64 1.31			1.36 0.06	0.70
NC		2013 High Efficiency Chiller Motors	School	2014	2054	14.45	7.43	0.01	1.43	9%	0.01	0.72	9%	0.09	0.06	0	0	1.06			0.01	0.01
NC	2000	2006 VSD for Chiller Pumps and Towers	School	2014	2054	14.42	7.42	0.03	1.46	9% 14%	0.01	0.73	9%	0.07	0.06	0	0	0.98			0.00	0.00
NC NC		2003 EMS - Chiller 2004 Cool Roof - Chiller	School School	2014 2014	2054 2054	13.64 13.38	7.31 7.18	0.78	2.24 2.50	16%	0.11 0.13	0.84 0.97	10% 12%	0.12 0.19	0.08	0	0	0.54			0.00	0.00
NC	2000	2002 Window Film (Standard) - Chiller	School	2014	2054	13.31	7.14	0.07	2.57	16%	0.03	1.01	12%	0.22	0.09	Ö	Ö	0.37			0.00	0.00
NC		2012 Duct Testing/Sealing	School	2014	2054	11.10	6.01	2.21	4.77	30%	1.13	2.14	26%	0.31	0.19	1	0	0.32			0.00	0.00
NC NC		2008 New Economizer - Chiller 2011 Duct/Pipe Insulation - Chiller	School School	2014 2014	2054 2054	9.92 9.86	5.84 5.81	1.18 0.06	5.95 6.01	38% 38%	0.17 0.03	2.31 2.34	28% 29%	0.36 5.08	0.23 0.27	2 10	1	0.16 0.02			0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	School	2014	2054	24.78	12.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	24.78	12.72	0.00	0.00
NC		2113 Ceiling/roof Insulation - DX	School	2014	2054	24.76	12.71	0.02	0.02	0% 23%	0.01	0.01	0%	0.02	0.02	0	0	4.24			0.02	0.01
NC NC	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	School School	2014 2014	2054 2054	19.07 19.06	9.79 9.79	5.70 0.00	5.71 5.71	23%	2.92 0.00	2.93 2.93	23% 23%	0.05 0.16	0.05 0.05	0	0	1.73 0.35			5.70 0.00	2.92 0.00
NC	2100	2115 Window Film (Standard) - DX	School	2014	2054	18.89	9.70	0.18	5.89	24%	0.09	3.02	24%	0.23	0.06	ó	ō	0.34			0.00	0.00
NC		2105 DX Tune Up/ Advanced Diagnostics	School	2014	2054	18.84	9.69	0.05	5.94	24%	0.01	3.04	24%	0.19	0.06	1	0	0.33			0.00	0.00
NC NC	2100 2100	2108 Optimize Controls - DX 2112 Aerosol Duct Sealing - DX	School School	2014 2014	2054 2054	18.55 17.57	9.64 9.14	0.29 0.98	6.23 7.21	25% 29%	0.04 0.51	3.08 3.58	24% 28%	0.16 0.35	0.06 0.10	1	0	0.31 0.28			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	School	2014	2054	17.41	9.12	0.15	7.36	30%	0.02	3.60	28%	0.21	0.10	1	0	0.25			0.00	0.00
NC	2100	2107 Cool Roof - DX	School	2014	2054	17.11	8.96	0.31	7.67	31%	0.16	3.76	30%	0.39	0.12	1	0	0.20			0.00	0.00
NC NC	2100 2100	2111 Economizer Repair - DX 2109 Economizer - DX	School School	2014 2014	2054 2054	17.07 16.99	8.93 8.92	0.04	7.71 7.79	31% 31%	0.03 0.01	3.79 3.80	30% 30%	0.86 1.25	0.12 0.13	1 9	0	0.09 0.04			0.00	0.00
NC		2114 Duct/Pipe Insulation - DX	School	2014	2054	16.78	8.82	0.20	7.79	32%	0.10	3.90	31%	4.66	0.13	9	1	0.02			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	School	2014	2054	17.76	9.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	17.76	9.12	0.00	0.00
NC NC		2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	School School	2014 2014	2054 2054	15.57 24.65	7.99 12.65	2.20 0.00	2.20 0.00	12% 0%	1.13 0.00	1.13 0.00	12% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	2.05 N/A	24.65	12.65	2.20 0.00	1.13 0.00
NC		2301 HE PTAC, EER=9.6, 1 ton	School	2014	2054	24.65	10.94	3.34	3.34	14%	1.71	1.71	14%	0.11	0.11	0 0	N/A 0	0.81	24.00	12.00	0.00	0.00
NC	2300	2302 Occupancy Sensor (hotels)	School	2014	2054	17.98	8.81	3.33	6.66	27%	2.13	3.85	30%	0.35	0.23	1	0	0.25			0.00	0.00
NC	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	School	2014 2014	2054	5.22	1.02	0.00	0.00	0%	0.00	0.00	0% 4%	N/A	N/A	N/A	N/A 1	N/A	5.22	1.02	0.00	0.00
NC NC		3002 Variable Speed Drive Control, 5 HP 3001 Fan Motor, 5hp, 1800rpm, 89.5%	School School	2014	2054 2054	4.45 4.38	0.98	0.76	0.76	15% 16%	0.04 0.01	0.04 0.05	4% 5%	0.03	0.03 0.04	1 0	1	1.71 1.24			0.76	0.04
NC	3000	3003 Demand Controlled Ventilation	School	2014	2054	3.72	0.74	0.65	1.49	29%	0.23	0.28	28%	1.68	0.76	5	4	0.05			0.00	0.00
NC		3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	School	2014	2054	13.96	2.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.96	2.72	0.00	0.00
NC	3100	3102 Variable Speed Drive Control, 15 HP	School	2014	2054	11.92	2.62	2.04	2.04	15%	0.10	0.10	4%	0.04	0.04	1	1	1.42			2.04	0.10

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
		Measure Number Measure	Building	Start	End Year	Total GWH	Total MW	GWH Savings	Savings	GWH	MW	Savings MW	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic MW
NC	Number 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Type School	2014	2054	10.25	2.33	1.67	3.71	Savings 27%	Savings 0.30	0.40	Savings 15%	0.06	0.05	0	0	1.21	GWH	IVI VV	1.67	0.30
NC	3100	3103 Air Handler Optimization, 15 HP	School	2014	2054	9.26	2.28	1.00	4.71	34%	0.05	0.45	16%	0.06	0.05	1	1	0.81			0.00	0.00
NC NC	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3105 Energy Recovery Ventilation (ERV)	School School	2014 2014	2054 2054	9.17 8.69	2.26	0.09 0.48	4.80 5.28	34% 38%	0.02 0.17	0.47 0.63	17% 23%	0.15 0.56	0.05 0.10	1 2	1	0.48 0.16			0.00	0.00
NC	3100	3107 Demand Controlled Ventilation	School	2014	2054	7.39	1.64	1.30	6.58	47%	0.45	1.09	40%	2.26	0.53	6	3	0.04			0.00	0.00
NC	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	School	2014	2054	5.82	1.14	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.82	1.14	0.00	0.00
NC NC	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	School School	2014 2014	2054 2054	4.97 4.96	1.09 1.09	0.85 0.01	0.85 0.86	15% 15%	0.04	0.04 0.04	4% 4%	0.01 0.03	0.01 0.01	0	0	9.91 2.75			0.85 0.01	0.04
NC	3200	3203 Air Handler Optimization, 40 HP	School	2014	2054	4.48	1.07	0.48	1.34	23%	0.02	0.07	6%	0.05	0.02	1	ő	0.94			0.00	0.00
NC	3200	3204 Demand Controlled Ventilation	School	2014	2054	3.81	0.83	0.67	2.01	35%	0.23	0.30	27%	1.83	0.62	5	4	0.05	0.00	0.00	0.00	0.00
NC NC	4000 4100	4000 Base Built-Up Refrigeration System 4100 Base Self-Contained Refrigeration	School School	2014 2014	2054 2054	0.00 7.25	0.00 1.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 7.25	0.00 1.00	0.00	0.00
NC	4100	4103 Night covers for display cases (self-contained)	School	2014	2054	7.24	1.00	0.01	0.01	0%	0.00	0.00	0%	0.00	0.00	0	0	23.21			0.01	0.00
NC	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	School	2014	2054	7.14	0.99	0.10	0.11	1%	0.01	0.01	1%	0.00	0.00	0	0	14.95			0.10	0.01
NC NC	4100 4100	4109 Energy-Star Freezer, glass door 4106 Energy-Star Refrigerator, solid door	School School	2014 2014	2054 2054	7.08 6.95	0.98	0.06 0.13	0.16 0.30	2% 4%	0.01 0.02	0.02 0.04	2% 4%	0.01 0.01	0.00 0.01	0	0	9.34 5.64			0.06 0.13	0.01 0.02
NC	4100	4107 Energy-Star Freezer, solid door	School	2014	2054	6.92	0.96	0.02	0.32	4%	0.00	0.04	4%	0.01	0.01	0	0	3.70			0.02	0.00
NC NC	4100 4100	4108 Energy-Star Refrigerator, glass door	School School	2014 2014	2054 2054	6.88	0.95	0.04	0.36	5% 7%	0.01	0.05	5% 7%	0.02	0.01	0	0	3.06 2.03			0.04	0.01
NC	4100	4110 Energy Star Ice Machines 4112 Reach-in unit occupancy sensors	School	2014	2054	6.77	0.94	0.00	0.48	7%	0.02	0.07	7%	0.03	0.01	2	0	0.22			0.00	0.02
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	School	2014	2054	6.76	0.93	0.01	0.49	7%	0.00	0.07	7%	0.29	0.02	2	0	0.18			0.00	0.00
NC NC	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	School School	2014 2014	2054 2054	6.74 2.19	0.93 0.19	0.02	0.51	7% 0%	0.00	0.07	7% 0%	0.93 N/A	0.05 N/A	7 N/A	0 N/A	0.05 N/A	2.19	0.19	0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	School	2014	2054	1.20	0.13	0.99	0.99	45%	0.04	0.04	23%	0.01	0.01	0	0	3.81	2.15	0.19	0.00	0.04
NC	5000	5002 Energy Star or Better PC	School	2014	2054	0.85	0.11	0.35	1.33	61%	0.03	0.07	39%	0.02	0.02	0	0	1.96			0.35	0.03
NC NC	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	School School	2014 2014	2054 2054	0.30 0.24	0.03	0.00 0.06	0.00 0.06	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.20	0.30	0.03	0.00 0.06	0.00
NC	5100	5101 Laptop Network Power Management Enabling	School	2014	2054	0.24	0.02	0.00	0.06	21%	0.00	0.00	21%	1.13	0.10	13	1	0.04			0.00	0.00
NC	5200	5200 Base Monitor, CRT	School	2014	2054	1.28	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.28	0.11	0.00	0.00
NC NC	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	School School	2014 2014	2054 2054	0.56	0.05	0.72 0.16	0.72 0.87	56% 68%	0.06 0.01	0.06 0.07	56% 62%	0.00	0.00	0	0	41.34 2.61			0.72 0.16	0.06 0.01
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	School	2014	2054	0.37	0.04	0.03	0.90	71%	0.00	0.07	65%	0.20	0.00	2	0	0.24			0.00	0.00
NC	5300	5300 Base Monitor, LCD	School	2014	2054	0.31	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.31	0.03	0.00	0.00
NC NC	5300 5300	5301 Energy Star or Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	School School	2014 2014	2054 2054	0.26 0.25	0.02	0.06 0.01	0.06 0.06	18% 20%	0.00	0.00 0.01	18% 19%	0.01 0.09	0.01 0.02	0	0	4.68 0.48			0.06	0.00
NC	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	School	2014	2054	0.23	0.02	0.02	0.08	26%	0.00	0.01	20%	0.27	0.02	12	1	0.16			0.00	0.00
NC	5400	5400 Base Copier	School	2014	2054	0.61	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.61	0.05	0.00	0.00
NC NC	5400 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	School School	2014 2014	2054 2054	0.57 0.55	0.05	0.03 0.02	0.03	6% 10%	0.00	0.00	6% 8%	0.00	0.00	0	0	33.22 0.60			0.03	0.00
NC	5500	5500 Base Multifunction	School	2014	2054	0.07	0.01	0.02	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.07	0.01	0.00	0.00
NC	5500	5502 ENERGY STAR Multi-Function Device	School	2014	2054	0.05	0.00	0.02	0.02	25%	0.00	0.00	25%	0.01	0.01	0	0	8.70			0.02	0.00
NC NC	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	School School	2014 2014	2054 2054	0.04 1.02	0.00	0.01 0.00	0.03	39% 0%	0.00	0.00	32% 0%	0.24 N/A	0.09 N/A	6 N/A	1 N/A	0.19 N/A	1.02	0.09	0.00	0.00
NC	5600	5602 ENERGY STAR Printer	School	2014	2054	0.66	0.06	0.35	0.35	35%	0.03	0.03	35%	0.00	0.00	0	0	39.98	1.02	0.03	0.35	0.03
NC	5600	5601 Printer Power Management Enabling	School	2014	2054	0.54	0.05	0.12	0.48	47%	0.01	0.04	41%	0.05	0.01	1	0	0.88			0.00	0.00
NC NC	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	School School	2014 2014	2054 2054	7.34 6.61	0.63	0.00 0.73	0.00 0.73	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 99.28	7.34	0.63	0.00 0.73	0.00
NC	5700	5702 Data Center Best Practices	School	2014	2054	5.77	0.50	0.84	1.58	21%	0.07	0.14	21%	0.00	0.00	0	ő	40.42			0.84	0.07
NC	5700 6000	5703 Data Center State of the Art practices	School	2014 2014	2054 2054	5.45	0.47	0.32	1.90	26% 0%	0.03	0.16	26% 0%	0.00 N/A	0.00 N/A	0	0	20.96	0.40	0.47	0.32	0.03
NC NC	6000	6000 Base Water Heating 6007 Heat Trap	School School	2014	2054	2.13	0.17	0.00	0.00	0% 5%	0.00	0.00	0% 5%	N/A 0.04	N/A 0.04	N/A 1	N/A 1	N/A 1.41	2.13	0.17	0.00	0.00
NC	6000	6002 High Efficiency Water Heater (electric)	School	2014	2054	1.98	0.15	0.04	0.15	7%	0.00	0.01	7%	0.08	0.05	1	1	0.75			0.00	0.00
NC	6000	6006 Heat Recovery Unit	School	2014	2054	1.79	0.14	0.19	0.34	16% 19%	0.02	0.03	16% 19%	0.08	0.07	1	1	0.70			0.00	0.00
NC NC	6000 6000	6001 Demand controlled circulating systems 6004 Tankless Water Heater	School School	2014 2014	2054 2054	1.72 1.59	0.13	0.07	0.41 0.54	25%	0.01 0.01	0.03 0.04	25%	0.11 0.14	0.07 0.09	2	1	0.57 0.46			0.00	0.00
NC	6000	6008 Solar Water Heater	School	2014	2054	1.48	0.12	0.11	0.65	31%	0.01	0.05	31%	0.17	0.10	2	1	0.39			0.00	0.00
NC NC	6000 7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	School School	2014 2014	2054 2054	1.47 1.48	0.11 0.13	0.02 0.00	0.67 0.00	31% 0%	0.00	0.05 0.00	31% 0%	0.18 N/A	0.10 N/A	2 N/A	1 N/A	0.33 N/A	1.48	0.13	0.00	0.00
NC	7000	7000 Base Reinigerated Vending Machines 7001 Vending Misers (Refrigerated units)	School	2014	2054	1.25	0.13	0.00	0.00	15%	0.00	0.00	8%	0.03	0.03	1	1	1.81	1.40	0.13	0.00	0.00
NC	7000	7002 Vending Misers (Refrigerated glass-front units)	School	2014	2054	1.13	0.11	0.12	0.35	24%	0.01	0.02	12%	0.05	0.03	1	1	0.99			0.00	0.00
NC NC	7100 7100	7100 Base Non-Refrigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	School School	2014 2014	2054 2054	0.05	0.00	0.00 0.02	0.00	0% 44%	0.00	0.00	0% 22%	N/A 0.43	N/A 0.43	N/A 10	N/A 10	N/A 0.11	0.05	0.00	0.00	0.00
NC	7100	7101 Vending Misers (Nort-Reingerated) 7200 Base Oven	School	2014	2054	2.21	0.00	0.02	0.02	0%	0.00	0.00	0%	0.43 N/A	0.43 N/A	N/A	N/A	N/A	2.21	0.16	0.00	0.00
NC	7200	7201 Convection Oven	School	2014	2054	1.70	0.13	0.51	0.51	23%	0.04	0.04	23%	0.41	0.41	5	5	0.14			0.00	0.00
NC NC	7300 7400	7300 Base Fryer 7400 Base Steamer	School School	2014 2014	2054 2054	0.06	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.06 0.48	0.00	0.00	0.00
NC NC	7400	7400 Base Steamer 7401 Efficient Steamer	School	2014	2054	0.48	0.04	0.00	0.00	63%	0.00	0.00	63%	0.17	0.17	N/A 2	N/A 2	0.34	0.40	0.04	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	School	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School	2014	2054	0.02	0.00	0.00	0.00	6% 0%	0.00	0.00	0% 0%	0.06 N/A	0.06 N/A	N/A	N/A	0.99	164	0.00	0.00	0.00
NC NC	8100 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	School School	2014 2014	2054 2054	1.64 8.43	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	1.64 8.43	0.00	0.00	0.00
NC	9500	9501 Xmisc	School	2014	2054	8.43	0.73	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Health	2020	2054	3.92	0.60	0.00	0.00	0% 0%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	3.92	0.60	0.00	0.00
NC	1030	1036 Lighting Control Tuneup (base 4L4T8), 2020	Health	2020	2054	3.90	0.60	0.01	0.01	U%	0.00	0.00	0%	0.02	0.02	0	U	2.05			0.01	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	age			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	
Sgm NC	t Number 1030	Number Measure 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Type Health	Year 2020	Year 2054	3.60	MW 0.56	Savings 0.30	0.31	Savings 8%	Savings 0.04	0.04	Savings 6%	\$/kWH 0.04	\$/kWH 0.03	\$/kW 0	\$/kW	1.75	GWH	MW	0.30	0.04
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Health	2020	2054	3.23	0.50	0.37	0.69	18%	0.06	0.09	16%	0.04	0.04	0	0	1.37			0.37	0.06
NC	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Health	2020	2054	2.82	0.44	0.41	1.10	28%	0.06	0.16	26%	0.08	0.05	1	0	0.66			0.00	0.00
NC NC	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Health Health	2020 2020	2054 2054	2.62	0.43	0.20	1.30 1.72	33% 44%	0.01 0.06	0.16 0.23	27% 38%	0.14 0.50	0.07 0.17	4	1	0.34 0.12			0.00	0.00
NC	1030	1035 LED Troffer (base 4L4'T8), 2020	Health	2020	2054	2.01	0.34	0.19	1.91	49%	0.03	0.26	43%	0.42	0.20	3	1	0.15			0.00	0.00
NC NC	1130 1130	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Health Health	2020 2020	2054 2054	0.47	0.07	0.00 0.05	0.00 0.05	0% 10%	0.00 0.01	0.00 0.01	0% 10%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.18	0.47	0.07	0.00 0.05	0.00 0.01
NC NC	1130	1131 ROB 2L4 High Performance 18 (86 W), 2020 1136 Lighting Control Tuneup (base 2L4 T8), 2020	Health	2020	2054	0.42	0.06	0.05	0.05	11%	0.01	0.01	10%	0.05	0.05	1	0	0.87			0.05	0.01
NC	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Health	2020	2054	0.39	0.06	0.03	0.08	18%	0.00	0.01	16%	0.08	0.06	1	0	0.74			0.00	0.00
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Health	2020	2054	0.34	0.05	0.05	0.13	28%	0.01	0.02	26%	0.10	0.08	1	1	0.52			0.00	0.00
NC NC	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Health Health	2020 2020	2054 2054	0.32	0.05	0.02	0.15 0.18	32% 37%	0.00	0.02 0.03	30% 36%	0.38 0.48	0.11 0.17	3	1	0.16 0.13			0.00	0.00
NC	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Health	2020	2054	0.27	0.05	0.02	0.20	42%	0.00	0.03	37%	0.29	0.18	8	1	0.17			0.00	0.00
NC NC	1200 1200	1200 Base Other Fluorescent Fixture	Health Health	2014 2014	2054 2054	0.13	0.02	0.00	0.00	0% 1%	0.00	0.00	0% 1%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.52	0.13	0.02	0.00	0.00
NC	1200	1203 Lighting Control Tuneup (base other fluorescent fixture) 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Health	2014	2054	0.13	0.02	0.00	0.00	9%	0.00	0.00	7%	0.01	0.01	1	1	0.65			0.00	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	Health	2014	2054	0.10	0.02	0.01	0.02	18%	0.00	0.00	16%	0.16	0.12	1	1	0.34			0.00	0.00
NC NC	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Health Health	2014 2020	2054 2054	0.08	0.02	0.02	0.04	34% 0%	0.00	0.00	20% 0%	0.17 N/A	0.14 N/A	5 N/A	2 N/A	0.29 N/A	0.24	0.04	0.00	0.00
NC NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Health	2020	2054	0.24	0.04	0.00	0.00	83%	0.00	0.00	83%	0.01	0.01	N/A 0	N/A 0	5.09	0.24	0.04	0.00	0.00
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Health	2020	2054	0.09	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.01	0.00	0.00
NC	1430	1432 LEDs (base incandescent A-line 72W) 2020	Health	2020	2054	0.02	0.00	0.07	0.07	82%	0.01	0.01	82%	0.01	0.01	0	0	4.30			0.07	0.01
NC NC	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Health Health	2020 2020	2054 2054	0.06	0.01	0.00 0.05	0.00 0.05	0% 75%	0.00	0.00 0.01	0% 75%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.20	0.06	0.01	0.00 0.05	0.00 0.01
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Health	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.01	0.00	0.00
NC	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Health	2020	2054	0.07	0.01	0.03	0.03	28%	0.00	0.00	28%	0.11	0.11	1	1	0.52			0.00	0.00
NC NC	1730 1730	1730 Base CFL 23W to screw-in replacement 2020	Health Health	2020 2020	2054 2054	0.12	0.02	0.00	0.00	0% 26%	0.00	0.00	0% 26%	N/A 0.08	N/A 0.08	N/A	N/A	N/A 0.69	0.12	0.02	0.00	0.00
NC NC	1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Health	2020	2054	0.09	0.01	0.03	0.03	26%	0.00	0.00	26%	0.08 N/A	0.08 N/A	N/A	N/A	0.69 N/A	0.00	0.00	0.00	0.00
NC	1850	1850 Base CFL Exit Sign	Health	2014	2054	0.11	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.02	0.00	0.00
NC	1850 1900	1851 LED Exit Sign	Health	2014	2054	0.09	0.01	0.01	0.01	12%	0.00	0.00	12%	0.03	0.03	0	0	1.71			0.01	0.00
NC NC	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Health Health	2014 2014	2054 2054	0.35	0.00	0.00	0.00	0% 8%	0.00	0.00	0% 25%	N/A 0.08	N/A 0.08	N/A 3	N/A 3	N/A 0.78	0.35	0.00	0.00	0.00
NC	1900	1902 LED Outdoor Area Lighting	Health	2014	2054	0.16	0.00	0.17	0.19	56%	0.00	0.00	73%	0.17	0.15	18	12	0.34			0.00	0.00
NC	1900	1903 Bi-Level LED Outdoor Lighting	Health	2014	2054	0.11	0.00	0.05	0.24	69%	0.00	0.00	85%	1.07	0.33	127	28	0.05			0.00	0.00
NC NC	2000 2100	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2100 Base DX Packaged System, EER=10.3, 10 tons	Health Health	2014 2014	2054 2054	0.00 2.64	0.00 1.45	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 2.64	0.00 1.45	0.00	0.00
NC	2100	2100 Dase DX Packaged System, EER=10.3, 10 tons 2102 DX Packaged System, EER=13.4, 10 tons	Health	2014	2054	2.03	1.12	0.61	0.61	23%	0.00	0.33	23%	0.03	0.03	0	0	2.75	2.04	1.43	0.61	0.33
NC	2100	2105 DX Tune Up/ Advanced Diagnostics	Health	2014	2054	2.00	1.11	0.03	0.64	24%	0.01	0.34	24%	0.11	0.04	0	0	0.57			0.00	0.00
NC NC	2100 2100	2108 Optimize Controls - DX 2106 Prog. Thermostat - DX	Health Health	2014 2014	2054 2054	1.97 1.92	1.10 1.10	0.04	0.67 0.71	25% 27%	0.00 0.01	0.35 0.35	24% 24%	0.09	0.04	1	0	0.56			0.00	0.00
NC	2100		Health	2014	2054	1.81	1.03	0.04	0.83	31%	0.01	0.42	29%	0.11	0.04	0	0	0.48			0.00	0.00
NC	2100	2115 Window Film (Standard) - DX	Health	2014	2054	1.80	1.03	0.01	0.84	32%	0.01	0.42	29%	0.29	0.07	1	0	0.27			0.00	0.00
NC	2100 2100	2107 Cool Roof - DX	Health	2014 2014	2054	1.79 1.77	1.03	0.01	0.84	32% 33%	0.00	0.42	29% 30%	0.77 3.01	0.08	1 5	0	0.10			0.00	0.00
NC NC	2100 2100	2114 Duct/Pipe Insulation - DX 2111 Economizer Repair - DX	Health Health	2014	2054	1.77	1.01 1.01	0.02	0.86 0.86	33%	0.01	0.43	30%	3.01 27206.90	0.14	5 32,812	0	0.03			0.00	0.00
NC	2100	2109 Economizer - DX	Health	2014	2054	1.77	1.01	0.00	0.86	33%	0.00	0.43	30%	31674.79	0.18	246,502	0	0.00			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Health	2014	2054	5.27	2.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.27	2.90	0.00	0.00
NC NC	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Health Health	2014 2014	2054 2054	4.62 0.45	2.54 0.25	0.65 0.00	0.65	12% 0%	0.36	0.36 0.00	12% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	3.21 N/A	0.45	0.25	0.65 0.00	0.36
NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Health	2014	2054	1.45	0.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.45	0.29	0.00	0.00
NC	3000	3002 Variable Speed Drive Control, 5 HP	Health	2014	2054	1.00	0.27	0.46	0.46	31%	0.02	0.02	8%	0.02	0.02	0	0	3.53			0.46	0.02
NC NC	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	Health Health	2014 2014	2054 2054	0.98	0.27	0.02	0.47	33% 39%	0.00 0.04	0.03 0.06	9% 22%	0.03 1.01	0.02	0	0	2.33 0.08			0.02	0.00
NC	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Health	2014	2054	5.05	1.02	0.09	0.00	0%	0.04	0.00	0%	N/A	0.16 N/A	N/A	N/A	0.06 N/A	5.05	1.02	0.00	0.00
NC	3100	3102 Variable Speed Drive Control, 15 HP	Health	2014	2054	3.46	0.95	1.58	1.58	31%	0.08	0.08	7%	0.01	0.01	0	0	10.20			1.58	0.08
NC NC	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Health Health	2014 2014	2054 2054	3.46 2.95	0.95 0.85	0.01 0.50	1.59 2.09	32% 41%	0.00	0.08 0.17	8% 17%	0.02 0.03	0.01 0.01	0	0	4.13 2.23			0.01 0.50	0.00 0.09
NC	3100	3105 Energy Recovery Ventilation (ERV)	Health	2014	2054	2.95	0.65	0.50	2.09	45%	0.09	0.17	24%	0.03	0.01	1	0	0.30			0.50	0.09
NC	3100	3107 Demand Controlled Ventilation	Health	2014	2054	2.50	0.67	0.26	2.55	50%	0.11	0.36	35%	1.24	0.16	3	1	0.07			0.00	0.00
NC	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Health	2014	2054	5.36	1.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.36	1.09	0.00	0.00
NC NC	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Health Health	2014 2014	2054 2054	4.85 0.00	0.88	0.51 0.00	0.51 0.00	10% 0%	0.21 0.00	0.21 0.00	20% 0%	0.68 N/A	0.68 N/A	2 N/A	2 N/A	0.13 N/A	0.00	0.00	0.00	0.00
NC	4100	4100 Base Self-Contained Refrigeration	Health	2014	2054	1.30	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.30	0.00	0.00	0.00
NC	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Health	2014	2054	1.28	0.18	0.02	0.02	2%	0.00	0.00	2%	0.01	0.01	0	0	9.11			0.02	0.00
NC NC	4100 4100	4108 Energy-Star Refrigerator, glass door	Health Health	2014 2014	2054 2054	1.27 1.27	0.18 0.18	0.00	0.02	2% 2%	0.00	0.00	2%	0.02 0.02	0.01 0.01	0	0	3.04 2.96			0.00	0.00
NC NC	4100 4100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Health	2014	2054	1.27	0.18	0.00	0.03	2% 3%	0.00	0.00	2% 3%	0.02	0.01	0	0	1.09			0.00	0.00
NC	4100	4112 Reach-in unit occupancy sensors	Health	2014	2054	1.26	0.18	0.00	0.03	3%	0.00	0.01	3%	0.31	0.02	2	0	0.18			0.00	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Health	2014	2054	1.26	0.18	0.00	0.04	3%	0.00	0.01	3%	0.36	0.02	2	0	0.15	0.00	0.00	0.00	0.00
NC NC	5000 5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Health Health	2014 2014	2054 2054	0.63 0.34	0.09	0.00 0.29	0.00 0.29	0% 46%	0.00 0.02	0.00 0.02	0% 23%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.15	0.63	0.09	0.00 0.29	0.00 0.02
NC	5000	5002 Energy Star or Better PC	Health	2014	2054	0.23	0.05	0.11	0.40	63%	0.02	0.04	40%	0.05	0.03	0	0	1.03			0.11	0.02
																						

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Manager	Measure				Total	Percent		Total Capacity	Percent	Marginal	Average	Marginal	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm NC	Number 5100	Number Measure 5100 Base Laptop PC	Type Health	Year 2014	Year 2054	0.02	MW 0.00	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	0.02	MW 0.00	0.00	0.00
NC	5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Health	2014	2054	0.02	0.00	0.00	0.00	19%	0.00	0.00	19%	0.02	0.02	0	0	2.91	0.02	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Health	2014	2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	2.07	0.18	15	1	0.02			0.00	0.00
NC NC	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Health Health	2014 2014	2054 2054	0.19	0.03	0.00 0.10	0.00 0.10	0% 55%	0.00 0.01	0.00 0.01	0% 55%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 23.75	0.19	0.03	0.00 0.10	0.00 0.01
NC	5200	5207 Energy Star of Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Health	2014	2054	0.06	0.01	0.03	0.10	70%	0.00	0.02	62%	0.00	0.00	0	0	1.39			0.10	0.00
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Health	2014	2054	0.05	0.01	0.00	0.13	72%	0.00	0.02	65%	0.38	0.02	3	0	0.13			0.00	0.00
NC NC	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Health Health	2014 2014	2054 2054	0.11	0.02	0.00 0.02	0.00 0.02	0% 20%	0.00	0.00	0% 20%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.56	0.11	0.02	0.00 0.02	0.00
NC	5300	5302 Monitor Power Management Enabling - LCD	Health	2014	2054	0.09	0.01	0.02	0.02	24%	0.00	0.00	22%	0.18	0.05	3	0	0.26			0.00	0.00
NC	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Health	2014	2054	0.08	0.01	0.01	0.03	30%	0.00	0.00	23%	0.50	0.14	14	.1	0.09			0.00	0.00
NC NC	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Health Health	2014 2014	2054 2054	0.32	0.05	0.00 0.05	0.00 0.05	0% 17%	0.00	0.00 0.01	0% 17%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 16.39	0.32	0.05	0.00	0.00
NC	5400	5402 Copier Power Management Enabling	Health	2014	2054	0.25	0.04	0.02	0.07	22%	0.00	0.01	19%	0.17	0.04	2	Ō	0.29			0.00	0.00
NC	5500	5500 Base Multifunction	Health	2014	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00	0.00
NC NC	5500 5500	5502 ENERGY STAR Multi-Function Device 5501 Multifunction Power Management Enabling	Health Health	2014 2014	2054 2054	0.04	0.01	0.02 0.01	0.02 0.02	25% 36%	0.00	0.00	25% 31%	0.01 0.40	0.01 0.13	0 6	0	4.86 0.12			0.02 0.00	0.00
NC	5600	5600 Base Printer	Health	2014	2054	0.07	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.07	0.01	0.00	0.00
NC NC	5600 5600	5602 ENERGY STAR Printer	Health Health	2014 2014	2054 2054	0.04	0.01	0.02 0.01	0.02	35% 44%	0.00	0.00	35% 40%	0.00	0.00 0.02	0	0	22.34 0.54			0.02	0.00
NC	5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Health	2014	2054	3.19	0.01	0.00	0.03	0%	0.00	0.00	40% 0%	0.09 N/A	0.02 N/A	N/A	N/A	0.54 N/A	3.19	0.45	0.00	0.00
NC	5700	5701 Data Center Improved Operations	Health	2014	2054	2.87	0.41	0.32	0.32	10%	0.05	0.05	10%	0.00	0.00	0	0	77.29	0.10	0.10	0.32	0.05
NC NC	5700 5700	5702 Data Center Best Practices	Health Health	2014 2014	2054 2054	2.51	0.36	0.37	0.68 0.82	21% 26%	0.05 0.02	0.10	21% 26%	0.00	0.00	0	0	31.47			0.37	0.05 0.02
NC	6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Health	2014	2054	0.58	0.34	0.14	0.82	26% 0%	0.02	0.12	26% 0%	0.00 N/A	0.00 N/A	0 N/A	N/A	16.32 N/A	0.58	0.07	0.14	0.02
NC	6000	6001 Demand controlled circulating systems	Health	2014	2054	0.56	0.07	0.02	0.02	4%	0.00	0.00	4%	0.04	0.04	0	0	1.42			0.02	0.00
NC NC	6000 6000	6007 Heat Trap	Health Health	2014 2014	2054 2054	0.53 0.52	0.07	0.03 0.01	0.05 0.06	9% 11%	0.00	0.01 0.01	9% 11%	0.05 0.09	0.04 0.05	0	0	1.25 0.67			0.03	0.00
NC	6000	6002 High Efficiency Water Heater (electric) 6006 Heat Recovery Unit	Health	2014	2054	0.52	0.07	0.01	0.06	57%	0.00	0.01	57%	0.09	0.05	1	1	0.64			0.00	0.00
NC	6000	6004 Tankless Water Heater	Health	2014	2054	0.23	0.03	0.02	0.35	60%	0.00	0.04	60%	0.30	0.09	2	1	0.23			0.00	0.00
NC	6000 6000	6008 Solar Water Heater	Health	2014	2054	0.20	0.03	0.03	0.38	66% 67%	0.00	0.05	66% 67%	0.35	0.11	3	1	0.20			0.00	0.00
NC NC	7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	Health Health	2014 2014	2054 2054	0.19	0.02	0.00	0.38	0%	0.00	0.05 0.00	0%	0.41 N/A	0.12 N/A	N/A	N/A	0.15 N/A	0.55	0.08	0.00	0.00
NC	7000	7001 Vending Misers (Refrigerated units)	Health	2014	2054	0.46	0.07	0.09	0.09	16%	0.01	0.01	8%	0.03	0.03	0	0	1.83			0.09	0.01
NC NC	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Health Health	2014 2014	2054 2054	0.41	0.07	0.05 0.00	0.14 0.00	25% 0%	0.00	0.01 0.00	12% 0%	0.05 N/A	0.03 N/A	1 N/A	0 N/A	1.00 N/A	0.00	0.00	0.00	0.00
NC	7100	7100 Base Non-Reinigerated Vending Macrilles 7101 Vending Misers (Non-Refrigerated)	Health	2014	2054	0.00	0.00	0.00	0.00	47%	0.00	0.00	23%	0.43	0.43	6	6	0.11	0.00	0.00	0.00	0.00
NC	7200	7200 Base Oven	Health	2014	2054	0.09	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.02	0.00	0.00
NC NC	7300 7300	7300 Base Fryer 7301 Efficient Fryer	Health Health	2014 2014	2054 2054	0.13 0.12	0.02	0.00 0.01	0.00 0.01	0% 6%	0.00	0.00	0% 6%	N/A 1.32	N/A 1.32	N/A 7	N/A 7	N/A 0.05	0.13	0.02	0.00	0.00
NC	7400	7301 Ellicient Fryer 7400 Base Steamer	Health	2014	2054	0.12	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.05 N/A	0.07	0.01	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Health	2014	2054	1.32	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.32	0.00	0.00	0.00
NC NC	8000 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	Health Health	2014 2014	2054 2054	1.25 0.00	0.00	0.07 0.00	0.07	6% 0%	0.00	0.00	0% 0%	0.02 N/A	0.02 N/A	N/A N/A	N/A N/A	2.56 N/A	0.00	0.00	0.07 0.00	0.00
NC	9500	9500 Base Miscellaneous	Health	2014	2054	10.03	1.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.03	1.40	0.00	0.00
NC	9500	9501 Xmisc	Health	2014	2054	10.03	1.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
NC NC	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Lodging Lodging	2020 2020	2054 2054	0.14 0.12	0.02	0.00 0.01	0.00 0.01	0% 10%	0.00	0.00	0% 10%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.28	0.14	0.02	0.00 0.01	0.00
NC	1030	1032 ROB 4L4 (light Performance T8 (35 W), 2020	Lodging	2020	2054	0.12	0.02	0.01	0.03	22%	0.00	0.00	22%	0.06	0.03	0	0	1.09			0.02	0.00
NC	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Lodging	2020	2054	0.11	0.01	0.00	0.03	22%	0.00	0.00	22%	0.05	0.04	1	0	0.90			0.00	0.00
NC NC	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1034 ROB 4L4' LED Tube, 2020	Lodging Lodging	2020 2020	2054 2054	0.10	0.01	0.01	0.04	28% 40%	0.00	0.01	27% 38%	0.08	0.05	1	0	0.76			0.00	0.00
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Lodging	2020	2054	0.08	0.01	0.02	0.05	41%	0.00	0.01	39%	0.39	0.15	6	1	0.15			0.00	0.00
NC	1030	1035 LED Troffer (base 4L4'T8), 2020	Lodging	2020	2054	0.07	0.01	0.01	0.06	46%	0.00	0.01	44%	0.34	0.17	2	.1	0.21			0.00	0.00
NC NC	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Lodging Lodging	2020 2020	2054 2054	0.55 0.49	0.08	0.00 0.06	0.00 0.06	0% 10%	0.00 0.01	0.00 0.01	0% 10%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.80	0.55	80.0	0.00 0.06	0.00 0.01
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Lodging	2020	2054	0.43	0.06	0.06	0.12	22%	0.01	0.02	22%	0.03	0.05	1	0	0.86			0.00	0.00
NC	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Lodging	2020	2054	0.43	0.06	0.00	0.12	22%	0.00	0.02	22%	0.07	0.05	1	0	0.64			0.00	0.00
NC NC	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 1134 ROB 2L4' LED Tube, 2020	Lodging Lodging	2020 2020	2054 2054	0.40	0.06	0.03 0.02	0.15 0.17	28% 32%	0.00	0.02 0.02	27% 30%	0.11 0.32	0.07 0.09	1 2	0	0.55 0.22			0.00	0.00
NC	1130	1135 LED Troffer (base 2L4'T8), 2020	Lodging	2020	2054	0.34	0.05	0.02	0.17	37%	0.00	0.02	36%	0.32	0.14	3	1	0.17			0.00	0.00
NC	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Lodging	2020	2054	0.33	0.05	0.01	0.22	39%	0.00	0.03	36%	0.33	0.15	10	1	0.14			0.00	0.00
NC NC	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Lodging Lodging	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 2%	0.00	0.00	0% 1%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.19	0.01	0.00	0.00	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	Lodging	2014	2054	0.01	0.00	0.00	0.00	12%	0.00	0.00	11%	0.02	0.10	1	1	0.55			0.00	0.00
NC	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Lodging	2014	2054	0.01	0.00	0.00	0.00	29%	0.00	0.00	27%	0.26	0.18	2	1	0.24			0.00	0.00
NC NC	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Lodging	2014 2020	2054 2054	0.01 1.11	0.00 0.16	0.00	0.00	35% 0%	0.00	0.00	28% 0%	0.22 N/A	0.19 N/A	7 N/A	2 N/A	0.22 N/A	1.11	0.16	0.00	0.00
NC NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Lodging Lodging	2020	2054	1.11 0.19	0.16	0.00	0.00	0% 83%	0.00	0.00	0% 83%	N/A 0.01	0.01	N/A 0	N/A 0	N/A 6.28	1.17	0.16	0.00	0.00
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Lodging	2020	2054	0.40	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.40	0.06	0.00	0.00
NC	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020	Lodging	2020	2054	0.07	0.01	0.33	0.33	82% 0%	0.05 0.00	0.05	82% 0%	0.01 N/A	0.01 N/A	0 N/A	0	5.30 N/A	0.20	0.04	0.33	0.05
NC NC	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Lodging Lodging	2020 2020	2054 2054	0.29 0.08	0.04	0.00	0.00 0.22	75%	0.00	0.00	75%	0.02	0.02	N/A 0	N/A 0	N/A 3.95	0.29	0.04	0.00	0.00
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Lodging	2020	2054	0.43	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.43	0.06	0.00	0.00

DNV GL H-33 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Moneuro	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm NC	Number 1630	Number Measure 1631 LED screw-in replacement (base CFL 18W) 2020	Type	Year 2020	Year 2054	0.31	MW 0.04	Savings 0.12	0.12	Savings 28%	Savings 0.02	MW	Savings	\$/kWH 0.10	\$/kWH 0.10	\$/kW	\$/kW	0.64	GWH	MW	0.00	MW
NC	1730	1730 Base CFL 23W to screw-in replacement 2020	Lodging Lodging	2020	2054	0.55	0.04	0.12	0.12	0%	0.02	0.02	28% 0%	N/A	N/A	N/A	N/A	0.64 N/A	0.55	0.08	0.00	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Lodging	2020	2054	0.41	0.06	0.14	0.14	26%	0.02	0.02	26%	0.08	0.08	1	1	0.86			0.00	0.00
NC	1800	1800 BaseMetal Halide, 465W	Lodging	2014	2054	0.11	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.02	0.00	0.00
NC NC	1800 1800	1801 T5 (240W) (base metal halide) 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Lodging Lodging	2014 2014	2054 2054	0.07	0.01	0.04 0.01	0.04	34% 39%	0.01 0.00	0.01 0.01	34% 38%	0.02 0.05	0.02	0	0	3.21 1.12			0.04	0.01
NC	1800	1806 Occupancy Sensor, High Bay T5	Lodging	2014	2054	0.06	0.01	0.00	0.04	41%	0.00	0.01	38%	0.06	0.03	2	ō	0.85			0.00	0.00
NC	1850	1850 Base CFL Exit Sign	Lodging	2014	2054	0.16	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.16	0.02	0.00	0.00
NC NC	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Lodging Lodging	2014 2014	2054 2054	0.09 1.05	0.01	0.07	0.07	44% 0%	0.01	0.01	44% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	1.63 N/A	1.05	0.01	0.07	0.01
NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Lodging	2014	2054	1.03	0.01	0.04	0.04	4%	0.00	0.00	13%	0.05	0.05	2	2	1.21	1.05	0.01	0.04	0.00
NC	1900	1902 LED Outdoor Area Lighting	Lodging	2014	2054	0.49	0.00	0.52	0.57	54%	0.00	0.01	63%	0.11	0.10	12	10	0.52			0.00	0.00
NC NC	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Lodging Lodging	2014 2014	2054 2054	0.34	0.00	0.14 0.00	0.71 0.00	67% 0%	0.00	0.01 0.00	75% 0%	0.69 N/A	0.22 N/A	89 N/A	23 N/A	0.08 N/A	0.00	0.00	0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Lodging	2014	2054	10.34	6.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.34	6.22	0.00	0.00
NC	2100	2115 Window Film (Standard) - DX	Lodging	2014	2054	9.81	5.91	0.53	0.53	5%	0.32	0.32	5%	0.03	0.03	0	0	2.38			0.53	0.32
NC	2100	2102 DX Packaged System, EER=13.4, 10 tons	Lodging	2014	2054	7.55	4.55	2.26	2.79	27%	1.36	1.68	27%	0.05	0.05	0	0	1.91			2.26	1.36
NC NC	2100 2100	2108 Optimize Controls - DX 2105 DX Tune Up/ Advanced Diagnostics	Lodging Lodging	2014 2014	2054 2054	7.41 7.31	4.53 4.50	0.14 0.11	2.92 3.03	28% 29%	0.02	1.70 1.73	27% 28%	0.09 0.17	0.05 0.05	1	0	0.53 0.38			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Lodging	2014	2054	7.09	4.47	0.21	3.25	31%	0.03	1.76	28%	0.16	0.06	1	Ö	0.32			0.00	0.00
NC	2100	2112 Aerosol Duct Sealing - DX	Lodging	2014	2054	6.66	4.21	0.43	3.68	36%	0.26	2.02	32%	0.35	0.09	1	0	0.29			0.00	0.00
NC NC	2100 2100	2111 Economizer Repair - DX 2107 Cool Roof - DX	Lodging Lodging	2014 2014	2054 2054	6.63 6.61	4.18 4.17	0.03	3.71 3.72	36% 36%	0.03	2.05 2.06	33% 33%	0.99 1.35	0.10 0.11	1 2	0	0.08			0.00	0.00
NC	2100	2109 Economizer - DX	Lodging	2014	2054	6.50	4.15	0.11	3.83	37%	0.02	2.07	33%	1.17	0.14	8	0	0.05			0.00	0.00
NC	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Lodging	2014	2054	6.50	4.15	0.00	3.83	37%	0.00	2.07	33%	1.97	0.14	14	0	0.03			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	Lodging	2014	2054	6.43	4.11	0.07	3.90	38%	0.04	2.11	34%	3.30 N/A	0.19 N/A	5	0	0.02	0.50	F 74	0.00	0.00
NC NC	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging Lodging	2014 2014	2054 2054	9.53 8.35	5.74 5.03	0.00 1.18	0.00 1.18	0% 12%	0.00 0.71	0.00 0.71	0% 12%	0.03	0.03	N/A 0	N/A 0	N/A 3.29	9.53	5.74	0.00 1.18	0.00 0.71
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	Lodging	2014	2054	8.66	5.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.66	5.22	0.00	0.00
NC	2300	2301 HE PTAC, EER=9.6, 1 ton	Lodging	2014	2054	7.49	4.51	1.17	1.17	14%	0.71	0.71	14%	0.09	0.09	0	0	1.12			1.17	0.71
NC NC	2300 3000	2302 Occupancy Sensor (hotels) 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Lodging Lodging	2014 2014	2054 2054	6.41 5.98	3.63 1.27	1.08 0.00	2.26	26% 0%	0.88	1.59 0.00	30% 0%	0.29 N/A	0.18 N/A	0 N/A	0 N/A	0.33 N/A	5.98	1.27	0.00	0.00
NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Lodging	2014	2054	5.88	1.24	0.10	0.10	2%	0.02	0.02	2%	0.03	0.03	0	0	2.13	5.50	1.27	0.10	0.02
NC	3000	3003 Demand Controlled Ventilation	Lodging	2014	2054	5.06	0.89	0.81	0.92	15%	0.35	0.38	30%	1.07	0.96	2	2	0.08			0.00	0.00
NC NC	3100 3200	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Lodging Lodging	2014 2014	2054 2054	0.00 1.03	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 1.03	0.00	0.00	0.00
NC	3200	3203 Air Handler Optimization, 40 HP	Lodging	2014	2054	0.93	0.22	0.00	0.00	10%	0.00	0.00	3%	0.03	0.03	1	1	1.80	1.03	0.22	0.11	0.00
NC	3200	3204 Demand Controlled Ventilation	Lodging	2014	2054	0.80	0.16	0.13	0.24	23%	0.06	0.06	28%	1.18	0.65	3	3	0.07			0.00	0.00
NC	4000	4000 Base Built-Up Refrigeration System	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Lodging Lodging	2014 2014	2054 2054	3.43 3.33	0.50 0.49	0.00 0.10	0.00 0.10	0% 3%	0.00 0.02	0.00 0.02	0% 3%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 62.63	3.43	0.50	0.00 0.10	0.00 0.02
NC	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Lodging	2014	2054	3.28	0.48	0.04	0.15	4%	0.01	0.02	4%	0.00	0.00	0	0	24.36			0.04	0.01
NC	4100	4109 Energy-Star Freezer, glass door	Lodging	2014	2054	3.23	0.47	0.05	0.20	6%	0.01	0.03	6%	0.00	0.00	0	0	18.17			0.05	0.01
NC NC	4100 4100	4107 Energy-Star Freezer, solid door 4106 Energy-Star Refrigerator, solid door	Lodging Lodging	2014 2014	2054 2054	3.21 3.19	0.47	0.02	0.22 0.24	6% 7%	0.00	0.03	6% 7%	0.01	0.00	0	0	7.23 5.74			0.02	0.00
NC	4100	4110 Energy Star Ice Machines	Lodging	2014	2054	3.17	0.46	0.03	0.26	8%	0.00	0.04	8%	0.03	0.01	0	0	2.13			0.03	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Lodging	2014	2054	3.17	0.46	0.00	0.26	8%	0.00	0.04	8%	0.36	0.01	2	0	0.15			0.00	0.00
NC NC	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Lodging	2014 2014	2054 2054	3.15 0.42	0.46	0.01 0.00	0.28	8% 0%	0.00	0.04	8% 0%	0.39 N/A	0.02 N/A	3 N/A	0 N/A	0.13 N/A	0.42	0.06	0.00	0.00
NC	5000	5000 Base Desktop PC 5002 Energy Star or Better PC	Lodging Lodging	2014	2054	0.42	0.05	0.00	0.00	21%	0.00	0.00	21%	0.02	0.02	0	0	3.34	0.42	0.06	0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	Lodging	2014	2054	0.18	0.04	0.15	0.24	58%	0.01	0.02	39%	0.02	0.02	0	0	2.56			0.15	0.01
NC NC	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Lodging	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.38	0.01	0.00	0.00	0.00
NC NC	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Lodging Lodging	2014	2054	0.01	0.00	0.00	0.00	19% 21%	0.00	0.00	19% 21%	1.38	0.01	9	1	4.38 0.04			0.00	0.00
NC	5200	5200 Base Monitor, CRT	Lodging	2014	2054	0.24	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.24	0.04	0.00	0.00
NC	5200	5201 Energy Star or Better Monitor - CRT	Lodging	2014	2054	0.10	0.02	0.13	0.13	56%	0.02	0.02	56%	0.00	0.00	0	0	34.86			0.13	0.02
NC NC	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Lodging Lodging	2014 2014	2054 2054	0.08	0.01	0.03	0.16 0.17	67% 69%	0.00	0.02 0.02	61% 64%	0.02 0.23	0.00	0 2	0	2.45 0.22			0.03	0.00
NC	5300	5300 Base Monitor, LCD	Lodging	2014	2054	0.11	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.02	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	Lodging	2014	2054	0.10	0.01	0.01	0.01	10%	0.00	0.00	10%	0.01	0.01	0	0	4.32			0.01	0.00
NC NC	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Lodging	2014 2014	2054 2054	0.09	0.01	0.01	0.02	20% 27%	0.00	0.00	15% 17%	0.12 0.32	0.07	2 9	1	0.39			0.00	0.00
NC NC	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Lodging Lodging	2014	2054	0.08	0.01	0.01	0.03	27% 0%	0.00	0.00	17% 0%	0.32 N/A	0.13 N/A	N/A	1 N/A	0.14 N/A	0.17	0.03	0.00	0.00
NC	5400	5401 Energy Star or Better Copier	Lodging	2014	2054	0.16	0.02	0.02	0.02	10%	0.00	0.00	10%	0.00	0.00	0	0	26.81			0.02	0.00
NC	5400	5402 Copier Power Management Enabling	Lodging	2014	2054	0.15	0.02	0.01	0.02	13%	0.00	0.00	12%	0.10	0.03	1	0	0.49	0.00	0.00	0.00	0.00
NC NC	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Lodging Lodging	2014 2014	2054 2054	0.02	0.00	0.00 0.01	0.00 0.01	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.32	0.02	0.00	0.00 0.01	0.00
NC	5500	5501 Multifunction Power Management Enabling	Lodging	2014	2054	0.01	0.00	0.00	0.01	39%	0.00	0.00	32%	0.28	0.11	4	1	0.17			0.00	0.00
NC	5600	5600 Base Printer	Lodging	2014	2054	0.14	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.14	0.02	0.00	0.00
NC NC	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Lodging Lodging	2014 2014	2054 2054	0.09	0.01 0.01	0.05 0.02	0.05 0.07	35% 47%	0.01	0.01 0.01	35% 41%	0.00 0.06	0.00 0.02	0 1	0	33.66 0.76			0.05	0.01
NC	5700	5700 Base Data Center/Server Room	Lodging	2014	2054	2.94	0.44	0.02	0.00	0%	0.00	0.00	0%	N/A	0.02 N/A	N/A	N/A	0.76 N/A	2.94	0.44	0.00	0.00
NC	5700	5701 Data Center Improved Operations	Lodging	2014	2054	2.65	0.39	0.29	0.29	10%	0.04	0.04	10%	0.00	0.00	0	0	103.65			0.29	0.04
NC	5700	5702 Data Center Best Practices	Lodging	2014	2054	2.31	0.34	0.34	0.63	21%	0.05	0.09	21%	0.00	0.00	0	0	42.20			0.34	0.05

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Came	Base	Measure Number Measure	Building	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
NC	Number 5700	5703 Data Center State of the Art practices	Type Lodging	2014	2054	2.18	0.32	0.13	0.76	Savings 26%	Savings 0.02	0.11	Savings 26%	0.00	0.00	0	0	21.88	GWH	IVIVV	0.13	0.02
NC	6000	6000 Base Water Heating	Lodging	2014	2054	2.12	0.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.12	0.29	0.00	0.00
NC NC	6000	6007 Heat Trap 6006 Heat Recovery Unit	Lodging Lodging	2014 2014	2054	2.01 1.75	0.27	0.11 0.26	0.11 0.37	5% 18%	0.01 0.04	0.01 0.05	5% 18%	0.01 0.02	0.01 0.02	0	0	3.83 2.86			0.11	0.01
NC	6000	6001 Demand controlled circulating systems	Lodging	2014	2054	1.68	0.23	0.20	0.44	21%	0.04	0.06	21%	0.02	0.02	0	0	1.96			0.20	0.04
NC	6000	6002 High Efficiency Water Heater (electric)	Lodging	2014	2054	1.65	0.22	0.03	0.47	22%	0.00	0.06	22%	0.04	0.02	0	0	1.71			0.03	0.00
NC NC	6000 6000	6004 Tankless Water Heater 6008 Solar Water Heater	Lodging Lodging	2014 2014	2054 2054	1.53 1.31	0.21 0.18	0.12 0.21	0.59 0.81	28% 38%	0.02	0.08 0.11	28% 38%	0.06 0.07	0.03 0.04	0	0	1.21 1.04			0.12 0.21	0.02 0.03
NC	6000	6003 Hot Water Pipe Insulation	Lodging	2014	2054	1.29	0.17	0.02	0.83	39%	0.00	0.11	39%	0.08	0.04	1	0	0.81			0.00	0.00
NC	7000	7000 Base Refrigerated Vending Machines	Lodging	2014	2054	0.62	0.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.62	0.10	0.00	0.00
NC NC	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Lodging Lodging	2014 2014	2054 2054	0.52 0.46	0.09	0.10 0.06	0.10	16% 25%	0.01 0.00	0.01 0.01	8% 12%	0.03 0.05	0.03	0	0	1.84 1.00			0.10 0.06	0.01 0.00
NC	7100	7100 Base Non-Refrigerated Vending Machines	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	7100	7101 Vending Misers (Non-Refrigerated)	Lodging	2014	2054	0.00	0.00	0.00	0.00	47%	0.00	0.00	23%	0.43	0.43	5	5	0.11			0.00	0.00
NC NC	7200 7300	7200 Base Oven 7300 Base Fryer	Lodging Lodging	2014 2014	2054 2054	0.15 0.18	0.03	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.15 0.18	0.03	0.00	0.00
NC	7400	7400 Base Steamer	Lodging	2014	2054	0.09	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.02	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Lodging	2014	2054	1.37	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.37	0.00	0.00	0.00
NC NC	8000 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	Lodging Lodging	2014 2014	2054 2054	1.29 0.66	0.00	0.08	0.08	6% 0%	0.00	0.00	0% 0%	0.03 N/A	0.03 N/A	N/A N/A	N/A N/A	1.90 N/A	0.66	0.00	0.08	0.00
NC	9500	9500 Base Miscellaneous	Lodging	2014	2054	7.41	1.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.41	1.21	0.00	0.00
NC	9500	9501 Xmisc	Lodging	2014	2054	7.41	1.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
NC NC	1030 1030	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Data Centers Data Centers	2020 2020	2054 2054	0.32	0.06	0.00	0.00	0% 7%	0.00	0.00	0% 6%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.67	0.32	0.06	0.00	0.00
NC NC	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4 18), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Data Centers Data Centers		2054	0.30	0.05	0.02	0.02	17%	0.00	0.00	15%	0.02	0.02	0	0	2.11			0.02	0.00
NC	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Data Centers	2020	2054	0.24	0.04	0.03	0.09	27%	0.01	0.01	26%	0.06	0.04	0	0	1.01			0.03	0.01
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Data Centers		2054	0.22	0.04	0.02	0.11	33%	0.00	0.02	28%	0.08	0.04	2	0	0.58			0.00	0.00
NC NC	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Data Centers Data Centers		2054 2054	0.18 0.17	0.03	0.03 0.02	0.14 0.16	44% 49%	0.01 0.00	0.02 0.02	38% 43%	0.36 0.30	0.12 0.14	2	1	0.19 0.22			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Data Centers	2020	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Data Centers		2054	0.01	0.00	0.00	0.00	7%	0.00	0.00	6%	0.03	0.03	0	0	2.13			0.00	0.00
NC NC	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Data Centers Data Centers		2054 2054	0.00	0.00	0.00	0.00	17% 28%	0.00	0.00	16% 26%	0.03 0.07	0.03	0	0	1.67 0.80			0.00	0.00
NC	1130	1132 ROB 2L4 LEW Watt High Performance 16 (73 W), 2020	Data Centers		2054	0.00	0.00	0.00	0.00	31%	0.00	0.00	30%	0.07	0.03	2	0	0.25			0.00	0.00
NC	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Data Centers		2054	0.00	0.00	0.00	0.00	37%	0.00	0.00	31%	0.16	0.09	3	1	0.31			0.00	0.00
NC NC	1130 1200	1135 LED Troffer (base 2L4'T8), 2020 1200 Base Other Fluorescent Fixture	Data Centers		2054 2054	0.00	0.00	0.00	0.00	42% 0%	0.00	0.00	37% 0%	0.37 N/A	0.12 N/A	2	1 N/A	0.18 N/A	0.01	0.00	0.00	0.00
NC NC	1200	1200 base Other Fluorescent Fixture 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Data Centers Data Centers		2054	0.01	0.00	0.00	0.00	7%	0.00	0.00	6%	0.04	0.04	N/A 0	0	1.72	0.01	0.00	0.00	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	Data Centers		2054	0.01	0.00	0.00	0.00	17%	0.00	0.00	16%	0.11	0.08	1	Ō	0.52			0.00	0.00
NC	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Data Centers		2054 2054	0.01	0.00	0.00	0.00	28% 0%	0.00	0.00	19%	0.15 N/A	0.11 N/A	3 N/A	1 N/A	0.33	0.40	0.02	0.00	0.00
NC NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Data Centers Data Centers		2054	0.10	0.02	0.00	0.00	83%	0.00	0.00	0% 83%	0.01	0.01	0 N/A	N/A 0	N/A 7.36	0.10	0.02	0.00	0.00
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Data Centers		2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
NC	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020	Data Centers		2054	0.01	0.00	0.03	0.03	82%	0.01	0.01	82%	0.01	0.01	0	0	6.22	0.00	0.00	0.03	0.01
NC NC	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Data Centers Data Centers		2054	0.03	0.00	0.00	0.00	0% 75%	0.00	0.00	0% 75%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.63	0.03	0.00	0.00 0.02	0.00
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Data Centers	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Data Centers		2054	0.01	0.00	0.01	0.01	28%	0.00	0.00	28%	0.07	0.07	0	0	0.75			0.00	0.00
NC NC	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Data Centers Data Centers		2054 2054	0.03	0.00	0.00 0.01	0.00 0.01	0% 26%	0.00	0.00	0% 26%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.00	0.03	0.00	0.00 0.01	0.00
NC	1800	1800 BaseMetal Halide, 465W	Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	1850	1850 Base CFL Exit Sign	Data Centers		2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC NC	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Data Centers Data Centers		2054 2054	0.00	0.00	0.00	0.00	44% 0%	0.00	0.00	44% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	1.61 N/A	0.08	0.00	0.00	0.00
NC	1900	1900 Base Outdoor Area Lighting	Data Centers		2054	0.04	0.00	0.00	0.00	52%	0.00	0.00	52%	0.11	0.11	10	10	0.55	0.00	0.00	0.00	0.00
NC	1900	1903 Bi-Level LED Outdoor Lighting	Data Centers		2054	0.03	0.00	0.01	0.05	66%	0.00	0.00	65%	0.72	0.24	70	22	0.08			0.00	0.00
NC NC	2000 2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2010 Ceiling/roof Insulation - Chiller	Data Centers Data Centers		2054 2054	0.66 0.65	0.16	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 20.15	0.66	0.16	0.00	0.00
NC	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Data Centers		2054	0.60	0.15	0.06	0.06	9%	0.00	0.00	9%	0.00	0.00	0	0	4.58			0.06	0.00
NC	2000	2006 VSD for Chiller Pumps and Towers	Data Centers		2054	0.59	0.15	0.00	0.06	10%	0.00	0.01	9%	0.02	0.02	0	0	3.34			0.00	0.00
NC	2000 2000	2013 High Efficiency Chiller Motors 2003 FMS - Chiller	Data Centers		2054 2054	0.59 0.58	0.15	0.00 0.02	0.06	10% 12%	0.00	0.02	9% 10%	0.03	0.02	0	0	2.98 2.23			0.00 0.02	0.00
NC NC	2000	2003 EMS - Chiller 2008 New Economizer - Chiller	Data Centers Data Centers		2054	0.58	0.15	0.02	0.08 0.12	12% 18%	0.00	0.02	10% 11%	0.03	0.02 0.02	1	0	1.76			0.02	0.00
NC	2000	2002 Window Film (Standard) - Chiller	Data Centers	2014	2054	0.54	0.14	0.00	0.12	18%	0.00	0.02	11%	0.05	0.02	0	Ō	1.19			0.00	0.00
NC	2000	2012 Duct Testing/Sealing	Data Centers		2054	0.43	0.12	0.10	0.22	34%	0.03	0.04	27%	0.09	0.05	0	0	0.84			0.00	0.00
NC NC	2000 2000	2004 Cool Roof - Chiller 2011 Duct/Pipe Insulation - Chiller	Data Centers Data Centers		2054 2054	0.43	0.12 0.12	0.00	0.22	34% 34%	0.00	0.04 0.04	27% 27%	0.14 1.13	0.05 0.06	1 5	0	0.47			0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Data Centers		2054	0.43	0.12	0.00	0.23	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.37	0.09	0.00	0.00
NC	2100	2102 DX Packaged System, EER=13.4, 10 tons	Data Centers		2054	0.29	0.07	0.09	0.09	23%	0.02	0.02	23%	0.01	0.01	0	0	4.89			0.09	0.02
NC NC	2100 2100	2111 Economizer Repair - DX 2108 Optimize Controls - DX	Data Centers Data Centers		2054 2054	0.28	0.07	0.00 0.01	0.09 0.10	24% 26%	0.00	0.02 0.02	25% 25%	0.04 0.03	0.02 0.02	0 1	0	1.56 1.50			0.00 0.01	0.00
NC	2100	2109 Economizer - DX	Data Centers		2054	0.24	0.07	0.01	0.10	35%	0.00	0.02	28%	0.03	0.02	1	0	1.28			0.03	0.00
NC	2100	2115 Window Film (Standard) - DX	Data Centers		2054	0.24	0.07	0.01	0.13	36%	0.00	0.03	29%	0.07	0.02	0	0	0.93			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Data Centers	2014	2054	0.23	0.06	0.01	0.15	39%	0.00	0.03	30%	0.06	0.03	1	0	0.90			0.00	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	age			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm NC	Number 2100	Number Measure 2112 Aerosol Duct Sealing - DX	Type Data Centers	Year 2014	Year 2054	0.21	MW 0.06	Savings 0.01	0.16	Savings 43%	Savings 0.00	0.03	Savings 33%	\$/kWH 0.12	\$/kWH 0.04	\$/kW 0	\$/kW	0.63	GWH	MW	0.00	0.00
NC	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Data Centers	2014	2054	0.21	0.06	0.00	0.16	43%	0.00	0.03	33%	0.12	0.04	2	0	0.45			0.00	0.00
NC	2100 2100	2107 Cool Roof - DX	Data Centers	2014	2054	0.21	0.06	0.00	0.16	43% 44%	0.00	0.03	34%	0.16	0.04	1 5	0	0.41			0.00	0.00
NC NC	2100 2200	2114 Duct/Pipe Insulation - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Data Centers Data Centers		2054	0.21	0.06 0.01	0.00	0.16	44% 0%	0.00	0.03	34% 0%	1.32 N/A	0.05 N/A	N/A	N/A	0.05 N/A	0.05	0.01	0.00	0.00
NC	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Data Centers	2014	2054	0.04	0.01	0.01	0.01	12%	0.00	0.00	12%	0.01	0.01	0	0	6.85			0.01	0.00
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Data Centers Data Centers	2014 2014	2054 2054	0.10	0.02	0.00	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 4.50	0.10	0.02	0.00	0.00
NC	3000	3002 Variable Speed Drive Control, 5 HP	Data Centers		2054	0.07	0.02	0.02	0.02	26%	0.00	0.00	8%	0.01	0.01	0	0	4.25			0.02	0.00
NC	3000	3003 Demand Controlled Ventilation	Data Centers	2014	2054	0.07	0.02	0.00	0.03	30%	0.00	0.00	15%	0.55	0.09	1	1	0.16	0.00	0.00	0.00	0.00
NC NC	3100 3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3102 Variable Speed Drive Control, 15 HP	Data Centers Data Centers	2014 2014	2054 2054	0.33	0.08 0.08	0.00 0.08	0.00 0.08	0% 24%	0.00 0.01	0.00 0.01	0% 6%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 15.63	0.33	0.08	0.00	0.00 0.01
NC	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Data Centers	2014	2054	0.25	0.08	0.00	0.08	25%	0.00	0.01	7%	0.01	0.00	0	ō	7.49			0.00	0.00
NC	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Data Centers	2014 2014	2054 2054	0.23	0.07	0.02	0.10 0.12	30% 36%	0.00	0.01	11% 13%	0.02	0.01 0.01	0	0	3.30			0.02 0.02	0.00
NC NC	3100	3103 Air Handler Optimization, 15 HP 3105 Energy Recovery Ventilation (ERV)	Data Centers Data Centers		2054	0.21	0.07	0.02	0.12	38%	0.00	0.01 0.01	16%	0.02	0.01	0	0	2.61 0.46			0.02	0.00
NC	3100	3107 Demand Controlled Ventilation	Data Centers	2014	2054	0.20	0.06	0.01	0.14	42%	0.01	0.02	22%	0.65	0.07	1	1	0.14			0.00	0.00
NC	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Data Centers	2014	2054	0.36	0.09	0.00	0.00	0% 9%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	0.36	0.09	0.00	0.00
NC NC	3200	3203 Air Handler Optimization, 40 HP 3202 Variable Speed Drive Control, 40 HP	Data Centers Data Centers	2014	2054 2054	0.32	0.09	0.03	0.03 0.11	32%	0.00	0.00 0.01	2% 8%	0.01 0.02	0.01 0.02	0	0	3.71 2.81			0.03	0.00
NC	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	Data Centers	2014	2054	0.24	0.08	0.00	0.11	32%	0.00	0.01	8%	0.09	0.02	0	0	0.84			0.00	0.00
NC	3200		Data Centers	2014	2054	0.23	0.07	0.01	0.13	36%	0.01	0.01	15%	0.60	0.08	1	1	0.15			0.00	0.00
NC NC	4000 4100		Data Centers Data Centers	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	4100		Data Centers	2014	2054	0.07	0.01	0.00	0.00	2%	0.00	0.00	2%	0.00	0.00	0	0	21.30	0.07	0.01	0.00	0.00
NC	5000	5000 Base Desktop PC	Data Centers		2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00	0.00
NC NC	5000 5000		Data Centers Data Centers		2054 2054	0.01	0.00	0.01 0.00	0.01	44% 56%	0.00	0.00	23% 35%	0.02 0.03	0.02 0.02	0	0	3.01 1.67			0.01 0.00	0.00
NC NC	5100		Data Centers Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	35% 0%	0.03 N/A	0.02 N/A	N/A	N/A	1.67 N/A	0.00	0.00	0.00	0.00
NC	5100	5102 Energy Star or Better Laptop	Data Centers	2014	2054	0.00	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	4.36			0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Data Centers		2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	1.46	0.13	8	1	0.04	0.04	0.00	0.00	0.00
NC NC	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Data Centers Data Centers	2014	2054 2054	0.01	0.00	0.00	0.00 0.01	0% 43%	0.00	0.00	0% 43%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 45.38	0.01	0.00	0.00	0.00
NC	5200	5202 Monitor Power Management Enabling - CRT	Data Centers		2054	0.01	0.00	0.00	0.01	50%	0.00	0.00	46%	0.01	0.00	0	0	3.50			0.00	0.00
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Data Centers		2054	0.01	0.00	0.00	0.01	54%	0.00	0.00	50%	0.16	0.01	1	0	0.33			0.00	0.00
NC NC	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Data Centers Data Centers	2014	2054 2054	0.01	0.00	0.00	0.00	0% 13%	0.00	0.00	0% 13%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.15	0.01	0.00	0.00	0.00
NC	5300	5302 Monitor Power Management Enabling - LCD	Data Centers	2014	2054	0.00	0.00	0.00	0.00	19%	0.00	0.00	16%	0.13	0.05	1	0	0.38			0.00	0.00
NC	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Data Centers		2054	0.00	0.00	0.00	0.00	25%	0.00	0.00	18%	0.37	0.12	8	1	0.12			0.00	0.00
NC NC	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Data Centers Data Centers		2054 2054	0.02	0.00	0.00	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 26.53	0.02	0.00	0.00	0.00
NC	5400		Data Centers	2014	2054	0.02	0.00	0.00	0.00	14%	0.00	0.00	12%	0.11	0.03	1	0	0.45			0.00	0.00
NC	5500		Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	5500 5500	5502 ENERGY STAR Multi-Function Device 5501 Multifunction Power Management Enabling	Data Centers Data Centers	2014	2054 2054	0.00	0.00	0.00	0.00	25% 38%	0.00	0.00	25% 32%	0.01 0.32	0.01	0	0	7.27 0.15			0.00	0.00
NC	5600	5600 Base Printer	Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.32 N/A	N/A	N/A	N/A	0.15 N/A	0.00	0.00	0.00	0.00
NC	5700	5700 Base Data Center/Server Room	Data Centers	2014	2054	18.10	3.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.10	3.15	0.00	0.00
NC NC	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Data Centers Data Centers		2054 2054	16.29 14.22	2.83 2.47	1.81 2.07	1.81 3.88	10% 21%	0.31 0.36	0.31 0.68	10% 21%	0.00	0.00	0	0	115.96 47.21			1.81 2.07	0.31 0.36
NC	5700		Data Centers	2014	2054	13.42	2.33	0.80	4.68	26%	0.36	0.81	26%	0.00	0.00	0	0	24.48			0.80	0.36
NC	6000	6000 Base Water Heating	Data Centers	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	6000	6007 Heat Trap	Data Centers		2054	0.01	0.00	0.00	0.00	5%	0.00	0.00	5%	0.04	0.04	0	0	1.42			0.00	0.00
NC NC	6000 6000		Data Centers Data Centers	2014 2014	2054 2054	0.01	0.00	0.00	0.00	7% 14%	0.00	0.00	7% 14%	0.09 0.13	0.05 0.09	1	0 1	0.76 0.54			0.00	0.00
NC	6000	6008 Solar Water Heater	Data Centers	2014	2054	0.01	0.00	0.01	0.01	60%	0.00	0.00	60%	0.16	0.14	1	1	0.46			0.00	0.00
NC	6000		Data Centers		2054	0.01	0.00	0.00	0.01	60%	0.00	0.00	60%	0.34	0.14	2	1	0.20			0.00	0.00
NC NC	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	Data Centers Data Centers	2014 2014	2054 2054	0.01	0.00	0.00	0.01 0.01	63% 64%	0.00	0.00	63% 64%	0.35 1.05	0.15 0.17	2 6	1	0.17 0.06			0.00	0.00
NC	7000		Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	7100	7100 Base Non-Refrigerated Vending Machines	Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7200 7300	7200 Base Oven 7300 Base Fryer	Data Centers	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	7400		Data Centers Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	8100 9500		Data Centers	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.01	0.00 0.01	0.00	0.00
NC NC	9500 9500		Data Centers Data Centers		2054	0.09	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.09	0.01	0.00	0.00
NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	eligious Worsh	2020	2054	0.79	0.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.79	0.13	0.00	0.00
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	eligious Worsh		2054	0.71	0.12	0.08	0.08	10%	0.01	0.01	10%	0.05	0.05	0	0	1.21			0.08	0.01
NC NC	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	eligious Worsh eligious Worsh		2054 2054	0.71 0.66	0.12 0.11	0.00 0.05	0.08 0.14	10% 17%	0.00	0.01 0.02	10% 16%	0.05 0.08	0.05 0.06	1	0	0.87 0.77			0.00	0.00
NC	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	eligious Worsh		2054	0.57	0.10	0.08	0.22	28%	0.01	0.04	26%	0.11	0.08	i	1	0.54			0.00	0.00
NC	1030	1034 ROB 4L4' LED Tube, 2020	eligious Worsh	2020	2054	0.48	0.08	0.09	0.31	39%	0.02	0.05	38%	0.70	0.26	4	2	0.10			0.00	0.00

DNV GL H-36 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Cam	Base Number	Measure Number Measure	Building Type	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base	Economic GWH	Economic MW
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	eligious Worsh	2020	2054	0.47	0.08	0.01	0.33	41%	0.00	0.05	38%	0.35	0.27	8	2	0.14	GWII	IAIAA	0.00	0.00
NC	1030	1035 LED Troffer (base 4L4'T8), 2020	eligious Worsh		2054	0.43	0.08	0.04	0.37	46%	0.01	0.06	43%	0.60	0.30	4	2	0.12			0.00	0.00
NC NC	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	eligious Worsh eligious Worsh		2054 2054	0.61	0.10	0.00	0.00	0% 9%	0.00	0.00	0% 9%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 0.97	0.61	0.10	0.00	0.00
NC	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	eligious Worsh		2054	0.55	0.09	0.00	0.06	9%	0.00	0.01	9%	0.07	0.06	1	0	0.71			0.00	0.00
NC	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	eligious Worsh		2054 2054	0.51	0.09	0.04	0.10	16% 27%	0.01	0.02	15%	0.10	0.08	1	1	0.63			0.00	0.00
NC NC	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	eligious Worsh eligious Worsh		2054	0.44	0.08	0.06	0.16	30%	0.01	0.03	26% 29%	0.14	0.10	3	1	0.43			0.00	0.00
NC	1130	1135 LED Troffer (base 2L4'T8), 2020	eligious Worsh	2020	2054	0.39	0.07	0.04	0.22	36%	0.01	0.04	35%	0.72	0.25	4	2	0.10			0.00	0.00
NC NC	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	eligious Worsh		2054 2054	0.37	0.07	0.01 0.00	0.23	38% 0%	0.00	0.04	35% 0%	0.59 N/A	0.26 N/A	14 N/A	2 N/A	0.08 N/A	0.01	0.00	0.00	0.00
NC NC	1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	eligious Worsh eligious Worsh		2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	0.04	0.04	0 0	N/A 0	1.24	0.01	0.00	0.00	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	eligious Worsh	2014	2054	0.01	0.00	0.00	0.00	8%	0.00	0.00	8%	0.20	0.20	1	1	0.31			0.00	0.00
NC NC	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	eligious Worsh eligious Worsh		2054 2054	0.01	0.00	0.00	0.00	25% 31%	0.00	0.00	24% 26%	0.43 0.39	0.35 0.36	3 9	2	0.15 0.13			0.00	0.00
NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	eligious Worsh		2054	1.41	0.00	0.00	0.00	0%	0.00	0.00	0%	0.39 N/A	N/A	N/A	N/A	0.13 N/A	1.41	0.24	0.00	0.00
NC	1330	1332 LEDs (base incandescent flood) 2020	eligious Worsh	2020	2054	0.24	0.04	1.17	1.17	83%	0.20	0.20	83%	0.02	0.02	0	0	3.99			1.17	0.20
NC NC	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	eligious Worsh eligious Worsh		2054 2054	0.51	0.09	0.00 0.41	0.00 0.41	0% 82%	0.00 0.07	0.00 0.07	0% 82%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.37	0.51	0.09	0.00 0.41	0.00 0.07
NC	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	eligious Worsh		2054	0.03	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.37	0.06	0.00	0.00
NC	1530	1532 LEDs (base incandescent A-line 53W) 2020	eligious Worsh		2054	0.10	0.02	0.28	0.28	75%	0.05	0.05	75%	0.02	0.02	0	0	2.51			0.28	0.05
NC NC	1630 1630	1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	eligious Worsh eligious Worsh		2054 2054	0.35 0.25	0.06	0.00 0.10	0.00 0.10	0% 28%	0.00 0.02	0.00 0.02	0% 28%	N/A 0.15	N/A 0.15	N/A 1	N/A 1	N/A 0.41	0.35	0.06	0.00	0.00
NC	1730	1730 Base CFL 23W to screw-in replacement 2020	eligious Worsh		2054	0.44	0.04	0.00	0.00	0%	0.02	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.44	0.08	0.00	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	eligious Worsh		2054	0.33	0.06	0.12	0.12	26%	0.02	0.02	26%	0.11	0.11	1	1	0.54			0.00	0.00
NC NC	1800 1800	1800 BaseMetal Halide, 465W 1801 T5 (240W) (base metal halide)	eligious Worsh eligious Worsh		2054 2054	1.77 1.17	0.30	0.00	0.00	0% 34%	0.00	0.00	0% 34%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.99	1.77	0.30	0.00	0.00
NC	1800	1806 Occupancy Sensor, High Bay T5	eligious Worsh		2054	1.13	0.20	0.04	0.64	36%	0.00	0.10	34%	0.03	0.03	2	0	0.53			0.00	0.00
NC	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	eligious Worsh		2054	1.05	0.19	0.09	0.72	41%	0.01	0.11	38%	0.17	0.05	1	0	0.36			0.00	0.00
NC NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	eligious Worsh eligious Worsh		2054 2054	0.04	0.01	0.00 0.02	0.00 0.02	0% 46%	0.00	0.00	0% 46%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 0.83	0.04	0.01	0.00	0.00
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	eligious Worsh		2054	0.56	0.04	0.02	0.02	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.56	0.04	0.00	0.00
NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	eligious Worsh		2054	0.50	0.03	0.05	0.05	10%	0.01	0.01	28%	0.09	0.09	0	0	0.89			0.00	0.00
NC NC	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	eligious Worsh eligious Worsh		2054 2054	0.24	0.01	0.26 0.07	0.32	57% 69%	0.02	0.03 0.04	75% 86%	0.22 1.41	0.19 0.42	3 20	2	0.28 0.04			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	eligious Worsh		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	eligious Worsh		2054	4.00	3.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.00	3.10	0.00	0.00
NC NC	2100 2100	2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	eligious Worsh eligious Worsh		2054 2054	4.00 3.08	3.10 2.38	0.00 0.92	0.00 0.92	0% 23%	0.00 0.71	0.00 0.71	0% 23%	0.05	0.05 0.08	0	0	2.58 1.37			0.00 0.92	0.00 0.71
NC	2100	2112 Aerosol Duct Sealing - DX	eligious Worsh		2054	2.90	2.24	0.18	1.10	28%	0.14	0.85	28%	0.51	0.15	1	0	0.23			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	eligious Worsh		2054	2.83	2.23	0.07	1.17	29%	0.01	0.87	28%	0.29	0.16	1	0	0.19			0.00	0.00
NC NC	2100 2100	2108 Optimize Controls - DX 2115 Window Film (Standard) - DX	eligious Worsh eligious Worsh		2054 2054	2.79 2.78	2.22	0.05 0.01	1.21 1.23	30% 31%	0.01 0.01	0.87 0.88	28% 29%	0.30 1.43	0.16 0.18	2	0	0.17 0.06			0.00	0.00
NC	2100	2107 Cool Roof - DX	eligious Worsh		2054	2.77	2.21	0.01	1.23	31%	0.00	0.89	29%	7.28	0.21	9	0	0.01			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	eligious Worsh		2054	2.75	2.19	0.02	1.25	31%	0.01	0.90	29%	8.70	0.33	11	0	0.01			0.00	0.00
NC NC	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	eligious Worsh eligious Worsh		2054 2054	3.33 2.92	2.57 2.26	0.00 0.41	0.00 0.41	0% 12%	0.00 0.32	0.00 0.32	0% 12%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 1.28	3.33	2.57	0.00 0.41	0.00 0.32
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	eligious Worsh	2014	2054	0.06	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.04	0.00	0.00
NC	2300	2301 HE PTAC, EER=9.6, 1 ton	eligious Worsh		2054	0.05	0.04	0.01	0.01	14%	0.01	0.01	14%	0.20	0.20	0	0	0.55			0.00	0.00
NC NC	2300 3000	2302 Occupancy Sensor (hotels) 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	eligious Worsh eligious Worsh		2054 2054	0.04 1.61	0.03	0.01 0.00	0.02	27% 0%	0.01	0.01	30% 0%	0.63 N/A	0.41 N/A	N/A	0 N/A	0.17 N/A	1.61	0.46	0.00	0.00
NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	eligious Worsh	2014	2054	1.59	0.45	0.03	0.03	2%	0.01	0.01	2%	0.15	0.15	1	1	0.53			0.00	0.00
NC	3000 3000	3002 Variable Speed Drive Control, 5 HP	eligious Worsh		2054	1.11	0.42	0.48	0.51	31%	0.03	0.04	9%	0.12	0.12	2	1	0.49			0.00	0.00
NC NC	3000	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	eligious Worsh eligious Worsh		2054 2054	1.09 1.29	0.41	0.02 0.00	0.53 0.00	33% 0%	0.01 0.00	0.05 0.00	12% 0%	3.72 N/A	0.27 N/A	N/A	N/A	0.03 N/A	1.29	0.37	0.00	0.00
NC	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	eligious Worsh	2014	2054	1.10	0.32	0.19	0.19	14%	0.05	0.05	13%	0.07	0.07	0	0	1.00	-		0.19	0.05
NC NC	3100 3100	3103 Air Handler Optimization, 15 HP	eligious Worsh		2054 2054	1.03	0.31	0.08 0.31	0.26 0.57	20% 44%	0.01 0.02	0.05 0.07	14% 20%	0.09 0.16	0.08 0.12	1 2	0	0.53 0.36			0.00	0.00
NC	3100	3102 Variable Speed Drive Control, 15 HP 3101 Fan Motor, 15hp, 1800rpm, 92.4%	eligious Worsh eligious Worsh		2054	0.72	0.29	0.01	0.57	45%	0.02	0.07	21%	0.16	0.12	2	1	0.36			0.00	0.00
NC	3100	3105 Energy Recovery Ventilation (ERV)	eligious Worsh		2054	0.70	0.28	0.01	0.59	46%	0.00	0.08	23%	1.04	0.14	2	1	0.10			0.00	0.00
NC NC	3100 3200	3107 Demand Controlled Ventilation	eligious Worsh		2054 2054	0.68 1.02	0.28	0.01 0.00	0.60	47% 0%	0.01	0.09	25% 0%	4.72 N/A	0.25 N/A	9 N/A	2 N/A	0.02 N/A	1.02	0.29	0.00	0.00
NC NC	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	eligious Worsh eligious Worsh		2054	0.95	0.29	0.00	0.00	7%	0.00	0.00	2%	0.08	0.08	N/A 1	N/A 1	0.62	1.02	0.29	0.00	0.00
NC	3200	3202 Variable Speed Drive Control, 40 HP	eligious Worsh	2014	2054	0.67	0.27	0.29	0.36	35%	0.02	0.03	9%	0.25	0.22	4	3	0.23			0.00	0.00
NC NC	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	eligious Worsh		2054 2054	0.66 0.65	0.26	0.00	0.36	35% 36%	0.00	0.03	9% 11%	1.22 3.94	0.22	4	3 4	0.07			0.00	0.00
NC NC	3200 4000	4000 Base Built-Up Refrigeration System	eligious Worsh eligious Worsh		2054	0.65	0.26	0.01	0.37	36% 0%	0.01	0.03	11% 0%	3.94 N/A	0.35 N/A	N/A	4 N/A	0.02 N/A	0.00	0.00	0.00	0.00
NC	4100	4100 Base Self-Contained Refrigeration	eligious Worsh	2014	2054	2.27	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.27	0.34	0.00	0.00
NC	4100		eligious Worsh		2054	2.24	0.34	0.03	0.03	1%	0.00	0.00	1%	0.00	0.00	0	0	14.88			0.03	0.00
NC NC	4100 5000	4110 Energy Star Ice Machines 5000 Base Desktop PC	eligious Worsh eligious Worsh		2054 2054	2.23 0.96	0.34 0.15	0.01 0.00	0.04	2% 0%	0.00	0.01 0.00	2% 0%	0.03 N/A	0.01 N/A	0 N/A	0 N/A	1.75 N/A	0.96	0.15	0.01 0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	eligious Worsh	2014	2054	0.53	0.11	0.43	0.43	45%	0.03	0.03	23%	0.03	0.03	0	0	1.63		20	0.43	0.03
NC	5000	5002 Energy Star or Better PC	eligious Worsh		2054	0.36	0.09	0.17	0.60	62%	0.03	0.06	40%	0.06	0.04	0	0	0.83	0.00	0.00	0.00	0.00
NC	5100	5100 Base Laptop PC	eligious Worsh	∠014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	age			Measure	Measure	,			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Cam	Base It Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings	GWH	MW Savings	Savings MW	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
NC	5100	5102 Energy Star or Better Laptop	eligious Worsh	2014	2054	0.02	0.00	0.00	GWH 0.00	Savings 19%	0.00	0.00	Savings 19%	0.02	0.02	0	0	2.27	GWH	IVI VV	0.00	0.00
NC NC	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	eligious Worsh eligious Worsh		2054 2054	0.02	0.00	0.00	0.00	21% 0%	0.00	0.00	21% 0%	2.69 N/A	0.24 N/A	18 N/A	2 N/A	0.02 N/A	0.26	0.04	0.00	0.00
NC	5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	eligious Worsh		2054	0.26	0.04	0.14	0.14	56%	0.00	0.00	56%	0.00	0.00	0	0	18.09	0.26	0.04	0.14	0.00
NC	5200	5202 Monitor Power Management Enabling - CRT	eligious Worsh		2054	0.08	0.01	0.03	0.17	67%	0.00	0.02	62%	0.04	0.01	1	0	1.18			0.03	0.00
NC NC	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	eligious Worsh eligious Worsh		2054 2054	0.08	0.01	0.01	0.18	70% 0%	0.00	0.02	64% 0%	0.46 N/A	0.03 N/A	N/A	N/A	0.11 N/A	0.05	0.01	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	eligious Worsh	2014	2054	0.04	0.01	0.01	0.01	18%	0.00	0.00	18%	0.03	0.03	0	0	2.04			0.01	0.00
NC NC	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	eligious Worsh eligious Worsh		2054 2054	0.04	0.01	0.00	0.01 0.01	21% 27%	0.00	0.00	19% 21%	0.23 0.66	0.05 0.19	3 17	0 2	0.20 0.07			0.00	0.00
NC	5400	5400 Base Copier	eligious Worsh	2014	2054	1.02	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.02	0.15	0.00	0.00
NC NC	5400 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	eligious Worsh eligious Worsh		2054 2054	0.88	0.13 0.13	0.14 0.04	0.14 0.18	13% 18%	0.02	0.02	13% 16%	0.00 0.21	0.00 0.05	0	0	13.32 0.23			0.14	0.02
NC	5500	5500 Base Multifunction	eligious Worsh		2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC NC	5500 5500	5502 ENERGY STAR Multi-Function Device	eligious Worsh		2054 2054	0.02	0.00	0.01	0.01	25% 37%	0.00	0.00	25% 31%	0.01	0.01	0 7	0	3.79 0.08			0.01	0.00
NC	5600	5501 Multifunction Power Management Enabling 5600 Base Printer	eligious Worsh eligious Worsh		2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	0.56 N/A	0.19 N/A	N/A	N/A	N/A	0.03	0.01	0.00	0.00
NC	5600 5600	5602 ENERGY STAR Printer	eligious Worsh		2054	0.02	0.00	0.01	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	17.44			0.01	0.00
NC NC	5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	eligious Worsh eligious Worsh		2054 2054	0.02	0.00	0.00	0.02	45% 0%	0.00	0.00	40% 0%	0.12 N/A	0.03 N/A	2 N/A	0 N/A	0.39 N/A	0.08	0.01	0.00	0.00
NC	5700	5701 Data Center Improved Operations	eligious Worsh	2014	2054	0.08	0.01	0.01	0.01	10%	0.00	0.00	10%	0.00	0.00	0	0	60.38			0.01	0.00
NC NC	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	eligious Worsh eligious Worsh		2054 2054	0.07	0.01 0.01	0.01 0.00	0.02	21% 26%	0.00	0.00	21% 26%	0.00	0.00	0	0	24.58 12.75			0.01 0.00	0.00
NC	6000	6000 Base Water Heating	eligious Worsh	2014	2054	0.37	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.37	0.06	0.00	0.00
NC NC	6000 6000	6007 Heat Trap	eligious Worsh		2054 2054	0.35 0.35	0.05	0.02	0.02	5% 7%	0.00	0.00	5% 7%	0.03	0.03 0.04	0	0	1.67 0.89			0.02	0.00
NC	6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	eligious Worsh eligious Worsh		2054	0.32	0.05	0.01	0.05	14%	0.00	0.00	14%	0.07	0.04	1	1	0.63			0.00	0.00
NC	6000	6003 Hot Water Pipe Insulation	eligious Worsh	2014	2054	0.31	0.05	0.01	0.06	16%	0.00	0.01	16%	0.13	0.08	1	1	0.49			0.00	0.00
NC NC	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	eligious Worsh eligious Worsh		2054 2054	0.30	0.04	0.01 0.01	0.07	18% 22%	0.00	0.01 0.01	18% 22%	0.13 0.37	0.09 0.13	1 2	1	0.46 0.18			0.00	0.00
NC	7000	7000 Base Refrigerated Vending Machines	eligious Worsh	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7100 7200	7100 Base Non-Refrigerated Vending Machines 7200 Base Oven	eligious Worsh eligious Worsh	2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	7300	7300 Base Fryer	eligious Worsh		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	eligious Worsh	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	eligious Worsh eligious Worsh		2054	0.13	0.00	0.00	0.00	6%	0.00	0.00	0%	0.07	0.07	N/A	N/A	0.79	0.13	0.00	0.00	0.00
NC	8100	8100 Base Heating, Other Electric	eligious Worsh	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	9500 9500	9500 Base Miscellaneous 9501 Xmisc	eligious Worsh eligious Worsh	2014	2054 2054	8.84 8.84	1.47 1.47	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	8.84	1.47	0.00	0.00
NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Misc	2020	2054	5.29	0.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.29	0.90	0.00	0.00
NC NC	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Misc Misc	2020 2020	2054 2054	5.29 4.89	0.90 0.84	0.00 0.40	0.00 0.40	0% 8%	0.00 0.05	0.00 0.05	0% 6%	0.01 0.02	0.01 0.02	0	0	3.68 3.24			0.00 0.40	0.00 0.05
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Misc	2020	2054	4.38	0.76	0.51	0.91	17%	0.09	0.14	16%	0.02	0.02	0	0	2.76			0.51	0.09
NC NC	1030 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Misc Misc	2020 2020	2054 2054	3.82 3.71	0.66	0.56	1.46 1.58	28% 30%	0.09	0.23 0.24	26% 27%	0.04	0.03	0	0	1.32 0.63			0.56	0.09
NC	1030	1037 Occupancy Senson, 424 Fluorescent Fixtures, 2020	Misc	2020	2054	3.11	0.56	0.60	2.17	41%	0.10	0.34	38%	0.05	0.03	1	1	0.05			0.00	0.00
NC	1030	1035 LED Troffer (base 4L4'T8), 2020	Misc	2020	2054	2.85	0.51	0.27	2.44	46%	0.05	0.39	43%	0.20	0.10	1	1	0.31			0.00	0.00
NC NC	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Misc Misc	2020 2020	2054 2054	4.05 4.05	0.69 0.69	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.99	4.05	0.69	0.00	0.00
NC	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Misc	2020	2054	3.74	0.65	0.31	0.31	8%	0.04	0.04	6%	0.02	0.02	0	0	2.63			0.31	0.04
NC NC	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Misc Misc	2020 2020	2054 2054	3.39 2.96	0.59 0.51	0.35 0.43	0.66 1.09	16% 27%	0.06 0.07	0.10 0.17	15% 25%	0.02 0.05	0.02 0.04	0	0	2.20 1.06			0.35	0.06 0.07
NC	1130	1134 ROB 2L4' LED Tube, 2020	Misc	2020	2054	2.81	0.49	0.14	1.23	31%	0.02	0.20	29%	0.19	0.05	1	ō	0.33			0.00	0.00
NC NC	1130 1130	1135 LED Troffer (base 2L4'T8), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Misc Misc	2020 2020	2054 2054	2.57 2.50	0.45 0.44	0.24 0.07	1.47 1.55	36% 38%	0.04 0.00	0.24 0.24	35% 35%	0.24 0.15	0.08 0.09	1	1	0.26 0.31			0.00	0.00
NC	1200	1200 Base Other Fluorescent Fixture	Misc	2014	2054	0.06	0.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00	0.00
NC	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Misc	2014	2054	0.06	0.01	0.00	0.00	0% 8%	0.00	0.00	0%	0.01	0.01	0	0	4.71			0.00	0.00
NC NC	1200 1200	1201 ROB High Performance T8 (base other fluorescent) 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Misc Misc	2014 2014	2054 2054	0.05 0.05	0.01	0.00	0.00 0.01	15%	0.00	0.00	8% 13%	0.07 0.10	0.07 0.08	0 1	1	0.76 0.64			0.00	0.00
NC	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Misc	2014	2054	0.04	0.01	0.00	0.01	21%	0.00	0.00	15%	0.09	0.09	2	1	0.55			0.00	0.00
NC NC	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Misc Misc	2020 2020	2054 2054	24.26 4.12	4.12 0.70	0.00 20.13	0.00 20.13	0% 83%	0.00 3.42	0.00 3.42	0% 83%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 10.21	24.26	4.12	0.00 20.13	0.00 3.42
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Misc	2020	2054	8.73	1.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.73	1.48	0.00	0.00
NC NC	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Misc Misc	2020 2020	2054 2054	1.62 6.43	0.27 1.09	7.12 0.00	7.12 0.00	82% 0%	1.21 0.00	1.21 0.00	82% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	8.62 N/A	6.43	1.09	7.12 0.00	1.21 0.00
NC	1530	1530 Base incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Misc	2020	2054	1.64	0.28	4.79	4.79	75%	0.81	0.81	75%	0.01	0.01	0	0	6.43	0.43		4.79	0.00
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Misc	2020	2054	0.78	0.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.78	0.13	0.00	0.00
NC NC	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Misc Misc	2020 2020	2054 2054	0.56 0.99	0.10 0.17	0.22	0.22	28% 0%	0.04	0.04 0.00	28% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.05 N/A	0.99	0.17	0.22	0.04
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Misc	2020	2054	0.73	0.12	0.26	0.26	26%	0.04	0.04	26%	0.04	0.04	0	0	1.39			0.26	0.04
NC NC	1800 1800	1800 BaseMetal Halide, 465W 1801 T5 (240W) (base metal halide)	Misc Misc	2014 2014	2054 2054	3.54 2.34	0.60 0.40	0.00 1.20	0.00 1.20	0% 34%	0.00 0.20	0.00 0.20	0% 34%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.55	3.54	0.60	0.00 1.20	0.00 0.20
NC	1800	1806 Occupancy Sensor, High Bay T5	Misc	2014	2054	2.27	0.39	0.08	1.27	36%	0.00	0.21	34%	0.02	0.01	1	0	2.00			0.08	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Sami	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic
NC	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Misc	2014	2054	2.09	0.37	0.17	1.44	41%	0.02	0.23	38%	0.05	0.01	0	0	1.38			0.17	0.02
NC NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Misc Misc	2014 2014	2054 2054	0.26 0.14	0.04	0.00 0.12	0.00 0.12	0% 46%	0.00 0.02	0.00 0.02	0% 46%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.95	0.26	0.04	0.00 0.12	0.00 0.02
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Misc	2014	2054	1.53	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.53	0.12	0.00	0.00
NC NC	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Misc Misc	2014 2014	2054 2054	1.40 0.68	0.09	0.13 0.73	0.13 0.86	9% 56%	0.03	0.03	25% 72%	0.04 0.09	0.04	0	0	2.12 0.67			0.13	0.03
NC	1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Misc	2014	2054	0.68	0.03	0.73	1.06	69%	0.06	0.09	72% 84%	0.09	0.08	8	2	0.67			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons 2113 Ceiling/roof Insulation - DX	Misc Misc	2014 2014	2054 2054	3.24	2.51 2.51	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 6.16	3.24	2.51	0.00	0.00
NC NC	2100	2102 DX Packaged System, EER=13.4, 10 tons	Misc	2014	2054	2.49	1.93	0.00	0.00	23%	0.58	0.00	23%	0.02	0.02	0	0	3.27			0.00	0.00
NC	2100	2105 DX Tune Up/ Advanced Diagnostics	Misc	2014	2054	2.49	1.93	0.00	0.75	23%	0.00	0.58	23%	0.11	0.03	0	0	0.61			0.00	0.00
NC NC	2100 2100	2112 Aerosol Duct Sealing - DX 2106 Prog. Thermostat - DX	Misc Misc	2014 2014	2054 2054	2.35	1.82 1.81	0.15	0.89 0.94	28% 29%	0.11	0.69 0.70	28% 28%	0.21	0.06	0	0	0.54			0.00	0.00
NC	2100	2108 Optimize Controls - DX	Misc	2014	2054	2.26	1.80	0.04	0.94	30%	0.01	0.70	28%	0.12	0.07	1	0	0.40			0.00	0.00
NC	2100	2115 Window Film (Standard) - DX	Misc	2014	2054	2.25	1.79	0.01	0.98	30%	0.01	0.71	28%	0.59	0.07	1	0	0.15			0.00	0.00
NC NC	2100 2100	2107 Cool Roof - DX 2114 Duct/Pipe Insulation - DX	Misc Misc	2014 2014	2054 2054	2.25	1.79 1.78	0.00	0.99 1.00	31% 31%	0.00	0.72	29% 29%	3.03 3.63	0.09	4 5	0	0.03			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Misc	2014	2054	17.26	13.35	0.00	0.00	0%	0.00	0.73	0%	3.63 N/A	0.14 N/A	N/A	N/A	0.03 N/A	17.26	13.35	0.00	0.00
NC	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	2014	2054	15.13	11.70	2.14	2.14	12%	1.65	1.65	12%	0.04	0.04	0	0	3.05			2.14	1.65
NC NC	2300 2300	2300 Base PTAC, EER=8.3, 1 ton 2301 HE PTAC, EER=9.6, 1 ton	Misc Misc	2014 2014	2054 2054	4.26 3.69	3.30 2.85	0.00 0.58	0.00 0.58	0% 14%	0.00 0.45	0.00 0.45	0% 14%	N/A 0.08	N/A 0.08	N/A 0	N/A 0	N/A 1.33	4.26	3.30	0.00 0.58	0.00 0.45
NC	2300	2302 Occupancy Sensor (hotels)	Misc	2014	2054	3.13	2.29	0.55	1.13	27%	0.56	1.00	30%	0.06	0.17	0	0	0.40			0.00	0.00
NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Misc	2014	2054	9.78	2.78	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.78	2.78	0.00	0.00
NC NC	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP	Misc Misc	2014 2014	2054 2054	9.61 6.72	2.73 2.53	0.17 2.89	0.17 3.06	2% 31%	0.05 0.20	0.05 0.25	2% 9%	0.06 0.05	0.06 0.05	0	0	1.26 1.17			0.17 2.89	0.05 0.20
NC	3000	3003 Demand Controlled Ventilation	Misc	2014	2054	6.59	2.45	0.13	3.19	33%	0.20	0.23	12%	1.56	0.03	3	1	0.06			0.00	0.00
NC	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Misc	2014	2054	7.79	2.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.79	2.21	0.00	0.00
NC NC	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Misc Misc	2014 2014	2054 2054	6.67 6.21	1.93 1.90	1.12 0.46	1.12 1.58	14% 20%	0.29	0.29 0.32	13% 14%	0.03 0.04	0.03	0	0	2.40 1.26			1.12 0.46	0.29
NC	3100	3102 Variable Speed Drive Control, 15 HP	Misc	2014	2054	4.34	1.76	1.87	3.45	44%	0.13	0.45	20%	0.07	0.05	1	ő	0.86			0.00	0.00
NC	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Misc	2014	2054	4.28	1.74	0.06	3.52	45%	0.02	0.47	21%	0.21	0.05	1	0	0.38			0.00	0.00
NC NC	3100 3100	3105 Energy Recovery Ventilation (ERV) 3107 Demand Controlled Ventilation	Misc Misc	2014 2014	2054 2054	4.22 4.14	1.71 1.67	0.05 0.08	3.57 3.65	46% 47%	0.03	0.50 0.55	23% 25%	0.43 1.97	0.06 0.10	1	0	0.24			0.00	0.00
NC	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Misc	2014	2054	6.19	1.76	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.19	1.76	0.00	0.00
NC	3200	3203 Air Handler Optimization, 40 HP	Misc	2014	2054	5.76	1.73	0.42	0.42	7%	0.03	0.03	2%	0.03	0.03	0	0	1.47			0.42	0.03
NC NC	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	Misc Misc	2014 2014	2054 2054	4.03 4.01	1.60 1.60	1.73	2.16	35% 35%	0.12	0.15	9% 9%	0.10 0.51	0.09	1 2	1	0.55			0.00	0.00
NC	3200	3204 Demand Controlled Ventilation	Misc	2014	2054	3.93	1.56	0.02	2.25	36%	0.04	0.20	11%	1.65	0.15	3	2	0.06			0.00	0.00
NC	4000	4000 Base Built-Up Refrigeration System	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	4100 4100	4100 Base Self-Contained Refrigeration 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Misc Misc	2014 2014	2054 2054	10.36 10.21	1.56 1.54	0.00 0.15	0.00 0.15	0% 1%	0.00 0.02	0.00 0.02	0% 1%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 35.57	10.36	1.56	0.00 0.15	0.00 0.02
NC	4100	4108 Energy-Star Refrigerator, glass door	Misc	2014	2054	10.20	1.54	0.01	0.15	1%	0.00	0.02	1%	0.00	0.00	0	ō	11.48			0.01	0.00
NC	4100	4106 Energy-Star Refrigerator, solid door	Misc	2014	2054	10.19	1.53	0.01	0.17	2%	0.00	0.03	2%	0.01	0.00	0	0	11.32			0.01	0.00
NC NC	4100 4100	4110 Energy Star Ice Machines 4112 Reach-in unit occupancy sensors	Misc Misc	2014 2014	2054 2054	10.17 10.17	1.53 1.53	0.02	0.18 0.18	2% 2%	0.00	0.03	2% 2%	0.01 0.26	0.00	0	0	4.18 0.22			0.02	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Misc	2014	2054	10.17	1.53	0.00	0.18	2%	0.00	0.03	2%	0.30	0.00	2	ō	0.18			0.00	0.00
NC	5000	5000 Base Desktop PC	Misc	2014	2054	0.72	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.72	0.11	0.00	0.00
NC NC	5000 5000	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	Misc Misc	2014 2014	2054 2054	0.40	0.08	0.33 0.12	0.33 0.45	45% 62%	0.03 0.02	0.03 0.04	23% 40%	0.01 0.03	0.01 0.02	0	0	3.90 1.98			0.33 0.12	0.03 0.02
NC	5100	5100 Base Laptop PC	Misc	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00	0.00
NC	5100	5102 Energy Star or Better Laptop	Misc	2014	2054	0.02	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	5.43			0.00	0.00
NC NC	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Misc Misc	2014 2014	2054 2054	0.02	0.00	0.00	0.01	21% 0%	0.00	0.00	21% 0%	1.13 N/A	0.10 N/A	N/A	N/A	0.05 N/A	0.24	0.04	0.00	0.00
NC	5200	5201 Energy Star or Better Monitor - CRT	Misc	2014	2054	0.11	0.02	0.13	0.13	56%	0.02	0.02	56%	0.00	0.00	0	0	43.26			0.13	0.02
NC	5200	5202 Monitor Power Management Enabling - CRT	Misc	2014	2054	0.08	0.01	0.03	0.16	67%	0.00	0.02	62%	0.02	0.00	0	0	2.81			0.03	0.00
NC NC	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Misc Misc	2014 2014	2054 2054	0.07	0.01	0.01 0.00	0.17	70% 0%	0.00	0.02	64% 0%	0.19 N/A	0.01 N/A	1 N/A	0 N/A	0.26 N/A	0.10	0.01	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	Misc	2014	2054	0.08	0.01	0.02	0.02	18%	0.00	0.00	18%	0.01	0.01	0	0	4.88			0.02	0.00
NC	5300 5300	5302 Monitor Power Management Enabling - LCD	Misc	2014 2014	2054	0.08	0.01	0.00	0.02	21% 27%	0.00	0.00	19% 21%	0.10 0.28	0.02	1 7	0	0.48			0.00	0.00
NC NC	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Misc Misc	2014	2054 2054	0.07	0.01	0.01 0.00	0.03	27% 0%	0.00	0.00	21% 0%	0.28 N/A	0.08 N/A	N/A	1 N/A	0.16 N/A	0.23	0.04	0.00	0.00
NC	5400	5401 Energy Star or Better Copier	Misc	2014	2054	0.20	0.03	0.03	0.03	13%	0.00	0.00	13%	0.00	0.00	0	0	31.86			0.03	0.00
NC	5400	5402 Copier Power Management Enabling 5500 Base Multifunction	Misc	2014 2014	2054	0.19	0.03	0.01	0.04	18% 0%	0.00	0.01	16% 0%	0.09	0.02 N/A	1	0	0.55	0.02	0.00	0.00	0.00
NC NC	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Misc Misc	2014	2054 2054	0.02	0.00	0.00 0.01	0.00 0.01	0% 25%	0.00	0.00	0% 25%	N/A 0.01	0.01	N/A 0	N/A 0	N/A 9.07	0.02	0.00	0.00 0.01	0.00
NC	5500	5501 Multifunction Power Management Enabling	Misc	2014	2054	0.01	0.00	0.00	0.01	37%	0.00	0.00	31%	0.23	0.08	3	1	0.20			0.00	0.00
NC	5600	5600 Base Printer	Misc	2014	2054	0.16	0.02	0.00	0.00	0% 35%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.16	0.02	0.00	0.00
NC NC	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Misc	2014	2054 2054	0.10	0.02	0.06 0.02	0.06 0.07	35% 45%	0.01 0.00	0.01 0.01	35% 40%	0.00 0.05	0.00 0.01	0 1	0	41.71 0.93			0.06	0.01 0.00
NC	5700	5700 Base Data Center/Server Room	Misc	2014	2054	2.15	0.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.15	0.33	0.00	0.00
NC NC	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Misc Misc	2014 2014	2054 2054	1.94	0.29	0.22 0.25	0.22 0.46	10% 21%	0.03	0.03 0.07	10% 21%	0.00	0.00	0	0	105.02 42.75			0.22	0.03
NC NC	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Misc	2014	2054	1.69	0.26 0.24	0.25	0.46	21% 26%	0.04	0.07	21% 26%	0.00	0.00	0	0	42.75 22.17			0.25	0.04
	2.00															-	-					

APPENDIX H

Base Avoided Costs

Con	mercial Elect	ric Existing Construction																				
		ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	ige								Total			Total		Marginal	Average	Marginal	Average	Total				/
				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource				/
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm		Number Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
NC	6000	6000 Base Water Heating	Misc	2014	2054	4.94	0.73	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.94	0.73	0.00	0.00
NC	6000	6007 Heat Trap	Misc	2014	2054	4.68	0.69	0.26	0.26	5%	0.04	0.04	5%	0.01	0.01	0	0	3.99			0.26	0.04
NC	6000	6002 High Efficiency Water Heater (electric)	Misc	2014	2054	4.59	0.68	0.09	0.35	7%	0.01	0.05	7%	0.03	0.02	0	0	2.13			0.09	0.01
NC	6000	6004 Tankless Water Heater	Misc	2014	2054	4.24	0.63	0.34	0.69	14%	0.05	0.10	14%	0.05	0.03	0	0	1.52			0.34	0.05
NC	6000	6003 Hot Water Pipe Insulation	Misc	2014	2054	4.16	0.61	0.08	0.78	16%	0.01	0.11	16%	0.05	0.03	0	0	1.18			0.08	0.01
NC	6000	6006 Heat Recovery Unit	Misc	2014	2054	4.02	0.59	0.14	0.91	18%	0.02	0.13	18%	0.05	0.04	0	0	1.10			0.14	0.02
NC	6000	6001 Demand controlled circulating systems	Misc	2014	2054	3.87	0.57	0.15	1.06	22%	0.02	0.16	22%	0.15	0.05	1	0	0.42			0.00	0.00
NC	7000	7000 Base Refrigerated Vending Machines	Misc	2014	2054	0.60	0.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.60	0.10	0.00	0.00
NC	7000	7001 Vending Misers (Refrigerated units)	Misc	2014	2054	0.51	0.09	0.09	0.09	16%	0.01	0.01	8%	0.03	0.03	0	0	1.85			0.09	0.01
NC	7000	7002 Vending Misers (Refrigerated glass-front units)	Misc	2014	2054	0.46	0.09	0.05	0.15	24%	0.00	0.01	12%	0.05	0.03	1	0	1.01			0.05	0.00
NC	7100	7100 Base Non-Refrigerated Vending Machines	Misc	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	7100	7101 Vending Misers (Non-Refrigerated)	Misc	2014	2054	0.00	0.00	0.00	0.00	45%	0.00	0.00	23%	0.43	0.43	5	5	0.11			0.00	0.00
NC	7200	7200 Base Oven	Misc	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	7300	7300 Base Fryer	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	7300	7301 Efficient Fryer	Misc	2014	2054	0.00	0.00	0.00	0.00	6%	0.00	0.00	6%	0.46	0.46	3	3	0.13			0.00	0.00
NC	7400	7400 Base Steamer	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Misc	2014	2054	3.96	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.96	0.00	0.00	0.00
NC	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	2014	2054	3.73	0.00	0.22	0.22	6%	0.00	0.00	0%	0.03	0.03	N/A	N/A	1.89			0.22	0.00
NC	8100	8100 Base Heating, Other Electric	Misc	2014	2054	0.12	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.00	0.00	0.00
NC	9500	9500 Base Miscellaneous	Misc	2014	2054	22.38	3.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	22.38	3.72	0.00	0.00
NC	9500	9501 Xmisc	Misc	2014	2054	22.38	3.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00

APPENDIX H

Base Avoided Costs

DSM A		E SUPPLY ANALYSIS		Year	2020	Year	2014														SUPPLY	
Vintag	e			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base Mea		Building	Start Year	End Year	Total	Total MW	GWH	Savings	GWH	MW	Savings MW	MW	Cost	Cost	Cost \$/kW	Cost	Cost Test	Base GWH	Base MW	Economic	
VA	Number Num	100 Base Bldg Design - 15%	Type Office	2014	2053	45.23	10.30	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	N/A	\$/kW N/A	TRC N/A	45.23	10.30	0.00	0.00
VA	100	101 High Performance Building/Int Design - Tier 1 15% - Office	Office	2014	2053	38.32	8.29	6.91	6.91	15%	2.01	2.01	20%	0.04	0.04	0	0	1.93	00.40	0.04	6.91	2.01
VA VA	200 200	200 Base Bldg Design - 30% 201 High Performance Building/Int Design - Tier 2 30% - Office	Office Office	2014 2014	2053 2053	36.18 25.13	8.24 5.03	0.00 11.05	0.00 11.05	0% 31%	0.00 3.21	0.00 3.21	0% 39%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.71	36.18	8.24	0.00 11.05	0.00 3.21
VA	300	300 Base Bldg Design - 50%	Office	2014	2053	8.14	1.85	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.14	1.85	0.00	0.00
VA VA	300 400	301 High Performance Building/Int Design - Tier 3 50% - Office 400 Base Bldg Design - 70%	Office Office	2014 2014	2053 2053	4.00 0.90	0.65	4.14 0.00	4.14 0.00	51% 0%	1.21 0.00	1.21	65% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	2.58 N/A	0.90	0.21	4.14 0.00	1.21 0.00
VA	400	401 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	Office	2014	2053	0.26	0.02	0.64	0.64	71%	0.19	0.19	91%	0.04	0.04	0	0	2.30	0.50		0.64	0.00
NC NC	100	100 Base Bldg Design - 15%	Office Office	2014 2014	2053 2053	1.89	0.43	0.00 0.29	0.00	0% 15%	0.00	0.00	0% 20%	N/A 0.04	N/A 0.04	N/A	N/A	N/A	1.89	0.43	0.00	0.00
NC NC	100 200	101 High Performance Building/Int Design - Tier 1 15% - Office 200 Base Bldg Design - 30%	Office	2014	2053	1.51	0.35	0.29	0.29	0%	0.08	0.08	20% 0%	0.04 N/A	0.04 N/A	N/A	N/A	2.30 N/A	1.51	0.34	0.29	0.08
NC	200	201 High Performance Building/Int Design - Tier 2 30% - Office	Office	2014	2053	1.05	0.21	0.46	0.46	31%	0.13	0.13	39%	0.03	0.03	0	0	3.22			0.46	0.13
NC NC	300 300	300 Base Bldg Design - 50% 301 High Performance Building/Int Design - Tier 3 50% - Office	Office Office	2014 2014	2053 2053	0.34	0.08	0.00	0.00	0% 51%	0.00 0.05	0.00 0.05	0% 65%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.07	0.34	0.08	0.00 0.17	0.00 0.05
NC	400	400 Base Bldg Design - 70%	Office	2014	2053	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
NC VA	400 100	401 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office 100 Base Bldg Design - 15%	Office Restaurant	2014 2014	2053 2053	0.01 19.73	0.00 4.18	0.03	0.03	71% 0%	0.01	0.01	91% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	2.74 N/A	19.73	4.18	0.03	0.01
VA	100	102 High Performance Building/Int Design - Tier 1 15% - Restaurant	Restaurant	2014	2053	16.73	3.36	3.00	3.00	15%	0.81	0.81	20%	0.05	0.05	0	0	1.60	19.73	4.10	3.00	0.81
VA	200	200 Base Bldg Design - 30%	Restaurant	2014	2053	15.79	3.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.79	3.34	0.00	0.00
VA VA	200 300	202 High Performance Building/Int Design - Tier 2 30% - Restaurant 300 Base Bldg Design - 50%	Restaurant Restaurant	2014 2014	2053 2053	10.98 3.55	2.04 0.75	4.80 0.00	4.80 0.00	30% 0%	1.30 0.00	1.30 0.00	39% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	2.24 N/A	3.55	0.75	4.80 0.00	1.30 0.00
VA	300	302 High Performance Building/Int Design - Tier 3 50% - Restaurant	Restaurant	2014	2053	1.75	0.26	1.80	1.80	51%	0.49	0.49	65%	0.04	0.04	0	0	2.13			1.80	0.49
VA VA	400 400	400 Base Bldg Design - 70% 402 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaurant	Restaurant Restaurant	2014 2014	2053 2053	0.39	0.08	0.00	0.00 0.28	0% 71%	0.00	0.00	0% 91%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.90	0.39	0.08	0.00 0.28	0.00 80.0
NC	100	100 Base Bldg Design - 15%	Restaurant	2014	2053	0.52	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.52	0.11	0.00	0.00
NC NC	100 200	102 High Performance Building/Int Design - Tier 1 15% - Restaurant	Restaurant Restaurant	2014 2014	2053 2053	0.44	0.09	0.08	0.08	15% 0%	0.02	0.02 0.00	20% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	1.90 N/A	0.40	0.00	0.08	0.02
NC	200	200 Base Bldg Design - 30% 202 High Performance Building/Int Design - Tier 2 30% - Restaurant	Restaurant	2014	2053	0.42	0.09	0.00	0.00	30%	0.00	0.00	39%	0.03	0.03	N/A 0	N/A 0	2.67	0.42	0.09	0.00	0.00
NC	300	300 Base Bldg Design - 50%	Restaurant	2014	2053	0.09	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.02	0.00	0.00
NC NC	300 400	302 High Performance Building/Int Design - Tier 3 50% - Restaurant 400 Base Bldg Design - 70%	Restaurant Restaurant	2014 2014	2053 2053	0.05	0.01	0.05 0.00	0.05 0.00	51% 0%	0.01 0.00	0.01 0.00	65% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	2.54 N/A	0.01	0.00	0.05 0.00	0.01 0.00
NC	400	402 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaurant	Restaurant	2014	2053	0.00	0.00	0.01	0.01	71%	0.00	0.00	91%	0.04	0.04	0	0	2.26			0.01	0.00
VA VA	100 100	100 Base Bldg Design - 15% 103 High Performance Building/Int Design - Tier 1 15% - Retail	Retail Retail	2014 2014	2053 2053	40.98 34.72	9.62 7.74	0.00 6.26	0.00 6.26	0% 15%	0.00 1.88	0.00 1.88	0% 20%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.93	40.98	9.62	0.00	0.00
VA	200	200 Base Bldg Design - 30%	Retail	2014	2053	32.78	7.69	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	32.78	7.69	0.00	0.00
VA	200	203 High Performance Building/Int Design - Tier 2 30% - Retail	Retail	2014	2053	22.77	4.69	10.01	10.01	31%	3.00	3.00	39%	0.06	0.06	0	0	1.30			10.01	3.00
VA VA	300 300	300 Base Bldg Design - 50% 303 High Performance Building/Int Design - Tier 3 50% - Retail	Retail Retail	2014 2014	2053 2053	7.38	1.73 0.61	0.00 3.75	0.00 3.75	0% 51%	0.00	0.00	0% 65%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.24	7.38	1.73	0.00 3.75	0.00
VA	400	400 Base Bldg Design - 70%	Retail	2014	2053	0.82	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.82	0.19	0.00	0.00
VA NC	400 100	403 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Retail 100 Base Bldg Design - 15%	Retail Retail	2014 2014	2053 2053	0.24 1.09	0.02	0.58	0.58 0.00	71% 0%	0.18	0.18 0.00	91% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.10 N/A	1.09	0.25	0.58	0.18 0.00
NC	100	103 High Performance Building/Int Design - Tier 1 15% - Retail	Retail	2014	2053	0.92	0.23	0.17	0.17	15%	0.05	0.05	20%	0.07	0.07	0	0	1.10	1.05	0.23	0.17	0.05
NC NC	200	200 Base Bldg Design - 30%	Retail Retail	2014 2014	2053 2053	0.87	0.20	0.00	0.00	0% 31%	0.00	0.00	0% 39%	N/A 0.05	N/A 0.05	N/A	N/A	N/A 1.55	0.87	0.20	0.00	0.00
NC NC	200 300	203 High Performance Building/Int Design - Tier 2 30% - Retail 300 Base Bldg Design - 50%	Retail	2014	2053	0.60	0.12	0.27	0.27	0%	0.08	0.08	0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.55 N/A	0.20	0.05	0.27	0.08
NC	300	303 High Performance Building/Int Design - Tier 3 50% - Retail	Retail	2014	2053	0.10	0.02	0.10	0.10	51%	0.03	0.03	65%	0.06	0.06	0	0	1.47			0.10	0.03
NC NC	400 400	400 Base Bldg Design - 70% 403 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Retail	Retail Retail	2014 2014	2053 2053	0.02	0.01	0.00 0.02	0.00 0.02	0% 71%	0.00	0.00	0% 91%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.31	0.02	0.01	0.00 0.02	0.00
VA	100	100 Base Bldg Design - 15%	Grocery	2014	2053	8.82	1.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.82	1.49	0.00	0.00
VA	100	104 High Performance Building/Int Design - Tier 1 15% - Grocery	Grocery	2014	2053 2053	7.49	1.20	1.33	1.33	15%	0.29	0.29	20%	0.03	0.03 N/A	0	0	2.38	7.00	4.40	1.33	0.29
VA VA	200 200	200 Base Bldg Design - 30% 204 High Performance Building/Int Design - Tier 2 30% - Grocery	Grocery Grocery	2014 2014	2053	7.06 4.93	1.19 0.73	0.00 2.13	0.00 2.13	0% 30%	0.00 0.46	0.00 0.46	0% 39%	N/A 0.02	0.02	N/A 0	N/A 0	N/A 3.33	7.06	1.19	0.00 2.13	0.00 0.46
VA	300	300 Base Bldg Design - 50%	Grocery	2014	2053	1.59	0.27	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.59	0.27	0.00	0.00
VA VA	300 400	304 High Performance Building/Int Design - Tier 3 50% - Grocery 400 Base Bldg Design - 70%	Grocery Grocery	2014 2014	2053 2053	0.79	0.09	0.80	0.80	50% 0%	0.17	0.17	65% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	3.17 N/A	0.18	0.03	0.80	0.17
VA	400	404 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Grocery	Grocery	2014	2053	0.05	0.00	0.12	0.12	70%	0.03	0.03	91%	0.03	0.03	0	0	2.83			0.12	0.03
NC NC	100 100	100 Base Bldg Design - 15% 104 High Performance Building/Int Design - Tier 1 15% - Grocery	Grocery Grocery	2014 2014	2053 2053	0.23	0.04	0.00	0.00 0.04	0% 15%	0.00	0.00 0.01	0% 20%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.84	0.23	0.04	0.00	0.00 0.01
NC	200	200 Base Bldg Design - 30%	Grocery	2014	2053	0.19	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.19	0.03	0.00	0.00
NC	200	204 High Performance Building/Int Design - Tier 2 30% - Grocery	Grocery	2014	2053	0.13	0.02	0.06	0.06	30%	0.01	0.01	39%	0.02	0.02	0	0	3.97			0.06	0.01
NC NC	300 300	300 Base Bldg Design - 50% 304 High Performance Building/Int Design - Tier 3 50% - Grocery	Grocery Grocery	2014 2014	2053 2053	0.04	0.01	0.00 0.02	0.00 0.02	0% 50%	0.00	0.00	0% 65%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.78	0.04	0.01	0.00 0.02	0.00
NC	400	400 Base Bldg Design - 70%	Grocery	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC VA	400 100	404 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Grocery 100 Base Bldg Design - 15%	Grocery Warehouse	2014 2014	2053 2053	0.00 16.15	0.00 3.16	0.00	0.00	70% 0%	0.00	0.00	91% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	3.37 N/A	16.15	3.16	0.00	0.00
VA	100	105 High Performance Building/Int Design - Tier 1 15% - Warehouse	Warehouse	2014	2053	13.70	2.54	2.45	2.45	15%	0.62	0.62	20%	0.10	0.10	0	0	0.75			0.00	0.00
VA	200	200 Base Bldg Design - 30%	Warehouse	2014	2053	12.92	2.53	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.92	2.53	0.00	0.00
VA VA	200 300	205 High Performance Building/Int Design - Tier 2 30% - Warehouse 300 Base Bldg Design - 50%	Warehouse Warehouse	2014 2014	2053 2053	8.99 2.91	1.54 0.57	3.93 0.00	3.93 0.00	30% 0%	0.98	0.98	39% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.05 N/A	2.91	0.57	3.93 0.00	0.98
VA	300	305 High Performance Building/Int Design - Tier 3 50% - Warehouse	Warehouse	2014	2053	1.43	0.20	1.47	1.47	51%	0.37	0.37	65%	0.08	0.08	0	0	1.00			1.47	0.37
VA VA	400 400	400 Base Bldg Design - 70% 405 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Warehouse	Warehouse Warehouse	2014 2014	2053 2053	0.32	0.06	0.00 0.23	0.00 0.23	0% 71%	0.00	0.00 0.06	0% 91%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.89	0.32	0.06	0.00	0.00
NC	100	100 Base Bldg Design - 15%	Warehouse	2014	2053	0.40	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.40	0.08	0.00	0.00
NC	100	105 High Performance Building/Int Design - Tier 1 15% - Warehouse	Warehouse	2014	2053	0.34	0.06	0.06	0.06	15%	0.02	0.02	20%	0.09	0.09	0	0	0.90			0.00	0.00

APPENDIX H

Base Avoided Costs

DSM		SUPPLY ANALYSIS		Year	2020	Year	2014														SUPPLY	
Vint	age			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy		Average Capacity	Total Resource				
0	Base Meas	ure er Measure	Building	Start	End Year	Total	Total MW	GWH	Savings	GWH	MW	Savings MW	MW	Cost	Cost \$/kWH	Cost \$/kW		Cost Test TRC	Base GWH	Base MW		Economic MW
NC	nt Number Numb	200 Base Bldg Design - 30%	Type Warehouse	2014	2053	0.32	0.06	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	N/A	N/A	N/A	N/A	0.32	0.06	0.00	0.00
NC	200	205 High Performance Building/Int Design - Tier 2 30% - Warehouse	Warehouse	2014	2053	0.22	0.04	0.10	0.10	30%	0.02	0.02	39%	0.06	0.06	0	0	1.25	0.07	0.04	0.10	0.02
NC NC	300 300	300 Base Bldg Design - 50% 305 High Performance Building/Int Design - Tier 3 50% - Warehouse	Warehouse Warehouse	2014 2014	2053 2053	0.07	0.01	0.00	0.00 0.04	0% 51%	0.00 0.01	0.00 0.01	0% 65%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.19	0.07	0.01	0.00 0.04	0.00 0.01
NC	400	400 Base Bldg Design - 70%	Warehouse	2014	2053	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC VA	400 100	405 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Warehouse 100 Base Bldg Design - 15%	Warehouse School	2014 2014	2053 2053	0.00 10.20	0.00	0.01 0.00	0.01 0.00	71% 0%	0.00	0.00	91% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.06 N/A	10.20	1.55	0.01	0.00
VA	100	106 High Performance Building/Int Design - Tier 1 15% - School	School	2014	2053	8.64	1.25	1.56	1.56	15%	0.30	0.30	20%	0.12	0.12	1	1	0.61	10.20	1.55	0.00	0.00
VA VA	200 200	200 Base Bldg Design - 30%	School	2014 2014	2053 2053	8.16 5.67	1.24 0.76	0.00 2.49	0.00 2.49	0% 31%	0.00	0.00	0% 39%	N/A 0.09	N/A 0.09	N/A	N/A	N/A 0.86	8.16	1.24	0.00	0.00
VA	300	206 High Performance Building/Int Design - Tier 2 30% - School 300 Base Bldg Design - 50%	School School	2014	2053	1.84	0.76	0.00	0.00	0%	0.48	0.48	39% 0%	0.09 N/A	0.09 N/A	N/A	0 N/A	0.86 N/A	1.84	0.28	0.00	0.00
VA	300	306 High Performance Building/Int Design - Tier 3 50% - School	School	2014	2053	0.90	0.10	0.93	0.93	51%	0.18	0.18	65%	0.09	0.09	0	0	0.82			0.00	0.00
VA VA	400 400	400 Base Bldg Design - 70% 406 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - School	School School	2014 2014	2053 2053	0.20	0.03	0.00 0.15	0.00	0% 71%	0.00	0.00 0.03	0% 91%	N/A 0.10	N/A 0.10	N/A 1	N/A 1	N/A 0.73	0.20	0.03	0.00	0.00
NC	100	100 Base Bldg Design - 15%	School	2014	2053	0.92	0.14	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.92	0.14	0.00	0.00
NC NC	100 200	106 High Performance Building/Int Design - Tier 1 15% - School 200 Base Bldg Design - 30%	School School	2014 2014	2053 2053	0.78	0.11	0.14	0.14	15% 0%	0.03	0.03	20% 0%	0.10 N/A	0.10 N/A	1 N/A	1 N/A	0.73 N/A	0.73	0.11	0.00	0.00
NC	200	206 High Performance Building/Int Design - Tier 2 30% - School	School	2014	2053	0.51	0.07	0.22	0.22	31%	0.04	0.04	39%	0.07	0.07	0	0	1.02	0.75	0.11	0.22	0.04
NC	300	300 Base Bldg Design - 50%	School	2014	2053	0.16	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A	N/A	0.16	0.03	0.00	0.00
NC NC	300 400	306 High Performance Building/Int Design - Tier 3 50% - School 400 Base Bldg Design - 70%	School School	2014 2014	2053 2053	0.08	0.01	0.08	0.08	51% 0%	0.02	0.02 0.00	65% 0%	0.08 N/A	0.08 N/A	N/A	0 N/A	0.98 N/A	0.02	0.00	0.00	0.00
NC	400	406 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - School	School	2014	2053	0.01	0.00	0.01	0.01	71%	0.00	0.00	91%	0.09	0.09	0	0	0.87			0.00	0.00
VA VA	100 100	100 Base Bldg Design - 15% 107 High Performance Building/Int Design - Tier 1 15% - Health	Health Health	2014 2014	2053 2053	13.16 11.17	2.46 1.98	0.00 1.99	0.00 1.99	0% 15%	0.00	0.00	0% 20%	N/A 0.12	N/A 0.12	N/A 1	N/A 1	N/A 0.62	13.16	2.46	0.00	0.00
VA	200	200 Base Bldg Design - 30%	Health	2014	2053	10.53	1.97	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.53	1.97	0.00	0.00
VA VA	200 300	207 High Performance Building/Int Design - Tier 2 30% - Health 300 Base Bldg Design - 50%	Health Health	2014 2014	2053 2053	7.34 2.37	1.20 0.44	3.19 0.00	3.19 0.00	30% 0%	0.77 0.00	0.77 0.00	39% 0%	0.09 N/A	0.09 N/A	0 N/A	0 N/A	0.87 N/A	2.37	0.44	0.00	0.00
VA	300	307 High Performance Building/Int Design - Tier 3 50% - Health	Health	2014	2053	1.17	0.44	1.19	1.19	50%	0.00	0.00	65%	0.09	0.09	0	0	0.83	2.31	0.44	0.00	0.00
VA	400	400 Base Bldg Design - 70%	Health	2014	2053	0.26	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.26	0.05	0.00	0.00
VA NC	400 100	407 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Health 100 Base Bldg Design - 15%	Health Health	2014 2014	2053 2053	0.08	0.00	0.19 0.00	0.19 0.00	71% 0%	0.04	0.04 0.00	91% 0%	0.10 N/A	0.10 N/A	0 N/A	0 N/A	0.74 N/A	0.35	0.07	0.00	0.00
NC	100	107 High Performance Building/Int Design - Tier 1 15% - Health	Health	2014	2053	0.30	0.05	0.05	0.05	15%	0.01	0.01	20%	0.10	0.10	0	0	0.74			0.00	0.00
NC NC	200 200	200 Base Bldg Design - 30% 207 High Performance Building/Int Design - Tier 2 30% - Health	Health Health	2014 2014	2053 2053	0.28	0.05	0.00 0.08	0.00 0.08	0% 30%	0.00 0.02	0.00 0.02	0% 39%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.04	0.28	0.05	0.00	0.00 0.02
NC	300	300 Base Bldg Design - 50%	Health	2014	2053	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00	0.00
NC	300	307 High Performance Building/Int Design - Tier 3 50% - Health	Health	2014	2053	0.03	0.00	0.03	0.03	50%	0.01	0.01	65%	0.08	0.08	0	0	0.99	0.04	0.00	0.00	0.00
NC NC	400 400	400 Base Bldg Design - 70% 407 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Health	Health Health	2014 2014	2053 2053	0.01	0.00	0.00	0.00	0% 71%	0.00	0.00	0% 91%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.88	0.01	0.00	0.00	0.00
VA	100	100 Base Bldg Design - 15%	Lodging	2014	2053	17.04	3.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	17.04	3.30	0.00	0.00
VA VA	100 200	108 High Performance Building/Int Design - Tier 1 15% - Lodging 200 Base Bldg Design - 30%	Lodging Lodging	2014 2014	2053 2053	14.46 13.63	2.66 2.64	2.58 0.00	2.58 0.00	15% 0%	0.64	0.64 0.00	20% 0%	0.09 N/A	0.09 N/A	0 N/A	0 N/A	0.84 N/A	13.63	2.64	0.00	0.00
VA	200	208 High Performance Building/Int Design - Tier 2 30% - Lodging	Lodging	2014	2053	9.51	1.61	4.12	4.12	30%	1.03	1.03	39%	0.07	0.07	0	0	1.17	13.03		4.12	1.03
VA VA	300 300	300 Base Bldg Design - 50%	Lodging	2014	2053 2053	3.07 1.52	0.59	0.00 1.55	0.00 1.55	0% 50%	0.00	0.00	0% 65%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.12	3.07	0.59	0.00 1.55	0.00
VA	400	308 High Performance Building/Int Design - Tier 3 50% - Lodging 400 Base Bldg Design - 70%	Lodging Lodging	2014	2053	0.34	0.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.34	0.07	0.00	0.00
VA	400	408 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodging	Lodging	2014	2053	0.10	0.01	0.24	0.24	71%	0.06	0.06	91%	0.08	0.08	0	0	1.00			0.00	0.00
NC NC	100 100	100 Base Bldg Design - 15% 108 High Performance Building/Int Design - Tier 1 15% - Lodging	Lodging Lodging	2014 2014	2053 2053	0.45	0.09	0.00 0.07	0.00 0.07	0% 15%	0.00 0.02	0.00 0.02	0% 20%	N/A 0.08	N/A 0.08	N/A 0	N/A 0	N/A 1.00	0.45	0.09	0.00	0.00
NC	200	200 Base Bldg Design - 30%	Lodging	2014	2053	0.36	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.36	0.07	0.00	0.00
NC NC	200 300	208 High Performance Building/Int Design - Tier 2 30% - Lodging 300 Base Bldg Design - 50%	Lodging	2014 2014	2053 2053	0.25	0.04	0.11 0.00	0.11 0.00	30% 0%	0.03	0.03	39% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.40 N/A	0.08	0.02	0.11	0.03
NC	300	308 High Performance Building/Int Design - Tier 3 50% - Lodging	Lodging Lodging	2014	2053	0.08	0.02	0.04	0.00	50%	0.00	0.00	65%	0.06	0.06	0	0	1.33	0.06	0.02	0.00	0.00
NC	400	400 Base Bldg Design - 70%	Lodging	2014	2053	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC VA	400 100	408 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodging 100 Base Bldg Design - 15%	Lodging Data Centers	2014 2014	2053 2053	0.00 7.21	0.00	0.01	0.01	71% 0%	0.00	0.00	91% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.19 N/A	7.21	1.26	0.01	0.00
VA	100	109 High Performance Building/Int Design - Tier 1 15% - Data Centers	Data Centers	2014	2053	6.13	1.01	1.09	1.09	15%	0.24	0.24	20%	0.01	0.01	0	0	6.12			1.09	0.24
VA VA	200 200	200 Base Bldg Design - 30% 209 High Performance Building/Int Design - Tier 2 30% - Data Centers	Data Centers Data Centers	2014 2014	2053 2053	5.77 4.03	1.00 0.61	0.00	0.00 1.74	0% 30%	0.00	0.00 0.39	0% 39%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.56	5.77	1.00	0.00 1.74	0.00 0.39
VA	300	300 Base Bldg Design - 50%	Data Centers	2014	2053	1.30	0.23	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.30	0.23	0.00	0.00
VA	300	309 High Performance Building/Int Design - Tier 3 50% - Data Centers	Data Centers	2014	2053	0.65	0.08	0.65	0.65	50%	0.15	0.15	65%	0.01	0.01	0	0	8.16	0.44	0.00	0.65	0.15
VA VA	400 400	400 Base Bldg Design - 70% 409 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Data Centers	Data Centers Data Centers	2014 2014	2053 2053	0.14	0.03	0.00 0.10	0.00 0.10	0% 70%	0.00 0.02	0.00 0.02	0% 91%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.27	0.14	0.03	0.00 0.10	0.00 0.02
NC	100	100 Base Bldg Design - 15%	Data Centers	2014	2053	0.16	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.16	0.03	0.00	0.00
NC NC	100 200	109 High Performance Building/Int Design - Tier 1 15% - Data Centers 200 Base Bldg Design - 30%	Data Centers Data Centers	2014 2014	2053 2053	0.14 0.13	0.02	0.02	0.02	15% 0%	0.01 0.00	0.01 0.00	20% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	7.29 N/A	0.13	0.02	0.02	0.01 0.00
NC	200	209 High Performance Building/Int Design - Tier 2 30% - Data Centers	Data Centers	2014	2053	0.09	0.01	0.04	0.04	30%	0.01	0.01	39%	0.01	0.01	0	0	10.21			0.04	0.01
NC NC	300 300	300 Base Bldg Design - 50% 309 High Performance Building/Int Design - Tier 3 50% - Data Centers	Data Centers Data Centers	2014	2053 2053	0.03	0.01	0.00	0.00	0% 50%	0.00	0.00	0% 65%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A	0.03	0.01	0.00	0.00
NC	400	400 Base Bldg Design - 70%	Data Centers	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	9.72 N/A	0.00	0.00	0.00	0.00
NC	400	409 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Data Centers		2014	2053	0.00	0.00	0.00	0.00	70%	0.00	0.00	91%	0.01	0.01	0	0	8.66			0.00	0.00
VA VA	100 100		eligious Worsh eligious Worsh	2014 2014	2053 2053	9.51 8.06	1.87 1.50	0.00 1.45	0.00 1.45	0% 15%	0.00 0.36	0.00 0.36	0% 20%	N/A 0.17	N/A 0.17	N/A 1	N/A 1	N/A 0.47	9.51	1.87	0.00	0.00
VA	200	200 Base Bldg Design - 30%	eligious Worsh	2014	2053	7.61	1.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.61	1.49	0.00	0.00
VA	200	211 High Performance Building/Int Design - Tier 2 30% - Religious Worship	eligious Worsh	2014	2053	5.30	0.91	2.31	2.31	30%	0.58	0.58	39%	0.12	0.12	0	0	0.66			0.00	0.00

APPENDIX H

Base Avoided Costs

Comm	nercial Elec	ctric New Construction																				
DSM A	ASSYST AL	DDITIVE SUPPLY ANALYSIS		Year	2020	Year	2014														SUPPLY	
Vintag	je								Total			Total		Marginal	Average	Marginal	Average	Total				
				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt	Number	Number Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA	300		eligious Worsh	2014	2053	1.71	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.71	0.34	0.00	0.00
VA	300		eligious Worsh	2014	2053	0.84	0.12	0.87	0.87	51%	0.22	0.22	65%	0.13	0.13	0	0	0.62			0.00	0.00
VA	400	0 400 Base Bldg Design - 70%	eligious Worsh	2014	2053	0.19	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.19	0.04	0.00	0.00
VA	400	411 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Religious W	Væligious Worsh	2014	2053	0.06	0.00	0.13	0.13	71%	0.03	0.03	91%	0.14	0.14	1	1	0.56			0.00	0.00
NC	100		eligious Worsh	2014	2053	0.25	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.25	0.05	0.00	0.00
NC	100		eligious Worsh	2014	2053	0.21	0.04	0.04	0.04	15%	0.01	0.01	20%	0.14	0.14	1	1	0.56			0.00	0.00
NC	200		eligious Worsh	2014	2053	0.20	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.20	0.04	0.00	0.00
NC	200		eligious Worsh	2014	2053	0.14	0.02	0.06	0.06	30%	0.02	0.02	39%	0.10	0.10	0	0	0.78			0.00	0.00
NC	300		eligious Worsh	2014	2053	0.05	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.01	0.00	0.00
NC	300		eligious Worsh	2014	2053	0.02	0.00	0.02	0.02	51%	0.01	0.01	65%	0.11	0.11	0	0	0.74			0.00	0.00
NC	400		eligious Worsh	2014	2053	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	400		Væligious Worsh	2014	2053	0.00	0.00	0.00	0.00	71%	0.00	0.00	91%	0.12	0.12	0	0	0.66			0.00	0.00
VA	100		Misc	2014	2053	39.46	7.74	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	39.46	7.74	0.00	0.00
VA	100		Misc	2014	2053	33.46	6.23	6.00	6.00	15%	1.51	1.51	20%	0.09	0.09	0	0	0.83			0.00	0.00
VA	200		Misc	2014	2053	31.57	6.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	31.57	6.19	0.00	0.00
VA	200		Misc	2014	2053	21.97	3.78	9.59	9.59	30%	2.42	2.42	39%	0.07	0.07	0	0	1.16			9.59	2.42
VA	300		Misc	2014	2053	7.10	1.39	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.10	1.39	0.00	0.00
VA	300		Misc	2014	2053	3.50	0.49	3.60	3.60	51%	0.91	0.91	65%	0.07	0.07	0	0	1.11			3.60	0.91
VA	400		Misc	2014	2053	0.79	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.79	0.15	0.00	0.00
VA	400			2014	2053	0.23	0.01	0.56	0.56	71%	0.14	0.14	91%	0.08	0.08	0	0	0.99			0.00	0.00
NC	100		Misc	2014	2053	1.10	0.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.10	0.22	0.00	0.00
NC	100		Misc	2014	2053	0.93	0.17	0.17	0.17	15%	0.04	0.04	20%	0.08	0.08	0	0	0.99			0.00	0.00
NC	200		Misc	2014	2053	0.88	0.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.88	0.17	0.00	0.00
NC	200		Misc	2014	2053	0.61	0.11	0.27	0.27	30%	0.07	0.07	39%	0.06	0.06	0	0	1.38			0.27	0.07
NC	300		Misc	2014	2053	0.20	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.20	0.04	0.00	0.00
NC	300		Misc	2014	2053	0.10	0.01	0.10	0.10	51%	0.03	0.03	65%	0.06	0.06	0	0	1.32			0.10	0.03
NC	400		Misc	2014	2053	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	400	412 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Miscellaneo	ou Misc	2014	2053	0.01	0.00	0.02	0.02	71%	0.00	0.00	91%	0.07	0.07	0	0	1.18			0.02	0.00

APPENDIX H

Base Avoided Costs

		empt/Nonjurisdictional Existing				V	2014														SUPPLY
Vintage	SI ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity		_	_	
Samt		easure umber Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base	Economic
Opt-Out/Ex		1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Office	2020	2054	151.74	28.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	151.74	28.25	0.00
Opt-Out/Ex		1036 Lighting Control Tuneup (base 4L4'T8), 2020	Office	2020	2054	150.56	28.14	1.18	1.18	1%	0.11	0.11	0%	0.01	0.01	0	0	6.08			1.18
Opt-Out/Ex Opt-Out/Ex		1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Office Office	2020 2020	2054 2054	139.27 125.08	26.46 23.81	11.29 14.19	12.47 26.66	8% 18%	1.68 2.64	1.79 4.43	6% 16%	0.01 0.02	0.01 0.02	0	0	5.43 3.07			11.29 14.19
Opt-Out/Ex	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	2020	2054	113.50	21.66	11.58	38.24	25%	2.16	6.59	23%	0.05	0.03	0	0	1.07			11.58
Opt-Out/Ex		1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	2020	2054	103.97	21.22	9.53	47.77	31%	0.44	7.03	25%	0.05	0.03	1	0	0.93			0.00
Opt-Out/Ex Opt-Out/Ex		1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Office	2020 2020	2054 2054	87.22 79.77	18.10 16.71	16.75 7.45	64.52 71.97	43% 47%	3.12 1.39	10.15 11.54	36% 41%	0.24 0.20	0.08	1	1	0.28			0.00
Opt-Out/Ex		1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Office	2020	2054	2.57	0.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.57	0.48	0.00
Opt-Out/Ex		1136 Lighting Control Tuneup (base 2L4'T8), 2020	Office	2020	2054	2.55	0.48	0.02	0.02	1%	0.00	0.00	0%	0.01	0.01	0	0	3.53			0.02
Opt-Out/Ex Opt-Out/Ex		1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Office Office	2020 2020	2054 2054	2.35 2.11	0.45 0.40	0.19 0.24	0.21 0.46	8% 18%	0.03 0.05	0.03	6% 16%	0.02 0.02	0.02 0.02	0	0	3.16 2.42			0.19 0.24
Opt-Out/Ex		1132 ROB 2L4 Low Watt High Performance T8 (75 W), 2020	Office	2020	2054	1.84	0.35	0.27	0.72	28%	0.05	0.13	26%	0.05	0.03	0	0	1.16			0.27
Opt-Out/Ex		1134 ROB 2L4' LED Tube, 2020	Office	2020	2054	1.75	0.34	0.09	0.81	32%	0.02	0.14	30%	0.18	0.05	1	0	0.36			0.00
Opt-Out/Ex Opt-Out/Ex		1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1135 LED Troffer (base 2L4'T8), 2020	Office Office	2020 2020	2054 2054	1.60 1.47	0.33	0.15	0.96 1.10	37% 43%	0.01 0.03	0.15 0.17	31% 37%	0.10 0.25	0.06 0.08	2	0	0.48 0.26			0.00
Opt-Out/Ex		1200 Base Other Fluorescent Fixture	Office	2014	2054	5.57	1.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.57	1.04	0.00
Opt-Out/Ex		1203 Lighting Control Tuneup (base other fluorescent fixture)	Office	2014	2054	5.30	1.01	0.27	0.27	5%	0.02	0.02	2%	0.00	0.00	0	0	17.09			0.27
Opt-Out/Ex Opt-Out/Ex		1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Office Office	2014 2014	2054 2054	4.90 4.39	0.95	0.40	0.66 1.17	12% 21%	0.06	0.08	8% 17%	0.03	0.02	0	0	2.44 0.73			0.40
Opt-Out/Ex		1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Office	2014	2054	3.75	0.83	0.64	1.17	33%	0.09	0.16	20%	0.08	0.04	2	1	0.73			0.00
Opt-Out/Ex	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Office	2020	2054	51.51	9.59	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	51.51	9.59	0.00
Opt-Out/Ex		1332 LEDs (base incandescent flood) 2020	Office	2020	2054	12.41	2.31	39.10	39.10	76%	7.28	7.28	76%	0.00	0.00	0	0	15.29			39.10
Opt-Out/Ex Opt-Out/Ex		1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	Office Office	2020 2020	2054 2054	18.54 4.83	3.45 0.90	0.00 13.72	0.00 13.72	0% 74%	0.00 2.55	0.00 2.55	0% 74%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 12.82	18.54	3.45	0.00 13.72
Opt-Out/Ex		1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	2020	2054	13.65	2.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.65	2.54	0.00
Opt-Out/Ex		1532 LEDs (base incandescent A-line 53W) 2020	Office	2020	2054	4.73	0.88	8.92	8.92	65%	1.66	1.66	65%	0.01	0.01	0	0	9.23			8.92
Opt-Out/Ex Opt-Out/Ex		1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	Office Office	2020 2020	2054 2054	3.37 2.43	0.63 0.45	0.00 0.93	0.00 0.93	0% 28%	0.00 0.17	0.00 0.17	0% 28%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.11	3.37	0.63	0.00 0.93
Opt-Out/Ex		1730 Base CFL 23W to screw-in replacement 2020	Office	2020	2054	4.30	0.80	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.30	0.80	0.00
Opt-Out/Ex	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Office	2020	2054	3.18	0.59	1.12	1.12	26%	0.21	0.21	26%	0.04	0.04	0	0	1.47			1.12
Opt-Out/Ex Opt-Out/Ex		1800 BaseMetal Halide, 465W 1850 Base CFL Exit Sign	Office Office	2014 2014	2054 2054	0.00 1.80	0.00 0.33	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 1.80	0.00	0.00
Opt-Out/Ex		1851 LED Exit Sign	Office	2014	2054	1.01	0.33	0.00	0.00	44%	0.00	0.00	44%	0.02	0.02	0	0	2.36	1.00	0.33	0.00
Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Office	2014	2054	12.31	0.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.31	0.17	0.00
Opt-Out/Ex		1901 Outdoor Lighting Controls (Photocell/Timeclock)	Office	2014	2054	9.85	0.06	2.46	2.46	20%	0.11	0.11	66%	0.05	0.05	1	1	1.42			2.46
Opt-Out/Ex Opt-Out/Ex		1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Office Office	2014 2014	2054 2054	4.74 3.35	-0.01 -0.03	5.11 1.39	7.57 8.96	61% 73%	0.07	0.18 0.20	108% 118%	0.09	0.08 0.16	7 48	3 7	0.61 0.09			0.00
Opt-Out/Ex		2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Office	2014	2054	19.03	13.31	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	19.03	13.31	0.00
Opt-Out/Ex		2010 Ceiling/roof Insulation - Chiller	Office	2014	2054	18.94	13.25	0.08	0.08	0%	0.06	0.06	0%	0.01	0.01	0	0	18.40			0.08
Opt-Out/Ex Opt-Out/Ex		2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2013 High Efficiency Chiller Motors	Office Office	2014 2014	2054 2054	17.32 17.29	12.12 12.10	1.62 0.03	1.70 1.73	9% 9%	1.13 0.02	1.19 1.21	9% 9%	0.03 0.04	0.03	0	0	4.19 2.74			1.62 0.03
Opt-Out/Ex		2006 VSD for Chiller Pumps and Towers	Office	2014	2054	17.18	12.06	0.03	1.85	10%	0.02	1.25	9%	0.03	0.03	0	0	2.45			0.11
Opt-Out/Ex		2003 EMS - Chiller	Office	2014	2054	15.98	11.85	1.20	3.05	16%	0.21	1.46	11%	0.05	0.03	0	0	1.37			1.20
Opt-Out/Ex Opt-Out/Ex		2008 New Economizer - Chiller 2002 Window Film (Standard) - Chiller	Office Office	2014 2014	2054 2054	14.95 14.94	11.67 11.67	1.03 0.00	4.08 4.08	21% 21%	0.18 0.00	1.64 1.65	12% 12%	0.05 0.09	0.04 0.04	0	0	1.04 0.99			1.03 0.00
Opt-Out/Ex		2012 Duct Testing/Sealing	Office	2014	2054	12.10	9.68	2.84	6.92	36%	1.99	3.63	27%	0.09	0.04	0	0	0.99			0.00
Opt-Out/Ex	2000	2004 Cool Roof - Chiller	Office	2014	2054	12.07	9.65	0.04	6.96	37%	0.03	3.66	27%	0.22	0.09	0	0	0.39			0.00
Opt-Out/Ex		2011 Duct/Pipe Insulation - Chiller	Office Office	2014 2014	2054 2054	12.03 86.33	9.63 60.40	0.04	7.00 0.00	37% 0%	0.03	3.68 0.00	28% 0%	1.86 N/A	0.10 N/A	3 N/A	0 N/A	0.05	86.33	60.40	0.00
Opt-Out/Ex Opt-Out/Ex		2100 Base DX Packaged System, EER=10.3, 10 tons 2102 DX Packaged System, EER=13.4, 10 tons	Office	2014	2054	66.48	46.51	19.86	19.86	23%	13.89	13.89	23%	0.02	0.02	0	0	N/A 4.41	00.33	60.40	19.86
Opt-Out/Ex	2100	2111 Economizer Repair - DX	Office	2014	2054	63.48	43.37	2.99	22.85	26%	3.14	17.03	28%	0.05	0.03	0	0	1.61			2.99
Opt-Out/Ex		2108 Optimize Controls - DX	Office	2014 2014	2054 2054	62.40	43.18	1.08	23.93	28% 29%	0.19	17.22	29%	0.06 0.10	0.03	0	0	0.90			0.00
Opt-Out/Ex Opt-Out/Ex		2115 Window Film (Standard) - DX 2109 Economizer - DX	Office Office	2014	2054	61.11 54.39	42.27 41.10	1.29 6.72	25.22 31.94	29% 37%	0.90 1.17	18.12 19.30	30% 32%	0.10	0.03	0	0	0.88			0.00
Opt-Out/Ex		2112 Aerosol Duct Sealing - DX	Office	2014	2054	51.08	38.79	3.31	35.25	41%	2.31	21.61	36%	0.19	0.05	ō	ō	0.59			0.00
Opt-Out/Ex		2106 Prog. Thermostat - DX	Office	2014	2054	50.00	38.60	1.09	36.33	42%	0.19	21.80	36%	0.10	0.06	1	0	0.53			0.00
Opt-Out/Ex Opt-Out/Ex		2107 Cool Roof - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office Office	2014 2014	2054 2054	49.57 49.56	38.30 38.30	0.43	36.76 36.77	43% 43%	0.30	22.10 22.10	37% 37%	0.25 0.20	0.06	0	0	0.35 0.29			0.00
Opt-Out/Ex		2114 Duct/Pipe Insulation - DX	Office	2014	2054	49.24	38.07	0.32	37.09	43%	0.22	22.33	37%	2.07	0.08	3	0	0.04			0.00
Opt-Out/Ex		2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Office	2014	2054	58.94	41.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	58.94	41.24	0.00
Opt-Out/Ex Opt-Out/Ex		2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Office Office	2014 2014	2054 2054	51.65 9.44	36.14 6.61	7.29	7.29 0.00	12% 0%	5.10	5.10 0.00	12% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	6.17 N/A	9.44	6.61	7.29 0.00
Opt-Out/Ex		3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Office	2014	2054	46.72	14.10	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	9.44 46.72	14.10	0.00
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Office	2014	2054	45.96	13.88	0.76	0.76	2%	0.23	0.23	2%	0.02	0.02	0	0	4.26			0.76
Opt-Out/Ex		3002 Variable Speed Drive Control, 5 HP	Office	2014 2014	2054 2054	34.57 32.69	13.02 11.94	11.39	12.15 14.03	26% 30%	0.86	1.09	8%	0.01	0.02	0	0	3.89			11.39
Opt-Out/Ex Opt-Out/Ex		3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	2014	2054	32.69 8.09	11.94 2.44	1.88 0.00	0.00	30% 0%	1.08	2.17 0.00	15% 0%	0.64 N/A	0.10 N/A	1 N/A	1 N/A	0.15 N/A	8.09	2.44	0.00
Opt-Out/Ex		3102 Variable Speed Drive Control, 15 HP	Office	2014	2054	6.09	2.29	2.01	2.01	25%	0.15	0.15	6%	0.00	0.00	0	0	14.31	50		2.01
Opt-Out/Ex		3101 Fan Motor, 15hp, 1800rpm, 92.4%	Office	2014	2054	6.05	2.28	0.04	2.04	25%	0.01	0.16	7%	0.01	0.00	0	0	7.06			0.04
Opt-Out/Ex Opt-Out/Ex		3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Office Office	2014 2014	2054 2054	5.65 5.11	2.17 2.13	0.40 0.54	2.44 2.98	30% 37%	0.11 0.04	0.27 0.31	11% 13%	0.02 0.02	0.01 0.01	0	0	3.12 2.36			0.40 0.54
Opt-Out/Ex		3105 Energy Recovery Ventilation (ERV)	Office	2014	2054	4.99	2.06	0.12	3.10	38%	0.07	0.31	16%	0.02	0.02	0	0	0.43			0.00
Opt-Out/Ex		3107 Demand Controlled Ventilation	Office	2014	2054	4.72	1.91	0.27	3.37	42%	0.16	0.54	22%	0.77	0.08	1	0	0.13			0.00

DNV GL H-1 1/5/2015

APPENDIX H

Base Avoided Costs

DSM ASSYS	ST ADDITIV	E SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal		Marginal		Total			SUPPLY
Vintage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Average Energy	Capacity	Average Capacity				
		Measure Number Measure	Building Type	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base	Economic GWH
Opt-Out/Ex	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Office	2014	2054	5.10	1.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.10	1.54	0.00
Opt-Out/Ex		3203 Air Handler Optimization, 40 HP	Office	2014	2054	4.62	1.50	0.49	0.49	10%	0.04	0.04	2%	0.01	0.01	0	0	3.38			0.49
Opt-Out/Ex Opt-Out/Ex	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	Office Office	2014 2014	2054 2054	3.47 3.46	1.42 1.41	1.14 0.02	1.63 1.65	32% 32%	0.09	0.12 0.13	8% 8%	0.02 0.10	0.02 0.02	0	0	2.57 0.80			1.14 0.00
Opt-Out/Ex	3200	3204 Demand Controlled Ventilation	Office	2014	2054	3.27	1.31	0.19	1.83	36%	0.11	0.24	15%	0.70	0.09	1	1	0.14			0.00
Opt-Out/Ex	4000	4000 Base Built-Up Refrigeration System	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Office Office	2014 2014	2054 2054	13.71 13.58	1.92 1.90	0.00 0.13	0.00 0.13	0% 1%	0.00 0.02	0.00 0.02	0% 1%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 48.88	13.71	1.92	0.00 0.13
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door	Office	2014	2054	13.56	1.90	0.02	0.15	1%	0.00	0.02	1%	0.00	0.00	ō	Ō	24.94			0.02
Opt-Out/Ex	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Office	2014	2054	13.31	1.87	0.25	0.40	3%	0.03	0.06	3%	0.00	0.00	0	0	23.92			0.25
Opt-Out/Ex Opt-Out/Ex	4100 4100	4107 Energy-Star Freezer, solid door 4108 Energy-Star Refrigerator, glass door	Office Office	2014 2014	2054 2054	13.30 13.22	1.86 1.85	0.01 0.08	0.41 0.49	3% 4%	0.00 0.01	0.06 0.07	3% 4%	0.01 0.01	0.00	0	0	9.98 8.40			0.01 0.08
Opt-Out/Ex	4100	4106 Energy-Star Refrigerator, solid door	Office	2014	2054	13.19	1.85	0.03	0.52	4%	0.00	0.07	4%	0.01	0.00	0	Ō	8.01			0.03
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Office	2014	2054	13.14	1.84	0.05	0.57	4%	0.01	0.08	4%	0.02	0.00	0	0	2.97			0.05
Opt-Out/Ex Opt-Out/Ex	4100 4100	4112 Reach-in unit occupancy sensors 4105 Bi-level LED Case Lighting (self-contained units) 2014	Office Office	2014 2014	2054 2054	13.14 13.14	1.84 1.84	0.00	0.57	4% 4%	0.00	0.08	4% 4%	0.27 0.31	0.00	2	0	0.21			0.00
Opt-Out/Ex	4100	4101 Strip curtains for walk-ins (self-contained)	Office	2014	2054	13.13	1.84	0.01	0.58	4%	0.00	0.08	4%	6.66	0.11	47	1	0.01			0.00
Opt-Out/Ex	5000	5000 Base Desktop PC	Office	2014	2054	5.60	0.78	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.60	0.78	0.00
Opt-Out/Ex Opt-Out/Ex	5000 5000	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	Office Office	2014 2014	2054 2054	3.02 2.35	0.60 0.51	2.58 0.67	2.58 3.25	46% 58%	0.18 0.09	0.18 0.27	23% 35%	0.01 0.02	0.01 0.01	0	0	4.47 2.22			2.58 0.67
Opt-Out/Ex		5100 Base Laptop PC	Office	2014	2054	0.51	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.51	0.07	0.00
Opt-Out/Ex	5100	5102 Energy Star or Better Laptop	Office	2014	2054	0.41	0.06	0.10	0.10	19%	0.01	0.01	19%	0.01	0.01	0	0	6.06			0.10
Opt-Out/Ex	5100	5101 Laptop Network Power Management Enabling	Office	2014	2054	0.40	0.06	0.01	0.10	21%	0.00	0.01	21%	0.99	0.09	7	1	0.05	4.40	0.40	0.00
Opt-Out/Ex Opt-Out/Ex	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Office Office	2014 2014	2054 2054	1.19 0.68	0.16 0.09	0.00 0.51	0.00 0.51	0% 43%	0.00 0.07	0.00 0.07	0% 43%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 63.11	1.19	0.16	0.00 0.51
Opt-Out/Ex	5200	5202 Monitor Power Management Enabling - CRT	Office	2014	2054	0.59	0.09	0.09	0.60	50%	0.01	0.08	46%	0.01	0.00	0	0	5.32			0.09
Opt-Out/Ex	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Office	2014	2054	0.55	0.08	0.05	0.64	54%	0.01	0.08	50%	0.11	0.01	1	0	0.45			0.00
Opt-Out/Ex Opt-Out/Ex	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Office Office	2014 2014	2054 2054	1.06 0.92	0.15 0.13	0.00	0.00	0% 13%	0.00	0.00 0.02	0% 13%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.50	1.06	0.15	0.00
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	Office	2014	2054	0.86	0.12	0.07	0.14	20%	0.00	0.02	16%	0.06	0.03	1	0	0.72			0.00
Opt-Out/Ex	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Office	2014	2054	0.79	0.12	0.07	0.28	26%	0.00	0.03	18%	0.18	0.06	5	1	0.24			0.00
Opt-Out/Ex Opt-Out/Ex	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Office Office	2014 2014	2054 2054	1.95 1.75	0.27 0.24	0.00 0.19	0.00 0.19	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 36.97	1.95	0.27	0.00 0.19
Opt-Out/Ex	5400	5401 Energy Star of Better Copier 5402 Copier Power Management Enabling	Office	2014	2054	1.75	0.24	0.19	0.19	14%	0.03	0.03	12%	0.00	0.00	1	0	0.67			0.19
Opt-Out/Ex	5500	5500 Base Multifunction	Office	2014	2054	0.33	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.33	0.05	0.00
Opt-Out/Ex	5500	5502 ENERGY STAR Multi-Function Device	Office	2014	2054	0.25	0.03	0.08	0.08	25%	0.01	0.01	25%	0.01	0.01	0	0	10.13			0.08
Opt-Out/Ex Opt-Out/Ex	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Office Office	2014 2014	2054 2054	0.20 1.93	0.03 0.27	0.05 0.00	0.13 0.00	39% 0%	0.00	0.01 0.00	32% 0%	0.21 N/A	0.08 N/A	3 N/A	1 N/A	0.23 N/A	1.93	0.27	0.00
Opt-Out/Ex	5600	5602 ENERGY STAR Printer	Office	2014	2054	1.26	0.17	0.67	0.67	35%	0.09	0.09	35%	0.00	0.00	0	0	46.55	1.00	0.27	0.67
Opt-Out/Ex	5600	5601 Printer Power Management Enabling	Office	2014	2054	1.03	0.16	0.23	0.90	47%	0.02	0.11	41%	0.04	0.01	1	0	1.05			0.23
Opt-Out/Ex Opt-Out/Ex	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Office Office	2014 2014	2054 2054	12.60 11.34	1.75 1.57	0.00 1.26	0.00 1.26	0% 10%	0.00 0.17	0.00 0.17	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 160.89	12.60	1.75	0.00 1.26
Opt-Out/Ex	5700	5702 Data Center Improved Operations	Office	2014	2054	9.90	1.37	1.44	2.70	21%	0.20	0.38	21%	0.00	0.00	0	0	65.50			1.44
Opt-Out/Ex	5700	5703 Data Center State of the Art practices	Office	2014	2054	9.34	1.30	0.55	3.26	26%	0.08	0.45	26%	0.00	0.00	0	0	33.97			0.55
Opt-Out/Ex Opt-Out/Ex	6000 6000	6000 Base Water Heating 6007 Heat Trap	Office Office	2014 2014	2054 2054	11.55 10.96	1.56 1.48	0.00 0.60	0.00	0% 5%	0.00	0.00 0.08	0% 5%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.24	11.55	1.56	0.00
Opt-Out/Ex	6000	6002 High Efficiency Water Heater (electric)	Office	2014	2054	10.96	1.45	0.60	0.82	7%	0.08	0.08	7%	0.01	0.01	0	0	2.26			0.80
Opt-Out/Ex	6000	6004 Tankless Water Heater	Office	2014	2054	9.93	1.34	0.81	1.62	14%	0.11	0.22	14%	0.04	0.03	0	0	1.61			0.81
Opt-Out/Ex	6000 6000	6008 Solar Water Heater	Office Office	2014 2014	2054 2054	4.65 4.59	0.63 0.62	5.28 0.05	6.91 6.96	60% 60%	0.71 0.01	0.93 0.94	60% 60%	0.05 0.11	0.05 0.05	0	0	1.38 0.58			5.28 0.00
Opt-Out/Ex Opt-Out/Ex	6000	6003 Hot Water Pipe Insulation 6006 Heat Recovery Unit	Office	2014	2054	4.39	0.52	0.05	7.26	63%	0.01	0.94	63%	0.11	0.05	1	0	0.56			0.00
Opt-Out/Ex	6000	6001 Demand controlled circulating systems	Office	2014	2054	4.17	0.56	0.13	7.39	64%	0.02	1.00	64%	0.33	0.05	2	0	0.19			0.00
Opt-Out/Ex	7000	7000 Base Refrigerated Vending Machines	Office	2014 2014	2054	2.10	0.31	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A 0.03	N/A	N/A	N/A	2.10	0.31	0.00
Opt-Out/Ex Opt-Out/Ex	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Office Office	2014	2054 2054	1.77 1.58	0.28 0.27	0.34 0.19	0.34 0.52	16% 25%	0.02 0.01	0.02 0.04	8% 12%	0.03 0.05	0.03	0	0	1.81 0.99			0.34
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Office	2014	2054	0.05	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.01	0.00
Opt-Out/Ex	7100	7101 Vending Misers (Non-Refrigerated)	Office	2014	2054	0.03	0.01	0.03	0.03	46%	0.00	0.00	23%	0.44	0.44	6	6	0.11			0.00
Opt-Out/Ex Opt-Out/Ex	7200 7300	7200 Base Oven 7300 Base Fryer	Office Office	2014 2014	2054 2054	0.62 0.39	0.09 0.06	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.62	0.09	0.00
Opt-Out/Ex	7400	7400 Base Steamer	Office	2014	2054	0.81	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.81	0.12	0.00
Opt-Out/Ex	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Office	2014	2054	8.56	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.56	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	8000 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	Office Office	2014 2014	2054 2054	8.08 8.65	0.00	0.48 0.00	0.48	6% 0%	0.00	0.00	0% 0%	0.02 N/A	0.02 N/A	N/A N/A	N/A N/A	3.24 N/A	8.65	0.00	0.48 0.00
Opt-Out/Ex	9500	9500 Base Miscellaneous	Office	2014	2054	74.29	10.81	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	74.29	10.81	0.00
Opt-Out/Ex	9500	9501 Xmisc	Office	2014	2054	74.29	10.81	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00
Opt-Out/Ex	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Retail	2020	2054	17.68	3.20	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	17.68	3.20	0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Retail Retail	2020 2020	2054 2054	17.64 16.30	3.20 3.00	0.04 1.34	0.04 1.38	0% 8%	0.00 0.19	0.00 0.20	0% 6%	0.01 0.02	0.01 0.02	0	0	4.09 3.61			0.04 1.34
Opt-Out/Ex	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Retail	2020	2054	14.61	2.70	1.70	3.07	17%	0.13	0.50	16%	0.02	0.02	0	0	2.18			1.70
Opt-Out/Ex	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Retail	2020	2054	14.25	2.63	0.36	3.43	19%	0.07	0.57	18%	0.27	0.05	1	0	0.20			0.00
Opt-Out/Ex Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube. 2020	Retail Retail	2020 2020	2054 2054	14.04 11.78	2.62	0.21 2.26	3.64 5.90	21% 33%	0.01	0.58	18% 31%	0.09 0.28	0.05	2	0	0.56 0.23			0.00
Opt-Out/Ex	.000	1034 ROB 4L4 LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Retail	2020	2054	10.77	2.03	1.01	6.91	39%	0.41	1.17	36%	0.28	0.14	1	1	0.23			0.00
Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Retail	2020	2054	3.53	0.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.53	0.64	0.00

APPENDIX H

Base Avoided Costs

DSM ASSYS Vintage	T ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
vintage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource			
		easure	Building Type	Start	End	Total	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base	Economic
Opt-Out/Ex	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Retail	2020	2054	3.52	0.64	0.01	0.01	0%	0.00	0.00	0%	0.02	0.02	0	0	2.40	GWII	141.44	0.01
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Retail	2020	2054	3.26	0.60	0.27	0.28	8%	0.04	0.04	6%	0.03	0.03	0	0	2.12			0.27
Opt-Out/Ex Opt-Out/Ex	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Retail Retail	2020 2020	2054 2054	2.92 2.55	0.54 0.47	0.34 0.37	0.61 0.99	17% 28%	0.06 0.07	0.10 0.17	16% 26%	0.03 0.07	0.03 0.04	0	0	1.72 0.83			0.34
Opt-Out/Ex	1130	1134 ROB 2L4' LED Tube, 2020	Retail	2020	2054	2.42	0.45	0.12	1.11	31%	0.02	0.19	30%	0.25	0.07	1	Ö	0.26			0.00
Opt-Out/Ex	1130	1135 LED Troffer (base 2L4'T8), 2020	Retail	2020	2054	2.22	0.41	0.21	1.32	37%	0.04	0.23	36%	0.31	0.11	2	1	0.20			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	Retail Retail	2020 2014	2054 2054	2.18	0.41	0.03	1.35	38% 0%	0.00	0.23	36% 0%	0.20 N/A	0.11 N/A	5 N/A	1 N/A	0.25 N/A	0.03	0.00	0.00
Opt-Out/Ex	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Retail	2014	2054	0.03	0.00	0.00	0.00	1%	0.00	0.00	1%	0.01	0.01	0	0	7.41	0.00	0.00	0.00
Opt-Out/Ex	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Retail	2014	2054	0.03	0.00	0.00	0.00	9%	0.00	0.00	7%	0.06	0.05	0	0	1.08			0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1201 ROB High Performance T8 (base other fluorescent) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Retail Retail	2014 2014	2054 2054	0.02 0.02	0.00	0.00	0.01 0.01	18% 21%	0.00	0.00	16% 17%	0.10 0.12	0.08	1	0	0.53 0.41			0.00
Opt-Out/Ex	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Retail	2020	2054	6.70	1.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.70	1.21	0.00
Opt-Out/Ex	1330	1332 LEDs (base incandescent flood) 2020	Retail	2020	2054	1.17	0.21	5.52	5.52	82%	1.00	1.00	82%	0.01	0.01	0	0	8.61			5.52
Opt-Out/Ex Opt-Out/Ex	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	Retail Retail	2020 2020	2054 2054	2.41 0.46	0.44	0.00 1.95	0.00 1.95	0% 81%	0.00 0.35	0.00	0% 81%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.27	2.41	0.44	0.00 1.95
Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Retail	2020	2054	1.77	0.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.77	0.32	0.00
Opt-Out/Ex	1530	1532 LEDs (base incandescent A-line 53W) 2020	Retail	2020	2054	0.46	0.08	1.31	1.31	74%	0.24	0.24	74%	0.01	0.01	0	0	5.40			1.31
Opt-Out/Ex Opt-Out/Ex	1630 1630	1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	Retail Retail	2020 2020	2054 2054	1.96 1.42	0.35 0.26	0.00 0.54	0.00 0.54	0% 28%	0.00 0.10	0.00	0% 28%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 0.86	1.96	0.35	0.00
Opt-Out/Ex	1730	1730 Base CFL 23W to screw-in replacement 2020	Retail	2020	2054	2.51	0.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.51	0.45	0.00
Opt-Out/Ex	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Retail	2020	2054	1.85	0.34	0.65	0.65	26%	0.12	0.12	26%	0.05	0.05	0	0	1.14	0.00	0.00	0.65
Opt-Out/Ex Opt-Out/Ex	1800 1850	1800 BaseMetal Halide, 465W 1850 Base CFL Exit Sign	Retail Retail	2014 2014	2054 2054	0.00 0.22	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	Retail	2014	2054	0.10	0.02	0.13	0.13	56%	0.02	0.02	56%	0.04	0.04	0	0	1.31	U.LL	0.01	0.13
Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Retail	2014	2054	3.60	0.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.60	0.24	0.00
Opt-Out/Ex Opt-Out/Ex	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Retail Retail	2014 2014	2054 2054	2.79 1.34	0.08 -0.01	0.81 1.45	0.81 2.26	23% 63%	0.16 0.09	0.16 0.25	66% 106%	0.06 0.13	0.06 0.10	0 2	0	1.36 0.46			0.81
Opt-Out/Ex	1900	1903 Bi-Level LED Outdoor Lighting	Retail	2014	2054	0.95	-0.04	0.39	2.65	74%	0.02	0.27	116%	0.86	0.22	14	2	0.07			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Retail	2014	2054	0.48	0.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.48	0.40	0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2010 Ceiling/roof Insulation - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Retail Retail	2014 2014	2054 2054	0.47	0.39 0.36	0.00	0.00 0.04	1% 9%	0.00	0.00	1% 9%	0.03	0.03	0	0	4.57 2.80			0.00 0.04
Opt-Out/Ex	2000	2003 EMS - Chiller	Retail	2014	2054	0.40	0.35	0.04	0.08	17%	0.01	0.04	11%	0.08	0.06	Ö	Ö	0.84			0.00
Opt-Out/Ex	2000	2012 Duct Testing/Sealing	Retail	2014	2054	0.32	0.29	0.08	0.16	33%	0.06	0.11	27%	0.23	0.14	0	0	0.52			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons 2102 DX Packaged System, EER=13.4, 10 tons	Retail Retail	2014 2014	2054 2054	16.88 13.00	13.95 10.74	0.00 3.88	0.00 3.88	0% 23%	0.00 3.21	0.00 3.21	0% 23%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 2.95	16.88	13.95	0.00 3.88
Opt-Out/Ex	2100	2111 Economizer Repair - DX	Retail	2014	2054	12.09	9.68	0.91	4.79	28%	1.06	4.27	31%	0.08	0.05	0	Ö	1.08			0.91
Opt-Out/Ex	2100	2107 Cool Roof - DX	Retail	2014	2054	11.56	9.24	0.54	5.33	32%	0.44	4.71	34%	0.12	0.05	0	0	0.81			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2108 Optimize Controls - DX 2109 Economizer - DX	Retail Retail	2014 2014	2054 2054	11.37 10.40	9.20 8.99	0.19 0.97	5.52 6.49	33% 38%	0.04 0.21	4.76 4.96	34% 36%	0.10 0.13	0.06 0.07	0	0	0.51 0.45			0.00
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Retail	2014	2054	9.77	8.47	0.63	7.12	42%	0.52	5.49	39%	0.31	0.09	ò	0	0.39			0.00
Opt-Out/Ex	2100	2106 Prog. Thermostat - DX	Retail	2014	2054	9.50	8.41	0.27	7.39	44%	0.06	5.54	40%	0.17	0.09	1	0	0.32			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2115 Window Film (Standard) - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Retail Retail	2014 2014	2054 2054	9.46 9.46	8.38 8.38	0.03	7.42 7.43	44% 44%	0.03	5.57 5.57	40% 40%	0.38	0.09	0	0	0.25			0.00
Opt-Out/Ex	2100	2114 Duct/Pipe Insulation - DX	Retail	2014	2054	9.39	8.32	0.07	7.50	44%	0.06	5.63	40%	3.43	0.12	4	0	0.03			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Retail	2014	2054	6.27	5.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.27	5.18	0.00
Opt-Out/Ex Opt-Out/Ex	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, FFR=8.3, 1 ton	Retail Retail	2014 2014	2054 2054	5.50 1.11	4.54 0.91	0.78	0.78	12% 0%	0.64	0.64	12% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	4.14 N/A	1.11	0.91	0.78
Opt-Out/Ex	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Retail	2014	2054	11.44	3.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.44	3.21	0.00
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Retail	2014	2054	11.26	3.15	0.18	0.18	2%	0.05	0.05	2%	0.02	0.02	0	0	3.41			0.18
Opt-Out/Ex Opt-Out/Ex	3000 3000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	7.88 7.06	2.92	3.38 0.83	3.56 4.38	31% 38%	0.24	0.29	9% 23%	0.02 1.16	0.02 0.23	0	0	3.15 0.08			3.38 0.00
Opt-Out/Ex	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Retail	2014	2054	0.40	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.40	0.11	0.00
Opt-Out/Ex	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Retail	2014	2054	0.34	0.10	0.06	0.06	14%	0.01	0.01	13%	0.03	0.03	0	0	2.44			0.06
Opt-Out/Ex Opt-Out/Ex	3100 3100	3103 Air Handler Optimization, 15 HP 3102 Variable Speed Drive Control, 15 HP	Retail Retail	2014 2014	2054 2054	0.31 0.22	0.09	0.03	0.09	23% 46%	0.00 0.01	0.02 0.02	15% 21%	0.03	0.03 0.05	0	0	1.86 0.85			0.03
Opt-Out/Ex	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Retail	2014	2054	0.21	0.09	0.00	0.18	46%	0.00	0.02	21%	0.21	0.05	1	0	0.39			0.00
Opt-Out/Ex	3100	3105 Energy Recovery Ventilation (ERV)	Retail	2014	2054	0.20	0.08	0.01	0.20	50%	0.01	0.03	28%	0.46	0.08	1	0	0.23			0.00
Opt-Out/Ex Opt-Out/Ex	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Retail Retail	2014 2014	2054 2054	0.18	0.07 0.11	0.02 0.00	0.22	55% 0%	0.01 0.00	0.04	38% 0%	1.59 N/A	0.22 N/A	3 N/A	1 N/A	0.06 N/A	0.40	0.11	0.00
Opt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP	Retail	2014	2054	0.36	0.11	0.04	0.04	10%	0.00	0.00	3%	0.02	0.02	0	0	2.17	0.40	0.11	0.04
Opt-Out/Ex	3200	3202 Variable Speed Drive Control, 40 HP	Retail	2014	2054	0.25	0.10	0.11	0.15	37%	0.01	0.01	9%	0.06	0.05	1	1	1.02			0.11
Opt-Out/Ex Opt-Out/Ex	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	0.25 0.22	0.10 0.09	0.00	0.15 0.17	37% 44%	0.00 0.01	0.01 0.02	9% 22%	0.28 1.27	0.05 0.23	1 2	1 2	0.29 0.07			0.00
Opt-Out/Ex	4000	4000 Base Built-Up Refrigeration System	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.02	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	4100	4100 Base Self-Contained Refrigeration	Retail	2014	2054	9.21	1.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.21	1.40	0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4103 Night covers for display cases (self-contained) 4109 Energy-Star Freezer, glass door	Retail Retail	2014 2014	2054 2054	9.03 9.00	1.37 1.37	0.18 0.04	0.18 0.21	2% 2%	0.03 0.01	0.03	2% 2%	0.01 0.04	0.01 0.01	0	0	5.36 1.54			0.18 0.04
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Retail	2014	2054	8.80	1.34	0.04	0.41	4%	0.03	0.03	4%	0.04	0.01	0	0	1.40			0.19
Opt-Out/Ex	4100	4107 Energy-Star Freezer, solid door	Retail	2014	2054	8.79	1.34	0.02	0.42	5%	0.00	0.06	5%	0.09	0.03	1	0	0.61			0.00
Opt-Out/Ex	4100 4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Retail Retail	2014	2054	8.64 8.62	1.31	0.15 0.02	0.57 0.59	6% 6%	0.02	0.09	6% 6%	0.11 0.12	0.05	1	0	0.52			0.00
Opt-Out/Ex	4100	4108 Energy-Star Reinigerator, solid door 4112 Reach-in unit occupancy sensors	Retail	2014	2054	8.58	1.30	0.02	0.63	7%	0.00	0.10	7%	0.12	0.05	2	0	0.49			0.00
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Retail	2014	2054	8.56	1.30	0.02	0.65	7%	0.00	0.10	7%	0.32	0.07	2	0	0.18			0.00

APPENDIX H

Base Avoided Costs

		empt/Nonjurisdictional Existing				V	2014														SUPPLY
Vintage	ST ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
_	D M.		D. Hallana	Measure	Measure	Total	Total	014/11	Energy	Percent	*****	Capacity	Percent	Energy	Energy	Capacity	Capacity		D	B	Farmente
		easure Imber Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH
Opt-Out/Ex	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Retail	2014	2054	8.49	1.29	0.07	0.72	8%	0.01	0.11	8%	0.32	0.10	2	1	0.17			0.00
Opt-Out/Ex Opt-Out/Ex	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Retail Retail	2014 2014	2054 2054	8.48 0.43	1.29 0.08	0.01 0.00	0.73 0.00	8% 0%	0.00	0.11	8% 0%	1.94 N/A	0.12 N/A	13 N/A	1 N/A	0.03 N/A	0.43	0.08	0.00
Opt-Out/Ex	5000	5002 Energy Star or Better PC	Retail	2014	2054	0.36	0.06	0.06	0.06	15%	0.00	0.01	15%	0.01	0.01	0	0	3.49	0.40	0.00	0.06
Opt-Out/Ex	5000	5001 PC Network Power Management Enabling	Retail	2014	2054	0.20	0.05	0.16	0.23	53%	0.01	0.03	35%	0.02	0.02	0	0	2.73			0.16
Opt-Out/Ex	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Retail Retail	2014 2014	2054 2054	0.02	0.00	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.53	0.02	0.00	0.00
Opt-Out/Ex	5100	5101 Laptop Network Power Management Enabling	Retail	2014	2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	1.38	0.12	8	1	0.04			0.00
Opt-Out/Ex	5200	5200 Base Monitor, CRT	Retail	2014	2054	0.14	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.14	0.02	0.00
Opt-Out/Ex	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Retail Retail	2014 2014	2054 2054	0.06	0.01	0.08	0.08	56% 63%	0.01	0.01 0.01	56% 60%	0.00 0.02	0.00	0	0	36.02 2.75			0.08
Opt-Out/Ex		5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Retail	2014	2054	0.05	0.01	0.00	0.09	66%	0.00	0.02	63%	0.02	0.01	1	0	0.25			0.00
Opt-Out/Ex	5300	5300 Base Monitor, LCD	Retail	2014	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	5300 5300	5301 Energy Star or Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Retail Retail	2014 2014	2054 2054	0.05	0.01 0.01	0.01	0.01 0.01	14% 17%	0.00	0.00	14% 16%	0.01	0.01	0	0	5.55 0.54			0.01
Opt-Out/Ex	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Retail	2014	2054	0.05	0.01	0.00	0.01	24%	0.00	0.00	17%	0.25	0.02	5	1	0.18			0.00
Opt-Out/Ex	5400	5400 Base Copier	Retail	2014	2054	0.21	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.21	0.04	0.00
Opt-Out/Ex Opt-Out/Ex	5400 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	Retail Retail	2014 2014	2054 2054	0.18	0.03	0.03 0.01	0.03 0.04	14% 18%	0.01	0.01	14% 16%	0.00	0.00	0	0	26.26 0.45			0.03
Opt-Out/Ex	5500	5500 Base Multifunction	Retail	2014	2054	0.03	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.01	0.00
Opt-Out/Ex	5500	5502 ENERGY STAR Multi-Function Device	Retail	2014	2054	0.02	0.00	0.01	0.01	25%	0.00	0.00	25%	0.01	0.01	0	0	7.56			0.01
Opt-Out/Ex Opt-Out/Ex	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Retail Retail	2014 2014	2054 2054	0.02	0.00 0.02	0.00	0.01 0.00	36% 0%	0.00	0.00	30% 0%	0.28 N/A	0.09 N/A	3 N/A	1 N/A	0.17 N/A	0.09	0.02	0.00
Opt-Out/Ex	5600	5602 ENERGY STAR Printer	Retail	2014	2054	0.06	0.02	0.03	0.03	35%	0.00	0.01	35%	0.00	0.00	0	0	34.75	0.03	0.02	0.03
Opt-Out/Ex	5600	5601 Printer Power Management Enabling	Retail	2014	2054	0.05	0.01	0.01	0.04	44%	0.00	0.01	39%	0.06	0.01	1	0	0.80			0.00
Opt-Out/Ex Opt-Out/Ex	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Retail Retail	2014 2014	2054 2054	0.37	0.07 0.06	0.00	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 120.93	0.37	0.07	0.00
Opt-Out/Ex	5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Retail	2014	2054	0.33	0.05	0.04	0.04	21%	0.01	0.01	21%	0.00	0.00	0	0	49.23			0.04
Opt-Out/Ex	5700	5703 Data Center State of the Art practices	Retail	2014	2054	0.28	0.05	0.02	0.10	26%	0.00	0.02	26%	0.00	0.00	0	0	25.53			0.02
Opt-Out/Ex	6000 6000	6000 Base Water Heating 6007 Heat Trap	Retail Retail	2014 2014	2054 2054	1.76 1.67	0.28 0.27	0.00	0.00	0% 5%	0.00 0.01	0.00 0.01	0% 5%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.86	1.76	0.28	0.00
Opt-Out/Ex	6000	6002 High Efficiency Water Heater (electric)	Retail	2014	2054	1.63	0.27	0.09	0.09	7%	0.01	0.01	7%	0.02	0.02	0	0	1.53			0.03
Opt-Out/Ex	6000	6004 Tankless Water Heater	Retail	2014	2054	1.51	0.24	0.12	0.25	14%	0.02	0.04	14%	0.07	0.05	ō	0	1.09			0.12
Opt-Out/Ex	6000 6000	6008 Solar Water Heater	Retail Retail	2014 2014	2054 2054	1.47 1.44	0.24	0.04	0.29	16% 18%	0.01	0.05	16%	0.08 0.08	0.05	0	0	0.93 0.82			0.00
Opt-Out/Ex Opt-Out/Ex	6000	6003 Hot Water Pipe Insulation 6006 Heat Recovery Unit	Retail	2014	2054	1.44	0.23 0.22	0.02 0.05	0.31 0.36	20%	0.00	0.05 0.06	18% 20%	0.08	0.05	0 1	0	0.82			0.00
Opt-Out/Ex	6000	6001 Demand controlled circulating systems	Retail	2014	2054	1.38	0.22	0.02	0.38	22%	0.00	0.06	22%	0.13	0.06	1	0	0.50			0.00
Opt-Out/Ex	7000 7000	7000 Base Refrigerated Vending Machines	Retail Retail	2014 2014	2054 2054	0.44 0.37	0.08	0.00 0.07	0.00 0.07	0% 16%	0.00 0.01	0.00 0.01	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.83	0.44	0.08	0.00 0.07
Opt-Out/Ex	7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Retail	2014	2054	0.37	0.07	0.07	0.07	25%	0.01	0.01	8% 12%	0.03	0.03	1	0	1.83			0.07
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	7100	7101 Vending Misers (Non-Refrigerated)	Retail Retail	2014	2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	23%	0.44	0.44	5	5	0.11	0.00	0.05	0.00
Opt-Out/Ex Opt-Out/Ex	7200 7200	7200 Base Oven 7201 Convection Oven	Retail	2014 2014	2054 2054	0.28	0.05 0.04	0.00 0.06	0.00 0.06	0% 23%	0.00 0.01	0.00 0.01	0% 23%	N/A 0.13	N/A 0.13	N/A 1	N/A 1	N/A 0.47	0.28	0.05	0.00
Opt-Out/Ex	7300	7300 Base Fryer	Retail	2014	2054	0.05	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.01	0.00
Opt-Out/Ex	7300	7301 Efficient Fryer	Retail	2014	2054	0.05	0.01	0.00	0.00	6%	0.00	0.00	6%	0.43	0.43	2	2	0.15			0.00
Opt-Out/Ex Opt-Out/Ex	7400 7400	7400 Base Steamer 7401 Efficient Steamer	Retail Retail	2014 2014	2054 2054	0.20	0.04 0.01	0.00	0.00 0.13	0% 64%	0.00 0.02	0.00 0.02	0% 64%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.21	0.20	0.04	0.00
Opt-Out/Ex	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Retail	2014	2054	0.31	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.31	0.00	0.00
Opt-Out/Ex	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	2014	2054	0.29	0.00	0.02	0.02	6%	0.00	0.00	0%	0.04	0.04	N/A	N/A	1.44			0.02
Opt-Out/Ex Opt-Out/Ex	8100 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	Retail Retail	2014 2014	2054 2054	1.14 27.46	0.00 4.91	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	1.14 27.46	0.00 4.91	0.00
Opt-Out/Ex	9500	9501 Xmisc	Retail	2014	2054	27.46	4.91	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00	27.10		0.00
Opt-Out/Ex	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Grocery	2020	2054	0.33	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.33	0.05	0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Grocery Grocery	2020 2020	2054 2054	0.33	0.05 0.05	0.00 0.03	0.00	0% 8%	0.00	0.00	0% 6%	0.01 0.02	0.01 0.02	0	0	4.44 3.80			0.00
Opt-Out/Ex	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Grocery	2020	2054	0.28	0.04	0.03	0.06	17%	0.00	0.01	15%	0.04	0.03	ő	Ö	1.27			0.03
Opt-Out/Ex	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Grocery	2020	2054	0.25	0.04	0.03	0.08	25%	0.00	0.01	23%	0.11	0.06	1	0	0.45			0.00
Opt-Out/Ex Opt-Out/Ex		1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Grocery	2020 2020	2054 2054	0.25 0.21	0.04 0.03	0.00 0.04	0.09 0.13	26% 38%	0.00 0.01	0.01 0.02	24% 35%	0.11 0.48	0.06 0.19	3	0	0.44 0.11			0.00
Opt-Out/Ex	1030	1035 LED Troffer (base 4L4'T8), 2020	Grocery	2020	2054	0.19	0.03	0.04	0.13	43%	0.00	0.02	41%	0.40	0.13	3	2	0.11			0.00
Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Grocery Grocery	2020 2020	2054 2054	0.00	0.00	0.00	0.00	0% 8%	0.00	0.00	0% 6%	0.01 0.02	0.01 0.02	0	0	3.71 3.18			0.00
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4 18), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	17%	0.00	0.00	15%	0.02	0.02	0	0	1.01			0.00
Opt-Out/Ex	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	27%	0.00	0.00	26%	0.11	0.06	1	ō	0.48			0.00
Opt-Out/Ex	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	29%	0.00	0.00	26%	0.20	0.07	6	0	0.24			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Grocery Grocery	2020 2020	2054 2054	0.00	0.00	0.00	0.00	32% 38%	0.00	0.00	29% 35%	0.40 0.51	0.10 0.17	3 3	1	0.14 0.11			0.00
Opt-Out/Ex	1200	1200 Base Other Fluorescent Fixture	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Grocery	2020	2054	0.10	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.10	0.02	0.00
Opt-Out/Ex Opt-Out/Ex	1330 1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Grocery Grocery	2020 2020	2054 2054	0.04	0.01 0.01	0.06	0.06	62% 0%	0.01 0.00	0.01 0.00	62% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	9.56 N/A	0.04	0.01	0.06 0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	Grocery	2020	2054	0.01	0.00	0.02	0.02	60%	0.00	0.00	60%	0.01	0.01	0	0	7.90			0.02

DNV GL 1/5/2015 H-4

APPENDIX H

Base Avoided Costs

DSM ASSY Vintage	ST ADDITIV	E SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
viiitage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource			
Sgmt		Measure Number Measure	Building Type	Start	End Year	Total	Total	GWH Savings	Savings	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base	Economic GWH
Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Grocery	2020	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex	1530	1532 LEDs (base incandescent A-line 53W) 2020	Grocery	2020	2054	0.01	0.00	0.01	0.01	50%	0.00	0.00	50%	0.01	0.01	0	0	5.36	0.01	0.00	0.01
Opt-Out/Ex Opt-Out/Ex	1630 1630	1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	Grocery Grocery	2020 2020	2054 2054	0.01 0.01	0.00	0.00	0.00	0% 28%	0.00	0.00	0% 28%	N/A 0.12	N/A 0.12	N/A 1	N/A 1	N/A 0.44	0.01	0.00	0.00
Opt-Out/Ex	1730	1730 Base CFL 23W to screw-in replacement 2020	Grocery	2020	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex		1731 LED screw-in replacement (base CFL 23W) 2020	Grocery	2020	2054	0.01	0.00	0.00	0.00	26%	0.00	0.00	26%	0.09	0.09	1	1	0.59	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1800 1800	1800 BaseMetal Halide, 465W 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Grocery Grocery	2014 2014	2054 2054	0.02	0.00	0.00	0.00	0% 8%	0.00	0.00	0% 6%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.77	0.02	0.00	0.00
Opt-Out/Ex		1801 T5 (240W) (base metal halide)	Grocery	2014	2054	0.01	0.00	0.01	0.01	39%	0.00	0.00	37%	0.02	0.01	0	0	4.35			0.01
Opt-Out/Ex	1800	1806 Occupancy Sensor, High Bay T5	Grocery	2014	2054	0.01	0.00	0.00	0.01	41%	0.00	0.00	38%	0.04	0.02	1	0	1.23	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.58	0.00	0.00	0.00
Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Grocery	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Grocery	2014	2054	0.00	0.00	0.00	0.00	20%	0.00	0.00	66%	0.11	0.11	1	1	0.60			0.00
Opt-Out/Ex Opt-Out/Ex	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	62% 73%	0.00	0.00	107% 117%	0.23 1.49	0.19	10 69	5 10	0.25 0.04			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Grocery	2014	2054	0.01	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.01	0.00
Opt-Out/Ex		2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Grocery	2014	2054	0.01	0.01	0.00	0.00	9%	0.00	0.00	9%	0.04	0.04	0	0	2.55			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2013 High Efficiency Chiller Motors 2006 VSD for Chiller Pumps and Towers	Grocery Grocery	2014 2014	2054 2054	0.01 0.01	0.01 0.01	0.00	0.00	11% 20%	0.00	0.00	11% 16%	0.07 0.05	0.05 0.05	0	0	1.62 1.39			0.00
Opt-Out/Ex		2002 Window Film (Standard) - Chiller	Grocery	2014	2054	0.01	0.00	0.00	0.00	26%	0.00	0.00	21%	0.10	0.06	0	0	0.87			0.00
Opt-Out/Ex	2000	2003 EMS - Chiller	Grocery	2014	2054	0.01	0.00	0.00	0.00	33%	0.00	0.00	23%	0.09	0.07	1	0	0.69			0.00
Opt-Out/Ex	2000	2004 Cool Roof - Chiller	Grocery	2014	2054 2054	0.01	0.00	0.00	0.00	38%	0.00	0.00	28% 40%	0.15	0.08	0	0	0.58			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2012 Duct Testing/Sealing 2011 Duct/Pipe Insulation - Chiller	Grocery Grocery	2014 2014	2054	0.00	0.00	0.00	0.00	50% 51%	0.00	0.00	40%	0.30 4.68	0.13 0.20	0 7	0	0.35			0.00
Opt-Out/Ex		2008 New Economizer - Chiller	Grocery	2014	2054	0.00	0.00	0.00	0.00	51%	0.00	0.00	41%	50270.28	0.20	316,012	0	0.00			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Grocery	2014	2054	0.29	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.29	0.19	0.00
Opt-Out/Ex	2100 2100	2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	Grocery Grocery	2014 2014	2054 2054	0.29	0.19 0.14	0.00 0.07	0.00	0% 23%	0.00	0.00	0% 23%	0.04	0.04	0	0	3.08 2.67			0.00
Opt-Out/Ex	2100	2115 Window Film (Standard) - DX	Grocery	2014	2054	0.22	0.14	0.02	0.07	28%	0.04	0.05	28%	0.10	0.04	0	0	0.84			0.00
Opt-Out/Ex	2100	2107 Cool Roof - DX	Grocery	2014	2054	0.19	0.12	0.02	0.10	34%	0.01	0.06	34%	0.14	0.06	0	0	0.62			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2108 Optimize Controls - DX 2106 Prog. Thermostat - DX	Grocery Grocery	2014 2014	2054 2054	0.19 0.18	0.12 0.12	0.00	0.10 0.10	35% 36%	0.00	0.06 0.06	34% 34%	0.12 0.14	0.07 0.07	1	0	0.42 0.37			0.00
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Grocery	2014	2054	0.18	0.12	0.00	0.10	40%	0.00	0.06	34%	0.14	0.07	0	0	0.37			0.00
Opt-Out/Ex	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Grocery	2014	2054	0.17	0.12	0.00	0.12	40%	0.00	0.07	38%	0.84	0.09	5	0	0.07			0.00
Opt-Out/Ex		2111 Economizer Repair - DX	Grocery	2014	2054	0.17	0.11	0.00	0.12	41%	0.00	0.07	39%	1.63	0.11	2	0	0.05			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2109 Economizer - DX 2114 Duct/Pipe Insulation - DX	Grocery Grocery	2014 2014	2054 2054	0.17	0.11 0.11	0.00	0.12 0.12	41% 42%	0.00	0.07 0.08	39% 40%	2.04 3.93	0.11 0.20	13 6	0	0.03 0.02			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Grocery	2014	2054	0.03	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.02	0.00
Opt-Out/Ex	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	2014	2054	0.02	0.01	0.00	0.00	12%	0.00	0.00	12%	0.03	0.03	0	0	3.06			0.00
Opt-Out/Ex Opt-Out/Ex	2300 3000	2300 Base PTAC, EER=8.3, 1 ton 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Grocery Grocery	2014 2014	2054 2054	0.01 0.28	0.01 0.06	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.01 0.28	0.01 0.06	0.00
Opt-Out/Ex	3000	3002 Variable Speed Drive Control, 5 HP	Grocery	2014	2054	0.19	0.06	0.09	0.00	31%	0.00	0.00	7%	0.03	0.03	1	1	1.61	0.20	0.00	0.09
Opt-Out/Ex		3001 Fan Motor, 5hp, 1800rpm, 89.5%	Grocery	2014	2054	0.19	0.05	0.00	0.09	32%	0.00	0.01	9%	0.07	0.04	0	1	1.09			0.00
Opt-Out/Ex Opt-Out/Ex	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Grocery Grocery	2014 2014	2054 2054	0.16 0.00	0.04	0.03	0.12	42% 0%	0.01	0.02	28% 0%	1.37 N/A	0.34 N/A	3 N/A	2 N/A	0.06 N/A	0.00	0.00	0.00
Opt-Out/Ex	3200	3200 Base Fan Motor, 15rip, 1600rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Grocery	2014	2054	0.00	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.06	0.00
Opt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP	Grocery	2014	2054	0.25	0.06	0.03	0.03	10%	0.00	0.00	3%	0.02	0.02	0	0	1.98			0.03
Opt-Out/Ex	3200	3204 Demand Controlled Ventilation	Grocery	2014	2054	0.21	0.04	0.04	0.06	23%	0.02	0.02	28%	1.04	0.58	2	2	0.08	4.40	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	4000 4000	4000 Base Built-Up Refrigeration System 4007 Efficient compressor motor	Grocery	2014 2014	2054 2054	1.40 1.39	0.22 0.22	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.52	1.40	0.22	0.00
Opt-Out/Ex	4000	4011 Demand Hot Gas Defrost	Grocery	2014	2054	1.36	0.22	0.03	0.04	3%	0.01	0.01	3%	0.02	0.02	o	0	3.25			0.03
Opt-Out/Ex		4009 Floating head pressure controls	Grocery	2014	2054	1.36	0.22	0.00	0.04	3%	0.00	0.01	3%	0.02	0.02	0	0	2.94			0.00
Opt-Out/Ex Opt-Out/Ex	4000 4000	4006 Electronically commutated evaporator fan motor 4013 Anti-sweat (humidistat) controls	Grocery Grocery	2014 2014	2054 2054	1.26 1.24	0.21 0.21	0.10 0.02	0.14 0.16	10% 11%	0.01 0.00	0.01 0.02	6% 7%	0.02 0.04	0.02 0.02	0	0	2.65 1.30			0.10 0.02
Opt-Out/Ex	4000	4002 Strip curtains for walk-ins (built-up)	Grocery	2014	2054	1.19	0.20	0.02	0.10	15%	0.00	0.02	10%	0.04	0.02	0	0	1.29			0.02
Opt-Out/Ex	4000	4014 Freezer-Cooler Replacement Gaskets	Grocery	2014	2054	1.15	0.19	0.04	0.25	18%	0.01	0.03	13%	0.06	0.03	0	0	0.90			0.00
Opt-Out/Ex Opt-Out/Ex	4000 4000	4018 Oversized Air Cooled Condenser 4001 High-efficiency fan motors	Grocery Grocery	2014 2014	2054 2054	1.10 1.06	0.19 0.18	0.05 0.04	0.29 0.33	21% 24%	0.01 0.01	0.04 0.04	17% 20%	0.08 0.11	0.04 0.05	0	0	0.82 0.65			0.00
Opt-Out/Ex		4004 Night covers for display cases	Grocery	2014	2054	1.00	0.18	0.04	0.33	28%	0.00	0.04	20%	0.11	0.05	N/A	0	0.59			0.00
Opt-Out/Ex	4000	4008 Compressor VSD retrofit	Grocery	2014	2054	0.94	0.18	0.06	0.46	33%	0.01	0.05	22%	0.10	0.06	1	1	0.53			0.00
Opt-Out/Ex	4000	4010 Refrigeration Commissioning	Grocery	2014	2054	0.94	0.18	0.00	0.46	33%	0.00	0.05	22%	0.18	0.06	1	1	0.27			0.00
Opt-Out/Ex Opt-Out/Ex	4000 4000	4005 Evaporator fan controller for MT walk-ins 4017 Multiplex Compressor System	Grocery Grocery	2014 2014	2054 2054	0.93 0.92	0.17 0.17	0.00 0.02	0.46	33% 34%	0.00	0.05 0.05	22% 23%	0.25 0.27	0.06 0.07	3 2	1	0.24 0.23			0.00
Opt-Out/Ex	4000	4016 LED Display Lighting	Grocery	2014	2054	0.84	0.16	0.07	0.55	40%	0.01	0.06	29%	0.45	0.12	3	1	0.12			0.00
Opt-Out/Ex	4000	4015 High R-Value Glass Doors	Grocery	2014	2054	0.83	0.16	0.01	0.57	40%	0.00	0.07	30%	2.02	0.16	13	1	0.03			0.00
Opt-Out/Ex	4100 4100	4100 Base Self-Contained Refrigeration	Grocery Grocery	2014 2014	2054 2054	0.16 0.16	0.03 0.02	0.00	0.00	0% 3%	0.00	0.00	0% 3%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 159.64	0.16	0.03	0.00
Opt-Out/Ex Opt-Out/Ex	4100	4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Grocery	2014	2054	0.16	0.02	0.00	0.00	3% 4%	0.00	0.00	3% 4%	0.00	0.00	0	0	3.72			0.00
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door	Grocery	2014	2054	0.14	0.02	0.01	0.01	9%	0.00	0.00	9%	0.03	0.02	0	0	2.17			0.01
Opt-Out/Ex Opt-Out/Ex	4100 4100	4107 Energy-Star Freezer, solid door	Grocery	2014	2054	0.14	0.02	0.00	0.02	11% 11%	0.00	0.00	11% 11%	0.07	0.03	0	0	0.83			0.00
Opt-Out/Ex	1100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Grocery Grocery	2014	2054	0.14	0.02	0.00	0.02 0.02	11% 11%	0.00	0.00	11% 11%	0.09	0.03	1	0	0.65 0.62			0.00
Opt-Out/Ex		4110 Energy Star Ice Machines	Grocery	2014	2054	0.14	0.02	0.00	0.02	11%	0.00	0.00	11%	0.24	0.03	1	0	0.24			0.00

APPENDIX H

Base Avoided Costs

DSM ASSY	ST ADDITIV	E SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal		Marginal		Total			SUPPLY
Vintage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Average Energy	Capacity	Average Capacity				
		Measure Number Measure	Building Type	Start	End Year	Total	Total	GWH Savings	Savings	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base MW	Economic GWH
Opt-Out/Ex	rearribor	4112 Reach-in unit occupancy sensors	Grocery	2014	2054	0.14	0.02	0.00	0.02	11%	0.00	0.00	11%	0.29	0.03	2	0	0.20	GWH	INIAA	0.00
Opt-Out/Ex		4105 Bi-level LED Case Lighting (self-contained units) 2014	Grocery	2014	2054	0.14	0.02	0.00	0.02	12%	0.00	0.00	12%	0.34	0.04	2	0	0.16			0.00
Opt-Out/Ex		4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Grocery	2014 2014	2054 2054	0.14 0.01	0.02	0.00	0.02	13%	0.00	0.00	13% 0%	0.65 N/A	0.11 N/A	4	1	0.08	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex		5000 Base Desktop PC 5001 PC Network Power Management Enabling	Grocery Grocery	2014	2054	0.00	0.00	0.00	0.00	0% 45%	0.00	0.00	23%	0.03	0.03	N/A 0	N/A 0	N/A 1.80	0.01	0.00	0.00
Opt-Out/Ex	5000	5002 Energy Star or Better PC	Grocery	2014	2054	0.00	0.00	0.00	0.00	63%	0.00	0.00	41%	0.06	0.04	0	ō	0.90			0.00
Opt-Out/Ex		5100 Base Laptop PC	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	19% 21%	0.00	0.00	19% 21%	0.02 2.48	0.02 0.22	0 14	0	2.52 0.02			0.00
Opt-Out/Ex		5200 Base Monitor, CRT	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex		5201 Energy Star or Better Monitor - CRT	Grocery	2014	2054	0.00	0.00	0.00	0.00	56%	0.00	0.00	56%	0.00	0.00	0	0	20.00			0.00
Opt-Out/Ex Opt-Out/Ex		5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	73% 76%	0.00	0.00	65% 67%	0.05	0.01	1	0	0.93			0.00
Opt-Out/Ex		5300 Base Monitor, LCD	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.52 N/A	0.03 N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex		5301 Energy Star or Better Monitor - LCD	Grocery	2014	2054	0.00	0.00	0.00	0.00	20%	0.00	0.00	20%	0.02	0.02	0	0	2.86			0.00
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	Grocery	2014	2054	0.00	0.00	0.00	0.00	31%	0.00	0.00	26%	0.19	0.08	2	1	0.24			0.00
Opt-Out/Ex Opt-Out/Ex		5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	36% 0%	0.00	0.00	27% 0%	0.53 N/A	0.15 N/A	12 N/A	N/A	0.08 N/A	0.00	0.00	0.00
Opt-Out/Ex		5401 Energy Star or Better Copier	Grocery	2014	2054	0.00	0.00	0.00	0.00	20%	0.00	0.00	20%	0.00	0.00	0	0	13.56	0.00	0.00	0.00
Opt-Out/Ex		5402 Copier Power Management Enabling	Grocery	2014	2054	0.00	0.00	0.00	0.00	31%	0.00	0.00	26%	0.24	0.09	3	1	0.20			0.00
Opt-Out/Ex Opt-Out/Ex		5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.20	0.00	0.00	0.00
Opt-Out/Ex		5502 ENERGY STAR Multi-Puriction Device 5501 Multifunction Power Management Enabling	Grocery	2014	2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	36%	0.64	0.30	7	2	0.07			0.00
Opt-Out/Ex	5600	5600 Base Printer	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex		5602 ENERGY STAR Printer	Grocery	2014	2054	0.00	0.00	0.00	0.00	35%	0.00	0.00	35%	0.00	0.00	0	0	19.30			0.00
Opt-Out/Ex Opt-Out/Ex		5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	53% 0%	0.00	0.00	44% 0%	0.14 N/A	0.05 N/A	2 N/A	0 N/A	0.34 N/A	0.00	0.00	0.00
Opt-Out/Ex		5701 Data Center Improved Operations	Grocery	2014	2054	0.00	0.00	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	0	0	67.16	0.00	0.00	0.00
Opt-Out/Ex	5700	5702 Data Center Best Practices	Grocery	2014	2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	0.00	0.00	0	0	27.34			0.00
Opt-Out/Ex		5703 Data Center State of the Art practices	Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	26%	0.00	0.00	26%	0.00 N/A	0.00 N/A	0	0 N/A	14.18	0.02	0.00	0.00
Opt-Out/Ex Opt-Out/Ex		6000 Base Water Heating 6007 Heat Trap	Grocery Grocery	2014	2054	0.03	0.00	0.00	0.00	0% 5%	0.00	0.00	0% 5%	0.03	0.03	N/A 0	0	N/A 1.99	0.03	0.00	0.00
Opt-Out/Ex	6000	6002 High Efficiency Water Heater (electric)	Grocery	2014	2054	0.03	0.00	0.00	0.00	7%	0.00	0.00	7%	0.06	0.04	0	Ö	1.07			0.00
Opt-Out/Ex		6006 Heat Recovery Unit	Grocery	2014	2054	0.01	0.00	0.01	0.02	55%	0.00	0.00	55%	0.07	0.07	0	0	0.82			0.00
Opt-Out/Ex Opt-Out/Ex		6004 Tankless Water Heater 6008 Solar Water Heater	Grocery Grocery	2014 2014	2054 2054	0.01 0.01	0.00	0.00	0.02 0.02	59% 65%	0.00	0.00	59% 65%	0.19 0.23	0.07 0.09	1	0	0.36 0.31			0.00
Opt-Out/Ex	6000	6001 Demand controlled circulating systems	Grocery	2014	2054	0.01	0.00	0.00	0.02	66%	0.00	0.00	66%	0.26	0.09	2	1	0.25			0.00
Opt-Out/Ex	6000	6003 Hot Water Pipe Insulation	Grocery	2014	2054	0.01	0.00	0.00	0.02	66%	0.00	0.00	66%	0.28	0.09	2	1	0.23			0.00
Opt-Out/Ex		7000 Base Refrigerated Vending Machines	Grocery	2014	2054	0.03	0.01	0.00	0.00	0% 16%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	0.03	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Grocery Grocery	2014 2014	2054 2054	0.03	0.00	0.01 0.00	0.01 0.01	25%	0.00	0.00	8% 12%	0.03	0.03	1	0	1.83 1.00			0.01 0.00
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex		7101 Vending Misers (Non-Refrigerated)	Grocery	2014	2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	23%	0.43	0.43	5	5	0.11			0.00
Opt-Out/Ex Opt-Out/Ex	7200 7300	7200 Base Oven 7300 Base Fryer	Grocery Grocery	2014 2014	2054 2054	0.04 0.05	0.00 0.01	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.04	0.00	0.00
Opt-Out/Ex		7400 Base Steamer	Grocery	2014	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00
Opt-Out/Ex		7401 Efficient Steamer	Grocery	2014	2054	0.02	0.00	0.05	0.05	69%	0.01	0.01	69%	0.06	0.06	0	0	0.98			0.00
Opt-Out/Ex Opt-Out/Ex	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.04	N/A 0.04	N/A N/A	N/A N/A	N/A 1.19	0.00	0.00	0.00
Opt-Out/Ex		8100 Base Heating, Other Electric	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex		9500 Base Miscellaneous	Grocery	2014	2054	0.36	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.36	0.06	0.00
Opt-Out/Ex		9501 Xmisc	Grocery	2014	2054	0.36	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00	0.07	0.54	0.00
Opt-Out/Ex Opt-Out/Ex		1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Warehouse Warehouse	2020 2020	2054 2054	2.87 2.64	0.51 0.47	0.00 0.24	0.00 0.24	0% 8%	0.00 0.04	0.00 0.04	0% 8%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.64	2.87	0.51	0.00 0.24
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Warehouse	2020	2054	2.59	0.46	0.04	0.28	10%	0.00	0.05	9%	0.03	0.02	0	0	1.54			0.04
Opt-Out/Ex		1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Warehouse	2020	2054	2.27	0.41	0.32	0.60	21%	0.06	0.10	20%	0.05	0.03	0	0	1.21			0.32
Opt-Out/Ex Opt-Out/Ex		1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Warehouse Warehouse	2020 2020	2054 2054	2.10	0.38 0.38	0.17	0.77	27% 29%	0.02	0.13	25% 26%	0.05	0.04	0	0	1.18 0.54			0.17
Opt-Out/Ex		1037 Occupancy Sensor, 4L4 Profession Prixtures, 2020	Warehouse	2020	2054	1.71	0.32	0.00	1.16	40%	0.06	0.13	37%	0.09	0.04	2	1	0.22			0.00
Opt-Out/Ex	1030	1035 LED Troffer (base 4L4'T8), 2020	Warehouse	2020	2054	1.57	0.30	0.15	1.31	46%	0.03	0.21	42%	0.24	0.12	1	1	0.27			0.00
Opt-Out/Ex		1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020	Warehouse	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Warehouse Warehouse	2020 2020	2054 2054	0.02 0.02	0.00	0.00	0.00	10% 12%	0.00	0.00	10% 11%	0.03	0.03	0	0	2.04 1.45			0.00
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Warehouse	2020	2054	0.02	0.00	0.00	0.00	18%	0.00	0.00	16%	0.05	0.04	0	0	1.27			0.00
Opt-Out/Ex	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Warehouse	2020	2054	0.01	0.00	0.00	0.01	29%	0.00	0.00	27%	0.06	0.05	0	0	0.89			0.00
Opt-Out/Ex Opt-Out/Ex		1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Warehouse Warehouse	2020 2020	2054 2054	0.01 0.01	0.00	0.00	0.01 0.01	32% 38%	0.00	0.00	30% 36%	0.23 0.29	0.07 0.10	1 2	0	0.27 0.22			0.00
Opt-Out/Ex		1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Warehouse	2020	2054	0.01	0.00	0.00	0.01	40%	0.00	0.00	36%	0.29	0.10	4	1	0.26			0.00
Opt-Out/Ex	1200	1200 Base Other Fluorescent Fixture	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex		1203 Lighting Control Tuneup (base other fluorescent fixture)	Warehouse	2014	2054	0.00	0.00	0.00	0.00	10%	0.00	0.00	5%	0.00	0.00	0	0	15.20			0.00
Opt-Out/Ex Opt-Out/Ex		1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Warehouse Warehouse	2014	2054 2054	0.00	0.00	0.00	0.00	17% 25%	0.00	0.00	10% 19%	0.03	0.01	0	0	2.04 0.53			0.00
Opt-Out/Ex		1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Warehouse	2014	2054	0.00	0.00	0.00	0.00	31%	0.00	0.00	20%	0.12	0.06	3	1	0.40			0.00
Opt-Out/Ex	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Warehouse	2020	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00

H-6 DNV GL 1/5/2015

APPENDIX H

Base Avoided Costs

DSM ASSYS	ST ADDITIV	E SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal		Marginal		Total			SUPPLY
Vintage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Average Energy	Capacity	Average Capacity				
		Measure Number Measure	Building Type	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base	Economic GWH
Opt-Out/Ex	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Warehouse	2020	2054	0.09	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.02	0.00
Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Warehouse	2020	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	1630 1630	1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	Warehouse Warehouse	2020 2020	2054 2054	0.12	0.02	0.00	0.00	0% 28%	0.00 0.01	0.00 0.01	0% 28%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 0.89	0.12	0.02	0.00
Opt-Out/Ex	1730	1730 Base CFL 23W to screw-in replacement 2020	Warehouse	2020	2054	0.05	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.15	0.03	0.00
Opt-Out/Ex	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Warehouse	2020	2054	0.11	0.02	0.04	0.04	26%	0.01	0.01	26%	0.05	0.05	0	0	1.18			0.04
Opt-Out/Ex	1800 1800	1800 BaseMetal Halide, 465W	Warehouse	2014	2054 2054	1.73	0.31	0.00	0.00	0% 34%	0.00	0.00	0% 34%	N/A	N/A 0.01	N/A	N/A	N/A	1.73	0.31	0.00
Opt-Out/Ex Opt-Out/Ex	1800	1801 T5 (240W) (base metal halide) 1806 Occupancy Sensor, High Bay T5	Warehouse Warehouse	2014 2014	2054	1.15 1.11	0.20	0.59	0.62	34% 36%	0.10	0.10	34%	0.01 0.03	0.01	0	0	6.53 1.67			0.59
Opt-Out/Ex	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Warehouse	2014	2054	1.03	0.19	0.08	0.71	41%	0.01	0.12	38%	0.05	0.02	o o	0	1.32			0.08
Opt-Out/Ex	1850	1850 Base CFL Exit Sign	Warehouse	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Warehouse Warehouse	2014 2014	2054 2054	0.00	0.00	0.01	0.01	69% 0%	0.00	0.00	69% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.04 N/A	0.64	0.01	0.01
Opt-Out/Ex	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Warehouse	2014	2054	0.52	0.00	0.13	0.13	20%	0.01	0.01	66%	0.06	0.06	1	1	1.12	0.04	0.01	0.13
Opt-Out/Ex	1900	1902 LED Outdoor Area Lighting	Warehouse	2014	2054	0.25	0.00	0.27	0.40	61%	0.00	0.01	108%	0.11	0.10	8	4	0.49			0.00
Opt-Out/Ex Opt-Out/Ex	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Warehouse Warehouse	2014 2014	2054 2054	0.18 0.00	0.00	0.07 0.00	0.47 0.00	73% 0%	0.00	0.01 0.00	118% 0%	0.74 N/A	0.20 N/A	61 N/A	9 N/A	0.07 N/A	0.00	0.00	0.00
Opt-Out/Ex	2100	2100 Base Centifugal Criffler, 0.56 kW/ton, 500 tons 2100 Base DX Packaged System, EER=10.3, 10 tons	Warehouse	2014	2054	1.46	1.38	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.46	1.38	0.00
Opt-Out/Ex	2100	2113 Ceiling/roof Insulation - DX	Warehouse	2014	2054	1.39	1.32	0.07	0.07	5%	0.06	0.06	5%	0.05	0.05	0	0	2.52	1.10	1.00	0.07
Opt-Out/Ex	2100	2107 Cool Roof - DX	Warehouse	2014	2054	1.29	1.22	0.10	0.17	12%	0.10	0.16	12%	0.12	0.09	0	0	0.86			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2108 Optimize Controls - DX 2102 DX Packaged System, EER=13.4, 10 tons	Warehouse Warehouse	2014 2014	2054 2054	1.27 0.97	1.22	0.02	0.19 0.48	13% 33%	0.01 0.28	0.17	12% 32%	0.15 0.48	0.10	1	0	0.36			0.00
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Warehouse	2014	2054	0.97	0.94	0.29	0.46	37%	0.26	0.50	36%	3.07	0.62	3	1	0.26			0.00
Opt-Out/Ex	2100	2115 Window Film (Standard) - DX	Warehouse	2014	2054	0.88	0.85	0.04	0.58	40%	0.04	0.54	39%	2.74	0.77	3	1	0.04			0.00
Opt-Out/Ex	2100	2106 Prog. Thermostat - DX	Warehouse	2014	2054	0.85	0.84	0.03	0.60	42%	0.01	0.54	39%	2.02	0.82	7	1	0.03			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2114 Duct/Pipe Insulation - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Warehouse Warehouse	2014 2014	2054 2054	0.85 0.85	0.84 0.84	0.00	0.61 0.61	42% 42%	0.00	0.55 0.55	39% 39%	5.62 3.71	0.83 0.84	6 14	1	0.02 0.02			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Warehouse	2014	2054	0.79	0.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.79	0.75	0.00
Opt-Out/Ex	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Warehouse	2014	2054	0.69	0.66	0.10	0.10	12%	0.09	0.09	12%	0.05	0.05	0	0	2.61			0.10
Opt-Out/Ex	2300	2300 Base PTAC, EER=8.3, 1 ton	Warehouse	2014 2014	2054 2054	0.04 0.82	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A	0.04	0.04	0.00
Opt-Out/Ex Opt-Out/Ex	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Warehouse Warehouse	2014	2054	0.82	0.25 0.25	0.00	0.00	0% 2%	0.00	0.00	0% 2%	0.05	0.05	0	0	N/A 1.83	0.82	0.25	0.00 0.01
Opt-Out/Ex	3000	3002 Variable Speed Drive Control, 5 HP	Warehouse	2014	2054	0.57	0.23	0.24	0.25	31%	0.02	0.02	9%	0.04	0.04	Ö	Ö	1.63			0.24
Opt-Out/Ex	3000	3003 Demand Controlled Ventilation	Warehouse	2014	2054	0.56	0.23	0.01	0.26	31%	0.00	0.03	11%	1.85	0.09	3		0.05			0.00
Opt-Out/Ex Opt-Out/Ex	3100 3200	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Warehouse Warehouse	2014 2014	2054 2054	0.00 0.27	0.00 0.08	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00
Opt-Out/Ex	3200	3202 Variable Speed Drive Control, 40 HP	Warehouse	2014	2054	0.19	0.08	0.08	0.08	29%	0.01	0.01	8%	0.02	0.02	0	0	3.18	0.27	0.00	0.08
Opt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP	Warehouse	2014	2054	0.17	0.08	0.02	0.10	36%	0.00	0.01	9%	0.06	0.03	1	0	0.78			0.00
Opt-Out/Ex	3200 4000	3204 Demand Controlled Ventilation	Warehouse	2014	2054	0.17 1.96	0.07	0.00	0.10	37%	0.00	0.01	11%	2.02	0.07 N/A	4	1	0.05	4.00	0.07	0.00
Opt-Out/Ex	4000	4000 Base Built-Up Refrigeration System 4018 Oversized Air Cooled Condenser	Warehouse Warehouse	2014 2014	2054 2054	1.88	0.37 0.36	0.00	0.00 0.08	0% 4%	0.00 0.02	0.00 0.02	0% 4%	N/A 0.03	0.03	N/A 0	N/A 0	N/A 2.16	1.96	0.37	0.00
Opt-Out/Ex	4000	4010 Refrigeration Commissioning	Warehouse	2014	2054	1.87	0.35	0.01	0.09	5%	0.00	0.02	5%	0.06	0.03	ō	ō	0.84			0.00
Opt-Out/Ex	4000	4006 Electronically commutated evaporator fan motor	Warehouse	2014	2054	1.76	0.34	0.11	0.20	10%	0.01	0.03	8%	0.11	0.07	1	1	0.56			0.00
Opt-Out/Ex Opt-Out/Ex	4000 4000	4005 Evaporator fan controller for MT walk-ins 4002 Strip curtains for walk-ins (built-up)	Warehouse Warehouse	2014 2014	2054 2054	1.75 1.68	0.34 0.33	0.01 0.07	0.21 0.28	11% 14%	0.00 0.01	0.03 0.04	8% 11%	0.19 0.19	0.08 0.10	2	1	0.32 0.28			0.00
Opt-Out/Ex	4000	4001 High-efficiency fan motors	Warehouse	2014	2054	1.63	0.32	0.05	0.33	17%	0.01	0.05	14%	0.47	0.16	2	1	0.16			0.00
Opt-Out/Ex	4100	4100 Base Self-Contained Refrigeration	Warehouse	2014	2054	0.52	0.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.52	0.10	0.00
Opt-Out/Ex Opt-Out/Ex	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Warehouse Warehouse	2014 2014	2054 2054	0.52 0.12	0.10 0.02	0.01	0.01	2% 0%	0.00	0.00	2% 0%	0.16 N/A	0.16 N/A	1 N/A	1 N/A	0.32 N/A	0.12	0.02	0.00
Opt-Out/Ex	5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Warehouse	2014	2054	0.12	0.02	0.00	0.00	44%	0.00	0.00	23%	0.01	0.01	0	0	3.53	0.12	0.02	0.05
Opt-Out/Ex	5000	5002 Energy Star or Better PC	Warehouse	2014	2054	0.05	0.01	0.02	0.08	63%	0.00	0.01	41%	0.03	0.02	0	0	1.82			0.02
Opt-Out/Ex	5100	5100 Base Laptop PC	Warehouse	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Warehouse Warehouse	2014 2014	2054 2054	0.01	0.00	0.00	0.00	19% 21%	0.00	0.00	19% 21%	0.01 1.24	0.01	0 7	0	5.03 0.04			0.00
Opt-Out/Ex	5200	5200 Base Monitor, CRT	Warehouse	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
Opt-Out/Ex	5200	5201 Energy Star or Better Monitor - CRT	Warehouse	2014	2054	0.01	0.00	0.01	0.01	56%	0.00	0.00	56%	0.00	0.00	0	0	40.01			0.01
Opt-Out/Ex Opt-Out/Ex	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Warehouse Warehouse	2014 2014	2054 2054	0.01	0.00	0.00	0.02 0.02	70% 73%	0.00	0.00	63% 66%	0.02	0.01	0	0	2.18 0.22			0.00
Opt-Out/Ex	5300	5300 Base Monitor, LCD	Warehouse	2014	2054	0.01	0.00	0.00	0.02	0%	0.00	0.00	0%	0.23 N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
Opt-Out/Ex	5300	5301 Energy Star or Better Monitor - LCD	Warehouse	2014	2054	0.02	0.00	0.00	0.00	20%	0.00	0.00	20%	0.01	0.01	0	0	5.71			0.00
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	Warehouse	2014	2054	0.02	0.00	0.00	0.00	21%	0.00	0.00	21%	0.08	0.01	1	0	0.57			0.00
Opt-Out/Ex Opt-Out/Ex	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Warehouse Warehouse	2014 2014	2054 2054	0.01	0.00 0.01	0.00	0.01 0.00	27% 0%	0.00	0.00	22% 0%	0.24 N/A	0.06 N/A	5 N/A	0 N/A	0.18 N/A	0.03	0.01	0.00
Opt-Out/Ex	5400	5401 Energy Star or Better Copier	Warehouse	2014	2054	0.03	0.00	0.00	0.00	12%	0.00	0.00	12%	0.00	0.00	0	0	29.97	0.00	0.01	0.00
Opt-Out/Ex	5400	5402 Copier Power Management Enabling	Warehouse	2014	2054	0.03	0.00	0.00	0.00	15%	0.00	0.00	14%	0.09	0.02	.1	0	0.52			0.00
Opt-Out/Ex Opt-Out/Ex	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Warehouse Warehouse	2014 2014	2054 2054	0.01 0.01	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.40	0.01	0.00	0.00
Opt-Out/Ex	5500	5502 ENERGY STAR Multi-Puriction Device 5501 Multifunction Power Management Enabling	Warehouse	2014	2054	0.00	0.00	0.00	0.00	32%	0.00	0.00	29%	0.01	0.06	3	0	0.20			0.00
Opt-Out/Ex	5600	5600 Base Printer	Warehouse	2014	2054	0.03	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.01	0.00
Opt-Out/Ex	5600	5602 ENERGY STAR Printer	Warehouse	2014	2054	0.02	0.00	0.01	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	38.61			0.01
Opt-Out/Ex Opt-Out/Ex	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Warehouse Warehouse	2014	2054 2054	0.02	0.00	0.00	0.01	41% 0%	0.00	0.00	38% 0%	0.05 N/A	0.01 N/A	1 N/A	0 N/A	0.93 N/A	0.37	0.06	0.00
Opt-Out/Ex	5700	5701 Data Center Improved Operations	Warehouse	2014	2054	0.33	0.05	0.04	0.04	10%	0.01	0.01	10%	0.00	0.00	0	0	107.17	0.01	0.00	0.04
Opt-Out/Ex	5700	5702 Data Center Best Practices	Warehouse	2014	2054	0.29	0.05	0.04	0.08	21%	0.01	0.01	21%	0.00	0.00	0	0	43.63			0.04

APPENDIX H

Base Avoided Costs

DSM ASSYS	ST ADDITIV	E SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		Measure Number Measure	Building	Start	End Year	Total	Total MW	GWH	Savings	GWH	MW	Savings MW	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base MW	Economic GWH
Sgmt Opt-Out/Ex	5700	5703 Data Center State of the Art practices	Type Warehouse	2014	2054	0.27	0.05	Savings 0.02	0.09	Savings 26%	Savings 0.00	0.02	Savings 26%	0.00	0.00	0	0	22.63	GWH	IVI VV	0.02
Opt-Out/Ex		6000 Base Water Heating	Warehouse	2014	2054	0.14	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.14	0.02	0.00
Opt-Out/Ex	6000 6000	6006 Heat Recovery Unit 6007 Heat Trap	Warehouse	2014 2014	2054 2054	0.13 0.12	0.02	0.01 0.01	0.01	7% 11%	0.00	0.00	7% 11%	0.25 0.45	0.25	2	2	0.23 0.13			0.00
Opt-Out/Ex Opt-Out/Ex	6000	6002 High Efficiency Water Heater (electric)	Warehouse Warehouse	2014	2054	0.12	0.02	0.00	0.02 0.02	13%	0.00	0.00	13%	0.45	0.33 0.42	6	3	0.13			0.00
Opt-Out/Ex	6000	6004 Tankless Water Heater	Warehouse	2014	2054	0.11	0.02	0.01	0.03	20%	0.00	0.00	20%	1.42	0.75	9	5	0.05			0.00
Opt-Out/Ex	6000	6008 Solar Water Heater	Warehouse	2014	2054	0.07	0.01	0.04	0.07	47%	0.01	0.01	47%	1.66	1.28	11	8	0.04			0.00
Opt-Out/Ex Opt-Out/Ex	6000 6000	6003 Hot Water Pipe Insulation 6001 Demand controlled circulating systems	Warehouse Warehouse	2014 2014	2054 2054	0.07 0.07	0.01 0.01	0.00	0.07 0.07	48% 49%	0.00	0.01 0.01	48% 49%	2.58 2.88	1.31 1.34	16 18	8 9	0.03 0.02			0.00
Opt-Out/Ex	7000	7000 Base Refrigerated Vending Machines	Warehouse	2014	2054	0.10	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.10	0.02	0.00
Opt-Out/Ex	7000	7001 Vending Misers (Refrigerated units)	Warehouse	2014	2054	0.08	0.02	0.02	0.02	16%	0.00	0.00	8%	0.03	0.03	0	0	1.83			0.02
Opt-Out/Ex Opt-Out/Ex	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Warehouse Warehouse	2014 2014	2054 2054	0.07	0.02	0.01	0.02	25% 0%	0.00	0.00	12% 0%	0.05 N/A	0.03 N/A	1 N/A	0 N/A	1.00 N/A	0.00	0.00	0.01
Opt-Out/Ex	7100	7100 Base Non-Reingerated Verlaing Macrilles 7101 Vending Misers (Non-Refrigerated)	Warehouse	2014	2054	0.00	0.00	0.00	0.00	45%	0.00	0.00	23%	0.44	0.44	5 N/A	5	0.11	0.00	0.00	0.00
Opt-Out/Ex	7200	7200 Base Oven	Warehouse	2014	2054	0.03	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.01	0.00
Opt-Out/Ex	7300	7300 Base Fryer	Warehouse	2014	2054	0.07	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.07	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Warehouse Warehouse	2014 2014	2054 2054	0.03	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.03	0.00	0.00
Opt-Out/Ex	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Warehouse	2014	2054	0.01	0.00	0.00	0.00	6%	0.00	0.00	0%	0.03	0.03	N/A	N/A	1.65	0.01	0.00	0.00
Opt-Out/Ex		8100 Base Heating, Other Electric	Warehouse	2014	2054	0.11	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Warehouse Warehouse	2014 2014	2054 2054	2.24	0.42	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	2.24	0.42	0.00
Opt-Out/Ex	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	School	2014	2054	3.64	0.42	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.64	0.49	0.00
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	School	2020	2054	3.60	0.49	0.04	0.04	1%	0.00	0.00	1%	0.02	0.02	0	0	2.35			0.04
Opt-Out/Ex	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	School	2020	2054	3.23	0.44	0.37	0.41	11%	0.05	0.05	11%	0.03	0.03	0	0	2.27			0.37
Opt-Out/Ex Opt-Out/Ex	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	School School	2020 2020	2054 2054	2.99 2.87	0.41 0.40	0.24 0.12	0.65 0.77	18% 21%	0.03 0.02	0.08	16% 19%	0.03 0.20	0.03 0.05	0	0	1.83 0.31			0.24 0.00
Opt-Out/Ex	1030	1034 ROB 4L4' LED Tube, 2020	School	2020	2054	2.41	0.33	0.46	1.23	34%	0.06	0.16	32%	0.35	0.17	3	1	0.20			0.00
Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	School	2020	2054	2.28	0.33	0.13	1.36	37%	0.00	0.16	33%	0.18	0.17	5	1	0.27			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	School School	2020 2020	2054 2054	2.08 0.23	0.30	0.19 0.00	1.56 0.00	43% 0%	0.03	0.19 0.00	38% 0%	0.31 N/A	0.18 N/A	2 N/A	2 N/A	0.22 N/A	0.23	0.03	0.00
Opt-Out/Ex	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	School	2020	2054	0.23	0.03	0.00	0.02	10%	0.00	0.00	10%	0.03	0.03	0	0	1.81	0.23	0.03	0.02
Opt-Out/Ex	1130	1136 Lighting Control Tuneup (base 2L4T8), 2020	School	2020	2054	0.20	0.03	0.00	0.03	11%	0.00	0.00	11%	0.03	0.03	0	0	1.43			0.00
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	School	2020	2054	0.19	0.03	0.02	0.04	18%	0.00	0.00	16%	0.05	0.04	0	0	1.24			0.02
Opt-Out/Ex Opt-Out/Ex	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	School School	2020 2020	2054 2054	0.16 0.16	0.02 0.02	0.02 0.01	0.06	28% 32%	0.00	0.01	27% 30%	0.08 0.32	0.05 0.08	2	0	0.79 0.22			0.00
Opt-Out/Ex		1135 LED Troffer (base 2L4'T8), 2020	School	2020	2054	0.14	0.02	0.01	0.09	38%	0.00	0.01	36%	0.40	0.13	3	1	0.17			0.00
Opt-Out/Ex	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	School	2020	2054	0.13	0.02	0.01	0.09	41%	0.00	0.01	37%	0.33	0.15	10	.1	0.15			0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	School School	2014 2014	2054 2054	0.02	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 3%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 1.94	0.02	0.00	0.00
Opt-Out/Ex	1200	1201 ROB High Performance T8 (base other fluorescent)	School	2014	2054	0.02	0.00	0.00	0.00	14%	0.00	0.00	11%	0.02	0.02	1	1	0.54			0.00
Opt-Out/Ex	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	School	2014	2054	0.01	0.00	0.00	0.01	37%	0.00	0.00	25%	0.20	0.16	6	2	0.25			0.00
Opt-Out/Ex	1200 1330	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	School School	2014 2020	2054 2054	0.01	0.00 0.01	0.00	0.01 0.00	41% 0%	0.00	0.00	29% 0%	0.37 N/A	0.18 N/A	3 N/A	2 N/A	0.17 N/A	0.05	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	1330	1330 Base incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	School	2020	2054	0.05	0.01	0.00	0.00	67%	0.00	0.00	67%	0.00	0.00	N/A 0	N/A 0	14.72	0.05	0.01	0.00
Opt-Out/Ex	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	School	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
Opt-Out/Ex	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020	School	2020 2020	2054 2054	0.01	0.00	0.01	0.01	64% 0%	0.00	0.00	64% 0%	0.00 N/A	0.00 N/A	0	0	12.22	0.04	0.00	0.01
Opt-Out/Ex Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	School School	2020	2054	0.01	0.00	0.00	0.00	54%	0.00	0.00	0% 54%	0.01	0.01	N/A 0	N/A 0	N/A 8.43	0.01	0.00	0.00
Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020	School	2020	2054	0.25	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.25	0.03	0.00
Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	School	2020	2054	0.18	0.02	0.07	0.07	28%	0.01	0.01	28%	0.08	0.08	1	.1	0.77			0.00
Opt-Out/Ex Opt-Out/Ex	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	School School	2020 2020	2054 2054	0.32 0.23	0.04 0.03	0.00 0.08	0.00 80.0	0% 26%	0.00 0.01	0.00 0.01	0% 26%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.02	0.32	0.04	0.00
Opt-Out/Ex	1800	1800 BaseMetal Halide, 465W	School	2014	2054	1.31	0.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.31	0.18	0.00
Opt-Out/Ex	1800	1801 T5 (240W) (base metal halide)	School	2014	2054	0.87	0.12	0.44	0.44	34%	0.06	0.06	34%	0.02	0.02	0	0	3.45			0.44
Opt-Out/Ex	1800 1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	School School	2014 2014	2054 2054	0.80 0.78	0.11 0.11	0.06	0.51 0.53	39% 41%	0.01	0.07 0.07	38% 38%	0.03	0.02	0	0	2.18 0.83			0.06
Opt-Out/Ex	1850	1806 Occupancy Sensor, High Bay T5 1850 Base CFI, Exit Sign	School	2014	2054	0.78	0.11	0.03	0.53	41% 0%	0.00	0.07	38% 0%	0.06 N/A	0.02 N/A	N/A	N/A	0.83 N/A	0.04	0.00	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	School	2014	2054	0.02	0.00	0.02	0.02	55%	0.00	0.00	55%	0.04	0.04	0	0	1.31			0.02
Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	School	2014	2054	1.30	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.30	0.05	0.00
Opt-Out/Ex Opt-Out/Ex	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	School School	2014 2014	2054 2054	1.19 0.57	0.04 0.01	0.11 0.62	0.11 0.73	9% 56%	0.01 0.02	0.01 0.04	28% 75%	0.05 0.11	0.05 0.10	0	0 2	1.37 0.52			0.11 0.00
Opt-Out/Ex	1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	School	2014	2054	0.40	0.01	0.17	0.90	69%	0.01	0.04	87%	0.72	0.10	20	4	0.52			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	School	2014	2054	3.60	1.85	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.60	1.85	0.00
Opt-Out/Ex Opt-Out/Ex	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2013 High Efficiency Chiller Motors	School School	2014 2014	2054 2054	3.29	1.69 1.69	0.31	0.31	9% 9%	0.16	0.16 0.16	9% 9%	0.07	0.07	0	0	1.34 0.87			0.31
Opt-Out/Ex	2000	2006 VSD for Chiller Pumps and Towers	School	2014	2054	3.29	1.69	0.00	0.31	9%	0.00	0.16	9%	0.12	0.08	0	0	0.87			0.00
Opt-Out/Ex	2000	2003 EMS - Chiller	School	2014	2054	3.11	1.66	0.18	0.49	14%	0.03	0.19	10%	0.14	0.10	1	0	0.44			0.00
Opt-Out/Ex	2000	2004 Cool Roof - Chiller	School	2014	2054	3.05	1.63	0.06	0.55	15%	0.03	0.22	12%	0.23	0.11	0	0	0.35			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2002 Window Film (Standard) - Chiller 2012 Duct Testing/Sealing	School School	2014 2014	2054 2054	3.03 2.53	1.62 1.37	0.02 0.50	0.57 1.07	16% 30%	0.01 0.26	0.22 0.48	12% 26%	0.26 0.38	0.12 0.24	1	0 1	0.30 0.26			0.00
Opt-Out/Ex	2000	2008 New Economizer - Chiller	School	2014	2054	2.26	1.33	0.27	1.34	37%	0.04	0.52	28%	0.43	0.28	3	1	0.13			0.00
Opt-Out/Ex		2011 Duct/Pipe Insulation - Chiller	School	2014	2054	2.25	1.32	0.01	1.35	38%	0.01	0.53	29%	6.18	0.34	12	1	0.01			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	School	2014	2054	1.83	0.94	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.83	0.94	0.00

APPENDIX H

Base Avoided Costs

	DSM ASSYS Vintage	ST ADDITIV	E SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
Section Sect		_								Energy			Capacity		Energy	Energy	Capacity	Capacity	Resource			
Second S																						
Control Cont	Opt-Out/Ex			School							0%			0%			-					
Charles 100 111 Manus Fringeneric December 111 Manus Fringeneric December																	0	-				
Second																	1	-				
Second S	Opt-Out/Ex	2100		School									0.23			0.08	1		0.25			
Change 1900 2000																	1					
Decompton Deco																	1	-				
																	1					
																		0				
Second S																		N/A		1.83	0.94	
Second	Opt-Out/Ex		2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School				0.83	0.23	0.23	12%		0.12	12%			0	0	1.68			0.23
Second Control Contr														-,-						1.83	0.94	
Second S																	1					
Decomposition Decompositio	Opt-Out/Ex		3000 Base Fan Motor, 5hp, 1800rpm, 87.5%			2054		0.17	0.00		0%		0.00	0%					N/A	0.87	0.17	
Second S																	-	-				
																				2.32	0.45	
Ground Sign Sign																				2.02	0.10	
Ground Strong S			3103 Air Handler Optimization, 15 HP														1	-				
Second 1970																	1					
Cycle 100 200 201 20																	_					
Cycludge 200 200 Art Index Cycludge 200 200 Art Index Cycludge 200																	N/A	N/A		0.97	0.19	
Change C																	0					
																	5					
Pos-Delify 100																				0.00	0.00	
Separate 190 Sepa																				1.31	0.18	
Sepon Sepo																						
Concount Concount																						
Configure 1400 4100 Energy-Star Refingement gliss door School 2014 2054 1.13 0.16 0.01 0.15 1.75 0.00 0.02 1.15 0.00 0.02 1.15 0.00 0.02 1.15 0.00 0.02 1.15 0.00																	-					
Opt-Opt-Opt-Opt-Opt-Opt-Opt-Opt-Opt-Opt-																	•	•				
Opc-Out-Disc 100 All Passer's units occupancy sensors School 214 2054 1.11 0.15 0.00 0.20 15% 0.00 0.03 15% 0.34 0.01 2 0 0.17 0.00 0.0																	-	-				
Opt-Opt-Exp 4100 4101 Strip curtains for walk-ine (self-contained) School 2014 2054 1.10 0.15 0.00 0.01 10% 0.00 0.03 16% 1.26 0.03 9.0 0.00 0.00 0.00 0.00 0.00 0.00		4100			2014		1.11		0.00							0.01	2	Ō				
Opt-Out-Res 5000 5001 Reside Desktop PC School 2014 2054 0.02 0.00 0.00 0.00 0.00 0.00 0.00 0.0																	-	-				
Opt-Outlets 5000 5010 FC Network Power Management Enabling Selbod 2014 2054 0.01 0.00 0.01 45% 0.00 0.00 23% 0.01 0.01 0.0 0.0 1.00 0.01 0.00 0.00																				0.03	0.00	
Opt-Out-Fix 5100 5100 Base Laptop PC School 2014 2054 0.01 0.00																				0.00	0.00	
Opt-Out-Ex 100 5102 Energy Stair or Better Laptop School 2014 2054 0.01 0.00 0.00 0.00 0.00 0.00 0.00 0.00 19% 0.01 0.01 0.01 0.01 0.01 0.00																						
Opt-Opt-Express 5100 5101 Laptop Network Power Management Enabling School 2014 2054 0.01 0.00 0.00 0.00 0.00 0.00 0.00 0.0																				0.01	0.00	
Display Disp																		-				
Opt-Quil-Ex S200 5202 Monitor Power Management Enabling - CRT School 2014 2054 0.01 0.00																				0.02	0.00	
CP-C-Q-WEX S200 S203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) School 2014 2054 0.01 0.00																						
Display Disp																						
Opt-Out/Ex S300 S302 Monifor Power Management Enabling LCD School 2014 2054 0.01 0.00 0.00 0.00 20% 0.00 0.00 19% 0.09 0.26 0.07 1.2 1 0.17 0.00	Opt-Out/Ex	5300	5300 Base Monitor, LCD		2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A			N/A	0.02	0.00	0.00
Cipt-Out/Ex 5400 5401 Flags 5400 54																	-	-				
Opt-Out/Ex S400 S400 Base Copier School 2014 2054 2																		1				
Chi-Out/Ex S400 S402 Copie/ Power Management Enabling School 2014 2054 0.03 0.00 0																		N/A		0.04	0.00	
Opt-Out/Ex 5500 5500 Base Multifunction 5500 Base Multifunction Power Management Enabling																		0				
Opt-Out/Ex S500 S502 ENERGY STAR Multi-Function Device School 2014 2054 0.00 0.00 0.00 0.00 0.00 25% 0.01 0.01 0 0 0 7.12 0.00 0.0																	_	1 N/Δ		0.01	0.00	
Opt-Out/Ex 5501 Multifunction Power Management Enabling School 2014 2054 0.00 0.00 0.00 39% 0.00 0.00 32% 0.30 0.11 7 2 0.16 0.00 0.00 0.00 39% 0.00 0.00 32% 0.30 0.11 7 2 0.16 0.00																				0.01	0.00	
Opt-Out/Ex 5600 5602 ENERGY STAR Printer School 2014 2054 0.02 0.00 0.01 35% 0.00 0.00 35% 0.00 0.00 35% 0.00 0.00 357 0.00 <	Opt-Out/Ex		5501 Multifunction Power Management Enabling			2054	0.00	0.00	0.00	0.00	39%	0.00	0.00	32%	0.30	0.11		_	0.16			
Opt-Out/Ex 560 opt-Out/Ex 560 opt-Out/Ex 560 opt-Out/Ex 560 opt-Out/Ex 560 opt-Out/Ex 560 opt-Out/Ex 570 opt-Out																				0.03	0.00	
Opt-Out/Ex 5700 5700 Base Data Center/Server Room School 2014 2054 1.55 0.13 0.00 </td <td></td>																						
Opt-Out/Ex 5700 5702 Data Center Best Practices School 2014 2054 1.21 0.10 0.18 0.33 21% 0.02 0.00 0.00 0 0 45.77 0.18 Opt-Out/Ex 5700 5703 Data Center State of the Art practices School 2014 2054 1.15 0.10 0.07 0.40 26% 0.01 0.03 26% 0.00 0.00 0 0 25.8 0.07 Opt-Out/Ex 6000 6000 Base Water Heating School 2014 2054 0.51 0.04 0.00 <t< td=""><td>Opt-Out/Ex</td><td>5700</td><td>5700 Base Data Center/Server Room</td><td>School</td><td>2014</td><td>2054</td><td>1.55</td><td>0.13</td><td>0.00</td><td>0.00</td><td>0%</td><td>0.00</td><td>0.00</td><td>0%</td><td>N/A</td><td>N/A</td><td></td><td>N/A</td><td>N/A</td><td>1.55</td><td>0.13</td><td>0.00</td></t<>	Opt-Out/Ex	5700	5700 Base Data Center/Server Room	School	2014	2054	1.55	0.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A		N/A	N/A	1.55	0.13	0.00
Opt-Out/Ex 5700 5703 bate Center State of the Art practices School 2014 2054 1.15 0.10 0.07 0.40 26% 0.01 0.03 26% 0.00 0.00 0 0 23.58 0.07 0.07 Opt-Out/Ex 6000 6000 Base Water Heating School 2014 2054 0.54 0.04 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A N/A 0.04 0.00 0.00 0.00 0.00 0% 0.00																	-	-				
Opt-Out/Ex 6000 6000 Base Water Heating School 2014 2054 0.54 0.04 0.00																						
Opt-Out/Ex 6000 6007 Heat Trap School 2014 2054 0.51 0.04 0.03 5% 0.0 0.05 0.05 1 1 1.16 0.03 Opt-Out/Ex 6000 6007 High Efficiency Water Heater (electric) School 2014 2054 0.50 0.04 0.01 0.00 0.00 7% 0.10 0.06 1 1 0.61 0.00 Opt-Out/Ex 6000 6007 Heat Recovery Unit School 2014 2054 0.45 0.04 0.05 0.00 0.01 16% 0.10 0.06 1 1 0.61 0.05 0.00 Opt-Out/Ex 6000 6001 Demand controlled circulating systems School 2014 2054 0.45 0.04 0.05 0.00 0.01 16% 0.10 0.08 1 1 0.61 0.05 Opt-Out/Ex 6000 6001 Demand controlled circulating systems School 2014 2054 0.44 0.03 0.02 0.10						2054														0.54	0.04	
Opt-Out/Ex 6000 6006 Heat Recovery Unit School 2014 2054 0.45 0.04 0.05 0.09 16% 0.00 0.01 16% 0.10 0.08 1 1 0.57 0.00 Opt-Out/Ex 6000 6001 Demand controlled circulating systems School 2014 2054 0.44 0.03 0.02 0.10 19% 0.03 0.09 2 1 0.47 0.00			6007 Heat Trap														1	1				
Opt-Out/Ex 6000 6001 Demand controlled circulating systems School 2014 2054 0.44 0.03 0.02 0.10 19% 0.00 0.01 19% 0.13 0.09 2 1 0.47 0.00																	1	1				
		0000			20		0.10				1070				0.10		2					
	Opt-Out/Ex	6000	6004 Tankless Water Heater	School	2014	2054	0.40	0.03	0.03	0.14	25%	0.00	0.01	25%	0.17	0.11	2	1	0.38			0.00

DNV GL H-9 1/5/2015

APPENDIX H

Base Avoided Costs

Part				empt/Nonjurisdictional Existing SUPPLY ANALYSIS				Year	2014														SUPPLY
Part	١	/intage				Moseuro	Moscuro					Porcont			Porcont								
Second Column Col						Start	End				Savings	GWH		Savings	MW	Cost	Cost	Cost	Cost	Cost Test			
Second	-	- 3														4,,,,,,,,,,	4,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		\$/kW		GWH	MW	
Sept Continue Co	(Opt-Out/Ex	7000	7000 Base Refrigerated Vending Machines	School	2014	2054	0.12	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A		N/A	N/A	0.12	0.01	0.00
Column C																			0				
Control Cont																			1 N/A		0.00	0.00	
Geo-Carlon Total																					0.00	0.00	
Geology Teal																					0.34	0.03	
Second Property																					0.04	0.00	
Second S	(Opt-Out/Ex		7400 Base Steamer		2014			0.02	0.00	0.00	0%	0.00	0.00	0%		N/A	N/A		N/A	0.26		0.00
Second 1900																			1				
Second S																							
Control Cont	(Opt-Out/Ex			School			1.71		0.00	0.00	0%	0.00	0.00	0%								0.00
Che Code 100																							
Co-Co-Co-Co-Co-Co-Co-Co-Co-Co-Co-Co-Co-C																					16.35	2.49	
Geo. Cont.																							
Color Colo																			-				
Grid College 1930 1934 68th 64 1871 1832 183																			1				
Conclusion Con																			2				
December 132 133	(Opt-Out/Ex	1030	1035 LED Troffer (base 4L4'T8), 2020	Health	2020	2054	9.54	1.60	0.89	6.81	42%	0.14	0.89	36%	0.44	0.27	-	_	0.14			0.00
Pick 1752																					1.97	0.30	
																		1					
Col-Curie 110	(Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Health	2020	2054	1.60	0.25	0.13	0.37	19%	0.02	0.05	17%	0.10			1	0.61			0.00
Opt-Out-Fig 130 115 ED Troffe (hase 2LFT) (120 120 115																			1				
Dept-Duck 1300 1370 Congress personal, Left Fluorescent Fluoring, 2020 1201																			1				
Geno Confect 150 120 Lighting Cornol Turney (Base other Russersen finance) Health 2014																			2				
Composition																					0.53	0.08	
Cys Cys																							
Georgia Fig. Georgia Georgia																							
Opt-Out-E 1330 1332 LEDs [base incandescent flation 2020 2054 0.18 0.03 0.88 0.88 83% 0.13 0.18 0.07 0.01 0.0 0.4 24 0.00																							
Girch Court 14:30 14:30 East East																					1.07	0.16	
Opt-Our Variety Vari																					0.38	0.06	
General Number 1530 1532 EEDs (base inclinatescent A-line Stay) (2200 Health 2020 2054 0.07 0.01 0.02 0.01 0.05 0.00 0.00 0.07 0.00	(Opt-Out/Ex		1432 LEDs (base incandescent A-line 72W) 2020														0		3.58			
Cyb-OufEx 1830 1632 Base CPL 18W to screw-in replacement (2302 Cheb Mode) Code																					0.28	0.04	
Op-Op-Opt-Ex 1630 1631 LED activen in replacement (pisse cFL 18W) 2020 Health 2020 2054 0.01 0.02 20% 0.00 0.00 28% 0.13 1.13 1.4 0.43 1.1 0.02 0.00 Op-OutEx 1730 1731 LED sorters in replacement (base GFL 28W) 2020 Health 2020 2054 0.01 0.03 0.00 0.00 0.00 26% 0.10 0.1 1 1 0.5 0.00 0.00 Op-OutEx 1730 LT 200 Base GFL 28W 19 Core Health 2020 2054 0.00																		-			0.09	0.01	
Opt-OutEx 1730 1731 ED serven-in replacement (please CFL 23W) 2020 Health 2024 2054 0.08 0.01 0.03 0.03 2.08 0.00 0.00 2.08 0.01 0.10 1 1 0.88 0.00	(Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Health	2020	2054	0.06	0.01	0.02	0.02	28%	0.00	0.00	28%	0.13	0.13	1	1	0.43			0.00
Cyp-OutEx 1800 1800 BaseMetal Halide, 465W Health 2014 2054 0.00																		N/A	N/A		0.11	0.02	
Opt-OutEx 1850 1850 1850 Rase CFL Exit Sign Health 2014 2054 0.45 0.07 0.00																		1 N/A	1 N/A		0.00	0.00	
Opt-Ouffex 1900	(Opt-Out/Ex	1850	1850 Base CFL Exit Sign	Health	2014	2054	0.45	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A			0.00
OPI-CUIEK 1900 1910 19																							
Opt-Ou/WEX 1900 1902 LED Outdoor Area Lighting Health 2014 2054 0.87 0.01 0.94 0.99 5.3% 0.01 0.01 6.0% 0.18 2.0 17 0.29 0.00 0																					1.86	0.02	
Opt-Ou/Ex 2000 2000 Base Centrifugal Chiller, 0.58 kW/Non, 500 tons Health 2014 2054 29.68 16.40 27.8 27.8 9% 0.05																							
Opt-OurEx 2000 2010 Centrifugal Chiller ().51 kW/ton, 500 tons Health 2014 2054 29.84 16.40 27.8 27.8 9% 1.53 1.53 9% 0.05 0.05 0.0 0 2.18 2.78 2.78 0.00																							
Opt-Out/Ex 2000 2006 VSD for Chiller Pumps and Towers Health 2014 2054 29.77 16.38 0.07 2.85 9% 0.02 1.55 9% 0.05 0.05 0.05 0.05 0.07																					32.62	17.93	
Opt-Out/Ex 2000 2003 EMS - Chiller Health 2014 2054 26.85 15.97 2.82 5.77 18% 0.36 1.96 1.97 0.08 0.06 1 0 0.80 0.00																							
Opt-Out/Ex 2000 2012 Duct Testing/Sealing Health 2014 2054 21,75 13,16 5.10 10,87 33% 2,80 4.77 27% 0,25 0.15 0 0 0.40 0.00																							
Opt-Out/Ex 2000 2008 New Economizer - Chiller Health 2014 2054 19.29 12.84 2.46 13.34 41% 0.32 5.09 28% 0.19 0.16 2 0 0.28 0.00																							
Opt-Out/Ex 2000 2002 Window Film (Slandard) - Chiller Health 2014 2054 19.26 12.83 0.03 13.37 41% 0.02 5.10 28% 0.41 0.16 1 0 0.19 0.00																							
Opt-Out/Ex 2100 2011 Duct/Pipe Insulation - Chiller Health 2014 2054 18.99 12.68 0.22 13.64 42% 0.12 5.25 29% 4.17 0.22 8 1 0.00 Opt-Out/Ex 2100 2100 Base DX Packaged System, EER=10.3, 10 tons Health 2014 2054 32.62 17.93 0.00 0.00 0% 0.00 0.00 0% N/A			2000			2014	2054	19.26		0.03		41%	0.02	5.10	28%			1	0	0.19			0.00
Opt-Out/Ex 2100 2100 Base DX Packaged System, EER=10.3, 10 tons Health 2014 2054 32.62 17.93 0.00 0.00 0% 0.00 0% N/A																			0				
Opt-Out/Ex 2100 2102 DX Packaged System, EER=13.4, 10 tons Health 2014 2054 25.12 13.81 7.50 7.50 23% 4.12 4.12 23% 0.04 0.0 0.047 0.00 Opt-Out/Ex 2100 2108 Optimizer Controls - DX Health 2014 2054 24.16 13.75 0.46 7.96 24% 0.06 4.18 23% 0.10 0.04 1 0.047 0.00 Opt-Out/Ex 2100 2168 Prog. Thermostat - DX Health 2014 2054 24.15 13.68 0.51 8.47 26% 0.07 4.25 24% 0.13 0.05 1 0 0.47 0.00 Opt-Out/Ex 2100 2112 Aerosol Duct Sealing - DX Health 2014 2054 22.56 12.81 0.12 10.06 31% 0.07 5.12 29% 0.35 0.09 1 0 0.36 0.00 Opt-Out/Ex 2100 2115 Window Film (Standard) - DX Health																			N/A		32.62	17.93	
Opt-Out/Ex 2100 2169 Frog. Thermostat - DX Health 2014 2054 24.15 13.68 0.51 8.47 26% 0.07 4.25 24% 0.13 0.05 1 0 0.41 0.00 Opt-Out/Ex 2100 2112 Aerosol Duct Sealing - DX Health 2014 22.54 12.81 0.12 10.06 31% 0.07 5.12 29% 0.35 0.09 1 0 0.36 0.00 Opt-Out/Ex 2100 2115 Window Film (Standard) - DX Health 2014 2054 22.56 12.81 0.12 10.06 31% 0.07 5.12 29% 0.35 0.09 1 0 0.23 0.00 Opt-Out/Ex 2100 2110 Cod Roof - DX Health 2014 2054 22.24 12.63 0.25 10.33 31% 0.07 5.12 29% 0.35 0.09 1 0 0.23 0.00 Opt-Out/Ex 2100 2114 Duct/Pipe Insulation - DX Health <td>(</td> <td>Opt-Out/Ex</td> <td>2100</td> <td>2102 DX Packaged System, EER=13.4, 10 tons</td> <td>Health</td> <td>2014</td> <td>2054</td> <td>25.12</td> <td>13.81</td> <td>7.50</td> <td>7.50</td> <td>23%</td> <td>4.12</td> <td>4.12</td> <td>23%</td> <td>0.04</td> <td>0.04</td> <td></td> <td></td> <td>2.29</td> <td></td> <td></td> <td>7.50</td>	(Opt-Out/Ex	2100	2102 DX Packaged System, EER=13.4, 10 tons	Health	2014	2054	25.12	13.81	7.50	7.50	23%	4.12	4.12	23%	0.04	0.04			2.29			7.50
Opt-Out/Ex 2100 2112 Aerosol Duct Sealing - DX Health 2014 2054 22.68 12.87 1.47 9.94 30% 0.81 5.06 28% 0.27 0.08 0 0.36 0.00 Opt-Out/Ex 2100 2115 Window Film (Standard) - DX Health 2014 2054 22.68 12.87 0.07 10.13 31% 0.07 5.12 29% 0.35 0.09 1 0 0.23 0.00 Opt-Out/Ex 2100 2107 Cool Roof - DX Health 2014 2054 22.24 12.63 0.05 10.38 32% 0.14 5.30 30% 3.56 0.9 1 0 0.03 0.00 Opt-Out/Ex 2100 2114 Duct/Pipe Insulation - DX Health 2014 2054 22.24 12.63 0.05 10.38 32% 0.14 5.30 30% 3.58 0.17 6 0 0.02 0.00 Opt-Out/Ex 2100 2105 Economizer - DX Health																		1	0				
Opt-Out/Ex 2100 2115 Window Film (Standard) - DX Health 2014 2054 22.56 12.81 0.12 10.06 31% 0.07 5.12 29% 0.35 0.09 1 0 0.03 0.00 Opt-Out/Ex 2100 2117 Cool Roof - DX Health 2014 20.54 22.94 12.77 0.07 10.13 31% 0.04 5.16 29% 0.91 0.09 2 0.09 0.00 Opt-Out/Ex 2100 2114 Duct/Pipe Insulation - DX Health 2014 2054 22.24 12.63 0.05 10.38 32% 0.14 5.30 30% 3.56 0.17 6 0 0.02 0.00 Opt-Out/Ex 2100 2111 Economizer Repair - DX Health 2014 2054 22.24 12.63 0.00 10.38 32% 0.00 5.30 30% 3.58 0.18 38,20 0 0.00 0.00 Opt-Out/Ex 2100 2115 Economizer - DX Health <td></td> <td>1 0</td> <td>0</td> <td></td> <td></td> <td></td> <td></td>																		1 0	0				
Opt-Out/Ex 2100 2107 Cool Roof - DX Health 2014 2054 22.49 12.77 0.07 10.13 31% 0.04 5.16 29% 0.91 0.09 2 0 0.09 0.00 Opt-Out/Ex 2100 2114 Duct/Pipe Insulation - DX Health 2014 2054 22.24 12.63 0.02 10.38 32% 0.14 5.30 30% 3.56 0.17 6 0 0.02 0.00 Opt-Out/Ex 2100 2109 Economizer - DX Health 2014 2054 22.24 12.63 0.00 10.38 32% 0.0 5.30 30% 318.847 0.18 38,820 0 0.00 0.00 Opt-Out/Ex 2100 2109 Economizer - DX Health 2014 2054 22.24 12.63 0.00 10.38 32% 0.00 5.30 30% 3749.44 0.22 291,636 0 0.00 0.00	(Opt-Out/Ex	2100	2115 Window Film (Standard) - DX	Health	2014	2054	22.56	12.81	0.12	10.06	31%	0.07	5.12	29%	0.35	0.09	1	Ō	0.23			0.00
Opt-Out/Ex 2100 2111 Economizer Repair - DX Health 2014 2054 22.24 12.63 0.00 10.38 32% 0.00 5.30 30% 32188.47 0.18 38,820 0 0.00 0.00 Opt-Out/Ex 2100 2109 Economizer - DX Health 2014 2054 22.24 12.63 0.00 10.38 32% 0.00 5.30 30% 37474.44 0.22 291,636 0 0.00 0.00	(Opt-Out/Ex		2107 Cool Roof - DX														_	-				
Opt-Out/Ex 2100 2109 Economizer - DX Health 2014 2054 22.24 12.63 0.00 10.38 32% 0.00 5.30 30% 37474.44 0.22 291,636 0 0.00 0.00 0.00																							
Opt-Out/Ex 2200 2200 Base Heat Pump (13 SEER, 7.7 HSPF) Health 2014 2054 18.27 10.04 0.00 0.00 0% 0.00 0% N/A N/A N/A N/A N/A 18.27 10.04 0.00																							
	(Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Health	2014	2054	18.27	10.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.27	10.04	0.00

APPENDIX H

Base Avoided Costs

		/Exempt/Nonjurisdictional Existing				V	2014														SUPPLY
Vintage	ST ADDITIV	IVE SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
_				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource	_	_	
Samt		Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH
Opt-Out/Ex		2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	2014	2054	16.01	8.80	2.26	2.26	12%	1.24	1.24	12%	0.03	0.03	0	0	2.68			2.26
Opt-Out/Ex	2300 3000	2300 Base PTAC, EER=8.3, 1 ton	Health Health	2014 2014	2054	18.27 6.05	10.04	0.00	0.00	0% 0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A	N/A	N/A	18.27	10.04	0.00
Opt-Out/Ex Opt-Out/Ex		3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3002 Variable Speed Drive Control, 5 HP	Health	2014	2054 2054	4.15	1.23 1.14	1.90	0.00 1.90	31%	0.00	0.00	0% 7%	0.02	0.02	N/A 0	N/A 0	N/A 2.94	6.05	1.23	0.00 1.90
Opt-Out/Ex		3001 Fan Motor, 5hp, 1800rpm, 89.5%	Health	2014	2054	4.08	1.12	0.07	1.97	33%	0.01	0.11	9%	0.04	0.02	Ö	Ö	1.95			0.07
Opt-Out/Ex			Health	2014	2054	3.69	0.96	0.39	2.36	39%	0.16	0.27	22%	1.21	0.22	3	2	0.07			0.00
Opt-Out/Ex Opt-Out/Ex	3100 3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3102 Variable Speed Drive Control, 15 HP	Health Health	2014 2014	2054 2054	21.03 14.44	4.27 3.95	0.00 6.59	0.00 6.59	0% 31%	0.00 0.32	0.00 0.32	0% 7%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.50	21.03	4.27	0.00 6.59
Opt-Out/Ex	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Health	2014	2054	14.41	3.94	0.03	6.63	32%	0.01	0.32	8%	0.01	0.01	0	0	3.44			0.03
Opt-Out/Ex	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Health	2014	2054	12.31	3.56	2.10	8.72	41%	0.38	0.71	17%	0.04	0.01	0	0	1.86			2.10
Opt-Out/Ex	3100	3105 Energy Recovery Ventilation (ERV)	Health	2014	2054	11.51	3.23	0.80	9.52	45%	0.33	1.04	24%	0.38	0.04	1	0	0.25			0.00
Opt-Out/Ex Opt-Out/Ex	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Health Health	2014 2014	2054 2054	10.41 22.35	2.78 4.54	1.10	10.62	50% 0%	0.46	1.49 0.00	35% 0%	1.49 N/A	0.19 N/A	4 N/A	1 N/A	0.06 N/A	22.35	4.54	0.00
Opt-Out/Ex		3204 Demand Controlled Ventilation	Health	2014	2054	20.22	3.65	2.13	2.13	10%	0.89	0.89	20%	0.82	0.82	2	2	0.10	22.00		0.00
Opt-Out/Ex		4000 Base Built-Up Refrigeration System	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4100 Base Self-Contained Refrigeration 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Health Health	2014 2014	2054 2054	3.02 2.98	0.44 0.43	0.00 0.05	0.00 0.05	0% 2%	0.00 0.01	0.00 0.01	0% 2%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.59	3.02	0.44	0.00 0.05
Opt-Out/Ex		4108 Energy-Star Refrigerator, glass door	Health	2014	2054	2.90	0.43	0.05	0.05	4%	0.01	0.01	4%	0.01	0.01	0	0	2.53			0.05
Opt-Out/Ex	4100		Health	2014	2054	2.80	0.41	0.10	0.22	7%	0.01	0.03	7%	0.02	0.02	ō	Ō	2.42			0.10
Opt-Out/Ex		4110 Energy Star Ice Machines	Health	2014	2054	2.68	0.39	0.12	0.34	11%	0.02	0.05	11%	0.07	0.04	0	0	0.86			0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4112 Reach-in unit occupancy sensors 4105 Bi-level LED Case Lighting (self-contained units) 2014	Health Health	2014 2014	2054 2054	2.68 2.67	0.39 0.39	0.00 0.01	0.34 0.35	11% 12%	0.00	0.05 0.05	11% 12%	0.41 0.47	0.04 0.05	3	0	0.14 0.11			0.00
Opt-Out/Ex	5000	5000 Base Desktop PC	Health	2014	2054	0.44	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.44	0.06	0.00
Opt-Out/Ex		5001 PC Network Power Management Enabling	Health	2014	2054	0.24	0.05	0.21	0.21	46%	0.01	0.01	23%	0.03	0.03	0	0	1.79			0.21
Opt-Out/Ex		5002 Energy Star or Better PC	Health	2014	2054	0.16	0.04	0.08	0.28	63%	0.01	0.03	40%	0.06	0.03	0	0	0.86	0.05	0.04	0.00
Opt-Out/Ex Opt-Out/Ex		5100 Base Laptop PC 5102 Energy Star or Better Laptop	Health Health	2014 2014	2054 2054	0.05 0.04	0.01 0.01	0.00 0.01	0.00 0.01	0% 19%	0.00	0.00	0% 19%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.42	0.05	0.01	0.00
Opt-Out/Ex			Health	2014	2054	0.04	0.01	0.00	0.01	21%	0.00	0.00	21%	2.48	0.22	17	2	0.02			0.00
Opt-Out/Ex		5200 Base Monitor, CRT	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex		5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Health Health	2014 2014	2054 2054	0.12	0.02	0.00	0.00	0% 20%	0.00	0.00	0% 20%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.77	0.12	0.02	0.00
Opt-Out/Ex			Health	2014	2054	0.10	0.01	0.02	0.02	24%	0.00	0.00	20%	0.02	0.02	2	0	0.28			0.02
Opt-Out/Ex		5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Health	2014	2054	0.09	0.01	0.01	0.04	30%	0.00	0.00	23%	0.46	0.13	13	1	0.09			0.00
Opt-Out/Ex			Health	2014	2054	0.22	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.22	0.03	0.00
Opt-Out/Ex Opt-Out/Ex		5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	Health Health	2014 2014	2054 2054	0.18 0.17	0.03	0.04 0.01	0.04 0.05	17% 22%	0.01 0.00	0.01 0.01	17% 19%	0.00 0.20	0.00 0.05	0 3	0	13.66 0.24			0.04 0.00
Opt-Out/Ex	5500	5500 Base Multifunction	Health	2014	2054	0.05	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.01	0.00
Opt-Out/Ex	5500	5502 ENERGY STAR Multi-Function Device	Health	2014	2054	0.03	0.00	0.01	0.01	25%	0.00	0.00	25%	0.01	0.01	0	0	4.05			0.01
Opt-Out/Ex Opt-Out/Ex		5501 Multifunction Power Management Enabling 5600 Base Printer	Health Health	2014 2014	2054 2054	0.03	0.00 0.02	0.00	0.02	36% 0%	0.00	0.00	31% 0%	0.48 N/A	0.15 N/A	7 N/A	1 N/A	0.10 N/A	0.18	0.02	0.00
Opt-Out/Ex			Health	2014	2054	0.10	0.02	0.06	0.06	35%	0.00	0.00	35%	0.00	0.00	0	0	18.62	0.10	0.02	0.06
Opt-Out/Ex	5600	5601 Printer Power Management Enabling	Health	2014	2054	0.10	0.02	0.02	0.08	44%	0.00	0.01	40%	0.10	0.02	1	0	0.45			0.00
Opt-Out/Ex			Health	2014	2054	7.01	1.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.01	1.00	0.00
Opt-Out/Ex Opt-Out/Ex	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Health Health	2014 2014	2054 2054	6.31 5.50	0.90 0.78	0.70 0.80	0.70 1.50	10% 21%	0.10 0.11	0.10 0.21	10% 21%	0.00	0.00	0	0	64.41 26.22			0.70
Opt-Out/Ex	5700		Health	2014	2054	5.19	0.74	0.31	1.81	26%	0.04	0.26	26%	0.00	0.00	0	0	13.60			0.31
Opt-Out/Ex			Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex		7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Health Health	2014 2014	2054 2054	0.74	0.10 0.10	0.00 0.12	0.00 0.12	0% 16%	0.00 0.01	0.00 0.01	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.83	0.74	0.10	0.00 0.12
Opt-Out/Ex			Health	2014	2054	0.56	0.09	0.12	0.12	25%	0.00	0.01	12%	0.05	0.03	1	0	1.00			0.00
Opt-Out/Ex		7100 Base Non-Refrigerated Vending Machines	Health	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex	7100		Health	2014 2014	2054 2054	0.01	0.00	0.01	0.01	47%	0.00	0.00	23%	0.43 N/A	0.43 N/A	6 N/A	6 N/A	0.11	0.20	0.07	0.00
Opt-Out/Ex Opt-Out/Ex	7200 7300	7200 Base Oven 7300 Base Fryer	Health Health	2014	2054	0.39	0.07 0.13	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.39 0.66	0.07	0.00
Opt-Out/Ex	7300	7301 Efficient Fryer	Health	2014	2054	0.62	0.12	0.04	0.04	6%	0.01	0.01	6%	31.87	31.87	167	167	0.00			0.00
Opt-Out/Ex			Health	2014	2054	0.47	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.47	0.09	0.00
Opt-Out/Ex Opt-Out/Ex		8000 Base Heating, Heat Pump (7.7 HSPF) 8100 Base Heating, Other Electric	Health Health	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00
Opt-Out/Ex	9500	9500 Base Miscellaneous	Health	2014	2054	50.19	6.99	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	50.19	6.99	0.00
Opt-Out/Ex		9501 Xmisc	Health	2014	2054	50.19	6.99	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00
Opt-Out/Ex		1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Lodging	2020	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex Opt-Out/Ex		1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Lodging Lodging	2020 2020	2054 2054	0.02	0.00	0.00	0.00	10% 17%	0.00	0.00	10% 17%	0.02	0.02 0.05	0 1	0	2.54 0.67			0.00
Opt-Out/Ex		1036 Lighting Control Tuneup (base 4L4'T8), 2020	Lodging	2020	2054	0.02	0.00	0.00	0.00	17%	0.00	0.00	17%	0.04	0.05	1	0	1.07			0.00
Opt-Out/Ex	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Lodging	2020	2054	0.02	0.00	0.00	0.01	23%	0.00	0.00	22%	0.07	0.05	1	0	0.90			0.00
Opt-Out/Ex	1030 1030	1034 ROB 4L4' LED Tube, 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Lodging	2020 2020	2054 2054	0.02	0.00	0.00	0.01 0.01	36% 38%	0.00	0.00	34% 35%	0.33 0.17	0.15 0.15	2 5	1	0.21 0.29			0.00
Opt-Out/Ex Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4 Fluorescent Fixtures, 2020 1035 LED Troffer (base 4L4'T8), 2020	Lodging Lodging	2020	2054	0.02	0.00	0.00	0.01	38% 43%	0.00	0.00	35% 40%	0.17	0.15	2	1	0.29			0.00
Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Lodging	2020	2054	0.11	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.01	0.00
Opt-Out/Ex			Lodging	2020	2054	0.09	0.01	0.01	0.01	10%	0.00	0.00	10%	0.03	0.03	0	0	2.00			0.01
Opt-Out/Ex	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Lodging Lodging	2020 2020	2054 2054	0.08	0.01	0.01	0.02	22% 22%	0.00	0.00	22% 22%	0.06	0.05	0	0	0.96			0.00
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Lodging	2020	2054	0.08	0.01	0.00	0.02	28%	0.00	0.00	27%	0.10	0.06	1	0	0.72			0.00
Opt-Out/Ex	1130		Lodging	2020	2054	0.07	0.01	0.00	0.03	32%	0.00	0.00	30%	0.29	0.08	2	1	0.25			0.00

APPENDIX H

Base Avoided Costs

		mpt/Nonjurisdictional Existing				.,															OLIDBU V
DSM ASSY Vintage	ST ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
viiitago				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource			
Samt		asure mber Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base	Economic
Opt-Out/Ex	1130	1135 LED Troffer (base 2L4'T8), 2020	Lodging	2020	2054	0.07	0.01	0.01	0.04	37%	0.00	0.01	36%	0.37	0.13	3	1	0.19	GWH	141.44	0.00
Opt-Out/Ex	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Lodging	2020	2054	0.06	0.01	0.00	0.04	39%	0.00	0.01	36%	0.31	0.14	9	1	0.16			0.00
Opt-Out/Ex		1200 Base Other Fluorescent Fixture	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1200	1203 Lighting Control Tuneup (base other fluorescent fixture) 1201 ROB High Performance T8 (base other fluorescent)	Lodging Lodging	2014 2014	2054 2054	0.00	0.00	0.00	0.00	3% 13%	0.00	0.00	1% 11%	0.02 0.10	0.02 0.08	0	0	2.44 0.61			0.00
Opt-Out/Ex		1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Lodging	2014	2054	0.00	0.00	0.00	0.00	30%	0.00	0.00	27%	0.23	0.16	2	1	0.26			0.00
Opt-Out/Ex	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Lodging	2014	2054	0.00	0.00	0.00	0.00	35%	0.00	0.00	28%	0.21	0.17	6	.1.	0.23			0.00
Opt-Out/Ex Opt-Out/Ex		1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Lodging Lodging	2020 2020	2054 2054	0.16	0.02	0.00 0.13	0.00 0.13	0% 81%	0.00 0.02	0.00 0.02	0% 81%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.93	0.16	0.02	0.00 0.13
Opt-Out/Ex		1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Lodging	2020	2054	0.06	0.01	0.00	0.00	0%	0.02	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	Lodging	2020	2054	0.01	0.00	0.05	0.05	79%	0.01	0.01	79%	0.01	0.01	0	0	6.68			0.05
Opt-Out/Ex Opt-Out/Ex		1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Lodging	2020 2020	2054 2054	0.04	0.01 0.00	0.00	0.00	0% 71%	0.00	0.00	0% 71%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.92	0.04	0.01	0.00 0.03
Opt-Out/Ex		1630 Base CFL 18W to screw-in replacement 2020	Lodging Lodging	2020	2054	0.01	0.00	0.03	0.03	0%	0.00	0.00	0%	0.01 N/A	0.01 N/A	N/A	N/A	4.92 N/A	0.03	0.00	0.03
Opt-Out/Ex		1631 LED screw-in replacement (base CFL 18W) 2020	Lodging	2020	2054	0.02	0.00	0.01	0.01	28%	0.00	0.00	28%	0.09	0.09	1	1	0.72			0.00
Opt-Out/Ex		1730 Base CFL 23W to screw-in replacement 2020	Lodging	2020	2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00
Opt-Out/Ex Opt-Out/Ex		1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Lodging Lodging	2020 2014	2054 2054	0.03	0.00 0.01	0.01	0.01 0.00	26% 0%	0.00	0.00	26% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	0.95 N/A	0.08	0.01	0.00
Opt-Out/Ex		1801 T5 (240W) (base metal halide)	Lodging	2014	2054	0.06	0.01	0.03	0.00	34%	0.00	0.00	34%	0.02	0.02	0	0	3.57	0.00	0.01	0.00
Opt-Out/Ex	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Lodging	2014	2054	0.05	0.01	0.00	0.03	39%	0.00	0.00	38%	0.05	0.02	0	0	1.25			0.00
Opt-Out/Ex	1800 1850	1806 Occupancy Sensor, High Bay T5	Lodging	2014	2054 2054	0.05	0.01	0.00	0.03	41%	0.00	0.00	38%	0.05 N/A	0.02 N/A	2	0	0.94	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex		1850 Base CFL Exit Sign 1851 LED Exit Sign	Lodging Lodging	2014 2014	2054	0.02	0.00	0.00	0.00	0% 44%	0.00	0.00	0% 44%	0.03	0.03	N/A	N/A 0	N/A 1.81	0.02	0.00	0.00 0.01
Opt-Out/Ex		1900 Base Outdoor High Pressure Sodium 250W Lamp	Lodging	2014	2054	0.12	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.00	0.00
Opt-Out/Ex		1901 Outdoor Lighting Controls (Photocell/Timeclock)	Lodging	2014	2054	0.10	0.00	0.02	0.02	20%	0.00	0.00	66%	0.06	0.06	2	2	1.10			0.02
Opt-Out/Ex Opt-Out/Ex		1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Lodging	2014 2014	2054 2054	0.05	0.00	0.05	0.08	61% 73%	0.00	0.00	108% 118%	0.11 0.74	0.10	13 95	6 14	0.49 0.07			0.00
Opt-Out/Ex		2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Lodging Lodging	2014	2054	0.03	0.00	0.01	0.09	0%	0.00	0.00	0%	0.74 N/A	0.20 N/A	N/A	N/A	N/A	0.43	0.26	0.00
Opt-Out/Ex		2002 Window Film (Standard) - Chiller	Lodging	2014	2054	0.41	0.25	0.02	0.02	4%	0.01	0.01	4%	0.03	0.03	0	0	2.71			0.02
Opt-Out/Ex		2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Lodging	2014	2054	0.37	0.23	0.03	0.05	12%	0.02	0.03	12%	0.05	0.04	0	0	2.05			0.03
Opt-Out/Ex Opt-Out/Ex		2013 High Efficiency Chiller Motors 2006 VSD for Chiller Pumps and Towers	Lodging Lodging	2014 2014	2054 2054	0.37	0.23 0.23	0.00	0.05 0.05	12% 12%	0.00	0.03	12% 12%	0.08	0.04 0.05	0	0	1.35 1.20			0.00
Opt-Out/Ex		2008 New Economizer - Chiller	Lodging	2014	2054	0.24	0.21	0.14	0.19	44%	0.02	0.05	20%	0.06	0.06	0	0	0.89			0.00
Opt-Out/Ex		2003 EMS - Chiller	Lodging	2014	2054	0.22	0.20	0.02	0.21	49%	0.00	0.05	21%	0.13	0.06	1	0	0.47			0.00
Opt-Out/Ex Opt-Out/Ex		2012 Duct Testing/Sealing 2004 Cool Roof - Chiller	Lodging Lodging	2014 2014	2054 2054	0.18 0.17	0.18 0.18	0.04	0.25 0.25	59% 59%	0.02 0.00	0.08 0.08	30% 30%	0.42 1.89	0.12	1	0	0.24 0.04			0.00
Opt-Out/Ex		2011 Duct/Pine Insulation - Chiller	Lodging	2014	2054	0.17	0.18	0.00	0.25	59%	0.00	0.08	31%	4.50	0.13	7	0	0.04			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Lodging	2014	2054	1.09	0.65	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.09	0.65	0.00
Opt-Out/Ex		2115 Window Film (Standard) - DX	Lodging	2014	2054	1.03	0.62	0.06	0.06	5%	0.03	0.03	5%	0.03	0.03	0	0	2.65			0.06
Opt-Out/Ex Opt-Out/Ex	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2108 Optimize Controls - DX	Lodging Lodging	2014 2014	2054 2054	0.79 0.78	0.48 0.48	0.24 0.01	0.29 0.31	27% 28%	0.14 0.00	0.18 0.18	27% 27%	0.05 0.08	0.04 0.04	0	0	2.12 0.59			0.24
Opt-Out/Ex		2106 Prog. Thermostat - DX	Lodging	2014	2054	0.76	0.47	0.02	0.33	30%	0.00	0.18	28%	0.14	0.05	1	0	0.36			0.00
Opt-Out/Ex		2112 Aerosol Duct Sealing - DX	Lodging	2014	2054	0.71	0.44	0.05	0.38	35%	0.03	0.21	32%	0.31	0.08	1	0	0.33			0.00
Opt-Out/Ex Opt-Out/Ex		2111 Economizer Repair - DX 2107 Cool Roof - DX	Lodging Lodging	2014 2014	2054 2054	0.71 0.70	0.44 0.44	0.00	0.38 0.38	35% 35%	0.00	0.21 0.21	32% 33%	0.88 1.20	0.09 0.09	1 2	0	0.09 0.07			0.00
Opt-Out/Ex		2109 Economizer - DX	Lodging	2014	2054	0.69	0.44	0.00	0.39	36%	0.00	0.21	33%	1.04	0.03	7	0	0.05			0.00
Opt-Out/Ex	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Lodging	2014	2054	0.69	0.44	0.00	0.39	36%	0.00	0.21	33%	1.75	0.12	12	0	0.03			0.00
Opt-Out/Ex		2114 Duct/Pipe Insulation - DX	Lodging	2014	2054	0.69	0.43	0.01	0.40	37%	0.00	0.22	34%	2.93	0.17	5	0	0.03	0.04	0.54	0.00
Opt-Out/Ex Opt-Out/Ex		2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging Lodging	2014 2014	2054 2054	0.84	0.51 0.44	0.00 0.10	0.00 0.10	0% 12%	0.00 0.06	0.00	0% 12%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.65	0.84	0.51	0.00 0.10
Opt-Out/Ex	2300	2300 Base PTAC, EER=8.3, 1 ton	Lodging	2014	2054	0.18	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.18	0.11	0.00
Opt-Out/Ex		2301 HE PTAC, EER=9.6, 1 ton	Lodging	2014	2054	0.15	0.09	0.02	0.02	14%	0.01	0.01	14%	0.08	0.08	0	0	1.24			0.02
Opt-Out/Ex Opt-Out/Ex	2300 3000	2302 Occupancy Sensor (hotels) 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Lodging Lodging	2014 2014	2054 2054	0.13 0.71	0.07 0.15	0.02	0.05 0.00	26% 0%	0.02	0.03	30% 0%	0.26 N/A	0.16 N/A	0 N/A	0 N/A	0.36 N/A	0.71	0.15	0.00
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Lodging	2014	2054	0.70	0.15	0.00	0.00	2%	0.00	0.00	2%	0.03	0.03	0	0	2.37	0.71	0.13	0.01
Opt-Out/Ex		3003 Demand Controlled Ventilation	Lodging	2014	2054	0.60	0.11	0.10	0.11	15%	0.04	0.04	30%	0.97	0.86	2	2	0.09			0.00
Opt-Out/Ex		3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Lodging	2014 2014	2054	0.00 0.12	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A	N/A N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex		3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	Lodging Lodging	2014	2054 2054	0.12	0.03	0.00	0.00	0% 10%	0.00	0.00	0% 3%	0.02	0.02	N/A 0	0	N/A 2.00	0.12	0.03	0.00
Opt-Out/Ex		3204 Demand Controlled Ventilation	Lodging	2014	2054	0.09	0.02	0.02	0.03	23%	0.01	0.01	28%	1.06	0.59	2	2	0.08			0.00
Opt-Out/Ex		4000 Base Built-Up Refrigeration System	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Lodging	2014 2014	2054 2054	0.40	0.06 0.06	0.00 0.02	0.00 0.02	0% 4%	0.00	0.00	0% 4%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 69.59	0.40	0.06	0.00
Opt-Out/Ex		4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Lodging Lodging	2014	2054	0.38	0.06	0.02	0.02	6%	0.00	0.00	6%	0.00	0.00	0	0	26.70			0.02
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door	Lodging	2014	2054	0.37	0.05	0.01	0.03	7%	0.00	0.00	7%	0.00	0.00	0	0	19.92			0.01
Opt-Out/Ex		4107 Energy-Star Freezer, solid door	Lodging	2014	2054	0.37	0.05	0.00	0.03	8%	0.00	0.00	8%	0.01	0.00	0	0	7.93 6.30			0.00
Opt-Out/Ex Opt-Out/Ex		4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Lodging Lodging	2014 2014	2054 2054	0.37 0.37	0.05 0.05	0.00	0.03 0.04	8% 9%	0.00	0.00 0.01	8% 9%	0.01 0.02	0.00	0	0	6.30 2.34			0.00
Opt-Out/Ex		4105 Bi-level LED Case Lighting (self-contained units) 2014	Lodging	2014	2054	0.37	0.05	0.00	0.04	9%	0.00	0.01	9%	0.33	0.00	2	0	0.17			0.00
Opt-Out/Ex		4101 Strip curtains for walk-ins (self-contained)	Lodging	2014	2054	0.36	0.05	0.00	0.04	10%	0.00	0.01	10%	0.35	0.03	2	0	0.14			0.00
Opt-Out/Ex Opt-Out/Ex		5000 Base Desktop PC 5002 Energy Star or Better PC	Lodging Lodging	2014 2014	2054 2054	0.03	0.00	0.00 0.01	0.00 0.01	0% 21%	0.00	0.00	0% 21%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 3.72	0.03	0.00	0.00 0.01
Opt-Out/Ex		5002 Energy Star of Better PC 5001 PC Network Power Management Enabling	Lodging	2014	2054	0.02	0.00	0.01	0.01	58%	0.00	0.00	39%	0.01	0.01	0	0	2.85			0.01
Opt-Out/Ex		5100 Base Laptop PC	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00

DNV GL H-12 1/5/2015

APPENDIX H

Base Avoided Costs

The column Part			empt/Nonjurisdictional Existing				Veer	2014														SUPPLY
Part		SI ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
	_														Energy	Energy	Capacity	Capacity				
100 100																						
Column C	9														4,,,,,,,	4,		4,		OWN		
Column C			5101 Laptop Network Power Management Enabling	Lodging									0.00									
Supplied Supplied																				0.01	0.00	
Second Control Contr																						
Property Property			5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)														1					
Second		0000	5300 Base Monitor, LCD																	0.01	0.00	
Second S																	0					
Second S																	6	1				
Selection Sele		5400	5400 Base Copier		2014		0.01		0.00								N/A	N/A		0.01	0.00	0.00
Second																	0					
Second S																	1 N/A			0.00	0.00	
Second S																				0.00	0.00	
0.00-clusts	Opt-Out/Ex							0.00		0.00			0.00	32%								
Conclusion Con																				0.00	0.00	
Column C																	0					
Column C																	N/A			0.11	0.02	
Cylinder STO STO Declared state of the Art paralles Ladying 2714 3054 0.08 0.01 0.01 0.01 0.01 0.01 0.01 0.00	Opt-Out/Ex			Lodging																		
Company Comp																						
Gir-Out-Fig 9010 907 Feet Trap																				0.18	0.02	
Configuration Configuratio																				0.10	0.02	
Conclust Solid Conclust Solid Conclust Solid Conclust Solid Conclust Conclusion Conclus																	0	-				
Concess Conc																						
Conclusion Con																	-	-				
Cybo																	-	-				
Color Colo																	1	-				
Cybour C																				0.04	0.01	
Cho-Ou-Net 7:00 7:00 Save Non-Redrigements Venering Matchines Lodging 2:14 2:054 0.00 0.0																	1					
Composition	Opt-Out/Ex	7100			2014	2054	0.00	0.00	0.00	0.00	0%	0.00			N/A	N/A	N/A	N/A		0.00	0.00	0.00
Cyb-Ou-Fix 730 730 Base Flyer 200 Cyb-Ou-Fix 740 740 Base Flyer 2014 2054																	-	-				
Cyb-Ou-Fix 1400 7400 8aes Biseamer Loging 2014 2054 2054 0.07 0.00																						
Cyb-Ou-Fix 500 800 Heat Pump Dygraysis (15 SEER, 8 2 HSFF) Loging 2014 2054 0.07 0.00 0																						
Oph-Out-Ex 9100 Sept Belearing, Other Electric Lodgring 2014 2054 0.06 0.07 0.00 0.00 0.00 0.00 0.00 0.00				Lodging																0.07	0.00	
Composition																				0.00	0.00	
Cycloudies Series Cycloudies Series Cycloudies Cycloudies																						
Op-OutFix 1030 1038 Lighting Control Tumerup (base 4L4TB), 2020 Data Centers 2020 2054 17.71 3.09 0.05 0.05 0.06 0.00 0.00 0.00 0.00 0.01 0.01 0.0 0.0 3.66 1.31 1.31																				0.70	0.10	
Op-OutFix 1030 1038 High Performance Lighting RR = 25% Savings (base 4L4TB), 2020 2054 16.40 2.90 1.31 1.38 8% 0.18 0.19 6% 0.02 0.02 0.0 0. 3.66 1.31 1.67 0.00 0.	Opt-Out/Ex																			17.77	3.09	
Op-Op-Op-Op-Op-Op-Op-Op-Op-Op-Op-Op-Op-O																	-					
Op-Courlet 1030 1032 ROB 4.4.1 Low Wast High Performance T8 (75 W), 2020 Data Centers 2020 2054 13.37 2.37 1.36 4.40 2.5% 0.24 0.72 2.3% 0.08 0.04 0 0 0.74 0.00																	-	-				
Oph-OutFex 1030 1034 ROB 4Lf \(\text{LET Tube} \) 2020 2024 0.33 1.98 1	Opt-Out/Ex	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020		2020	2054	13.37	2.37	1.36	4.40	25%	0.24	0.72	23%	0.08	0.04			0.74			0.00
Op-Cup Cup C																		0				
Opt-Outlex 1130 1130 Base Fluorescent Fixture, 214T8, 1EB, 2020 Data Centers 2020 2054 0.30 0.05 0.00																	_	1				
Opt-Oul/Ex 1130 1136 Lighting Control Tuneup (base 2L4TB), 2020 Data Centers 2020 2054 0.30 0.05 0.00 0.00 0.9% 0.00 0.00 0.9% 0.02 0.02 0.02 0.03 0.05 0.00																				0.30	0.05	
Opt-Out/Ex 1130 1131 ROB 2L4* High Performance T8 (88 W), 2020 Data Centers 2020 2054 0.25 0.04 0.03 0.05 17% 0.01 0.01 16% 0.03 0.03 0.0 0.1.66 0.05	Opt-Out/Ex		1136 Lighting Control Tuneup (base 2L4'T8), 2020		2020		0.30	0.05		0.00	0%		0.00				-	0	2.33			
Opt-Out/Ex 1130 1132 ROB 2L4' LeD Tube, 2020 Data Centers 2020 2054 0.22 0.04 0.03 0.08 28% 0.01 0.01 28% 0.07 0.05 0 0.80 0.00																	-					
Opt-Out/Ex 1130 1134 RDB 2L4′ LED Tuble, 2020 Data Centers 2020 2054 0.19 0.04 0.02 0.11 37% 0.00 0.02 37% 0.07 2 0 0.25 Opt-Out/Ex 1130 1135 LED Troffer (base 2L4′TB), 2020 Data Centers 2020 2054 0.19 0.04 0.02 0.11 37% 0.00 0.02 37% 0.37 0.12 2 1 0.18 Opt-Out/Ex 1130 1135 LED Troffer (base 2L4′TB), 2020 Data Centers 2020 2054 0.17 0.03 0.02 0.13 42% 0.00 0.02 37% 0.37 0.12 2 1 0.18 Opt-Out/Ex 1200 1200 Base Other Fluorescent Fixture Data Centers 2014 2054 0.65 0.11 0.00 0.00 0.00 0.00 0.00 0.00 0.0																	-	-				
Opt-Ou/Ex 1130 Opt-Ou/Ex 1130 Occupancy Sensor, 214' Fluorescent Fixtures, 2020 Data Centers 2020 2054 0.19 0.04 0.02 0.11 37% 0.00 0.02 31% 0.16 0.08 3 1 0.31 0.00 Opt-Ou/Ex 1130 1135 LED Troffer (base 2L4T8), 2020 Data Centers 2020 2054 0.17 0.03 0.02 0.13 42% 0.00 0.01 0.00 0.00 0.00 0.00																						
Opt-Out/Ex 1200 1200 Base Other Fluorescent Fixture Data Centers 2014 2054 0.65 0.11 0.00 0.00 0,00 <t< td=""><td>Opt-Out/Ex</td><td></td><td>1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>	Opt-Out/Ex		1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020																			
Opt-Out/Ex 1200 1203 Lighting Control Tuneup (base other fluorescent fixture) Data Centers 2014 2054 0.59 0.11 0.05 0.06 9% 0.01 0.01 7% 0.00 0.00 0 0 11.27 0.05 0.05																	-			0.65	0.11	
Op-Du/Ex 1200 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent Data Centers 2014 2054 0.59 0.11 0.05 0.04 0.01 7% 0.04 0.03 0 0 1.69 0.05 Opt-Out/Ex 1200 1201 ROB High Performance T8 (base other fluorescent fluorescent) Data Centers 2014 2054 0.53 0.09 0.06 9% 0.01 0.02 16% 0.11 0.07 1 0 0.51 0.00 Opt-Out/Ex 1200 1204 Occupancy Sensor, 4L8 Fluorescent Fixtures Data Centers 2014 2054 0.46 0.09 0.07 0.19 30% 0.00 0.02 19% 0.15 0.10 3 1 0.52 0.00 Opt-Out/Ex 1330 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 Data Centers 2020 2054 5.49 0.96 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00																				0.05	0.11	
Opt-Out/Ex 1200 1201 ROB High Performance TB (base other fluorescent) Data Centers 2014 2054 0.53 0.09 0.06 0.12 19% 0.01 0.02 16% 0.11 0.07 1 0 0.51 0.00 0.00 0.00 0.00 0.00 0.00																	-	-				
Opt-Out/Ex 1330 1330 lasse incandescent Flood, 100W to Screw-in Replacement 2020 Data Centers 2020 2054 5.49 0.96 0.00	Opt-Out/Ex		1201 ROB High Performance T8 (base other fluorescent)	Data Centers		2054											1	-				
Opt-Out/Ex 1330 1332 LEDs (base incandescent flood) 2020 Data Centers 2020 2054 1.08 0.19 4.41 4.41 80% 0.77 0.77 80% 0.01 0.01 0 0 8.50 4.41 0.00 0.00 0.00 0.00 0.00 0.00 0.0																				F 40	0.06	
Opt-Out/Ex 1430 1430 Base incandescent A-Line Lamp, 72/W to Screw-in Replacement 2020 Data Centers 2020 2054 1.98 0.34 0.00 0,0																				5.49	0.96	
Opt-Out/Ex 1430 1432 LEDs (base incandescent A-line 72W) 2020 Data Centers 2020 2054 0.42 0.07 1.56 1.56 79% 0.27 0.27 79% 0.01 0.01 0 0 7.16 1.56 1.56 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0						2054								0%				-		1.98	0.34	
Op-Du/UEX 1530 1532 LEDs (base incandescent A-line 53W) 2020 Data Centers 2020 2054 0.42 0.07 1.03 71% 0.18 0.18 71% 0.01 0.01 0 5.27 1.03 Opt-Ou/Ex 1630 1630 Ease CPL 18W to screw-in replacement to screw-in replacement (base CPL 18W) 2020 Data Centers 2020 2054 1.11 0.19 0.00 0.00 0.00 0% 0.00 0% 0.00 0% 0.07 0.70 0 0.75 1.03 0.00 Op-Ou/Ex 1630 1630 Ease CPL 18W to screw-in replacement (base CPL 18W) 2020 Data Centers 2020 2054 1.11 0.19 0.00 0.00 0.00 0.00 0% N/A			1432 LEDs (base incandescent A-line 72W) 2020														0					
Opt-Out/Ex 1630 1630 Base CFL 18W to screw-in replacement 2020 Data Centers 2020 2054 1.11 0.19 0.00																				1.45	0.25	
Opt-Out/Ex 1630 1631 LED screw-in replacement (base CFL 18W) 2020 Data Centers 2020 2054 0.80 0.14 0.31 0.31 28% 0.05 0.05 28% 0.07 0.07 0 0 0.75 0.00																				1.11	0.19	
Opt-Out/Ex 1730 1730 Base CFL 23W to screw-in replacement 2020 Data Centers 2020 2054 1.42 0.25 0.00 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A 1.42 0.25 0.00	Opt-Out/Ex	1630					0.80									0.07						
	Opt-Out/Ex	1730	1730 Base CFL 23W to screw-in replacement 2020	Data Centers	2020	2054	1.42	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.42	0.25	0.00

DNV GL 1/5/2015 H-13

APPENDIX H

Base Avoided Costs

		empt/Nonjurisdictional Existing				V	0044														SUPPLY
Vintage	ST ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
				Measure					Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource		_	
		easure mber Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic
Opt-Out/Ex	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Data Centers	2020	2054	1.05	0.18	0.37	0.37	26%	0.06	0.06	26%	0.06	0.06	0	0	1.00	01111		0.37
Opt-Out/Ex	1800	1800 BaseMetal Halide, 465W	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Data Centers Data Centers	2014 2014	2054 2054	0.28 0.16	0.05 0.03	0.00 0.12	0.00 0.12	0% 44%	0.00 0.02	0.00 0.02	0% 44%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.61	0.28	0.05	0.00 0.12
Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Data Centers	2014	2054	4.17	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.17	0.05	0.00
Opt-Out/Ex	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Data Centers	2014	2054	2.80	0.02	1.37	1.37	33%	0.03	0.03	66%	0.04	0.04	2	2	1.63			1.37
Opt-Out/Ex Opt-Out/Ex	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Data Centers	2014 2014	2054 2054	1.35 0.96	0.00	1.45 0.38	2.82 3.21	68% 77%	0.02	0.05	101% 109%	0.16 1.07	0.10 0.22	14 104	6 14	0.37 0.05			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Data Centers Data Centers	2014	2054	36.02	8.87	0.00	0.00	0%	0.00	0.00	0%	N/A	0.22 N/A	N/A	N/A	0.05 N/A	36.02	8.87	0.00
Opt-Out/Ex		2010 Ceiling/roof Insulation - Chiller	Data Centers	2014	2054	35.86	8.83	0.16	0.16	0%	0.04	0.04	0%	0.00	0.00	0	0	20.15			0.16
Opt-Out/Ex	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Data Centers	2014	2054	32.80	8.07	3.06	3.22	9%	0.75	0.79	9%	0.02	0.02	0	0	4.58			3.06
Opt-Out/Ex Opt-Out/Ex	2000 2000	2006 VSD for Chiller Pumps and Towers 2013 High Efficiency Chiller Motors	Data Centers Data Centers	2014 2014	2054 2054	32.57 32.51	8.05 8.03	0.23 0.06	3.45 3.51	10% 10%	0.03 0.01	0.82 0.83	9% 9%	0.02 0.03	0.02 0.02	0	0	3.34 2.98			0.23 0.06
Opt-Out/Ex		2003 EMS - Chiller	Data Centers Data Centers	2014	2054	31.68	7.99	0.84	4.35	12%	0.05	0.88	10%	0.03	0.02	0	0	2.23			0.84
Opt-Out/Ex	2000	2008 New Economizer - Chiller	Data Centers	2014	2054	29.39	7.86	2.29	6.63	18%	0.13	1.01	11%	0.03	0.02	1	0	1.76			2.29
Opt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	Data Centers	2014	2054	29.38	7.85	0.01	6.64	18%	0.00	1.01	11%	0.05	0.02	0	0	1.19			0.01
Opt-Out/Ex Opt-Out/Ex	2000 2000	2012 Duct Testing/Sealing 2004 Cool Roof - Chiller	Data Centers Data Centers	2014 2014	2054 2054	23.80 23.72	6.48 6.46	5.58 0.07	12.22 12.30	34% 34%	1.37 0.02	2.39 2.40	27% 27%	0.09 0.14	0.05 0.05	0	0	0.84 0.47			0.00
Opt-Out/Ex	2000	2011 Duct/Pipe Insulation - Chiller	Data Centers	2014	2054	23.65	6.44	0.07	12.37	34%	0.02	2.42	27%	1.13	0.06	5	0	0.06			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Data Centers	2014	2054	20.54	5.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	20.54	5.06	0.00
Opt-Out/Ex	2100	2102 DX Packaged System, EER=13.4, 10 tons	Data Centers	2014 2014	2054 2054	15.82 15.47	3.89 3.74	4.72 0.34	4.72	23% 25%	1.16 0.15	1.16	23%	0.01	0.01	0	0	4.89 1.56			4.72 0.34
Opt-Out/Ex Opt-Out/Ex	2100 2100	2111 Economizer Repair - DX 2108 Optimize Controls - DX	Data Centers Data Centers	2014	2054	15.47	3.74	0.34	5.07 5.36	25% 26%	0.15	1.31 1.33	26% 26%	0.04	0.02	1	0	1.56			0.34
Opt-Out/Ex		2109 Economizer - DX	Data Centers	2014	2054	13.35	3.62	1.83	7.19	35%	0.10	1.43	28%	0.04	0.02	1	0	1.27			1.83
Opt-Out/Ex	2100	2115 Window Film (Standard) - DX	Data Centers	2014	2054	13.07	3.56	0.28	7.47	36%	0.07	1.50	30%	0.07	0.03	0	0	0.92			0.00
Opt-Out/Ex Opt-Out/Ex		2106 Prog. Thermostat - DX 2112 Aerosol Duct Sealing - DX	Data Centers Data Centers	2014 2014	2054 2054	12.43 11.68	3.52	0.64	8.11 8.87	39% 43%	0.04	1.54 1.72	30% 34%	0.06	0.03	1 0	0	0.89			0.00
Opt-Out/Ex	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Data Centers	2014	2054	11.67	3.33	0.00	8.87	43%	0.00	1.72	34%	0.12	0.04	2	0	0.45			0.00
Opt-Out/Ex	2100	2107 Cool Roof - DX	Data Centers	2014	2054	11.57	3.31	0.10	8.97	44%	0.02	1.75	35%	0.16	0.04	1	0	0.40			0.00
Opt-Out/Ex	2100 2200	2114 Duct/Pipe Insulation - DX	Data Centers Data Centers	2014 2014	2054 2054	11.50 2.63	3.29 0.65	0.07	9.04 0.00	44% 0%	0.02	1.77 0.00	35% 0%	1.33 N/A	0.05 N/A	5 N/A	0 N/A	0.05 N/A	2.63	0.65	0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Data Centers Data Centers	2014	2054	2.63	0.65	0.00	0.00	12%	0.00	0.00	12%	0.01	0.01	N/A 0	N/A 0	6.85	2.63	0.65	0.00
Opt-Out/Ex	2300	2300 Base PTAC, EER=8.3, 1 ton	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Data Centers	2014	2054	5.27	1.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.27	1.30	0.00
Opt-Out/Ex Opt-Out/Ex	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP	Data Centers Data Centers	2014 2014	2054 2054	5.19 3.92	1.28 1.20	0.09 1.27	0.09 1.35	2% 26%	0.02 0.08	0.02 0.10	2% 8%	0.02 0.01	0.02	0	0	4.50 4.25			0.09 1.27
Opt-Out/Ex	3000	3003 Demand Controlled Ventilation	Data Centers	2014	2054	3.69	1.10	0.23	1.58	30%	0.10	0.20	15%	0.55	0.01	1	1	0.16			0.00
Opt-Out/Ex	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Data Centers	2014	2054	18.33	4.51	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.33	4.51	0.00
Opt-Out/Ex	3100	3102 Variable Speed Drive Control, 15 HP	Data Centers	2014	2054	13.84	4.23	4.48	4.48	24%	0.28	0.28	6%	0.00	0.00	0	0	15.63			4.48
Opt-Out/Ex Opt-Out/Ex	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Data Centers Data Centers	2014 2014	2054 2054	13.76 12.86	4.21 4.01	0.08 0.90	4.57 5.47	25% 30%	0.02 0.20	0.30 0.50	7% 11%	0.01 0.02	0.00 0.01	0	0	7.49 3.30			0.08 0.90
Opt-Out/Ex	3100	3103 Air Handler Optimization, 15 HP	Data Centers	2014	2054	11.65	3.93	1.21	6.68	36%	0.08	0.58	13%	0.02	0.01	Ö	Ö	2.61			1.21
Opt-Out/Ex		3105 Energy Recovery Ventilation (ERV)	Data Centers	2014	2054	11.36	3.81	0.29	6.97	38%	0.13	0.70	16%	0.21	0.02	0	0	0.46			0.00
Opt-Out/Ex Opt-Out/Ex	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Data Centers Data Centers	2014 2014	2054 2054	10.70 19.47	3.52 4.79	0.65 0.00	7.62 0.00	42% 0%	0.29 0.00	0.99 0.00	22% 0%	0.65 N/A	0.07 N/A	1 N/A	1 N/A	0.14 N/A	19.47	4.79	0.00
Opt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP	Data Centers	2014	2054	17.63	4.79	1.84	1.84	9%	0.00	0.11	2%	0.01	0.01	0	0	3.71	15.47	4.75	1.84
Opt-Out/Ex	3200	3202 Variable Speed Drive Control, 40 HP	Data Centers	2014	2054	13.32	4.41	4.31	6.15	32%	0.27	0.38	8%	0.02	0.02	0	0	2.81			4.31
Opt-Out/Ex	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	Data Centers	2014	2054	13.26	4.40	0.06	6.21	32%	0.01	0.40	8%	0.09	0.02	0	0	0.84			0.00
Opt-Out/Ex Opt-Out/Ex	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Data Centers Data Centers	2014 2014	2054 2054	12.50 0.00	4.06 0.00	0.76 0.00	6.98 0.00	36% 0%	0.34	0.74	15% 0%	0.60 N/A	0.08 N/A	N/A	1 N/A	0.15 N/A	0.00	0.00	0.00
Opt-Out/Ex		4100 Base Self-Contained Refrigeration	Data Centers	2014	2054	3.79	0.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.79	0.71	0.00
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door	Data Centers	2014	2054	3.79	0.71	0.00	0.00	0%	0.00	0.00	0%	0.00	0.00	0	0	23.12			0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4107 Energy-Star Freezer, solid door	Data Centers Data Centers	2014 2014	2054 2054	3.72 3.72	0.70 0.70	0.07	0.07 0.07	2% 2%	0.01 0.00	0.01 0.01	2% 2%	0.00 0.01	0.00	0	0	22.18 9.26			0.07 0.00
Opt-Out/Ex	4100	4108 Energy-Star Refrigerator, glass door	Data Centers	2014	2054	3.72	0.70	0.00	0.07	2%	0.00	0.01	2%	0.01	0.00	0	0	7.81			0.00
Opt-Out/Ex	4100	4106 Energy-Star Refrigerator, solid door	Data Centers	2014	2054	3.71	0.70	0.00	0.08	2%	0.00	0.01	2%	0.01	0.00	0	0	7.48			0.00
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Data Centers	2014	2054	3.71	0.70	0.00	0.08	2%	0.00	0.02	2%	0.02	0.00	0	0	2.78			0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4112 Reach-in unit occupancy sensors 4105 Bi-level LED Case Lighting (self-contained units) 2014	Data Centers Data Centers	2014 2014	2054 2054	3.71 3.71	0.70	0.00	0.08	2% 2%	0.00	0.02 0.02	2% 2%	0.31 0.36	0.00	2	0	0.20			0.00
Opt-Out/Ex		4101 Strip curtains for walk-ins (self-contained)	Data Centers	2014	2054	3.71	0.70	0.00	0.08	2%	0.00	0.02	2%	8.40	0.04	45	0	0.01			0.00
Opt-Out/Ex	5000	5000 Base Desktop PC	Data Centers	2014	2054	0.50	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.50	0.09	0.00
Opt-Out/Ex Opt-Out/Ex	5000 5000	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	Data Centers Data Centers	2014 2014	2054 2054	0.28 0.22	0.07 0.06	0.22	0.22 0.28	44% 56%	0.02 0.01	0.02	23% 35%	0.02	0.02	0	0	3.01 1.67			0.22
Opt-Out/Ex		5100 Base Laptop PC	Data Centers	2014	2054	0.22	0.06	0.00	0.28	0%	0.00	0.00	0%	0.03 N/A	0.02 N/A	N/A	N/A	N/A	0.04	0.01	0.00
Opt-Out/Ex	5100	5102 Energy Star or Better Laptop	Data Centers	2014	2054	0.03	0.01	0.01	0.01	19%	0.00	0.00	19%	0.01	0.01	0	0	4.36			0.01
Opt-Out/Ex	5100	5101 Laptop Network Power Management Enabling	Data Centers	2014	2054	0.03	0.00	0.00	0.01	21%	0.00	0.00	21%	1.46	0.13	8	1	0.04	0.04	0.04	0.00
Opt-Out/Ex Opt-Out/Ex	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Data Centers Data Centers	2014 2014	2054 2054	0.21	0.04 0.02	0.00	0.00	0% 43%	0.00 0.02	0.00 0.02	0% 43%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 45.38	0.21	0.04	0.00
Opt-Out/Ex	5200	5202 Monitor Power Management Enabling - CRT	Data Centers	2014	2054	0.12	0.02	0.03	0.09	50%	0.02	0.02	46%	0.01	0.00	0	0	3.50			0.01
Opt-Out/Ex	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Data Centers	2014	2054	0.10	0.02	0.01	0.11	54%	0.00	0.02	50%	0.16	0.01	1	0	0.33			0.00
Opt-Out/Ex Opt-Out/Ex	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Data Centers Data Centers	2014 2014	2054 2054	0.13 0.11	0.02 0.02	0.00 0.02	0.00 0.02	0% 13%	0.00	0.00	0% 13%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.39	0.13	0.02	0.00 0.02
Opt-Out/Ex	5300	5301 Energy Star of Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Data Centers Data Centers	2014	2054	0.11	0.02	0.02	0.02	13%	0.00	0.00	16%	0.01	0.01	1	0	0.49			0.02
Opt-Out/Ex	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Data Centers	2014	2054	0.10	0.02	0.01	0.03	25%	0.00	0.00	18%	0.29	0.10	6	1	0.16			0.00

APPENDIX H

Base Avoided Costs

			pt/Nonjurisdictional Existing				V	2014														SUPPLY
Vintage	SYST ADL	DITIVE SU	IPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
					Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource			
Samt	Base Numbe	Meas er Num		Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH
Opt-Out		400	5400 Base Copier	Data Centers	2014	2054	0.11	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.02	0.00
Opt-Out	/Ex 54		5401 Energy Star or Better Copier	Data Centers	2014	2054	0.10	0.02	0.01	0.01	10%	0.00	0.00	10%	0.00	0.00	0	0	26.53			0.01
Opt-Out		100	5402 Copier Power Management Enabling	Data Centers	2014	2054	0.10	0.02	0.00	0.02	14%	0.00	0.00	12%	0.11	0.03	1	0	0.45	0.04	0.00	0.00
Opt-Out		500 500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Data Centers Data Centers	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.27	0.01	0.00	0.00
Opt-Out			5501 Multifunction Power Management Enabling	Data Centers	2014	2054	0.01	0.00	0.00	0.01	38%	0.00	0.00	32%	0.32	0.11	4	1	0.15			0.00
Opt-Out		600	5600 Base Printer	Data Centers	2014	2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00
Opt-Out		600 600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Data Centers Data Centers	2014 2014	2054 2054	0.03	0.00	0.02	0.02	35% 46%	0.00	0.00	35% 41%	0.00 0.07	0.00	0	0	33.42 0.70			0.02
Opt-Out		700	5700 Base Data Center/Server Room	Data Centers Data Centers	2014	2054	992.35	172.65	0.00	0.02	46% 0%	0.00	0.00	41% 0%	N/A	0.02 N/A	N/A	N/A	0.70 N/A	992.35	172.65	0.00
Opt-Out		700	5701 Data Center Improved Operations	Data Centers	2014	2054	893.12	155.39	99.24	99.24	10%	17.27	17.27	10%	0.00	0.00	0	0	115.96	002.00	112.00	99.24
Opt-Out		700	5702 Data Center Best Practices	Data Centers	2014	2054	779.49	135.62	113.63	212.86	21%	19.77	37.03	21%	0.00	0.00	0	0	47.21			113.63
Opt-Out		700 000	5703 Data Center State of the Art practices 6000 Base Water Heating	Data Centers Data Centers	2014 2014	2054 2054	735.84 0.47	128.02	43.65	256.51	26% 0%	7.59 0.00	44.63 0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	24.48 N/A	0.47	0.08	43.65 0.00
Opt-Out		000	6007 Heat Trap	Data Centers	2014	2054	0.47	0.08	0.00	0.02	5%	0.00	0.00	5%	0.08	0.08	0	0	0.79	0.47	0.00	0.00
Opt-Out	/Ex 60	000	6002 High Efficiency Water Heater (electric)	Data Centers	2014	2054	0.44	0.08	0.01	0.03	7%	0.00	0.01	7%	0.16	0.10	1	1	0.42			0.00
Opt-Out		000	6004 Tankless Water Heater	Data Centers	2014	2054	0.40	0.07	0.03	0.07	14%	0.01	0.01	14%	0.24	0.17	1	1	0.30			0.00
Opt-Out Opt-Out		000	6008 Solar Water Heater 6003 Hot Water Pipe Insulation	Data Centers Data Centers	2014 2014	2054 2054	0.19 0.19	0.03	0.21	0.28 0.28	60% 60%	0.04	0.05 0.05	60% 60%	0.28 0.62	0.26 0.26	2	1	0.26 0.11			0.00
Opt-Out		000	6006 Heat Recovery Unit	Data Centers	2014	2054	0.15	0.03	0.00	0.20	63%	0.00	0.05	63%	0.63	0.28	4	2	0.10			0.00
Opt-Out		000	6001 Demand controlled circulating systems	Data Centers	2014	2054	0.17	0.03	0.01	0.30	64%	0.00	0.05	64%	1.89	0.30	11	2	0.04			0.00
Opt-Out			7000 Base Refrigerated Vending Machines	Data Centers	2014	2054	0.31	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.31	0.05	0.00
Opt-Out		000 000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Data Centers Data Centers	2014 2014	2054 2054	0.26 0.23	0.05 0.05	0.05	0.05 0.07	16% 24%	0.00	0.00 0.01	8% 12%	0.01 0.02	0.01 0.01	0	0	5.44 3.00			0.05
Opt-Out		100	7100 Base Non-Refrigerated Vending Machines	Data Centers	2014	2054	0.23	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out		100	7101 Vending Misers (Non-Refrigerated)	Data Centers	2014	2054	0.01	0.00	0.01	0.01	44%	0.00	0.00	23%	0.12	0.12	1	1	0.41			0.00
Opt-Out		200	7200 Base Oven	Data Centers	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out		300 400	7300 Base Fryer 7400 Base Steamer	Data Centers Data Centers	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00
Opt-Out		000	8000 Base Heating, Heat Pump (7.7 HSPF)	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out	/Ex 81	100	8100 Base Heating, Other Electric	Data Centers	2014	2054	0.58	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.58	0.00	0.00
Opt-Out		500	9500 Base Miscellaneous	Data Centers	2014	2054	4.70	0.82	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.70	0.82	0.00
Opt-Out Opt-Out		500 030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Data Centers Non-Jurisdictional	2014	2054 2054	4.70 8.11	0.82 1.44	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	8.11	1.44	0.00
Opt-Out		030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Non-Jurisdictional	2020	2054	8.06	1.44	0.05	0.05	1%	0.00	0.00	0%	0.01	0.01	0	0	5.03	0		0.05
Opt-Out		030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Non-Jurisdictional	2020	2054	7.45	1.35	0.61	0.66	8%	0.09	0.09	6%	0.01	0.01	0	0	4.45			0.61
Opt-Out		030 030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Non-Jurisdictional	2020 2020	2054 2054	6.68	1.22	0.77	1.42 1.77	18%	0.14	0.23	16%	0.02	0.02	0	0	3.38			0.77
Opt-Out		030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Non-Jurisdictional Non-Jurisdictional	2020	2054	6.34 6.00	1.15 1.14	0.35 0.34	2.11	22% 26%	0.06	0.29 0.30	20% 21%	0.05	0.03	1	0	0.00			0.00
Opt-Out		030	1034 ROB 4L4' LED Tube, 2020	Non-Jurisdictional	2020	2054	5.03	0.97	0.97	3.08	38%	0.17	0.48	33%	0.20	0.08	1	1	0.33			0.00
Opt-Out		030	1035 LED Troffer (base 4L4'T8), 2020	Non-Jurisdictional	2020	2054	4.60	0.89	0.43	3.51	43%	0.08	0.55	38%	0.16	0.09	.1.	.1	0.40			0.00
Opt-Out		130 130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	1.54 1.53	0.27 0.27	0.00 0.01	0.00 0.01	0% 0%	0.00	0.00	0% 0%	N/A 0.01	N/A 0.01	N/A	N/A 0	N/A 3.35	1.54	0.27	0.00 0.01
Opt-Out		130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Non-Jurisdictional	2020	2054	1.42	0.27	0.01	0.01	8%	0.00	0.00	6%	0.01	0.01	0	0	2.98			0.01
Opt-Out	/Ex 11	130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Non-Jurisdictional	2020	2054	1.28	0.23	0.14	0.26	17%	0.03	0.04	15%	0.02	0.02	ō	ō	2.56			0.14
Opt-Out		130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Non-Jurisdictional	2020	2054	1.12	0.20	0.16	0.43	28%	0.03	0.07	26%	0.05	0.03	0	0	1.23			0.16
Opt-Out Opt-Out		130 130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	1.06 0.97	0.19 0.18	0.05 0.09	0.48 0.57	31% 37%	0.01 0.02	0.08 0.10	29% 35%	0.17 0.22	0.05 0.07	1	0	0.38 0.30			0.00
Opt-Out		130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Non-Jurisdictional	2020	2054	0.92	0.18	0.05	0.62	40%	0.02	0.10	36%	0.12	0.08	3	0	0.39			0.00
Opt-Out		200	1200 Base Other Fluorescent Fixture	Non-Jurisdictional	2014	2054	0.21	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.21	0.04	0.00
Opt-Out		200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Non-Jurisdictional	2014	2054	0.20	0.04	0.01	0.01	4%	0.00	0.00	2%	0.00	0.00	0	0	11.32			0.01
Opt-Out		200 200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.19 0.17	0.03	0.02	0.02	11% 19%	0.00	0.00 0.01	8% 16%	0.04 0.05	0.03	0	0	1.62 1.14			0.02 0.02
Opt-Out		200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Non-Jurisdictional	2014	2054	0.17	0.03	0.02	0.04	28%	0.00	0.01	18%	0.06	0.05	1	0	0.77			0.02
Opt-Out		330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Non-Jurisdictional	2020	2054	2.31	0.41	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.31	0.41	0.00
Opt-Out		330 430	1332 LEDs (base incandescent flood) 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	0.58	0.10	1.73	1.73	75%	0.31	0.31	75%	0.00 N/A	0.00 N/A	0	0	29.67	0.00	0.45	1.73
Opt-Out		430 430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	Non-Jurisdictional	2020	2054	0.83	0.15 0.04	0.00	0.00	0% 73%	0.00	0.00 0.11	0% 73%	0.00	0.00	N/A 0	N/A 0	N/A 24.85	0.83	0.15	0.00 0.61
Opt-Out		530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Non-Jurisdictional	2020	2054	0.61	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.61	0.11	0.00
Opt-Out		530	1532 LEDs (base incandescent A-line 53W) 2020	Non-Jurisdictional	2020	2054	0.22	0.04	0.39	0.39	64%	0.07	0.07	64%	0.00	0.00	0	0	17.82			0.39
Opt-Out		630 630	1630 Base CFL 18W to screw-in replacement 2020	Non-Jurisdictional	2020 2020	2054	0.35	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A	N/A	0.35	0.06	0.00
Opt-Out		730 730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Non-Jurisdictional Non-Jurisdictional	2020	2054 2054	0.25 0.44	0.04 0.08	0.10	0.10 0.00	28% 0%	0.02 0.00	0.02	28% 0%	0.06 N/A	0.06 N/A	N/A	0 N/A	0.94 N/A	0.44	0.08	0.00
Opt-Out			1731 LED screw-in replacement (base CFL 23W) 2020	Non-Jurisdictional	2020	2054	0.33	0.06	0.00	0.12	26%	0.02	0.02	26%	0.04	0.04	0	0	1.25	U. /-	0.50	0.12
Opt-Out	/Ex 18	300	1800 BaseMetal Halide, 465W	Non-Jurisdictional	2014	2054	0.36	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.36	0.06	0.00
Opt-Out		300 300	1801 T5 (240W) (base metal halide)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.24 0.23	0.04	0.12 0.01	0.12 0.13	34% 36%	0.02 0.00	0.02 0.02	34% 34%	0.03	0.03	0	0	2.75 0.71			0.12
Opt-Out		300	1806 Occupancy Sensor, High Bay T5 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Non-Jurisdictional	2014	2054	0.23	0.04	0.01	0.13	36% 41%	0.00	0.02	34%	0.07	0.03	1	0	0.71			0.00
Opt-Out	/Ex 18	350	1850 Base CFL Exit Sign	Non-Jurisdictional	2014	2054	0.10	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.10	0.02	0.00
Opt-Out		350	1851 LED Exit Sign	Non-Jurisdictional	2014	2054	0.06	0.01	0.05	0.05	45%	0.01	0.01	45%	0.02	0.02	0	0	2.92			0.05
Opt-Out		900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	1.23 0.97	0.05 0.02	0.00	0.00 0.26	0% 21%	0.00	0.00	0% 66%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.78	1.23	0.05	0.00
Opt-Out		900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Non-Jurisdictional	2014	2054	0.97	0.02	0.26	0.26	62%	0.03	0.03	107%	0.04	0.04	2	1	0.66			0.26
Opt-Out		900	1903 Bi-Level LED Outdoor Lighting	Non-Jurisdictional	2014	2054	0.33	-0.01	0.14	0.90	73%	0.01	0.06	117%	0.58	0.15	15	2	0.10			0.00

DNV GL H-15 1/5/2015

APPENDIX H

Base Avoided Costs

DSM ASSY	ST ADDITIV	/E SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt Opt-Out/Ex	Number 2000	Number Measure 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Type Non-Jurisdictional	Year 2014	Year 2054	3.06	MW 2.26	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	3.06	MW 2.26	0.00
Opt-Out/Ex		2010 Ceiling/roof Insulation - Chiller	Non-Jurisdictional	2014	2054	3.04	2.24	0.00	0.02	1%	0.02	0.02	1%	0.01	0.01	0	0	10.57	3.00	2.20	0.02
Opt-Out/Ex		2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Non-Jurisdictional	2014	2054	2.78	2.05	0.26	0.28	9%	0.19	0.21	9%	0.05	0.05	0	0	2.40			0.26
Opt-Out/Ex Opt-Out/Ex		2013 High Efficiency Chiller Motors 2006 VSD for Chiller Pumps and Towers	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	2.77	2.04	0.01	0.29 0.35	9% 11%	0.00 0.02	0.21	9% 10%	0.07	0.05	0	0	1.56 1.37			0.01
Opt-Out/Ex		2003 EMS - Chiller	Non-Jurisdictional	2014	2054	2.72	2.02	0.10	0.45	15%	0.02	0.25	11%	0.08	0.05	0	0	0.78			0.00
Opt-Out/Ex		2012 Duct Testing/Sealing	Non-Jurisdictional	2014	2054	2.12	1.64	0.49	0.94	31%	0.36	0.61	27%	0.24	0.15	0	0	0.46			0.00
Opt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	Non-Jurisdictional	2014	2054	2.09	1.62	0.04	0.98	32%	0.03	0.64	28%	0.35	0.16	0 2	0	0.26			0.00
Opt-Out/Ex Opt-Out/Ex		2008 New Economizer - Chiller 2004 Cool Roof - Chiller	Non-Jurisdictional Non-Jurisdictional	2014	2054 2054	1.92 1.91	1.59 1.58	0.17	1.14 1.15	37% 38%	0.03	0.67 0.68	30% 30%	0.29 0.67	0.18 0.18	1	0	0.20			0.00
Opt-Out/Ex		2011 Duct/Pipe Insulation - Chiller	Non-Jurisdictional	2014	2054	1.90	1.57	0.02	1.17	38%	0.01	0.69	31%	3.39	0.23	5	Ö	0.03			0.00
Opt-Out/Ex		2100 Base DX Packaged System, EER=10.3, 10 tons	Non-Jurisdictional	2014	2054	3.77	2.78	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.77	2.78	0.00
Opt-Out/Ex Opt-Out/Ex		2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	3.77 2.91	2.78	0.00	0.00 0.87	0% 23%	0.00	0.00	0% 23%	0.01	0.01	0	0	10.81 2.53			0.00
Opt-Out/Ex		2108 Optimize Controls - DX	Non-Jurisdictional	2014	2054	2.86	2.14	0.05	0.92	24%	0.04	0.65	23%	0.10	0.04	1	0	0.53			0.00
Opt-Out/Ex	2100	2111 Economizer Repair - DX	Non-Jurisdictional	2014	2054	2.78	2.05	0.08	0.99	26%	0.08	0.73	26%	0.20	0.06	0	0	0.44			0.00
Opt-Out/Ex		2112 Aerosol Duct Sealing - DX	Non-Jurisdictional	2014	2054	2.62	1.93	0.17	1.16	31%	0.12	0.85	31%	0.28	0.09	0	0	0.40			0.00
Opt-Out/Ex Opt-Out/Ex		2106 Prog. Thermostat - DX 2115 Window Film (Standard) - DX	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	2.53	1.91 1.89	0.09 0.04	1.25 1.28	33% 34%	0.02 0.03	0.87 0.90	31% 32%	0.16 0.35	0.09	1 0	0	0.34 0.26			0.00
Opt-Out/Ex		2109 Economizer - DX	Non-Jurisdictional	2014	2054	2.38	1.87	0.11	1.39	37%	0.02	0.92	33%	0.29	0.12	2	Ö	0.20			0.00
Opt-Out/Ex		2107 Cool Roof - DX	Non-Jurisdictional	2014	2054	2.37	1.86	0.01	1.41	37%	0.01	0.93	33%	0.66	0.12	1	0	0.13			0.00
Opt-Out/Ex		2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Non-Jurisdictional	2014 2014	2054 2054	2.37 2.35	1.86	0.00 0.02	1.41	37% 38%	0.00 0.01	0.93 0.94	33% 34%	0.66 3.37	0.12 0.16	4 5	0	0.09			0.00
Opt-Out/Ex Opt-Out/Ex		2114 Duct/Pipe Insulation - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Non-Jurisdictional Non-Jurisdictional	2014	2054	1.64	1.85 1.21	0.02	1.42 0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.64	1.21	0.00
Opt-Out/Ex		2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Non-Jurisdictional	2014	2054	1.44	1.06	0.20	0.20	12%	0.15	0.15	12%	0.03	0.03	0	0	3.55			0.20
Opt-Out/Ex		2300 Base PTAC, EER=8.3, 1 ton	Non-Jurisdictional	2014	2054	2.54	1.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.54	1.87	0.00
Opt-Out/Ex Opt-Out/Ex		3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	2.21 2.18	0.65 0.64	0.00 0.04	0.00 0.04	0% 2%	0.00 0.01	0.00 0.01	0% 2%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 2.24	2.21	0.65	0.00 0.04
Opt-Out/Ex		3002 Variable Speed Drive Control, 5 HP	Non-Jurisdictional	2014	2054	1.58	0.59	0.60	0.63	29%	0.04	0.05	8%	0.03	0.03	0	0	2.06			0.60
Opt-Out/Ex	3000	3003 Demand Controlled Ventilation	Non-Jurisdictional	2014	2054	1.52	0.56	0.06	0.70	31%	0.03	0.09	14%	1.22	0.13	2	1	0.08			0.00
Opt-Out/Ex		3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Non-Jurisdictional	2014	2054 2054	2.29 1.66	0.67	0.00	0.00	0% 27%	0.00	0.00	0%	N/A	N/A 0.01	N/A	N/A	N/A	2.29	0.67	0.00
Opt-Out/Ex Opt-Out/Ex	3100 3100	3102 Variable Speed Drive Control, 15 HP 3101 Fan Motor, 15hp, 1800rpm, 92.4%	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054	1.66	0.63 0.62	0.63 0.02	0.63 0.65	28%	0.05 0.01	0.05 0.05	7% 8%	0.01 0.02	0.01	0	0	7.57 3.57			0.63 0.02
Opt-Out/Ex		3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Non-Jurisdictional	2014	2054	1.47	0.57	0.18	0.82	36%	0.05	0.10	15%	0.05	0.02	Ö	Ö	1.51			0.18
Opt-Out/Ex		3103 Air Handler Optimization, 15 HP	Non-Jurisdictional	2014	2054	1.35	0.56	0.12	0.94	41%	0.01	0.11	16%	0.04	0.02	1	0	1.16			0.12
Opt-Out/Ex Opt-Out/Ex		3105 Energy Recovery Ventilation (ERV) 3107 Demand Controlled Ventilation	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	1.32 1.27	0.55 0.52	0.03 0.05	0.97 1.02	42% 45%	0.02	0.12 0.15	18% 22%	0.49 1.51	0.03	1	0	0.21 0.06			0.00
Opt-Out/Ex		3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Non-Jurisdictional	2014	2054	1.36	0.52	0.00	0.00	0%	0.03	0.15	0%	N/A	N/A	N/A	N/A	N/A	1.36	0.40	0.00
Opt-Out/Ex		3203 Air Handler Optimization, 40 HP	Non-Jurisdictional	2014	2054	1.25	0.39	0.11	0.11	8%	0.01	0.01	2%	0.03	0.03	0	0	1.81			0.11
Opt-Out/Ex Opt-Out/Ex	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	Non-Jurisdictional	2014 2014	2054 2054	0.90	0.36 0.36	0.34	0.45 0.46	33% 34%	0.02	0.03	8% 9%	0.04	0.04 0.04	1	1	1.38 0.41			0.34
Opt-Out/Ex		3201 Fan Motor, 40np, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Non-Jurisdictional Non-Jurisdictional	2014	2054	0.90	0.36	0.00	0.46	34% 36%	0.00	0.03	14%	1.32	0.04	2	1	0.41			0.00
Opt-Out/Ex		4000 Base Built-Up Refrigeration System	Non-Jurisdictional	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex		4100 Base Self-Contained Refrigeration	Non-Jurisdictional	2014	2054	1.89	0.28	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.89	0.28	0.00
Opt-Out/Ex Opt-Out/Ex		4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Non-Jurisdictional Non-Jurisdictional	2014	2054 2054	1.79 1.76	0.26	0.10	0.10	5% 7%	0.01	0.01 0.02	5% 7%	0.00	0.00	0	0	65.08 27.05			0.10 0.03
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door	Non-Jurisdictional	2014	2054	1.76	0.26	0.03	0.13	7%	0.00	0.02	7%	0.00	0.00	0	0	15.56			0.03
Opt-Out/Ex	4100	4106 Energy-Star Refrigerator, solid door	Non-Jurisdictional	2014	2054	1.73	0.25	0.02	0.16	8%	0.00	0.02	8%	0.00	0.00	0	0	14.64			0.02
Opt-Out/Ex		4108 Energy-Star Refrigerator, glass door	Non-Jurisdictional	2014 2014	2054 2054	1.71 1.71	0.25 0.25	0.02	0.18 0.19	10% 10%	0.00	0.03	10% 10%	0.01 0.01	0.00	0	0	6.94 6.17			0.02
Opt-Out/Ex Opt-Out/Ex		4107 Energy-Star Freezer, solid door 4110 Energy Star Ice Machines	Non-Jurisdictional Non-Jurisdictional	2014	2054	1.71	0.25	0.00	0.19	11%	0.00	0.03	11%	0.01	0.00	0	0	5.27			0.00
Opt-Out/Ex	4100	4112 Reach-in unit occupancy sensors	Non-Jurisdictional	2014	2054	1.68	0.24	0.00	0.21	11%	0.00	0.03	11%	0.33	0.00	2	0	0.17			0.00
Opt-Out/Ex		4105 Bi-level LED Case Lighting (self-contained units) 2014	Non-Jurisdictional	2014	2054	1.68	0.24	0.00	0.21	11%	0.00	0.03	11%	0.38	0.01	3	0	0.14			0.00
Opt-Out/Ex Opt-Out/Ex	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	1.68 0.36	0.24 0.05	0.00	0.22	11% 0%	0.00	0.03	11% 0%	15.38 N/A	0.16 N/A	106 N/A	1 N/A	0.00 N/A	0.36	0.05	0.00
Opt-Out/Ex		5001 PC Network Power Management Enabling	Non-Jurisdictional	2014	2054	0.19	0.04	0.16	0.16	46%	0.00	0.01	23%	0.01	0.01	0	0	4.27	0.50	0.00	0.16
Opt-Out/Ex	5000	5002 Energy Star or Better PC	Non-Jurisdictional	2014	2054	0.14	0.03	0.05	0.21	60%	0.01	0.02	37%	0.02	0.01	0	0	2.15			0.05
Opt-Out/Ex		5100 Base Laptop PC	Non-Jurisdictional	2014 2014	2054 2054	0.03	0.00	0.00 0.01	0.00 0.01	0% 19%	0.00	0.00	0%	N/A 0.01	N/A	N/A 0	N/A	N/A	0.03	0.00	0.00 0.01
Opt-Out/Ex Opt-Out/Ex		5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Non-Jurisdictional Non-Jurisdictional	2014	2054	0.03	0.00	0.01	0.01	21%	0.00	0.00	19% 21%	1.03	0.01 0.09	7	0	5.87 0.05			0.00
Opt-Out/Ex		5200 Base Monitor, CRT	Non-Jurisdictional	2014	2054	0.08	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.08	0.01	0.00
Opt-Out/Ex		5201 Energy Star or Better Monitor - CRT	Non-Jurisdictional	2014	2054	0.04	0.01	0.04	0.04	50%	0.01	0.01	50%	0.00	0.00	0	0	53.00			0.04
Opt-Out/Ex Opt-Out/Ex	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.03	0.00	0.01 0.00	0.05 0.05	60% 63%	0.00	0.01 0.01	55% 58%	0.01 0.15	0.00 0.01	0	0	3.90 0.35			0.01 0.00
Opt-Out/Ex		5300 Base Monitor, LCD	Non-Jurisdictional	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.08	0.01	0.00
Opt-Out/Ex	5300	5301 Energy Star or Better Monitor - LCD	Non-Jurisdictional	2014	2054	0.07	0.01	0.01	0.01	16%	0.00	0.00	16%	0.01	0.01	0	0	7.05			0.01
Opt-Out/Ex		5302 Monitor Power Management Enabling - LCD	Non-Jurisdictional	2014	2054	0.07	0.01	0.00	0.02	20%	0.00	0.00	18%	0.07	0.02	1	0	0.69			0.00
Opt-Out/Ex Opt-Out/Ex	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.06 0.10	0.01 0.01	0.01 0.00	0.02	26% 0%	0.00	0.00	19% 0%	0.19 N/A	0.06 N/A	N/A	1 N/A	0.23 N/A	0.10	0.01	0.00
Opt-Out/Ex		5401 Energy Star or Better Copier	Non-Jurisdictional	2014	2054	0.09	0.01	0.01	0.01	12%	0.00	0.00	12%	0.00	0.00	0	0	35.12	20		0.01
Opt-Out/Ex	5400	5402 Copier Power Management Enabling	Non-Jurisdictional	2014	2054	0.08	0.01	0.00	0.02	16%	0.00	0.00	14%	0.08	0.02	1	0	0.62			0.00
Opt-Out/Ex Opt-Out/Ex		5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.01 0.01	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.81	0.01	0.00	0.00
Opt-Out/Ex		5501 Multifunction Power Management Enabling	Non-Jurisdictional	2014	2054	0.01	0.00	0.00	0.00	38%	0.00	0.00	32%	0.01	0.01	3	1	0.22			0.00
		ž ž																			

APPENDIX H

Base Avoided Costs

		SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage									Total			Total		Marginal	Average	Marginal	Average	Total			
В	lase Me	easure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity	Capacity	Resource Cost Test	Base	Base	Economic
Sgmt N	lumber Nu	imber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH
Opt-Out/Ex Opt-Out/Ex	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.12	0.02 0.01	0.00 0.04	0.00 0.04	0% 35%	0.00 0.01	0.00 0.01	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 45.10	0.12	0.02	0.00 0.04
Opt-Out/Ex	5600	5601 Printer Power Management Enabling	Non-Jurisdictional	2014	2054	0.06	0.01	0.04	0.04	46%	0.01	0.01	40%	0.00	0.00	1	0	1.01			0.04
Opt-Out/Ex	5700	5700 Base Data Center/Server Room	Non-Jurisdictional	2014	2054	1.03	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.03	0.15	0.00
Opt-Out/Ex	5700	5701 Data Center Improved Operations	Non-Jurisdictional	2014	2054	0.93	0.14	0.10	0.10	10%	0.02	0.02	10%	0.00	0.00	0	0	156.01			0.10
Opt-Out/Ex Opt-Out/Ex	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.81	0.12 0.11	0.12 0.05	0.22 0.27	21% 26%	0.02	0.03	21% 26%	0.00	0.00	0	0	63.52 32.94			0.12 0.05
Opt-Out/Ex	6000	6000 Base Water Heating	Non-Jurisdictional	2014	2054	0.77	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.37	0.05	0.00
Opt-Out/Ex	6000	6007 Heat Trap	Non-Jurisdictional	2014	2054	0.35	0.05	0.02	0.02	5%	0.00	0.00	5%	0.02	0.02	0	0	3.74			0.02
Opt-Out/Ex Opt-Out/Ex	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.34	0.05 0.04	0.01 0.03	0.03 0.05	7% 14%	0.00	0.00 0.01	7% 14%	0.03 0.05	0.02 0.03	0	0	2.00 1.42			0.01 0.03
Opt-Out/Ex	6000	6008 Solar Water Heater	Non-Jurisdictional	2014	2054	0.32	0.04	0.03	0.05	37%	0.00	0.01	37%	0.05	0.05	0	0	1.42			0.03
Opt-Out/Ex	6000	6003 Hot Water Pipe Insulation	Non-Jurisdictional	2014	2054	0.23	0.03	0.00	0.14	38%	0.00	0.02	38%	0.08	0.05	1	0	0.81			0.00
Opt-Out/Ex	6000	6006 Heat Recovery Unit	Non-Jurisdictional	2014	2054	0.22	0.03	0.01	0.15	41%	0.00	0.02	41%	0.08	0.05	1	0	0.71			0.00
Opt-Out/Ex Opt-Out/Ex	6000 7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.21 0.12	0.03 0.02	0.01 0.00	0.16 0.00	43% 0%	0.00	0.02	43% 0%	0.24 N/A	0.06 N/A	2 N/A	0 N/A	0.27 N/A	0.12	0.02	0.00
Opt-Out/Ex	7000	7001 Vending Misers (Refrigerated units)	Non-Jurisdictional	2014	2054	0.12	0.02	0.00	0.00	16%	0.00	0.00	8%	0.05	0.05	1	1	0.99	0.12	0.02	0.00
Opt-Out/Ex	7000	7002 Vending Misers (Refrigerated glass-front units)	Non-Jurisdictional	2014	2054	0.09	0.02	0.01	0.03	25%	0.00	0.00	12%	0.09	0.06	1	1	0.54			0.00
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Non-Jurisdictional	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.00 0.35	0.00 0.05	0.00	0.00	46% 0%	0.00	0.00	23% 0%	0.92 N/A	0.92 N/A	12 N/A	12 N/A	0.05 N/A	0.35	0.05	0.00
Opt-Out/Ex	7300	7300 Base Gveri	Non-Jurisdictional	2014	2054	0.33	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.33	0.03	0.00
Opt-Out/Ex	7300	7301 Efficient Fryer	Non-Jurisdictional	2014	2054	0.17	0.03	0.01	0.01	3%	0.00	0.00	3%	0.42	0.42	3	3	0.15			0.00
Opt-Out/Ex	7400	7400 Base Steamer	Non-Jurisdictional	2014	2054	0.35	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.35	0.06	0.00
Opt-Out/Ex Opt-Out/Ex	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	0.07	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.03	N/A 0.03	N/A N/A	N/A N/A	N/A 1.89	0.07	0.00	0.00
Opt-Out/Ex	8100	8100 Base Heating, Other Electric	Non-Jurisdictional	2014	2054	0.07	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.17	0.00	0.00
Opt-Out/Ex	9500	9500 Base Miscellaneous	Non-Jurisdictional	2014	2054	4.28	0.67	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.28	0.67	0.00
Opt-Out/Ex	9500	9501 Xmisc	Non-Jurisdictional	2014	2054	4.28	0.67	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1036 Lighting Control Tuneup (base 4L4'T8), 2020	Misc Misc	2020 2020	2054 2054	9.64 9.53	1.64 1.63	0.00 0.11	0.00 0.11	0% 1%	0.00 0.01	0.00 0.01	0% 1%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 3.68	9.64	1.64	0.00 0.11
Opt-Out/Ex	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Misc	2020	2054	8.81	1.53	0.72	0.83	9%	0.10	0.11	6%	0.02	0.02	0	0	3.20			0.72
Opt-Out/Ex	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Misc	2020	2054	7.89	1.37	0.91	1.75	18%	0.15	0.26	16%	0.02	0.02	0	0	2.73			0.91
Opt-Out/Ex	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Misc	2020	2054	7.80	1.36	0.09	1.84	19%	0.02	0.28	17%	0.45	0.04	3	0	0.12			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Misc Misc	2020 2020	2054 2054	7.62 6.39	1.35 1.14	0.18 1.23	2.02 3.25	21% 34%	0.01 0.21	0.28 0.49	17% 30%	0.07 0.22	0.04 0.11	2	0	0.74 0.29			0.00
Opt-Out/Ex	1030	1035 LED Troffer (base 4L4T8), 2020	Misc	2020	2054	5.85	1.05	0.55	3.79	39%	0.09	0.59	36%	0.18	0.12	1	1	0.34			0.00
Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Misc	2020	2054	7.38	1.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.38	1.25	0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Misc Misc	2020 2020	2054 2054	7.29 6.74	1.25 1.17	0.09 0.55	0.09 0.64	1% 9%	0.01 0.07	0.01 0.08	1% 6%	0.02	0.02	0	0	2.99 2.60			0.09 0.55
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Misc	2020	2054	6.11	1.17	0.64	1.28	17%	0.07	0.08	15%	0.02	0.02	0	0	2.00			0.55
Opt-Out/Ex	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Misc	2020	2054	5.33	0.93	0.78	2.05	28%	0.13	0.32	26%	0.05	0.03	ō	0	1.04			0.78
Opt-Out/Ex	1130	1134 ROB 2L4' LED Tube, 2020	Misc	2020	2054	5.07	0.89	0.26	2.31	31%	0.04	0.37	29%	0.19	0.05	1	0	0.32			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1135 LED Troffer (base 2L4'T8), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Misc Misc	2020 2020	2054 2054	4.64 4.53	0.81 0.81	0.43	2.74 2.85	37% 39%	0.07	0.44 0.44	35% 35%	0.25	0.08	1 4	1	0.25			0.00 0.00
Opt-Out/Ex	1200	1200 Base Other Fluorescent Fixture	Misc	2014	2054	0.10	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.10	0.02	0.00
Opt-Out/Ex	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Misc	2014	2054	0.09	0.02	0.01	0.01	7%	0.00	0.00	3%	0.01	0.01	0	0	4.71			0.01
Opt-Out/Ex	1200 1200	1201 ROB High Performance T8 (base other fluorescent)	Misc Misc	2014	2054 2054	0.09	0.02	0.01	0.01	14% 20%	0.00	0.00	10% 12%	0.08	0.04	0	0	0.71 0.63			0.00
Opt-Out/Ex Opt-Out/Ex	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Misc	2014	2054	0.08	0.02	0.01	0.02	26%	0.00	0.00	17%	0.08	0.05	1	1	0.55			0.00
Opt-Out/Ex	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Misc	2020	2054	11.75	1.99	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.75	1.99	0.00
Opt-Out/Ex	1330	1332 LEDs (base incandescent flood) 2020	Misc	2020	2054	2.48	0.42	9.27	9.27	79%	1.57	1.57	79%	0.00	0.00	0	0	12.68			9.27
Opt-Out/Ex Opt-Out/Ex	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	Misc Misc	2020 2020	2054 2054	4.23 0.97	0.72 0.16	0.00 3.26	0.00 3.26	0% 77%	0.00 0.55	0.00 0.55	0% 77%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 10.66	4.23	0.72	0.00 3.26
Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Misc	2020	2054	3.11	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.11	0.53	0.00
Opt-Out/Ex	1530	1532 LEDs (base incandescent A-line 53W) 2020	Misc	2020	2054	0.96	0.16	2.15	2.15	69%	0.37	0.37	69%	0.01	0.01	0	0	7.79			2.15
Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020	Misc	2020	2054	1.90	0.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.90	0.32	0.00
Opt-Out/Ex Opt-Out/Ex	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Misc Misc	2020 2020	2054 2054	1.38 2.43	0.23 0.41	0.53 0.00	0.53 0.00	28% 0%	0.09	0.09	28% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.05 N/A	2.43	0.41	0.53 0.00
Opt-Out/Ex	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Misc	2020	2054	1.80	0.41	0.63	0.63	26%	0.00	0.11	26%	0.04	0.04	0	0	1.39	2.43	0.41	0.63
Opt-Out/Ex	1800	1800 BaseMetal Halide, 465W	Misc	2014	2054	4.40	0.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.40	0.75	0.00
Opt-Out/Ex	1800	1801 T5 (240W) (base metal halide)	Misc	2014	2054	2.91	0.49	1.49	1.49	34%	0.25	0.25	34%	0.01	0.01	0	0	7.55			1.49
Opt-Out/Ex Opt-Out/Ex	1800 1800	1806 Occupancy Sensor, High Bay T5 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Misc Misc	2014 2014	2054 2054	2.81 2.60	0.49 0.46	0.10 0.21	1.58 1.79	36% 41%	0.00	0.26 0.28	34% 38%	0.02 0.05	0.01 0.01	1 0	0	2.00 1.38			0.10 0.21
Opt-Out/Ex	1850	1850 Base CFL Exit Sign	Misc	2014	2054	0.52	0.46	0.21	0.00	0%	0.00	0.28	0%	N/A	N/A	N/A	N/A	N/A	0.52	0.09	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	Misc	2014	2054	0.28	0.05	0.24	0.24	46%	0.04	0.04	46%	0.03	0.03	0	0	1.95			0.24
Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Misc	2014	2054	7.31	0.57	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.31	0.57	0.00
Opt-Out/Ex Opt-Out/Ex	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Misc Misc	2014 2014	2054 2054	3.52 2.49	0.27 0.20	3.79 1.03	3.79 4.82	52% 66%	0.29 0.07	0.29 0.37	52% 65%	0.08 0.54	0.08 0.18	1 8	1 2	0.74 0.11			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Misc	2014	2054	2.28	1.76	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.28	1.76	0.00
Opt-Out/Ex	2000	2010 Ceiling/roof Insulation - Chiller	Misc	2014	2054	2.25	1.74	0.03	0.03	1%	0.02	0.02	1%	0.02	0.02	0	0	6.00			0.03
Opt-Out/Ex	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Misc	2014	2054	2.06	1.59	0.19	0.22	10%	0.15	0.17	10%	0.04	0.04	0	0	3.08			0.19
Opt-Out/Ex Opt-Out/Ex	2000 2000	2013 High Efficiency Chiller Motors 2006 VSD for Chiller Pumps and Towers	Misc Misc	2014 2014	2054 2054	2.06 1.98	1.59 1.56	0.00	0.22 0.30	10% 13%	0.00	0.17 0.20	10% 12%	0.06	0.04	0	0	1.99 1.71			0.00
Opt-Out/EX	2000	2000 100 Online i unipa una Towella	IVIIOU	2014	2004	1.50	1.50	0.00	0.30	1370	0.03	0.20	12/0	0.00	0.04	U	U	1.71			0.00

APPENDIX H

Base Avoided Costs

DSM ASSY	ST ADDITIV	E SUPPLY ANALYSIS				Year	2014		Total	Total Marginal Average Marginal Ave								SUPPL verage Total					
Vintage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Average Energy	Capacity	Average Capacity						
Sgmt		Measure Number Measure	Building Type	Start Year	End Year	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base	Economic GWH		
Opt-Out/Ex	2000	2003 EMS - Chiller	Misc	2014	2054	1.80	1.53	0.17	0.48	21%	0.03	0.24	14%	0.07	0.05	0	0	0.91	GWH	141.44	0.00		
Opt-Out/Ex		2012 Duct Testing/Sealing	Misc	2014	2054	1.47	1.27	0.33	0.81	35%	0.26	0.49	28%	0.21	0.12	0	0	0.55			0.00		
Opt-Out/Ex Opt-Out/Ex	2000 2000	2002 Window Film (Standard) - Chiller 2004 Cool Roof - Chiller	Misc Misc	2014 2014	2054 2054	1.46 1.46	1.26 1.26	0.01	0.82 0.82	36% 36%	0.01 0.00	0.50 0.50	28% 29%	0.76 3.29	0.12 0.13	1	0	0.12			0.00		
Opt-Out/Ex	2000	2011 Duct/Pipe Insulation - Chiller	Misc	2014	2054	1.44	1.25	0.02	0.84	37%	0.00	0.52	29%	3.29	0.13	5	0	0.03			0.00		
Opt-Out/Ex	2000	2008 New Economizer - Chiller	Misc	2014	2054	1.44	1.25	0.00	0.84	37%	0.00	0.52	29%	36634.21	0.28	184,662	0	0.00			0.00		
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Misc Misc	2014	2054 2054	53.61 53.61	41.46 41.46	0.00	0.00	0% 0%	0.00	0.00	0%	N/A 0.02	N/A 0.02	N/A	N/A	N/A	53.61	41.46	0.00		
Opt-Out/Ex Opt-Out/Ex	2100 2100	2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	Misc	2014 2014	2054	41.28	31.92	12.33	12.33	23%	9.53	9.54	0% 23%	0.02	0.02	0	0	6.16 3.27			0.00 12.33		
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Misc	2014	2054	38.85	30.04	2.43	14.76	28%	1.88	11.41	28%	0.21	0.06	0	Ö	0.54			0.00		
Opt-Out/Ex	2100	2106 Prog. Thermostat - DX	Misc	2014	2054	38.11	29.90	0.74	15.50	29%	0.15	11.56	28%	0.12	0.07	1	0	0.46			0.00		
Opt-Out/Ex Opt-Out/Ex	2100 2100	2108 Optimize Controls - DX 2115 Window Film (Standard) - DX	Misc Misc	2014 2014	2054 2054	37.47 37.33	29.77 29.66	0.63 0.15	16.13 16.28	30% 30%	0.13 0.11	11.69 11.80	28% 28%	0.13 0.59	0.07	1	0	0.40			0.00		
Opt-Out/Ex	2100	2107 Cool Roof - DX	Misc	2014	2054	37.25	29.60	0.13	16.35	31%	0.06	11.86	29%	3.03	0.07	4	0	0.13			0.00		
Opt-Out/Ex	2100	2114 Duct/Pipe Insulation - DX	Misc	2014	2054	37.02	29.42	0.24	16.59	31%	0.18	12.04	29%	3.62	0.14	5	0	0.03			0.00		
Opt-Out/Ex Opt-Out/Ex	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Misc Misc	2014 2014	2054 2054	6.61 5.79	5.11 4.48	0.00 0.82	0.00 0.82	0% 12%	0.00 0.63	0.00 0.63	0% 12%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 3.05	6.61	5.11	0.00 0.82		
Opt-Out/Ex		2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Misc	2014	2054	6.61	5.11	0.02	0.02	0%	0.00	0.00	0%	0.04 N/A	0.04 N/A	N/A	N/A	3.05 N/A	6.61	5.11	0.02		
Opt-Out/Ex	2300	2301 HE PTAC, EER=9.6, 1 ton	Misc	2014	2054	5.72	4.42	0.90	0.90	14%	0.69	0.69	14%	0.08	0.08	0	0	1.33	0.01	0.11	0.90		
Opt-Out/Ex		2302 Occupancy Sensor (hotels)	Misc	2014	2054	4.86	3.56	0.86	1.76	27%	0.86	1.55	30%	0.26	0.17	0	0	0.40			0.00		
Opt-Out/Ex Opt-Out/Ex	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Misc Misc	2014 2014	2054 2054	19.47 19.13	5.53 5.44	0.00	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.26	19.47	5.53	0.00		
Opt-Out/Ex	3000	3002 Variable Speed Drive Control, 5 HP	Misc	2014	2054	13.38	5.44	5.75	6.09	31%	0.10	0.10	9%	0.05	0.05	1	1	1.17			5.75		
Opt-Out/Ex	3000	3003 Demand Controlled Ventilation	Misc	2014	2054	13.12	4.89	0.26	6.35	33%	0.14	0.65	12%	1.56	0.11	3	1	0.06			0.00		
Opt-Out/Ex		3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Misc	2014	2054	15.52	4.41	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.52	4.41	0.00		
Opt-Out/Ex Opt-Out/Ex	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Misc Misc	2014 2014	2054 2054	13.28 12.37	3.84 3.77	2.24 0.91	2.24 3.15	14% 20%	0.57 0.06	0.57 0.64	13% 14%	0.03 0.04	0.03	0	0	2.40 1.26			2.24 0.91		
Opt-Out/Ex	3100	3102 Variable Speed Drive Control, 15 HP	Misc	2014	2054	8.65	3.51	3.72	6.87	44%	0.26	0.90	20%	0.04	0.05	1	0	0.86			0.00		
Opt-Out/Ex	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Misc	2014	2054	8.52	3.47	0.13	7.00	45%	0.04	0.94	21%	0.21	0.05	1	0	0.38			0.00		
Opt-Out/Ex	3100	3105 Energy Recovery Ventilation (ERV)	Misc	2014	2054	8.41	3.41	0.11	7.11	46%	0.06	1.00	23%	0.43	0.06	1	0	0.24			0.00		
Opt-Out/Ex Opt-Out/Ex	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Misc Misc	2014 2014	2054 2054	8.25 12.31	3.32 3.50	0.16 0.00	7.27 0.00	47% 0%	0.09	1.09 0.00	25% 0%	1.97 N/A	0.10 N/A	N/A	N/A	0.05 N/A	12.31	3.50	0.00		
Opt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP	Misc	2014	2054	11.47	3.44	0.84	0.84	7%	0.06	0.06	2%	0.03	0.03	0	0	1.47	12.51	5.50	0.84		
Opt-Out/Ex	3200	3202 Variable Speed Drive Control, 40 HP	Misc	2014	2054	8.02	3.19	3.45	4.29	35%	0.24	0.30	9%	0.10	0.09	1	1	0.55			0.00		
Opt-Out/Ex	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Misc Misc	2014 2014	2054 2054	7.99 7.83	3.19 3.10	0.03 0.16	4.33 4.48	35% 36%	0.01 0.09	0.31	9% 11%	0.51 1.65	0.09 0.15	2	1 2	0.16 0.06			0.00		
Opt-Out/Ex Opt-Out/Ex		4000 Base Built-Up Refrigeration System	Misc	2014	2054	0.00	0.00	0.10	0.00	0%	0.00	0.00	0%	N/A	0.13 N/A	N/A	N/A	N/A	0.00	0.00	0.00		
Opt-Out/Ex	4100	4100 Base Self-Contained Refrigeration	Misc	2014	2054	13.77	2.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.77	2.07	0.00		
Opt-Out/Ex	4100	4103 Night covers for display cases (self-contained)	Misc	2014	2054	12.53	1.89	1.24	1.24	9%	0.19	0.19	9%	0.00	0.00	0	0	36.38			1.24		
Opt-Out/Ex	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4108 Energy-Star Refrigerator, glass door	Misc Misc	2014 2014	2054 2054	12.35 12.19	1.86 1.83	0.18 0.17	1.42 1.58	10% 11%	0.03	0.21 0.24	10% 11%	0.00 0.01	0.00	0	0	32.37 10.44			0.18 0.17		
Opt-Out/Ex	4100	4106 Energy-Star Refrigerator, solid door	Misc	2014	2054	11.76	1.77	0.42	2.01	15%	0.02	0.30	15%	0.01	0.00	0	Ö	10.17			0.42		
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Misc	2014	2054	11.72	1.76	0.05	2.05	15%	0.01	0.31	15%	0.02	0.00	0	0	3.63			0.05		
Opt-Out/Ex Opt-Out/Ex	4100 4100	4112 Reach-in unit occupancy sensors	Misc Misc	2014 2014	2054 2054	11.72 11.71	1.76 1.76	0.00 0.01	2.05 2.07	15% 15%	0.00	0.31 0.31	15% 15%	0.31 0.35	0.00	2	0	0.19 0.15			0.00		
Opt-Out/Ex	5000	4105 Bi-level LED Case Lighting (self-contained units) 2014 5000 Base Desktop PC	Misc	2014	2054	0.48	0.07	0.01	0.00	0%	0.00	0.00	0%	0.35 N/A	0.00 N/A	N/A	N/A	0.15 N/A	0.48	0.07	0.00		
Opt-Out/Ex	5000	5001 PC Network Power Management Enabling	Misc	2014	2054	0.26	0.06	0.21	0.21	45%	0.02	0.02	23%	0.01	0.01	0	0	3.90			0.21		
Opt-Out/Ex	5000	5002 Energy Star or Better PC	Misc	2014	2054	0.18	0.04	0.08	0.30	62%	0.01	0.03	40%	0.03	0.02	0	0	1.98			0.08		
Opt-Out/Ex Opt-Out/Ex	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Misc Misc	2014 2014	2054 2054	0.01 0.01	0.00	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.43	0.01	0.00	0.00		
Opt-Out/Ex	5100	5101 Laptop Network Power Management Enabling	Misc	2014	2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	1.13	0.10	7	1	0.05			0.00		
Opt-Out/Ex	5200	5200 Base Monitor, CRT	Misc	2014	2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00		
Opt-Out/Ex Opt-Out/Ex	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Misc Misc	2014 2014	2054 2054	0.02	0.00	0.02 0.00	0.02	56% 67%	0.00	0.00	56% 62%	0.00 0.02	0.00	0	0	43.26 2.81			0.02		
Opt-Out/Ex	5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Misc	2014	2054	0.01	0.00	0.00	0.03	70%	0.00	0.00	64%	0.02	0.00	1	0	0.26			0.00		
Opt-Out/Ex	5300	5300 Base Monitor, LCD	Misc	2014	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00		
Opt-Out/Ex	5300	5301 Energy Star or Better Monitor - LCD	Misc	2014	2054	0.05	0.01	0.01	0.01	18%	0.00	0.00	18%	0.01	0.01	0	0	6.34			0.01		
Opt-Out/Ex Opt-Out/Ex	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Misc Misc	2014 2014	2054 2054	0.05 0.05	0.01 0.01	0.00	0.01 0.02	21% 27%	0.00	0.00	19% 21%	0.07 0.21	0.02 0.06	1 5	0	0.63 0.21			0.00		
Opt-Out/Ex		5400 Base Copier	Misc	2014	2054	0.11	0.02	0.00	0.02	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.02	0.00		
Opt-Out/Ex	5400	5401 Energy Star or Better Copier	Misc	2014	2054	0.10	0.01	0.01	0.01	13%	0.00	0.00	13%	0.00	0.00	0	0	31.86			0.01		
Opt-Out/Ex	5400	5402 Copier Power Management Enabling	Misc	2014	2054	0.09	0.01	0.00	0.02	18%	0.00	0.00	16%	0.09	0.02 N/A	1	0	0.55	0.00	0.00	0.00		
Opt-Out/Ex Opt-Out/Ex	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Misc Misc	2014 2014	2054 2054	0.02 0.01	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.07	0.02	0.00	0.00		
Opt-Out/Ex	5500	5501 Multifunction Power Management Enabling	Misc	2014	2054	0.01	0.00	0.00	0.01	37%	0.00	0.00	31%	0.23	0.08	3	1	0.20			0.00		
Opt-Out/Ex	5600	5600 Base Printer	Misc	2014	2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00		
Opt-Out/Ex	5600 5600	5602 ENERGY STAR Printer	Misc Misc	2014 2014	2054 2054	0.03	0.00	0.02	0.02	35% 45%	0.00	0.00	35% 40%	0.00 0.05	0.00 0.01	0	0	41.71 0.93			0.02		
Opt-Out/Ex Opt-Out/Ex	5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Misc	2014	2054	5.32	0.00	0.00	0.02	45% 0%	0.00	0.00	40% 0%	0.05 N/A	0.01 N/A	N/A	N/A	0.93 N/A	5.32	0.81	0.00		
Opt-Out/Ex	5700	5701 Data Center Improved Operations	Misc	2014	2054	4.79	0.73	0.53	0.53	10%	0.08	0.08	10%	0.00	0.00	0	0	105.02			0.53		
Opt-Out/Ex	5700	5702 Data Center Best Practices	Misc	2014	2054	4.18	0.63	0.61	1.14	21%	0.09	0.17	21%	0.00	0.00	0	0	42.75			0.61		
Opt-Out/Ex Opt-Out/Ex	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Misc Misc	2014 2014	2054 2054	3.95 0.77	0.60 0.11	0.23 0.00	1.38 0.00	26% 0%	0.04	0.21 0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	22.17 N/A	0.77	0.11	0.23 0.00		
Opt-Out/Ex		6007 Heat Trap	Misc	2014	2054	0.73	0.11	0.04	0.04	5%	0.00	0.00	5%	0.01	0.01	0	0	3.99	····	0	0.04		

APPENDIX H

Base Avoided Costs

		mpt/Nonjurisdictional Existing				.,															OLIDAL V
DSM ASSYS Vintage	ST ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
viiitago				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity				
		asure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt Opt-Out/Ex	Number Nu 6000	mber Measure 6002 High Efficiency Water Heater (electric)	Type Misc	Year 2014	Year 2054	GWH 0.72	0.11	Savings 0.01	0.05	Savings 7%	Savings 0.00	0.01	Savings 7%	\$/kWH 0.03	\$/kWH 0.02	\$/kW 0	\$/kW	2.13	GWH	MW	0.01
Opt-Out/Ex		6004 Tankless Water Heater	Misc	2014	2054	0.72	0.10	0.05	0.03	14%	0.00	0.02	14%	0.05	0.02	0	0	1.52			0.05
Opt-Out/Ex	6000	6003 Hot Water Pipe Insulation	Misc	2014	2054	0.65	0.10	0.01	0.12	16%	0.00	0.02	16%	0.05	0.03	0	0	1.18			0.01
Opt-Out/Ex	6000	6006 Heat Recovery Unit	Misc	2014	2054	0.63	0.09	0.02	0.14	18%	0.00	0.02	18%	0.05	0.04	0	0	1.10			0.02
Opt-Out/Ex Opt-Out/Ex	6000 7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Misc Misc	2014 2014	2054 2054	0.60 0.12	0.09 0.02	0.02 0.00	0.17 0.00	22% 0%	0.00	0.02 0.00	22% 0%	0.15 N/A	0.05 N/A	1 N/A	0 N/A	0.42 N/A	0.12	0.02	0.00
Opt-Out/Ex	7000	7000 base Reinigerated Veriding Macrimes 7001 Vending Misers (Refrigerated units)	Misc	2014	2054	0.12	0.02	0.00	0.00	16%	0.00	0.00	8%	0.03	0.03	0	0	1.82	0.12	0.02	0.00
Opt-Out/Ex	7000	7002 Vending Misers (Refrigerated drifts) 7002 Vending Misers (Refrigerated glass-front units)	Misc	2014	2054	0.09	0.02	0.02	0.02	25%	0.00	0.00	12%	0.05	0.03	1	0	1.00			0.00
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	7100	7101 Vending Misers (Non-Refrigerated)	Misc	2014	2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	23%	0.44	0.44	5	5	0.11			0.00
Opt-Out/Ex Opt-Out/Ex	7200 7300	7200 Base Oven 7300 Base Fryer	Misc Misc	2014 2014	2054 2054	0.56 1.16	0.09 0.19	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.56 1.16	0.09 0.19	0.00
Opt-Out/Ex		7301 Efficient Fryer	Misc	2014	2054	1.08	0.18	0.07	0.00	6%	0.00	0.00	6%	1.65	1.65	10	10	0.04	1.10	0.15	0.00
Opt-Out/Ex	7400	7400 Base Steamer	Misc	2014	2054	0.07	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.07	0.01	0.00
Opt-Out/Ex	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex		8100 Base Heating, Other Electric 9500 Base Miscellaneous	Misc Misc	2014 2014	2054 2054	5.50 44.56	0.00 7.41	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	5.50 44.56	0.00 7.41	0.00
Opt-Out/Ex		9501 Xmisc	Misc	2014	2054	44.56	7.41	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00	44.56	7.41	0.00
VA VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Non-Jurisdictional	2020	2054	1,337.88	237.97	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1,337.88	237.97	0.00
VA	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Non-Jurisdictional	2020	2054	1,323.24	236.69	14.64	14.64	1%	1.29	1.29	1%	0.01	0.01	0	0	3.98			14.64
VA	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Non-Jurisdictional	2020	2054	1,223.50	222.57	99.75	114.38	9%	14.12	15.41	6%	0.02	0.02	0	0	3.50			99.75
VA VA	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	1,097.81 958.13	200.21 175.36	125.69 139.68	240.07 379.75	18% 28%	22.36 24.84	37.77 62.61	16% 26%	0.02 0.04	0.02	0	0	2.66 1.27			125.69 139.68
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Non-Jurisdictional	2020	2054	915.80	173.50	42.33	422.08	32%	1.85	64.46	27%	0.04	0.03	2	0	0.70			0.00
VA	1030	1034 ROB 4L4' LED Tube, 2020	Non-Jurisdictional	2020	2054	768.24	147.27	147.56	569.64	43%	26.25	90.71	38%	0.27	0.09	2	1	0.24			0.00
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	Non-Jurisdictional	2020	2054	702.66	135.60	65.58	635.22	47%	11.67	102.37	43%	0.22	0.11	1	1	0.29			0.00
VA	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Non-Jurisdictional	2020	2054	266.78	47.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	266.78	47.45	0.00
VA VA	1130 1130	1136 Lighting Control Tuneup (base 2L4T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	263.81 243.92	47.19 44.38	2.97 19.89	2.97 22.85	1% 9%	0.26 2.82	0.26 3.08	1% 6%	0.02	0.02	0	0	2.78 2.45			2.97 19.89
VA	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Non-Jurisdictional	2020	2054	219.71	40.07	24.21	47.07	18%	4.31	7.38	16%	0.03	0.02	0	0	2.11			24.21
VA	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Non-Jurisdictional	2020	2054	191.76	35.10	27.95	75.02	28%	4.97	12.36	26%	0.06	0.04	0	0	1.01			27.95
VA	1130	1134 ROB 2L4' LED Tube, 2020	Non-Jurisdictional	2020	2054	182.49	33.45	9.27	84.29	32%	1.65	14.00	30%	0.21	0.06	1	0	0.32			0.00
VA VA	1130 1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1135 LED Troffer (base 2L4'T8), 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	174.42 159.53	33.10 30.45	8.06 14.89	92.35 107.24	35% 40%	0.35 2.65	14.36 17.00	30% 36%	0.13 0.28	0.06	3	0	0.38 0.24			0.00
VA	1200	1200 Base Other Fluorescent Fixture	Non-Jurisdictional	2014	2054	25.29	4.50	0.00	0.00	0%	0.00	0.00	0%	0.26 N/A	0.09 N/A	N/A	N/A	0.24 N/A	25.29	4.50	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Non-Jurisdictional	2014	2054	23.60	4.35	1.69	1.69	7%	0.15	0.15	3%	0.01	0.01	0	0	6.44			1.69
VA	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Non-Jurisdictional	2014	2054	21.82	4.10	1.78	3.47	14%	0.25	0.40	9%	0.07	0.04	1	0	0.89			0.00
VA	1200	1201 ROB High Performance T8 (base other fluorescent)	Non-Jurisdictional	2014	2054	19.86	3.75	1.97	5.43	21%	0.35	0.75	17%	0.09	0.06	1 2	0	0.63			0.00
VA VA	1200 1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures 1202 ROB Low Watt High Performance T8 (base other fluorescent)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	17.91 15.63	3.66 3.26	1.95 2.28	7.38 9.66	29% 38%	0.09	0.84 1.24	19% 28%	0.10 0.21	0.07	1	1	0.48 0.27			0.00
VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Non-Jurisdictional	2020	2054	235.95	41.97	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	235.95	41.97	0.00
VA	1330	1332 LEDs (base incandescent flood) 2020	Non-Jurisdictional	2020	2054	58.86	10.47	177.09	177.09	75%	31.50	31.50	75%	0.00	0.00	0	0	14.52			177.09
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Non-Jurisdictional	2020	2054	84.94	15.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	84.94	15.11	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 20201530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	22.87 62.53	4.07 11.12	62.08	62.08 0.00	73% 0%	11.04	11.04	73% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	12.16 N/A	62.53	11.12	62.08
VA	1530	1532 LEDs (base incandescent A-Line 53W) 2020	Non-Jurisdictional	2020	2054	22.33	3.97	40.20	40.20	64%	7.15	7.15	64%	0.01	0.01	0	0	8.72	02.33	11.12	40.20
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Non-Jurisdictional	2020	2054	78.05	13.88	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	78.05	13.88	0.00
VA	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Non-Jurisdictional	2020	2054	56.43	10.04	21.62	21.62	28%	3.85	3.85	28%	0.05	0.05	0	0	1.01			21.62
VA VA	1730 1730	1730 Base CFL 23W to screw-in replacement 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	99.73 73.80	17.74 13.13	0.00 25.93	0.00 25.93	0% 26%	0.00 4.61	0.00 4.61	0% 26%	N/A 0.04	N/A 0.04	N/A	N/A 0	N/A 1.35	99.73	17.74	0.00 25.93
VA VA	1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Non-Jurisdictional	2020	2054	179.43	31.92	0.00	0.00	26% 0%	0.00	0.00	26% 0%	0.04 N/A	0.04 N/A	N/A	N/A	1.35 N/A	179.43	31.92	0.00
VA	1800	1801 T5 (240W) (base metal halide)	Non-Jurisdictional	2014	2054	118.76	21.12	60.66	60.66	34%	10.79	10.79	34%	0.01	0.01	0	0	6.49			60.66
VA	1800	1806 Occupancy Sensor, High Bay T5	Non-Jurisdictional	2014	2054	114.95	20.96	3.81	64.47	36%	0.17	10.96	34%	0.03	0.01	1	0	1.68			3.81
VA VA	1800 1850	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1850 Base CFL Exit Sign	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	106.29 14.79	19.73 2.63	8.67 0.00	73.14 0.00	41% 0%	1.23 0.00	12.18 0.00	38% 0%	0.04 N/A	0.02 N/A	0 N/A	0 N/A	1.65 N/A	14.79	2.62	8.67 0.00
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Non-Jurisdictional Non-Jurisdictional	2014	2054	14.79 8.14	2.63 1.45	6.66	6.66	0% 45%	1.18	1.18	0% 45%	0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.01	14.79	2.63	6.66
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Non-Jurisdictional	2014	2054	214.61	8.98	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	214.61	8.98	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Non-Jurisdictional	2014	2054	199.35	7.01	15.26	15.26	7%	1.97	1.97	22%	0.04	0.04	0	0	1.79			15.26
VA	1900	1902 LED Outdoor Area Lighting	Non-Jurisdictional	2014	2054	95.93	2.69	103.42	118.69	55%	4.33	6.30	70%	0.09	0.08	2	2	0.65			0.00
VA VA	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	67.81 639.79	1.62 471.58	28.12 0.00	146.80 0.00	68% 0%	1.06 0.00	7.36 0.00	82% 0%	0.58 N/A	0.18 N/A	15 N/A	4 N/A	0.10 N/A	639.79	471.58	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Non-Jurisdictional	2014	2054	634.60	467.75	5.20	5.20	1%	3.83	3.83	1%	0.01	0.01	0	0	10.57	033.13	→11.50	5.20
VA	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Non-Jurisdictional	2014	2054	580.42	427.82	54.17	59.37	9%	39.93	43.76	9%	0.05	0.05	0	0	2.40			54.17
VA	2000	2005 Chiller Tune Up/Diagnostics	Non-Jurisdictional	2014	2054	577.09	426.58	3.33	62.70	10%	1.24	45.00	10%	0.04	0.04	0	0	1.87			3.33
VA	2000	2013 High Efficiency Chiller Motors	Non-Jurisdictional	2014	2054	575.85	425.67	1.24	63.94	10%	0.91	45.91	10%	0.08	0.05	0	0	1.55			1.24
VA VA	2000	2006 VSD for Chiller Pumps and Towers 2003 EMS - Chiller	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	564.16 542.51	421.32 417.28	11.68 21.66	75.63 97.28	12% 15%	4.35 4.04	50.26 54.30	11% 12%	0.06	0.05	0	0	1.36 0.78			11.68 0.00
VA	2000	2012 Duct Testing/Sealing - Chiller	Non-Jurisdictional	2014	2054	441.10	342.53	101.41	198.69	31%	74.75	129.05	27%	0.05	0.00	0	0	0.46			0.00
VA	2000	2002 Window Film (Standard) - Chiller	Non-Jurisdictional	2014	2054	433.63	337.03	7.47	206.16	32%	5.50	134.55	29%	0.35	0.16	ō	Ō	0.26			0.00
VA	2000	2008 New Economizer - Chiller	Non-Jurisdictional	2014	2054	398.83	330.53	34.81	240.97	38%	6.50	141.04	30%	0.30	0.18	2	0	0.19			0.00
VA VA	2000 2000	2004 Cool Roof - Chiller 2011 Duct/Pipe Insulation - Chiller	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	397.35 394.07	329.45 327.03	1.47 3.28	242.44 245.72	38% 38%	1.08 2.42	142.13 144.55	30% 31%	0.67 3.41	0.18	1 5	0	0.13			0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Non-Jurisdictional	2014	2054	788.26	581.01	0.00	0.00	0%	0.00	0.00	0%	N/A	0.23 N/A	N/A	N/A	N/A	788.26	581.01	0.00
VA	2100	2113 Ceiling/roof Insulation - DX	Non-Jurisdictional	2014	2054	788.25	581.01	0.01	0.01	0%	0.00	0.00	0%	0.01	0.01	0	0	10.81			0.01

DNV GL H-19 1/5/2015

APPENDIX H

Base Avoided Costs

	ASSYST ADDITIVE S	SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintag	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average	Total Resource			
		asure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Capacity Cost	Cost Test	Base	Base	Economic
Sgmt VA	Number Nu 2100	mber Measure 2102 DX Packaged System, EER=13.4, 10 tons	Type Non-Jurisdictional	2014	Year 2054	606.95	MW 447.37	Savings 181.30	181.30	Savings 23%	Savings 133,63	MW 133.64	Savings 23%	\$/kWH 0.04	\$/kWH 0.04	\$/kW	\$/kW	2.53	GWH	MW	181.30
VA	2100	2108 Optimize Controls - DX	Non-Jurisdictional	2014	2054	596.73	445.47	10.23	191.53	24%	1.91	135.54	23%	0.10	0.04	1	ō	0.53			0.00
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Non-Jurisdictional	2014 2014	2054	594.65	444.69	2.08	193.61	25%	0.77	136.32	23%	0.14	0.05	0	0	0.47			0.00
VA VA	2100 2100	2111 Economizer Repair - DX 2112 Duct Testing/Sealing - DX	Non-Jurisdictional Non-Jurisdictional	2014	2054 2054	586.00 550.95	435.43 409.59	8.64 35.05	202.25 237.31	26% 30%	9.27 25.84	145.58 171.42	25% 30%	0.20 0.28	0.05 0.09	0	0	0.44			0.00
VA	2100	2106 Prog. Thermostat - DX	Non-Jurisdictional	2014	2054	532.42	406.13	18.53	255.84	32%	3.46	174.88	30%	0.16	0.09	1	0	0.35			0.00
VA VA	2100 2100	2115 Window Film (Standard) - DX	Non-Jurisdictional	2014 2014	2054 2054	524.69 501.30	400.43 396.07	7.73 23.38	263.57 286.95	33% 36%	5.70 4.36	180.58 184.94	31%	0.35	0.10 0.11	0	0	0.26			0.00
VA	2100	2109 Economizer - DX 2107 Cool Roof - DX	Non-Jurisdictional Non-Jurisdictional	2014	2054	498.63	396.07	23.38	289.63	36%	1.97	184.94	32% 32%	0.29	0.11	1	0	0.20 0.14			0.00
VA	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Non-Jurisdictional	2014	2054	498.59	394.09	0.04	289.67	37%	0.01	186.92	32%	0.66	0.12	4	0	0.09			0.00
VA	2100 2200	2114 Duct/Pipe Insulation - DX	Non-Jurisdictional	2014 2014	2054 2054	495.38 342.49	391.73 252.44	3.20	292.87	37% 0%	2.36	189.28	33%	3.34 N/A	0.15 N/A	5	0	0.03			0.00
VA VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Non-Jurisdictional Non-Jurisdictional	2014	2054	342.49	252.44	42.36	42.36	12%	31.22	0.00 31.22	0% 12%	0.03	0.03	N/A 0	N/A 0	N/A 3.55	342.49	252.44	42.36
VA	2300	2300 Base PTAC, EER=8.3, 1 ton	Non-Jurisdictional	2014	2054	530.62	391.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	530.62	391.11	0.00
VA VA	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	488.60 390.32	143.21 136.02	0.00 98.28	0.00 98.28	0% 20%	0.00 7.19	0.00 7.19	0% 5%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.33	488.60	143.21	0.00 98.28
VA	3000	3002 Variable Speed Drive Control, 5 HP 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Non-Jurisdictional	2014	2054	383.78	134.10	6.54	104.82	21%	1.92	9.11	6%	0.02	0.02	0	0	1.79			6.54
VA	3000	3003 Demand Controlled Ventilation	Non-Jurisdictional	2014	2054	368.87	125.76	14.91	119.73	25%	8.35	17.45	12%	1.11	0.16	2	1	0.09			0.00
VA VA	3100 3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3102 Variable Speed Drive Control, 15 HP	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	254.70 203.47	74.65 70.91	0.00 51.23	0.00 51.23	0% 20%	0.00 3.75	0.00 3.75	0% 5%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.44	254.70	74.65	0.00 51.23
VA	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Non-Jurisdictional	2014	2054	203.47	70.91	2.11	53.34	21%	0.62	4.37	6%	0.01	0.01	0	0	3.93			2.11
VA	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Non-Jurisdictional	2014	2054	179.83	64.62	21.53	74.87	29%	5.67	10.04	13%	0.04	0.02	0	0	1.66			21.53
VA VA	3100 3100	3103 Air Handler Optimization, 15 HP 3105 Energy Recovery Ventilation (ERV)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	165.03 161.67	63.53 61.65	14.80 3.37	89.67 93.03	35% 37%	1.08	11.12 13.01	15% 17%	0.04 0.45	0.02 0.04	1	0	1.28 0.24			14.80
VA	3100	3107 Demand Controlled Ventilation	Non-Jurisdictional	2014	2054	155.39	58.13	6.28	99.32	39%	3.52	16.52	22%	1.37	0.04	2	1	0.24			0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Non-Jurisdictional	2014	2054	196.01	57.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	196.01	57.45	0.00
VA VA	3200 3200	3203 Air Handler Optimization, 40 HP	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	179.88 143.70	56.27 53.62	16.13 36.18	16.13 52.31	8% 27%	1.18 2.65	1.18 3.83	2% 7%	0.03 0.04	0.03	0	0	1.81 1.54			16.13 36.18
VA	3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	Non-Jurisdictional	2014	2054	143.70	53.45	0.60	52.51	27%	0.18	4.00	7%	0.04	0.03	1	0	0.45			0.00
VA	3200	3204 Demand Controlled Ventilation	Non-Jurisdictional	2014	2054	137.54	50.34	5.56	58.47	30%	3.11	7.12	12%	1.20	0.15	2	1	0.08			0.00
VA VA	4000 4100	4000 Base Built-Up Refrigeration System	Non-Jurisdictional	2014 2014	2054 2054	0.00 395.15	0.00 57.43	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 395.15	0.00 57.43	0.00
VA	4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Non-Jurisdictional Non-Jurisdictional	2014	2054	385.17	55.98	9.98	9.98	3%	1.45	1.45	3%	0.00	0.00	0	0	66.98	395.15	57.43	9.98
VA	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Non-Jurisdictional	2014	2054	378.91	55.07	6.26	16.24	4%	0.91	2.36	4%	0.00	0.00	0	0	27.85			6.26
VA VA	4100 4100	4109 Energy-Star Freezer, glass door 4106 Energy-Star Refrigerator, solid door	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	377.75 372.61	54.90 54.16	1.16 5.13	17.40 22.53	4% 6%	0.17	2.53 3.28	4% 6%	0.00	0.00	0	0	16.03 15.08			1.16 5.13
VA	4100	4108 Energy-Star Refrigerator, glass door	Non-Jurisdictional	2014	2054	367.40	53.40	5.22	27.75	7%	0.76	4.03	7%	0.00	0.00	0	0	7.15			5.22
VA	4100	4107 Energy-Star Freezer, solid door	Non-Jurisdictional	2014	2054	366.92	53.33	0.47	28.23	7%	0.07	4.10	7%	0.01	0.00	0	0	6.36			0.47
VA VA	4100 4100	4110 Energy Star Ice Machines 4112 Reach-in unit occupancy sensors	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	361.12 361.05	52.49 52.48	5.80 0.07	34.02 34.09	9% 9%	0.84 0.01	4.94 4.96	9% 9%	0.01 0.32	0.00	0	0	5.43 0.18			5.80 0.00
VA	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Non-Jurisdictional	2014	2054	360.88	52.45	0.17	34.26	9%	0.02	4.98	9%	0.32	0.01	3	0	0.15			0.00
VA	4100	4101 Strip curtains for walk-ins (self-contained)	Non-Jurisdictional	2014	2054	360.66	52.42	0.22	34.48	9%	0.03	5.01	9%	14.92	0.10	103	1	0.00			0.00
VA VA	5000 5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	68.50 37.28	9.95 7.66	0.00 31.22	0.00 31.22	0% 46%	0.00 2.29	0.00 2.29	0% 23%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 3.91	68.50	9.95	0.00 31.22
VA	5000	5002 Energy Star or Better PC	Non-Jurisdictional	2014	2054	27.36	6.22	9.92	41.14	60%	1.44	3.73	37%	0.03	0.02	0	0	1.97			9.92
VA	5100	5100 Base Laptop PC	Non-Jurisdictional	2014	2054	6.06	0.88	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.06	0.88	0.00
VA VA	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	4.91 4.81	0.71 0.70	1.15 0.10	1.15 1.25	19% 21%	0.17 0.01	0.17 0.18	19% 21%	0.01 1.13	0.01 0.10	0 8	0	5.38 0.04			1.15 0.00
VA	5200	5200 Base Monitor, CRT	Non-Jurisdictional	2014	2054	14.74	2.14	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.74	2.14	0.00
VA	5200	5201 Energy Star or Better Monitor - CRT	Non-Jurisdictional	2014	2054	7.34	1.07	7.40	7.40	50%	1.08	1.08	50%	0.00	0.00	0	0	48.58			7.40
VA VA	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	5.86 5.40	0.96 0.89	1.47 0.46	8.88 9.34	60% 63%	0.11 0.07	1.18 1.25	55% 58%	0.01 0.16	0.00 0.01	0	0	3.57 0.32			1.47 0.00
VA	5300	5300 Base Monitor, LCD	Non-Jurisdictional	2014	2054	15.83	2.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.83	2.30	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Non-Jurisdictional	2014	2054	13.36	1.94	2.47	2.47	16%	0.36	0.36	16%	0.01	0.01	0	0	6.47			2.47
VA VA	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	12.63 11.65	1.89 1.85	0.73	3.20 4.18	20% 26%	0.05	0.41 0.45	18% 19%	0.07 0.21	0.02 0.07	1 6	0	0.63 0.21			0.00
VA	5400	5400 Base Copier	Non-Jurisdictional	2014	2054	19.09	2.77	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	19.09	2.77	0.00
VA	5400	5401 Energy Star or Better Copier	Non-Jurisdictional	2014	2054	16.86	2.45	2.23	2.23	12%	0.32	0.32	12%	0.00	0.00	0	0	32.19			2.23
VA VA	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	16.08 2.74	2.39 0.40	0.78	3.01	16% 0%	0.06	0.38	14% 0%	0.08 N/A	0.02 N/A	1 N/A	0 N/A	0.57 N/A	2.74	0.40	0.00
VA	5500	5502 ENERGY STAR Multi-Function Printer	Non-Jurisdictional	2014	2054	2.05	0.30	0.69	0.69	25%	0.10	0.10	25%	0.01	0.01	0	0	8.99	2	0.10	0.69
VA	5500	5501 Multifunction Power Management Enabling	Non-Jurisdictional	2014	2054	1.70	0.27	0.35	1.04	38%	0.03	0.13	32%	0.23	0.08	3	.1.	0.20			0.00
VA VA	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	22.50 14.67	3.27 2.13	0.00 7.83	0.00 7.83	0% 35%	0.00 1.14	0.00 1.14	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 41.34	22.50	3.27	0.00 7.83
VA	5600	5601 Printer Power Management Enabling	Non-Jurisdictional	2014	2054	12.14	1.95	2.54	10.36	46%	0.19	1.32	40%	0.05	0.01	1	0	0.93			0.00
VA	5700	5700 Base Data Center/Server Room	Non-Jurisdictional	2014	2054	143.83	20.89	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	143.83	20.89	0.00
VA VA	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	129.45 112.98	18.80 16.41	14.38 16.47	14.38 30.85	10% 21%	2.09 2.39	2.09 4.48	10% 21%	0.00	0.00	0	0	104.01 42.34			14.38 16.47
VA	5700	5703 Data Center State of the Art practices	Non-Jurisdictional	2014	2054	106.65	15.49	6.33	37.18	26%	0.92	5.40	26%	0.00	0.00	0	0	21.96			6.33
VA	6000	6000 Base Water Heating	Non-Jurisdictional	2014	2054	76.92	10.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	76.92	10.87	0.00
VA VA	6000 6000	6007 Heat Trap 6002 High Efficiency Water Heater (electric)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	72.94 71.48	10.31 10.10	3.98 1.46	3.98 5.44	5% 7%	0.56 0.21	0.56 0.77	5% 7%	0.02 0.03	0.02 0.02	0	0	3.74 2.00			3.98 1.46
VA	6000	6004 Tankless Water Heater	Non-Jurisdictional	2014	2054	66.12	9.34	5.36	10.80	14%	0.76	1.53	14%	0.05	0.03	0	0	1.42			5.36
VA	6000	6008 Solar Water Heater	Non-Jurisdictional	2014	2054	48.53	6.86	17.59	28.39	37%	2.49	4.01	37%	0.06	0.05	0	0	1.22			17.59

DNV GL H-20 1/5/2015


APPENDIX H

Base Avoided Costs

Commercial Opt-Out/Exempt/Nonjurisdictional Existing																					
DSM AS	SYST ADDITIVE	SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage									Total			Total		Marginal	Average	Marginal	Average				
				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource			
		easure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt		umber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH
VA	6000	6003 Hot Water Pipe Insulation	Non-Jurisdictional	2014	2054	47.91	6.77	0.62	29.01	38%	0.09	4.10	38%	0.08	0.05	1	0	0.81			0.00
VA	6000	6006 Heat Recovery Unit	Non-Jurisdictional	2014	2054	45.57	6.44	2.34	31.35	41%	0.33	4.43	41%	0.08	0.05	1	0	0.71			0.00
VA	6000	6001 Demand controlled circulating systems	Non-Jurisdictional	2014	2054	44.03	6.22	1.54	32.89	43%	0.22	4.65	43%	0.24	0.06	2	0	0.27			0.00
VA	7000	7000 Base Refrigerated Vending Machines	Non-Jurisdictional	2014	2054	25.15	3.92	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	25.15	3.92	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	Non-Jurisdictional	2014	2054	21.46	3.63	3.69	3.69	15%	0.29	0.29	7%	0.04	0.04	1	1	1.06			3.69
VA	7000	7002 Vending Misers (Refrigerated glass-front units)	Non-Jurisdictional	2014	2054	19.46	3.47	2.00	5.70	23%	0.16	0.44	11%	0.08	0.06	1	1	0.58			0.00
VA	7100	7100 Base Non-Refrigerated Vending Machines	Non-Jurisdictional	2014	2054	0.45	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.45	0.07	0.00
VA	7100	7101 Vending Misers (Non-Refrigerated)	Non-Jurisdictional	2014	2054	0.26	0.05	0.19	0.19	42%	0.01	0.01	21%	0.86	0.86	11	11	0.06			0.00
VA	7200	7200 Base Oven	Non-Jurisdictional	2014	2054	72.06	11.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	72.06	11.40	0.00
VA	7300	7300 Base Fryer	Non-Jurisdictional	2014	2054	36.07	5.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	36.07	5.71	0.00
VA	7300	7301 Efficient Fryer	Non-Jurisdictional	2014	2054	34.88	5.52	1.19	1.19	3%	0.19	0.19	3%	0.42	0.42	3	3	0.15			0.00
VA	7400	7400 Base Steamer	Non-Jurisdictional	2014	2054	72.69	11.50	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	72.69	11.50	0.00
VA	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Non-Jurisdictional	2014	2054	15.57	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.57	0.00	0.00
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Non-Jurisdictional	2014	2054	14.70	0.00	0.88	0.88	6%	0.00	0.00	0%	0.03	0.03	N/A	N/A	1.89			0.88
VA	8100	8100 Base Heating, Other Electric	Non-Jurisdictional	2014	2054	34.88	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	34.88	0.00	0.00
VA	9500	9500 Base Miscellaneous	Non-Jurisdictional	2014	2054	894.20	139.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	894.20	139.33	0.00
VA	9500	9501 Xmisc	Non-Jurisdictional	2014	2054	894.20	139.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00


APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs



APPENDIX H


Base Avoided Costs



DNV GL 1/5/2015 H-26

APPENDIX H


Base Avoided Costs



DNV GL 1/5/2015 H-27


APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs



APPENDIX H


Base Avoided Costs



DNV GL 1/5/2015 H-31


APPENDIX H

Base Avoided Costs



APPENDIX H


Base Avoided Costs



DNV GL 1/5/2015 H-33


APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs



APPENDIX H


Base Avoided Costs



DNV GL 1/5/2015 H-37


APPENDIX H

Base Avoided Costs



APPENDIX H


Base Avoided Costs



DNV GL 1/5/2015 H-39


APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs



APPENDIX H

Base Avoided Costs



APPENDIX H

Base Avoided Costs

DSM ASSYS		SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
		easure mber Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic I GWH	Economic
Sgmt Opt-Out/Ex	100	100 Base Bldg Design - 15%	Office	2014	2053	6.32	1.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.32	1.44	0.00	0.00
Opt-Out/Ex	100	101 High Performance Building/Int Design - Tier 1 15% - Office	Office	2014	2053	5.36	1.16	0.97	0.97	15%	0.28	0.28	20%	0.04	0.04	0	0	1.93			0.97	0.28
Opt-Out/Ex Opt-Out/Ex	200 200	200 Base Bldg Design - 30% 201 High Performance Building/Int Design - Tier 2 30% - Office	Office Office	2014 2014	2053 2053	5.06 3.51	1.15 0.70	0.00 1.54	0.00 1.54	0% 31%	0.00 0.45	0.00 0.45	0% 39%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.71	5.06	1.15	0.00 1.54	0.00 0.45
Opt-Out/Ex	300	300 Base Bldg Design - 50%	Office	2014	2053	1.14	0.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.14	0.26	0.00	0.00
Opt-Out/Ex	300	301 High Performance Building/Int Design - Tier 3 50% - Office	Office	2014	2053	0.56	0.09	0.58	0.58	51%	0.17	0.17	65%	0.03	0.03	0	0	2.58			0.58	0.17
Opt-Out/Ex Opt-Out/Ex	400 400	400 Base Bldg Design - 70% 401 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	Office Office	2014 2014	2053 2053	0.13	0.03	0.00	0.00	0% 71%	0.00	0.00	0% 91%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 2.30	0.13	0.03	0.00	0.00
Opt-Out/Ex	100	100 Base Bldg Design - 15%	Retail	2014	2053	0.81	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.81	0.19	0.00	0.00
Opt-Out/Ex	100	103 High Performance Building/Int Design - Tier 1 15% - Retail	Retail	2014	2053	0.69	0.15	0.12	0.12	15%	0.04	0.04	20%	0.09	0.09	0	0	0.93			0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 200	200 Base Bldg Design - 30% 203 High Performance Building/Int Design - Tier 2 30% - Retail	Retail Retail	2014 2014	2053 2053	0.65 0.45	0.15 0.09	0.00 0.20	0.00 0.20	0% 31%	0.00	0.00	0% 39%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.30	0.65	0.15	0.00 0.20	0.00
Opt-Out/Ex	300	300 Base Bldg Design - 50%	Retail	2014	2053	0.15	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.15	0.03	0.00	0.00
Opt-Out/Ex	300	303 High Performance Building/Int Design - Tier 3 50% - Retail	Retail	2014	2053	0.07	0.01	0.07	0.07	51%	0.02	0.02	65%	0.07	0.07	0	0	1.24			0.07	0.02
Opt-Out/Ex Opt-Out/Ex	400 400	400 Base Bldg Design - 70% 403 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Retail	Retail Retail	2014 2014	2053 2053	0.02	0.00	0.00 0.01	0.00 0.01	0% 71%	0.00	0.00	0% 91%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.10	0.02	0.00	0.00 0.01	0.00
Opt-Out/Ex	100	100 Base Bldg Design - 15%	Grocery	2014	2053	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
Opt-Out/Ex	100	104 High Performance Building/Int Design - Tier 1 15% - Grocery	Grocery	2014	2053	0.02	0.00	0.00	0.00	15%	0.00	0.00	20%	0.03	0.03	0	0	2.38			0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 200	200 Base Bldg Design - 30% 204 High Performance Building/Int Design - Tier 2 30% - Grocery	Grocery Grocery	2014 2014	2053 2053	0.02	0.00	0.00 0.01	0.00 0.01	0% 30%	0.00	0.00	0% 39%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.33	0.02	0.00	0.00 0.01	0.00
Opt-Out/Ex	300	300 Base Blda Design - 50%	Grocery	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
Opt-Out/Ex	300	304 High Performance Building/Int Design - Tier 3 50% - Grocery	Grocery	2014	2053	0.00	0.00	0.00	0.00	50%	0.00	0.00	65%	0.02	0.02	0	0	3.17			0.00	0.00
Opt-Out/Ex	400	400 Base Bldg Design - 70%	Grocery	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	400 100	404 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Grocery 100 Base Bldg Design - 15%	Grocery Warehouse	2014 2014	2053 2053	0.00	0.00	0.00	0.00	70% 0%	0.00	0.00	91% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	2.83 N/A	0.10	0.02	0.00	0.00
Opt-Out/Ex	100	105 High Performance Building/Int Design - Tier 1 15% - Warehouse	Warehouse	2014	2053	0.09	0.02	0.02	0.02	15%	0.00	0.00	20%	0.10	0.10	0	0	0.75	0.10	0.02	0.00	0.00
Opt-Out/Ex	200	200 Base Bldg Design - 30%	Warehouse	2014	2053	0.08	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.08	0.02	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 300	205 High Performance Building/Int Design - Tier 2 30% - Warehouse 300 Base Bldg Design - 50%	Warehouse Warehouse	2014 2014	2053 2053	0.06	0.01 0.00	0.03	0.03	30% 0%	0.01 0.00	0.01 0.00	39% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.05 N/A	0.02	0.00	0.03	0.01
Opt-Out/Ex	300	305 High Performance Building/Int Design - Tier 3 50% - Warehouse	Warehouse	2014	2053	0.02	0.00	0.00	0.00	51%	0.00	0.00	65%	0.08	0.08	0	0	1.00	0.02	0.00	0.00	0.00
Opt-Out/Ex	400	400 Base Bldg Design - 70%	Warehouse	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
Opt-Out/Ex	400 100	405 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Warehous 100 Base Bldg Design - 15%	Warehouse School	2014 2014	2053 2053	0.00 0.19	0.00	0.00	0.00	71% 0%	0.00	0.00	91% 0%	0.09 N/A	0.09 N/A	0 N/A	0 N/A	0.89 N/A	0.40	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	100	100 Base Bidg Design - 15% 106 High Performance Building/Int Design - Tier 1 15% - School	School	2014	2053	0.19	0.03	0.00	0.00	15%	0.00	0.00	20%	0.12	0.12	N/A 1	1 1	0.61	0.19	0.03	0.00	0.00
Opt-Out/Ex	200	200 Base Bldg Design - 30%	School	2014	2053	0.15	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.15	0.02	0.00	0.00
Opt-Out/Ex	200	206 High Performance Building/Int Design - Tier 2 30% - School	School	2014	2053	0.10	0.01	0.05	0.05	31%	0.01	0.01	39%	0.09	0.09	0	0	0.86			0.00	0.00
Opt-Out/Ex Opt-Out/Ex	300 300	300 Base Bldg Design - 50% 306 High Performance Building/Int Design - Tier 3 50% - School	School School	2014 2014	2053 2053	0.03	0.01	0.00	0.00	0% 51%	0.00	0.00	0% 65%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.82	0.03	0.01	0.00	0.00
Opt-Out/Ex	400	400 Base Bldg Design - 70%	School	2014	2053	0.02	0.00	0.02	0.02	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
Opt-Out/Ex	400	406 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - School	School	2014	2053	0.00	0.00	0.00	0.00	71%	0.00	0.00	91%	0.10	0.10	1	1	0.73			0.00	0.00
Opt-Out/Ex Opt-Out/Ex	100 100	100 Base Bldg Design - 15% 107 High Performance Building/Int Design - Tier 1 15% - Health	Health Health	2014 2014	2053 2053	1.74 1.48	0.33 0.26	0.00 0.26	0.00 0.26	0% 15%	0.00 0.06	0.00 0.06	0% 20%	N/A 0.12	N/A 0.12	N/A	N/A 1	N/A 0.62	1.74	0.33	0.00	0.00
Opt-Out/Ex	200	200 Base Bldg Design - 30%	Health	2014	2053	1.40	0.26	0.20	0.00	0%	0.00	0.00	0%	0.12 N/A	0.12 N/A	N/A	N/A	0.62 N/A	1.39	0.26	0.00	0.00
Opt-Out/Ex	200	207 High Performance Building/Int Design - Tier 2 30% - Health	Health	2014	2053	0.97	0.16	0.42	0.42	30%	0.10	0.10	39%	0.09	0.09	0	0	0.87			0.00	0.00
Opt-Out/Ex	300	300 Base Bldg Design - 50%	Health	2014	2053	0.31	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.31	0.06	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	300 400	307 High Performance Building/Int Design - Tier 3 50% - Health 400 Base Bldg Design - 70%	Health Health	2014 2014	2053 2053	0.16	0.02	0.16	0.16 0.00	50% 0%	0.04	0.04	65% 0%	0.09 N/A	0.09 N/A	0 N/A	0 N/A	0.83 N/A	0.03	0.01	0.00	0.00
Opt-Out/Ex	400	407 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Health	Health	2014	2053	0.01	0.00	0.02	0.02	71%	0.01	0.01	91%	0.10	0.10	0	0	0.74			0.00	0.00
Opt-Out/Ex	100	100 Base Bldg Design - 15%	Lodging	2014	2053	0.05	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	100 200	108 High Performance Building/Int Design - Tier 1 15% - Lodging 200 Base Bldg Design - 30%	Lodging Lodging	2014 2014	2053 2053	0.04	0.01 0.01	0.01 0.00	0.01 0.00	15% 0%	0.00	0.00	20% 0%	0.09 N/A	0.09 N/A	0 N/A	0 N/A	0.84 N/A	0.04	0.01	0.00	0.00
Opt-Out/Ex	200	208 High Performance Building/Int Design - Tier 2 30% - Lodging	Lodging	2014	2053	0.03	0.00	0.01	0.01	30%	0.00	0.00	39%	0.07	0.07	0	0	1.17	0.04	0.01	0.01	0.00
Opt-Out/Ex	300	300 Base Bldg Design - 50%	Lodging	2014	2053	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	300 400	308 High Performance Building/Int Design - Tier 3 50% - Lodging 400 Base Bldg Design - 70%	Lodging Lodging	2014 2014	2053 2053	0.00	0.00	0.00	0.00	50% 0%	0.00	0.00	65% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.12 N/A	0.00	0.00	0.00	0.00
Opt-Out/Ex	400	400 Base Bidg Design - 70% 408 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodging	Lodging	2014	2053	0.00	0.00	0.00	0.00	71%	0.00	0.00	91%	0.08	0.08	0 0	0	1.00	0.00	0.00	0.00	0.00
Opt-Out/Ex	100	100 Base Bldg Design - 15%	Data Centers	2014	2053	8.83	1.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.83	1.54	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	100	109 High Performance Building/Int Design - Tier 1 15% - Data Centers	Data Centers	2014 2014	2053 2053	7.50 7.07	1.24 1.23	1.33 0.00	1.33 0.00	15% 0%	0.30	0.30	20% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	6.12 N/A	7.07	4.00	1.33 0.00	0.30
Opt-Out/Ex	200 200	200 Base Bldg Design - 30% 209 High Performance Building/Int Design - Tier 2 30% - Data Centers	Data Centers Data Centers	2014	2053	4.94	0.75	2.13	2.13	30%	0.00	0.00	39%	0.01	0.01	0 N/A	0	8.56	7.07	1.23	2.13	0.00
Opt-Out/Ex	300	300 Base Bldg Design - 50%	Data Centers	2014	2053	1.59	0.28	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.59	0.28	0.00	0.00
Opt-Out/Ex	300	309 High Performance Building/Int Design - Tier 3 50% - Data Centers	Data Centers	2014	2053	0.79	0.10	0.80	0.80	50%	0.18	0.18	65%	0.01	0.01	0	0	8.16			0.80	0.18
Opt-Out/Ex Opt-Out/Ex	400 400	400 Base Bldg Design - 70% 409 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Data Cent	Data Centers Data Centers	2014 2014	2053 2053	0.18 0.05	0.03	0.00 0.12	0.00 0.12	0% 70%	0.00	0.00	0% 91%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.27	0.18	0.03	0.00 0.12	0.00
Opt-Out/Ex	100	100 Base Bldg Design - 15%	Misc	2014	2053	2.19	0.43	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.19	0.43	0.00	0.00
Opt-Out/Ex	100	112 High Performance Building/Int Design - Tier 1 15% - Miscellaneous	Misc	2014	2053	1.85	0.35	0.33	0.33	15%	0.08	0.08	20%	0.09	0.09	0	0	0.83			0.00	0.00
Opt-Out/Ex	200	200 Base Bldg Design - 30%	Misc Misc	2014 2014	2053 2053	1.75 1.22	0.34	0.00	0.00 0.53	0% 30%	0.00	0.00	0% 39%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A	1.75	0.34	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 300	212 High Performance Building/Int Design - Tier 2 30% - Miscellaneous 300 Base Bldg Design - 50%	Misc	2014	2053	0.39	0.21	0.53	0.53	30% 0%	0.13	0.13	39% 0%	0.07 N/A	0.07 N/A	N/A	N/A	1.16 N/A	0.39	0.08	0.53	0.13
Opt-Out/Ex	300	312 High Performance Building/Int Design - Tier 3 50% - Miscellaneous	Misc	2014	2053	0.19	0.03	0.20	0.20	51%	0.05	0.05	65%	0.07	0.07	0	0	1.11			0.20	0.05
Opt-Out/Ex	400	400 Base Bldg Design - 70%	Misc	2014	2053	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
Opt-Out/Ex VA	400 100	412 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Miscellance 100 Base Bldg Design - 15%	Misc Non-Jurisdictional	2014 2014	2053 2053	0.01 79.60	0.00 16.85	0.03	0.03	71% 0%	0.01	0.01 0.00	91% 0%	0.08 N/A	0.08 N/A	0 N/A	0 N/A	0.99 N/A	79.60	16.85	0.00	0.00
VA	100		Non-Jurisdictional	2014	2053	67.47	13.57	12.13	12.13	15%	3.29	3.29	20%	0.06	0.06	0	0	1.37	, 0.00	. 0.00	12.13	3.29

APPENDIX H

Base Avoided Costs

D			empt/Nonjurisdictional New Construction SUPPLY ANALYSIS			,	Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY	
•	intage				Measure	Vleasure				Energy	Percent		Capacity	Percent	Energy	Energy			Resource				
		Base Me	easure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic I	Economic
S	Sgmt	Number Nu	mber Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
V	/A	200	200 Base Bldg Design - 30%	Non-Jurisdictional	2014	2053	63.68	13.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	63.68	13.48	0.00	0.00
V	/A	200	210 High Performance Building/Int Design - Tier 2 30% - Non-Jurisdictional	Non-Jurisdictional	2014	2053	44.28	8.22	19.40	19.40	30%	5.26	5.26	39%	0.04	0.04	0	0	1.92			19.40	5.26
V	/A	300	300 Base Bldg Design - 50%	Non-Jurisdictional	2014	2053	14.33	3.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.33	3.03	0.00	0.00
V	/A	300	310 High Performance Building/Int Design - Tier 3 50% - Non-Jurisdictional	Non-Jurisdictional	2014	2053	7.05	1.06	7.28	7.28	51%	1.97	1.97	65%	0.04	0.04	0	0	1.83			7.28	1.97
V	/A	400	400 Base Bldg Design - 70%	Non-Jurisdictional	2014	2053	1.59	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.59	0.34	0.00	0.00
V	/A	400	410 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Non-Juri	sc Non-Jurisdictional	2014	2053	0.46	0.03	1.13	1.13	71%	0.31	0.31	91%	0.05	0.05	0	0	1.63			1.13	0.31

APPENDIX H

Base Avoided Costs

DSM ASSYS	Electric Existing Construction T ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Energy	Capacity	Average Capacity	Total Resource				
Sgmt Numb		Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
VA 100 VA 100		Single Family Single Family	2014 2014	2053 2053	2,123.48		0.00 23.66	0.00 23.66	0% 1%	0.00 14.06	0.00 14.06	0% 1%	N/A 0.01	N/A 0.01	N/A 0	N/A	N/A 6.57	2,123.48	1,261.52	0.00 23.66	0.00 14.06
VA 100	00 1022 Programmable Thermostat (CAC)	Single Family	2014	2053	2,087.47	1,240.13	12.34	36.01	2%	7.33	21.39	2%	0.04	0.02	o	0	2.38			12.34	7.33
VA 100		Single Family	2014	2053 2053	2,075.37		12.10	48.11 50.32	2%	7.19 1.32	28.58 29.90	2% 2%	0.06	0.03	0	0	1.90 1.28			12.10 2.22	7.19 1.32
VA 100		Single Family Single Family	2014	2053	1,924.33		2.22 148.83	199.16	2% 9%	88.42	118.32	2% 9%	0.09	0.03	0	0	1.28			148.83	88.42
VA 100	00 1025 Door Weatherization (CAC)	Single Family	2014	2053	1,893.00	1,124.60	31.33	230.48	11%	18.61	136.93	11%	0.07	0.07	0	0	1.01			31.33	18.61
VA 100 VA 100		Single Family Single Family	2014 2014	2053 2053	1,778.11		114.89 100.65	345.38 446.02	16% 21%	68.26 59.79	205.18 264.97	16% 21%	0.13 0.16	0.09	0	0	0.84 0.71			0.00	0.00
VA 100		Single Family	2014	2053	1,514.52		162.94	608.96	29%	96.80	361.78	29%	0.17	0.12	0	0	0.65			0.00	0.00
VA 100	1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Single Family	2014	2053	1,361.98		152.54	761.51	36%	90.62	452.40	36%	0.22	0.14	0	0	0.49			0.00	0.00
VA 100 VA 100		Single Family Single Family	2014 2014	2053 2053	1,353.27		8.70 38.18	770.21 808.39	36% 38%	5.17 22.68	457.57 480.25	36% 38%	0.26 0.27	0.14 0.15	0	0	0.44			0.00	0.00
VA 100	00 1009 Ceiling R-0 to R-49 Insulation (CAC)	Single Family	2014	2053	1,314.53	780.94	0.55	808.95	38%	0.33	480.58	38%	3.00	0.15	5	Ö	0.04			0.00	0.00
VA 100		Single Family	2014	2053	1,254.71		59.82	868.77	41%	35.54	516.12	41%	0.33	0.16	1	0	0.27			0.00	0.00
VA 100		Single Family Single Family	2014 2014	2053 2053	1,131.76		122.95 12.66	991.72 1.004.38	47% 47%	73.04 7.52	589.16 596.68	47% 47%	0.36 0.51	0.19	1	0	0.24			0.00	0.00
VA 100		Single Family	2014	2053	1,095.69		23.41	1,027.79	48%	13.91	610.59	48%	0.74	0.20	1	0	0.15			0.00	0.00
VA 100		Single Family	2014	2053	1,094.69		1.00	1,028.79	48%	0.59	611.18	48%	3.60	0.21	6	0	0.03			0.00	0.00
VA 100		Single Family Single Family	2014 2014	2053 2053	1,090.03		4.67 6.07	1,033.45 1.039.52	49% 49%	2.77 3.61	613.96 617.56	49% 49%	1.06 1.26	0.21 0.22	2	0	0.10 0.09			0.00	0.00
VA 100	1030 WINDOWS - Double-Glazed Clear to Energy Star (CAC)	Single Family	2014	2053	1,078.68	640.83	5.27	1,044.80	49%	3.13	620.70	49%	1.30	0.22	2	ō	0.09			0.00	0.00
VA 100		Single Family	2014	2053	1,060.37		18.31	1,063.11	50%	10.88	631.57	50%	1.34	0.24	2	0	0.08			0.00	0.00
VA 100		Single Family Single Family	2014 2014	2053 2053	1,059.82		0.55 27.75	1,063.66 1,091.41	50% 51%	0.33 16.49	631.90 648.39	50% 51%	3.72 1.68	0.24 0.28	6 3	0	0.03			0.00	0.00
VA 100	00 1028 Window Film (CAC)	Single Family	2014	2053	997.22	592.43	34.85	1,126.26	53%	20.70	669.09	53%	1.73	0.33	3	1	0.05			0.00	0.00
VA 100		Single Family	2014 2014	2053 2053	995.17 990.93	591.21 588.70	2.05 4.24	1,128.31	53% 53%	1.22 2.52	670.31 672.83	53% 53%	2.48 1.83	0.33	4	1	0.05			0.00	0.00
VA 100		Single Family Single Family	2014	2053	986.52	586.07	4.24	1,132.55	53% 54%	2.52	675.45	53% 54%	2.09	0.34	4	1	0.04			0.00	0.00
VA 100	1015 Basement insulation R-13 (CAC)	Single Family	2014	2053	982.22	583.52	4.30	1,141.26	54%	2.55	678.00	54%	3.64	0.35	6	1	0.03			0.00	0.00
VA 100		Single Family	2014 2014	2053 2053	981.99 349.12	583.38 207.41	0.23	1,141.49	54% 0%	0.14	678.14 0.00	54% 0%	4.19 N/A	0.36 N/A	7 N/A	1 N/A	0.03 N/A	349.12	207.41	0.00	0.00
VA 110		Single Family	2014	2053	349.12	207.41	2.85	2.85	1%	1.69	1.69	1%	0.01	0.01	N/A 0	0 0	9.28	349.12	207.41	2.85	1.69
VA 110	1122 Self Install Weatherization (CAC early replacement)	Single Family	2014	2053	340.44	202.25	5.84	8.69	2%	3.47	5.16	2%	0.01	0.01	0	0	6.04			5.84	3.47
VA 110		Single Family Single Family	2014 2014	2053 2053	338.44 336.47	201.06 199.89	2.00 1.96	10.69 12.65	3% 4%	1.19	6.35 7.51	3% 4%	0.04	0.02	0	0	2.19 1.74			2.00 1.96	1.19 1.17
VA 110		Single Family	2014	2053	330.11	196.11	6.37	19.02	5%	3.78	11.30	5%	0.06	0.03	0	0	1.16			6.37	3.78
VA 110	1102 Proper Refrigerant Charging and Air Flow (CAC early replacer	m Single Family	2014	2053	302.78	179.88	27.32	46.34	13%	16.23	27.53	13%	0.09	0.07	0	0	1.02			27.32	16.23
VA 110		Single Family Single Family	2014 2014	2053 2053	271.17 221.49	161.09 131.58	31.62 49.68	77.96 127.64	22% 37%	18.78 29.51	46.31 75.83	22% 37%	0.14	0.10	0	0	0.76			0.00	0.00
VA 110		Single Family	2014	2053	196.79	116.91	24.70	152.34	44%	14.67	90.50	44%	0.17	0.12	0	0	0.48			0.00	0.00
VA 110		Single Family	2014	2053	195.53	116.16	1.26	153.59	44%	0.75	91.25	44%	0.32	0.14	1	0	0.36			0.00	0.00
VA 110		Single Family Single Family	2014 2014	2053 2053	190.01 182.51	112.88 108.43	5.52 7.50	159.11 166.61	46% 48%	3.28 4.46	94.52 98.98	46% 48%	0.34 0.37	0.15 0.16	1	0	0.34 0.31			0.00	0.00
VA 110		Single Family	2014	2053	182.43	108.38	0.08	166.69	48%	0.05	99.03	48%	3.82	0.16	6	0	0.03			0.00	0.00
VA 110	1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early		2014	2053	179.74	106.78	2.70	169.39	49%	1.60	100.63	49%	0.45	0.16	1	0	0.25			0.00	0.00
VA 110		Single Family re Single Family	2014 2014	2053 2053	178.06 169.96	105.78 100.97	1.68 8.10	171.06 179.17	49% 51%	1.00 4.81	101.63 106.44	49% 51%	0.52 0.43	0.17 0.18	1	0	0.21 0.21			0.00	0.00
VA 110		Single Family	2014	2053	168.37	100.03	1.58	180.75	52%	0.94	107.38	52%	0.72	0.18	1	0	0.14			0.00	0.00
VA 110		Single Family	2014	2053	164.85	97.94	3.52	184.27	53%	2.09	109.47	53%	0.87	0.20	1	0	0.13			0.00	0.00
VA 110		Single Family Single Family	2014 2014	2053 2053	164.70 152.35	97.85 90.51	0.15 12.35	184.42 196.77	53% 56%	0.09 7.34	109.56 116.90	53% 56%	4.23 0.86	0.20 0.24	7 1	0	0.03 0.10			0.00	0.00
VA 110	00 1127 WINDOWS - Default With Sunscreen (CAC early replacemen	nt) Single Family	2014	2053	145.08	86.19	7.27	204.04	58%	4.32	121.22	58%	1.09	0.27	2	ō	0.08			0.00	0.00
VA 110		Single Family	2014 2014	2053	144.27	85.71	0.81	204.85	59%	0.48	121.70	59%	1.67	0.28	3	0	0.07			0.00	0.00
VA 110		Single Family Single Family	2014	2053 2053	144.20 143.90	85.66 85.49	0.08 0.30	204.93 205.22	59% 59%	0.04	121.74 121.92	59% 59%	4.83 3.03	0.28 0.28	8 5	0	0.02 0.04			0.00	0.00
VA 110	1105 AC Filter Changes (CAC early replacement)	Single Family	2014	2053	143.29	85.12	0.61	205.84	59%	0.36	122.28	59%	2.23	0.29	4	0	0.03			0.00	0.00
VA 110		Single Family	2014	2053 2053	142.65 138.99	84.75 82.57	0.64 3.66	206.47 210.13	59% 60%	0.38 2.17	122.66 124.84	59% 60%	2.55 3.37	0.30	4 6	0	0.03			0.00	0.00
VA 110		Single Family	2014	2053	138.99	82.57 82.55	0.03	210.13	60%	0.02	124.84	60%	5.23	0.35	9	1	0.02			0.00	0.00
VA 120	00 1200 Base Heat Pump Cooling (13 SEER)	Single Family	2014	2053	1,802.58	1,070.88	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1,802.58	1,070.88	0.00	0.00
VA 120		Single Family Single Family	2014	2053 2053	1,787.87		14.71 19.92	14.71 34.64	1% 2%	8.74 11.84	8.74 20.58	1% 2%	0.01	0.01	0	0	9.51 2.38			14.71 19.92	8.74 11.84
VA 120		Single Family Single Family	2014	2053	1,767.92		26.56	61.19	2% 3%	15.78	36.35	2% 3%	0.04	0.03	0	0	1.73			26.56	15.78
VA 120	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	2014	2053	1,446.34	859.24	295.05	356.24	20%	175.29	211.64	20%	0.08	0.07	0	0	1.29			295.05	175.29
VA 120		Single Family Single Family	2014	2053 2053	1,342.50		103.83 21.86	460.08 481.93	26% 27%	61.68 12.98	273.32 286.31	26% 27%	0.10	0.08	0	0	0.90			0.00	0.00
VA 120		Single Family	2014	2053	1,182.74		137.91	619.84	34%	81.93	368.24	34%	0.16	0.08	0	0	0.79			0.00	0.00
VA 120	00 1226 Whole House Fans (HP cooling)	Single Family	2014	2053	966.05	573.92	216.68	836.53	46%	128.73	496.97	46%	0.19	0.12	0	0	0.54			0.00	0.00
VA 120		Single Family Single Family	2014 2014	2053 2053	872.22 866.64	518.17 514.85	93.84 5.58	930.36 935.94	52% 52%	55.75 3.31	552.71 556.03	52% 52%	0.29 0.36	0.14 0.14	0	0	0.38 0.32			0.00	0.00
VA 120	1208 Ceiling R-0 to R-38 Insulation (HP cooling)	Single Family Single Family	2014	2053	841.94	500.18	24.70	960.64	53%	14.67	570.70	53%	0.38	0.14	1	0	0.30			0.00	0.00
VA 120	1215 Basement insulation R-13 (HP cooling)	Single Family	2014	2053	808.61	480.38	33.33	993.97	55%	19.80	590.50	55%	0.42	0.16	1	0	0.27			0.00	0.00
VA 120	1209 Ceiling R-0 to R-49 Insulation (HP cooling)	Single Family	2014	2053	807.86	479.93	0.76	994.72	55%	0.45	590.95	55%	1.95	0.16	3	0	0.06			0.00	0.00

DNV GL H-1 1/5/2015

APPENDIX H

Base Avoided Costs

	Electric Existing Construction ST ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage	TI ADDITIVE SUFFET ANALISIS				rear	2014		Total			Total		Marginal		Marginal		Total			SUFFEI	
Base	Measure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy	Energy	Capacity Cost	Capacity	Resource Cost Test	Base	Base	Economic	Economic
Sgmt Numb	per Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA 120 VA 120		Single Family Single Family	2014 2014	2053 2053	800.31 763.89	475.45 453.82	7.54 36.42	1,002.27 1.038.69	56% 58%	4.48 21.64	595.43 617.07	56% 58%	0.58 0.48	0.16 0.17	1	0	0.19 0.18			0.00	0.00
VA 120	00 1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling)		2014	2053	752.60	447.11	11.29	1,049.98	58%	6.71	623.77	58%	0.84	0.18	1	0	0.14			0.00	0.00
VA 120 VA 120		Single Family Single Family	2014 2014	2053 2053	745.60 729.61	442.95 433.45	7.01 15.99	1,056.98 1,072.97	59% 60%	4.16 9.50	627.94 637.43	59% 60%	0.82 0.96	0.18	1 2	0	0.13 0.12			0.00	0.00
VA 120		Single Family	2014	2053	728.13	432.57	1.48	1,074.45	60%	0.88	638.31	60%	2.16	0.19	4	0	0.05			0.00	0.00
VA 120		Single Family	2014	2053	727.50	432.19	0.63	1,075.08	60%	0.38	638.69	60%	1.36	0.20	2	0	0.08			0.00	0.00
VA 120 VA 120		Single Family Single Family	2014 2014	2053 2053	723.56 722.72	429.85 429.35	3.94 0.84	1,079.02	60% 60%	2.34 0.50	641.03 641.53	60% 60%	1.73 2.18	0.20	3 4	0	0.07			0.00	0.00
VA 120		Single Family	2014	2053	719.64	427.53	3.08	1,082.94	60%	1.83	643.36	60%	2.49	0.21	4	0	0.03			0.00	0.00
VA 120		Single Family	2014	2053	717.15	426.05	2.49	1,085.43	60%	1.48	644.83	60%	5.83	0.22	10	0	0.02			0.00	0.00
VA 120 VA 130		Single Family Single Family	2014 2014	2053 2053	713.96 274.13	424.15 162.86	3.19 0.00	1,088.62	60% 0%	1.90	646.73	60% 0%	4.04 N/A	0.24 N/A	7 N/A	0 N/A	0.02 N/A	274.13	162.86	0.00	0.00
VA 130		Single Family	2014	2053	271.89	161.53	2.24	2.24	1%	1.33	1.33	1%	0.01	0.01	0	0	8.19	274.10	102.00	2.24	1.33
VA 130		Single Family	2014	2053	268.86	159.73	3.03	5.27	2%	1.80	3.13	2%	0.04	0.03	0	0	2.05			3.03	1.80
VA 130 VA 130		Single Family Single Family	2014 2014	2053 2053	223.31 219.95	132.66 130.67	45.56 3.35	50.82 54.18	19% 20%	27.06 1.99	30.19 32.19	19% 20%	0.09 0.11	0.09	0	0	1.12 0.90			45.56 0.00	27.06 0.00
VA 130		Single Family	2014	2053	215.79	128.20	4.16	58.34	21%	2.47	34.66	21%	0.09	0.09	0	0	0.85			0.00	0.00
VA 130			2014	2053	200.30	118.99	15.49	73.83	27%	9.20	43.86	27%	0.12	0.09	0	0	0.76			0.00	0.00
VA 130 VA 130		Single Family Single Family	2014 2014	2053 2053	179.38 146.52	106.57 87.04	20.92 32.86	94.75 127.61	35% 47%	12.43 19.52	56.29 75.81	35% 47%	0.18 0.22	0.11 0.14	0	0	0.56 0.47			0.00	0.00
VA 130			2014	2053	132.29	78.59	14.23	141.84	52%	8.46	84.27	52%	0.22	0.14	1	0	0.47			0.00	0.00
VA 130	00 1314 Crawlspace insulation (HP cooling Early Replacement)	Single Family	2014	2053	131.44	78.09	0.84	142.69	52%	0.50	84.77	52%	0.42	0.16	1	0	0.27			0.00	0.00
VA 130			2014 2014	2053 2053	127.70 122.65	75.86 72.86	3.75 5.05	146.44 151.48	53% 55%	2.23	86.99 89.99	53% 55%	0.44	0.17	1	0	0.26 0.23			0.00	0.00
VA 130		Single Family	2014	2053	122.55	72.80	0.11	151.46	55%	0.07	90.06	55%	2.27	0.18	4	0	0.23			0.00	0.00
VA 130	00 1320 Duct Testing and Sealing (HP cooling Early Replacement)	Single Family	2014	2053	121.39	72.12	1.14	152.74	56%	0.68	90.74	56%	0.68	0.19	1	0	0.16			0.00	0.00
VA 130			2014	2053	115.87	68.84	5.52	158.26	58%	3.28	94.02	58%	0.56	0.20	1	0	0.16			0.00	0.00
VA 130 VA 130		Single Family	2014 2014	2053 2053	114.16 113.09	67.82 67.19	1.71 1.06	159.98 161.04	58% 59%	1.02 0.63	95.04 95.67	58% 59%	0.97 0.96	0.21 0.21	2	0	0.12 0.11			0.00	0.00
VA 130			2014	2053	110.67	65.75	2.42	163.46	60%	1.44	97.11	60%	1.12	0.23	2	0	0.10			0.00	0.00
VA 130	00 1311 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement	Single Family	2014	2053	110.44	65.61	0.22	163.69	60%	0.13	97.24	60%	2.52	0.23	4	0	0.05			0.00	0.00
VA 130			2014 2014	2053 2053	110.35 109.75	65.56 65.20	0.10 0.60	163.78 164.38	60% 60%	0.06	97.30 97.66	60% 60%	1.58 2.01	0.23 0.24	3	0	0.07 0.06			0.00	0.00
VA 130			2014	2053	109.62	65.12	0.13	164.51	60%	0.08	97.73	60%	2.54	0.24	4	0	0.04			0.00	0.00
VA 130	00 1307 Heat Pump Filter Replacement	Single Family	2014	2053	109.16	64.85	0.47	164.98	60%	0.28	98.01	60%	2.90	0.25	5	0	0.02			0.00	0.00
VA 130			2014 2014	2053 2053	108.78 108.29	64.62 64.34	0.38 0.48	165.35 165.84	60% 60%	0.22	98.23 98.52	60% 60%	6.79 4.70	0.26 0.27	11 8	0	0.02			0.00	0.00
VA 130		Single Family Single Family	2014	2053	112.24	66.68	0.48	0.00	0%	0.29	0.00	0%	4.70 N/A	N/A	N/A	N/A	0.02 N/A	112.24	66.68	0.00	0.00
VA 140	00 1413 Self Install Weatherization (RAC)	Single Family	2014	2053	110.99	65.94	1.25	1.25	1%	0.74	0.74	1%	0.03	0.03	0	0	3.07			1.25	0.74
VA 140 VA 140		Single Family Single Family	2014 2014	2053 2053	109.18 97.78	64.86 58.09	1.81 11.40	3.06 14.46	3% 13%	1.07 6.77	1.82 8.59	3% 13%	0.14 0.24	0.10 0.21	0	0	0.51			0.00	0.00
VA 140		Single Family	2014	2053	79.87	47.45	17.91	32.37	29%	10.64	19.23	29%	0.24	0.21	0	0	0.43			0.00	0.00
VA 140	00 1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	Single Family	2014	2053	75.39	44.79	4.48	36.85	33%	2.66	21.89	33%	0.31	0.26	1	Ō	0.27			0.00	0.00
VA 140		Single Family	2014 2014	2053 2053	59.56 57.97	35.38 34.44	15.83	52.68 54.27	47% 48%	9.41 0.94	31.30	47% 48%	0.43	0.31	1	1	0.21			0.00	0.00
VA 140		Single Family Single Family	2014	2053	57.97 57.12	34.44	1.59 0.86	54.27 55.13	48% 49%	0.94	32.24 32.75	48% 49%	0.75 0.90	0.33	2	1	0.15			0.00	0.00
VA 140		Single Family	2014	2053	54.01	32.09	3.11	58.23	52%	1.85	34.59	52%	0.72	0.36	1	1	0.12			0.00	0.00
VA 140		Single Family	2014	2053	53.97	32.06	0.04	58.27	52%	0.02	34.62	52%	4.53	0.36	8	1	0.03			0.00	0.00
VA 140 VA 140		Single Family Single Family	2014 2014	2053 2053	53.47 52.45	31.76 31.16	0.50 1.02	58.77 59.79	52% 53%	0.30	34.92 35.52	52% 53%	1.46 1.93	0.37	2	1	0.07 0.06			0.00	0.00
VA 140		Single Family	2014	2053	52.36	31.11	0.09	59.88	53%	0.05	35.57	53%	4.67	0.40	8	1	0.02			0.00	0.00
VA 140		Single Family	2014	2053	52.14	30.97	0.23	60.10	54%	0.13	35.71	54%	2.58	0.41	4	1	0.04			0.00	0.00
VA 140 VA 140		Single Family Single Family	2014 2014	2053 2053	49.65 49.40	29.50 29.35	2.49 0.25	62.59 62.84	56% 56%	1.48 0.15	37.18 37.34	56% 56%	2.03 3.42	0.47	3 6	1	0.04			0.00	0.00
VA 140		Single Family	2014	2053	49.40	29.33	0.25	62.89	56%	0.13	37.36	56%	4.96	0.49	8	1	0.03			0.00	0.00
VA 140	00 1403 Room AC Filter Replacement	Single Family	2014	2053	49.14	29.19	0.21	63.10	56%	0.12	37.49	56%	4.18	0.50	7	. 1	0.02			0.00	0.00
VA 150 VA 150		Single Family	2014 2014	2053 2053	23.56 20.43	14.00 12.14	0.00 3.13	0.00 3.13	0% 13%	0.00 1.86	0.00 1.86	0% 13%	N/A 0.63	N/A 0.63	N/A 1	N/A	N/A 0.13	23.56	14.00	0.00	0.00
VA 150		Single Family	2014	2053	25.36	12.14	0.00	0.00	0%	0.00	0.00	0%	0.63 N/A	0.63 N/A	N/A	N/A	0.13 N/A	25.36	15.07	0.00	0.00
VA 160	00 1601 10% better than Energy Star Dehumidifier ROB (35-45 pints/da	Single Family	2014	2053	21.52	12.79	3.84	3.84	15%	2.28	2.28	15%	0.18	0.18	0	0	0.52			0.00	0.00
VA 170		Single Family	2014	2053	1,754.83		0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A		1,754.83	900.13	0.00	0.00
VA 170		Single Family Single Family	2014 2014	2053 2053	974.90 2.499.04	500.07 296.50	779.92 0.00	779.92 0.00	44% 0%	400.06 0.00	400.06 0.00	44% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	3.76 N/A	2,499.04	296,50	779.92 0.00	400.06 0.00
VA 200	00 2016 Duct Insulation (HP heating)	Single Family	2014	2053	2,478.64	294.08	20.40	20.40	1%	2.42	2.42	1%	0.01	0.01	0	0	10.47	,		20.40	2.42
VA 200		Single Family	2014	2053	2,451.02		27.62	48.02	2%	3.28	5.70	2%	0.02	0.02	0	0	2.80			27.62	3.28
VA 200		Single Family Single Family	2014 2014	2053 2053	2,414.21	286.44 260.05	36.82 222.45	84.84 307.28	3% 12%	4.37 26.39	10.07 36.46	3% 12%	0.05 0.08	0.03	0	0	1.44 0.85			36.82 0.00	4.37 0.00
VA 200		Single Family	2014	2053	2,170.07		21.69	328.97	13%	2.57	39.03	13%	0.08	0.07	1	1	0.70			0.00	0.00
VA 200		Single Family	2014	2053	2,156.21	255.83	13.85	342.83	14%	1.64	40.68	14%	0.12	0.07	1	1	0.62			0.00	0.00
VA 200		Single Family Single Family	2014 2014	2053 2053	2,094.77		61.45 454.58	404.27 858.85	16% 34%	7.29 53.93	47.97 101.90	16% 34%	0.13	0.08	1	1	0.60			0.00	0.00
VA 200	,,	Single Family	2014	2053	1,575.39		64.80	923.65	37%	7.69	101.90	37%	0.14	0.11	2	1	0.42			0.00	0.00
VA 200		Single Family	2014	2053	1,573.92	186.74	1.48	925.12	37%	0.18	109.76	37%	0.85	0.12	7	1	0.09			0.00	0.00

DNV GL H-2 1/5/2015

APPENDIX H

Base Avoided Costs

Part		Electric Existing Construction ST ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Part		30.12.7.00		Measure	Measure	· our	20.7			Percent			Percent								00.121	
200 200 Convenement of Mark Enging Inf. Places 204 202 202 202 203 2				Start	End				Savings	GWH		Savings	MW	Cost	Cost	Cost	Cost	Cost Test				
12 12 13 13 13 13 13 13	VA 20	00 2020 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Single Family	2014	2053	1,502.29	9 178.24	71.62	996.75	40%	8.50	118.26	40%	0.21	0.12	2	1	0.31	GWII	INIAA	0.00	0.00
1. 1. 1. 1. 1. 1. 1. 1.																	1					
1			,														1					
No. 2006 2001 Control per the plane plan																	1					
Vis. 200 2011 Centing time 5 to 6 in marker of the container of the		3,															1					
No. 200 2001 Number Park Park Park 201																	1					
1			,														-					
No. 200 200 700																						
Vis. 200 2116 Detail Learn Engage Agreement Sungle Flows 2014 2024 2024 4.07 4.08 1.09 7.00 7.00 2.00 0.0			g,			.,			.,=								-					
Vis. 200 2115 Set Printal Well-Centific (PF) Persistage of synthesis and synth																			420.83	49.93		
Vis. 200 2116 Programment Primating andy segment 2014 2015		00 2116 Duct Insulation (HP heating early replacement) 00 2121 Self Install Weatherization (HP heating early replacement)														-	-					
Value 100 2122 Coor Virune-fractament (ref) Feature gar yrigosament () Single Feature 2514 2523 2525 2535				2011												-	•					
Value 100 212 Contention instation (Pri benting unifferently eight representation (Pri benting unifferently eight representation 2.000 2.0				20												1	1					
Value 100 21																1	1					
Value 101 211 Statement missistics (7-1 Peril profit pr																1	i					
Vis. 200 200 Caling Feel Beed lesishation (Perhamity surprise permit) 2014 2025 2025 1750		00 2118 Heat Recovery Ventilators (HP heating early replacement)			2053			76.51	144.76	34%	9.08					1	1					
12 20 20 20 20 20 20 20																	1					
Value 17 2010 21 17 2017																	1					
Value 2100		00 2117 Duct Testing and Sealing (HP heating early replacement)	Single Family			250.51	29.72			40%			40%				1					
Val 2100 2																-	1					
14 Floor Ref. to Ref. 10 Floor Ref. to Ref. 10 Floor Institution Simple Family 2014 2033 240.50 23.54 24.55 23.54 24.55 23.5																-	1					
VA 2100 2111 Colling's Fish to Ft-4d Installation (FF healthing early replacement) Single Family 214 255 234.8 439. 0.32 25.5 439. 0.38 0.3		00 2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replaceme		2014	2053		28.59	0.21	179.90	43%	0.02	21.34	43%	0.61	0.15	5	1	0.13			0.00	0.00
VA 2100 2103 Ground Source Healt Pump with Designe-femating (PF) Passing on Single Family 2014 2053 211.51 2015 20																7	1					
VA 200 210 Sharp Pump Files Replacement (heating) Single Family 2014 2053 216.91 257.4 20.93 20.932 48% 0.11 2.19 2.19 4.95% 2.00 0.34 1.0 3 0.4 0.0																-	3					
V. 2.000 2 115 Was flowwish FQ to FL31 flowfalterin (IPP healing early replication grows place Planting (Plantin) 2014 2053 215.00 2.55.3 d. 97.0 0 0.00 0.00 0.00 0.00 0.00 0.00 0				20																		
VA 2200 2200 Base Resistance Space heleating (Primary)																	-					
V. 2000																			1 220 36	144 79		
VA 2200 2214 Dorgammatide Thermostati (resistance heating) Single Family 2014 2053 390.71 11.0 13.0 15.0			,						248.28				- , -						1,220.00			
VA 2200 2217 Drow Weather/action (resistance heating) Single Family 2014 2053 302.03 10.03 10.03 2203 302.03 302	***			2011					200													
VA 2200 22013 Gelling R-10 in R-30 insulation (resistance heating) Single Family 2014 2053 706.29 36.88 318.33 208, 34.97, 70.98 3.10 30.07 1 1 0.58 0.00																	-					
VA 2200 2209 Cardwagene insulation (resistance heating) Single Family 2014 2053 695.8 70.14 83.31 4.14 595.8 695.8 40% 50.6 66.5 46% 50.8 0.08 1 0.08 1 0.08 0.00 0.	VA 22					902.03	107.02			26%						1	-					
VA 2200 2210 Basement insulation R-13 (resistance heating) Single Family Single Fami		,,														1	1					
VA 2200 2294 Celling R-0 to R-49 Insulation (resistance heating) Single Family 2014 2053 658.88 71.70 0.53 561.84 45% 0.06 66.62 46% 0.09 0.08 8 1 0.08																1	1					
VA 2200 2215 Comprehensives Shell Air Sealing-Inf. Reduction (resistance he Single Family VA 2200 2206 Ceiling R-11 to R-39 Insulation (resistance heating) Single Family 2014 2053 618.62 73.40 10.28 617.4 49% 0.21 1 0.08 0.03 0.09 3 1 0.20 1 0.00 0.00 0.00 0.00 0.00 0.00																8	1					
VA		00 2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance hε															1					
VA																	1					
VA																	1					
VA																	1					
VA 2200 2202 Ground Source Heat Purm with Desuperheater (resistance heating) 2014 2053 593.20 70.38 4.92 627.16 51% 0.58 74.41 51% 21.03 0.26 177 2 0.00																	1					
VA 3030 3030 Base Halogen Lighting - 0.5 hrs/day/ 2020 Single Family 2020 2053 183.04 20.49 0.00 0.00 0.00																	2					
VA 3030 3032 LEDs (base Halogen 0.5 hrs/day) 2020 Single Family 2020 2053 58.50 6.55 124.54 68% 13.94 13.94 68% 0.04 0.04 0 0 0 2.43 75.77 84.17 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																						
VA 3130 3130 Base Halogen Lighting - 2.5 hrs/day 2020 Single Family 2020 2053 751.7 84.17 0.00																			183.04	20.49		
VA 3130 3132 LEDs (base Halogen £2.5 hrs/day) 2020 Single Family 202 263 496.8 2.05 554.81 554.81 554.81 67.12 62.12 62.12 74% 0.10 0.01 0.01 0.13.20 558.81 62.12 VA 3230 3232 LEDs (base Halogen 6 hrs/day) 2020 Single Family 202 253 158.78 17.78 338.04 37.85 68% 0.00 0.0 <td< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>-</td><td></td><td>751.77</td><td>84.17</td><td></td><td></td></td<>																	-		751.77	84.17		
VA 3230 3232 LEDs (base Halogen & Firs/day) 2020 Single Family 202 2053 15.78 33.80 33.80 d 37.85 37.85 37.85 68% 0.0 0.0 0.0 0.0 18.12 33.00 d 37.85 37.85 37.85 37.85 68% 0.0 0.0 0.0 0.0 18.12 35.00 37.85 37.85 37.85 37.85 68% 0.0 0.0 0.0 0.0 0.00		30 3132 LEDs (base Halogen 2.5 hrs/day) 2020	Single Family											0.01		0	0	13.20				
VA 3330 3330 Base CFL Lighting - 0.5 hrs/day 2020 Single Family 202 263 35.20 3.94 0.00 0.00 0% 0.00 0% N/A <			,																496.82	55.62		
VA 3330 3331 LEDs (base CFL \(\bar{2}\) in Instragrange) 2020 265 2.88 9.50 9.50 27% 1.06 1.06 27% 0.21 0.21 2 2 0.42 9.50 0.00																			35.20	3.94		
VA 3430 3431 LEDs (base CFL ½ 5 Ins/day) 2020 Single Family 202 2053 10.64 0.08 27% 4.36 4.36 27% 0.04 0.04 0.0 2.10 38.96 4.36 4.36 4.26 27% 0.04 0.04 0.0 2.10 38.96 4.36 4.36 4.26 27% 0.04 0.04 0.0 2.10 38.96 4.36 4.36 4.36 4.36 4.26 27% 0.02 0.0 0.0 0.00	VA 33	30 3331 LEDs (base CFL 0.5 hrs/day) 2020	Single Family	2020	2053	25.69	2.88	9.50	9.50	27%	1.06	1.06	27%	0.21	0.21	2	2	0.42			0.00	0.00
VA 3530 3530 Base CFL Lighting - 6 hrs/day 2020 Single Family 2020 263 95.03 10.64 0.00													- , -						144.30	16.16		
VA 3530 3531 LEDs (base CFL 6 hrs/day) 2020 Single Family 2020 2053 69.37 7.77 25.66 2.87 2.87 2.87 2.87 2.87 2.87 2.87 2.87																			95.03	10.64		
VA 3630 3632 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020 Single Family 2020 2053 44.61 4.99 68.27 68.27 68.27 68.27 6.0% 7.64 6.0% 0.01 0.01 0.01 0.07 7.33 46.66 52.36 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0	VA 35	30 3531 LEDs (base CFL 6 hrs/day) 2020	Single Family	2020	2053	69.37	7.77	25.66	25.66	27%	2.87	2.87	27%	0.02	0.02	0	0	3.15			25.66	2.87
VA 3730 3730 Base Halogen (Specialty) Lighting - 2.5 hrs/day) 2020 Single Family 2020 2053 487.68 52.36 0.90 0.00 0.00 0.0		(-p)gg											- , -						112.88	12.64		
VA 3730 3732 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020 Single Family 2020 2053 184.82 20.69 282.84 282.84 60% 31.67 60% 0.00 0.00 0.00 0 0 36.67 282.84 31.67 VA 3830 3830 Base Halogen (Specialty) Lighting - 6 hrs/day) 2020 Single Family 2020 2053 309.62 34.66 0.00 0.00 0% 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A N/A N/A 309.62 34.66 0.00 0.00 0.00 0% 0.00 0% 0.00 0.00																			467,66	52.36		
VA 3830 3830 Base Halogen (Specialty) Lighting - 6 Inris/day 2020 Single Family 202 2053 39,62 34,66 0.00 0.00 0% 0.00 0.0 <th< td=""><td>VA 37</td><td>30 3732 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020</td><td>Single Family</td><td>2020</td><td>2053</td><td>184.82</td><td>20.69</td><td>282.84</td><td>282.84</td><td>60%</td><td>31.67</td><td>31.67</td><td>60%</td><td>0.00</td><td>0.00</td><td>0</td><td>0</td><td>36.67</td><td></td><td></td><td>282.84</td><td>31.67</td></th<>	VA 37	30 3732 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family	2020	2053	184.82	20.69	282.84	282.84	60%	31.67	31.67	60%	0.00	0.00	0	0	36.67			282.84	31.67
VA 3900 3900 Base Fluorescent Fixture 1.8 hrs/day Single Family 2014 2053 777.81 87.08 0.00 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A N/A 777.81 87.08 0.00 0.00																			309.62	34.66		
																			777.81	87.08		
																				200		

APPENDIX H

Base Avoided Costs

		Existing Construction				Year	2014														SUPPLY	
Vintage	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,					100.	2014		Total	B		Total	B	Marginal		Marginal	Average	Total			001121	
Ва	se Me	asure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	Economic
Sgmt Nu		mber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
	4000 4000	4000 Base Refrigerator 4001 Refrigerator (Energy Star)	Single Family Single Family	2014 2014	2053 2053	991.68 835.60	160.73 135.43	0.00 156.08	0.00 156.08	0% 16%	0.00 25.30	0.00 25.30	0% 16%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.92	991.68	160.73	0.00 156.08	0.00 25.30
	4100	4100 Base RefrigeratorEarly Replacement	Single Family	2014	2053	140.69	22.80	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	140.69	22.80	0.00	0.00
	4100 4200	4101 Refrigerator - Early Replacement (Energy Star) 4200 Base 2nd Refrigerator - Recycling	Single Family Single Family	2014 2014	2053 2053	77.73 618.86	12.60 100.30	62.96	62.96 0.00	45% 0%	10.20 0.00	10.20 0.00	45% 0%	0.09 N/A	0.09 N/A	1 N/A	1 N/A	0.61 N/A	618.86	100.30	0.00	0.00
VA	4200	4201 2nd Refrigerator Recycling	Single Family	2014	2053	159.36	25.83	459.50	459.50	74%	74.48	74.48	74%	0.03	0.03	0	0	2.24			459.50	74.48
	4500 4500	4500 Base Freezer 4501 Freezer (Energy Star)	Single Family Single Family	2014 2014	2053 2053	417.14 380.37	67.61 61.65	0.00 36.77	0.00 36.77	0% 9%	0.00 5.96	0.00 5.96	0% 9%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.24	417.14	67.61	0.00 36.77	0.00 5.96
	4600	4600 Base Early Replacement Freezer	Single Family	2014	2053	104.06	16.47	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	104.06	16.47	0.00	0.00
	4600	4601 Freezer - Early Replacement (Energy Star)	Single Family	2014	2053	47.80	7.57	56.26	56.26	54%	8.91	8.91	54%	0.04	0.04	0	0	1.47			56.26	8.91
	4700 4700	4700 Base 2nd Freezer Recycling 4701 2nd Freezer Recycling	Single Family Single Family	2014 2014	2053 2053	32.02 16.17	5.07 2.56	0.00 15.85	0.00 15.85	0% 50%	0.00 2.51	0.00 2.51	0% 50%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.09	32.02	5.07	0.00 15.85	0.00 2.51
VA	5000	5000 Base Water Heating (40 gal, EF=0.88)	Single Family	2014	2053	2,760.04	339.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2,760.04	339.93	0.00	0.00
	5000 5000	5006 Pipe Wrap 5007 Hot water turndown 5 degrees	Single Family Single Family	2014 2014	2053 2053	2,675.24 2,665.88	329.49 328.34	84.80 9.36	84.80 94.16	3% 3%	10.44 1.15	10.44 11.60	3% 3%	0.02	0.02	0	0	4.19 2.75			84.80 9.36	10.44 1.15
VA	5000	5008 Hot water turndown 10 degrees	Single Family	2014	2053	2,653.22	326.78	12.66	106.82	4%	1.56	13.16	4%	0.02	0.02	0	0	2.74			12.66	1.56
	5000 5000	5010 Hot water turndown 20 degrees 5009 Hot water turndown 15 degrees	Single Family Single Family	2014 2014	2053 2053	2,652.09	326.64 326.27	1.13 2.98	107.95 110.93	4% 4%	0.14	13.29 13.66	4% 4%	0.02	0.02	0	0	2.73 2.73			1.13 2.98	0.14
	5000	5015 Low Flow Showerhead 1.5 Gal/Min	Single Family	2014	2053	2,569.93	316.52	79.18	190.11	7%	9.75	23.41	7%	0.02	0.02	0	0	2.62			79.18	9.75
	5000	5011 Drain Water Heat Recovery (GFX)	Single Family	2014	2053	2,473.33	304.62	96.60	286.71	10%	11.90	35.31	10%	0.05	0.03	0	0	1.52			96.60	11.90
	5000 5000	5014 Faucent Aerators 5005 DHW Tank Wrap	Single Family Single Family	2014 2014	2053 2053	2,420.92 2,279.91	298.17 280.80	52.41 141.00	339.12 480.13	12% 17%	6.46 17.37	41.77 59.13	12% 17%	0.05 0.05	0.03	0	0	1.29 1.13			52.41 141.00	6.46 17.37
VA	5000	5003 Heat Pump Water Heater - Energy Star	Single Family	2014	2053	1,954.44	240.71	325.48	805.60	29%	40.09	99.22	29%	0.06	0.05	1	ō	1.09			325.48	40.09
	5000 5000	5004 Solar Domestic Water Heating 5012 Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family Single Family	2014 2014	2053 2053	1,041.06 1,038.30	128.22 127.88	913.38 2.77	1,718.98 1,721.74	62% 62%	112.49 0.34	211.71 212.05	62% 62%	0.16 3.70	0.11	1 30	1	0.48 0.02			0.00	0.00
	5000	5013 Energy Star Dishwasher (EF=0.72)	Single Family	2014	2053	1,036.03	127.60	2.27	1,724.01	62%	0.28	212.33	62%	3.64	0.12	30	1	0.02			0.00	0.00
	5100 5100	5100 Base Water Heating Early Replacement to Heat Pump Water H		2014 2014	2053 2053	487.07 417.53	59.99 51.42	0.00 69.53	0.00 69.53	0% 14%	0.00 8.56	0.00 8.56	0% 14%	N/A 0.07	N/A 0.07	N/A	N/A 1	N/A 1.06	487.07	59.99	0.00 69.53	0.00 8.56
	5100	5101 Heat Pump Water Heater - Energy Star - Early Replacement 5500 Base Clotheswasher (MEF=1.26)	Single Family Single Family	2014	2053	74.50	13.46	0.00	0.00	0%	0.00	0.00	0%	0.07 N/A	N/A	1 N/A	N/A	1.06 N/A	74.50	13.46	0.00	0.00
VA	5500	5501 Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family	2014	2053	56.55	10.22	17.95	17.95	24%	3.24	3.24	24%	1.18	1.18	7	7	0.06			0.00	0.00
	5600 5600	5600 Base Clothes Dryer (EF=3.01) 5602 High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family Single Family	2014 2014	2053 2053	1,055.90 861.96	178.70 145.88	0.00 193.94	0.00 193.94	0% 18%	0.00 32.82	0.00 32.82	0% 18%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.48	1,055.90	178.70	0.00 193.94	0.00 32.82
VA	5600	5601 Heat Pump Dryer	Single Family	2014	2053	430.98	72.94	430.98	624.92	59%	72.94	105.76	59%	0.77	0.55	5	3	0.09			0.00	0.00
	5700 5700	5700 Base Dishwasher (EF=0.65)	Single Family	2014 2014	2053 2053	256.25 247.12	42.02 40.53	0.00 9.13	0.00 9.13	0% 4%	0.00 1.50	0.00 1.50	0% 4%	N/A 1.59	N/A 1.59	N/A 10	N/A 10	N/A 0.05	256.25	42.02	0.00	0.00
	6000	5701 Energy Star Dishwasher (EF=0.72) 6000 Base Single Speed Pool Pump (RET)	Single Family Single Family	2014	2053	278.12	33.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	278.12	33.07	0.00	0.00
	6000	6002 Variable-Speed Pool Pump (<1 hp)	Single Family	2014	2053	77.04	9.16	201.08	201.08	72%	23.91	23.91	72%	0.03	0.03	0	0	2.01			201.08	23.91
	6000 7000	6001 PV-Powered Pool Pumps 7000 Base Plasma TV	Single Family Single Family	2014 2014	2053 2053	3.08 135.72	0.37 19.58	73.96 0.00	275.04 0.00	99% 0%	8.79 0.00	32.71 0.00	99% 0%	1.02 N/A	0.30 N/A	9 N/A	2 N/A	0.06 N/A	135.72	19.58	0.00	0.00
VA	7000	7001 Energy Star Plasma TV	Single Family	2014	2053	123.92	17.88	11.80	11.80	9%	1.70	1.70	9%	0.01	0.01	0	0	7.30			11.80	1.70
	7000 7100	7002 Plug Load Controls - Smart Power Strip (base plasma TV) 7100 Base LCD TV	Single Family Single Family	2014 2014	2053 2053	122.98 317.27	17.74 45.78	0.94	12.74 0.00	9% 0%	0.14	1.84 0.00	9% 0%	4.08 N/A	0.31 N/A	28 N/A	2 N/A	0.01 N/A	317.27	45.78	0.00	0.00
VA	7100	7101 Energy Star LCD TV	Single Family	2014	2053	207.82	29.98	109.45	109.45	34%	15.79	15.79	34%	0.00	0.00	0	0	16.12	0111.21	10.70	109.45	15.79
	7100 7200	7102 Plug Load Controls - Smart Power Strip (base LCD TV) 7200 Base CRT TV	Single Family	2014 2014	2053 2053	203.47 103.11	29.36 14.88	4.35 0.00	113.80	36% 0%	0.63	16.42 0.00	36% 0%	4.38 N/A	0.17 N/A	30 N/A	1 N/A	0.01 N/A	103.11	14.88	0.00	0.00
	7200	7200 Base CRT TV 7202 Plug Load Controls - Smart Power Strip (base CRT TV)	Single Family Single Family	2014	2053	97.12	14.00	5.99	5.99	6%	0.86	0.86	6%	1.20	1.20	8	8	0.04	103.11	14.00	0.00	0.00
	7300	7300 Base Set-Top Box	Single Family	2014	2053	389.53	56.20	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	389.53	56.20	0.00	0.00
	7400 7400	7400 Base DVD Player 7401 Energy Star DVD Player	Single Family Single Family	2014 2014	2053 2053	47.21 22.25	6.81 3.21	0.00 24.96	0.00 24.96	0% 53%	0.00 3.60	0.00 3.60	0% 53%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.08	47.21	6.81	0.00 24.96	0.00 3.60
VA	7400	7402 Plug Load Controls - Smart Power Strip (base DVD player)	Single Family	2014	2053	2.42	0.35	19.83	44.78	95%	2.86	6.46	95%	0.74	0.34	5	2	0.07			0.00	0.00
	7500 7500	7500 Base Desktop PC 7501 Energy Star Desktop PC	Single Family Single Family	2014 2014	2053 2053	423.38 373.57	55.78 49.21	0.00 49.81	0.00 49.81	0% 12%	0.00 6.56	0.00 6.56	0% 12%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 15.16	423.38	55.78	0.00 49.81	0.00 6.56
VA	7500	7502 Plug Load Controls - Smart Power Strip (base Desktop PC)	Single Family	2014	2053	268.77	35.41	104.80	154.61	37%	13.81	20.37	37%	0.08	0.06	1	0	0.67			0.00	0.00
	7600	7600 Base Laptop PC	Single Family	2014	2053	75.86	9.99	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	75.86	9.99	0.00	0.00
	7600 8000	7601 Energy Star Laptop PC 8000 Base Cooking	Single Family Single Family	2014 2014	2053 2053	63.79 929.00	8.40 296.60	12.07 0.00	12.07 0.00	16% 0%	1.59 0.00	1.59 0.00	16% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	2.27 N/A	929.00	296.60	12.07 0.00	1.59 0.00
VA	9000	9000 Base Miscellaneous	Single Family	2014	2053	565.76	74.53	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	565.76	74.53	0.00	0.00
	9900 9900	9900 Base House Use 9901 Indirect Feedback	Single Family Single Family	2014 2014	2053 2053	25,081.46 24,708.94	6,210.75 6,118.50	0.00 372.52	0.00 372.52	0% 1%	0.00 92.24	0.00 92.24	0% 1%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.40	25,081.46	6,210.75	0.00 372.52	0.00 92.24
VA	9900	9902 Direct Feedback	Single Family	2014	2053	23,544.13	5,830.07	1,164.81	1,537.33	6%	288.44	380.68	6%	0.06	0.05	0	0	0.99			0.00	0.00
VA VA	1000	1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER) 1024 Self Install Weatherization (CAC)	Multi-Family Multi-Family	2014	2053 2053	157.52 155.02	93.58 92.09	0.00 2.51	0.00 2.51	0% 2%	0.00 1.49	0.00 1.49	0% 2%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 4.43	157.52	93.58	0.00 2.51	0.00 1.49
	1000	1024 Self Install Weatherization (CAC) 1025 Door Weatherization (CAC)	Multi-Family Multi-Family	2014	2053	155.02 147.51	92.09 87.63	7.51	10.02	2% 6%	1.49 4.46	1.49 5.95	2% 6%	0.02	0.02	0	0	4.43 0.98			0.00	0.00
VA	1000	1022 Programmable Thermostat (CAC)	Multi-Family	2014	2053	146.36	86.95	1.15	11.16	7%	0.68	6.63	7%	0.12	0.07	0	0	0.83			0.00	0.00
VA VA	1000 1000	1004 Proper Refrigerant Charging and Air Flow (CAC) 1019 Duct Insulation (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	135.85 135.58	80.71 80.54	10.51 0.28	21.67 21.95	14% 14%	6.24 0.16	12.87 13.04	14% 14%	0.12 0.18	0.09	0	0	0.74 0.63			0.00	0.00
VA	1000	1021 Return Duct Modification (CAC)	Multi-Family	2014	2053	134.79	80.08	0.79	22.73	14%	0.47	13.51	14%	0.19	0.10	ō	0	0.61			0.00	0.00
VA VA	1000	1001 14 SEER (12.15 EER) Split-System Air Conditioner (CAC) 1002 15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Multi-Family Multi-Family	2014	2053 2053	126.15 118.61	74.95 70.47	8.64 7.54	31.37 38.91	20% 25%	5.13 4.48	18.64 23.12	20% 25%	0.20 0.24	0.13	0	0	0.55			0.00	0.00
	1000	1002 15 SEER (12.72 EER) Split-System Air Conditioner (CAC) 1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Multi-Family	2014	2053	106.03	62.99	12.58	51.49	33%	7.48	30.59	33%	0.24	0.19	1	0	0.35			0.00	0.00
VA VA	1000 1000	1014 Crawlspace insulation (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	105.66 100.02	62.77 59.42	0.37	51.87 57.50	33% 37%	0.22	30.81 34.16	33% 37%	0.35	0.19	1	0	0.32			0.00	0.00
VA VA	1000 1000	1026 Ceiling Fans (CAC) 1005 Proper Sizing and Quality Install (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	100.02 90.31	59.42 53.65	5.64 9.72	57.50 67.22	37% 43%	3.35 5.77	34.16 39.93	37% 43%	0.40 0.57	0.21	1	0	0.26 0.19			0.00	0.00
VA	1000	1023 Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	Multi-Family	2014	2053	86.20	51.21	4.11	71.33	45%	2.44	42.37	45%	0.53	0.28	1	0	0.17			0.00	0.00

APPENDIX H

Base Avoided Costs

	Electric Existing Construction				Voor	2014														SUPPLY	
DSM ASSYS Vintage	ST ADDITIVE SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY	
_			Measure					Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource				
Samt Numb	Measure per Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
VA 100	00 1008 Ceiling R-0 to R-38 Insulation (CAC)	Multi-Family	2014	2053	79.00	46.93	7.20	78.53	50%	4.28	46.65	50%	0.74	0.32	1	1	0.15	01111		0.00	0.00
VA 100 VA 100		Multi-Family Multi-Family	2014 2014	2053	77.23	45.88 44.70	1.76 1.99	80.29 82.28	51%	1.05	47.70 48.88	51% 52%	0.83	0.33	1	1	0.14			0.00	0.00
VA 100		Multi-Family	2014	2053 2053	75.24 75.15	44.70 44.64	0.09	82.28 82.38	52% 52%	0.06	48.88 48.94	52% 52%	0.88 9.01	0.34	15	1	0.13			0.00	0.00
VA 100		Multi-Family	2014	2053	69.95	41.55	5.20	87.58	56%	3.09	52.03	56%	1.08	0.40	2	i	0.08			0.00	0.00
VA 100		Multi-Family	2014	2053	68.90	40.93	1.04	88.62	56%	0.62	52.65	56%	2.03	0.42	3	1	0.06			0.00	0.00
VA 100 VA 100		Multi-Family	2014 2014	2053	66.71 66.09	39.63 39.26	2.19 0.62	90.82 91.43	58% 58%	1.30 0.37	53.95 54.32	58% 58%	1.93	0.45 0.47	3	1	0.05 0.05			0.00	0.00
VA 100		Multi-Family Multi-Family	2014	2053 2053	62.19	36.95	3.90	95.33	61%	2.32	56.64	61%	2.47 1.93	0.47	3	1	0.05			0.00	0.00
VA 100		Multi-Family	2014	2053	58.54	34.78	3.65	98.98	63%	2.17	58.80	63%	2.43	0.60	4	1	0.04			0.00	0.00
VA 100		Multi-Family	2014	2053	58.51	34.76	0.04	99.02	63%	0.02	58.82	63%	11.58	0.60	19	1	0.01			0.00	0.00
VA 100 VA 100		Multi-Family Multi-Family	2014 2014	2053 2053	58.40 58.39	34.70 34.69	0.11 0.01	99.12 99.13	63% 63%	0.06	58.89 58.89	63% 63%	4.03 11.61	0.60 0.61	7 20	1	0.03			0.00	0.00
VA 100		Multi-Family	2014	2053	58.08	34.59	0.01	99.13	63%	0.01	59.08	63%	6.44	0.61	11	1	0.01			0.00	0.00
VA 100		Multi-Family	2014	2053	57.95	34.43	0.13	99.57	63%	0.08	59.16	63%	6.52	0.63	11	1	0.02			0.00	0.00
VA 100		Multi-Family	2014	2053	57.78	34.32	0.17	99.75	63%	0.10	59.26	63%	6.33	0.64	11	1	0.01			0.00	0.00
VA 100		Multi-Family	2014 2014	2053 2053	57.60 47.64	34.22 28.30	0.18	99.93	63% 0%	0.11	59.37 0.00	63% 0%	7.24 N/A	0.65 N/A	12 N/A	1 N/A	0.01 N/A	47.64	28.30	0.00	0.00
VA 110		Multi-Family	2014	2053	46.84	27.83	0.80	0.80	2%	0.48	0.00	2%	0.01	0.01	0	0	7.59	47.04	20.30	0.80	0.48
VA 110	00 1117 Duct Insulation (CAC early replacement)	Multi-Family	2014	2053	46.46	27.60	0.38	1.19	2%	0.23	0.70	2%	0.02	0.02	ō	ō	4.95			0.38	0.23
VA 110		Multi-Family	2014	2053	44.26	26.29	2.20	3.39	7%	1.31	2.01	7%	0.04	0.03	0	0	1.63			2.20	1.31
VA 110		Multi-Family	2014	2053 2053	43.91 40.08	26.09 23.81	0.34 3.83	3.73 7.56	8% 16%	0.20 2.28	2.22	8% 16%	0.07	0.04	0	0	1.41			0.34 3.83	0.20
VA 110		Multi-Family	2014	2053	39.85	23.67	0.23	7.56	16%	0.14	4.49	16%	0.07	0.05	0	0	1.02			0.23	0.14
VA 110		Multi-Family	2014	2053	39.71	23.59	0.14	7.94	17%	0.08	4.71	17%	0.17	0.06	Ö	Ö	0.69			0.00	0.00
VA 110		Multi-Family	2014	2053	35.27	20.95	4.44	12.37	26%	2.64	7.35	26%	0.17	0.10	0	0	0.62			0.00	0.00
VA 110		Multi-Family	2014 2014	2053 2053	28.39 27.68	16.87 16.45	6.88 0.71	19.25 19.96	40% 42%	4.09 0.42	11.44 11.86	40% 42%	0.23 0.37	0.14 0.15	0	0	0.46 0.31			0.00	0.00
VA 110		Multi-Family	2014	2053	24.43	14.52	3.25	23.21	42%	1.93	13.79	42%	0.37	0.15	1	0	0.31			0.00	0.00
VA 110		Multi-Family	2014	2053	23.71	14.08	0.73	23.93	50%	0.43	14.22	50%	0.43	0.19	1	0	0.26			0.00	0.00
VA 110	00 1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early re	Multi-Family	2014	2053	22.63	13.44	1.08	25.01	53%	0.64	14.86	53%	0.35	0.20	1	0	0.25			0.00	0.00
VA 110		Multi-Family	2014	2053	20.74	12.32	1.89	26.90	56%	1.12	15.98	56%	0.50	0.22	1	0	0.23			0.00	0.00
VA 110		Multi-Family Multi-Family	2014 2014	2053 2053	20.71	12.31 12.17	0.03 0.23	26.93 27.16	57% 57%	0.02	16.00 16.14	57% 57%	5.77 0.67	0.22	10 1	0	0.02			0.00	0.00
VA 110		Multi-Family	2014	2053	19.95	11.85	0.53	27.69	58%	0.32	16.45	58%	0.74	0.24	1	0	0.17			0.00	0.00
VA 110	00 1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Multi-Family	2014	2053	19.65	11.67	0.30	27.99	59%	0.18	16.63	59%	1.26	0.25	2	0	0.09			0.00	0.00
VA 110			2014	2053	18.71	11.12	0.94	28.93	61%	0.56	17.19	61%	1.06	0.27	2	0	0.08			0.00	0.00
VA 110		Multi-Family Multi-Family	2014 2014	2053 2053	18.54 18.53	11.01 11.01	0.17 0.01	29.10 29.11	61% 61%	0.10	17.29 17.30	61% 61%	1.55 6.45	0.28	3 11	0	0.07 0.02			0.00	0.00
VA 110		Multi-Family	2014	2053	17.68	10.50	0.85	29.97	63%	0.51	17.80	63%	1.56	0.20	3	1	0.02			0.00	0.00
VA 110	00 1110 Ceiling R-19 to R-38 Insulation (CAC early replacement)	Multi-Family	2014	2053	17.64	10.48	0.03	30.00	63%	0.02	17.82	63%	2.36	0.32	4	1	0.05			0.00	0.00
VA 110		Multi-Family	2014	2053	17.64	10.48	0.00	30.00	63%	0.00	17.82	63%	6.78	0.32	11	1	0.02			0.00	0.00
VA 110		Multi-Family Multi-Family	2014 2014	2053 2053	16.74 16.65	9.95 9.89	0.90 0.09	30.90 30.99	65% 65%	0.53	18.36 18.41	65% 65%	2.57 3.97	0.39	4 7	1	0.03			0.00	0.00
VA 110		Multi-Family	2014	2053	16.60	9.86	0.05	31.04	65%	0.03	18.44	65%	3.89	0.40	7	1	0.03			0.00	0.00
VA 110	00 1104 AC Maintenance and/or tune-up (CAC early replacement)	Multi-Family	2014	2053	16.55	9.83	0.05	31.09	65%	0.03	18.47	65%	4.44	0.41	7	1	0.02			0.00	0.00
VA 120		Multi-Family	2014	2053	245.48	145.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	245.48	145.83	0.00	0.00
VA 120 VA 120		Multi-Family Multi-Family	2014 2014	2053 2053	243.47 239.60	144.64 142.34	2.00 3.88	2.00 5.88	1% 2%	1.19 2.30	1.19 3.49	1% 2%	0.03 0.04	0.03	0	0	4.16 2.38			2.00 3.88	1.19 2.30
VA 120		Multi-Family	2014	2053	227.99	135.45	11.61	17.49	7%	6.90	10.39	7%	0.05	0.05	0	0	1.38			11.61	6.90
VA 120	00 1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Multi-Family	2014	2053	189.36	112.50	38.63	56.12	23%	22.95	33.34	23%	0.08	0.07	0	0	1.24			38.63	22.95
VA 120		Multi-Family	2014	2053	175.77	104.42	13.59	69.71	28%	8.08	41.41	28%	0.10	0.08	0	0	0.87			0.00	0.00
VA 120 VA 120		Multi-Family Multi-Family	2014 2014	2053 2053	172.29 171.68	102.35 101.99	3.48 0.60	73.19 73.79	30% 30%	2.07 0.36	43.48 43.84	30% 30%	0.16 0.24	0.08 0.08	0	0	0.60 0.48			0.00	0.00
VA 120		Multi-Family	2014	2053	152.50	90.60	19.19	92.98	38%	11.40	55.24	38%	0.24	0.08	0	0	0.43			0.00	0.00
VA 120	00 1226 Whole House Fans (HP cooling)	Multi-Family	2014	2053	122.76	72.93	29.74	122.72	50%	17.67	72.91	50%	0.33	0.17	1	Ō	0.32			0.00	0.00
VA 120		Multi-Family	2014	2053	119.11	70.76	3.65	126.37	51%	2.17	75.07	51%	0.53	0.18	1	0	0.21			0.00	0.00
VA 120 VA 120		Multi-Family Multi-Family	2014 2014	2053 2053	113.69 104.09	67.54 61.84	5.42 9.59	131.79 141.38	54% 58%	3.22 5.70	78.29 83.99	54% 58%	0.44 0.61	0.19 0.22	1	0	0.20 0.19			0.00	0.00
VA 120		Multi-Family	2014	2053	93.98	55.83	10.11	151.49	62%	6.01	90.00	62%	0.75	0.22	1	0	0.19			0.00	0.00
VA 120	00 1209 Ceiling R-0 to R-49 Insulation (HP cooling)	Multi-Family	2014	2053	93.72	55.68	0.26	151.76	62%	0.15	90.16	62%	3.57	0.26	6	Ō	0.03			0.00	0.00
VA 120		Multi-Family	2014	2053	92.69	55.07	1.03	152.79	62%	0.61	90.77	62%	0.92	0.26	2	0	0.12			0.00	0.00
VA 120 VA 120		Multi-Family Multi-Family	2014 2014	2053 2053	90.38 88.02	53.69 52.29	2.31 2.36	155.10 157.46	63% 64%	1.37	92.14 93.54	63% 64%	1.08 1.05	0.28	2	0	0.11			0.00	0.00
VA 120		Multi-Family	2014	2053	86.67	52.29 51.49	1.35	157.46	65%	0.80	93.54	65%	1.73	0.29	3	1	0.10			0.00	0.00
VA 120		Multi-Family	2014	2053	86.55	51.42	0.13	158.93	65%	0.07	94.42	65%	3.87	0.30	7	1	0.03			0.00	0.00
VA 120	00 1216 Floor R-0 to R-19 Insulation-Batts (HP cooling)	Multi-Family	2014	2053	85.65	50.88	0.90	159.83	65%	0.53	94.95	65%	2.42	0.31	4	1	0.05			0.00	0.00
VA 120		Multi-Family Multi-Family	2014 2014	2053 2053	85.50 85.47	50.79 50.77	0.15	159.98 160.01	65% 65%	0.09	95.04 95.06	65% 65%	3.12 3.93	0.32	5 7	1	0.04			0.00	0.00
VA 120		Multi-Family Multi-Family	2014	2053	85.47 84.77	50.77	0.03	160.01	65% 65%	0.02	95.06 95.48	65% 65%	3.93 7.69	0.32	13	1	0.03			0.00	0.00
VA 120		Multi-Family	2014	2053	84.51	50.21	0.26	160.97	66%	0.15	95.63	66%	5.86	0.36	10	1	0.01			0.00	0.00
VA 120	00 1206 Heat pump tune up	Multi-Family	2014	2053	84.25	50.05	0.27	161.23	66%	0.16	95.79	66%	9.46	0.37	16	. 1	0.01			0.00	0.00
VA 130		Multi-Family	2014	2053	44.29	26.31	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	44.29	26.31	0.00	0.00
VA 130	00 1319 Duct Insulation (HP cooling Early Replacement)	Multi-Family	2014	2053	43.93	26.10	0.36	0.36	1%	0.21	0.21	1%	0.03	0.03	0	0	4.25			0.36	0.21

1/5/2015 DNV GL H-5

APPENDIX H

Base Avoided Costs

	I Electric Existing Construction /ST ADDITIVE SUPPLY ANALYSIS				١	/ear	2014														SUPPLY	
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Bas Sgmt Nun	e Measure ober Number Measure		uilding Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
VA 1	 300 1323 Self Install Weatherization (H 300 1324 Door Weatherization (HP cod 		lti-Family lti-Family	2014 2014	2053 2053	43.23 41.18	25.68 24.47	0.70 2.05	1.06 3.11	2% 7%	0.42 1.22	0.63 1.85	2% 7%	0.04	0.03	0	0	2.43 1.38			0.70 2.05	0.42 1.22
VA 1	300 1302 Heat pump upgrade to (16+ \$	SEER, 8.7+ HSPF) (HP cooling Ea Mult		2014	2053	34.20	20.32	6.98	10.09	23%	4.15	5.99	23%	0.08	0.07	0	0	1.27			6.98	4.15
	 300 1304 Proper Refrigerant Charging 300 1314 Crawlspace insulation (HP co 	and Air Flow (HP cooling Early Re Mult	lti-Family	2014 2014	2053 2053	31.75 31.64	18.86 18.80	2.46 0.11	12.54 12.65	28% 29%	1.46	7.45 7.52	28% 29%	0.10 0.23	0.08	0	0	0.89			0.00	0.00
	300 1314 Grawispace insulation (HP co 300 1321 Programmable Thermostat (F		Iti-Family Iti-Family	2014	2053	31.64	18.42	0.11	13.28	30%	0.07	7.52	29% 30%	0.23	0.08	0	0	0.50			0.00	0.00
	300 1318 Cool Roof (HP cooling Early	Replacement) Mult	Iti-Family	2014	2053	27.55	16.36	3.47	16.74	38%	2.06	9.95	38%	0.24	0.12	0	0	0.44			0.00	0.00
	 300 1326 Whole House Fans (HP cooli 300 1320 Duct Testing and Sealing (HF 		lti-Family lti-Family	2014 2014	2053 2053	22.17 21.51	13.17 12.78	5.37 0.66	22.12 22.78	50% 51%	3.19 0.39	13.14 13.53	50% 51%	0.32	0.17	1	0	0.32 0.21			0.00	0.00
		ling - Inf. Reduction (HP cooling E Mult	,	2014	2053	20.54	12.20	0.98	23.75	54%	0.58	14.11	54%	0.43	0.19	1	0	0.21			0.00	0.00
	300 1308 Ceiling R-0 to R-38 Insulation		lti-Family	2014	2053	18.80	11.17	1.73	25.49	58%	1.03	15.14	58%	0.60	0.21	1	0	0.19			0.00	0.00
	 1305 Proper Sizing and Quality Ins 1309 Ceiling R-0 to R-49 Insulation 	tall (HP cooling Early Replacement) Mult	lti-Family lti-Family	2014 2014	2053 2053	16.98 16.93	10.09 10.06	1.83 0.05	27.31 27.36	62% 62%	1.09 0.03	16.23 16.25	62% 62%	0.73 3.49	0.25 0.25	1 6	0	0.15			0.00	0.00
VA 1	300 1315 Basement insulation R-13 (H	P cooling Early Replacement) Mult	lti-Family	2014	2053	16.74	9.95	0.19	27.55	62%	0.11	16.37	62%	0.90	0.26	2	0	0.13			0.00	0.00
		Clear to Energy Star (HP cooling I Mult		2014	2053	16.33	9.70	0.42	27.96	63%	0.25	16.61	63%	1.06	0.27	2	0	0.11			0.00	0.00
	 300 1325 Ceiling Fans (HP cooling earl 300 1310 Ceiling R-11 to R-38 Insulato 	n (HP cooling Early Replacement) Mult	lti-Family Iti-Family	2014 2014	2053 2053	15.90 15.66	9.45 9.30	0.43 0.24	28.39 28.63	64% 65%	0.25 0.14	16.87 17.01	64% 65%	1.02 1.69	0.28	2	0	0.10 0.07			0.00	0.00
VA 1	300 1311 Ceiling R-11 to R-49 Insulation	on (HP cooling Early Replacement; Mult	lti-Family	2014	2053	15.63	9.29	0.02	28.66	65%	0.01	17.02	65%	3.78	0.30	6	0	0.03			0.00	0.00
		Batts (HP cooling Early Replaceme Mult on (HP cooling Early Replacement Mult		2014 2014	2053 2053	15.47 15.44	9.19 9.18	0.16 0.03	28.82 28.85	65% 65%	0.10	17.12 17.14	65% 65%	2.37 3.05	0.31	4 5	1	0.05 0.04			0.00	0.00
		on (HP cooling Early Replacement, Multi		2014	2053	15.44	9.17	0.03	28.85	65%	0.02	17.14	65%	3.83	0.31	6	1	0.04			0.00	0.00
	300 1317 Wall Blow-in R-0 to R-13 Inst	ulation (HP cooling Early Replacer Mult	Iti-Family	2014	2053	15.31	9.10	0.13	28.98	65%	0.08	17.22	65%	7.51	0.34	13	1	0.02			0.00	0.00
	 300 1307 Heat Pump Filter Replaceme 300 1306 Heat pump tune up 		lti-Family Iti-Family	2014 2014	2053 2053	15.27 15.22	9.07 9.04	0.05 0.05	29.02 29.07	66% 66%	0.03	17.24 17.27	66% 66%	5.73 9.24	0.35 0.37	10 16	1	0.01 0.01			0.00	0.00
	400 1400 Base Room Air Conditioner -		lti-Family	2014	2053	13.91	8.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.91	8.26	0.00	0.00
	400 1413 Self Install Weatherization (R		lti-Family	2014	2053	13.69	8.13	0.22	0.22	2%	0.13	0.13	2%	0.01	0.01	0	0	8.99			0.22	0.13
	400 1414 Door Weatherization (RAC) 400 1411 Cool Roof (RAC)		lti-Family Iti-Family	2014 2014	2053 2053	13.02 11.57	7.74 6.87	0.66 1.46	0.88 2.34	6% 17%	0.39	0.53 1.39	6% 17%	0.04	0.03	0	0	1.99 0.82			0.66	0.39
	400 1416 Whole House Fans (RAC)		lti-Family	2014	2053	9.31	5.53	2.26	4.60	33%	1.34	2.73	33%	0.17	0.13	0	0	0.61			0.00	0.00
	400 1412 Comprehensive Shell Air Sea 400 1419 WINDOWS - Double-Glazed		Iti-Family	2014 2014	2053 2053	8.81 8.59	5.23 5.10	0.51 0.22	5.10 5.32	37% 38%	0.30	3.03	37% 38%	0.19 0.29	0.14	0	0	0.48			0.00	0.00
	400 1419 WINDOWS - Double-Glazed 400 1402 HE Room Air Conditioner - C		lti-Family Iti-Family	2014	2053	8.08	5.10 4.80	0.22	5.32	38% 42%	0.13	3.16 3.46	38% 42%	0.29	0.14	0	0	0.39			0.00	0.00
VA 1	400 1404 Ceiling R-0 to R-38 Insulation		lti-Family	2014	2053	7.44	4.42	0.64	6.47	46%	0.38	3.84	46%	0.36	0.17	1	Ō	0.31			0.00	0.00
	400 1405 Ceiling R-0 to R-49 Insulation 400 1415 Ceiling Fans (RAC)		lti-Family Iti-Family	2014 2014	2053 2053	7.43 7.23	4.41 4.30	0.02	6.48 6.68	47% 48%	0.01 0.12	3.85 3.97	47% 48%	2.17 0.50	0.18	4 1	0	0.05 0.21			0.00	0.00
	400 1415 Ceiling Fans (RAC) 400 1417 Window Film (RAC)		lti-Family	2014	2053	6.58	3.91	0.19	7.33	53%	0.12	4.35	53%	0.50	0.16	1	0	0.21			0.00	0.00
	400 1410 Wall Blow-in R-0 to R-13 Inst		lti-Family	2014	2053	6.52	3.87	0.07	7.39	53%	0.04	4.39	53%	1.00	0.22	2	0	0.11			0.00	0.00
• • • • • •	 400 1418 WINDOWS - Default With S 400 1406 Ceiling R-11 to R-38 Insulato 		lti-Family Iti-Family	2014 2014	2053 2053	6.20	3.69 3.64	0.31 0.08	7.70 7.79	55% 56%	0.18 0.05	4.58 4.63	55% 56%	0.79 1.10	0.24 0.25	1 2	0	0.11 0.10			0.00	0.00
	400 1407 Ceiling R-11 to R-49 Insulation		lti-Family	2014	2053	6.11	3.63	0.01	7.80	56%	0.00	4.63	56%	2.64	0.25	4	0	0.04			0.00	0.00
	400 1408 Ceiling R-19 to R-38 Insulation 400 1409 Ceiling R-19 to R-49 Insulation		lti-Family lti-Family	2014 2014	2053 2053	6.10	3.63 3.62	0.01	7.81 7.81	56% 56%	0.01	4.64 4.64	56% 56%	1.84 2.65	0.26	3 4	0	0.06			0.00	0.00
	 400 1409 Ceiling R-19 to R-49 Insulation 400 1403 Room AC Filter Replacement 		Iti-Family	2014	2053	6.08	3.62	0.00	7.81	56%	0.00	4.65	56%	2.65	0.26	4	0	0.04			0.00	0.00
VA 1	500 1500 Base Room Air Conditioner, I	Early Replacement - EER 9.7 Mult	lti-Family	2014	2053	1.09	0.65	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.09	0.65	0.00	0.00
	 1501 EER 8.5 RAC Early Replacer 1600 Base Dehumidifier (40 pints/d 	nent, CEE Tier 1 EER 11.3 (early Mult	lti-Family Iti-Family	2014 2014	2053 2053	0.95 3.17	0.56 1.88	0.15 0.00	0.15 0.00	13% 0%	0.09	0.09	13% 0%	1.05 N/A	1.05 N/A	2 N/A	2 N/A	0.08 N/A	3.17	1.88	0.00	0.00
		Dehumidifier ROB (35-45 pints/da Mult		2014	2053	2.68	1.59	0.49	0.49	15%	0.29	0.00	15%	0.19	0.19	0	0	0.52	3.17	1.00	0.00	0.00
	700 1700 Base Furnace Fan - Furnace	& CAC Mult	lti-Family	2014	2053	232.33	119.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	232.33	119.17	0.00	0.00
	 700 1701 ECM Furnace Fan (variable s 2000 Base Heat Pump Space Heat 		lti-Family Iti-Family	2014 2014	2053 2053	129.07 362.58	66.21 43.02	103.26 0.00	103.26 0.00	44% 0%	52.97 0.00	52.97 0.00	44% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	3.76 N/A	362.58	43.02	103.26 0.00	52.97 0.00
VA 2	2016 Duct Insulation (HP heating)	Mult	lti-Family	2014	2053	359.63	42.67	2.96	2.96	1%	0.35	0.35	1%	0.02	0.02	0	0	3.57	- 32.00	10.02	2.96	0.35
	 2021 Self Install Weatherization (H 2022 Door Weatherization (HP hea 		Iti-Family Iti-Family	2014 2014	2053 2053	353.90 340.51	41.99 40.40	5.72 13.39	8.68 22.07	2% 6%	0.68 1.59	1.03 2.62	2% 6%	0.03	0.03	0	0	2.18 1.04			5.72 13.39	0.68 1.59
	2022 Door Weatherization (HP hea 2000 2002 Heat pump upgrade to 16+ S		Iti-Family Iti-Family	2014	2053	340.51	40.40 36.68	13.39 31.38	53.45	6% 15%	1.59 3.72	6.34	6% 15%	0.05	0.04	1	1	1.04 0.65			0.00	0.00
VA 2	000 2012 Crawlspace insulation (HP he	eating) Mult	lti-Family	2014	2053	308.05	36.55	1.08	54.53	15%	0.13	6.47	15%	0.15	0.08	1	1	0.50			0.00	0.00
	 2019 Programmable Thermostat (h 2020 Comprehensive Shell Air Sea 		lti-Family lti-Family	2014	2053	301.95 288.21	35.83 34.20	6.10 13.74	60.63 74.37	17% 21%	0.72 1.63	7.19 8.82	17% 21%	0.14	0.09	1 2	1	0.48			0.00	0.00
	000 2017 Duct Testing and Sealing (HF		Iti-Family Iti-Family	2014	2053	279.65	34.20	8.57	74.37 82.94	21%	1.02	9.84	23%	0.20	0.11	2	1	0.32			0.00	0.00
	000 2006 Ceiling R-0 to R-38 Insulation	n (HP heating) Mult	lti-Family	2014	2053	256.05	30.38	23.59	106.53	29%	2.80	12.64	29%	0.29	0.16	2	1	0.27			0.00	0.00
	 2007 Ceiling R-0 to R-49 Insulation 2013 Basement insulation R-13 (H 		lti-Family lti-Family	2014 2014	2053 2053	255.34 252.53	30.30 29.96	0.71 2.82	107.24 110.06	30% 30%	0.08	12.72 13.06	30% 30%	1.52 0.39	0.17 0.18	13 3	1	0.05 0.20			0.00	0.00
VA 2	000 2018 Heat Recovery Ventilators (H	P heating) Mult	lti-Family	2014	2053	197.73	23.46	54.80	164.86	45%	6.50	19.56	45%	0.43	0.26	4	2	0.18			0.00	0.00
	000 2023 WINDOWS - Double-Glazed	Clear to Energy Star (HP heating) Mult	Iti-Family	2014	2053	192.95	22.89	4.78	169.63	47%	0.57	20.13	47%	0.61	0.27	5	2	0.13			0.00	0.00
	2008 Ceiling R-11 to R-38 Insulato 2009 Ceiling R-11 to R-49 Insulation		lti-Family Iti-Family	2014 2014	2053 2053	190.00 189.73	22.54 22.51	2.95 0.27	172.58 172.86	48% 48%	0.35	20.48 20.51	48% 48%	0.92 2.04	0.28	8 17	2	0.08 0.04			0.00	0.00
VA 2	000 2014 Floor R-0 to R-19 Insulation-	Batts (HP heating) Mult	lti-Family	2014	2053	187.75	22.28	1.97	174.83	48%	0.23	20.74	48%	1.28	0.30	11	2	0.06			0.00	0.00
	 2003 Ground Source Heat Pump w 2010 Ceiling R-19 to R-38 Insulation 		lti-Family lti-Family	2014 2014	2053 2053	170.46 170.17	20.23 20.19	17.29 0.30	192.12 192.42	53% 53%	2.05 0.04	22.79 22.83	53% 53%	2.45 1.81	0.49	21 15	4	0.03 0.04			0.00	0.00
	000 2011 Ceiling R-19 to R-38 Insulation		Iti-Family Iti-Family	2014	2053	170.17	20.19	0.30	192.42	53%	0.04	22.83	53%	2.28	0.49	19	4	0.04			0.00	0.00
	000 2015 Wall Blow-in R-0 to R-13 Inst	ulation (HP heating) Mult	lti-Family	2014	2053	168.71	20.02	1.39	193.88	53%	0.17	23.00	53%	4.47	0.52	38	4	0.02			0.00	0.00
	2005 Heat Pump Filter Replaceme 2000 2004 Heat pump tune up		lti-Family Iti-Family	2014 2014	2053 2053	168.20 167.67	19.96 19.89	0.51 0.53	194.38 194.91	54% 54%	0.06	23.06 23.13	54% 54%	3.41 5.50	0.53 0.54	29 46	4 5	0.01 0.01			0.00	0.00
		ing - Early Replacement (7.7 HSP Mult		2014	2053	87.04	10.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	87.04	10.33	0.00	0.00
VA 2	100 2116 Duct Insulation (HP heating e	early replacement) Mult	lti-Family	2014	2053	86.32	10.24	0.71	0.71	1%	80.0	0.08	1%	0.02	0.02	0	0	4.86			0.71	0.08

DNV GL H-6 1/5/2015

APPENDIX H

Base Avoided Costs

		tric Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base N lumber N	Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic MW
VA	2100	2121 Self Install Weatherization (HP heating early replacement)	Multi-Family	2014	2053	84.95	10.08	1.37	2.08	2%	0.16	0.25	2%	0.02	0.02	0	0	2.97			1.37	0.16
VA VA	2100 2100	2122 Door Weatherization (HP heating early replacement) 2102 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early	Multi-Family Multi-Family	2014 2014	2053 2053	82.59 74.98	9.80 8.90	2.36 7.61	4.44 12.05	5% 14%	0.28	0.53 1.43	5% 14%	0.05	0.04	0	0	1.04 0.89			2.36 0.00	0.28
VA	2100	2112 Crawlspace insulation (HP heating early replacement)	Multi-Family	2014	2053	74.72	8.87	0.26	12.32	14%	0.03	1.46	14%	0.11	0.07	1	1	0.68			0.00	0.00
VA VA	2100 2100	2119 Programmable Thermostat (HP heating early replacement)	Multi-Family	2014 2014	2053	73.24 69.91	8.69	1.48	13.79 17.13	16%	0.18	1.64	16% 20%	0.10 0.15	0.07	1	1	0.66 0.44			0.00	0.00
VA	2100	2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating e 2117 Duct Testing and Sealing (HP heating early replacement)	Multi-Family	2014	2053 2053	67.83	8.29 8.05	3.33 2.08	17.13	20% 22%	0.40	2.03 2.28	20%	0.15	0.08	2	1	0.44			0.00	0.00
VA	2100	2106 Ceiling R-0 to R-38 Insulation (HP heating early replacement)	Multi-Family	2014	2053	62.11	7.37	5.72	24.93	29%	0.68	2.96	29%	0.21	0.12	2	1	0.37			0.00	0.00
VA VA	2100 2100	2107 Ceiling R-0 to R-49 Insulation (HP heating early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	61.94 61.25	7.35 7.27	0.17 0.69	25.10 25.79	29% 30%	0.02	2.98 3.06	29% 30%	1.10 0.28	0.13	9	1	0.07 0.27			0.00	0.00
VA	2100	2113 Basement insulation R-13 (HP heating early replacement) 2118 Heat Recovery Ventilators (HP heating early replacement)	Multi-Family	2014	2053	47.96	5.69	13.29	39.08	45%	1.58	4.64	45%	0.28	0.13	3	2	0.24			0.00	0.00
VA	2100	2123 WINDOWS - Double-Glazed Clear to Energy Star (HP heating	Multi-Family	2014	2053	46.80	5.55	1.16	40.24	46%	0.14	4.77	46%	0.44	0.20	4	2	0.17			0.00	0.00
VA VA	2100 2100	2108 Ceiling R-11 to R-38 Insulaton (HP heating early replacement) 2109 Ceiling R-11 to R-49 Insulation (HP heating early replacement)	Multi-Family	2014 2014	2053 2053	46.08 46.02	5.47 5.46	0.72 0.07	40.95 41.02	47% 47%	0.08	4.86 4.87	47% 47%	0.67 1.49	0.21 0.21	6 13	2	0.12			0.00	0.00
VA	2100	2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replacement		2014	2053	45.54	5.40	0.48	41.50	48%	0.06	4.92	48%	0.93	0.22	8	2	0.08			0.00	0.00
VA	2100	2103 Ground Source Heat Pump with Desuperheater (HP heating ear		2014	2053	41.34	4.91	4.19	45.69	52%	0.50	5.42	52%	1.78	0.36	15	3	0.04			0.00	0.00
VA VA	2100 2100	2110 Ceiling R-19 to R-38 Insulation (HP heating early replacement) 2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement)		2014 2014	2053 2053	41.27 41.26	4.90 4.89	0.07	45.76 45.78	53% 53%	0.01	5.43 5.43	53% 53%	1.32 1.66	0.37	11 14	3	0.06			0.00	0.00
VA	2100	2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacem		2014	2053	40.92	4.85	0.34	46.12	53%	0.04	5.47	53%	3.25	0.39	27	3	0.02			0.00	0.00
VA	2100	2105 Heat Pump Filter Replacement (heating)	Multi-Family	2014	2053	40.79	4.84	0.12	46.24	53%	0.01	5.49	53%	2.48	0.39	21	3	0.02			0.00	0.00
VA VA	2100 2200	2104 Heat pump tune up (heating) 2200 Base Resistance Space Heating (Primary)	Multi-Family Multi-Family	2014 2014	2053 2053	40.67 374.37	4.83 44.42	0.13 0.00	46.37 0.00	53% 0%	0.02	5.50	53% 0%	4.00 N/A	0.40 N/A	34 N/A	3 N/A	0.01 N/A	374.37	44.42	0.00	0.00
VA	2200	2201 Air Source Heat Pump (resistance heating)	Multi-Family	2014	2053	295.43	35.05	78.94	78.94	21%	9.37	9.37	21%	0.01	0.01	0	0	5.85	01 1.01	2	78.94	9.37
VA	2200	2216 Self Install Weatherization	Multi-Family	2014	2053	290.73	34.49	4.70	83.64	22%	0.56	9.92	22%	0.02	0.01	0	0	2.89			4.70	0.56
VA VA	2200	2217 Door Weatherization (resistance heating) 2214 Programmable Thermostat (resistance heating)	Multi-Family Multi-Family	2014 2014	2053 2053	277.47 271.97	32.92 32.27	13.26 5.49	96.90 102.40	26% 27%	1.57 0.65	11.50 12.15	26% 27%	0.03	0.02	0	0	1.67			13.26	1.57
VA	2200	2209 Crawlspace insulation (resistance heating)	Multi-Family	2014	2053	270.90	32.14	1.08	103.48	28%	0.13	12.28	28%	0.10	0.02	1	Ö	0.80			0.00	0.00
VA	2200	2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance he		2014 2014	2053	258.57	30.68	12.33	115.80	31%	1.46	13.74	31%	0.14	0.03	1	0	0.46			0.00	0.00
VA VA	2200 2200	2203 Ceiling R-0 to R-38 Insulation (resistance heating) 2204 Ceiling R-0 to R-49 Insulation (resistance heating)	Multi-Family Multi-Family	2014	2053 2053	234.98 234.42	27.88 27.81	23.59 0.56	139.39 139.95	37% 37%	2.80 0.07	16.54 16.60	37% 37%	0.18 1.20	0.06	2 10	0	0.43			0.00	0.00
VA	2200	2210 Basement insulation R-13 (resistance heating)	Multi-Family	2014	2053	230.44	27.34	3.98	143.93	38%	0.47	17.08	38%	0.26	0.07	2	1	0.29			0.00	0.00
VA	2200	2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance h		2014	2053	224.09	26.59	6.35	150.28	40%	0.75	17.83	40%	0.28	0.08	2	1	0.27			0.00	0.00
VA VA	2200 2200	2213 Heat Recovery Ventilators (resistance heating) 2205 Ceiling R-11 to R-38 Insulaton (resistance heating)	Multi-Family Multi-Family	2014 2014	2053 2053	175.46 172.56	20.82 20.47	48.63 2.91	198.91 201.81	53% 54%	5.77 0.34	23.60 23.94	53% 54%	0.30	0.13 0.14	3 5	1	0.25 0.13			0.00	0.00
VA	2200	2211 Floor R-0 to R-19 Insulation-Batts (resistance heating)	Multi-Family	2014	2053	170.03	20.17	2.53	204.34	55%	0.30	24.24	55%	0.62	0.14	5	1	0.12			0.00	0.00
VA	2200	2206 Ceiling R-11 to R-49 Insulation (resistance heating)	Multi-Family	2014	2053	169.82	20.15	0.21	204.55	55%	0.02	24.27	55%	1.66	0.15	14	1	0.05			0.00	0.00
VA VA	2200 2200	2202 Ground Source Heat Pump with Desuperheater (resistance hea 2207 Ceiling R-19 to R-38 Insulation (resistance heating)	Multi-Family	2014 2014	2053 2053	170.00 169.66	20.17 20.13	-0.18 0.34	204.37 204.71	55% 55%	-0.02 0.04	24.25 24.29	55% 55%	-154.51 0.99	0.29	-1,302 8	2	0.00			0.00	0.00
VA	2200	2208 Ceiling R-19 to R-49 Insulation (resistance heating)	Multi-Family	2014	2053	169.61	20.12	0.05	204.77	55%	0.01	24.29	55%	1.67	0.29	14	2	0.05			0.00	0.00
VA VA	2200 3030	2212 Wall Blow-in R-0 to R-13 Insulation (resistance heating)	Multi-Family	2014 2020	2053	167.68 21.22	19.89 2.38	1.93	206.69	55% 0%	0.23	24.52 0.00	55% 0%	2.01 N/A	0.30 N/A	17 N/A	3	0.04	24.22	2.38	0.00	0.00
VA	3030	3030 Base Halogen Lighting - 0.5 hrs/day 2020 3032 LEDs (base Halogen 0.5 hrs/day) 2020	Multi-Family Multi-Family	2020	2053 2053	5.56	0.62	15.66	15.66	74%	1.75	1.75	74%	0.03	0.03	0	N/A 0	N/A 2.64	21.22	2.30	15.66	1.75
VA	3130	3130 Base Halogen Lighting - 2.5 hrs/day 2020	Multi-Family	2020	2053	88.41	9.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	88.41	9.90	0.00	0.00
VA VA	3130 3230	3132 LEDs (base Halogen 2.5 hrs/day) 2020 3230 Base Halogen Lighting - 6 hrs/day 2020	Multi-Family Multi-Family	2020 2020	2053 2053	23.16 55.17	2.59 6.18	65.25 0.00	65.25 0.00	74% 0%	7.30	7.30 0.00	74% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	13.20 N/A	55.17	6.18	65.25 0.00	7.30 0.00
VA	3230	3232 LEDs (base Halogen 6 hrs/day) 2020	Multi-Family	2020	2053	17.63	1.97	37.54	37.54	68%	4.20	4.20	68%	0.00	0.00	0	0	18.12	33.17	0.10	37.54	4.20
VA	3330	3330 Base CFL Lighting - 0.5 hrs/day 2020	Multi-Family	2020	2053	3.97	0.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.97	0.44	0.00	0.00
VA VA	3330 3430	3331 LEDs (base CFL 0.5 hrs/day) 2020 3430 Base CFL Lighting - 2.5 hrs/day 2020	Multi-Family Multi-Family	2020 2020	2053 2053	2.90 16.33	0.32 1.83	1.07	1.07	27% 0%	0.12	0.12 0.00	27% 0%	0.21 N/A	0.21 N/A	2 N/A	2 N/A	0.42 N/A	16.33	1.83	0.00	0.00
VA	3430	3431 LEDs (base CFL 2.5 hrs/day) 2020	Multi-Family	2020	2053	11.92	1.33	4.41	4.41	27%	0.49	0.49	27%	0.04	0.04	0	0	2.08	10.55	1.03	4.41	0.49
VA	3530	3530 Base CFL Lighting - 6 hrs/day 2020	Multi-Family	2020	2053	11.03	1.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.03	1.24	0.00	0.00
VA VA	3530 3630	3531 LEDs (base CFL 6 hrs/day) 2020 3630 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	Multi-Family Multi-Family	2020 2020	2053 2053	8.05 9.32	0.90 1.04	2.98	2.98	27% 0%	0.33	0.33	27% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	3.17 N/A	9.32	1.04	2.98 0.00	0.33
VA	3630	3632 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Multi-Family	2020	2053	3.68	0.41	5.64	5.64	60%	0.63	0.63	60%	0.01	0.01	0	0	7.33			5.64	0.63
VA VA	3730 3730	3730 Base Halogen (Specialty) Lighting - 2.5 hrs/day 2020	Multi-Family Multi-Family	2020 2020	2053 2053	37.63 14.87	4.21 1.66	0.00 22.76	0.00 22.76	0% 60%	0.00 2.55	0.00 2.55	0% 60%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 36.67	37.63	4.21	0.00 22.76	0.00 2.55
VA VA	3830	3732 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020 3830 Base Halogen (Specialty) Lighting - 6 hrs/day 2020	Multi-Family	2020	2053	25.80	2.89	0.00	0.00	0%	0.00	0.00	0%	0.00 N/A	0.00 N/A	N/A	N/A	36.67 N/A	25.80	2.89	0.00	0.00
VA	3830	3832 LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Multi-Family	2020	2053	10.20	1.14	15.61	15.61	60%	1.75	1.75	60%	0.00	0.00	0	0	54.61			15.61	1.75
VA	3900	3900 Base Fluorescent Fixture 1.8 hrs/day	Multi-Family	2014	2053	59.58	6.67	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	59.58	6.67	0.00	0.00
VA VA	3900 4000	3902 ROB 2L4'T8, 1EB 4000 Base Refrigerator	Multi-Family Multi-Family	2014 2014	2053 2053	43.51 217.96	4.87 35.33	16.07 0.00	16.07 0.00	27% 0%	1.80	1.80 0.00	27% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	2.45 N/A	217.96	35.33	16.07 0.00	1.80 0.00
VA	4000	4001 Refrigerator (Energy Star)	Multi-Family	2014	2053	173.06	28.05	44.90	44.90	21%	7.28	7.28	21%	0.05	0.05	0	0	1.59			44.90	7.28
VA	4100	4100 Base RefrigeratorEarly Replacement	Multi-Family	2014	2053	29.59	4.80	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	29.59	4.80	0.00	0.00
VA VA	4100 4200	4101 Refrigerator - Early Replacement (Energy Star) 4200 Base 2nd Refrigerator - Recycling	Multi-Family Multi-Family	2014 2014	2053 2053	13.93	2.26 0.57	15.67 0.00	15.67 0.00	53% 0%	2.54 0.00	2.54 0.00	53% 0%	0.13 N/A	0.13 N/A	1 N/A	1 N/A	0.44 N/A	3.49	0.57	0.00	0.00
VA	4200	4201 2nd Refrigerator Recycling	Multi-Family	2014	2053	0.90	0.15	2.59	2.59	74%	0.42	0.42	74%	0.05	0.05	0	0	1.16			2.59	0.42
VA	4500	4500 Base Freezer	Multi-Family	2014	2053	20.38	3.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	20.38	3.30	0.00	0.00
VA VA	4500 4600	4501 Freezer (Energy Star) 4600 Base Early Replacement Freezer	Multi-Family Multi-Family	2014 2014	2053 2053	18.47 5.04	2.99	1.91	1.91	9% 0%	0.31	0.31	9% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.16 N/A	5.04	0.80	1.91	0.31
VA	4600	4601 Freezer - Early Replacement (Energy Star)	Multi-Family	2014	2053	2.23	0.35	2.81	2.81	56%	0.44	0.44	56%	0.04	0.04	0	0	1.34			2.81	0.44
VA	4700	4700 Base 2nd Freezer Recycling	Multi-Family	2014	2053	0.00	0.00 97.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	5000 5000	5000 Base Water Heating (40 gal, EF=0.88) 5006 Pipe Wrap	Multi-Family Multi-Family	2014 2014	2053 2053	795.29 770.86	97.95 94.94	0.00 24.43	0.00 24.43	0% 3%	0.00 3.01	0.00 3.01	0% 3%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.30	795.29	97.95	0.00 24.43	0.00 3.01
VA	5000	5015 Low Flow Showerhead 1.5 Gal/Min	Multi-Family	2014	2053	745.47	91.81	25.39	49.82	6%	3.13	6.14	6%	0.02	0.02	ō	0	3.02			25.39	3.13

APPENDIX H

Base Avoided Costs

DSM ASSYS	al Electric Existing Construction YST ADDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage			Measure					Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Energy	Marginal Capacity	Average Capacity					
Base Sgmt Numb		Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
VA 50	5000 5008 Hot water turndown 10 degrees	Multi-Family Multi-Family	2014 2014	2053 2053	740.05 736.09	91.15 90.66	5.42 3.96	55.24 59.20	7% 7%	0.67 0.49	6.80 7.29	7% 7%	0.02 0.02	0.02	0	0	2.11 2.10			5.42 3.96	0.67 0.49
VA 50	5000 5009 Hot water turndown 15 degrees	Multi-Family	2014	2053	734.82		1.27	60.47	8%	0.49	7.45	8%	0.02	0.02	0	0	2.09			1.27	0.49
		Multi-Family Multi-Family	2014 2014	2053 2053	734.34 719.00	90.44 88.55	0.48 15.34	60.95	8%	0.06 1.89	7.51 9.40	8% 10%	0.02	0.02	0	0	2.08			0.48	0.06
		Multi-Family Multi-Family	2014	2053	719.00 691.97	88.55 85.23	15.34 27.03	76.29 103.32	10% 13%	1.89 3.33	9.40 12.72	10% 13%	0.04	0.02	0	0	1.70 1.17			15.34 27.03	1.89 3.33
VA 50	5000 5005 DHW Tank Wrap	Multi-Family	2014	2053	653.13	80.44	38.84	142.16	18%	4.78	17.51	18%	0.06	0.04	0	0	0.90			0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	563.23 475.22	69.37 58.53	89.91 88.00	232.06 320.07	29% 40%	11.07 10.84	28.58 39.42	29% 40%	0.08 0.20	0.06	1 2	0 1	0.90 0.38			0.00	0.00
	g	Multi-Family	2014	2053	473.22		2.01	322.07	40%	0.25	39.42	40%	2.25	0.10	18	1	0.38			0.00	0.00
	5000 5013 Energy Star Dishwasher (EF=0.72)	Multi-Family	2014	2053	472.18	58.16	1.03	323.11	41%	0.13	39.79	41%	2.93	0.12	24	1	0.02			0.00	0.00
	5100 Base Water Heating Early Replacement to Heat Pump Water H 5100 5101 Heat Pump Water Heater - Energy Star - Early Replacement	Multi-Family Multi-Family	2014 2014	2053 2053	140.35 121.03	17.29 14.91	0.00 19.32	0.00 19.32	0% 14%	0.00 2.38	0.00 2.38	0% 14%	N/A 0.08	N/A 0.08	N/A 1	N/A 1	N/A 0.88	140.35	17.29	0.00	0.00
		Multi-Family	2014	2053	13.76	2.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.76	2.49	0.00	0.00
		Multi-Family	2014	2053	9.84	1.78	3.92	3.92	28%	0.71	0.71	28%	1.21	1.21	7	7	0.06			0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	258.64 211.14	43.77 35.73	0.00 47.51	0.00 47.51	0% 18%	0.00 8.04	0.00 8.04	0% 18%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.08	258.64	43.77	0.00 47.51	0.00 8.04
		Multi-Family	2014	2053	105.57	17.87	105.57	153.08	59%	17.87	25.91	59%	0.55	0.39	3	2	0.13			0.00	0.00
		Multi-Family	2014	2053	60.34	9.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	60.34	9.90	0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	58.19 0.00	9.54 0.00	2.15 0.00	2.15 0.00	4% 0%	0.35	0.35	4% 0%	1.59 N/A	1.59 N/A	10 N/A	10 N/A	0.05 N/A	0.00	0.00	0.00	0.00
		Multi-Family	2014	2053	18.99	2.74	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.99	2.74	0.00	0.00
		Multi-Family	2014	2053	17.31	2.50	1.68	1.68	9%	0.24	0.24	9%	0.01	0.01	0	0	7.64			1.68	0.24
		Multi-Family Multi-Family	2014 2014	2053 2053	17.08 56.69	2.46 8.18	0.23 0.00	1.91 0.00	10% 0%	0.03	0.28 0.00	10% 0%	2.23 N/A	0.28 N/A	15 N/A	2 N/A	0.02 N/A	56.69	8.18	0.00	0.00
		Multi-Family	2014	2053	36.03	5.20	20.66	20.66	36%	2.98	2.98	36%	0.00	0.00	0	0	16.39	00.00	0.10	20.66	2.98
		Multi-Family	2014	2053	34.66	5.00	1.37	22.03	39%	0.20	3.18	39%	2.36	0.15	16	1	0.02			0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	17.04 15.32	2.46 2.21	0.00 1.73	0.00 1.73	0% 10%	0.00 0.25	0.00 0.25	0% 10%	N/A 0.66	N/A 0.66	N/A 5	N/A 5	N/A 0.08	17.04	2.46	0.00	0.00
VA 73	7300 7300 Base Set-Top Box	Multi-Family	2014	2053	56.64	8.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	56.64	8.17	0.00	0.00
		Multi-Family	2014	2053	9.64	1.39	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.64	1.39	0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	4.52 0.35	0.65 0.05	5.12 4.17	5.12 9.29	53% 96%	0.74	0.74 1.34	53% 96%	0.01 0.69	0.01	0 5	0	4.24 0.08			5.12 0.00	0.74
VA 75	7500 7500 Base Desktop PC	Multi-Family	2014	2053	70.86	9.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	70.86	9.33	0.00	0.00
		Multi-Family Multi-Family	2014 2014	2053 2053	61.76 32.35	8.14 4.26	9.10 29.41	9.10 38.51	13% 54%	1.20 3.87	1.20 5.07	13% 54%	0.00 0.05	0.00	0	0	15.00 1.12			9.10 29.41	1.20 3.87
		Multi-Family	2014	2053	14.28	1.88	0.00	0.00	0%	0.00	0.00	0%	0.05 N/A	0.04 N/A	N/A	N/A	N/A	14.28	1.88	0.00	0.00
VA 76	7600 7601 Energy Star Laptop PC	Multi-Family	2014	2053	11.90	1.57	2.38	2.38	17%	0.31	0.31	17%	0.03	0.03	0	0	2.25			2.38	0.31
		Multi-Family Multi-Family	2014 2014	2053 2053	198.97 119.20	63.52 15.70	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	198.97 119.20	63.52 15.70	0.00	0.00
		Multi-Family	2014	2053	4,108.27		0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4,108.27	1,017.30	0.00	0.00
		Multi-Family	2014	2053	4,047.26	1,002.19	61.02	61.02	1%	15.11	15.11	1%	0.03	0.03	0	0	1.57			61.02	15.11
		Multi-Family Single Family	2014 2014	2053 2053	3,864.22 50.03	2 956.87 29.72	183.04 0.00	244.06 0.00	6% 0%	45.33 0.00	60.43 0.00	6% 0%	0.09 N/A	0.08 N/A	0 N/A	0 N/A	0.65 N/A	50.03	29.72	0.00	0.00
		Single Family	2014	2053	49.38	29.33	0.66	0.66	1%	0.39	0.39	1%	0.02	0.02	0	0	5.65	30.03	23.72	0.66	0.39
		Single Family	2014	2053	48.98	29.10	0.39	1.05	2%	0.23	0.62	2%	0.06	0.03	0	0	1.65			0.39	0.23
		Single Family Single Family	2014 2014	2053 2053	48.70 48.65	28.93 28.90	0.28 0.05	1.33 1.39	3% 3%	0.17	0.79 0.82	3% 3%	0.09 0.10	0.04	0	0	1.32 1.09			0.28 0.05	0.17 0.03
NC 10	1000 1004 Proper Refrigerant Charging and Air Flow (CAC)	Single Family	2014	2053	45.16	26.83	3.49	4.88	10%	2.07	2.90	10%	0.09	0.08	0	0	0.98			0.00	0.00
		Single Family		2053	44.29	26.31	0.87	5.75	11%	0.51	3.41	11%	0.08	0.08	0	0	0.86			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	41.60 39.25	24.71 23.32	2.69	8.43 10.79	17% 22%	1.60	5.01 6.41	17% 22%	0.15 0.18	0.10	0	0	0.72			0.00	0.00
NC 10	1000 1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Single Family	2014	2053	35.29	20.97	3.95	14.74	29%	2.35	8.76	29%	0.24	0.15	Ō	Ō	0.47			0.00	0.00
		Single Family	2014	2053	31.87	18.93	3.43	18.17	36%	2.04	10.79	36%	0.27	0.17	0	0	0.40			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	31.56 30.95	18.75 18.39	0.30 0.62	18.47 19.09	37% 38%	0.18 0.37	10.97 11.34	37% 38%	0.33 0.37	0.18 0.18	1	0	0.35			0.00	0.00
NC 10	1000 1029 WINDOWS - Default With Sunscreen (CAC)	Single Family	2014	2053	27.92	16.58	3.03	22.12	44%	1.80	13.14	44%	0.35	0.21	1	0	0.25			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	27.91 26.64	16.58 15.82	0.01 1.27	22.13 23.40	44% 47%	0.00	13.15 13.90	44% 47%	4.46 0.43	0.21	8	0	0.03			0.00	0.00
		Single Family	2014	2053	26.54	15.82	0.25	23.40	47%	0.75	14.05	47% 47%	0.43	0.22	1	0	0.21			0.00	0.00
NC 10	1000 1010 Ceiling R-11 to R-38 Insulaton (CAC)	Single Family	2014	2053	25.69	15.26	0.69	24.34	49%	0.41	14.46	49%	0.99	0.24	2	0	0.12			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	25.67 25.56	15.25 15.18	0.03	24.37 24.48	49% 49%	0.02	14.48 14.54	49% 49%	4.84 1.23	0.25	8	0	0.02			0.00	0.00
		Single Family		2053	25.56	15.18	0.11	24.48	49% 49%	0.06	14.54	49%	1.23	0.25	2	0	0.09			0.00	0.00
NC 10	1000 1012 Ceiling R-19 to R-38 Insulation (CAC)	Single Family	2014	2053	25.35	15.06	0.08	24.68	49%	0.05	14.66	49%	1.70	0.26	3	0	0.07			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	24.92 24.91	14.81 14.80	0.43	25.11 25.12	50% 50%	0.26	14.92 14.92	50% 50%	1.80 4.99	0.29	3 8	0	0.06			0.00	0.00
		Single Family	2014	2053	24.91	14.80	0.01	25.12 25.96	50%	0.50	15.42	50% 52%	1.72	0.29	3	1	0.02			0.00	0.00
NC 10	1000 1017 Wall Blow-in R-0 to R-13 Insulation (CAC)	Single Family	2014	2053	24.03	14.28	0.04	26.01	52%	0.03	15.45	52%	2.47	0.34	4	1	0.05			0.00	0.00
		Single Family Single Family	2014 2014	2053 2053	23.39	13.89 13.88	0.64 0.02	26.65 26.67	53% 53%	0.38	15.83 15.84	53% 53%	2.51 4.51	0.39	4 8	1	0.04			0.00	0.00
		Single Family	2014	2053	23.37	13.88	0.02	26.67	53%	0.01	15.84	53%	2.63	0.40	4	1	0.03			0.00	0.00
NC 10	1000 1006 AC Maintenance and/or tune-up (CAC)	Single Family	2014	2053	23.16	13.76	0.10	26.87	54%	0.06	15.96	54%	3.01	0.42	5	1	0.02			0.00	0.00
NC 10	1000 1016 Floor R-0 to R-19 Insulation-Batts (CAC)	Single Family	2014	2053	23.14	13.75	0.03	26.90	54%	0.02	15.98	54%	5.60	0.42	9	1	0.02			0.00	0.00

DNV GL H-8 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Moneyers	Measure		20.7		Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			00.121	
		easure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	
Sgmt N	umber N 1100	umber Measure 1100 Base Split-System Air Conditioner - Early Replacement (11 SEI	Type Single Family	Year 2014	2053	8.38	MW 4.98	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	6WH 8.38	MW 4.98	0.00	MW 0.00
NC	1100	1117 Duct Insulation (CAC early replacement)	Single Family	2014	2053	8.31	4.94	0.07	0.07	1%	0.04	0.04	1%	0.01	0.01	0	0	8.15	0.00	1.00	0.07	0.04
NC NC	1100 1100	1122 Self Install Weatherization (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	8.20 8.14	4.87 4.84	0.11 0.07	0.18 0.24	2% 3%	0.06	0.11 0.14	2% 3%	0.02	0.02	0	0	5.32 1.56			0.11	0.06
NC	1100	1120 Programmable Thermostat (CAC early replacement) 1119 Return Duct Modification (CAC early replacement)	Single Family	2014	2053	8.09	4.81	0.07	0.24	3%	0.04	0.14	3%	0.08	0.03	0	0	1.24			0.07	0.04
NC	1100	1102 Proper Refrigerant Charging and Air Flow (CAC early replacem		2014	2053	7.42	4.41	0.67	0.96	11%	0.40	0.57	11%	0.10	0.08	0	0	0.91			0.00	0.00
NC NC	1100 1100	1123 Door Weatherization (CAC early replacement) 1116 Cool Roof (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	7.26 6.50	4.31 3.86	0.17 0.76	1.13 1.88	13% 22%	0.10 0.45	0.67 1.12	13% 22%	0.08 0.18	0.08	0	0	0.93 0.58			0.00	0.00
NC	1100	1125 Whole House Fans (CAC early replacement)	Single Family	2014	2053	5.29	3.14	1.21	3.09	37%	0.72	1.84	37%	0.18	0.12	0	0	0.44			0.00	0.00
NC	1100	1103 Proper Sizing and Quality Install (CAC early replacement)	Single Family	2014	2053	4.70	2.79	0.59	3.68	44%	0.35	2.19	44%	0.33	0.19	1	0	0.34			0.00	0.00
NC NC	1100 1100	1112 Crawlspace insulation (CAC early replacement) 1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early replacement)	Single Family	2014 2014	2053 2053	4.66 4.59	2.77 2.73	0.04 0.07	3.73 3.80	44% 45%	0.03	2.21 2.25	44% 45%	0.39	0.19	1	0	0.29 0.27			0.00	0.00
NC	1100	1113 Basement insulation R-13 (CAC early replacement)	Single Family	2014	2053	4.55	2.70	0.04	3.83	46%	0.02	2.28	46%	0.45	0.20	1	0	0.26			0.00	0.00
NC	1100	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	Single Family	2014	2053	4.46	2.65	0.09	3.92	47%	0.05	2.33	47%	0.45	0.21	1	0	0.25			0.00	0.00
NC NC	1100 1100	1107 Ceiling R-0 to R-49 Insulation (CAC early replacement) 1118 Duct Testing and Sealing (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	4.46 4.42	2.65 2.63	0.00 0.04	3.92 3.96	47% 47%	0.00	2.33 2.35	47% 47%	4.92 0.57	0.21 0.21	8	0	0.02 0.19			0.00	0.00
NC	1100	1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early re		2014	2053	4.22	2.51	0.20	4.16	50%	0.12	2.47	50%	0.47	0.22	1	0	0.19			0.00	0.00
NC	1100	1124 Ceiling Fans (CAC early replacement)	Single Family	2014	2053	4.18	2.49	0.03	4.20	50%	0.02	2.49	50%	0.76	0.23	1	0	0.14			0.00	0.00
NC NC	1100 1100	1126 Window Film (CAC early replacement) 1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	3.87 3.77	2.30 2.24	0.31 0.10	4.51 4.61	54% 55%	0.19	2.68 2.74	54% 55%	0.81 1.19	0.27	1 2	0	0.11 0.10			0.00	0.00
NC	1100	1127 WINDOWS - Default With Sunscreen (CAC early replacement		2014	2053	3.59	2.13	0.18	4.79	57%	0.11	2.85	57%	1.05	0.32	2	1	0.08			0.00	0.00
NC	1100 1100	1109 Ceiling R-11 to R-49 Insulation (CAC early replacement)	Single Family	2014 2014	2053	3.59 3.57	2.13	0.00	4.80	57%	0.00	2.85 2.86	57% 57%	6.12	0.32	10 4	1	0.02			0.00	0.00
NC NC	1100	1110 Ceiling R-19 to R-38 Insulation (CAC early replacement) 1111 Ceiling R-19 to R-49 Insulation (CAC early replacement)	Single Family Single Family	2014	2053 2053	3.57	2.12 2.12	0.01 0.00	4.81 4.81	57% 57%	0.01	2.86	57% 57%	2.13 6.14	0.33	4 10	1	0.05			0.00	0.00
NC	1100	1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement)	Single Family	2014	2053	3.57	2.12	0.01	4.82	57%	0.00	2.86	57%	2.93	0.33	5	1	0.04			0.00	0.00
NC	1100	1101 14 SEER (12.15 EER) Split-System Air Conditioner w/ Quality		2014	2053	3.48	2.06	0.09	4.91	59%	0.05	2.92	59%	2.86	0.38	5	1	0.03			0.00	0.00
NC NC	1100 1100	1105 AC Filter Changes (CAC early replacement) 1104 AC Maintenance and/or tune-up (CAC early replacement)	Single Family Single Family	2014 2014	2053 2053	3.46	2.06 2.05	0.01	4.92 4.94	59% 59%	0.01	2.92	59% 59%	3.12 3.57	0.39	5 6	1	0.02			0.00	0.00
NC	1100	1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	Single Family	2014	2053	3.44	2.04	0.00	4.94	59%	0.00	2.94	59%	6.64	0.40	11	1	0.02			0.00	0.00
NC NC	1200 1200	1200 Base Heat Pump Cooling (13 SEER)	Single Family	2014 2014	2053 2053	126.33 125.30	75.05 74.44	0.00 1.03	0.00 1.03	0%	0.00 0.61	0.00 0.61	0% 1%	N/A 0.01	N/A 0.01	N/A	N/A 0	N/A 9.87	126.33	75.05	0.00 1.03	0.00 0.61
NC NC	1200	1219 Duct Insulation (HP cooling) 1223 Self Install Weatherization (HP cooling)	Single Family Single Family	2014	2053	125.30	73.46	1.03	2.68	1% 2%	0.61	1.59	1% 2%	0.01	0.01	0	0	9.87 2.47			1.03	0.61
NC	1200	1221 Programmable Thermostat (HP cooling)	Single Family	2014	2053	121.15	71.97	2.50	5.18	4%	1.49	3.08	4%	0.07	0.05	Ō	ō	1.38			2.50	1.49
NC NC	1200 1200	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	2014 2014	2053 2053	100.62 93.40	59.78 55.49	20.53	25.71 32.93	20%	12.19 4.29	15.27 19.57	20% 26%	0.08 0.10	0.07	0	0	1.32 0.92			20.53	12.19
NC NC	1200	1204 Proper Refrigerant Charging and Air Flow (HP cooling) 1224 Door Weatherization (HP cooling)	Single Family Single Family	2014	2053	93.40	55.49 54.42	7.22 1.79	34.73	26% 27%	1.06	20.63	26%	0.10	0.08	0	0	0.92			0.00	0.00
NC	1200	1218 Cool Roof (HP cooling)	Single Family	2014	2053	82.04	48.74	9.57	44.29	35%	5.68	26.31	35%	0.18	0.10	0	0	0.58			0.00	0.00
NC NC	1200 1200	1205 Proper Sizing and Quality Install (HP cooling) 1226 Whole House Fans (HP cooling)	Single Family Single Family	2014 2014	2053 2053	74.07 60.29	44.00 35.82	7.97 13.78	52.26 66.04	41% 52%	4.73 8.19	31.05 39.24	41% 52%	0.22 0.26	0.12 0.15	0	0	0.51 0.41			0.00	0.00
NC	1200	1214 Crawlspace insulation (HP cooling)	Single Family	2014	2053	59.71	35.47	0.58	66.62	53%	0.34	39.58	53%	0.20	0.15	1	0	0.30			0.00	0.00
NC	1200	1208 Ceiling R-0 to R-38 Insulation (HP cooling)	Single Family	2014	2053	58.53	34.77	1.18	67.80	54%	0.70	40.28	54%	0.43	0.15	1	0	0.27			0.00	0.00
NC NC	1200 1200	1215 Basement insulation R-13 (HP cooling) 1209 Ceiling R-0 to R-49 Insulation (HP cooling)	Single Family Single Family	2014 2014	2053 2053	58.05 58.02	34.49 34.47	0.48 0.04	68.28 68.32	54% 54%	0.29	40.56 40.59	54% 54%	0.44 2.11	0.16	1	0	0.26 0.05			0.00	0.00
NC	1200	1220 Duct Testing and Sealing (HP cooling)	Single Family	2014	2053	57.47	34.14	0.54	68.86	55%	0.32	40.91	55%	0.55	0.16	1	0	0.20			0.00	0.00
NC	1200	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)		2014	2053	54.86	32.59	2.62	71.47	57%	1.55	42.46	57%	0.45	0.17	1	0	0.19			0.00	0.00
NC NC	1200 1200	1227 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling) 1225 Ceiling Fans (HP cooling)	Single Family Single Family	2014 2014	2053 2053	54.05 53.62	32.11 31.86	0.81 0.43	72.28 72.71	57% 58%	0.48	42.94 43.20	57% 58%	0.69 0.73	0.18 0.18	1	0	0.17 0.14			0.00	0.00
NC	1200	1210 Ceiling R-11 to R-38 Insulaton (HP cooling)	Single Family	2014	2053	52.19	31.00	1.44	74.15	59%	0.85	44.05	59%	1.04	0.20	2	Ö	0.11			0.00	0.00
NC	1200	1211 Ceiling R-11 to R-49 Insulation (HP cooling)	Single Family	2014	2053	52.05	30.92	0.13	74.28	59%	0.08	44.13	59%	2.35	0.20	4	0	0.05			0.00	0.00
NC NC	1200 1200	1216 Floor R-0 to R-19 Insulation-Batts (HP cooling) 1212 Ceiling R-19 to R-38 Insulation (HP cooling)	Single Family Single Family	2014 2014	2053 2053	51.83 51.67	30.79 30.70	0.22 0.16	74.50 74.66	59% 59%	0.13	44.26 44.35	59% 59%	1.47 1.89	0.20	2	0	0.08			0.00	0.00
NC	1200	1213 Ceiling R-19 to R-49 Insulation (HP cooling)	Single Family	2014	2053	51.64	30.68	0.03	74.69	59%	0.02	44.37	59%	2.37	0.21	4	ō	0.05			0.00	0.00
NC NC	1200 1200	1207 Heat Pump Filter Replacement	Single Family	2014 2014	2053 2053	51.42 51.26	30.55 30.45	0.22 0.16	74.91 75.07	59% 59%	0.13	44.50 44.60	59% 59%	2.22 4.83	0.21	4 8	0	0.03 0.02			0.00	0.00
NC NC	1200 1200	1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling) 1206 Heat pump tune up	Single Family Single Family	2014	2053	51.26	30.45	0.16	75.07 75.30	59% 60%	0.10	44.60 44.74	59% 60%	4.83 3.59	0.22	6	0	0.02			0.00	0.00
NC	1300	1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	Single Family	2014	2053	21.98	13.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	21.98	13.06	0.00	0.00
NC NC	1300 1300	1319 Duct Insulation (HP cooling Early Replacement) 1323 Self Install Weatherization (HP cooling Early Replacement)	Single Family Single Family	2014 2014	2053 2053	21.81 21.52	12.95 12.78	0.18 0.29	0.18 0.47	1% 2%	0.11 0.17	0.11 0.28	1% 2%	0.01 0.04	0.01	0	0	9.73 2.43			0.18 0.29	0.11 0.17
NC NC	1300	1323 Self Install Weatherization (HP cooling Early Replacement) 1321 Programmable Thermostat (HP cooling Early Replacement)	Single Family	2014	2053	21.52	12.78	0.29	0.47	2% 4%	0.17	0.28	2% 4%	0.04	0.03	0	0	1.36			0.29	0.17
NC	1300	1302 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Ea	Single Family	2014	2053	17.51	10.40	3.57	4.47	20%	2.12	2.66	20%	0.08	0.07	0	0	1.31			3.57	2.12
NC NC	1300 1300	1304 Proper Refrigerant Charging and Air Flow (HP cooling Early Re		2014 2014	2053	16.25 15.89	9.66 9.44	1.26	5.73 6.09	26%	0.75	3.40 3.62	26% 28%	0.10 0.08	0.08	0	0	0.91 0.93			0.00	0.00
NC NC	1300	1324 Door Weatherization (HP cooling Early Replacement) 1318 Cool Roof (HP cooling Early Replacement)	Single Family Single Family	2014	2053 2053	14.23	9.44 8.45	0.36 1.66	7.75	28% 35%	0.22	4.61	28% 35%	0.08	0.08	0	0	0.93			0.00	0.00
NC	1300	1305 Proper Sizing and Quality Install (HP cooling Early Replacement		2014	2053	12.85	7.63	1.38	9.14	42%	0.82	5.43	42%	0.22	0.12	0	0	0.50			0.00	0.00
NC NC	1300 1300	1326 Whole House Fans (HP cooling early replacement) 1314 Crawlspace insulation (HP cooling Early Replacement)	Single Family Single Family	2014 2014	2053 2053	10.46	6.21 6.15	2.39	11.53 11.63	52% 53%	1.42	6.85 6.91	52% 53%	0.26	0.15	0	0	0.40			0.00	0.00
NC NC	1300	1308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)		2014	2053	10.36	6.03	0.10	11.83	53% 54%	0.06	7.03	53% 54%	0.39	0.15	1	0	0.30			0.00	0.00
NC	1300	1315 Basement insulation R-13 (HP cooling Early Replacement)	Single Family	2014	2053	10.07	5.98	0.08	11.91	54%	0.05	7.08	54%	0.44	0.16	1	0	0.26			0.00	0.00
NC NC	1300 1300	1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) 1320 Duct Testing and Sealing (HP cooling Early Replacement)	Single Family Single Family	2014 2014	2053 2053	10.06 9.97	5.98 5.92	0.01 0.09	11.92 12.01	54% 55%	0.00	7.08 7.14	54% 55%	2.15 0.56	0.16 0.16	4	0	0.05 0.20			0.00	0.00
NC	1300	1322 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling E		2014	2053	9.52	5.65	0.45	12.47	57%	0.06	7.14	57%	0.46	0.16	1	0	0.20			0.00	0.00
NC	1300	1327 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling	Single Family	2014	2053	9.38	5.57	0.14	12.61	57%	0.08	7.49	57%	0.70	0.18	1	0	0.16			0.00	0.00
NC NC	1300 1300	1325 Ceiling Fans (HP cooling early replacement) 1310 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)	Single Family	2014 2014	2053 2053	9.30	5.53 5.38	0.07	12.68 12.93	58% 59%	0.04 0.15	7.53 7.68	58% 59%	0.75 1.06	0.18	1 2	0	0.14			0.00	0.00
INC	1300	1310 Coming N-11 to N-30 insulation (Fir Cooling Larry Replacement)	Unigle Faililly	2014	2000	5.00	5.50	0.20	12.53	33/0	0.13	7.00	J3 /0	1.00	0.20	-	U	0.11			0.00	0.00

APPENDIX H

Base Avoided Costs

		ic Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Measure	Measure		20.7		Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			00.121	
Bas Sgmt Nu		easure umber Measure	Building	Start	End	Total GWH	Total MW	GWH Savings	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic	Economic MW
	1300	1311 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement)	Single Family	2014	2053	9.03	5.36	0.02	12.95	59%	Savings 0.01	7.70	Savings 59%	2.39	0.20	4	0	0.05	GWH	IVIVV	0.00	0.00
	1300	1316 Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement		2014	2053	8.99	5.34	0.04	12.99	59%	0.02	7.72	59%	1.50	0.21	3	0	0.08			0.00	0.00
	1300 1300	1312 Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement, 1313 Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)		2014 2014	2053 2053	8.96 8.96	5.33 5.32	0.03 0.01	13.02 13.03	59% 59%	0.02	7.74 7.74	59% 59%	1.92 2.42	0.21	3 4	0	0.06 0.05			0.00	0.00
	1300	1307 Heat Pump Filter Replacement	Single Family	2014	2053	8.92	5.30	0.04	13.07	59%	0.02	7.76	59%	2.26	0.22	4	0	0.03			0.00	0.00
	1300	1317 Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacer		2014	2053	8.89	5.28	0.03	13.09	60%	0.02	7.78	60%	4.91	0.23	8	0	0.02			0.00	0.00
	1300 1400	1306 Heat pump tune up 1400 Base Room Air Conditioner - EER 10.6	Single Family Single Family	2014 2014	2053 2053	8.85 6.82	5.26 4.05	0.04 0.00	13.13 0.00	60% 0%	0.02	7.80 0.00	60% 0%	3.65 N/A	0.24 N/A	6 N/A	0 N/A	0.02 N/A	6.82	4.05	0.00	0.00
	1400	1413 Self Install Weatherization (RAC)	Single Family	2014	2053	6.73	4.00	0.09	0.09	1%	0.05	0.05	1%	0.05	0.05	0	0	1.92	0.02	4.00	0.09	0.05
	1400	1414 Door Weatherization (RAC)	Single Family	2014	2053	6.60	3.92	0.13	0.22	3%	0.08	0.13	3%	0.23	0.15	0	0	0.32			0.00	0.00
	1400 1400	1411 Cool Roof (RAC) 1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	Single Family Single Family	2014	2053 2053	5.91 5.58	3.51 3.31	0.69 0.33	0.91 1.24	13% 18%	0.41	0.54 0.74	13% 18%	0.45	0.38	1	1	0.23 0.20			0.00	0.00
	1400	1417 Window Film (RAC)	Single Family	2014	2053	4.41	2.62	1.17	2.41	35%	0.70	1.43	35%	0.49	0.44	1	1	0.18			0.00	0.00
NC	1400	1416 Whole House Fans (RAC)	Single Family	2014	2053	3.59	2.13	0.82	3.23	47%	0.49	1.92	47%	0.79	0.53	1	1	0.13			0.00	0.00
	1400	1419 WINDOWS - Double-Glazed Clear to Energy Star (RAC)	Single Family	2014	2053	3.53	2.10	0.05	3.28	48%	0.03	1.95	48%	1.24	0.54	2	1	0.09			0.00	0.00
	1400 1400	1404 Ceiling R-0 to R-38 Insulation (RAC) 1412 Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	Single Family Single Family	2014 2014	2053 2053	3.47	2.06 1.95	0.07 0.19	3.35 3.54	49% 52%	0.04	1.99 2.10	49% 52%	1.41 1.15	0.56	2	1	0.08			0.00	0.00
	1400	1405 Ceiling R-0 to R-49 Insulation (RAC)	Single Family	2014	2053	3.28	1.95	0.00	3.54	52%	0.00	2.10	52%	8.33	0.59	14	1	0.01			0.00	0.00
	1400	1415 Ceiling Fans (RAC)	Single Family	2014	2053	3.25	1.93	0.03	3.56	52%	0.02	2.12	52%	2.21	0.60	4	1	0.05			0.00	0.00
	1400 1400	1410 Wall Blow-in R-0 to R-13 Insulation (RAC) 1406 Ceiling R-11 to R-38 Insulaton (RAC)	Single Family Single Family	2014 2014	2053 2053	3.24	1.92 1.88	0.01 0.08	3.58 3.65	52% 54%	0.01	2.13 2.17	52% 54%	3.53 3.55	0.61 0.68	6 6	1	0.03			0.00	0.00
	1400	1418 WINDOWS - Default With Sunscreen (RAC)	Single Family	2014	2053	3.01	1.79	0.05	3.81	56%	0.03	2.26	56%	2.85	0.76	5	1	0.03			0.00	0.00
	1400	1407 Ceiling R-11 to R-49 Insulation (RAC)	Single Family	2014	2053	3.01	1.79	0.01	3.81	56%	0.00	2.26	56%	9.07	0.78	15	1	0.01			0.00	0.00
	1400 1400	1408 Ceiling R-19 to R-38 Insulation (RAC) 1409 Ceiling R-19 to R-49 Insulation (RAC)	Single Family Single Family	2014 2014	2053 2053	3.00	1.78 1.78	0.01 0.00	3.82 3.82	56% 56%	0.01	2.27 2.27	56% 56%	6.31 9.12	0.79 0.79	11 15	1	0.0 <u>2</u> 0.01			0.00	0.00
	1400	1403 Room AC Filter Replacement	Single Family	2014	2053	2.98	1.77	0.01	3.83	56%	0.01	2.28	56%	6.97	0.73	12	1	0.01			0.00	0.00
	1500	1500 Base Room Air Conditioner, Early Replacement - EER 9.7	Single Family	2014	2053	2.03	1.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.03	1.21	0.00	0.00
	1500 1600	1501 EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early 1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	Single Family Single Family	2014 2014	2053 2053	1.76 1.49	1.05 0.88	0.27 0.00	0.27	13% 0%	0.16	0.16 0.00	13% 0%	0.73 N/A	0.73 N/A	1 N/A	1 N/A	0.11 N/A	1.49	0.88	0.00	0.00
	1600	1601 10% better than Energy Star Dehumidifier ROB (35-45 pints/da		2014	2053	1.49	0.00	0.00	0.00	15%	0.00	0.00	15%	0.18	0.18	0	0	0.52	1.49	0.00	0.00	0.00
NC	1700	1700 Base Furnace Fan - Furnace & CAC	Single Family	2014	2053	85.65	43.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	85.65	43.93	0.00	0.00
	1700 2000	1701 ECM Furnace Fan (variable speed motor) - Cooling	Single Family Single Family	2014 2014	2053 2053	47.58 167.75	24.41 19.90	38.07 0.00	38.07 0.00	44% 0%	19.53 0.00	19.53 0.00	44% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	3.79 N/A	167.75	19.90	38.07 0.00	19.53 0.00
	2000	2000 Base Heat Pump Space Heating (7.7 HSPF) 2016 Duct Insulation (HP heating)	Single Family	2014	2053	166.38	19.90	1.37	1.37	1%	0.00	0.00	1%	0.01	0.01	N/A 0	0 0	N/A 8.49	167.75	19.90	1.37	0.00
NC	2000	2021 Self Install Weatherization (HP heating)	Single Family	2014	2053	164.19	19.48	2.19	3.56	2%	0.26	0.42	2%	0.03	0.02	0	0	2.26			2.19	0.26
	2000	2019 Programmable Thermostat (HP heating)	Single Family	2014	2053	160.87	19.09	3.33	6.88	4%	0.39	0.82	4%	0.05	0.04	0	0	1.23			3.33	0.39
	2000 2000	2022 Door Weatherization (HP heating) 2002 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	Single Family Single Family	2014	2053 2053	158.99 144.34	18.86 17.13	1.88 14.65	8.76 23.41	5% 14%	0.22 1.74	1.04 2.78	5% 14%	0.09	0.05	1	0	0.62			0.00	0.00
	2000	2018 Heat Recovery Ventilators (HP heating)	Single Family	2014	2053	113.02	13.41	31.32	54.73	33%	3.72	6.49	33%	0.16	0.13	1	1	0.47			0.00	0.00
	2000	2012 Crawlspace insulation (HP heating)	Single Family	2014	2053	112.55	13.35	0.47	55.20	33%	0.06	6.55	33%	0.21	0.13	2	1	0.37			0.00	0.00
	2000 2000	2006 Ceiling R-0 to R-38 Insulation (HP heating) 2013 Basement insulation R-13 (HP heating)	Single Family	2014 2014	2053 2053	110.33	13.09 13.04	2.22 0.39	57.42 57.81	34% 34%	0.26	6.81 6.86	34% 34%	0.23 0.24	0.13	2	1	0.33			0.00	0.00
	2000	2007 Ceiling R-0 to R-49 Insulation (HP heating)	Single Family	2014	2053	109.87	13.04	0.07	57.88	35%	0.01	6.87	35%	1.16	0.14	10	1	0.07			0.00	0.00
	2000		Single Family	2014	2053	104.87	12.44	5.00	62.88	37%	0.59	7.46	37%	0.25	0.14	2	1	0.26			0.00	0.00
	2000 2000	2017 Duct Testing and Sealing (HP heating) 2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Single Family	2014 2014	2053 2053	103.89 102.40	12.33 12.15	0.98 1.49	63.86 65.35	38% 39%	0.12 0.18	7.58 7.75	38% 39%	0.31 0.39	0.15 0.15	3	1	0.24 0.20			0.00	0.00
	2000	2008 Ceiling R-11 to R-38 Insulaton (HP heating)	Single Family	2014	2053	99.66	11.82	2.74	68.09	41%	0.18	8.08	41%	0.57	0.13	5	1	0.14			0.00	0.00
	2000	2009 Ceiling R-11 to R-49 Insulation (HP heating)	Single Family	2014	2053	99.40	11.79	0.25	68.34	41%	0.03	8.11	41%	1.28	0.17	11	1	0.06			0.00	0.00
	2000 2000	2014 Floor R-0 to R-19 Insulation-Batts (HP heating) 2010 Ceiling R-19 to R-38 Insulation (HP heating)	Single Family Single Family	2014 2014	2053 2053	99.22 98.92	11.77 11.74	0.19 0.30	68.53 68.83	41% 41%	0.02	8.13 8.17	41% 41%	0.80 1.02	0.18 0.18	7 9	1 2	0.10 0.08			0.00	0.00
	2000		Single Family	2014	2053	90.17	10.70	8.75	77.58	46%	1.04	9.20	46%	2.07	0.18	17	3	0.08			0.00	0.00
NC	2000	2011 Ceiling R-19 to R-49 Insulation (HP heating)	Single Family	2014	2053	90.11	10.69	0.06	77.64	46%	0.01	9.21	46%	1.41	0.39	12	3	0.05			0.00	0.00
	2000 2000	2005 Heat Pump Filter Replacement	Single Family Single Family	2014 2014	2053 2053	89.72 89.44	10.65 10.61	0.38 0.28	78.02 78.31	47% 47%	0.05	9.26 9.29	47% 47%	1.32 2.88	0.40	11 24	3	0.04			0.00	0.00
	2000	2015 Wall Blow-in R-0 to R-13 Insulation (HP heating) 2004 Heat pump tune up	Single Family	2014	2053	89.44 89.04	10.61 10.56	0.28	78.31 78.70	47% 47%	0.03	9.29	47% 47%	2.88	0.41	24 18	3 4	0.03			0.00	0.00
NC	2100	2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSP	Single Family	2014	2053	32.77	3.89	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	32.77	3.89	0.00	0.00
	2100	2116 Duct Insulation (HP heating early replacement)	Single Family	2014	2053	32.50	3.86	0.27	0.27	1%	0.03	0.03	1%	0.01	0.01	0	0	9.40			0.27	0.03
	2100 2100	2121 Self Install Weatherization (HP heating early replacement) 2119 Programmable Thermostat (HP heating early replacement)	Single Family Single Family	2014 2014	2053 2053	32.07 31.42	3.81 3.73	0.43 0.65	0.69 1.34	2% 4%	0.05	0.08 0.16	2% 4%	0.03	0.02	0	0	2.51 1.36			0.43 0.65	0.05 0.08
NC	2100	2122 Door Weatherization (HP heating early replacement)	Single Family	2014	2053	31.04	3.68	0.38	1.73	5%	0.05	0.21	5%	0.08	0.04	1	0	0.72			0.00	0.00
	2100	2102 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early		2014	2053	28.18	3.34	2.86	4.59	14%	0.34	0.54	14%	0.10	0.08	1	1	0.75			0.00	0.00
	2100 2100	2118 Heat Recovery Ventilators (HP heating early replacement) 2112 Crawlspace insulation (HP heating early replacement)	Single Family	2014 2014	2053 2053	22.06	2.62	6.11 0.52	10.70 11.22	33% 34%	0.73	1.27	33% 34%	0.15 0.19	0.12	1 2	1	0.52			0.00	0.00
	2100	2106 Ceiling R-0 to R-38 Insulation (HP heating early replacement)	Single Family	2014	2053	21.12	2.51	0.42	11.65	36%	0.05	1.38	36%	0.19	0.12	2	1	0.35			0.00	0.00
	2100	2113 Basement insulation R-13 (HP heating early replacement)	Single Family	2014	2053	20.69	2.46	0.43	12.07	37%	0.05	1.43	37%	0.22	0.13	2	1	0.35			0.00	0.00
	2100 2100	2107 Ceiling R-0 to R-49 Insulation (HP heating early replacement) 2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating e	Single Family	2014 2014	2053 2053	20.68 19.74	2.45 2.34	0.01 0.94	12.09 13.03	37% 40%	0.00	1.43 1.55	37% 40%	1.09 0.23	0.13	9	1	0.07 0.27			0.00	0.00
	2100	2117 Duct Testing and Sealing (HP heating early replacement)	Single Family	2014	2053	19.74	2.34	0.18	13.03	40%	0.11	1.55	40%	0.23	0.14	2	1	0.27			0.00	0.00
NC	2100	2123 WINDOWS - Double-Glazed Clear to Energy Star (HP heating	Single Family	2014	2053	19.27	2.29	0.28	13.49	41%	0.03	1.60	41%	0.37	0.14	3	1	0.21			0.00	0.00
	2100 2100	2108 Ceiling R-11 to R-38 Insulaton (HP heating early replacement) 2109 Ceiling R-11 to R-49 Insulation (HP heating early replacement)		2014 2014	2053 2053	18.76 18.71	2.23 2.22	0.52 0.05	14.01 14.06	43% 43%	0.06	1.66 1.67	43% 43%	0.53 1.20	0.16 0.16	4 10	1	0.14 0.06			0.00	0.00
	2100	2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replacement)		2014	2053	18.71	2.22	0.05	14.06	43% 44%	0.01	1.67	43% 44%	0.75	0.16	6	1	0.10			0.00	0.00
NC	2100	2110 Ceiling R-19 to R-38 Insulation (HP heating early replacement)	Single Family	2014	2053	18.46	2.19	0.06	14.31	44%	0.01	1.70	44%	0.97	0.17	8	1	0.08			0.00	0.00
NC	2100	2103 Ground Source Heat Pump with Desuperheater (HP heating ear	Single Family	2014	2053	16.82	2.00	1.63	15.94	49%	0.19	1.89	49%	1.96	0.35	17	3	0.04			0.00	0.00

APPENDIX H

Base Avoided Costs

		Existing Construction IVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage	ITST ADDIT	IVE SUPPLI ANALISIS				Tear	2014		Total			Total		Marginal		Marginal	Average	Total			SUPPLI	
Ba	se Meas		Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	Faanamia
Sgmt Nu			Type	Year	Year	GWH	MW	Savings	GWH		Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
		2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement)	Single Family Single Family	2014 2014	2053 2053	16.81 16.74	1.99 1.99	0.01	15.96 16.03	49% 49%	0.00	1.89	49% 49%	1.34 1.25	0.36	11 11	3	0.06			0.00	0.00
		2105 Heat Pump Filter Replacement (heating)2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacem		2014	2053	16.74	1.98	0.07	16.03	49%	0.01	1.90	49%	2.72	0.36	23	3	0.04			0.00	0.00
	2100	2104 Heat pump tune up (heating)	Single Family	2014	2053	16.61	1.97	0.07	16.15	49%	0.01	1.92	49%	2.02	0.37	17	3	0.03			0.00	0.00
		2200 Base Resistance Space Heating (Primary) 2201 Air Source Heat Pump (resistance heating)	Single Family Single Family	2014 2014	2053 2053	78.22 62.31	9.28 7.39	0.00 15.91	0.00 15.91	0% 20%	0.00 1.89	0.00 1.89	0% 20%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.91	78.22	9.28	0.00 15.91	0.00 1.89
NC		2216 Self Install Weatherization	Single Family	2014	2053	61.49	7.39	0.82	16.73	21%	0.10	1.99	21%	0.02	0.02	0	0	2.02			0.82	0.10
		2214 Programmable Thermostat (resistance heating)	Single Family	2014	2053	60.24	7.15	1.25	17.98	23%	0.15	2.13	23%	0.05	0.02	0	0	1.42			1.25	0.15
		2217 Door Weatherization (resistance heating) 2213 Heat Recovery Ventilators (resistance heating)	Single Family Single Family	2014 2014	2053 2053	59.04 46.23	7.00 5.48	1.21 12.81	19.19 32.00	25% 41%	0.14 1.52	2.28 3.80	25% 41%	0.06 0.17	0.02	0	0	0.95			0.00	0.00
		2203 Ceiling R-0 to R-38 Insulation (resistance heating)	Single Family	2014	2053	45.24	5.37	0.98	32.98	42%	0.12	3.91	42%	0.17	0.09	2	i	0.40			0.00	0.00
	2200	2209 Crawlspace insulation (resistance heating)	Single Family	2014	2053	44.83	5.32	0.41	33.39	43%	0.05	3.96	43%	0.24	0.09	2	1	0.32			0.00	0.00
NC NC		2210 Basement insulation R-13 (resistance heating) 2204 Ceiling R-0 to R-49 Insulation (resistance heating)	Single Family Single Family	2014 2014	2053 2053	44.24 44.22	5.25 5.25	0.59	33.98 34.00	43% 43%	0.07	4.03 4.03	43% 43%	0.25 1.42	0.09	2 12	1	0.31			0.00	0.00
NC		2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance he		2014	2053	42.21	5.23	2.01	36.02	46%	0.00	4.03	46%	0.26	0.09	2	i	0.05			0.00	0.00
NC	2200	2218 WINDOWS - Double-Glazed Clear to Energy Star (resistance h	Single Family	2014	2053	41.52	4.93	0.69	36.71	47%	0.08	4.36	47%	0.35	0.10	3	1	0.22			0.00	0.00
NC NC		2205 Ceiling R-11 to R-38 Insulaton (resistance heating) 2211 Floor R-0 to R-19 Insulation-Batts (resistance heating)	Single Family Single Family	2014	2053	40.31 40.06	4.78 4.75	1.21 0.25	37.91 38.16	48% 49%	0.14	4.50 4.53	48% 49%	0.54 0.59	0.12	5 5	1	0.14			0.00	0.00
		2206 Ceiling R-11 to R-49 Insulation (resistance heating)	Single Family	2014	2053	39.97	4.75 4.74	0.25	38.16	49% 49%	0.03	4.53	49%	1.56	0.12	13	1	0.13			0.00	0.00
NC	2200	2207 Ceiling R-19 to R-38 Insulation (resistance heating)	Single Family	2014	2053	39.83	4.73	0.14	38.39	49%	0.02	4.55	49%	0.93	0.13	8	1	0.08			0.00	0.00
		2208 Ceiling R-19 to R-49 Insulation (resistance heating)	Single Family	2014	2053	39.81	4.72	0.02	38.41	49%	0.00	4.56	49%	1.57	0.13	13	1	0.05			0.00	0.00
NC NC		2202 Ground Source Heat Pump with Desuperheater (resistance hea 2212 Wall Blow-in R-0 to R-13 Insulation (resistance heating)	Single Family Single Family	2014 2014	2053 2053	39.48 39.31	4.68 4.66	0.33 0.17	38.74 38.91	50% 50%	0.04	4.60 4.62	50% 50%	26.32 1.97	0.35 0.36	222 17	3	0.00 0.04			0.00	0.00
NC	3030	3030 Base Halogen Lighting - 0.5 hrs/day 2020	Single Family	2020	2053	4.06	0.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.06	0.45	0.00	0.00
NC		3032 LEDs (base Halogen 0.5 hrs/day) 2020	Single Family	2020	2053	1.30	0.15	2.76	2.76	68%	0.31	0.31	68%	0.04	0.04	0	0	2.44			2.76	0.31
		3130 Base Halogen Lighting - 2.5 hrs/day 2020 3132 LEDs (base Halogen 2.5 hrs/day) 2020	Single Family Single Family	2020 2020	2053 2053	16.58 4.34	1.86 0.49	0.00 12.24	0.00 12.24	0% 74%	0.00 1.37	0.00 1.37	0% 74%	N/A 0.01	N/A 0.01	N/A 0	N/A	N/A 13.20	16.58	1.86	0.00 12.24	0.00 1.37
NC		3230 Base Halogen Lighting - 6 hrs/day 2020	Single Family	2020	2053	10.97	1.23	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.97	1.23	0.00	0.00
NC		3232 LEDs (base Halogen 6 hrs/day) 2020	Single Family	2020	2053	3.51	0.39	7.47	7.47	68%	0.84	0.84	68%	0.00	0.00	0	0	18.15			7.47	0.84
NC NC		3330 Base CFL Lighting - 0.5 hrs/day 2020 3331 LEDs (base CFL 0.5 hrs/day) 2020	Single Family Single Family	2020 2020	2053 2053	1.87 1.37	0.21 0.15	0.00 0.51	0.00 0.51	0% 27%	0.00	0.00	0% 27%	N/A 0.20	N/A 0.20	N/A	N/A	N/A 0.43	1.87	0.21	0.00	0.00
NC		3430 Base CFL Lighting - 2.5 hrs/day 2020	Single Family	2020	2053	7.58	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.58	0.85	0.00	0.00
NC	3430	3431 LEDs (base CFL 2.5 hrs/day) 2020	Single Family	2020	2053	5.54	0.62	2.05	2.05	27%	0.23	0.23	27%	0.04	0.04	0	0	2.11			2.05	0.23
		3530 Base CFL Lighting - 6 hrs/day 2020 3531 LEDs (base CFL 6 hrs/day) 2020	Single Family Single Family	2020 2020	2053 2053	4.94 3.61	0.55 0.40	0.00 1.33	0.00 1.33	0% 27%	0.00 0.15	0.00 0.15	0% 27%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.13	4.94	0.55	0.00 1.33	0.00
NC		3630 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020	Single Family	2020	2053	8.78	0.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.78	0.98	0.00	0.00
NC	3630	3632 LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Single Family	2020	2053	3.47	0.39	5.31	5.31	60%	0.59	0.59	60%	0.01	0.01	0	0	7.30			5.31	0.59
		3730 Base Halogen (Specialty) Lighting - 2.5 hrs/day 2020	Single Family Single Family	2020 2020	2053 2053	36.55 14.44	4.09 1.62	0.00 22.11	0.00 22.11	0% 60%	0.00 2.47	0.00 2.47	0% 60%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 36.70	36.55	4.09	0.00 22.11	0.00 2.47
NC		3732 LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020 3830 Base Halogen (Specialty) Lighting - 6 hrs/day 2020	Single Family	2020	2053	24.20	2.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	24.20	2.71	0.00	0.00
NC	3830	3832 LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	2020	2053	9.56	1.07	14.63	14.63	60%	1.64	1.64	60%	0.00	0.00	0	0	54.64			14.63	1.64
NC NC		3900 Base Fluorescent Fixture 1.8 hrs/day 3902 ROB 2L4T8, 1FB	Single Family Single Family	2014 2014	2053 2053	54.27 39.63	6.08 4.44	0.00 14.64	0.00 14.64	0% 27%	0.00 1.64	0.00 1.64	0% 27%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 2.44	54.27	6.08	0.00 14.64	0.00 1.64
NC		4000 Base Refrigerator	Single Family	2014	2053	47.87	7.76	0.00	0.00	0%	0.00	0.00	0%	0.04 N/A	0.04 N/A	N/A	N/A	2.44 N/A	47.87	7.76	0.00	0.00
NC	4000	4001 Refrigerator (Energy Star)	Single Family	2014	2053	40.33	6.54	7.53	7.53	16%	1.22	1.22	16%	0.04	0.04	0	0	1.92			7.53	1.22
NC NC	4100 4100	4100 Base RefrigeratorEarly Replacement	Single Family Single Family	2014 2014	2053 2053	6.82 3.77	1.11 0.61	0.00 3.05	0.00 3.05	0% 45%	0.00	0.00	0% 45%	N/A 0.09	N/A 0.09	N/A 1	N/A	N/A 0.61	6.82	1.11	0.00	0.00
NC		4101 Refrigerator - Early Replacement (Energy Star) 4200 Base 2nd Refrigerator - Recycling	Single Family	2014	2053	23.56	3.82	0.00	0.00	0%	0.49	0.49	0%	N/A	N/A	N/A	N/A	N/A	23.56	3.82	0.00	0.00
NC	4200	4201 2nd Refrigerator Recycling	Single Family	2014	2053	6.07	0.98	17.49	17.49	74%	2.84	2.84	74%	0.03	0.03	0	0	2.33			17.49	2.84
NC		4500 Base Freezer	Single Family	2014	2053	31.46	5.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	31.46	5.10	0.00	0.00
NC NC		4501 Freezer (Energy Star) 4600 Base Early Replacement Freezer	Single Family Single Family	2014 2014	2053 2053	28.69 6.58	4.65 1.04	2.77 0.00	2.77 0.00	9% 0%	0.45	0.45 0.00	9% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.46 N/A	6.58	1.04	2.77 0.00	0.45
NC	4600	4601 Freezer - Early Replacement (Energy Star)	Single Family	2014	2053	3.02	0.48	3.56	3.56	54%	0.56	0.56	54%	0.04	0.04	0	0	1.46			3.56	0.56
NC		4700 Base 2nd Freezer Recycling	Single Family	2014	2053	7.09	1.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.09	1.12	0.00	0.00
NC NC		4701 2nd Freezer Recycling 5000 Base Water Heating (40 gal, EF=0.88)	Single Family Single Family	2014 2014	2053 2053	3.58 189.05	0.57 23.28	3.51 0.00	3.51 0.00	50% 0%	0.56	0.56 0.00	50% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	3.66 N/A	189.05	23.28	3.51 0.00	0.56
NC		5006 Pipe Wrap	Single Family	2014	2053	183.24	22.57	5.81	5.81	3%	0.72	0.72	3%	0.02	0.02	0	0	3.61	. 50.00	20.20	5.81	0.72
NC		5007 Hot water turndown 5 degrees	Single Family	2014	2053	182.60	22.49	0.64	6.45	3%	0.08	0.79	3%	0.02	0.02	0	0	2.42			0.64	0.08
NC NC		5009 Hot water turndown 15 degrees 5010 Hot water turndown 20 degrees	Single Family Single Family	2014 2014	2053 2053	182.40 182.32	22.46 22.46	0.20 0.08	6.65 6.73	4% 4%	0.03	0.82 0.83	4% 4%	0.02	0.02	0	0	2.41 2.41			0.20	0.03 0.01
NC		5008 Hot water turndown 10 degrees	Single Family	2014	2053	181.46	22.46	0.86	7.59	4%	0.01	0.63	4%	0.02	0.02	0	0	2.41			0.86	0.01
NC	5000	5015 Low Flow Showerhead 1.5 Gal/Min	Single Family	2014	2053	176.03	21.68	5.42	13.02	7%	0.67	1.60	7%	0.03	0.02	0	0	2.26			5.42	0.67
NC NC		5011 Drain Water Heat Recovery (GFX) 5014 Faucent Aerators	Single Family Single Family	2014 2014	2053 2053	169.42 165.83	20.87 20.42	6.62 3.59	19.63 23.22	10% 12%	0.81 0.44	2.42 2.86	10% 12%	0.06 0.05	0.03	0	0	1.31 1.11			6.62 3.59	0.81
NC		5005 DHW Tank Wrap	Single Family	2014	2053	156.73	19.30	9.10	32.32	17%	1.12	3.98	17%	0.05	0.04	0	0	1.00			0.00	0.00
NC	5000	5003 Heat Pump Water Heater - Energy Star	Single Family	2014	2053	133.71	16.47	23.02	55.34	29%	2.84	6.82	29%	0.08	0.06	1	0	0.91			0.00	0.00
NC NC		5004 Solar Domestic Water Heating	Single Family	2014	2053 2053	71.07 70.88	8.75 8.73	62.64 0.19	117.99 118.17	62% 63%	7.72 0.02	14.53 14.55	62% 63%	0.19 4.86	0.13	2 39	1	0.41 0.01			0.00	0.00
NC NC		5012 Energy Star CW CEE Tier 2 (MEF=2.0) 5013 Energy Star Dishwasher (EF=0.72)	Single Family Single Family	2014	2053	70.88	8.73 8.71	0.19	118.17	63%	0.02	14.55	63%	4.86	0.13	39	1	0.01			0.00	0.00
	5100	5100 Base Water Heating Early Replacement to Heat Pump Water H	Single Family	2014	2053	33.36	4.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	33.36	4.11	0.00	0.00
NC NC		5101 Heat Pump Water Heater - Energy Star - Early Replacement	Single Family	2014	2053 2053	28.60	3.52 0.61	4.76 0.00	4.76 0.00	14% 0%	0.59	0.59	14% 0%	0.08 N/A	0.08 N/A	1 N/A	1 N/A	0.92	2.20	0.61	0.00	0.00
NC NC	5500 5500	5500 Base Clotheswasher (MEF=1.26) 5501 Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family Single Family	2014	2053	2.56	0.61	0.00	0.00	0% 24%	0.00	0.00	0% 24%	1.33	N/A 1.33	N/A 7	7	N/A 0.06	3.38	0.61	0.00	0.00
NC		5600 Base Clothes Dryer (EF=3.01)	Single Family	2014	2053	50.79	8.60	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	50.79	8.60	0.00	0.00

DNV GL H-11 1/5/2015

APPENDIX H

Base Avoided Costs

		ic Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity		Total Resource				
Sgmt No	ımber Nu	easure imber Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	MW
NC NC	5600 5600	5602 High Efficiency CD (EF=3.01 w/moisture sensor) 5601 Heat Pump Dryer	Single Family Single Family	2014 2014	2053 2053	41.46 20.73	7.02 3.51	9.33 20.73	9.33 30.06	18% 59%	1.58 3.51	1.58 5.09	18% 59%	0.05 0.75	0.05 0.53	0 4	0 3	1.53 0.09			9.33 0.00	1.58 0.00
NC NC	5700 5700	5700 Base Dishwasher (EF=0.65) 5701 Energy Star Dishwasher (EF=0.72)	Single Family Single Family	2014 2014	2053 2053	6.77 6.53	1.11 1.07	0.00	0.00	0% 4%	0.00	0.00	0% 4%	N/A 1.70	N/A 1.70	N/A 10	N/A 10	N/A 0.04	6.77	1.11	0.00	0.00
NC	6000	6000 Base Single Speed Pool Pump (RET)	Single Family	2014	2053	13.47	1.60	0.24	0.24	0%	0.04	0.04	0%	N/A	N/A	N/A	N/A	N/A	13.47	1.60	0.00	0.00
NC NC	6000	6002 Variable-Speed Pool Pump (<1 hp)	Single Family	2014	2053	3.73 0.15	0.44	9.74	9.74	72%	1.16	1.16	72% 99%	0.03	0.03	0	0	2.01			9.74	1.16
NC	7000	6001 PV-Powered Pool Pumps 7000 Base Plasma TV	Single Family Single Family	2014 2014	2053 2053	9.20	0.02 1.33	3.58 0.00	13.32 0.00	99% 0%	0.43	1.58 0.00	0%	1.02 N/A	0.30 N/A	N/A	N/A	0.06 N/A	9.20	1.33	0.00	0.00
NC	7000 7000	7001 Energy Star Plasma TV	Single Family	2014	2053	8.40 8.34	1.21	0.80	0.80	9%	0.12	0.12	9%	0.01	0.01	0	0	6.83			0.80	0.12
NC NC	7100	7002 Plug Load Controls - Smart Power Strip (base plasma TV) 7100 Base LCD TV	Single Family Single Family	2014 2014	2053 2053	10.93	1.20 1.58	0.06 0.00	0.86 0.00	9% 0%	0.01	0.12 0.00	9% 0%	4.37 N/A	0.33 N/A	30 N/A	N/A	0.01 N/A	10.93	1.58	0.00	0.00
NC	7100 7100	7101 Energy Star LCD TV	Single Family	2014	2053	7.16	1.03	3.77	3.77	34%	0.54	0.54	34%	0.00	0.00	0	0	15.08			3.77	0.54
NC NC	7100	7102 Plug Load Controls - Smart Power Strip (base LCD TV) 7200 Base CRT TV	Single Family Single Family	2014 2014	2053 2053	7.01 5.33	1.01 0.77	0.15 0.00	3.92 0.00	36% 0%	0.02	0.57 0.00	36% 0%	4.68 N/A	0.18 N/A	32 N/A	1 N/A	0.01 N/A	5.33	0.77	0.00	0.00
NC	7200	7202 Plug Load Controls - Smart Power Strip (base CRT TV)	Single Family	2014	2053	5.02	0.72	0.31	0.31	6%	0.04	0.04	6%	1.29	1.29	9	9	0.04			0.00	0.00
NC NC	7300 7400	7300 Base Set-Top Box 7400 Base DVD Player	Single Family Single Family	2014 2014	2053 2053	15.22 1.66	2.20 0.24	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	15.22 1.66	2.20 0.24	0.00	0.00
NC	7400	7401 Energy Star DVD Player	Single Family	2014	2053	0.78	0.11	0.88	0.88	53%	0.13	0.13	53%	0.02	0.02	0	0	3.77			0.88	0.13
NC NC	7400 7500	7402 Plug Load Controls - Smart Power Strip (base DVD player) 7500 Base Desktop PC	Single Family Single Family	2014 2014	2053 2053	0.08 17.75	0.01 2.34	0.70 0.00	1.57 0.00	95% 0%	0.10	0.23	95% 0%	0.80 N/A	0.36 N/A	6 N/A	3 N/A	0.07 N/A	17.75	2.34	0.00	0.00
NC	7500	7501 Energy Star Desktop PC	Single Family	2014	2053	15.66	2.06	2.09	2.09	12%	0.28	0.28	12%	0.00	0.00	0	0	15.18			2.09	0.28
NC NC	7500 7600	7502 Plug Load Controls - Smart Power Strip (base Desktop PC) 7600 Base Laptop PC	Single Family Single Family	2014 2014	2053 2053	11.27 2.54	1.48 0.33	4.39 0.00	6.48 0.00	37% 0%	0.58	0.85	37% 0%	0.08 N/A	0.06 N/A	1 N/A	0 N/A	0.67 N/A	2.54	0.33	0.00	0.00
NC	7600	7601 Energy Star Laptop PC	Single Family	2014	2053	2.13	0.28	0.40	0.40	16%	0.05	0.05	16%	0.03	0.03	0	0	2.28			0.40	0.05
NC NC	9000	8000 Base Cooking 9000 Base Miscellaneous	Single Family Single Family	2014 2014	2053 2053	47.21 67.94	15.07 8.95	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	47.21 67.94	15.07 8.95	0.00	0.00
NC	9900	9900 Base House Use	Single Family	2014	2053	1,379.15	341.51	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1,379.15	341.51	0.00	0.00
NC NC	9900 9900	9901 Indirect Feedback 9902 Direct Feedback	Single Family Single Family	2014 2014	2053 2053	1,358.66		20.48 64.05	20.48 84.53	1% 6%	5.07 15.86	5.07 20.93	1% 6%	0.02 0.05	0.02	0	0	2.73 1.12			20.48 64.05	5.07 15.86
NC	1000	1000 Base Split-System Air Conditioner - (13 SEER, 11.09 EER)	Multi-Family	2014	2053	7.75	4.60	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.75	4.60	0.00	0.00
NC NC	1000 1000	1024 Self Install Weatherization (CAC) 1025 Door Weatherization (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	7.63 7.26	4.53 4.31	0.12 0.37	0.12 0.49	2% 6%	0.07	0.07 0.29	2% 6%	0.02	0.02	0	0	4.23 1.00			0.12 0.00	0.07
NC	1000	1004 Proper Refrigerant Charging and Air Flow (CAC)	Multi-Family	2014	2053	6.74	4.00	0.52	1.01	13%	0.31	0.60	13%	0.12	0.09	Ō	Ō	0.71			0.00	0.00
NC NC	1000	1019 Duct Insulation (CAC) 1022 Programmable Thermostat (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	6.72 6.67	3.99 3.96	0.01 0.05	1.03 1.08	13% 14%	0.01	0.61 0.64	13% 14%	0.18 0.15	0.09	0	0	0.65			0.00	0.00
NC	1000	1001 14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	Multi-Family	2014	2053	6.24	3.71	0.43	1.51	19%	0.25	0.90	19%	0.21	0.13	o	Ō	0.52			0.00	0.00
NC NC	1000 1000	1021 Return Duct Modification (CAC) 1002 15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Multi-Family Multi-Family	2014	2053 2053	6.21 5.84	3.69 3.47	0.04	1.54 1.91	20% 25%	0.02	0.92 1.14	20% 25%	0.24	0.13	0	0	0.47			0.00	0.00
NC	1000	1026 Ceiling Fans (CAC)	Multi-Family	2014	2053	5.53	3.28	0.31	2.23	29%	0.18	1.32	29%	0.28	0.17	0	Ō	0.37			0.00	0.00
NC NC	1000 1000	1014 Crawlspace insulation (CAC) 1003 17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	5.51 4.92	3.27 2.92	0.02 0.58	2.25 2.83	29% 37%	0.01	1.33 1.68	29% 37%	0.33 0.35	0.17 0.21	1	0	0.35 0.32			0.00	0.00
NC	1000	1008 Ceiling R-0 to R-38 Insulation (CAC)	Multi-Family	2014	2053	4.51	2.68	0.41	3.24	42%	0.24	1.93	42%	0.63	0.26	1	0	0.18			0.00	0.00
NC NC	1000 1000	1023 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) 1030 WINDOWS - Double-Glazed Clear to Energy Star (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	4.31 4.21	2.56 2.50	0.21 0.10	3.45 3.54	44% 46%	0.12	2.05 2.10	44% 46%	0.54 0.74	0.28	1	0	0.16 0.15			0.00	0.00
NC	1000	1005 Proper Sizing and Quality Install (CAC)	Multi-Family	2014	2053	3.80	2.26	0.41	3.95	51%	0.24	2.35	51%	0.82	0.35	1	1	0.13			0.00	0.00
NC NC	1000 1000	1020 Duct Testing and Sealing (CAC) 1009 Ceiling R-0 to R-49 Insulation (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	3.70 3.70	2.20 2.20	0.10 0.00	4.05 4.05	52% 52%	0.06	2.41 2.41	52% 52%	0.92 8.89	0.36	2 15	1	0.12 0.01			0.00	0.00
NC	1000	1029 WINDOWS - Default With Sunscreen (CAC)	Multi-Family	2014	2053	3.44	2.04	0.26	4.31	56%	0.15	2.56	56%	1.06	0.41	2	1	0.08			0.00	0.00
NC NC	1000 1000	1010 Ceiling R-11 to R-38 Insulaton (CAC) 1018 Cool Roof (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	3.39 3.28	2.01 1.95	0.05 0.11	4.36 4.47	56% 58%	0.03	2.59 2.65	56% 58%	2.00 1.90	0.43	3	1	0.06 0.05			0.00	0.00
NC	1000	1017 Wall Blow-in R-0 to R-13 Insulation (CAC)	Multi-Family	2014	2053	3.25	1.93	0.03	4.50	58%	0.02	2.67	58%	2.44	0.48	4	1	0.05			0.00	0.00
NC NC	1000	1028 Window Film (CAC) 1027 Whole House Fans (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	3.06 2.88	1.82 1.71	0.19 0.18	4.69 4.87	61% 63%	0.11 0.11	2.79 2.89	61% 63%	1.91 2.40	0.54	3 4	1	0.05			0.00	0.00
NC	1000	1011 Ceiling R-11 to R-49 Insulation (CAC)	Multi-Family	2014	2053	2.88	1.71	0.00	4.87	63%	0.00	2.89	63%	11.43	0.61	19	1	0.01			0.00	0.00
NC NC	1000 1000	1012 Ceiling R-19 to R-38 Insulation (CAC) 1013 Ceiling R-19 to R-49 Insulation (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	2.87 2.87	1.71 1.71	0.01 0.00	4.88 4.88	63% 63%	0.00	2.90 2.90	63% 63%	3.98 11.46	0.61 0.62	7 19	1	0.03 0.01			0.00	0.00
NC	1000	1016 Floor R-0 to R-19 Insulation-Batts (CAC)	Multi-Family	2014	2053	2.86	1.70	0.02	4.89	63%	0.01	2.91	63%	6.36	0.63	11	1	0.02			0.00	0.00
NC NC	1000 1000	1015 Basement insulation R-13 (CAC) 1007 AC Filter Changes (CAC)	Multi-Family Multi-Family	2014 2014	2053 2053	2.85 2.84	1.69 1.69	0.01	4.90 4.91	63% 63%	0.00	2.91 2.92	63% 63%	6.44 7.74	0.64 0.65	11 13	1	0.02			0.00	0.00
NC	1000	1006 AC Maintenance and/or tune-up (CAC)	Multi-Family	2014	2053	2.83	1.68	0.01	4.92	63%	0.01	2.92	63%	8.85	0.67	15	1	0.01			0.00	0.00
NC NC	1100 1100	1100 Base Split-System Air Conditioner - Early Replacement (11 SE 1122 Self Install Weatherization (CAC early replacement)	El Multi-Family Multi-Family	2014 2014	2053 2053	2.32	1.38 1.36	0.00 0.04	0.00 0.04	0% 2%	0.00	0.00 0.02	0% 2%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.17	2.32	1.38	0.00 0.04	0.00
NC	1100	1117 Duct Insulation (CAC early replacement)	Multi-Family	2014	2053	2.26	1.35	0.02	0.06	2%	0.01	0.03	2%	0.02	0.02	0	0	4.97			0.02	0.01
NC NC	1100 1100	1123 Door Weatherization (CAC early replacement)	Multi-Family	2014 2014	2053 2053	2.16 1.97	1.28 1.17	0.11 0.19	0.16 0.35	7% 15%	0.06	0.10 0.21	7% 15%	0.04	0.03	0	0	1.64 1.17			0.11 0.19	0.06 0.11
NC	1100	1102 Proper Refrigerant Charging and Air Flow (CAC early replacer 1120 Programmable Thermostat (CAC early replacement)	Multi-Family	2014	2053	1.95	1.16	0.02	0.37	16%	0.01	0.22	16%	0.09	0.06	0	0	1.04			0.02	0.01
NC NC	1100 1100	1119 Return Duct Modification (CAC early replacement) 1112 Crawlspace insulation (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	1.94 1.93	1.15 1.15	0.01 0.01	0.38 0.38	16% 17%	0.01	0.22 0.23	16% 17%	0.14 0.17	0.06	0	0	0.83 0.69			0.00	0.00
NC	1100	1116 Cool Roof (CAC early replacement)	Multi-Family	2014	2053	1.72	1.02	0.22	0.60	26%	0.13	0.36	26%	0.17	0.10	0	0	0.62			0.00	0.00
NC NC	1100 1100	1125 Whole House Fans (CAC early replacement) 1128 WINDOWS - Double-Glazed Clear to Energy Star (CAC early	Multi-Family	2014 2014	2053 2053	1.38 1.35	0.82 0.80	0.34	0.94 0.97	40% 42%	0.20	0.56 0.58	40% 42%	0.23	0.15 0.15	0	0	0.46 0.31			0.00	0.00
NC	1100	1106 Ceiling R-0 to R-38 Insulation (CAC early replacement)	Multi-Family	2014	2053	1.24	0.73	0.11	1.08	47%	0.07	0.64	47%	0.41	0.18	1	0	0.28			0.00	0.00
NC	1100	1118 Duct Testing and Sealing (CAC early replacement)	Multi-Family	2014	2053	1.20 1.14	0.71 0.68	0.04	1.12	48%	0.02	0.67	48%	0.43	0.19	1	0	0.25			0.00	0.00
NC	1100	1121 Comprehensive Shell Air Sealing - Inf. Reduction (CAC early r	e wuu-ramily	2014	2053	1.14	0.00	0.05	1.17	51%	0.03	0.70	51%	0.36	0.20	1	U	0.25			0.00	0.00

DNV GL H-12 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	ase M umber N	easure umber Measure	Building Type	Start	End	Total GWH	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
NC	1100	1103 Proper Sizing and Quality Install (CAC early replacement)	Multi-Family	2014	2053	1.01	0.60	0.13	1.31	56%	0.08	0.78	56%	0.55	0.23	1	0	0.20	GWH	IVIVV	0.00	0.00
NC NC	1100 1100	1124 Ceiling Fans (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.98	0.58 0.58	0.03	1.34 1.34	58% 58%	0.02	0.79 0.79	58% 58%	0.58 5.90	0.24	1 10	0	0.18 0.02			0.00	0.00
NC NC	1100	1107 Ceiling R-0 to R-49 Insulation (CAC early replacement) 1113 Basement insulation R-13 (CAC early replacement)	Multi-Family	2014	2053	0.98	0.58	0.00	1.35	58%	0.00	0.79	58%	0.68	0.25	10	0	0.02			0.00	0.00
NC	1100	1108 Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Multi-Family	2014	2053	0.96	0.57	0.01	1.36	59%	0.01	0.81	59%	1.25	0.26	2	Ō	0.09			0.00	0.00
NC	1100 1100		Multi-Family	2014 2014	2053	0.91	0.54	0.05	1.41 1.42	61% 61%	0.03	0.84	61% 61%	1.05	0.28	2	0	80.0			0.00	0.00
NC NC	1100	1115 Wall Blow-in R-0 to R-13 Insulation (CAC early replacement) 1109 Ceiling R-11 to R-49 Insulation (CAC early replacement)	Multi-Family Multi-Family	2014	2053 2053	0.90	0.54 0.54	0.01 0.00	1.42	61%	0.01	0.84 0.84	61%	1.55 6.44	0.29	11	0	0.07 0.02			0.00	0.00
NC	1100	1126 Window Film (CAC early replacement)	Multi-Family	2014	2053	0.86	0.51	0.04	1.46	63%	0.02	0.87	63%	1.56	0.33	3	1	0.06			0.00	0.00
NC NC	1100 1100	1110 Ceiling R-19 to R-38 Insulation (CAC early replacement) 1111 Ceiling R-19 to R-49 Insulation (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.86	0.51 0.51	0.00	1.46 1.46	63% 63%	0.00	0.87 0.87	63% 63%	2.35 6.76	0.33	4 11	1	0.05 0.02			0.00	0.00
NC	1100		Multi-Family	2014	2053	0.82	0.48	0.04	1.50	65%	0.03	0.89	65%	2.56	0.40	4	1	0.02			0.00	0.00
NC	1100	1114 Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	Multi-Family	2014	2053	0.81	0.48	0.00	1.51	65%	0.00	0.90	65%	3.96	0.41	7	1	0.03			0.00	0.00
NC NC	1100 1100	1105 AC Filter Changes (CAC early replacement) 1104 AC Maintenance and/or tune-up (CAC early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.81	0.48 0.48	0.00	1.51 1.51	65% 65%	0.00	0.90 0.90	65% 65%	4.80 5.49	0.42	8	1	0.01 0.01			0.00	0.00
NC	1200	1200 Base Heat Pump Cooling (13 SEER)	Multi-Family	2014	2053	11.87	7.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.87	7.05	0.00	0.00
NC	1200	1219 Duct Insulation (HP cooling)	Multi-Family	2014	2053	11.77	6.99	0.10	0.10	1%	0.06	0.06	1%	0.03	0.03	0	0	4.16			0.10	0.06
NC NC	1200 1200	1223 Self Install Weatherization (HP cooling) 1224 Door Weatherization (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	11.58 11.02	6.88 6.55	0.19 0.56	0.28 0.85	2% 7%	0.11	0.17 0.50	2% 7%	0.04 0.05	0.04	0	0	2.24 1.38			0.19 0.56	0.11 0.33
NC	1200	1202 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Multi-Family	2014	2053	9.15	5.44	1.87	2.71	23%	1.11	1.61	23%	0.09	0.08	0	0	1.17			1.87	1.11
NC	1200	1204 Proper Refrigerant Charging and Air Flow (HP cooling)	Multi-Family	2014	2053	8.50	5.05	0.66	3.37	28%	0.39	2.00	28%	0.11	0.08	0	0	0.82			0.00	0.00
NC NC	1200 1200	1214 Crawlspace insulation (HP cooling) 1221 Programmable Thermostat (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	8.47 8.30	5.03 4.93	0.03 0.17	3.40 3.57	29% 30%	0.02	2.02 2.12	29% 30%	0.23 0.21	0.08	0	0	0.49 0.45			0.00	0.00
NC	1200	1218 Cool Roof (HP cooling)	Multi-Family	2014	2053	7.37	4.38	0.93	4.49	38%	0.55	2.67	38%	0.24	0.12	ō	0	0.43			0.00	0.00
NC	1200	1226 Whole House Fans (HP cooling)	Multi-Family	2014	2053	5.93	3.53	1.44	5.93	50%	0.85	3.52	50%	0.33	0.17	1	0	0.32			0.00	0.00
NC NC	1200 1200	1208 Ceiling R-0 to R-38 Insulation (HP cooling) 1220 Duct Testing and Sealing (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	5.43 5.27	3.23 3.13	0.50 0.16	6.43 6.59	54% 56%	0.30	3.82 3.92	54% 56%	0.57 0.61	0.20	1	0	0.20 0.18			0.00	0.00
NC	1200	1222 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)	Multi-Family	2014	2053	5.03	2.99	0.24	6.83	58%	0.14	4.06	58%	0.51	0.22	1	Ö	0.17			0.00	0.00
NC	1200	1205 Proper Sizing and Quality Install (HP cooling)	Multi-Family	2014	2053	4.54	2.70	0.49	7.32	62%	0.29	4.35	62%	0.74	0.26	1	0	0.15			0.00	0.00
NC NC	1200 1200	1209 Ceiling R-0 to R-49 Insulation (HP cooling) 1225 Ceiling Fans (HP cooling)	Multi-Family Multi-Family	2014 2014	2053 2053	4.53 4.41	2.69 2.62	0.01 0.12	7.34 7.45	62% 63%	0.01	4.36 4.43	62% 63%	3.57 0.81	0.26 0.27	6 1	0	0.03			0.00	0.00
NC	1200	1215 Basement insulation R-13 (HP cooling)	Multi-Family	2014	2053	4.36	2.59	0.05	7.50	63%	0.03	4.46	63%	0.95	0.28	2	0	0.12			0.00	0.00
NC NC	1200 1200		Multi-Family Multi-Family	2014 2014	2053 2053	4.26 4.19	2.53 2.49	0.11 0.07	7.61 7.68	64% 65%	0.06	4.52 4.56	64% 65%	1.11 1.74	0.29	2	0	0.10 0.07			0.00	0.00
NC	1200	1210 Ceiling R-11 to R-38 Insulaton (HP cooling) 1211 Ceiling R-11 to R-49 Insulation (HP cooling)	Multi-Family	2014	2053	4.19	2.49	0.07	7.68	65%	0.04	4.56	65%	3.87	0.30	7	1	0.07			0.00	0.00
NC	1200	1216 Floor R-0 to R-19 Insulation-Batts (HP cooling)	Multi-Family	2014	2053	4.14	2.46	0.04	7.72	65%	0.03	4.59	65%	2.42	0.31	4	1	0.05			0.00	0.00
NC NC	1200 1200	1212 Ceiling R-19 to R-38 Insulation (HP cooling) 1213 Ceiling R-19 to R-49 Insulation (HP cooling)	Multi-Family Multi-Family	2014	2053 2053	4.13 4.13	2.46	0.01	7.73 7.73	65% 65%	0.00	4.59 4.59	65% 65%	3.12 3.93	0.32	5 7	1	0.04			0.00	0.00
NC	1200	1217 Wall Blow-in R-0 to R-13 Insulation (HP cooling)	Multi-Family	2014	2053	4.10	2.43	0.00	7.77	65%	0.02	4.61	65%	7.69	0.35	13	1	0.03			0.00	0.00
NC	1200	1207 Heat Pump Filter Replacement	Multi-Family	2014	2053	4.09	2.43	0.01	7.78	66%	0.01	4.62	66%	5.82	0.36	10	1	0.01			0.00	0.00
NC NC	1200 1300	1206 Heat pump tune up 1300 Base Heat Pump Cooling - Early Replacement (13 SEER)	Multi-Family Multi-Family	2014 2014	2053 2053	4.07 2.14	2.42 1.27	0.01	7.79 0.00	66% 0%	0.01	4.63 0.00	66% 0%	9.38 N/A	0.37 N/A	16 N/A	1 N/A	0.01 N/A	2.14	1.27	0.00	0.00
NC	1300	1319 Duct Insulation (HP cooling Early Replacement)	Multi-Family	2014	2053	2.13	1.26	0.02	0.02	1%	0.01	0.01	1%	0.03	0.03	0	0	4.26	2		0.02	0.01
NC NC	1300 1300	1323 Self Install Weatherization (HP cooling Early Replacement)	Multi-Family	2014 2014	2053 2053	2.09 1.99	1.24 1.18	0.03	0.05	2%	0.02	0.03	2% 7%	0.04	0.03	0	0	2.29 1.38			0.03	0.02
NC NC	1300	1324 Door Weatherization (HP cooling Early Replacement) 1302 Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Ea	Multi-Family Multi-Family	2014	2053	1.66	0.98	0.10	0.15	7% 23%	0.06	0.09	23%	0.05	0.05	0	0	1.38			0.10	0.06
NC	1300	1304 Proper Refrigerant Charging and Air Flow (HP cooling Early Re		2014	2053	1.54	0.91	0.12	0.61	28%	0.07	0.36	28%	0.11	0.08	ō	ō	0.84			0.00	0.00
NC NC	1300 1300	1314 Crawlspace insulation (HP cooling Early Replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	1.53 1.50	0.91 0.89	0.01	0.61 0.64	29%	0.00	0.36	29% 30%	0.23	0.08	0	0	0.50			0.00	0.00
NC	1300	1321 Programmable Thermostat (HP cooling Early Replacement) 1318 Cool Roof (HP cooling Early Replacement)	Multi-Family	2014	2053	1.33	0.69	0.03	0.84	30% 38%	0.02	0.38	38%	0.21	0.09	0	0	0.46			0.00	0.00
NC	1300	1326 Whole House Fans (HP cooling early replacement)	Multi-Family	2014	2053	1.07	0.64	0.26	1.07	50%	0.15	0.64	50%	0.32	0.17	1	0	0.32			0.00	0.00
NC NC	1300 1300	1308 Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement) 1320 Duct Testing and Sealing (HP cooling Early Replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.98	0.58 0.57	0.09	1.16 1.19	54% 56%	0.05	0.69 0.71	54% 56%	0.55 0.60	0.20	1	0	0.21 0.18			0.00	0.00
NC	1300	1322 Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling E		2014	2053	0.91	0.54	0.03	1.23	58%	0.02	0.73	58%	0.50	0.22	1	0	0.18			0.00	0.00
NC	1300	1305 Proper Sizing and Quality Install (HP cooling Early Replacemer	Multi-Family	2014	2053	0.82	0.49	0.09	1.32	62%	0.05	0.79	62%	0.72	0.25	1	0	0.15			0.00	0.00
NC NC	1300 1300	1309 Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) 1325 Ceiling Fans (HP cooling early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	0.82	0.49	0.00	1.32 1.35	62% 63%	0.00	0.79	62% 63%	3.49 0.79	0.26	6 1	0	0.03			0.00	0.00
NC	1300	1315 Basement insulation R-13 (HP cooling Early Replacement)	Multi-Family	2014	2053	0.79	0.47	0.01	1.35	63%	0.01	0.80	63%	0.92	0.27	2	0	0.12			0.00	0.00
NC	1300	1327 WINDOWS - Double-Glazed Clear to Energy Star (HP cooling I		2014	2053	0.77	0.46	0.02	1.37	64%	0.01	0.82	64%	1.09	0.28	2	0	0.11			0.00	0.00
NC NC	1300 1300	1310 Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement) 1311 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement)		2014 2014	2053 2053	0.76 0.76	0.45 0.45	0.01 0.00	1.39 1.39	65% 65%	0.01	0.82 0.82	65% 65%	1.69 3.78	0.29	3 6	0	0.07 0.03			0.00	0.00
NC	1300	1316 Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement	Multi-Family	2014	2053	0.75	0.45	0.01	1.39	65%	0.00	0.83	65%	2.36	0.31	4	1	0.05			0.00	0.00
NC NC	1300 1300	1312 Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)		2014 2014	2053 2053	0.75 0.75	0.44 0.44	0.00	1.40 1.40	65% 65%	0.00	0.83 0.83	65% 65%	3.05 3.83	0.31	5 6	1	0.04			0.00	0.00
NC NC	1300	1313 Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement, 1317 Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacer		2014	2053	0.75	0.44	0.00	1.40	65%	0.00	0.83	65%	7.49	0.31	13	1	0.03			0.00	0.00
NC	1300	1307 Heat Pump Filter Replacement	Multi-Family	2014	2053	0.74	0.44	0.00	1.40	65%	0.00	0.83	65%	5.67	0.35	10	1	0.01			0.00	0.00
NC NC	1300 1400	1306 Heat pump tune up 1400 Base Room Air Conditioner - EER 10.6	Multi-Family Multi-Family	2014 2014	2053 2053	0.74 0.67	0.44 0.40	0.00	1.41 0.00	66% 0%	0.00	0.84	66% 0%	9.15 N/A	0.36 N/A	15 N/A	1 N/A	0.01 N/A	0.67	0.40	0.00	0.00
NC	1400	1413 Self Install Weatherization (RAC)	Multi-Family	2014	2053	0.66	0.40	0.00	0.00	2%	0.00	0.00	2%	0.01	0.01	0	0	8.46	0.07	0.40	0.00	0.00
NC	1400	1414 Door Weatherization (RAC)	Multi-Family	2014	2053	0.63	0.37	0.03	0.04	6%	0.02	0.03	6%	0.04	0.03	0	0	1.99			0.03	0.02
NC NC	1400 1400	1411 Cool Roof (RAC) 1416 Whole House Fans (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.56	0.33 0.27	0.07 0.11	0.11 0.22	17% 33%	0.04	0.07 0.13	17% 33%	0.13 0.17	0.09	0	0	0.82 0.61			0.00	0.00
NC	1400	1412 Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	Multi-Family	2014	2053	0.42	0.25	0.02	0.25	37%	0.01	0.15	37%	0.20	0.14	0	Ō	0.45			0.00	0.00
NC	1400	1402 HE Room Air Conditioner - CEE Tier 1 EER 11.3	Multi-Family	2014	2053	0.40	0.24	0.03	0.27	40%	0.01	0.16	40%	0.20	0.14	0	0	0.42			0.00	0.00

DNV GL H-13 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	ase M umber N	easure umber Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
NC NC	1400 1400	1419 WINDOWS - Double-Glazed Clear to Energy Star (RAC) 1404 Ceiling R-0 to R-38 Insulation (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.39 0.36	0.23 0.21	0.01 0.03	0.28 0.31	42% 46%	0.01 0.02	0.17 0.18	42% 46%	0.31 0.36	0.15 0.17	1	0	0.37 0.31			0.00	0.00
NC	1400	1415 Ceiling Fans (RAC)	Multi-Family	2014	2053	0.35	0.21	0.01	0.32	48%	0.01	0.19	48%	0.40	0.18	1	0	0.26			0.00	0.00
NC NC	1400 1400	1405 Ceiling R-0 to R-49 Insulation (RAC) 1417 Window Film (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.35	0.21	0.00	0.32 0.35	48% 53%	0.00	0.19 0.21	48% 53%	2.23 0.51	0.18	4 1	0	0.05			0.00	0.00
NC	1400	1410 Wall Blow-in R-0 to R-13 Insulation (RAC)	Multi-Family	2014	2053	0.31	0.19	0.00	0.36	53%	0.00	0.21	53%	1.00	0.22	2	Ō	0.11			0.00	0.00
NC NC	1400 1400	1418 WINDOWS - Default With Sunscreen (RAC) 1406 Ceiling R-11 to R-38 Insulaton (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.30	0.18 0.18	0.01 0.00	0.37 0.37	55% 56%	0.01	0.22 0.22	55% 56%	0.79 1.10	0.24 0.25	1 2	0	0.11 0.10			0.00	0.00
NC	1400	1407 Ceiling R-11 to R-49 Insulation (RAC)	Multi-Family	2014	2053	0.29	0.17	0.00	0.38	56%	0.00	0.22	56%	2.65	0.25	4	0	0.04			0.00	0.00
NC NC	1400 1400	1408 Ceiling R-19 to R-38 Insulation (RAC) 1409 Ceiling R-19 to R-49 Insulation (RAC)	Multi-Family Multi-Family	2014 2014	2053 2053	0.29	0.17 0.17	0.00	0.38	56% 56%	0.00	0.22	56% 56%	1.84 2.65	0.25	3	0	0.06 0.04			0.00	0.00
NC	1400	1403 Room AC Filter Replacement	Multi-Family	2014	2053	0.29	0.17	0.00	0.38	56%	0.00	0.22	56%	2.40	0.26	4	0	0.04			0.00	0.00
NC	1500	1500 Base Room Air Conditioner, Early Replacement - EER 9.7	Multi-Family	2014	2053	0.05	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.03	0.00	0.00
NC NC	1500 1600	1501 EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early 1 1600 Base Dehumidifier (40 pints/day, 1.5 liters/kWh)	Multi-Family Multi-Family	2014 2014	2053 2053	0.05 0.19	0.03 0.11	0.01	0.01	13% 0%	0.00	0.00	13% 0%	0.96 N/A	0.96 N/A	2 N/A	2 N/A	0.09 N/A	0.19	0.11	0.00	0.00
NC	1600	1601 10% better than Energy Star Dehumidifier ROB (35-45 pints/da		2014	2053	0.16	0.09	0.03	0.03	15%	0.02	0.02	15%	0.19	0.19	0	0	0.52			0.00	0.00
NC NC	1700 1700	1700 Base Furnace Fan - Furnace & CAC 1701 ECM Furnace Fan (variable speed motor) - Cooling	Multi-Family Multi-Family	2014 2014	2053 2053	11.33 6.30	5.81 3.23	0.00 5.04	0.00 5.04	0% 44%	0.00 2.58	0.00 2.58	0% 44%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.79	11.33	5.81	0.00 5.04	0.00 2.58
NC	2000	2000 Base Heat Pump Space Heating (7.7 HSPF)	Multi-Family	2014	2053	17.55	2.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	17.55	2.08	0.00	0.00
NC NC	2000 2000	2016 Duct Insulation (HP heating)	Multi-Family	2014	2053 2053	17.41 17.13	2.07 2.03	0.14 0.28	0.14 0.42	1%	0.02	0.02 0.05	1% 2%	0.02	0.02	0	0	3.57 2.05			0.14 0.28	0.02
NC NC	2000	2021 Self Install Weatherization (HP heating) 2022 Door Weatherization (HP heating)	Multi-Family Multi-Family	2014	2053	16.49	1.96	0.28	1.07	2% 6%	0.03	0.05	2% 6%	0.03	0.03	0	0	1.04			0.28	0.03
NC	2000	2002 Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	Multi-Family	2014	2053	14.97	1.78	1.52	2.59	15%	0.18	0.31	15%	0.12	0.09	1	1	0.61			0.00	0.00
NC NC	2000 2000	2012 Crawlspace insulation (HP heating) 2019 Programmable Thermostat (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	14.93 14.63	1.77 1.74	0.04 0.30	2.63 2.92	15% 17%	0.00	0.31 0.35	15% 17%	0.15 0.14	0.09	1	1	0.50 0.48			0.00	0.00
NC	2000	2020 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Multi-Family	2014	2053	13.96	1.66	0.67	3.59	20%	0.08	0.43	20%	0.21	0.11	2	1	0.30			0.00	0.00
NC NC	2000 2000	2006 Ceiling R-0 to R-38 Insulation (HP heating) 2017 Duct Testing and Sealing (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	12.79 12.41	1.52 1.47	1.18 0.38	4.77 5.15	27% 29%	0.14	0.57 0.61	27% 29%	0.28	0.16	2	1	0.28			0.00	0.00
NC	2000	2007 Ceiling R-0 to R-49 Insulation (HP heating)	Multi-Family	2014	2053	12.37	1.47	0.03	5.18	30%	0.00	0.61	30%	1.52	0.17	13	1	0.25			0.00	0.00
NC NC	2000	2013 Basement insulation R-13 (HP heating)	Multi-Family	2014 2014	2053 2053	12.26 9.60	1.46 1.14	0.11 2.66	5.29 7.95	30% 45%	0.01	0.63 0.94	30% 45%	0.39	0.18 0.26	3	2 2	0.20			0.00	0.00
NC NC	2000	2018 Heat Recovery Ventilators (HP heating) 2023 WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Multi-Family Multi-Family	2014	2053	9.60	1.14	0.23	7.95 8.18	45% 47%	0.32	0.94	45% 47%	0.43	0.26	5	2	0.18			0.00	0.00
NC	2000	2008 Ceiling R-11 to R-38 Insulaton (HP heating)	Multi-Family	2014	2053	9.23	1.09	0.14	8.33	47%	0.02	0.99	47%	0.91	0.29	8	2	0.08			0.00	0.00
NC NC	2000	2009 Ceiling R-11 to R-49 Insulation (HP heating) 2014 Floor R-0 to R-19 Insulation-Batts (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	9.21 9.14	1.09 1.08	0.01 0.08	8.34 8.42	48% 48%	0.00	0.99	48% 48%	2.04 1.28	0.29	17 11	2	0.04			0.00	0.00
NC	2000	2003 Ground Source Heat Pump with Desuperheater (HP heating)	Multi-Family	2014	2053	8.30	0.98	0.84	9.26	53%	0.10	1.10	53%	2.59	0.51	22	4	0.03			0.00	0.00
NC NC	2000 2000	2010 Ceiling R-19 to R-38 Insulation (HP heating) 2011 Ceiling R-19 to R-49 Insulation (HP heating)	Multi-Family Multi-Family	2014	2053 2053	8.28	0.98	0.01	9.27 9.28	53% 53%	0.00	1.10 1.10	53% 53%	1.81 2.27	0.51 0.51	15 19	4	0.04			0.00	0.00
NC	2000	2015 Wall Blow-in R-0 to R-13 Insulation (HP heating)	Multi-Family	2014	2053	8.21	0.97	0.07	9.34	53%	0.00	1.11	53%	4.44	0.54	37	5	0.03			0.00	0.00
NC	2000	2005 Heat Pump Filter Replacement	Multi-Family	2014	2053	8.19	0.97	0.02	9.37	53%	0.00	1.11	53%	3.36	0.54	28	5	0.01			0.00	0.00
NC NC	2000 2100	2004 Heat pump tune up 2100 Base Heat Pump Space Heating - Early Replacement (7.7 HSP	Multi-Family Multi-Family	2014 2014	2053 2053	8.16 4.23	0.97 0.50	0.03	9.39 0.00	54% 0%	0.00	1.11 0.00	54% 0%	5.43 N/A	0.56 N/A	46 N/A	5 N/A	0.01 N/A	4.23	0.50	0.00	0.00
NC	2100	2116 Duct Insulation (HP heating early replacement)	Multi-Family	2014	2053	4.19	0.50	0.03	0.03	1%	0.00	0.00	1%	0.02	0.02	0	0	4.88			0.03	0.00
NC NC	2100 2100	2121 Self Install Weatherization (HP heating early replacement) 2122 Door Weatherization (HP heating early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	4.13 4.01	0.49 0.48	0.07	0.10 0.22	2% 5%	0.01	0.01	2% 5%	0.02	0.02	0	0	2.80 1.05			0.07	0.01
NC	2100			2014	2053	3.64	0.43	0.37	0.59	14%	0.04	0.07	14%	0.08	0.07	1	1	0.84			0.00	0.00
NC NC	2100 2100	2112 Crawlspace insulation (HP heating early replacement) 2119 Programmable Thermostat (HP heating early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	3.59 3.51	0.43 0.42	0.06 0.07	0.64 0.71	15% 17%	0.01 0.01	0.08	15% 17%	0.11 0.10	0.07	1	1	0.69 0.66			0.00	0.00
NC	2100	2120 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating e		2014	2053	3.35	0.42	0.16	0.87	21%	0.01	0.10	21%	0.16	0.09	1	1	0.41			0.00	0.00
NC	2100	2106 Ceiling R-0 to R-38 Insulation (HP heating early replacement)	Multi-Family	2014	2053	3.07	0.36	0.28	1.16	27%	0.03	0.14	27%	0.21	0.12	2	1	0.37			0.00	0.00
NC NC	2100 2100	2117 Duct Testing and Sealing (HP heating early replacement) 2107 Ceiling R-0 to R-49 Insulation (HP heating early replacement)	Multi-Family Multi-Family	2014 2014	2053 2053	2.98 2.97	0.35 0.35	0.09 0.01	1.25 1.26	30% 30%	0.01	0.15 0.15	30% 30%	0.22 1.11	0.13 0.13	2 9	1	0.34 0.07			0.00	0.00
NC	2100	2113 Basement insulation R-13 (HP heating early replacement)	Multi-Family	2014	2053	2.82	0.34	0.15	1.40	33%	0.02	0.17	33%	0.29	0.15	2	1	0.27			0.00	0.00
NC NC	2100 2100	2118 Heat Recovery Ventilators (HP heating early replacement) 2123 WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Multi-Family Multi-Family	2014 2014	2053 2053	2.21	0.26 0.26	0.61 0.05	2.02 2.07	48% 49%	0.07	0.24 0.25	48% 49%	0.33	0.20	3 4	2	0.23			0.00	0.00
NC	2100	2108 Ceiling R-11 to R-38 Insulaton (HP heating early replacement)	Multi-Family	2014	2053	2.13	0.25	0.03	2.10	50%	0.00	0.25	50%	0.70	0.22	6	2	0.11			0.00	0.00
NC NC	2100 2100	2109 Ceiling R-11 to R-49 Insulation (HP heating early replacement) 2114 Floor R-0 to R-19 Insulation-Batts (HP heating early replaceme		2014 2014	2053 2053	2.12	0.25 0.24	0.00 0.10	2.11 2.20	50% 52%	0.00	0.25 0.26	50% 52%	1.56 0.98	0.22	13 8	2 2	0.05 0.08			0.00	0.00
NC	2100	2103 Ground Source Heat Pump with Desuperheater (HP heating ear	Multi-Family	2014	2053	1.84	0.22	0.19	2.39	57%	0.02	0.28	57%	2.07	0.40	17	3	0.03			0.00	0.00
NC	2100	2110 Ceiling R-19 to R-38 Insulation (HP heating early replacement)		2014	2053	1.83	0.22	0.00	2.39	57%	0.00	0.28	57%	1.44	0.40	12	3	0.05			0.00	0.00
NC NC	2100 2100	2111 Ceiling R-19 to R-49 Insulation (HP heating early replacement) 2115 Wall Blow-in R-0 to R-13 Insulation (HP heating early replacement)		2014 2014	2053 2053	1.83 1.82	0.22 0.22	0.00 0.02	2.40 2.41	57% 57%	0.00	0.28 0.29	57% 57%	1.81 3.54	0.40 0.42	15 30	3 4	0.04 0.02			0.00	0.00
NC	2100	2105 Heat Pump Filter Replacement (heating)	Multi-Family	2014	2053	1.81	0.22	0.01	2.42	57%	0.00	0.29	57%	2.68	0.42	23	4	0.02			0.00	0.00
NC NC	2100 2200	2104 Heat pump tune up (heating) 2200 Base Resistance Space Heating (Primary)	Multi-Family Multi-Family	2014 2014	2053 2053	1.81 17.86	0.21 2.12	0.01 0.00	2.42 0.00	57% 0%	0.00	0.29	57% 0%	4.32 N/A	0.43 N/A	36 N/A	4 N/A	0.01 N/A	17.86	2.12	0.00	0.00
NC	2200	2201 Air Source Heat Pump (resistance heating)	Multi-Family	2014	2053	14.10	1.67	3.77	3.77	21%	0.45	0.45	21%	0.01	0.01	0	0	5.51	.7.00	2.12	3.77	0.45
NC NC	2200 2200	2216 Self Install Weatherization 2217 Door Weatherization (resistance heating)	Multi-Family Multi-Family	2014 2014	2053 2053	13.87 13.24	1.65 1.57	0.22 0.63	3.99 4.62	22% 26%	0.03	0.47 0.55	22% 26%	0.02	0.01	0	0	2.72 1.67			0.22 0.63	0.03
NC NC	2200	2217 Door Weatherization (resistance heating) 2214 Programmable Thermostat (resistance heating)	Multi-Family Multi-Family	2014	2053	12.98	1.57	0.63	4.62	26% 27%	0.08	0.55	26% 27%	0.03	0.02	1	0	0.93			0.00	0.08
NC	2200	2209 Crawlspace insulation (resistance heating)	Multi-Family	2014	2053	12.91	1.53	0.07	4.95	28%	0.01	0.59	28%	0.10	0.02	1	0	0.80			0.00	0.00
NC NC	2200 2200	2203 Ceiling R-0 to R-38 Insulation (resistance heating) 2215 Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating)	Multi-Family Multi-Family	2014 2014	2053 2053	11.73 11.20	1.39 1.33	1.18 0.53	6.13 6.66	34% 37%	0.14	0.73 0.79	34% 37%	0.17 0.16	0.05	1 1	0	0.45 0.39			0.00	0.00
NC	2200	2204 Ceiling R-0 to R-49 Insulation (resistance heating)	Multi-Family	2014	2053	11.17	1.33	0.03	6.69	37%	0.00	0.79	37%	1.20	0.06	10	1	0.06			0.00	0.00
NC	2200	2210 Basement insulation R-13 (resistance heating)	Multi-Family	2014	2053	10.93	1.30	0.25	6.94	39%	0.03	0.82	39%	0.27	0.07	2	1	0.29			0.00	0.00

DNV GL H-14 1/5/2015

APPENDIX H

Base Avoided Costs

Part			Existing Construction				Voor	2014														SUPPLY	
Part		ST ADDI	TIVE SUFFLY ANALYSIS				Year	2014										Average	Total			SUPPLY	
The part	Berry		OCUPA .	Duilding			Total	Total	CIAIL	Energy		MIM	Capacity		Energy	Energy	Capacity	Capacity		Pace	Dana	Econom's	Economi-
No.																							
No. 2002 200 Calley B. 1. To Sell Insulation (resultane configure) Mile Fall S. 2014 2014 1. Sell S. 2014 2014 2014 2014 2014 2014 2014 2014																		1					
No. 2006 200 Carly of 1-1 field Personne Content Century 1.00 2.00																							
No. 200 201 Claused Household per per mit Consumer forcing service from 19	NC 2		2211 Floor R-0 to R-19 Insulation-Batts (resistance heating)					0.95		9.84			1.17		0.62			1				0.00	0.00
Mart																							
No. 2006 2006 Cearly of the first plane strong incompany of																							
Mathematical Math	NC 2	200		Multi-Family						9.86	55%		1.17		1.68		14	3	0.05				
No. 2002 2002 Each person plant pl																							
No. 310 3110 Date Interpretation plants 2-2 Servinery 2001 Multi Family 2000 2003 200 0.00 0.00 0.00 0.00 0.00																				0.70	0.08		
No. 10.00																				2.90	0.32		
No. 20. 20. 20. 15. 15. 15. 15. 15. 20.																							
No. 18.00 3.50 3.50 6.60 6.7											-,-			- , -						1.81	0.20		
No. 280 331 LES Dance Chi S. 280 331 LES Dance Chi S. 280 340 Aug. Promise 200 205 0 0.4 0.00																				0.19	0.02		
Main-Faring	NC 3	330		Multi-Family	2020		0.14	0.02	0.05	0.05		0.01	0.01	27%	0.21	0.21			0.42			0.00	0.00
No. 2003 300 300 300 300 300 300 300 300 30																				0.79	0.09		
Main September Main September September Main September Septemb																				0.53	0.06		
No. 935 9852 ESPA (under bridgen) (Sportally) (planty) 2-15 (minus) 2-1																				0.00	0.00		
No. 9720 9730 Bass Plasgenes (Specially) Liphings 22 has been separate property of the propert	NC 3	630	3630 Base Halogen (Specialty) Lighting - 0.5 hrs/day 2020		2020	2053	0.92	0.10		0.00	0%	0.00	0.00	0%	N/A	N/A	N/A		N/A	0.92	0.10	0.00	0.00
No. 2380 9782 LESE Notes Halpons (Specially 2520 Mall-Family 2020 S. 254 0.05 0.00 0.00 0.00 0.00 0.00 0.00 0.					2020												-			2.70	0.41		
No. S.																				3.70	0.41		
No. 300			3830 Base Halogen (Specialty) Lighting - 6 hrs/day 2020	Multi-Family												N/A	N/A	N/A	N/A	2.54	0.28	0.00	
NC 4000 9800 RMR GRAP LATR FEB																				0.00	0.00		
No. 4000 4000 Base Refrigement (Energy Star) Multi-Enarthy 2014 2033 8.0 1.0 1.3 1.3 1.2 1.0 0.0 0.0 0.0 0, 0.0 0.0 0, 0.0 0, 0.0 0.0																				2.88	0.32		
NC 4100 4100 Ease Refrespleament (Energy Blar) Multi-Family 2014 2053 1.43 0.23 0.00 0.00 0.00 0.00 0.00 0.00 0.0	NC 4	000								0.00	0%		0.00	0%						10.53	1.71		
NC 4100 4101 Feature Flashy Registement (Energy Star) Mulli-Family 2014 2053 0.07 0.03 0.00 0.00 0.00 0.00 0.00 0.0																							
NC 4200 4200 Base 2art Performance Recogning "Mulli-Family 2014 2053 0.04 0.01 0.02 0.00 0.00 0.00 0.00 0.00 0.00			·····															N/A		1.43	0.23		
NC 4500 4 201 faz Refrigeriary Responding 1 2014 2035 0.94 0.01 0.12 0.12 0.02 0.02 0.02 0.00 0.00																		N/A		0.17	0.03		
NC 4500 4 501 Freezer (Energy Start) 4051 400 4 501 Freezer (Energy Start) 4051 400 5 Base Enirs (Prejacement (Energy Start) 4051 400 5 Base Enirs (Prejacem			4201 2nd Refrigerator Recycling																				
NC 4600 4 6000 Base Early Replacement Freezer (Engry Slar) Mulfi-Family 2014 2053 0.11 0.02 0.02 0.02 0.00 0.00 0.00 0.00																				0.98	0.16		
NC 4500 4 6901 Feature Flags Peptagoment (Energy Star) Multi-Family 2014 2053 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																				0.24	0.04		
NC 500 500 500 Base Water Heating (dg gil, EF-0.89) Multi-Family 2014 2053 36.03 4.44 1.14 1.14 3.74 0.14 3.76 0.02 0.02 0.0 0.3.26 1.14 0.14 0.14 0.14 0.14 0.14 0.14 0.14		600			2014	2053	0.11		0.14		56%		0.02	56%	0.04	0.04							0.02
NC 5000 500FpW Yamer Landown Multi-Family 2014 2053 34.03 4.24 1.14 1.14 1.14 3% 0.12 2079 0.02 0.02 0.0 0.2 99 1.14 0.14 0.15 0.15 0.05 0.05 0.05 0.05 0.05 0.05																							
NC 5000 5016 Live Flow Showerhead 1.5 Gal/Min 5000 5007 Hot water turndown 1.0 degrees Multi-Family 2014 2053 34.68 4.27 0.19 2.52 7% 0.02 0.31 7% 0.02 0.0 0.0																				37.17	4.58		
NC 5000 5000 Flow later furndown 10 degrees Multi-Family 2014 2053 34.39 4.24 0.26 2.78 7% 0.03 0.34 7% 0.02 0.02 0 0 2.07 50 0.00 0.00 NC 5000 5000 Flow later furndown 20 degrees Multi-Family 2014 2053 34.30 4.23 0.02 2.86 8% 0.00 0.35 8% 0.02 0.02 0 0 2.06 50 0.02 0.00 0.00 0.00 NC 5000 5011 Flaurent Areatres Multi-Family 2014 2053 34.30 4.23 0.02 2.86 8% 0.00 0.35 8% 0.02 0.02 0 0 2.06 50 1.68 0.02 0.00 0.00 NC 5000 5011 Flaurent Areatres Multi-Family 2014 2053 33.59 4.14 0.72 3.88 10% 0.09 0.01 10% 0.00 0.00 0.00 1.68 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																		-					
NC 5000 5000 Hot water turndown 15 degrees Multi-Family 2014 2053 34.33 4.23 0.06 2.86 8% 0.07 0.05 8% 0.02 0.02 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0																							
NC 5000 5010 Hot water turndown 20 degrees Multi-Family 2014 2053 34.30 4.23 0.02 2.86 8% 0.00 0.55 88% 0.02 0.00 0.00 0.00 0.00 0.00 0.00 0.0																							
NC 5000 5010 Fair Water Heater Cenery (FEY) 104 2053 33.59 4.14 0.72 3.88 10.90 0.04 10% 0.04 0.02 0 0 1.68 5 1.28 0.09 0.00 0.00 0.00 0.00 0.00 0.00 0.0																							
NC 500 5005 FeM* Trak Wrap	NC 5				2014			4.14		3.58	10%	0.09	0.44		0.04		0	0	1.68				0.09
NC 500 500 Sold Heat Pump Water Heater - Energy Star Multi-Family 2014 2053 22.0 2.73 4.11 14.97 40% 0.51 1.84 40% 0.20 0.10 2 1 0.37 . 0.00 0.00 0.00 0.00 0.00 0.00 0.																							
NC 500 501 Solar Domestic Water Heating S 2014 Solar Domestic Wate																	-	-					
NC 500 5013 Energy Star Dishwasher (EF=0.72)	NC 5	000		Multi-Family	2014	2053	22.20	2.73	4.11	14.97	40%	0.51	1.84	40%	0.20	0.10	2	-	0.37			0.00	0.00
NC 5100 5100 Base Water Heating Early Replacement to Heat Pump Water H Multi-Family 2014 2053 6.56 0.81 0.00 0.00 0% 0.00 0.00 0% 0.00 0% 0.00 0% 0.00 0.00 0% 0.00 0% 0.00 0.00 0% 0.00 0% 0.00 0.00 0.00 0% 0.00 0.00 0% 0.00 0.00 0% 0.00 0.00 0% 0.00 0.00 0.00 0% 0.00 0.00 0.00 0% 0.00 0.00 0.00 0% 0.00																							
NC 5500 5500 Base Coltabeswasher (MEF=1.28)																				6.56	0.81		
NC 5500 5501 Base Clotheswasher (MEF=1.2f)																				0.00	0.01		
NC 5600 5600 Leg Clarke Dyner (EF=3.01) Multi-Family 2014 2053 12.52 2.12 0.00 0.00 0.00 0.00 0.00 0.00 0.0	NC 5	500	5500 Base Clotheswasher (MEF=1.26)				0.67	0.12			0%			0%					N/A	0.67	0.12		
NC 5600 5601 High Efficiency CD (EF=3.01 w/moisture sensor) Multi-Family 2014 2053 10.22 1.73 2.30 2.30 18% 0.39 18% 0.39 18% 0.30 0.30 0.0 0.22 1.25 2.00 0.39 0.39 0.39 0.30 0.30 0.30 0.30 0																				12.52	2.12		
NC 5700 5700 Base Dishwasher (EF=0.65) Multi-Family 2014 2053 2.92 0.48 0.00 0.00 0.00 0.00 0.00 0.00 0.00																				12.32	2.12		
NC 600 600 Base Single Speed Pool Pump (RET) Multi-Family 2014 2053 2.82 0.46 0.10 0.00 0.00 0.00 0.00 0.00 0.00 0.0	NC 5	600	5601 Heat Pump Dryer	Multi-Family	2014	2053	5.11	0.86	5.11	7.41	59%	0.86	1.25	59%	0.51	0.36	3	2	0.14			0.00	0.00
NC 6000 6000 Base Single Speed Pool Pump (RET) Multi-Family 2014 2053 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																				2.92	0.48		
NC 7000 7000 Base Plasma TV Multi-Family 2014 2053 0.64 0.09 0.00 0.00 0.00 0.00 0.00 0.00 0.0																				0.00	0.00		
NC 7000 7001 Energy Star Plasma TV Multi-Family 2014 2053 0.64 0.09 0.06 0.06 9% 0.01 0.01 9% 0.01 0.01 0.0 0 5.87 0.06 0.01 0.01 0.07 0.00 0.00 0.00 0.00 0.00	NC 7										0%												
NC 7100 7100 Base LCD TV Multi-Family 2014 2053 2.10 0.30 0.00 0.00 0.00 0.00 0.00 0.00 0											9%						0	0	5.87				
NC 7100 7101 Energy Star LCD TV Multi-Family 2014 2053 1.34 0.19 0.77 0.77 36% 0.11 0.11 36% 0.00 0.00 0 0 1.257 0.77 0.11 NC 7100 7102 Plug Load Controls - Smart Power Strip (base LCD TV) Multi-Family 2014 2053 1.29 0.19 0.05 0.82 39% 0.01 0.12 39% 0.00 0.00 0 0 0 12.57 0.07 0.11 0.02 0.00 0.00 0.00 0.00 0.00 0.00																				2.10	0.20		
NC 7100 7102 Plug Load Controls - Smart Power Strip (base LCD TV) Multi-Family 2014 2053 1.29 0.19 0.05 0.82 39% 0.01 0.12 39% 3.08 0.20 21 1 0.02 0.00 0.00 0.00 0.00 0.00																				2.10	0.30		
NC 7200 7202 Plug Load Controls - Smart Power Strip (base CRT TV) Multi-Family 2014 2053 0.57 0.08 0.06 0.06 10% 0.01 10% 0.85 0.85 6 6 0.06 0.00 0.00 0.00 0.00 0.00 0.00	NC 7	100																1					
NC 7300 7300 Base Sel-Top Box Multi-Family 2014 2053 2.10 0.30 0.00 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A 2.10 0.30 0.00 0.00 0.00																				0.63	0.09		
																	-	-		2.10	0.30		

DNV GL H-15 1/5/2015

APPENDIX H

Base Avoided Costs

		tric Existing Construction DDITIVE SUPPLY ANALYSIS				Year	2014														SUPPLY	
		DUTTIVE SUPPLY ANALYSIS				rear	2014		Total			Total		Marginal	A.,	Marginal	Augrana	Total			SUPPLI	
Vint	age			Manager	Measure					Doroont			Devenue		Energy	Capacity						
	_								Energy	Percent		Capacity	Percent	Energy	,				_	_		
		Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	
Sgm	t Number	Number Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
NC	7400	7401 Energy Star DVD Player	Multi-Family	2014	2053	0.17	0.02	0.19	0.19	53%	0.03	0.03	53%	0.02	0.02	0	0	3.21			0.19	0.03
NC	7400	7402 Plug Load Controls - Smart Power Strip (base DVD player)	Multi-Family	2014	2053	0.01	0.00	0.15	0.34	96%	0.02	0.05	96%	0.91	0.42	6	3	0.06			0.00	0.00
NC	7500	7500 Base Desktop PC	Multi-Family	2014	2053	3.42	0.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.42	0.45	0.00	0.00
NC	7500	7501 Energy Star Desktop PC	Multi-Family	2014	2053	2.98	0.39	0.44	0.44	13%	0.06	0.06	13%	0.00	0.00	0	0	14.98			0.44	0.06
NC	7500	7502 Plug Load Controls - Smart Power Strip (base Desktop PC)	Multi-Family	2014	2053	1.56	0.21	1.42	1.86	54%	0.19	0.25	54%	0.05	0.04	0	0	1.12			1.42	0.19
NC	7600	7600 Base Laptop PC	Multi-Family	2014	2053	0.69	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.69	0.09	0.00	0.00
NC	7600	7601 Energy Star Laptop PC	Multi-Family	2014	2053	0.58	0.08	0.12	0.12	17%	0.02	0.02	17%	0.03	0.03	0	0	2.25			0.12	0.02
NC	8000	8000 Base Cooking	Multi-Family	2014	2053	9.65	3.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.65	3.08	0.00	0.00
NC	9000	9000 Base Miscellaneous	Multi-Family	2014	2053	15.81	2.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.81	2.08	0.00	0.00
NC	9900	9900 Base House Use	Multi-Family	2014	2053	205.57	50.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	205.57	50.90	0.00	0.00
NC	9900	9901 Indirect Feedback	Multi-Family	2014	2053	202.51	50.15	3.05	3.05	1%	0.76	0.76	1%	0.03	0.03	0	0	1.62			3.05	0.76
NC	9900	9902 Direct Feedback	Multi-Family	2014	2053	193.36	47.88	9.16	12.21	6%	2.27	3.02	6%	0.09	0.07	0	0	0.67			0.00	0.00

APPENDIX H

Base Avoided Costs

	SSYST AD	ric New Cons	truction LY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY	
					Measure	Measure	9			Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource				
	Base	Measure		Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic I	Economic
Sgmt	Number	Number	Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA	100	100	Base Code Home - IECC 2006	Single Family	2013	2054	242.08	59.94	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	242.1	59.94	0.00	0.00
VA	100	101	Energy Star Home	Single Family	2013	2054	188.72	55.15	53.35	53.35	22%	4.80	4.80	8%	0.06	0.06	1	1	1.14			53.35	4.80
VA	100	100	Base Code Home - IECC 2006	Multi-Family	2013	2054	39.65	9.82	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	39.6	9.82	0.00	0.00
VA	100	101	Energy Star Home	Multi-Family	2013	2054	30.91	9.03	8.74	8.74	22%	0.79	0.79	8%	0.06	0.06	1	1	1.33			8.74	0.79
NC	100	100	Base Code Home - IECC 2006	Single Family	2013	2054	13.31	3.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.3	3.30	0.00	0.00
NC	100	101	Energy Star Home	Single Family	2013	2054	10.38	3.03	2.93	2.93	22%	0.26	0.26	8%	0.06	0.06	1	1	1.29			2.93	0.26
NC	100	100	Base Code Home - IECC 2006	Multi-Family	2013	2054	1.98	0.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.0	0.49	0.00	0.00
NC	100	101	Energy Star Home	Multi-Family	2013	2054	1.55	0.45	0.44	0.44	22%	0.04	0.04	8%	0.05	0.05	1	1	1.37			0.44	0.04

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint									Total			Total		Marginal	Average	Marginal						
	Base	Measure	Building	Measure Start	Measure	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	Economic
		Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA VA	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1036 Lighting Control Tuneup (base 4L4'T8), 2020	Office Office	2020 2020	2054	1,085.70		0.00 8.43	0.00 8.43	0% 1%	0.00 0.78	0.00 0.78	0% 0%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.72	1,085.70	202.10	0.00 8.43	0.00 0.78
VA	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Office	2020	2054	996.47	189.29	80.81	89.24	8%	12.03	12.82	6%	0.01	0.01	0	0	6.12			80.81	12.03
VA VA	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office Office	2020 2020	2054 2054	894.97 781.10	170.39 149.20	101.49 113.87	190.73 304.60	18% 28%	18.89 21.20	31.71 52.91	16% 26%	0.02	0.02 0.02	0	0	3.41 1.64			101.49 113.87	18.89 21.20
VA	1030	1032 ROB 4L4 Low Walt High Performance 18 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	2020	2054	723.19	146.50	57.91	362.51	33%	21.20	55.60	28%	0.04	0.02	1	0	1.07			57.91	2.70
VA	1030	1034 ROB 4L4' LED Tube, 2020	Office	2020	2054	606.67	124.81	116.53	479.03	44%	21.69	77.29	38%	0.24	0.08	1	0	0.31			0.00	0.00
VA VA	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Office Office	2020 2020	2054 2054	554.88 18.36	115.17 3.42	51.79 0.00	530.82 0.00	49% 0%	9.64 0.00	86.93 0.00	43% 0%	0.20 N/A	0.09 N/A	1 N/A	1 N/A	0.37 N/A	18.36	3.42	0.00	0.00
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Office	2020	2054	18.21	3.42	0.00	0.00	1%	0.00	0.00	0%	0.01	0.01	0	0	3.90	10.30	3.42	0.00	0.01
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Office	2020	2054	16.84	3.20	1.37	1.51	8%	0.20	0.22	6%	0.02	0.02	0	0	3.56			1.37	0.20
VA VA	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Office Office	2020 2020	2054 2054	15.09 13.17	2.87 2.52	1.75 1.92	3.26 5.18	18% 28%	0.33 0.36	0.54 0.90	16% 26%	0.02 0.05	0.02 0.03	0	0	2.69 1.29			1.75 1.92	0.33 0.36
VA	1130	1134 ROB 2L4' LED Tube, 2020	Office	2020	2054	12.54	2.40	0.64	5.82	32%	0.12	1.02	30%	0.18	0.05	1	0	0.41			0.00	0.00
VA	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Office	2020	2054	11.61	2.35	0.93	6.75	37%	0.04	1.06	31%	0.10	0.06	2	0	0.57			0.00	0.00
VA VA	1130 1200	1135 LED Troffer (base 2L4'T8), 2020 1200 Base Other Fluorescent Fixture	Office Office	2020 2014	2054 2054	10.62 39.84	2.17 7.42	0.99	7.74 0.00	42% 0%	0.18	1.25 0.00	36% 0%	0.25 N/A	0.08 N/A	1 N/A	0 N/A	0.30 N/A	39.84	7.42	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Office	2014	2054	37.93	7.24	1.90	1.90	5%	0.18	0.18	2%	0.00	0.00	0	0	18.89	33.04	7.42	1.90	0.18
VA	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	2014	2054	35.09	6.81	2.85	4.75	12%	0.42	0.60	8%	0.03	0.02	0	0	2.75			2.85	0.42
VA VA	1200 1200	1201 ROB High Performance T8 (base other fluorescent) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Office Office	2014 2014	2054 2054	31.44 27.24	6.14 5.94	3.65 4.19	8.40 12.59	21% 32%	0.68	1.28 1.48	17% 20%	0.08	0.04 0.06	0 2	0	0.81 0.59			0.00	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Office	2014	2054	23.78	5.30	3.47	16.06	40%	0.65	2.12	29%	0.19	0.09	1	1	0.34			0.00	0.00
VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Office	2020	2054	368.56	68.61	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	368.56	68.61	0.00	0.00
VA VA	1330 1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Office Office	2020 2020	2054 2054	88.80 132.68	16.53 24.70	279.76 0.00	279.76 0.00	76% 0%	52.08 0.00	52.08 0.00	76% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	16.88 N/A	132.68	24.70	279.76 0.00	52.08 0.00
VA	1430	1432 LEDs (base incandescent A-line 72W) 2020	Office	2020	2054	34.53	6.43	98.15	98.15	74%	18.27	18.27	74%	0.00	0.00	0	0	14.15			98.15	18.27
VA	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	2020	2054	97.67	18.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	97.67	18.18	0.00	0.00
VA VA	1530 1630	1532 LEDs (base incandescent A-line 53W) 2020 1630 Base CFL 18W to screw-in replacement 2020	Office Office	2020 2020	2054 2054	33.85 24.08	6.30 4.48	63.82 0.00	63.82 0.00	65% 0%	11.88 0.00	11.88 0.00	65% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	10.19 N/A	24.08	4.48	63.82 0.00	11.88 0.00
VA	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Office	2020	2054	17.41	3.24	6.67	6.67	28%	1.24	1.24	28%	0.05	0.05	0	0	1.22			6.67	1.24
VA	1730	1730 Base CFL 23W to screw-in replacement 2020	Office	2020	2054	30.77	5.73	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	30.77	5.73	0.00	0.00
VA VA	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Office Office	2020 2014	2054 2054	22.77 0.00	4.24 0.00	8.00 0.00	8.00 0.00	26% 0%	1.49 0.00	1.49 0.00	26% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	1.62 N/A	0.00	0.00	8.00 0.00	1.49 0.00
VA	1850	1850 Base CFL Exit Sign	Office	2014	2054	12.87	2.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.87	2.40	0.00	0.00
VA VA	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Office Office	2014 2014	2054 2054	7.23 88.06	1.35 1.21	5.64	5.64 0.00	44% 0%	1.05 0.00	1.05 0.00	44% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	2.61 N/A	88.06	1.21	5.64 0.00	1.05 0.00
VA	1900	1900 Base Outdoor Fight Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Office	2014	2054	77.56	0.73	10.50	10.50	12%	0.48	0.48	39%	0.04	0.04	1	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	1.81	00.00	1.21	10.50	0.48
VA	1900	1902 LED Outdoor Area Lighting	Office	2014	2054	37.32	0.18	40.24	50.74	58%	0.55	1.03	85%	0.08	0.07	6	4	0.77			0.00	0.00
VA VA	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Office Office	2014 2014	2054 2054	26.35 136.14	0.04 95.24	10.97 0.00	61.71 0.00	70% 0%	0.14	1.17 0.00	96% 0%	0.54 N/A	0.16 N/A	44 N/A	8 N/A	0.12 N/A	136.14	95.24	0.00	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Office	2014	2054	135.53	95.24	0.61	0.61	0%	0.42	0.42	0%	0.01	0.01	0	0	19.88	130.14	95.24	0.61	0.42
VA	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Office	2014	2054	123.96	86.72	11.57	12.18	9%	8.09	8.52	9%	0.03	0.03	0	0	4.52			11.57	8.09
VA VA	2000 2000	2005 Chiller Tune Up/Diagnostics 2013 High Efficiency Chiller Motors	Office Office	2014 2014	2054 2054	123.59 123.37	86.60 86.44	0.37 0.22	12.55 12.77	9% 9%	0.13 0.16	8.65 8.80	9% 9%	0.02 0.04	0.03	0	0	3.68 2.95			0.37 0.22	0.13 0.16
VA	2000	2006 VSD for Chiller Pumps and Towers	Office	2014	2054	123.57	86.16	0.22	13.58	10%	0.16	9.09	10%	0.04	0.03	0	0	2.95			0.22	0.16
VA	2000	2003 EMS - Chiller	Office	2014	2054	113.99	84.66	8.56	22.14	16%	1.50	10.58	11%	0.05	0.03	0	0	1.54			8.56	1.50
VA VA	2000 2000	2008 New Economizer - Chiller 2002 Window Film (Standard) - Chiller	Office Office	2014 2014	2054 2054	106.64 106.60	83.37 83.35	7.36 0.03	29.50 29.53	22% 22%	1.29 0.02	11.87 11.89	12% 12%	0.05	0.04 0.04	0	0	1.16 1.06			7.36	1.29
VA	2000	2012 Duct Testing/Sealing - Chiller	Office	2014	2054	86.35	69.18	20.25	49.79	37%	14.17	26.06	27%	0.05	0.08	0	0	0.79			0.00	0.00
VA	2000	2004 Cool Roof - Chiller	Office	2014	2054	86.08	68.99	0.27	50.05	37%	0.19	26.25	28%	0.22	0.09	0	0	0.42			0.00	0.00
VA VA	2000 2100	2011 Duct/Pipe Insulation - Chiller 2100 Base DX Packaged System, EER=10.3, 10 tons	Office Office	2014 2014	2054 2054	85.82 617.70	68.81 432.16	0.27 0.00	50.32 0.00	37% 0%	0.19 0.00	26.44 0.00	28% 0%	1.87 N/A	0.09 N/A	3 N/A	0 N/A	0.05 N/A	617.70	432.16	0.00	0.00
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons	Office	2014	2054	475.63	332.76	142.07	142.07	23%	99.40	99.40	23%	0.02	0.02	0	0	4.76	017.70	432.10	142.07	99.40
VA	2100 2100	2111 Economizer Repair - DX	Office Office	2014 2014	2054 2054	454.22 446.47	310.29 308.93	21.40 7.76	163.48	26% 28%	22.47	121.87 123.23	28% 29%	0.05 0.06	0.03	0	0	1.70 0.98			21.40	22.47 0.00
VA VA	2100 2100	2108 Optimize Controls - DX 2115 Window Film (Standard) - DX	Office	2014 2014	2054 2054	446.47 437.24	308.93 302.47	7.76 9.23	171.23 180.46	28% 29%	1.36 6.46	123.23 129.68	29% 30%	0.06 0.10	0.03	0	0	0.98 0.95			0.00	0.00
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Office	2014	2054	436.45	302.20	0.79	181.25	29%	0.28	129.96	30%	0.09	0.03	0	Ö	0.87			0.00	0.00
VA VA	2100 2100	2109 Economizer - DX	Office	2014 2014	2054 2054	388.46 364.84	293.81	47.98 23.62	229.24	37% 41%	8.39 16.52	138.35 154.87	32% 36%	0.07 0.19	0.04 0.05	0	0	0.86			0.00	0.00
VA	2100	2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX	Office Office	2014	2054	357.09	277.28 275.93	7.76	252.86 260.61	41%	1.36	154.87	36%	0.19	0.05	0	0	0.59			0.00	0.00
VA	2100	2107 Cool Roof - DX	Office	2014	2054	354.04	273.80	3.05	263.66	43%	2.13	158.36	37%	0.25	0.06	o	ő	0.38			0.00	0.00
VA VA	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office Office	2014 2014	2054	353.96	273.78	0.08 2.29	263.74 266.04	43% 43%	0.01	158.38	37% 37%	0.20	0.06	1	0	0.32			0.00	0.00
VA VA	2100 2200	2114 Duct/Pipe Insulation - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Office	2014 2014	2054 2054	351.66 421.72	272.18 295.04	2.29 0.00	266.04 0.00	43% 0%	1.60 0.00	159.98 0.00	37% 0%	2.07 N/A	0.08 N/A	3 N/A	0 N/A	0.05 N/A	421.72	295.04	0.00	0.00
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	2014	2054	369.56	258.55	52.16	52.16	12%	36.49	36.49	12%	0.02	0.02	0	0	6.66			52.16	36.49
VA	2300 3000	2300 Base PTAC, EER=8.3, 1 ton	Office Office	2014 2014	2054 2054	67.57	47.28 100.92	0.00	0.00	0% 0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	67.57	47.28 100.92	0.00	0.00
VA VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3002 Variable Speed Drive Control. 5 HP	Office	2014	2054	334.29 268.04	100.92 95.92	66.25	0.00 66.25	20%	0.00 5.00	0.00 5.00	0% 5%	N/A 0.01	0.01	N/A 0	N/A 0	N/A 4.89	334.29	100.92	0.00 66.25	0.00 5.00
VA	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Office	2014	2054	263.67	94.60	4.36	70.62	21%	1.32	6.32	6%	0.02	0.01	Ō	ō	3.79			4.36	1.32
VA VA	3000 3100	3003 Demand Controlled Ventilation	Office	2014	2054 2054	249.34 57.92	86.38 17.49	14.34	84.95	25% 0%	8.22 0.00	14.54 0.00	14% 0%	0.60 N/A	0.11 N/A	1 N/A	1 N/A	0.18 N/A	57.92	17.49	0.00	0.00
VA VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3102 Variable Speed Drive Control, 15 HP	Office	2014	2054	57.92 46.44	17.49 16.62	11.48	0.00 11.48	20%	0.00	0.00	0% 5%	0.00	0.00	N/A 0	N/A 0	N/A 17.70	57.92	17.49	0.00 11.48	0.00
VA	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Office	2014	2054	46.16	16.53	0.28	11.76	20%	0.08	0.95	5%	0.01	0.00	ō	ō	8.36			0.28	0.08
VA	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Office	2014	2054	43.11	15.70	3.06	14.81	26%	0.83	1.78	10%	0.02	0.01	0	0	3.70			3.06	0.83

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Measure	Мозента				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base		Economic
Sgmt VA	Number 3100	Number Measure 3103 Air Handler Optimization, 15 HP	Type Office	Year 2014	Year 2054	GWH 38.98	MW 15.39	Savings 4.12	GWH 18.94	Savings 33%	Savings 0.31	MW 2.09	Savings 12%	\$/kWH 0.02	\$/kWH 0.01	\$/kW 0	\$/kW	2.82	GWH	MW	4.12	MW 0.31
VA	3100	3105 Energy Recovery Ventilation (ERV)	Office	2014	2054	38.07	14.87	0.91	19.85	34%	0.52	2.61	15%	0.02	0.01	0	0	0.50			0.00	0.00
VA	3100	3107 Demand Controlled Ventilation	Office	2014	2054	36.00	13.69	2.07	21.92	38%	1.19	3.80	22%	0.72	0.09	.1	0	0.15			0.00	0.00
VA VA	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	Office Office	2014 2014	2054 2054	36.51 33.02	11.02 10.76	0.00 3.49	0.00 3.49	0% 10%	0.00 0.26	0.00 0.26	0% 2%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 3.79	36.51	11.02	0.00 3.49	0.00 0.26
VA	3200	3202 Variable Speed Drive Control, 40 HP	Office	2014	2054	26.48	10.27	6.54	10.04	27%	0.49	0.76	7%	0.02	0.02	0	0	3.18			6.54	0.49
VA	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	Office	2014	2054	26.36	10.23	0.12	10.15	28%	0.04	0.79	7%	0.10	0.02	0	0	0.94			0.00	0.00
VA VA	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Office Office	2014 2014	2054 2054	24.93	9.41	1.43 0.00	11.59	32% 0%	0.82	1.61	15% 0%	0.65 N/A	0.10 N/A	1 N/A	1 N/A	0.16 N/A	0.00	0.00	0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Office	2014	2054	98.08	13.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	98.08	13.75	0.00	0.00
VA	4100	4103 Night covers for display cases (self-contained)	Office	2014	2054	97.41	13.66	0.66	0.66	1%	0.09	0.09	1%	0.00	0.00	0	0	54.69			0.66	0.09
VA VA	4100 4100	4109 Energy-Star Freezer, glass door 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Office Office	2014 2014	2054 2054	97.25 95.47	13.64 13.39	0.16 1.78	0.82 2.61	1% 3%	0.02 0.25	0.12 0.37	1% 3%	0.00	0.00	0	0	27.98 25.64			0.16 1.78	0.02
VA	4100	4107 Energy-Star Freezer, solid door	Office	2014	2054	95.40	13.38	0.07	2.67	3%	0.01	0.37	3%	0.01	0.00	Ō	ō	11.19			0.07	0.01
VA VA	4100	4108 Energy-Star Refrigerator, glass door	Office Office	2014 2014	2054	94.86 94.61	13.30	0.55 0.24	3.22 3.46	3% 4%	0.08	0.45	3% 4%	0.01	0.00	0	0	9.45 9.01			0.55 0.24	0.08
VA	4100 4100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Office	2014	2054 2054	94.61	13.27 13.22	0.24	3.46	4% 4%	0.03	0.49	4% 4%	0.01	0.00	0	0	3.34			0.24	0.03
VA	4100	4112 Reach-in unit occupancy sensors	Office	2014	2054	94.27	13.22	0.01	3.81	4%	0.00	0.53	4%	0.27	0.01	2	0	0.23			0.00	0.00
VA VA	4100 4100	4105 Bi-level LED Case Lighting (self-contained units) 2014 4101 Strip curtains for walk-ins (self-contained)	Office Office	2014 2014	2054 2054	94.25 94.19	13.22 13.21	0.02 0.06	3.83 3.89	4% 4%	0.00 0.01	0.54 0.55	4% 4%	0.31 6.64	0.01	2 47	0	0.19 0.01			0.00	0.00
VA	5000	5000 Base Desktop PC	Office	2014	2054	40.10	5.56	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	40.10	5.56	0.00	0.00
VA	5000	5001 PC Network Power Management Enabling	Office	2014	2054	21.62	4.28	18.48	18.48	46%	1.28	1.28	23%	0.01	0.01	0	0	4.80			18.48	1.28
VA VA	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	Office Office	2014 2014	2054 2054	16.81 3.65	3.61 0.51	4.81 0.00	23.29	58% 0%	0.67	1.95 0.00	35% 0%	0.02 N/A	0.01 N/A	0 N/A	0 N/A	2.37 N/A	2.65	0.51	4.81 0.00	0.67 0.00
VA	5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Office	2014	2054	2.96	0.51	0.69	0.69	19%	0.00	0.00	19%	0.01	0.01	0 0	N/A 0	6.47	3.65	0.51	0.69	0.00
VA	5100	5101 Laptop Network Power Management Enabling	Office	2014	2054	2.90	0.40	0.06	0.75	21%	0.01	0.10	21%	0.99	0.09	7	1	0.05			0.00	0.00
VA VA	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Office Office	2014 2014	2054 2054	8.50 4.89	1.18 0.68	0.00 3.62	0.00 3.62	0% 43%	0.00 0.50	0.00 0.50	0% 43%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 67.43	8.50	1.18	0.00 3.62	0.00 0.50
VA	5200	5201 Energy Star of Better Monitor - CR1 5202 Monitor Power Management Enabling - CRT	Office	2014	2054	4.09	0.63	0.65	4.27	50%	0.50	0.55	45%	0.00	0.00	0	0	5.72			0.65	0.50
VA	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Office	2014	2054	3.90	0.59	0.33	4.60	54%	0.05	0.59	50%	0.11	0.01	1	ō	0.48			0.00	0.00
VA VA	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Office Office	2014 2014	2054 2054	7.61 6.61	1.06 0.92	0.00	0.00	0% 13%	0.00 0.14	0.00 0.14	0% 13%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.01	7.61	1.06	0.00	0.00 0.14
VA	5300	5301 Energy Star of Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Office	2014	2054	6.12	0.92	0.99	1.49	20%	0.14	0.14	16%	0.01	0.01	1	0	0.78			0.99	0.14
VA	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Office	2014	2054	5.64	0.87	0.48	1.97	26%	0.02	0.19	18%	0.18	0.06	5	1	0.26			0.00	0.00
VA VA	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Office Office	2014 2014	2054 2054	13.93 12.54	1.93	0.00 1.38	0.00 1.38	0% 10%	0.00 0.19	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 40.67	13.93	1.93	0.00 1.38	0.00
VA	5400	5401 Energy Star of Better Copier 5402 Copier Power Management Enabling	Office	2014	2054	12.00	1.74	0.54	1.93	14%	0.19	0.19	12%	0.00	0.00	1	0	0.74			0.00	0.00
VA	5500	5500 Base Multifunction	Office	2014	2054	2.37	0.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.37	0.33	0.00	0.00
VA VA	5500 5500	5502 ENERGY STAR Multi-Function Printer 5501 Multifunction Power Management Enabling	Office Office	2014 2014	2054	1.77 1.45	0.25	0.59 0.32	0.59 0.92	25% 39%	0.08 0.02	0.08 0.10	25% 32%	0.01 0.21	0.01 0.08	0	0 1	11.01 0.25			0.59 0.00	0.08
VA	5600	5600 Base Printer	Office	2014	2054	13.79	1.91	0.00	0.92	0%	0.02	0.00	0%	0.21 N/A	N/A	N/A	N/A	0.25 N/A	13.79	1.91	0.00	0.00
VA	5600	5602 ENERGY STAR Printer	Office	2014	2054	9.00	1.25	4.80	4.80	35%	0.67	0.67	35%	0.00	0.00	0	0	50.63			4.80	0.67
VA VA	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Office Office	2014 2014	2054 2054	7.36 72.12	1.13 10.01	1.64 0.00	6.44 0.00	47% 0%	0.11 0.00	0.78	41% 0%	0.04 N/A	0.01 N/A	1 N/A	0 N/A	1.15 N/A	72.12	10.01	1.64 0.00	0.11
VA	5700	5700 Base Bata Center/Server Room 5701 Data Center Improved Operations	Office	2014	2054	64.91	9.01	7.21	7.21	10%	1.00	1.00	10%	0.00	0.00	0	0	144.38	12.12	10.01	7.21	1.00
VA	5700	5702 Data Center Best Practices	Office	2014	2054	56.65	7.86	8.26	15.47	21%	1.15	2.15	21%	0.00	0.00	0	0	58.78			8.26	1.15
VA VA	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Office Office	2014 2014	2054 2054	53.48 82.67	7.42 11.17	3.17 0.00	18.64 0.00	26% 0%	0.44 0.00	2.59 0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	30.49 N/A	82.67	11.17	3.17 0.00	0.44 0.00
VA	6000	6007 Heat Trap	Office	2014	2054	78.39	10.59	4.28	4.28	5%	0.58	0.58	5%	0.01	0.01	0	0	4.76	02.01		4.28	0.58
VA	6000	6002 High Efficiency Water Heater (electric)	Office	2014	2054	76.82	10.38	1.57	5.85	7%	0.21	0.79	7%	0.03	0.02	0	0	2.55			1.57	0.21
VA VA	6000 6000	6004 Tankless Water Heater 6008 Solar Water Heater	Office Office	2014 2014	2054 2054	71.06 33.25	9.60 4.49	5.76 37.80	11.61 49.41	14% 60%	0.78 5.11	1.57 6.67	14% 60%	0.04 0.05	0.03 0.05	0	0	1.82 1.56			5.76 37.80	0.78 5.11
VA	6000	6003 Hot Water Pipe Insulation	Office	2014	2054	32.90	4.44	0.35	49.77	60%	0.05	6.72	60%	0.11	0.05	1	0	0.66			0.00	0.00
VA	6000	6006 Heat Recovery Unit	Office	2014	2054	30.76	4.16	2.14	51.90	63%	0.29	7.01	63%	0.11	0.05	1	0	0.58			0.00	0.00
VA VA	6000 7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Office Office	2014 2014	2054 2054	29.84 15.06	4.03 2.19	0.92	52.83 0.00	64% 0%	0.12	7.14 0.00	64% 0%	0.33 N/A	0.05 N/A	2 N/A	0 N/A	0.22 N/A	15.06	2.19	0.00	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	Office	2014	2054	12.80	2.03	2.26	2.26	15%	0.16	0.16	8%	0.02	0.02	0	0	2.10	.0.00	2.10	2.26	0.16
VA	7000	7002 Vending Misers (Refrigerated glass-front units)	Office	2014	2054	11.57	1.94	1.23	3.49	23%	0.09	0.25	12%	0.05	0.03	1	0	1.14	0.20	0.00	1.23	0.09
VA VA	7100 7100	7100 Base Non-Refrigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	Office Office	2014 2014	2054 2054	0.39	0.06	0.00 0.17	0.00	0% 43%	0.00 0.01	0.00 0.01	0% 21%	N/A 0.41	N/A 0.41	N/A 6	N/A 6	N/A 0.13	0.39	0.06	0.00	0.00
VA	7200	7200 Base Oven	Office	2014	2054	4.43	0.66	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.43	0.66	0.00	0.00
VA	7300	7300 Base Fryer	Office	2014	2054	2.80	0.42	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.80	0.42	0.00	0.00
VA VA	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Office Office	2014 2014	2054 2054	5.82 61.27	0.87	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	5.82 61.27	0.87	0.00	0.00
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	2014	2054	57.82	0.00	3.46	3.46	6%	0.00	0.00	0%	0.02	0.02	N/A	N/A	3.73			3.46	0.00
VA	8100	8100 Base Heating, Other Electric	Office	2014	2054	61.90	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	61.90	0.00	0.00	0.00
VA VA	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Office Office	2014 2014	2054 2054	531.51 531.51	77.37 77.37	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	531.51	77.37	0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Restaurant	2020	2054	14.87	2.94	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.87	2.94	0.00	0.00
VA	1030	1036 Lighting Control Tuneup (base 4L4T8), 2020	Restaurant	2020	2054	14.85	2.93	0.02	0.02	0%	0.00	0.00	0%	0.01	0.01	0	0	6.75			0.02	0.00
VA VA	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Restaurant Restaurant	2020 2020	2054 2054	13.73 12.30	2.76 2.48	1.12 1.43	1.15 2.57	8% 17%	0.18 0.28	0.18 0.46	6% 16%	0.01 0.03	0.01 0.02	0	0	6.11 1.89			1.12 1.43	0.18 0.28
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Restaurant	2020	2054	10.73	2.17	1.56	4.14	28%	0.31	0.77	26%	0.07	0.04	Ō	Ö	0.91			0.00	0.00
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Restaurant	2020	2054	10.58	2.16	0.15	4.29	29%	0.01	0.78	26%	0.13	0.04	3	0	0.44			0.00	0.00

DNV GL H-2 1/5/2015

APPENDIX H

Base Avoided Costs

DSM	ASSYST AD	ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	Э			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
Samt	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic
VA	1030	1034 ROB 4L4' LED Tube, 2020	Restaurant	2020	2054	8.88	1.82	1.71	5.99	40%	0.34	1.11	38%	0.40	0.14	2	1	0.18	OWN		0.00	0.00
VA	1030 1130	1035 LED Troffer (base 4L4'T8), 2020	Restaurant	2020	2054	8.12	1.67	0.76	6.75	45%	0.15	1.26	43%	0.33	0.16	2	1	0.22	00.00	17.43	0.00	0.00
VA VA	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Restaurant Restaurant	2020	2054 2054	88.32 88.18	17.43 17.42	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.22	88.32	17.43	0.00	0.00
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Restaurant	2020	2054	81.51	16.38	6.67	6.81	8%	1.04	1.06	6%	0.02	0.02	0	ō	2.93			6.67	1.04
VA	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Restaurant	2020	2054	73.03 63.74	14.70 12.87	8.48 9.29	15.29	17% 28%	1.67	2.73	16% 26%	0.04	0.03	0	0	1.49			8.48	1.67
VA VA	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	Restaurant Restaurant	2020	2054 2054	63.74	12.87	3.08	24.58 27.66	28% 31%	1.83 0.61	4.57 5.17	26% 30%	0.09 0.32	0.05 0.08	2	0	0.72 0.22			0.00	0.00
VA	1130	1135 LED Troffer (base 2L4'T8), 2020	Restaurant	2020	2054	55.48	11.24	5.18	32.84	37%	1.02	6.20	36%	0.40	0.13	2	1	0.18			0.00	0.00
VA VA	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	Restaurant Restaurant	2020 2014	2054 2054	54.70 0.00	11.20 0.00	0.78 0.00	33.62 0.00	38% 0%	0.04	6.23 0.00	36% 0%	0.26 N/A	0.14 N/A	5 N/A	1 N/A	0.22 N/A	0.00	0.00	0.00	0.00
VA	1200	1330 Base Other Fluorescent Fixture 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Restaurant	2014	2054	73.49	14.51	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	73.49	14.51	0.00	0.00
VA	1330	1332 LEDs (base incandescent flood) 2020	Restaurant	2020	2054	15.60	3.08	57.89	57.89	79%	11.43	11.43	79%	0.01	0.01	0	0	8.69			57.89	11.43
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Restaurant	2020	2054	26.46	5.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	26.46	5.22	0.00	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Restaurant Restaurant	2020	2054 2054	6.09 19.48	1.20 3.84	20.37	20.37 0.00	77% 0%	4.02	4.02 0.00	77% 0%	0.01 N/A	0.01 N/A	0 N/A	N/A	7.31 N/A	19.48	3.84	20.37 0.00	4.02
VA	1530	1532 LEDs (base incandescent A-line 53W) 2020	Restaurant	2020	2054	6.05	1.19	13.43	13.43	69%	2.65	2.65	69%	0.01	0.01	0	0	5.34			13.43	2.65
VA	1630 1630	1630 Base CFL 18W to screw-in replacement 2020	Restaurant	2020	2054	12.55	2.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	12.55	2.48	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Restaurant Restaurant	2020 2020	2054 2054	9.07 16.04	1.79 3.17	3.48 0.00	3.48 0.00	28% 0%	0.69	0.69	28% 0%	0.08 N/A	0.08 N/A	N/A	N/A	0.71 N/A	16.04	3.17	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Restaurant	2020	2054	11.87	2.34	4.17	4.17	26%	0.82	0.82	26%	0.06	0.06	0	0	0.95	10.01		0.00	0.00
VA	1800	1800 BaseMetal Halide, 465W	Restaurant	2014	2054	0.34	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.34	0.07	0.00	0.00
VA VA	1800 1800	1801 T5 (240W) (base metal halide) 1806 Occupancy Sensor, High Bay T5	Restaurant Restaurant	2014 2014	2054 2054	0.22	0.04	0.11 0.01	0.11 0.12	34% 36%	0.02	0.02	34% 34%	0.02 0.04	0.02	0	0	5.32 1.39			0.11 0.01	0.02
VA	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Restaurant	2014	2054	0.20	0.04	0.02	0.12	41%	0.00	0.03	38%	1.06	0.14	7	1	0.07			0.00	0.00
VA	1850	1850 Base CFL Exit Sign	Restaurant	2014	2054	4.21	0.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.21	0.83	0.00	0.00
VA VA	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Restaurant Restaurant	2014 2014	2054 2054	1.75 102.87	0.35 6.81	2.46	2.46 0.00	58% 0%	0.49 0.00	0.49 0.00	58% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.08 N/A	102.87	6.81	2.46 0.00	0.49
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Restaurant	2014	2054	85.98	3.48	16.89	16.89	16%	3.34	3.34	49%	0.07	0.07	0	0	1.27	102.07	0.01	16.89	3.34
VA	1900	1902 LED Outdoor Area Lighting	Restaurant	2014	2054	41.37	0.52	44.61	61.50	60%	2.96	6.29	92%	0.16	0.13	2	1	0.44			0.00	0.00
VA VA	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Restaurant	2014	2054 2054	29.27	-0.20 53.08	12.11	73.60	72%	0.73	7.02	103%	1.02 N/A	0.28 N/A	17 N/A	3 N/A	0.07	04.70	53.08	0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2010 Ceiling/roof Insulation - Chiller	Restaurant Restaurant	2014	2054	84.79 78.62	49.22	6.17	0.00 6.17	0% 7%	3.86	0.00 3.86	0% 7%	0.02	0.02	N/A 0	N/A 0	N/A 7.73	84.79	53.08	0.00 6.17	3.86
VA	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Restaurant	2014	2054	71.91	45.02	6.71	12.88	15%	4.20	8.07	15%	0.02	0.02	0	0	5.22			6.71	4.20
VA	2000	2005 Chiller Tune Up/Diagnostics	Restaurant	2014	2054	71.78	44.98	0.13	13.02	15%	0.04	8.11	15%	0.02	0.02	0	0	4.39			0.13	0.04
VA VA	2000 2000	2003 EMS - Chiller 2012 Duct Testing/Sealing - Chiller	Restaurant Restaurant	2014 2014	2054 2054	65.68 54.07	44.04 36.77	6.09 11.62	19.11 30.73	23% 36%	0.93 7.27	9.04 16.31	17% 31%	0.04 0.11	0.02 0.06	0	0	1.86 0.99			6.09 0.00	0.93
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Restaurant	2014	2054	449.34	281.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	449.34	281.30	0.00	0.00
VA	2100	2113 Ceiling/roof Insulation - DX	Restaurant	2014	2054	449.20	281.22	0.13	0.13	0%	0.08	0.08	0%	0.01	0.01	0	0	8.33			0.13	0.08
VA VA	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2115 Window Film (Standard) - DX	Restaurant Restaurant	2014	2054 2054	345.89 320.80	216.54	103.32 25.09	103.45 128.53	23% 29%	64.68 15.70	64.76 80.47	23% 29%	0.02 0.02	0.02 0.02	0	0	5.90 4.09			103.32 25.09	64.68 15.70
VA	2100	2108 Optimize Controls - DX	Restaurant	2014	2054	315.20	199.98	5.60	134.14	30%	0.86	81.33	29%	0.04	0.02	0	ő	1.25			5.60	0.86
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Restaurant	2014	2054	314.84	199.87	0.36	134.49	30%	0.11	81.44	29%	0.07	0.02	0	0	1.10			0.36	0.11
VA VA	2100 2100	2106 Prog. Thermostat - DX 2112 Duct Testing/Sealing - DX	Restaurant Restaurant	2014 2014	2054 2054	307.83 290.41	198.79 187.88	7.01 17.42	141.50 158.93	31% 35%	1.07 10.91	82.51 93.42	29% 33%	0.06 0.13	0.02 0.03	0	0	0.92 0.87			0.00	0.00
VA	2100	2111 Economizer Repair - DX	Restaurant	2014	2054	276.94	175.36	13.46	172.39	38%	12.52	105.94	38%	0.12	0.04	0	ō	0.72			0.00	0.00
VA	2100	2107 Cool Roof - DX	Restaurant	2014	2054	268.19	169.88	8.76	181.15	40%	5.48	111.42	40%	0.14	0.05	0	0	0.65			0.00	0.00
VA VA	2100 2100	2109 Economizer - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Restaurant Restaurant	2014	2054 2054	262.70 262.55	169.04 169.01	5.48 0.15	186.63 186.78	42% 42%	0.84 0.02	112.26 112.29	40% 40%	0.15 0.16	0.05 0.05	1	0	0.41 0.40			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Restaurant	2014	2054	259.35	167.01	3.20	189.99	42%	2.00	114.29	41%	1.57	0.07	3	ő	0.06			0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Restaurant	2014	2054	140.83	88.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	140.83	88.17	0.00	0.00
VA VA	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Restaurant Restaurant	2014 2014	2054 2054	123.41 16.99	77.26 10.64	17.42 0.00	17.42 0.00	12% 0%	10.90 0.00	10.90 0.00	12% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	8.27 N/A	16.99	10.64	17.42 0.00	10.90 0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Restaurant	2014	2054	150.38	38.78	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	150.38	38.78	0.00	0.00
VA	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Restaurant	2014	2054	147.78	38.11	2.59	2.59	2%	0.67	0.67	2%	0.11	0.11	0	0	0.78			0.00	0.00
VA VA	3000 3000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Restaurant Restaurant	2014 2014	2054 2054	103.43 89.51	35.29 28.28	44.35 13.92	46.94 60.86	31% 40%	2.82 7.01	3.49 10.50	9% 27%	0.08 0.85	0.09 0.26	1 2	1 2	0.77 0.12			0.00	0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	4000 4100	4000 Base Built-Up Refrigeration System 4100 Base Self-Contained Refrigeration	Restaurant Restaurant	2014 2014	2054 2054	0.00 637.81	0.00 95.50	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 637.81	0.00 95.50	0.00	0.00
VA	4100	4100 Base Self-Contained Reingeration 4103 Night covers for display cases (self-contained)	Restaurant	2014	2054	609.06	95.50	28.75	28.75	5%	4.31	4.31	5%	0.00	0.00	N/A 0	N/A 0	13.77	037.01	95.50	28.75	4.31
VA	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Restaurant	2014	2054	600.41	89.90	8.65	37.40	6%	1.29	5.60	6%	0.01	0.00	0	ō	8.57			8.65	1.29
VA	4100	4109 Energy-Star Freezer, glass door	Restaurant	2014	2054	590.83	88.47	9.58	46.98	7%	1.43	7.03	7%	0.01	0.01	0	0	7.58			9.58	1.43
VA VA	4100 4100	4107 Energy-Star Freezer, solid door 4108 Energy-Star Refrigerator, glass door	Restaurant Restaurant	2014 2014	2054 2054	586.86 582.47	87.87 87.22	3.97 4.39	50.95 55.34	8% 9%	0.60 0.66	7.63 8.29	8% 9%	0.02	0.01 0.01	0	0	3.05 2.49			3.97 4.39	0.60
VA	4100	4106 Energy-Star Refrigerator, solid door	Restaurant	2014	2054	573.01	85.80	9.46	64.80	10%	1.42	9.70	10%	0.03	0.01	0	0	2.43			9.46	1.42
VA	4100	4110 Energy Star Ice Machines	Restaurant	2014	2054	564.41	84.51	8.60	73.40	12%	1.29	10.99	12%	0.07	0.02	0	0	0.88			0.00	0.00
VA VA	4100 4100	4112 Reach-in unit occupancy sensors 4105 Bi-level LED Case Lighting (self-contained units) 2014	Restaurant Restaurant	2014 2014	2054 2054	564.16 563.06	84.48 84.31	0.25	73.65 74.74	12% 12%	0.04 0.16	11.03 11.19	12% 12%	0.29	0.02 0.02	2	0	0.22 0.18			0.00	0.00
VA	4100	4101 Strip curtains for walk-ins (self-contained)	Restaurant	2014	2054	560.87	83.98	2.19	76.93	12%	0.10	11.52	12%	0.34	0.02	3	0	0.14			0.00	0.00
VA	5000	5000 Base Desktop PC	Restaurant	2014	2054	5.69	1.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.69	1.11	0.00	0.00
VA VA	5000 5000	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	Restaurant Restaurant	2014 2014	2054 2054	3.14 2.11	0.86 0.65	2.55 1.03	2.55 3.58	45% 63%	0.25 0.20	0.25 0.46	23% 41%	0.02	0.02	0	0	2.69 1.36			2.55 1.03	0.25
٧A	5000	3002 Energy Star of Detter PO	Nesiauidill	2014	2004	2.11	0.03	1.03	3.50	03/6	0.20	0.40	41/0	0.04	0.03	U	U	1.30			1.03	0.20

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	9			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
	Base	Measure Number Measure	Building	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base	Economic GWH	Economic MW
VA	Number 5100	5100 Base Laptop PC	Type Restaurant	2014	2054	0.23	0.05	0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	N/A	\$/kWH N/A	N/A	N/A	N/A	0.23	0.05	0.00	0.00
VA	5100	5102 Energy Star or Better Laptop	Restaurant	2014	2054	0.19	0.04	0.04	0.04	19%	0.01	0.01	19%	0.01	0.01	0	0	3.80			0.04	0.01
VA VA	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Restaurant Restaurant	2014	2054 2054	0.19	0.04	0.00	0.05	21% 0%	0.00	0.01 0.00	21% 0%	1.77 N/A	0.16 N/A	9 N/A	1 N/A	0.03 N/A	3.04	0.59	0.00	0.00
VA	5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Restaurant	2014	2054	1.33	0.35	1.71	1.71	56%	0.33	0.00	56%	0.00	0.00	0	0	30.23	3.04	0.55	1.71	0.33
VA	5200	5202 Monitor Power Management Enabling - CRT	Restaurant	2014	2054	1.01	0.23	0.33	2.03	67%	0.03	0.37	62%	0.03	0.01	0	0	1.97			0.33	0.03
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Restaurant Restaurant	2014 2014	2054 2054	0.93 1.27	0.21 0.25	0.08	2.11 0.00	69% 0%	0.02	0.38	64% 0%	0.30 N/A	0.02 N/A	2 N/A	0 N/A	0.19 N/A	1.27	0.25	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Restaurant	2014	2054	1.02	0.20	0.25	0.25	20%	0.05	0.05	20%	0.01	0.01	0	0	4.32	1.27	0.25	0.25	0.05
VA	5300	5302 Monitor Power Management Enabling - LCD	Restaurant	2014	2054	0.93	0.19	0.09	0.34	27%	0.01	0.06	24%	0.13	0.04	1	0	0.39			0.00	0.00
VA VA	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Restaurant Restaurant	2014 2014	2054 2054	0.86 2.37	0.19	0.07	0.41	32% 0%	0.00	0.06	25% 0%	0.36 N/A	0.10 N/A	7 N/A	1 N/A	0.13 N/A	2.37	0.46	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Restaurant	2014	2054	2.02	0.39	0.35	0.35	15%	0.07	0.07	15%	0.00	0.00	0	0	22.54	2.57	0.40	0.35	0.07
VA	5400	5402 Copier Power Management Enabling	Restaurant	2014	2054	1.83	0.38	0.19	0.54	23%	0.02	0.09	19%	0.15	0.05	1	0	0.36			0.00	0.00
VA VA	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Printer	Restaurant Restaurant	2014 2014	2054 2054	0.90	0.18	0.00 0.23	0.00 0.23	0% 25%	0.00 0.04	0.00 0.04	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.45	0.90	0.18	0.00 0.23	0.00
VA	5500	5501 Multifunction Power Management Enabling	Restaurant	2014	2054	0.43	0.11	0.24	0.47	52%	0.02	0.07	39%	0.56	0.29	6	2	0.09			0.00	0.00
VA	5600	5600 Base Printer	Restaurant	2014	2054	1.03	0.20	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.03	0.20	0.00	0.00
VA VA	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Restaurant Restaurant	2014	2054 2054	0.67	0.13	0.36 0.24	0.36 0.60	35% 58%	0.07 0.02	0.07	35% 47%	0.00 0.12	0.00 0.05	0	0	29.66 0.43			0.36	0.07
VA	5700	5700 Base Data Center/Server Room	Restaurant	2014	2054	5.67	1.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.67	1.11	0.00	0.00
VA	5700	5701 Data Center Improved Operations	Restaurant	2014	2054	5.10	0.99	0.57	0.57	10%	0.11	0.11	10%	0.00	0.00	0	0	106.53			0.57	0.11
VA VA	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Restaurant Restaurant	2014 2014	2054 2054	4.45 4.20	0.87	0.65 0.25	1.22 1.46	21% 26%	0.13 0.05	0.24 0.29	21% 26%	0.00	0.00	0	0	43.37 22.49			0.65	0.13 0.05
VA	6000	6000 Base Water Heating	Restaurant	2014	2054	61.77	10.42	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	61.77	10.42	0.00	0.00
VA	6000	6007 Heat Trap	Restaurant	2014	2054	58.57	9.88	3.20	3.20	5%	0.54	0.54	5%	0.01	0.01	0	0	10.74			3.20	0.54
VA VA	6000 6000	6002 High Efficiency Water Heater (electric) 6006 Heat Recovery Unit	Restaurant Restaurant	2014 2014	2054 2054	57.40 27.55	9.69 4.65	1.17 29.85	4.37 34.22	7% 55%	0.20 5.04	0.74 5.77	7% 55%	0.01 0.01	0.01 0.01	0	0	5.79 5.64			1.17 29.85	0.20 5.04
VA	6000	6004 Tankless Water Heater	Restaurant	2014	2054	25.48	4.30	2.07	36.28	59%	0.35	6.12	59%	0.04	0.01	0	0	1.98			2.07	0.35
VA	6000	6008 Solar Water Heater	Restaurant	2014	2054	21.92	3.70	3.57	39.85	65%	0.60	6.72	65%	0.05	0.02	0	0	1.70			3.57	0.60
VA VA	6000 6000	6003 Hot Water Pipe Insulation 6001 Demand controlled circulating systems	Restaurant Restaurant	2014	2054 2054	21.58 20.77	3.64	0.33	40.18 40.99	65% 66%	0.06 0.14	6.78 6.92	65% 66%	0.06	0.02 0.02	0	0	1.32 0.42			0.33	0.06
VA	7000	7000 Base Refrigerated Vending Machines	Restaurant	2014	2054	4.13	0.81	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.13	0.81	0.00	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	Restaurant	2014	2054	3.46	0.74	0.66	0.66	16%	0.07	0.07	8%	0.03	0.03	0	0	2.02			0.66	0.07
VA VA	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Restaurant Restaurant	2014 2014	2054 2054	3.10 0.06	0.71	0.36 0.00	1.03 0.00	25% 0%	0.04	0.10 0.00	12% 0%	0.05 N/A	0.03 N/A	0 N/A	0 N/A	1.11 N/A	0.06	0.01	0.36 0.00	0.04
VA	7100	7101 Vending Misers (Non-Refrigerated)	Restaurant	2014	2054	0.03	0.01	0.03	0.03	46%	0.00	0.00	23%	0.43	0.43	4	4	0.12	0.00	0.01	0.00	0.00
VA	7200	7200 Base Oven	Restaurant	2014	2054	28.48	5.84	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	28.48	5.84	0.00	0.00
VA VA	7200 7300	7201 Convection Oven 7300 Base Fryer	Restaurant Restaurant	2014 2014	2054 2054	21.93 35.82	4.50 7.34	6.55 0.00	6.55 0.00	23% 0%	1.34 0.00	1.34 0.00	23% 0%	0.13 N/A	0.13 N/A	1 N/A	1 N/A	0.54 N/A	35.82	7.34	0.00	0.00
VA	7300	7301 Efficient Fryer	Restaurant	2014	2054	33.52	6.87	2.29	2.29	6%	0.47	0.47	6%	0.43	0.43	2	2	0.17	33.02		0.00	0.00
VA	7400	7400 Base Steamer	Restaurant	2014	2054	45.52	9.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	45.52	9.33	0.00	0.00
VA VA	7400 8000	7401 Efficient Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Restaurant Restaurant	2014 2014	2054 2054	13.91 1.84	2.85 0.00	31.61 0.00	31.61 0.00	69% 0%	6.48 0.00	6.48 0.00	69% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.18 N/A	1.84	0.00	31.61 0.00	6.48 0.00
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	2014	2054	1.74	0.00	0.10	0.10	6%	0.00	0.00	0%	0.05	0.05	N/A	N/A	1.21		0.00	0.10	0.00
VA	8100	8100 Base Heating, Other Electric	Restaurant	2014	2054	5.09	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.09	0.00	0.00	0.00
VA VA	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Restaurant Restaurant	2014 2014	2054	263.18 263.18	51.65 51.65	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	263.18	51.65	0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Retail	2020	2054	894.58	161.88	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	894.58	161.88	0.00	0.00
VA	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Retail	2020	2054	892.49	161.69	2.09	2.09	0%	0.18	0.18	0%	0.01	0.01	0	0	4.53			2.09	0.18
VA VA	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Retail Retail	2020 2020	2054 2054	824.86 739.07	152.00 136.48	67.63 85.79	69.72 155.51	8% 17%	9.69 15.52	9.87 25.40	6% 16%	0.02	0.02	0	0	4.08 2.41			67.63 85.79	9.69 15.52
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Retail	2020	2054	645.04	119.46	94.03	249.54	28%	17.02	42.41	26%	0.05	0.03	0	ō	1.15			94.03	17.02
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Retail Retail	2020	2054	636.01	119.07	9.03 102.48	258.58	29%	0.39	42.81	26%	0.10	0.04	2	0	0.57			0.00	0.00
VA VA	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Retail Retail	2020 2020	2054 2054	533.53 487.98	100.53 92.28	102.48 45.55	361.05 406.60	40% 45%	18.54 8.24	61.35 69.59	38% 43%	0.31 0.26	0.11 0.13	2 1	1 1	0.23 0.28			0.00	0.00
VA	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Retail	2020	2054	178.68	32.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	178.68	32.33	0.00	0.00
VA VA	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Retail Retail	2020 2020	2054 2054	178.26 164.75	32.30 30.36	0.42 13.51	0.42 13.93	0% 8%	0.04 1.94	0.04 1.97	0% 6%	0.02 0.03	0.02	0	0	2.65 2.39			0.42 13.51	0.04 1.94
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Retail	2020	2054	147.62	27.26	17.13	31.06	8% 17%	3.10	5.07	16%	0.03	0.03	0	0	1.90			17.13	3.10
VA	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Retail	2020	2054	128.84	23.86	18.78	49.84	28%	3.40	8.47	26%	0.07	0.04	0	ō	0.91			0.00	0.00
VA	1130	1134 ROB 2L4' LED Tube, 2020	Retail	2020	2054	122.61	22.73	6.23	56.07	31%	1.13	9.60	30%	0.25	0.07	1 2	0	0.29			0.00	0.00
VA VA	1130 1130	1135 LED Troffer (base 2L4'T8), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Retail Retail	2020 2020	2054 2054	112.14 110.57	20.84	10.47 1.57	66.54 68.11	37% 38%	1.89 0.07	11.49 11.56	36% 36%	0.31 0.20	0.11 0.11	5	1 1	0.23 0.28			0.00	0.00
VA	1200	1200 Base Other Fluorescent Fixture	Retail	2014	2054	1.40	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.40	0.25	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Retail	2014	2054	1.38	0.25	0.02	0.02	1%	0.00	0.00	1%	0.01	0.01	0	0	8.19			0.02	0.00
VA VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Retail Retail	2014 2014	2054 2054	1.27 1.14	0.24	0.10 0.13	0.12 0.26	9% 18%	0.01 0.02	0.02 0.04	7% 16%	0.06 0.10	0.05 0.08	0	0	1.22 0.59			0.10 0.00	0.01 0.00
VA	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Retail	2014	2054	1.10	0.21	0.04	0.30	21%	0.00	0.04	17%	0.11	0.08	3	1	0.48			0.00	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Retail	2014	2054	0.96	0.18	0.14	0.44	31%	0.03	0.07	27%	0.22	0.13	1	1	0.27	200 74	04.00	0.00	0.00
VA VA	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Retail Retail	2020 2020	2054 2054	338.74 59.32	61.29 10.73	0.00 279.42	0.00 279.42	0% 82%	0.00 50.56	0.00 50.56	0% 82%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.44	338.74	61.29	0.00 279.42	0.00 50.56
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Retail	2020	2054	121.95	22.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	121.95	22.07	0.00	0.00
VA	1430	1432 LEDs (base incandescent A-line 72W) 2020	Retail	2020	2054	23.23	4.20	98.72	98.72	81%	17.86	17.86	81%	0.01	0.01	0	0	7.97			98.72	17.86

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintag	e			Measure	Measure	9			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
0	Base	Measure Number Measure	Building	Start	End Year	Total	Total MW	GWH	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base MW	Economic GWH	Economic MW
VA	Number 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Type Retail	2020	2054	89.77	16.24	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	N/A	\$/kWH N/A	N/A	N/A	TRC N/A	89.77	16.24	0.00	0.00
VA	1530	1532 LEDs (base incandescent A-line 53W) 2020	Retail	2020	2054	23.51	4.25	66.26	66.26	74%	11.99	11.99	74%	0.01	0.01	0	0	5.92			66.26	11.99
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Retail	2020	2054	99.18	17.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	99.18	17.95	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Retail Retail	2020 2020	2054 2054	71.71 126.73	12.98 22.93	27.47 0.00	27.47 0.00	28% 0%	4.97 0.00	4.97 0.00	28% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	0.94 N/A	126.73	22.93	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Retail	2020	2054	93.78	16.97	32.95	32.95	26%	5.96	5.96	26%	0.05	0.05	0	0	1.25	120.75	22.33	32.95	5.96
VA	1800	1800 BaseMetal Halide, 465W	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Retail Retail	2014 2014	2054 2054	11.37 4.99	2.06 0.90	0.00 6.37	0.00 6.37	0% 56%	0.00 1.15	0.00 1.15	0% 56%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.45	11.37	2.06	0.00 6.37	0.00 1.15
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Retail	2014	2054	182.10	11.91	0.00	0.00	0%	0.00	0.00	0%	0.04 N/A	0.04 N/A	N/A	N/A	1.45 N/A	182.10	11.91	0.00	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Retail	2014	2054	164.09	8.46	18.02	18.02	10%	3.45	3.45	29%	0.05	0.05	0	0	1.82	102.10		18.02	3.45
VA	1900	1902 LED Outdoor Area Lighting	Retail	2014	2054	78.96	2.89	85.13	103.14	57%	5.57	9.02	76%	0.11	0.10	2	1	0.61			0.00	0.00
VA VA	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Retail Retail	2014 2014	2054 2054	55.87 24.24	1.52 20.03	23.09	126.23 0.00	69% 0%	1.37 0.00	10.39 0.00	87% 0%	0.74 N/A	0.22 N/A	12 N/A	3 N/A	0.09 N/A	24.24	20.03	0.00	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Retail	2014	2054	24.24	19.86	0.00	0.00	1%	0.17	0.17	1%	0.03	0.03	0	0	4.91	24.24	20.03	0.00	0.00
VA	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Retail	2014	2054	21.98	18.16	2.05	2.26	9%	1.70	1.87	9%	0.04	0.04	0	0	3.01			2.05	1.70
VA VA	2000 2000	2005 Chiller Tune Up/Diagnostics 2003 FMS - Chiller	Retail Retail	2014 2014	2054 2054	21.83	18.10 17.71	0.15 1.82	2.41 4.23	10% 17%	0.06	1.93 2.32	10% 12%	0.03	0.04	0	0	2.31 0.93			0.15	0.06
VA	2000	2012 Duct Testing/Sealing - Chiller	Retail	2014	2054	20.01 16.21	14.57	3.80	4.23 8.03	33%	3.14	2.32 5.46	27%	0.08	0.06	0	0	0.93			0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Retail	2014	2054	854.18	705.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	854.18	705.93	0.00	0.00
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons	Retail	2014	2054	657.71	543.56	196.46	196.46	23%	162.36	162.36	23%	0.04	0.04	0	0	3.17			196.46	162.36
VA VA	2100 2100	2111 Economizer Repair - DX 2107 Cool Roof - DX	Retail Retail	2014 2014	2054 2054	611.76 584.59	489.86 467.41	45.95 27.18	242.41 269.59	28% 32%	53.70 22.46	216.06 238.52	31% 34%	0.08 0.12	0.05 0.05	0	0	1.13 0.87			45.95 0.00	53.70 0.00
VA	2100	2107 Cool Rool - DX 2108 Optimize Controls - DX	Retail	2014	2054	574.97	465.35	9.61	279.20	32%	2.06	240.58	34%	0.12	0.05	0	0	0.56			0.00	0.00
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Retail	2014	2054	572.65	464.36	2.33	281.53	33%	0.99	241.57	34%	0.15	0.06	Ö	Ö	0.52			0.00	0.00
VA	2100	2109 Economizer - DX	Retail	2014	2054	523.89	453.91	48.76	330.29	39%	10.45	252.01	36%	0.13	0.07	1	0	0.50			0.00	0.00
VA VA	2100 2100	2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX	Retail Retail	2014 2014	2054 2054	492.03 478.43	427.59 424.67	31.85 13.60	362.14 375.74	42% 44%	26.32 2.91	278.34 281.25	39% 40%	0.31 0.18	0.09	0	0	0.41 0.35			0.00	0.00
VA	2100	2115 Window Film (Standard) - DX	Retail	2014	2054	476.68	423.23	1.75	377.50	44%	1.45	282.70	40%	0.18	0.09	o o	0	0.27			0.00	0.00
VA	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Retail	2014	2054	476.48	423.18	0.20	377.70	44%	0.04	282.74	40%	0.29	0.09	1	0	0.23			0.00	0.00
VA VA	2100 2200	2114 Duct/Pipe Insulation - DX	Retail Retail	2014 2014	2054	472.98	420.29	3.50 0.00	381.20	45% 0%	2.89	285.64	40%	3.45 N/A	0.12 N/A	4	0	0.03	047.00	000.47	0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	2014	2054 2054	317.23 278.00	262.17 229.75	39.23	0.00 39.23	12%	32.42	0.00 32.42	0% 12%	0.03	0.03	N/A 0	N/A 0	N/A 4.44	317.23	262.17	39.23	32.42
VA	2300	2300 Base PTAC, EER=8.3, 1 ton	Retail	2014	2054	55.95	46.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	55.95	46.24	0.00	0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Retail	2014	2054	578.78	162.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	578.78	162.16	0.00	0.00
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP	Retail Retail	2014 2014	2054 2054	569.62 403.89	159.59 147.97	9.16 165.73	9.16 174.89	2% 30%	2.57 11.62	2.57 14.18	2% 9%	0.02 0.02	0.02 0.02	0	0	3.79 3.64			9.16 165.73	2.57 11.62
VA	3000	3003 Demand Controlled Ventilation	Retail	2014	2054	361.48	125.40	42.41	217.30	38%	22.57	36.76	23%	1.14	0.02	2	1	0.09			0.00	0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Retail	2014	2054	20.17	5.65	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	20.17	5.65	0.00	0.00
VA VA	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Retail Retail	2014 2014	2054 2054	17.26 15.54	4.92 4.80	2.91 1.73	2.91 4.63	14% 23%	0.73 0.12	0.73 0.85	13% 15%	0.03	0.03	0	0	2.72 2.08			2.91 1.73	0.73
VA	3100	3103 Air Handler Optimization, 15 HP 3102 Variable Speed Drive Control, 15 HP	Retail	2014	2054	11.02	4.80	4.52	9.15	23% 45%	0.12	1.17	21%	0.03	0.03	1	0	0.98			0.00	0.12
VA	3100		Retail	2014	2054	10.99	4.47	0.03	9.18	46%	0.01	1.18	21%	0.20	0.05	1	0	0.44			0.00	0.00
VA	3100		Retail	2014	2054	10.23	4.07	0.75	9.94	49%	0.40	1.58	28%	0.45	0.08	1	0	0.25			0.00	0.00
VA VA	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Retail Retail	2014 2014	2054 2054	9.16 20.17	3.50 5.65	1.07	11.01	55% 0%	0.57	2.15 0.00	38% 0%	1.57 N/A	0.22 N/A	3 N/A	1 N/A	0.07 N/A	20.17	5.65	0.00	0.00
VA	3200	3203 Air Handler Optimization, 40 HP	Retail	2014	2054	18.15	5.51	2.02	2.02	10%	0.14	0.14	3%	0.02	0.02	0	0	2.44	20.17	3.03	2.02	0.14
VA	3200	3202 Variable Speed Drive Control, 40 HP	Retail	2014	2054	12.87	5.14	5.28	7.30	36%	0.37	0.51	9%	0.06	0.05	1	1	1.18			5.28	0.37
VA	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	Retail	2014	2054	12.85	5.13	0.03	7.32	36%	0.01	0.52	9%	0.27	0.05	1 2	1	0.33			0.00	0.00
VA VA	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Retail Retail	2014 2014	2054 2054	11.50 0.00	4.41 0.00	1.35 0.00	8.67 0.00	43% 0%	0.72 0.00	1.24 0.00	22% 0%	1.25 N/A	0.23 N/A	N/A	2 N/A	0.08 N/A	0.00	0.00	0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Retail	2014	2054	466.01	70.84	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	466.01	70.84	0.00	0.00
VA	4100	4103 Night covers for display cases (self-contained)	Retail	2014	2054	457.33	69.52	8.69	8.69	2%	1.32	1.32	2%	0.01	0.01	0	0	5.85			8.69	1.32
VA VA	4100 4100	4109 Energy-Star Freezer, glass door 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Retail Retail	2014 2014	2054 2054	455.44 445.67	69.23 67.75	1.88 9.77	10.57 20.34	2% 4%	0.29 1.49	1.61 3.09	2% 4%	0.04	0.01 0.02	0	0	1.73 1.50			1.88 9.77	0.29 1.49
VA	4100	4107 Energy-Star Freezer, solid door	Retail	2014	2054	444.90	67.63	0.77	21.11	5%	0.12	3.21	5%	0.09	0.02	1	0	0.69			0.00	0.00
VA	4100	4108 Energy-Star Refrigerator, glass door	Retail	2014	2054	437.40	66.49	7.50	28.61	6%	1.14	4.35	6%	0.11	0.05	1	0	0.59			0.00	0.00
VA VA	4100 4100		Retail Retail	2014 2014	2054 2054	436.20 435.01	66.30 66.12	1.21 1.19	29.82 31.00	6% 7%	0.18 0.18	4.53 4.71	6% 7%	0.12 0.28	0.05 0.06	1 2	0	0.54 0.23			0.00	0.00
VA	4100	4112 Reach-in unit occupancy sensors 4110 Energy Star Ice Machines	Retail	2014	2054	435.01	66.00	0.81	31.00	7% 7%	0.18	4.71	7% 7%	0.28	0.06	2	0	0.23			0.00	0.00
VA	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Retail	2014	2054	432.07	65.68	2.14	33.94	7%	0.32	5.16	7%	0.31	0.08	2	1	0.19			0.00	0.00
VA	4100	4101 Strip curtains for walk-ins (self-contained)	Retail	2014	2054	431.63	65.61	0.44	34.38	7%	0.07	5.23	7%	1.93	0.11	13	1	0.03			0.00	0.00
VA VA	5000 5000	5000 Base Desktop PC 5002 Energy Star or Better PC	Retail Retail	2014 2014	2054 2054	21.51 18.25	3.84 3.26	0.00 3.26	0.00 3.26	0% 15%	0.00 0.58	0.00 0.58	0% 15%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 3.72	21.51	3.84	0.00 3.26	0.00 0.58
VA	5000	5002 Energy Star of Better PC 5001 PC Network Power Management Enabling	Retail	2014	2054	10.23	2.51	8.22	11.48	53%	0.56	1.33	35%	0.01	0.01	0	0	2.93			8.22	0.75
VA	5100	5100 Base Laptop PC	Retail	2014	2054	0.89	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.89	0.16	0.00	0.00
VA	5100	5102 Energy Star or Better Laptop	Retail	2014	2054	0.72	0.13	0.17	0.17	19%	0.03	0.03	19%	0.01	0.01	0	0	4.83			0.17	0.03
VA VA	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Retail Retail	2014 2014	2054 2054	0.71 4.90	0.13 0.87	0.01 0.00	0.18	21% 0%	0.00	0.03	21% 0%	1.38 N/A	0.12 N/A	8 N/A	1 N/A	0.04 N/A	4.90	0.87	0.00	0.00
VA	5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Retail	2014	2054	2.15	0.38	2.75	2.75	56%	0.49	0.49	56%	0.00	0.00	0	0	38.40		0.01	2.75	0.49
VA	5200	5202 Monitor Power Management Enabling - CRT	Retail	2014	2054	1.80	0.35	0.35	3.10	63%	0.03	0.52	60%	0.02	0.00	0	0	2.95			0.35	0.03
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, I CD	Retail Retail	2014 2014	2054	1.66 3.06	0.33 0.55	0.14 0.00	3.24 0.00	66% 0%	0.03	0.55	63% 0%	0.21 N/A	0.01 N/A	1 N/A	0 N/A	0.26 N/A	3.06	0.55	0.00	0.00
VA	5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Retail	2014	2054	2.64	0.55	0.00	0.00	14%	0.00	0.00	14%	0.01	0.01	N/A 0	N/A 0	5.92	3.00	0.33	0.00	0.00
																-	-					

APPENDIX H

Base Avoided Costs

		c Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	e Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
		Measure Number Measure	Building	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH	MW Savings	Savings	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic MW
VA	Number 5300	5302 Monitor Power Management Enabling - LCD	Type Retail	2014	2054	2.54	0.46	0.10	0.53	Savings 17%	0.01	0.09	Savings 16%	0.09	0.02	\$/KVV	0	0.58	GWH	IVIVV	0.00	0.00
VA	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Retail	2014	2054	2.34	0.45	0.19	0.72	24%	0.01	0.09	17%	0.25	0.08	5	1	0.19			0.00	0.00
VA VA	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Retail Retail	2014 2014	2054 2054	10.62 9.10	1.90 1.62	0.00 1.52	0.00 1.52	0% 14%	0.00 0.27	0.00 0.27	0% 14%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 28.81	10.62	1.90	0.00 1.52	0.00 0.27
VA	5400	5402 Copier Power Management Enabling	Retail	2014	2054	8.67	1.58	0.43	1.95	18%	0.04	0.27	16%	0.00	0.00	1	0	0.50			0.00	0.00
VA	5500	5500 Base Multifunction	Retail	2014	2054	1.62	0.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.62	0.29	0.00	0.00
VA VA	5500 5500	5502 ENERGY STAR Multi-Function Printer 5501 Multifunction Power Management Enabling	Retail Retail	2014 2014	2054 2054	1.22 1.05	0.22	0.41 0.17	0.41 0.58	25% 36%	0.07 0.02	0.07 0.09	25% 30%	0.01 0.28	0.01 0.09	0	0	8.20 0.19			0.41 0.00	0.07
VA	5600	5600 Base Printer	Retail	2014	2054	4.65	0.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.65	0.83	0.00	0.00
VA	5600	5602 ENERGY STAR Printer	Retail	2014	2054	3.03	0.54	1.62	1.62	35%	0.29	0.29	35%	0.00	0.00	0	0	37.69			1.62	0.29
VA VA	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Retail Retail	2014 2014	2054 2054	2.60 16.72	0.50 2.98	0.43 0.00	2.04 0.00	44% 0%	0.04	0.33	39% 0%	0.06 N/A	0.01 N/A	1 N/A	0 N/A	0.87 N/A	16.72	2.98	0.00	0.00
VA	5700	5701 Data Center Improved Operations	Retail	2014	2054	15.05	2.69	1.67	1.67	10%	0.30	0.30	10%	0.00	0.00	0	0	120.08	10.72	2.50	1.67	0.30
VA	5700	5702 Data Center Best Practices	Retail	2014	2054	13.13	2.34	1.91	3.59	21%	0.34	0.64	21%	0.00	0.00	0	0	48.89			1.91	0.34
VA VA	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Retail Retail	2014 2014	2054 2054	12.40 88.87	2.21 14.28	0.74	4.32 0.00	26% 0%	0.13	0.77	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	25.35 N/A	88.87	14.28	0.74	0.13
VA	6000	6007 Heat Trap	Retail	2014	2054	84.27	13.54	4.60	4.60	5%	0.74	0.74	5%	0.02	0.02	0	0	3.20			4.60	0.74
VA VA	6000 6000	6002 High Efficiency Water Heater (electric)	Retail Retail	2014	2054 2054	82.61 76.41	13.27 12.28	1.66 6.20	6.26 12.46	7% 14%	0.27 1.00	1.01	7% 14%	0.04	0.03	0	0	1.72			1.66 6.20	1.00
VA VA	6000	6004 Tankless Water Heater 6008 Solar Water Heater	Retail	2014	2054	76.41 74.27	12.28	6.20 2.14	12.46 14.60	14% 16%	0.34	2.00	14% 16%	0.07	0.05	0	0	1.23			6.20 2.14	1.00 0.34
VA	6000	6003 Hot Water Pipe Insulation	Retail	2014	2054	73.05	11.74	1.22	15.82	18%	0.20	2.54	18%	0.08	0.05	0	0	0.92			0.00	0.00
VA VA	6000 6000	6006 Heat Recovery Unit	Retail Retail	2014 2014	2054 2054	70.68 69.59	11.35 11.18	2.37 1.09	18.19 19.28	20% 22%	0.38 0.17	2.92 3.10	20% 22%	0.09 0.13	0.06	1	0	0.72			0.00	0.00
VA	7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Retail	2014	2054	22.16	3.96	0.00	0.00	0%	0.17	0.00	0%	0.13 N/A	0.06 N/A	1 N/A	N/A	0.57 N/A	22.16	3.96	0.00	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	Retail	2014	2054	19.04	3.68	3.13	3.13	14%	0.28	0.28	7%	0.02	0.02	0	0	2.19	LL. 10	0.00	3.13	0.28
VA	7000	7002 Vending Misers (Refrigerated glass-front units)	Retail	2014	2054	17.35	3.53	1.69	4.82	22%	0.15	0.43	11%	0.04	0.03	0	0	1.19			1.69	0.15
VA VA	7100 7100	7100 Base Non-Refrigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	Retail Retail	2014 2014	2054 2054	0.11	0.02	0.00 0.04	0.00 0.04	0% 40%	0.00	0.00	0% 20%	N/A 0.40	N/A 0.40	N/A 4	N/A 4	N/A 0.13	0.11	0.02	0.00	0.00
VA	7200	7200 Base Oven	Retail	2014	2054	14.10	2.55	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.10	2.55	0.00	0.00
VA	7200	7201 Convection Oven	Retail	2014	2054	10.86	1.96	3.24	3.24	23%	0.59	0.59	23%	0.13	0.13	1	1	0.53	0.50	0.47	0.00	0.00
VA VA	7300 7300	7300 Base Fryer 7301 Efficient Fryer	Retail Retail	2014 2014	2054 2054	2.58 2.41	0.47 0.44	0.00 0.16	0.00 0.16	0% 6%	0.00	0.00	0% 6%	N/A 0.43	N/A 0.43	N/A 2	N/A 2	N/A 0.16	2.58	0.47	0.00	0.00
VA	7400	7400 Base Steamer	Retail	2014	2054	10.12	1.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.12	1.83	0.00	0.00
VA	7400	7401 Efficient Steamer	Retail	2014	2054	3.61	0.65	6.51	6.51	64%	1.18	1.18	64%	0.05	0.05	0	0	1.35			6.51	1.18
VA VA	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail Retail	2014 2014	2054 2054	13.99 13.20	0.00	0.00 0.79	0.00 0.79	0% 6%	0.00	0.00	0% 0%	N/A 0.04	N/A 0.04	N/A N/A	N/A N/A	N/A 1.47	13.99	0.00	0.00 0.79	0.00
VA	8100	8100 Base Heating, Other Electric	Retail	2014	2054	51.10	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	51.10	0.00	0.00	0.00
VA	9500	9500 Base Miscellaneous	Retail	2014		1,389.43		0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A		1,389.43	248.50	0.00	0.00
VA VA	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Retail Grocery	2014 2020	2054 2054	1,389.43	248.50	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	144.92	22.11	0.00	0.00
VA	1030	1036 Lighting Control Tuneup (base 4L4T8), 2020	Grocery	2020	2054	144.77	22.10	0.15	0.15	0%	0.01	0.01	0%	0.01	0.01	0	0	5.90			0.15	0.01
VA	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Grocery	2020	2054	133.68	20.77	11.09	11.24	8%	1.33	1.34	6%	0.01	0.01	0	0	5.17			11.09	1.33
VA VA	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Grocery	2020 2020	2054 2054	119.99 104.72	18.69 16.36	13.69 15.27	24.93 40.20	17% 28%	2.09	3.42 5.75	15% 26%	0.03	0.02	0	0	1.66 0.79			13.69 0.00	2.09
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Grocery	2020	2054	103.17	16.30	1.56	41.76	29%	0.06	5.81	26%	0.10	0.04	3	Ö	0.58			0.00	0.00
VA VA	1030 1030	1034 ROB 4L4' LED Tube, 2020	Grocery	2020 2020	2054 2054	86.54	13.77	16.62 7.39	58.38	40% 45%	2.54 1.13	8.34	38% 43%	0.42	0.15	3	1	0.15			0.00	0.00
VA VA	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Grocery Grocery	2020	2054	79.16 0.51	12.64 0.08	0.00	65.77 0.00	45% 0%	0.00	9.47 0.00	43% 0%	0.35 N/A	0.17 N/A	2 N/A	1 N/A	0.18 N/A	0.51	0.08	0.00	0.00
VA	1130	1136 Lighting Control Tuneup (base 2L4T8), 2020	Grocery	2020	2054	0.51	0.08	0.00	0.00	0%	0.00	0.00	0%	0.01	0.01	0	0	4.93			0.00	0.00
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Grocery	2020	2054	0.47	0.07	0.04	0.04	8%	0.00	0.00	6%	0.02	0.02	0	0	4.32			0.04	0.00
VA VA	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Grocery Grocery	2020	2054 2054	0.42	0.07	0.05	0.09	17% 27%	0.01	0.01	15% 26%	0.04	0.03	0	0	1.31 0.63			0.05	0.01
VA	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Grocery	2020	2054	0.36	0.06	0.01	0.15	29%	0.00	0.02	26%	0.17	0.06	5	0	0.33			0.00	0.00
VA	1130	1134 ROB 2L4' LED Tube, 2020	Grocery	2020	2054	0.35	0.05	0.02	0.16	32%	0.00	0.02	29%	0.34	0.09	2	1	0.18			0.00	0.00
VA VA	1130 1200	1135 LED Troffer (base 2L4T8), 2020 1200 Base Other Fluorescent Fixture	Grocery Grocery	2020 2014	2054 2054	0.32	0.05	0.03	0.19 0.00	38% 0%	0.00	0.03	35% 0%	0.43 N/A	0.14 N/A	3 N/A	1 N/A	0.14 N/A	0.00	0.00	0.00	0.00
VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Grocery	2020	2054	44.35	6.77	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	44.35	6.77	0.00	0.00
VA	1330	1332 LEDs (base incandescent flood) 2020	Grocery	2020	2054	16.64	2.54	27.71	27.71	62%	4.23	4.23	62%	0.00	0.00	0	0	12.47			27.71	4.23
VA VA	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	Grocery Grocery	2020 2020	2054 2054	15.97 6.38	2.44 0.97	0.00 9.59	0.00 9.59	0% 60%	0.00 1.46	0.00 1.46	0% 60%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 10.31	15.97	2.44	0.00 9.59	0.00 1.46
VA	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Grocery	2020	2054	11.75	1.79	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.75	1.79	0.00	0.00
VA	1530	1532 LEDs (base incandescent A-line 53W) 2020	Grocery	2020	2054	5.89	0.90	5.87	5.87	50%	0.90	0.90	50%	0.01	0.01	0	0	6.99			5.87	0.90
VA VA	1630 1630	1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	Grocery Grocery	2020 2020	2054 2054	3.18 2.30	0.48 0.35	0.00 0.88	0.00 0.88	0% 28%	0.00 0.13	0.00 0.13	0% 28%	N/A 0.10	N/A 0.10	N/A 1	N/A 1	N/A 0.58	3.18	0.48	0.00	0.00
VA	1730	1730 Base CFL 23W to screw-in replacement 2020	Grocery	2020	2054	4.06	0.62	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.06	0.62	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Grocery	2020	2054	3.01	0.46	1.06	1.06	26%	0.16	0.16	26%	0.07	0.07	0	0	0.77			0.00	0.00
VA VA	1800 1800	1800 BaseMetal Halide, 465W 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Grocery Grocery	2014 2014	2054 2054	7.60 7.02	1.16 1.09	0.00 0.58	0.00 0.58	0% 8%	0.00 0.07	0.00 0.07	0% 6%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 11.91	7.60	1.16	0.00 0.58	0.00 0.07
VA	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1801 T5 (240W) (base metal halide)	Grocery	2014	2054	4.64	0.73	2.37	2.95	39%	0.07	0.07	37%	0.01	0.01	0	0	5.89			2.37	0.07
VA	1800	1806 Occupancy Sensor, High Bay T5	Grocery	2014	2054	4.49	0.72	0.16	3.11	41%	0.01	0.44	38%	0.03	0.01	1	ō	1.67			0.16	0.01
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Grocery Grocery	2014 2014	2054 2054	0.30	0.05	0.00 0.01	0.00 0.01	0% 2%	0.00	0.00	0% 2%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.10	0.30	0.05	0.00 0.01	0.00
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Grocery	2014	2054	2.31	0.04	0.00	0.00	0%	0.00	0.00	0%	0.03 N/A	N/A	N/A	N/A	2.10 N/A	2.31	0.06	0.00	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Grocery	2014	2054	2.05	0.04	0.26	0.26	11%	0.02	0.02	36%	0.08	0.08	1	1	0.93			0.00	0.00

APPENDIX H

Base Avoided Costs

			Existing Construction IVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
	intage	7100111								Total			Total		Marginal	Average	Marginal	Average	Total			00	
	Base	Me	easure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity	Resource Cost Test	Base	Base	Economic	Economic
	gmt Numb		ımber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
V.		900 900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Grocery Grocery	2014 2014	2054 2054	0.99	0.01	1.07 0.29	1.33 1.62	57% 70%	0.03 0.01	0.05 0.05	82% 94%	0.17 1.12	0.15 0.33	7 52	4 10	0.38			0.00	0.00
V	A 2	000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Grocery	2014	2054	4.02	2.62	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.02	2.62	0.00	0.00
V.		000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	Grocery Grocery	2014 2014	2054 2054	3.67 3.67	2.40 2.40	0.34 0.01	0.34 0.35	9% 9%	0.22	0.22 0.23	9% 9%	0.04 0.03	0.04 0.04	0	0	3.31 2.77			0.34 0.01	0.22
V		000	2003 Crimer Fune Op/Dragnostics 2013 High Efficiency Chiller Motors	Grocery	2014	2054	3.55	2.40	0.01	0.35	12%	0.00	0.23	12%	0.03	0.04	0	0	2.77			0.01	0.08
V	A 2	000	2006 VSD for Chiller Pumps and Towers	Grocery	2014	2054	3.19	2.20	0.36	0.83	21%	0.12	0.42	16%	0.05	0.04	0	0	1.84			0.36	0.12
V.		000	2002 Window Film (Standard) - Chiller 2003 EMS - Chiller	Grocery Grocery	2014 2014	2054 2054	2.97 2.67	2.06 2.01	0.22 0.29	1.05 1.34	26% 33%	0.14 0.05	0.56 0.61	21% 23%	0.08 0.08	0.05 0.06	0	0	1.13 0.93			0.22 0.00	0.14
V		000	2004 Cool Roof - Chiller	Grocery	2014	2054	2.47	1.88	0.29	1.55	39%	0.03	0.74	28%	0.08	0.06	0	0	0.93			0.00	0.00
V	A 2	000	2012 Duct Testing/Sealing - Chiller	Grocery	2014	2054	2.00	1.57	0.47	2.02	50%	0.31	1.05	40%	0.25	0.11	ō	ō	0.45			0.00	0.00
V.		000	2011 Duct/Pipe Insulation - Chiller 2008 New Economizer - Chiller	Grocery Grocery	2014 2014	2054 2054	1.97 1.97	1.55 1.55	0.03	2.05 2.05	51% 51%	0.02	1.07 1.07	41% 41%	3.91 41971.95	0.16 0.17	6 263,846	0	0.02			0.00	0.00
V		100	2100 Base DX Packaged System, EER=10.3, 10 tons	Grocery	2014	2054	124.62	81.40	0.00	0.00	0%	0.00	0.00	0%	N/A	0.17 N/A	203,040 N/A	N/A	N/A	124.62	81.40	0.00	0.00
V		100	2113 Ceiling/roof Insulation - DX	Grocery	2014	2054	124.46	81.29	0.16	0.16	0%	0.11	0.11	0%	0.03	0.03	0	0	4.01			0.16	0.11
V.		100	2102 DX Packaged System, EER=13.4, 10 tons 2115 Window Film (Standard) - DX	Grocery Grocery	2014 2014	2054 2054	95.83 89.16	62.59 58.24	28.63 6.67	28.79 35.45	23% 28%	18.70 4.36	18.80 23.16	23% 28%	0.03	0.03 0.04	0	0	3.46 1.09			28.63 6.67	18.70 4.36
V		100	2107 Cool Roof - DX	Grocery	2014	2054	82.27	53.74	6.89	42.34	34%	4.50	27.66	34%	0.08	0.04	0	0	0.80			0.00	0.00
V	A 2	100	2105 DX Tune Up/ Advanced Diagnostics	Grocery	2014	2054	82.18	53.71	0.09	42.44	34%	0.03	27.69	34%	0.12	0.05	0	0	0.60			0.00	0.00
V.		100	2108 Optimize Controls - DX 2106 Prog. Thermostat - DX	Grocery Grocery	2014 2014	2054 2054	80.74 79.54	53.48 53.29	1.44 1.20	43.88 45.08	35% 36%	0.23 0.19	27.92 28.11	34% 35%	0.10 0.12	0.05 0.06	1	0	0.55 0.50			0.00	0.00
V		100	2112 Duct Testing/Sealing - DX	Grocery	2014	2054	74.70	50.13	4.84	49.92	40%	3.16	31.27	38%	0.12	0.06	0	0	0.50			0.00	0.00
V		100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Grocery	2014	2054	74.68	50.12	0.02	49.94	40%	0.00	31.27	38%	0.70	0.07	4	0	0.09			0.00	0.00
V.		100	2111 Economizer Repair - DX 2109 Economizer - DX	Grocery Grocery	2014 2014	2054 2054	73.87 73.86	49.35 49.35	0.81 0.01	50.75 50.76	41% 41%	0.77 0.00	32.04 32.04	39% 39%	1.36 1.70	0.10 0.10	1 11	0	0.06 0.04			0.00	0.00
V		100	2114 Duct/Pipe Insulation - DX	Grocery	2014	2054	72.75	48.63	1.11	51.87	41%	0.00	32.04	40%	3.28	0.16	5	0	0.04			0.00	0.00
V	A 2	200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Grocery	2014	2054	11.12	7.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.12	7.26	0.00	0.00
V		200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	2014	2054	9.75	6.37	1.38	1.38	12%	0.90	0.90	12%	0.03	0.03	0	0	3.98	F 40	0.07	1.38	0.90
V.		300 000	2300 Base PTAC, EER=8.3, 1 ton 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Grocery Grocery	2014 2014	2054 2054	5.16 121.17	3.37 25.96	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	5.16 121.17	3.37 25.96	0.00	0.00
V	A 3	000	3002 Variable Speed Drive Control, 5 HP	Grocery	2014	2054	83.66	24.01	37.51	37.51	31%	1.95	1.95	7%	0.03	0.03	1	1	2.21			37.51	1.95
V		000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Grocery	2014	2054	82.22	23.70	1.44	38.95	32%	0.31	2.25	9%	0.06	0.03	0	1 2	1.47			1.44	0.31
V.		100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Grocery Grocery	2014 2014	2054 2054	70.52 0.00	18.68 0.00	11.70 0.00	50.65 0.00	42% 0%	5.02 0.00	7.27 0.00	28% 0%	1.14 N/A	0.29 N/A	N/A	N/A	0.08 N/A	0.00	0.00	0.00	0.00
V	Α 3	200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Grocery	2014	2054	119.80	25.66	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	119.80	25.66	0.00	0.00
V		200	3203 Air Handler Optimization, 40 HP	Grocery	2014	2054	107.44	25.02	12.37	12.37	10%	0.64	0.64	3%	0.02	0.02	0	0	2.67			12.37	0.64
V.		200 000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Grocery Grocery	2014 2014	2054 2054	92.15 504.16	18.46 81.17	15.28 0.00	27.65 0.00	23% 0%	6.56 0.00	7.20 0.00	28% 0%	0.86 N/A	0.49 N/A	2 N/A	2 N/A	0.11 N/A	504.16	81.17	0.00	0.00
V	A 4	000	4007 Efficient compressor motor	Grocery	2014	2054	503.18	81.01	0.98	0.98	0%	0.16	0.16	0%	0.02	0.02	0	0	3.94		*****	0.98	0.16
V		000	4011 Demand Hot Gas Defrost	Grocery	2014	2054	490.60	78.98	12.58	13.56	3%	2.03	2.18	3%	0.02	0.02	0	0	3.64			12.58	2.03
V.		000	4006 Electronically commutated evaporator fan motor 4009 Floating head pressure controls	Grocery Grocery	2014 2014	2054 2054	455.70 454.58	73.36 73.27	34.90 1.12	48.46 49.58	10% 10%	5.62 0.09	7.80 7.89	10% 10%	0.02 0.02	0.02 0.02	0	0	3.33 3.11			34.90 1.12	5.62 0.09
V		000	4002 Strip curtains for walk-ins (built-up)	Grocery	2014	2054	450.63	72.64	3.94	53.52	11%	0.63	8.53	11%	0.04	0.02	0	0	1.44			3.94	0.63
V		000	4013 Anti-sweat (humidistat) controls	Grocery	2014	2054	444.35	72.13	6.29	59.81	12%	0.51	9.03	11%	0.04	0.02	1	0	1.47			6.29	0.51
V.		000	4014 Freezer-Cooler Replacement Gaskets 4018 Oversized Air Cooled Condenser	Grocery Grocery	2014 2014	2054 2054	429.18 411.11	69.69 66.78	15.16 18.07	74.98 93.05	15% 18%	2.44 2.91	11.47 14.38	14% 18%	0.05 0.08	0.03 0.04	0	0	0.99 0.96			0.00	0.00
V	A 4	000	4004 Night covers for display cases	Grocery	2014	2054	389.44	65.04	21.67	114.72	23%	1.74	16.13	20%	0.07	0.04	1	Ö	0.78			0.00	0.00
V		000	4001 High-efficiency fan motors	Grocery	2014	2054	375.71	62.83	13.73	128.45	25%	2.21	18.34	23%	0.11	0.05	1	0	0.72			0.00	0.00
V.		000	4008 Compressor VSD retrofit 4010 Refrigeration Commissioning	Grocery Grocery	2014 2014	2054 2054	352.42 350.61	60.95 60.66	23.29 1.81	151.74 153.55	30% 30%	1.88 0.29	20.21 20.50	25% 25%	0.10 0.18	0.06	1	0	0.63 0.30			0.00	0.00
V	A 4	000	4005 Evaporator fan controller for MT walk-ins	Grocery	2014	2054	350.36	60.64	0.25	153.80	31%	0.02	20.52	25%	0.24	0.06	3	0	0.28			0.00	0.00
V		000	4017 Multiplex Compressor System	Grocery	2014	2054	344.19	59.65	6.17	159.97	32%	0.99	21.52	27%	0.26	0.07	2	1	0.27			0.00	0.00
V.		000	4016 LED Display Lighting 4015 High R-Value Glass Doors	Grocery Grocery	2014	2054 2054	317.93 313.01	55.42 54.63	26.26 4.92	186.23 191.15	37% 38%	4.23 0.79	25.74 26.54	32% 33%	0.43 1.94	0.12 0.17	3 12	1	0.14 0.03			0.00	0.00
V		100	4100 Base Self-Contained Refrigeration	Grocery	2014	2054	57.45	9.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	57.45	9.25	0.00	0.00
V		100	4103 Night covers for display cases (self-contained)	Grocery	2014	2054	56.06	9.03	1.39	1.39	2%	0.22	0.22	2%	0.00	0.00	0	0	174.99			1.39	0.22
V.		100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4109 Energy-Star Freezer, glass door	Grocery Grocery	2014 2014	2054 2054	55.32 52.33	8.91 8.43	0.74 2.99	2.13 5.12	4% 9%	0.12 0.48	0.34 0.82	4% 9%	0.01 0.03	0.00 0.02	0	0	3.99 2.43			0.74 2.99	0.12 0.48
V	A 4	100	4107 Energy-Star Freezer, solid door	Grocery	2014	2054	51.16	8.24	1.18	6.29	11%	0.19	1.01	11%	0.07	0.03	Ō	ō	0.93			0.00	0.00
V		100	4108 Energy-Star Refrigerator, glass door	Grocery	2014	2054	51.09	8.23	0.06	6.36	11%	0.01	1.02	11%	0.09	0.03	1	0	0.72			0.00	0.00
V.		100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Grocery Grocery	2014 2014	2054 2054	51.07 51.05	8.22 8.22	0.03 0.02	6.38 6.40	11% 11%	0.00	1.03 1.03	11% 11%	0.09 0.24	0.03	1	0	0.69 0.27			0.00	0.00
V	A 4	100	4112 Reach-in unit occupancy sensors	Grocery	2014	2054	51.04	8.22	0.01	6.41	11%	0.00	1.03	11%	0.29	0.03	2	ō	0.22			0.00	0.00
V		100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Grocery	2014	2054	50.70	8.16	0.35	6.75	12%	0.06	1.09	12%	0.33	0.04	2	0	0.18			0.00	0.00
V.		100	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Grocery Grocery	2014 2014	2054 2054	50.52 2.29	8.13 0.41	0.17 0.00	6.93 0.00	12% 0%	0.03	1.12 0.00	12% 0%	0.64 N/A	0.06 N/A	4 N/A	0 N/A	0.08 N/A	2.29	0.41	0.00	0.00
V	A 5	000	5001 PC Network Power Management Enabling	Grocery	2014	2054	1.25	0.32	1.03	1.03	45%	0.09	0.09	23%	0.02	0.02	0	0	2.31		0	1.03	0.09
V		000	5002 Energy Star or Better PC	Grocery	2014	2054	0.85	0.24	0.41	1.44	63%	0.07	0.17	41%	0.05	0.03	0	0	1.15	0.07	0.04	0.41	0.07
V.		100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Grocery Grocery	2014 2014	2054 2054	0.07	0.01	0.00 0.01	0.00 0.01	0% 19%	0.00	0.00	0% 19%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.22	0.07	0.01	0.00 0.01	0.00
V	A 5	100	5101 Laptop Network Power Management Enabling	Grocery	2014	2054	0.06	0.01	0.00	0.01	21%	0.00	0.00	21%	2.07	0.18	12	1	0.03			0.00	0.00
V		200	5200 Base Monitor, CRT	Grocery	2014	2054	0.43	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.43	0.08	0.00	0.00
V.		200 200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Grocery Grocery	2014	2054 2054	0.19 0.12	0.03	0.24	0.24	56% 73%	0.04	0.04 0.05	56% 65%	0.00	0.00	0	0	25.59 1.20			0.24	0.04
V	5	_00	OLOL MONITOR I OWO I WARRAGOTTON CHADINING - OT I	Grocery	2014	2004	0.12	0.03	0.07	0.02	13/0	0.01	0.00	00/0	0.04	0.01	U	U	1.20			0.07	0.01

DNV GL H-7 1/5/2015

APPENDIX H

Base Avoided Costs

	ectric Existing Construction ADDITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintage	25.11.2 00.1 21.1 Mal210.0							Total			Total		Marginal	Average	Marginal					00	
Base	Measure	Building	Measure	e weasur End	e Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic	Economic
Sgmt Numbe		Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA 52 VA 53		Grocery Grocery	2014	2054 2054	0.11 0.68	0.03	0.01 0.00	0.33	76% 0%	0.00	0.05	67% 0%	0.44 N/A	0.02 N/A	2 N/A	0 N/A	0.13 N/A	0.68	0.12	0.00	0.00
VA 53		Grocery	2014	2054	0.54	0.10	0.14	0.14	20%	0.02	0.02	20%	0.02	0.02	0	0	3.65			0.14	0.02
VA 53 VA 53		Grocery Grocery	2014 2014	2054 2054	0.47	0.09	0.07 0.04	0.21 0.25	31% 36%	0.01 0.00	0.03	26% 27%	0.16 0.45	0.07 0.12	2 10	0	0.31 0.11			0.00	0.00
VA 53		Grocery	2014	2054	0.43	0.09	0.04	0.25	0%	0.00	0.00	0%	0.45 N/A	0.12 N/A	N/A	N/A	N/A	0.55	0.10	0.00	0.00
VA 54		Grocery	2014	2054	0.44	0.08	0.11	0.11	20%	0.02	0.02	20%	0.00	0.00	0	0	17.84			0.11	0.02
VA 54 VA 55		Grocery Grocery	2014 2014	2054 2054	0.38	0.07	0.06 0.00	0.17 0.00	31% 0%	0.01	0.03	26% 0%	0.20 N/A	0.07 N/A	2 N/A	0 N/A	0.27 N/A	0.22	0.04	0.00	0.00
VA 55		Grocery	2014	2054	0.22	0.04	0.05	0.05	25%	0.00	0.00	25%	0.01	0.01	0	0	5.46	0.22	0.04	0.00	0.00
VA 55	5501 Multifunction Power Management Enabling	Grocery	2014	2054	0.12	0.03	0.05	0.10	46%	0.00	0.01	36%	0.53	0.25	6	2	0.10			0.00	0.00
VA 56 VA 56		Grocery Grocery	2014 2014	2054 2054	0.18 0.12	0.03	0.00 0.06	0.00	0% 35%	0.00 0.01	0.00 0.01	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 25.12	0.18	0.03	0.00 0.06	0.00 0.01
VA 56		Grocery	2014	2054	0.12	0.02	0.08	0.06	53%	0.01	0.01	44%	0.00	0.00	1	0	0.45			0.00	0.00
VA 57		Grocery	2014	2054	0.45	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.45	0.08	0.00	0.00
VA 57 VA 57		Grocery Grocery	2014 2014	2054 2054	0.40	0.07	0.04 0.05	0.04 0.10	10% 21%	0.01 0.01	0.01 0.02	10% 21%	0.00	0.00	0	0	120.04 48.87			0.04 0.05	0.01 0.01
VA 57		Grocery	2014	2054	0.33	0.06	0.03	0.10	26%	0.00	0.02	26%	0.00	0.00	0	0	25.35			0.03	0.00
VA 60	00 6000 Base Water Heating	Grocery	2014	2054	13.04	2.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.04	2.10	0.00	0.00
VA 60		Grocery	2014	2054	12.36	1.99	0.68	0.68	5%	0.11	0.11	5%	0.02	0.02	0	0	2.67			0.68	0.11
VA 60 VA 60		Grocery Grocery	2014 2014	2054 2054	12.11 5.82	1.95 0.94	0.25 6.30	0.92 7.22	7% 55%	0.04 1.01	0.15 1.16	7% 55%	0.05 0.06	0.03	0	0	1.44 1.10			0.25 6.30	0.04 1.01
VA 60	00 6004 Tankless Water Heater	Grocery	2014	2054	5.38	0.87	0.44	7.66	59%	0.07	1.23	59%	0.16	0.06	1	ō	0.49			0.00	0.00
VA 60		Grocery	2014	2054	4.63	0.74	0.75	8.41	65%	0.12	1.35	65%	0.19	0.07	1	0	0.42			0.00	0.00
VA 60 VA 60		Grocery Grocery	2014 2014	2054 2054	4.46 4.37	0.72	0.17 0.09	8.58 8.67	66% 66%	0.03 0.01	1.38 1.39	66% 66%	0.22 0.23	0.08 0.08	1	0	0.33 0.32			0.00	0.00
VA 70	7000 Base Refrigerated Vending Machines	Grocery	2014	2054	11.46	1.82	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.46	1.82	0.00	0.00
VA 70		Grocery	2014	2054	9.75	1.69	1.71	1.71	15%	0.13	0.13	7%	0.02	0.02	0	0	2.15			1.71	0.13
VA 70 VA 71		Grocery Grocery	2014 2014	2054 2054	8.82 0.02	1.61 0.00	0.92	2.63 0.00	23% 0%	0.07	0.21	11% 0%	0.04 N/A	0.03 N/A	1 N/A	0 N/A	1.16 N/A	0.02	0.00	0.92 0.00	0.07 0.00
VA 71	7101 Vending Misers (Non-Refrigerated)	Grocery	2014	2054	0.01	0.00	0.01	0.01	43%	0.00	0.00	21%	0.40	0.40	5	5	0.13			0.00	0.00
VA 72		Grocery	2014	2054	12.90	1.79	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.90	1.79	0.00	0.00
VA 73 VA 74		Grocery Grocery	2014	2054 2054	16.78 23.43	2.33 3.26	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	16.78 23.43	2.33 3.26	0.00	0.00
VA 74	7401 Efficient Steamer	Grocery	2014	2054	7.16	1.00	16.27	16.27	69%	2.26	2.26	69%	0.06	0.06	0	0	1.11	20.10		16.27	2.26
VA 80		Grocery	2014	2054	0.56	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.56	0.00	0.00	0.00
VA 80 VA 81		Grocery Grocery	2014 2014	2054 2054	0.53 13.76	0.00	0.03	0.03	6% 0%	0.00	0.00	0% 0%	0.04 N/A	0.04 N/A	N/A N/A	N/A N/A	1.65 N/A	13.76	0.00	0.03	0.00
VA 95		Grocery	2014	2054	131.26	20.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	131.26	20.87	0.00	0.00
VA 95		Grocery	2014	2054	131.26	20.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
VA 10 VA 10		Warehouse Warehouse	2020 2020	2054 2054	448.71 411.35	79.75 73.11	0.00 37.36	0.00 37.36	0% 8%	0.00 6.64	0.00 6.64	0% 8%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.91	448.71	79.75	0.00 37.36	0.00 6.64
VA 10		Warehouse	2020	2054	404.59	72.51	6.77	44.12	10%	0.60	7.24	9%	0.03	0.02	0	0	1.70			6.77	0.60
VA 10	30 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Warehouse	2020	2054	353.11	63.36	51.48	95.60	21%	9.15	16.38	21%	0.04	0.03	0	0	1.37			51.48	9.15
VA 10 VA 10		Warehouse Warehouse	2020 2020	2054 2054	326.55 319.89	59.60 59.30	26.56 6.66	122.16 128.82	27% 29%	3.77 0.29	20.15 20.44	25% 26%	0.05 0.09	0.04 0.04	0 2	0	1.33 0.65			26.56 0.00	3.77 0.00
VA 10		Warehouse	2020	2054	268.34	50.14	51.54	180.36	40%	9.16	29.60	37%	0.28	0.11	2	1	0.25			0.00	0.00
VA 10		Warehouse	2020	2054	245.44	46.07	22.91	203.27	45%	4.07	33.67	42%	0.24	0.12	1	1	0.30			0.00	0.00
VA 11 VA 11		Warehouse Warehouse	2020 2020	2054 2054	3.06 2.74	0.54	0.00 0.32	0.00 0.32	0% 10%	0.00	0.00	0% 10%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.25	3.06	0.54	0.00 0.32	0.00 0.06
VA 11	30 1136 Lighting Control Tuneup (base 2L4T8), 2020	Warehouse	2020	2054	2.70	0.48	0.05	0.36	12%	0.00	0.06	11%	0.03	0.03	0	0	1.60			0.05	0.00
VA 11	30 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Warehouse	2020	2054	2.49	0.45	0.20	0.56	18%	0.03	0.09	16%	0.05	0.04	0	0	1.44			0.20	0.03
VA 11 VA 11		Warehouse Warehouse	2020	2054 2054	2.18	0.40	0.32	0.88 0.99	29% 32%	0.06 0.02	0.15 0.16	27% 30%	0.06 0.23	0.05	0	0	0.98 0.31			0.00	0.00
VA 11		Warehouse	2020	2054	1.90	0.38	0.11	1.16	32%	0.02	0.16	36%	0.23	0.07	2	1	0.31			0.00	0.00
VA 11	30 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Warehouse	2020	2054	1.86	0.35	0.04	1.20	39%	0.00	0.20	36%	0.18	0.10	4	.1	0.31			0.00	0.00
VA 12 VA 12		Warehouse Warehouse	2014	2054 2054	0.46	0.08	0.00 0.05	0.00 0.05	0% 10%	0.00	0.00	0% 5%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 16.81	0.46	0.08	0.00 0.05	0.00
VA 12		Warehouse	2014	2054	0.42	0.08	0.05	0.05	17%	0.00	0.00	10%	0.00	0.00	0	0	2.30			0.05	0.00
VA 12	00 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Warehouse	2014	2054	0.36	0.07	0.02	0.10	22%	0.00	0.01	12%	0.09	0.03	2	0	0.62			0.00	0.00
VA 12 VA 12		Warehouse Warehouse	2014 2014	2054 2054	0.33	0.07	0.04 0.04	0.14 0.18	30% 39%	0.01 0.01	0.02 0.02	20% 29%	0.11 0.23	0.05 0.09	1	0	0.55 0.26			0.00	0.00
VA 12 VA 13		Warehouse	2014	2054	0.28	0.00	0.04	0.00	39% 0%	0.00	0.02	29% 0%	0.23 N/A	0.09 N/A	N/A	N/A	0.26 N/A	0.00	0.00	0.00	0.00
VA 14	30 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Warehouse	2020	2054	13.47	2.39	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.47	2.39	0.00	0.00
VA 15 VA 16		Warehouse	2020	2054 2054	9.92	1.76	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A	N/A	N/A	N/A	9.92	1.76	0.00	0.00
VA 16 VA 16		Warehouse Warehouse	2020 2020	2054	18.72 13.54	3.33 2.41	0.00 5.19	0.00 5.19	28%	0.00 0.92	0.00 0.92	28%	0.06	N/A 0.06	N/A 0	N/A 0	N/A 0.98	18.72	3.33	0.00	0.00
VA 17	1730 Base CFL 23W to screw-in replacement 2020	Warehouse	2020	2054	23.92	4.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	23.92	4.25	0.00	0.00
VA 17		Warehouse	2020	2054	17.70	3.15	6.22	6.22	26%	1.11	1.11	26%	0.05 N/A	0.05 N/A	0	0	1.31	270 54	40.00	6.22	1.11
VA 18 VA 18	00 1800 BaseMetal Halide, 465W 00 1801 T5 (240W) (base metal halide)	Warehouse Warehouse	2014	2054 2054	270.51 179.05	48.08 31.82	0.00 91.46	0.00 91.46	0% 34%	0.00 16.25	0.00 16.25	0% 34%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.34	270.51	48.08	0.00 91.46	0.00 16.25
VA 18	1806 Occupancy Sensor, High Bay T5	Warehouse	2014	2054	173.36	31.57	5.70	97.16	36%	0.25	16.50	34%	0.03	0.01	1	ō	1.90			5.70	0.25
VA 18		Warehouse	2014	2054	160.31	29.72	13.04	110.20	41%	1.85	18.35	38%	0.05	0.02	0	0	1.49			13.04	1.85
VA 18	50 1850 Base CFL Exit Sign	Warehouse	2014	2054	1.60	0.28	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.60	0.28	0.00	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

DSM A	SSYST ADI	ric Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintag	е			Measure	Measur	Э			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Samt	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic
VA	1850	1851 LED Exit Sign	Warehouse	2014	2054	0.50	0.09	1.10	1.10	69%	0.20	0.20	69%	0.05	0.05	0	0	1.15	OWN		1.10	0.20
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Warehouse	2014	2054	100.54	1.36	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	100.54	1.36	0.00	0.00
VA VA	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Warehouse Warehouse	2014 2014	2054 2054	96.70 46.53	1.19 0.51	3.84 50.17	3.84 54.01	4% 54%	0.17 0.68	0.17 0.85	13% 63%	0.05	0.05 0.09	1 7	1 6	1.58 0.68			3.84 0.00	0.17
VA	1900	1903 Bi-Level LED Outdoor Lighting	Warehouse	2014	2054	32.84	0.34	13.69	67.70	67%	0.00	1.02	75%	0.10	0.09	51	13	0.10			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Warehouse	2014	2054	227.17	216.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	227.17	216.04	0.00	0.00
VA VA	2100 2100	2113 Ceiling/roof Insulation - DX 2107 Cool Roof - DX	Warehouse Warehouse	2014 2014	2054 2054	216.72 200.59	206.10 190.77	10.45 16.12	10.45 26.58	5% 12%	9.94 15.33	9.94 25.28	5% 12%	0.05 0.12	0.05 0.09	0	0	2.69 0.92			10.45 0.00	9.94
VA	2100	2108 Optimize Controls - DX	Warehouse	2014	2054	197.61	189.96	2.98	29.56	13%	0.81	26.09	12%	0.12	0.10	1	0	0.39			0.00	0.00
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons	Warehouse	2014	2054	152.16	146.73	45.45	75.01	33%	43.22	69.31	32%	0.48	0.33	0	0	0.27			0.00	0.00
VA VA	2100 2100	2112 Duct Testing/Sealing - DX	Warehouse	2014	2054	143.11	138.12	9.05 6.16	84.06	37% 40%	8.61 5.86	77.92 83.78	36% 39%	3.07 2.74	0.62	3	1	0.05			0.00	0.00
VA VA	2100 2100	2115 Window Film (Standard) - DX 2106 Prog. Thermostat - DX	Warehouse Warehouse	2014 2014	2054 2054	136.95 132.85	132.27 131.15	6.16 4.10	90.22 94.33	40% 42%	1.12	83.78 84.89	39%	2.74	0.77	3 7	1	0.04			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Warehouse	2014	2054	132.58	130.90	0.26	94.59	42%	0.25	85.14	39%	5.62	0.83	6	1	0.02			0.00	0.00
VA	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Warehouse	2014	2054	132.51	130.88	0.07	94.66	42%	0.02	85.16	39%	3.71	0.84	14	1	0.02			0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Warehouse	2014	2054	122.99	116.97	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	122.99	116.97	0.00	0.00
VA VA	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Warehouse Warehouse	2014 2014	2054 2054	107.78 5.83	102.50 5.54	15.21 0.00	15.21 0.00	12% 0%	14.47 0.00	14.47 0.00	12% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	2.78 N/A	5.83	5.54	15.21 0.00	14.47 0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Warehouse	2014	2054	128.07	39.55	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	128.07	39.55	0.00	0.00
VA	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Warehouse	2014	2054	125.86	38.87	2.21	2.21	2%	0.68	0.68	2%	0.05	0.05	0	0	2.03			2.21	0.68
VA VA	3000 3000	3002 Variable Speed Drive Control, 5 HP	Warehouse	2014 2014	2054 2054	88.87 87.73	35.95 35.31	36.99 1.14	39.20 40.34	31% 31%	2.92 0.65	3.60	9% 11%	0.04	0.04	0	0	1.85			36.99 0.00	2.92 0.00
VA	3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Warehouse Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	4.25 0.00	0%	1.85 N/A	0.09 N/A	N/A	N/A	0.06 N/A	0.00	0.00	0.00	0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Warehouse	2014	2054	42.48	13.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	42.48	13.12	0.00	0.00
VA	3200	3202 Variable Speed Drive Control, 40 HP	Warehouse	2014	2054	29.99	12.13	12.48	12.48	29%	0.98	0.98	8%	0.02	0.02	0	0	3.63			12.48	0.98
VA VA	3200 3200	3203 Air Handler Optimization, 40 HP 3204 Demand Controlled Ventilation	Warehouse Warehouse	2014 2014	2054 2054	27.06 26.71	11.90 11.71	2.94 0.35	15.42 15.77	36% 37%	0.23 0.20	1.22 1.41	9% 11%	0.06 2.02	0.03 0.07	1	0	0.88 0.05			0.00	0.00
VA	4000	4000 Base Built-Up Refrigeration System	Warehouse	2014	2054	306.50	58.07	0.00	0.00	0%	0.20	0.00	0%	2.02 N/A	N/A	N/A	N/A	0.05 N/A	306.50	58.07	0.00	0.00
VA	4000	4018 Oversized Air Cooled Condenser	Warehouse	2014	2054	293.60	55.62	12.90	12.90	4%	2.44	2.44	4%	0.03	0.03	0	0	2.42	000.00	00.07	12.90	2.44
VA	4000	4010 Refrigeration Commissioning	Warehouse	2014	2054	292.09	55.34	1.51	14.41	5%	0.29	2.73	5%	0.06	0.03	0	0	0.87			0.00	0.00
VA VA	4000 4000	4006 Electronically commutated evaporator fan motor 4005 Evaporator fan controller for MT walk-ins	Warehouse Warehouse	2014 2014	2054 2054	274.39 274.34	51.98 51.98	17.70 0.05	32.11 32.16	10% 10%	3.35 0.01	6.08 6.09	10% 10%	0.11 0.19	0.07 0.07	1 2	0	0.71 0.36			0.00	0.00
VA	4000	4002 Strip curtains for walk-ins (built-up)	Warehouse	2014	2054	273.17	51.76	1.17	33.33	11%	0.01	6.31	11%	0.19	0.07	1	0	0.30			0.00	0.00
VA	4000	4001 High-efficiency fan motors	Warehouse	2014	2054	264.80	50.17	8.37	41.70	14%	1.59	7.90	14%	0.45	0.15	2	1	0.18			0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Warehouse	2014	2054	81.91	15.52	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	81.91	15.52	0.00	0.00
VA VA	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Warehouse Warehouse	2014 2014	2054	81.78 19.15	15.49 3.19	0.13	0.13	0% 0%	0.03	0.03	0% 0%	0.15 N/A	0.15 N/A	1 N/A	1 N/A	0.36 N/A	19.15	3.19	0.00	0.00
VA	5000	5001 PC Network Power Management Enabling	Warehouse	2014	2054	10.66	2.46	8.49	8.49	44%	0.73	0.73	23%	0.01	0.01	0	0	3.79	15.15	3.15	8.49	0.73
VA	5000	5002 Energy Star or Better PC	Warehouse	2014	2054	7.16	1.88	3.49	11.98	63%	0.58	1.31	41%	0.03	0.02	0	0	1.94			3.49	0.58
VA	5100	5100 Base Laptop PC	Warehouse	2014	2054	1.36	0.23	0.00	0.00	0%	0.00	0.00	0% 19%	N/A	N/A	N/A 0	N/A 0	N/A 5.37	1.36	0.23	0.00	0.00
VA VA	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Warehouse Warehouse	2014 2014	2054 2054	1.10 1.08	0.18	0.26 0.02	0.26 0.28	19% 21%	0.04	0.04 0.05	21%	0.01 1.24	0.01 0.11	7	1	0.04			0.26 0.00	0.04
VA	5200	5200 Base Monitor, CRT	Warehouse	2014	2054	3.95	0.66	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.95	0.66	0.00	0.00
VA	5200	5201 Energy Star or Better Monitor - CRT	Warehouse	2014	2054	1.73	0.29	2.22	2.22	56%	0.37	0.37	56%	0.00	0.00	0	0	42.66			2.22	0.37
VA VA	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Warehouse Warehouse	2014 2014	2054 2054	1.18 1.08	0.24	0.55 0.09	2.77 2.86	70% 73%	0.05 0.02	0.42 0.43	63% 66%	0.02 0.23	0.01 0.01	0	0	2.33 0.24			0.55 0.00	0.05
VA	5300	5300 Base Monitor, LCD	Warehouse	2014	2054	3.15	0.23	0.00	0.00	0%	0.02	0.00	0%	0.23 N/A	N/A	N/A	N/A	N/A	3.15	0.53	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Warehouse	2014	2054	2.51	0.42	0.64	0.64	20%	0.11	0.11	20%	0.01	0.01	0	0	6.08			0.64	0.11
VA	5300	5302 Monitor Power Management Enabling - LCD	Warehouse	2014	2054	2.48	0.42	0.03	0.67	21%	0.00	0.11	21%	0.08	0.01	1	0	0.61			0.00	0.00
VA VA	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Warehouse Warehouse	2014 2014	2054	2.30 4.86	0.41 0.81	0.18	0.85	27% 0%	0.01	0.12	22% 0%	0.24 N/A	0.06 N/A	5 N/A	0 N/A	0.20 N/A	4.86	0.81	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Warehouse	2014	2054	4.28	0.71	0.58	0.58	12%	0.10	0.10	12%	0.00	0.00	0	0	32.89		0.01	0.58	0.10
VA	5400	5402 Copier Power Management Enabling	Warehouse	2014	2054	4.13	0.70	0.15	0.73	15%	0.01	0.11	14%	0.09	0.02	.1.	0	0.58			0.00	0.00
VA VA	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Printer	Warehouse Warehouse	2014 2014	2054 2054	1.09 0.82	0.18	0.00 0.27	0.00 0.27	0% 25%	0.00 0.05	0.00 0.05	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.11	1.09	0.18	0.00 0.27	0.00 0.05
VA	5500	5502 ENERGY STAR Multi-Function Printer 5501 Multifunction Power Management Enabling	Warehouse	2014	2054	0.82	0.14	0.27	0.27	25% 32%	0.05	0.05	25% 29%	0.01	0.01	3	0	0.22			0.27	0.05
VA	5600	5600 Base Printer	Warehouse	2014	2054	4.88	0.81	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.88	0.81	0.00	0.00
VA	5600	5602 ENERGY STAR Printer	Warehouse	2014	2054	3.18	0.53	1.70	1.70	35%	0.28	0.28	35%	0.00	0.00	0	0	41.89			1.70	0.28
VA	5600 5700	5601 Printer Power Management Enabling	Warehouse	2014 2014	2054 2054	2.87 57.03	0.50	0.31	2.01	41% 0%	0.03	0.31	38% 0%	0.05 N/A	0.01 N/A	1 N/A	0	1.01 N/A	E7 02	9.51	0.31	0.03
VA VA	5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Warehouse Warehouse	2014	2054	51.32	9.51 8.56	5.70	0.00 5.70	10%	0.00	0.00 0.95	10%	0.00	0.00	N/A 0	N/A 0	N/A 119.82	57.03	9.51	0.00 5.70	0.00
VA	5700	5702 Data Center Best Practices	Warehouse	2014	2054	44.79	7.47	6.53	12.23	21%	1.09	2.04	21%	0.00	0.00	0	0	48.78			6.53	1.09
VA	5700	5703 Data Center State of the Art practices	Warehouse	2014	2054	42.29	7.05	2.51	14.74	26%	0.42	2.46	26%	0.00	0.00	0	0	25.30			2.51	0.42
VA VA	6000 6000	6000 Base Water Heating	Warehouse Warehouse	2014 2014	2054	21.67	3.40 3.18	0.00 1.41	0.00 1.41	0% 7%	0.00	0.00	0% 7%	N/A 0.25	N/A 0.25	N/A	N/A	N/A 0.26	21.67	3.40	0.00	0.00
VA VA	6000	6006 Heat Recovery Unit 6007 Heat Trap	Warehouse Warehouse	2014	2054	20.26 19.21	3.18	1.41	1.41 2.46	7% 11%	0.22	0.22	7% 11%	0.25	0.25	3	2	0.26			0.00	0.00
VA	6000	6002 High Efficiency Water Heater (electric)	Warehouse	2014	2054	18.83	2.95	0.38	2.84	13%	0.06	0.45	13%	0.93	0.42	6	3	0.08			0.00	0.00
VA	6000	6004 Tankless Water Heater	Warehouse	2014	2054	17.42	2.73	1.41	4.25	20%	0.22	0.67	20%	1.42	0.75	9	5	0.06			0.00	0.00
VA VA	6000 6000	6008 Solar Water Heater 6003 Hot Water Pipe Insulation	Warehouse Warehouse	2014 2014	2054 2054	11.44 11.40	1.80 1.79	5.97 0.05	10.23 10.27	47% 47%	0.94 0.01	1.60 1.61	47% 47%	1.66 2.54	1.28 1.28	11 16	8	0.05 0.03			0.00	0.00
VA	6000	6001 Demand controlled circulating systems	Warehouse	2014	2054	11.40	1.79	0.05	10.27	47%	0.01	1.65	48%	2.54	1.28	18	8	0.03			0.00	0.00
VA	7000	7000 Base Refrigerated Vending Machines	Warehouse	2014	2054	14.96	2.82	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.96	2.82	0.00	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	Warehouse	2014	2054	13.29	2.66	1.67	1.67	11%	0.16	0.16	6%	0.02	0.02	0	0	2.48			1.67	0.16

APPENDIX H

Base Avoided Costs

		ric Existing Construction		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm1 VA	Number 7000	Number Measure 7002 Vending Misers (Refrigerated glass-front units)	Type Warehouse	Year 2014	Year 2054	12,40	MW 2.57	Savings 0.89	GWH 2.57	Savings 17%	Savings 0.09	MW 0.25	Savings 9%	\$/kWH 0.04	\$/kWH 0.03	\$/kW 0	\$/kW	1.33	GWH	MW	0.89	0.09
VA	7100	7100 Base Non-Refrigerated Vending Machines	Warehouse	2014	2054	0.62	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.62	0.12	0.00	0.00
VA VA	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Warehouse Warehouse	2014 2014	2054 2054	0.43 4.94	0.10 0.81	0.20 0.00	0.20	32% 0%	0.02	0.02	16% 0%	0.36 N/A	0.36 N/A	4 N/A	4 N/A	0.15 N/A	4.94	0.81	0.00	0.00
VA	7300	7300 Base Gveri	Warehouse	2014	2054	10.26	1.69	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.26	1.69	0.00	0.00
VA VA	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Warehouse	2014	2054	4.31 2.14	0.71	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	4.31	0.71	0.00	0.00
VA	8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Warehouse Warehouse	2014	2054	2.14	0.00	0.00	0.00	6%	0.00	0.00	0%	0.03	0.03	N/A N/A	N/A N/A	1.90	2.14	0.00	0.00	0.00
VA	8100	8100 Base Heating, Other Electric	Warehouse	2014	2054	16.88	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.88	0.00	0.00	0.00
VA VA	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Warehouse Warehouse	2014 2014	2054 2054	349.99 349.99	65.97 65.97	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	349.99	65.97	0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	School	2020	2054	286.28	38.69	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	286.28	38.69	0.00	0.00
VA VA	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	School School	2020 2020	2054 2054	283.96 254.79	38.53 34.59	2.33 29.17	2.33	1% 11%	0.16 3.94	0.16 4.10	0% 11%	0.02 0.02	0.02	0	0	2.90 2.84			2.33 29.17	0.16 3.94
VA	1030	1031 ROB 4L4 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	School	2020	2054	235.71	32.52	19.08	50.57	18%	2.07	6.17	16%	0.02	0.02	0	0	2.31			19.08	2.07
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	School	2020	2054	205.72	28.47	29.99	80.56	28%	4.05	10.22	26%	0.05	0.04	0	0	1.26			29.99	4.05
VA VA	1030 1030	1034 ROB 4L4' LED Tube, 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	School School	2020 2020	2054 2054	172.57 162.46	23.99	33.15 10.12	113.71 123.83	40% 43%	4.48 0.34	14.70 15.04	38% 39%	0.35 0.18	0.13 0.13	3 5	1	0.23			0.00	0.00
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	School	2020	2054	148.59	21.77	13.87	137.70	48%	1.87	16.92	44%	0.31	0.15	2	1	0.26			0.00	0.00
VA VA	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	School School	2020 2020	2054 2054	17.97 16.14	2.43 2.18	0.00 1.84	0.00 1.84	0% 10%	0.00 0.25	0.00 0.25	0% 10%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.27	17.97	2.43	0.00 1.84	0.00 0.25
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	School	2020	2054	15.98	2.17	0.15	1.99	11%	0.23	0.26	11%	0.03	0.03	0	0	1.76			0.15	0.23
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	School	2020	2054	14.79	2.04	1.20	3.19	18%	0.13	0.39	16%	0.04	0.04	0	0	1.57			1.20	0.13
VA VA	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	School School	2020 2020	2054 2054	12.91 12.28	1.79 1.70	1.88 0.62	5.07 5.69	28% 32%	0.25 0.08	0.64	26% 30%	0.07 0.28	0.05 0.07	1 2	0	1.00 0.28			0.00	0.00
VA	1130	1135 LED Troffer (base 2L4'T8), 2020	School	2020	2054	11.23	1.56	1.05	6.74	37%	0.14	0.87	36%	0.36	0.12	3	1	0.22			0.00	0.00
VA VA	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	School School	2020 2014	2054 2054	10.58 1.39	1.54 0.19	0.66 0.00	7.40 0.00	41% 0%	0.02	0.89	37% 0%	0.30 N/A	0.13 N/A	9 N/A	1 N/A	0.18 N/A	1.39	0.19	0.00	0.00
VA	1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	School	2014	2054	1.33	0.19	0.06	0.06	5%	0.00	0.00	2%	0.02	0.02	0	0	2.39	1.39	0.19	0.06	0.00
VA	1200	1201 ROB High Performance T8 (base other fluorescent)	School	2014	2054	1.21	0.17	0.11	0.18	13%	0.02	0.02	10%	0.10	0.07	1	1	0.69			0.00	0.00
VA VA	1200 1200	1202 ROB Low Watt High Performance T8 (base other fluorescent) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	School School	2014 2014	2054 2054	1.06 0.89	0.15 0.14	0.15 0.17	0.33 0.50	24% 36%	0.02	0.04	22% 25%	0.21 0.18	0.14 0.15	2	1 2	0.33 0.31			0.00	0.00
VA	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	School	2014	2054	0.82	0.13	0.07	0.57	41%	0.01	0.05	29%	0.33	0.17	3	2	0.21			0.00	0.00
VA	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	School	2020 2020	2054 2054	1.04 0.21	0.14	0.00 0.84	0.00	0% 80%	0.00 0.11	0.00 0.11	0% 80%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 10.94	1.04	0.14	0.00	0.00
VA VA	1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	School School	2020	2054	0.21	0.03	0.84	0.84	80% 0%	0.11	0.00	0%	0.01 N/A	0.01 N/A	N/A	N/A	10.94 N/A	0.38	0.05	0.84	0.11
VA	1430	1432 LEDs (base incandescent A-line 72W) 2020	School	2020	2054	0.08	0.01	0.29	0.29	78%	0.04	0.04	78%	0.01	0.01	0	0	9.21			0.29	0.04
VA VA	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	School School	2020 2020	2054 2054	0.28	0.04	0.00 0.20	0.00 0.20	0% 71%	0.00	0.00	0% 71%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.77	0.28	0.04	0.00 0.20	0.00
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	School	2020	2054	20.83	2.82	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	20.83	2.82	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	School School	2020 2020	2054 2054	15.06 26.62	2.04 3.60	5.77 0.00	5.77 0.00	28% 0%	0.78	0.78	28% 0%	0.07 N/A	0.07 N/A	1 N/A	1 N/A	0.96 N/A	26.62	3.60	0.00	0.00
VA	1730	1730 base CFL 23W to screw-in replacement (base CFL 23W) 2020	School	2020	2054	19.70	2.66	6.92	6.92	26%	0.00	0.00	26%	0.05	0.05	0	0	1.27	20.02	3.60	6.92	0.00
VA	1800	1800 BaseMetal Halide, 465W	School	2014	2054	41.12	5.56	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	41.12	5.56	0.00	0.00
VA VA	1800 1800	1801 T5 (240W) (base metal halide) 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	School School	2014 2014	2054 2054	27.22 25.18	3.68 3.46	13.90 2.04	13.90 15.94	34% 39%	1.88 0.22	1.88 2.10	34% 38%	0.02	0.02 0.02	0	0	4.33 2.75			13.90 2.04	1.88 0.22
VA	1800	1806 Occupancy Sensor, High Bay T5	School	2014	2054	24.39	3.43	0.79	16.73	41%	0.03	2.13	38%	0.05	0.02	2	ō	1.05			0.79	0.03
VA	1850 1850	1850 Base CFL Exit Sign	School	2014 2014	2054 2054	2.22	0.30	0.00	0.00	0% 55%	0.00 0.17	0.00 0.17	0% 55%	N/A 0.04	N/A	N/A 0	N/A 0	N/A	2.22	0.30	0.00	0.00
VA VA	1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	School School	2014	2054	1.00 67.16	2.68	1.22 0.00	1.22 0.00	55% 0%	0.17	0.17	55% 0%	0.04 N/A	0.04 N/A	N/A	N/A	1.62 N/A	67.16	2.68	1.22 0.00	0.17
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	School	2014	2054	60.40	1.82	6.75	6.75	10%	0.86	0.86	32%	0.05	0.05	0	0	1.70			6.75	0.86
VA VA	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	School School	2014 2014	2054 2054	29.07	0.57	31.34 8.53	38.09 46.62	57% 69%	1.25 0.31	2.10 2.41	79% 90%	0.10 0.66	0.09 0.20	3 18	2	0.65 0.10			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	School	2014	2054	93.36	47.93	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	93.36	47.93	0.00	0.00
VA VA	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	School School	2014	2054 2054	85.39 85.17	43.84 43.78	7.97 0.22	7.97 8.19	9% 9%	4.09 0.06	4.09 4.15	9% 9%	0.07 0.05	0.07 0.07	0	0	1.63 1.32			7.97 0.22	4.09 0.06
VA	2000	2013 High Efficiency Chiller Motors	School	2014	2054	85.09	43.74	0.22	8.27	9%	0.06	4.15	9%	0.05	0.07	0	0	1.05			0.22	0.06
VA	2000	2006 VSD for Chiller Pumps and Towers	School	2014	2054	84.94	43.70	0.15	8.42	9%	0.04	4.24	9%	0.08	0.07	0	0	0.99			0.00	0.00
VA VA	2000 2000	2003 EMS - Chiller 2004 Cool Roof - Chiller	School School	2014 2014	2054 2054	80.35 78.80	43.04 42.25	4.59 1.55	13.01 14.56	14% 16%	0.66 0.79	4.89 5.69	10% 12%	0.13 0.21	0.09 0.10	1	0	0.55 0.42			0.00	0.00
VA	2000	2002 Window Film (Standard) - Chiller	School	2014	2054	78.40	42.04	0.40	14.96	16%	0.79	5.89	12%	0.24	0.10	0	0	0.36			0.00	0.00
VA	2000	2012 Duct Testing/Sealing - Chiller	School	2014	2054	65.41	35.37	12.99	27.95	30%	6.67	12.56	26%	0.34	0.21	1	0	0.31			0.00	0.00
VA VA	2000 2000	2008 New Economizer - Chiller 2011 Duct/Pipe Insulation - Chiller	School School	2014 2014	2054 2054	58.45 58.10	34.38 34.20	6.96 0.35	34.91 35.26	37% 38%	0.99 0.18	13.56 13.74	28% 29%	0.39 5.57	0.25 0.30	3 11	1	0.16 0.02			0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	School	2014	2054	223.92	114.97	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	223.92	114.97	0.00	0.00
VA VA	2100 2100	2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	School School	2014	2054 2054	223.78 172.31	114.90 88.47	0.14 51.47	0.14 51.61	0% 23%	0.07 26.43	0.07 26.50	0% 23%	0.03	0.03	0	0	4.21 1.72			0.14 51.47	0.07 26.43
VA	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	School	2014	2054	172.07	88.43	0.24	51.85	23%	0.03	26.53	23%	0.06	0.06	1	0	0.36			0.00	0.00
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	School	2014	2054	171.80	88.36	0.27	52.11	23%	0.07	26.60	23%	0.21	0.06	1	0	0.34			0.00	0.00
VA VA	2100 2100	2115 Window Film (Standard) - DX 2108 Optimize Controls - DX	School School	2014 2014	2054 2054	170.22 167.62	87.55 87.18	1.58 2.60	53.69 56.30	24% 25%	0.81 0.37	27.41 27.79	24% 24%	0.26 0.18	0.07 0.07	1	0	0.33 0.30			0.00	0.00
VA	2100	2112 Duct Testing/Sealing - DX	School	2014	2054	158.73	82.61	8.89	65.19	29%	4.56	32.35	28%	0.38	0.11	1	o	0.28			0.00	0.00
VA VA	2100	2106 Prog. Thermostat - DX	School	2014	2054	157.35	82.42	1.38	66.57	30%	0.20	32.55	28%	0.23	0.12	2	0	0.25			0.00	0.00
VA	2100	2107 Cool Roof - DX	School	2014	2054	154.57	80.99	2.78	69.35	31%	1.43	33.97	30%	0.43	0.13	1	U	0.20			0.00	0.00

DNV GL H-10 1/5/2015

APPENDIX H

Base Avoided Costs

DSM	ASSYST ADD	ic Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	je			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Samt	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic
VA	2100	2111 Economizer Repair - DX	School	2014	2054	151.53	78.79	3.04	72.39	32%	2.20	36.18	31%	0.94	0.16	1	0	0.09	OWN	10100	0.00	0.00
VA	2100	2109 Economizer - DX	School	2014	2054	150.79	78.68	0.74	73.13	33%	0.11	36.28	32%	1.40	0.17	10	0	0.04			0.00	0.00
VA VA	2100 2200	2114 Duct/Pipe Insulation - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	School School	2014 2014	2054 2054	148.99 176.18	77.76 90.46	1.80 0.00	74.93 0.00	33% 0%	0.92	37.20 0.00	32% 0%	5.22 N/A	0.30 N/A	10 N/A	N/A	0.02 N/A	176.18	90.46	0.00	0.00
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School	2014	2054	154.39	79.27	21.79	21.79	12%	11.19	11.19	12%	0.05	0.05	0	0	2.03			21.79	11.19
VA VA	2300 2300	2300 Base PTAC, EER=8.3, 1 ton 2301 HE PTAC, EER=9.6, 1 ton	School School	2014 2014	2054 2054	160.46 138.73	82.38 71.23	0.00 21.73	0.00 21.73	0% 14%	0.00 11.16	0.00 11.16	0% 14%	N/A 0.12	N/A 0.12	N/A 0	N/A 0	N/A 0.81	160.46	82.38	0.00	0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	School	2014	2054	52.81	10.30	0.00	0.00	0%	0.00	0.00	0%	0.12 N/A	0.12 N/A	N/A	N/A	N/A	52.81	10.30	0.00	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	School	2014	2054	39.02	9.61	13.79	13.79	26%	0.69	0.69	7%	0.04	0.04	1	1	1.54			13.79	0.69
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	School School	2014 2014	2054 2054	38.34 32.61	9.48 7.48	0.67 5.73	14.47 20.20	27% 38%	0.13 2.00	0.82 2.82	8% 27%	0.08 2.13	0.04 0.64	0 6	1 5	1.10 0.04			0.67 0.00	0.13 0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	School	2014	2054	141.36	27.58	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	141.36	27.58	0.00	0.00
VA VA	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3102 Variable Speed Drive Control, 15 HP	School School	2014 2014	2054 2054	121.57 89.82	24.08 22.48	19.79 31.75	19.79 51.55	14% 36%	3.51 1.59	3.51 5.10	13% 18%	0.05 0.06	0.05 0.06	0 1	0	1.45 1.09			19.79 31.75	3.51 1.59
VA	3100	3103 Air Handler Optimization, 15 HP	School	2014	2054	81.08	22.46	8.74	60.28	43%	0.44	5.54	20%	0.08	0.06	2	1	0.72			0.00	0.00
VA	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	School	2014	2054	80.29	21.89	0.78	61.07	43%	0.15	5.69	21%	0.20	0.06	1	1	0.43			0.00	0.00
VA VA	3100 3100	3105 Energy Recovery Ventilation (ERV) 3107 Demand Controlled Ventilation	School School	2014 2014	2054 2054	76.08 64.71	20.43 16.46	4.21 11.38	65.28 76.65	46% 54%	1.47 3.96	7.16 11.12	26% 40%	0.71 2.88	0.10 0.51	2 8	1	0.14 0.03			0.00	0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	School	2014	2054	58.92	11.50	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	58.92	11.50	0.00	0.00
VA VA	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	School School	2014 2014	2054 2054	43.53 43.44	10.73 10.71	15.39 0.09	15.39 15.48	26% 26%	0.77	0.77	7% 7%	0.01	0.01	0	0	8.91 2.43			15.39 0.09	0.77
VA	3200	3203 Air Handler Optimization, 40 HP	School	2014	2054	39.21	10.71	4.23	19.71	33%	0.02	1.00	9%	0.03	0.01	1	0	0.83			0.09	0.02
VA	3200	3204 Demand Controlled Ventilation	School	2014	2054	33.35	8.45	5.86	25.58	43%	2.04	3.04	26%	2.33	0.55	7	5	0.04			0.00	0.00
VA VA	4000 4100	4000 Base Built-Up Refrigeration System 4100 Base Self-Contained Refrigeration	School School	2014 2014	2054 2054	0.00 66.40	0.00 9.18	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 66.40	0.00 9.18	0.00	0.00
VA	4100	4103 Night covers for display cases (self-contained)	School	2014	2054	64.09	8.87	2.30	2.30	3%	0.32	0.32	3%	0.00	0.00	0	0	22.96	00.10	0.10	2.30	0.32
VA VA	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	School School	2014 2014	2054 2054	63.22 62.88	8.74 8.70	0.88 0.34	3.18 3.52	5% 5%	0.12 0.05	0.44 0.49	5% 5%	0.00 0.01	0.00	0	0	14.04 9.18			0.88 0.34	0.12 0.05
VA	4100	4109 Energy-Star Freezer, glass door 4106 Energy-Star Refrigerator, solid door	School	2014	2054	62.07	8.58	0.81	4.33	7%	0.05	0.60	7%	0.01	0.00	0	0	5.57			0.81	0.05
VA	4100	4107 Energy-Star Freezer, solid door	School	2014	2054	61.93	8.57	0.14	4.47	7%	0.02	0.62	7%	0.02	0.01	0	0	3.66			0.14	0.02
VA VA	4100 4100	4108 Energy-Star Refrigerator, glass door 4110 Energy Star Ice Machines	School School	2014 2014	2054 2054	61.68 60.41	8.53 8.36	0.25 1.27	4.72 5.99	7% 9%	0.03 0.18	0.65 0.83	7% 9%	0.02	0.01 0.01	0	0	3.05 2.02			0.25 1.27	0.03 0.18
VA	4100	4112 Reach-in unit occupancy sensors	School	2014	2054	60.40	8.35	0.01	6.00	9%	0.00	0.83	9%	0.29	0.01	2	ō	0.22			0.00	0.00
VA VA	4100 4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	School School	2014 2014	2054 2054	60.34 60.29	8.35 8.34	0.05 0.05	6.06 6.11	9% 9%	0.01 0.01	0.84 0.84	9% 9%	0.33 1.05	0.01 0.02	2	0	0.18 0.05			0.00	0.00
VA	5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	School	2014	2054	10.42	0.90	0.05	0.00	9% 0%	0.00	0.84	9% 0%	1.05 N/A	0.02 N/A	N/A	N/A	0.05 N/A	10.42	0.90	0.00	0.00
VA	5000	5001 PC Network Power Management Enabling	School	2014	2054	5.73	0.69	4.69	4.69	45%	0.21	0.21	23%	0.01	0.01	0	0	3.72			4.69	0.21
VA VA	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	School School	2014 2014	2054 2054	4.06 1.16	0.55 0.10	1.66 0.00	6.36 0.00	61% 0%	0.14	0.35	39% 0%	0.03 N/A	0.02 N/A	0 N/A	0 N/A	1.90 N/A	1.16	0.10	1.66 0.00	0.14
VA	5100	5102 Energy Star or Better Laptop	School	2014	2054	0.94	0.08	0.22	0.22	19%	0.02	0.02	19%	0.01	0.01	0	0	5.06	0	0.10	0.22	0.02
VA VA	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	School School	2014 2014	2054 2054	0.92 4.23	0.08	0.02	0.24	21% 0%	0.00	0.02	21% 0%	1.24 N/A	0.11 N/A	14 N/A	1 N/A	0.04 N/A	4.23	0.36	0.00	0.00
VA	5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	School	2014	2054	1.85	0.36	2.37	2.37	56%	0.00	0.20	56%	0.00	0.00	0	0	40.23	4.23	0.36	2.37	0.20
VA	5200	5202 Monitor Power Management Enabling - CRT	School	2014	2054	1.34	0.14	0.51	2.89	68%	0.02	0.23	62%	0.02	0.00	0	0	2.55			0.51	0.02
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	School School	2014 2014	2054 2054	1.23 2.18	0.13 0.19	0.11	2.99 0.00	71% 0%	0.01 0.00	0.24	65% 0%	0.22 N/A	0.01 N/A	3 N/A	0 N/A	0.24 N/A	2.18	0.19	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	School	2014	2054	1.80	0.15	0.39	0.39	18%	0.03	0.03	18%	0.01	0.01	0	0	5.92	2.10	0.10	0.39	0.03
VA VA	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	School School	2014 2014	2054 2054	1.75 1.62	0.15 0.15	0.04 0.13	0.43 0.56	20% 26%	0.00	0.04 0.04	19% 20%	0.08 0.23	0.02 0.07	2 10	0	0.61 0.20			0.00	0.00
VA	5400	5400 Base Copier	School	2014	2054	2.78	0.15	0.00	0.00	0%	0.00	0.04	0%	0.23 N/A	N/A	N/A	N/A	0.20 N/A	2.78	0.24	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	School	2014	2054	2.62	0.23	0.16	0.16	6%	0.01	0.01	6%	0.00	0.00	0	0	33.32			0.16	0.01
VA VA	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	School School	2014 2014	2054 2054	2.52 0.34	0.22	0.11	0.27	10% 0%	0.00	0.02	8% 0%	0.09 N/A	0.04 N/A	2 N/A	1 N/A	0.60 N/A	0.34	0.03	0.00	0.00
VA	5500	5502 ENERGY STAR Multi-Function Printer	School	2014	2054	0.26	0.02	0.09	0.09	25%	0.01	0.01	25%	0.01	0.01	0	0	8.62			0.09	0.01
VA VA	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	School School	2014 2014	2054 2054	0.21 2.91	0.02 0.25	0.05 0.00	0.13 0.00	39% 0%	0.00	0.01 0.00	32% 0%	0.27 N/A	0.10 N/A	6 N/A	1 N/A	0.19 N/A	2.91	0.25	0.00	0.00
VA	5600	5602 ENERGY STAR Printer	School	2014	2054	1.90	0.23	1.01	1.01	35%	0.00	0.00	35%	0.00	0.00	0	0	39.62	2.91	0.23	1.01	0.00
VA	5600	5601 Printer Power Management Enabling	School	2014	2054	1.55	0.15	0.35	1.36	47%	0.02	0.10	41%	0.06	0.02	1	0	0.87			0.00	0.00
VA VA	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	School School	2014 2014	2054 2054	67.83 61.05	5.83 5.24	0.00 6.78	0.00 6.78	0% 10%	0.00 0.58	0.00 0.58	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 111.93	67.83	5.83	0.00 6.78	0.00 0.58
VA	5700	5702 Data Center Best Practices	School	2014	2054	53.28	4.58	7.77	14.55	21%	0.67	1.25	21%	0.00	0.00	0	0	45.57			7.77	0.67
VA	5700	5703 Data Center State of the Art practices	School	2014	2054	50.30	4.32	2.98	17.53	26%	0.26	1.51	26%	0.00	0.00	0	0	23.63	00.00	4.05	2.98	0.26
VA VA	6000 6000	6000 Base Water Heating 6007 Heat Trap	School School	2014 2014	2054 2054	23.82 22.58	1.85 1.76	0.00 1.23	0.00 1.23	0% 5%	0.00 0.10	0.00 0.10	0% 5%	N/A 0.04	N/A 0.04	N/A 1	N/A 1	N/A 1.45	23.82	1.85	0.00 1.23	0.00 0.10
VA	6000	6002 High Efficiency Water Heater (electric)	School	2014	2054	22.14	1.72	0.44	1.67	7%	0.03	0.13	7%	0.09	0.06	1	1	0.77			0.00	0.00
VA VA	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	School School	2014 2014	2054 2054	19.99 19.24	1.55 1.50	2.16 0.75	3.83 4.58	16% 19%	0.17 0.06	0.30 0.36	16% 19%	0.09 0.12	0.07	1	1	0.71 0.59			0.00	0.00
VA	6000	6004 Tankless Water Heater	School	2014	2054	17.79	1.38	1.44	6.02	25%	0.06	0.36	25%	0.12	0.10	2	1	0.59			0.00	0.00
VA	6000	6008 Solar Water Heater	School	2014	2054	16.55	1.29	1.25	7.27	31%	0.10	0.57	31%	0.18	0.11	2	1	0.41			0.00	0.00
VA VA	6000 7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	School School	2014 2014	2054 2054	16.38 6.12	1.27 0.53	0.17 0.00	7.43 0.00	31% 0%	0.01	0.58 0.00	31% 0%	0.20 N/A	0.11 N/A	3 N/A	1 N/A	0.34 N/A	6.12	0.53	0.00	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	School	2014	2054	5.19	0.49	0.93	0.93	15%	0.04	0.04	8%	0.03	0.03	1	1	2.01			0.93	0.04
VA VA	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	School School	2014 2014	2054 2054	4.69 0.09	0.47 0.01	0.51 0.00	1.43 0.00	23%	0.02	0.06 0.00	12% 0%	0.05 N/A	0.03 N/A	1 N/A	1 N/A	1.10 N/A	0.09	0.01	0.51 0.00	0.02
***	7 100		201001	2014	2004	0.00	0.01	5.50	0.00	U 70	0.00	0.00	J 70			.4/1	. 4/7		0.00	0.01	0.00	0.00

DNV GL H-11 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average					
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt VA	Number 7100	Number Measure 7101 Vending Misers (Non-Refrigerated)	Type School	Year 2014	Year 2054	0.05	0.01	Savings 0.04	GWH 0.04	Savings 43%	Savings 0.00	0.00	Savings 22%	\$/kWH 0.43	\$/kWH 0.43	\$/kW 10	\$/kW 10	0.12	GWH	MW	0.00	0.00
VA	7200	7200 Base Oven	School	2014	2054	6.68	0.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.68	0.49	0.00	0.00
VA VA	7200 7300	7201 Convection Oven 7300 Base Fryer	School School	2014 2014	2054 2054	5.15 1.19	0.38	1.54 0.00	1.54 0.00	23% 0%	0.11 0.00	0.11	23% 0%	0.13 N/A	0.13 N/A	2 N/A	2 N/A	0.49 N/A	1.19	0.09	0.00	0.00
VA	7400	7400 Base Steamer	School	2014	2054	0.32	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.32	0.02	0.00	0.00
VA VA	7400 8000	7401 Efficient Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	School School	2014 2014	2054 2054	0.12 4.30	0.01	0.21	0.21	63% 0%	0.02	0.02	63% 0%	0.05 N/A	0.05 N/A	1 N/A	1 N/A	1.29 N/A	4.30	0.00	0.21	0.02
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School	2014	2054	4.06	0.00	0.24	0.24	6%	0.00	0.00	0%	0.08	0.08	N/A	N/A	0.83			0.00	0.00
VA	8100	8100 Base Heating, Other Electric	School	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	9500 9500	9500 Base Miscellaneous 9501 Xmisc	School School	2014 2014	2054 2054	93.87 93.87	8.18 8.18	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	93.87	8.18	0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Health	2020	2054	152.78	23.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	152.78	23.25	0.00	0.00
VA VA	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Health Health	2020 2020	2054 2054	152.55 140.86	23.23	0.23 11.70	0.23 11.92	0% 8%	0.02 1.39	0.02 1.41	0% 6%	0.02	0.02	0	0	2.65			0.23 11.70	0.02 1.39
VA	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Health	2020	2054	126.21	19.61	14.65	26.57	17%	2.23	3.64	16%	0.03	0.03	0	0	1.78			14.65	2.23
VA VA	1030 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Health Health	2020 2020	2054 2054	110.15 101.99	17.17 16.88	16.06 8.16	42.63 50.79	28% 33%	2.44 0.29	6.08 6.37	26% 27%	0.07 0.12	0.05 0.06	0	0	0.85 0.45			0.00	0.00
VA	1030	1037 Occupancy Sensor, 4L4 Problescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Health	2020	2054	85.56	14.38	16.43	67.22	33% 44%	2.50	8.87	38%	0.12	0.06	3	1	0.45			0.00	0.00
VA	1030	1035 LED Troffer (base 4L4'T8), 2020	Health	2020	2054	78.25	13.27	7.30	74.52	49%	1.11	9.98	43%	0.36	0.17	2	.1	0.19			0.00	0.00
VA VA	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Health Health	2020 2020	2054 2054	18.41 16.50	2.80 2.51	0.00 1.92	0.00 1.92	0% 10%	0.00 0.29	0.00 0.29	0% 10%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.52	18.41	2.80	0.00 1.92	0.00 0.29
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Health	2020	2054	16.48	2.51	0.02	1.94	11%	0.00	0.29	10%	0.05	0.04	1	0	1.13			0.02	0.00
VA VA	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Health Health	2020 2020	2054 2054	15.21 13.28	2.36	1.26 1.94	3.20 5.14	17% 28%	0.15 0.29	0.44 0.74	16% 26%	0.07	0.05 0.07	1	0	0.99 0.67			0.00	0.00
VA	1130	1132 ROB 2L4 Low Watt High Performance 18 (75 W), 2020 1134 ROB 2L4 LED Tube, 2020	Health	2020	2054	13.28	1.97	0.64	5.14	28% 31%	0.29	0.74	30%	0.09	0.07	2	1	0.67			0.00	0.00
VA	1130	1135 LED Troffer (base 2L4'T8), 2020	Health	2020	2054	11.56	1.80	1.08	6.86	37%	0.16	1.00	36%	0.41	0.14	3	1	0.17			0.00	0.00
VA VA	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	Health Health	2020 2014	2054 2054	10.70 4.95	1.77 0.75	0.86 0.00	7.71 0.00	42% 0%	0.03	1.03 0.00	37% 0%	0.25 N/A	0.16 N/A	7 N/A	1 N/A	0.22 N/A	4.95	0.75	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Health	2014	2054	4.92	0.75	0.03	0.03	1%	0.00	0.00	0%	0.01	0.01	0	0	7.14	1.00	0.70	0.03	0.00
VA VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Health Health	2014 2014	2054 2054	4.54 4.07	0.71	0.38 0.47	0.40 0.88	8% 18%	0.04	0.05 0.12	6% 16%	0.08 0.14	0.08 0.11	1	1	0.87 0.44			0.00	0.00
VA	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Health	2014	2054	3.28	0.63	0.47	1.67	34%	0.07	0.12	19%	0.14	0.11	4	1	0.44			0.00	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Health	2014	2054	2.86	0.54	0.42	2.08	42%	0.06	0.21	28%	0.35	0.17	2	2	0.17			0.00	0.00
VA VA	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Health Health	2020 2020	2054 2054	8.93 1.60	1.36	0.00 7.33	0.00 7.33	0% 82%	0.00 1.12	0.00 1.12	0% 82%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.98	8.93	1.36	0.00 7.33	0.00 1.12
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Health	2020	2054	3.22	0.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.22	0.49	0.00	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020	Health	2020 2020	2054	0.63	0.10	2.59 0.00	2.59	81%	0.39	0.39	81% 0%	0.01 N/A	0.01 N/A	0	0 N/A	5.89	0.07	0.36	2.59	0.39
VA	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Health Health	2020	2054 2054	2.37 0.63	0.36 0.10	1.74	1.74	0% 73%	0.00	0.00 0.26	73%	0.01	0.01	N/A 0	0	N/A 4.37	2.37	0.36	0.00 1.74	0.00
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Health	2020	2054	3.00	0.46	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.00	0.46	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Health Health	2020 2020	2054 2054	2.17 3.83	0.33	0.83	0.83	28% 0%	0.13	0.13	28% 0%	0.09 N/A	0.09 N/A	1 N/A	1 N/A	0.68 N/A	3.83	0.58	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Health	2020	2054	2.83	0.43	1.00	1.00	26%	0.15	0.15	26%	0.07	0.07	0	0	0.90			0.00	0.00
VA VA	1800 1850	1800 BaseMetal Halide, 465W 1850 Base CFL Exit Sign	Health Health	2014 2014	2054 2054	0.00 4.72	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 4.72	0.00 0.72	0.00	0.00
VA	1850	1851 LED Exit Sign	Health	2014	2054	4.17	0.63	0.55	0.55	12%	0.08	0.08	12%	0.03	0.03	0	0	2.21	4.72	0.72	0.55	0.00
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Health	2014	2054	12.58	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.58	0.12	0.00	0.00
VA VA	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Health Health	2014 2014	2054 2054	11.58 5.57	0.09	1.00 6.01	1.00 7.01	8% 56%	0.03	0.03	27% 74%	0.07 0.14	0.07 0.13	2 15	2 11	1.03 0.45			1.00 0.00	0.03
VA	1900	1903 Bi-Level LED Outdoor Lighting	Health	2014	2054	3.93	0.02	1.64	8.65	69%	0.01	0.10	86%	0.92	0.28	109	24	0.07			0.00	0.00
VA VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Health Health	2014 2014	2054 2054	66.67 60.98	36.64 33.51	0.00 5.69	0.00 5.69	0% 9%	0.00 3.13	0.00 3.13	0% 9%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.33	66.67	36.64	0.00 5.69	0.00 3.13
VA	2000	2005 Chiller Tune Up/Diagnostics	Health	2014	2054	60.88	33.49	0.10	5.79	9%	0.03	3.15	9%	0.02	0.03	0	0	2.95			0.10	0.03
VA	2000	2006 VSD for Chiller Pumps and Towers	Health	2014	2054	60.75	33.45	0.14	5.93	9%	0.04	3.19	9%	0.04	0.03	0	0	2.21			0.14	0.04
VA VA	2000 2000	2013 High Efficiency Chiller Motors 2003 EMS - Chiller	Health Health	2014 2014	2054 2054	60.55 54.79	33.34 32.60	0.20 5.75	6.12 11.88	9% 18%	0.11 0.74	3.30 4.04	9% 11%	0.05 0.05	0.03 0.04	0	0	2.14 1.26			0.20 5.75	0.11 0.74
VA	2000	2012 Duct Testing/Sealing - Chiller	Health	2014	2054	44.38	26.88	10.41	22.29	33%	5.72	9.76	27%	0.18	0.11	0	ō	0.61			0.00	0.00
VA VA	2000 2000	2008 New Economizer - Chiller 2002 Window Film (Standard) - Chiller	Health Health	2014 2014	2054 2054	39.35 39.29	26.24 26.20	5.03 0.06	27.32 27.38	41% 41%	0.65 0.03	10.41 10.44	28% 28%	0.14 0.29	0.11 0.11	1	0	0.44 0.29			0.00	0.00
VA	2000	2004 Cool Roof - Chiller	Health	2014	2054	39.18	26.14	0.11	27.49	41%	0.06	10.50	29%	0.23	0.11	i	0	0.11			0.00	0.00
VA	2000	2011 Duct/Pipe Insulation - Chiller	Health	2014	2054	38.74	25.90	0.44	27.93	42%	0.24	10.74	29%	2.99	0.16	5	0	0.03	000 10	400.00	0.00	0.00
VA VA	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons 2102 DX Packaged System, EER=13.4, 10 tons	Health Health	2014 2014	2054 2054	223.12 171.80	122.63 94.42	0.00 51.32	0.00 51.32	0% 23%	0.00 28.20	0.00 28.20	0% 23%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.49	223.12	122.63	0.00 51.32	0.00 28.20
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Health	2014	2054	171.64	94.38	0.16	51.48	23%	0.04	28.25	23%	0.09	0.03	0	0	0.75			0.00	0.00
VA VA	2100 2100	2108 Optimize Controls - DX 2106 Prog. Thermostat - DX	Health Health	2014 2014	2054 2054	168.50 165.02	93.98 93.53	3.14 3.48	54.62 58.10	24% 26%	0.40 0.45	28.65 29.10	23% 24%	0.07 0.09	0.03	1	0	0.72 0.64			0.00	0.00
VA	2100	2112 Duct Testing/Sealing - DX	Health	2014	2054	154.98	88.01	10.03	68.14	31%	5.51	34.61	28%	0.19	0.06	0	0	0.55			0.00	0.00
VA	2100	2115 Window Film (Standard) - DX	Health	2014	2054	154.15	87.56	0.83	68.97	31%	0.46	35.07	29%	0.25	0.06	0	0	0.34			0.00	0.00
VA VA	2100 2100	2107 Cool Roof - DX 2114 Duct/Pipe Insulation - DX	Health Health	2014 2014	2054 2054	153.66 151.97	87.29 86.36	0.49 1.69	69.46 71.15	31% 32%	0.27 0.93	35.34 36.27	29% 30%	0.65 2.55	0.07 0.12	1 5	0	0.13 0.03			0.00	0.00
VA	2100	2111 Economizer Repair - DX	Health	2014	2054	151.97	86.36	0.00	71.15	32%	0.00	36.27	30%	23013.76	0.13	27,755	0	0.00			0.00	0.00
VA VA	2100 2200	2109 Economizer - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Health Health	2014 2014	2054 2054	151.97 142.15	86.36 78.13	0.00	71.15 0.00	32% 0%	0.00	36.27 0.00	30% 0%	26793.07 N/A	0.15 N/A	208,511 N/A	0 N/A	0.00 N/A	142.15	78.13	0.00	0.00
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	2014	2054	124.57	68.46	17.58	17.58	12%	9.66	9.66	12%	0.02	0.02	0	0	4.08			17.58	9.66

DNV GL H-12 1/5/2015

APPENDIX H

Base Avoided Costs

			ic Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Bare Macure Mac	Vintage				Measure	Measure	•				Percent			Percent									
1.00 2000										Savings	GWH		Savings	MW	Cost	Cost	Cost	Cost	Cost Test				Economic
No. 1000 2				71.											4,,,,,,,,,,		4,,,,,	4,					
Mail	VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Health	2014	2054	63.96	12.98	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A			N/A			0.00	0.00
Mail																							
No. 1902 100 Bare Privater, 18th, 18																	-	-					
No. 100 3100 10																				222.31	45.13		
No. 100 3104 Estimates (Section as Arthurder Unit Program (Section as Arthurder																	0	0					
No.																							
No. 200																	-	-					
No.																	2	1					
Mathematical Performance Mathematical Perfor																				236.21	47.95		
																				0.00	0.00		
Math																							
May																							
VA																							
VA																							
VA 100 4105 Birbor ED Case Lighting (seel contamend unital) 2014 1864 1875 252 141 100 1	VA	4100	4110 Energy Star Ice Machines	Health	2014	2054	41.07	5.95	0.45	2.68	6%	0.07	0.39	6%	0.05	0.02	0	0	1.38			0.45	0.07
VA																		-					
VA 500 501 Performer Fourer Fromer From From From From From From From Fro																				9.92	1 //1		
VA 5100 5100 Store Store Greater Laptop Health 2014 2054 0.47 0.07 0.00																				3.32	1.41		
VA 5100 5101 Energy Stair or Better Laptop Health 2014 2054 0.42 0.06 0.10 0.10 1.91 1.91 0.01 0.01 1.91 0.01 0.01 0.0																							
VA 5100 510 Laptop Network Proves Miningament Enabling Health 2014 2054 273 0.00																				0.51	0.07		
VA																		-					
VA 5200 5202 Monitor Plower Minangement Enabling - CRT Health 2014 2054 0.73 0.14 0.07 0.17 0.25 65% 0.03 0.02 0.0 0.175 0.00									0.00	0.00	0%				N/A			N/A		2.73	0.39		
VA																							
VA S500 S500 Ease Moniter, LCD Health 2014 2054 1,75 0,25 0,00 0,0																							
VA																				1.75	0.25		
VA																							
VA 5400 5400 Base Copier Health 2014 2054 237 239 0.0																		0					
VA 5400 5401 Energy Star or Better Copier Health 2014 2054 2.30 0.33 0.47 0.47 17% 0.07 0.07 17% 0.00																	-	N/A		2.77	0.39		
VA	VA	5400		Health			2.30	0.33		0.47	17%				0.00		0	0	21.03			0.47	
VA																							
VA																				0.45	0.06		
VA 5600 5602 FNERCY STAR Printer VA 5600 5601 Printer Power Management Enabling Health 2014 2054 1.26 0.19 0.21 0.99 44% 0.02 0.13 40% 0.00 0.00 0.0 0.02 1 0.069 0.00 0.00 VA 5700 6700 Base Data Center/Server Room Health 2014 2054 3.55 0.59 0.99 4.9% 0.02 0.00 0.00 0% NA NA NA NA NA NA NA NA 39.44 5.61 0.00 0.00 VA 5700 5700 Data Centering Improved Operations Health 2014 2054 35.5 0.51 0.99 4.9% 0.00 0.00 0% NA NA NA NA NA NA NA NA 39.44 5.61 0.00 0.00 0.00 0.00 0.00 0.00 0% NA NA NA NA NA NA NA NA NA 39.44 5.61 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																		-					
VA 5600 5601 Printer Power Management Enabling Health 2014 2054 1,25 0.19 0.21 0.99 4.4% 0.02 0.13 40% 0.07 0.02 1 0 0.89 0.00 0.00 0.00 VA 5700 5701 Base Data Center Improved Operations Health 2014 2054 3.561 0.01 0.00 0.0																				2.25	0.32		
VA 5700 5700 Ease Data Center/Server Room Health 2014 2054 39.44 5.61 0.00 0.0																							
VA 5700 5701 Data Center Improved Operations Health 2014 2054 35.50 5.04 3.94 3.94 10% 0.56 0.56 10% 0.00																				39.44	5.61		
VA S700 S703 Data Center State of the Art practices Health 2014 2054 2054 16.04 2.07 0.00 0.																							
VA																							
VA																				16.04	2.07		
VA								1.99		0.60	4%			4%	0.04								0.08
VA 600 6006 Heat Recovery Unit Health 2014 2054 6.89 0.89 7.46 9.15 57% 0.96 1.18 57% 0.08 0.07 1 1 0.84 0.00 0.00 0.00 0.00 0.00 0.00 0.00																	0	0					
VA 6000 6004 Tankless Waier Heater Health 2014 2054 6.37 0.82 0.52 9.67 60% 0.07 1.25 60% 0.26 0.08 2 1 0.30 0.00 0.00 0.00 VA 6000 6008 Solar Water Heater Health 2014 2.054 5.48 0.71 0.89 10.56 66% 0.11 1.36 66% 0.30 0.10 2 1 0.30 0.00 0.00 0.00 VA 6000 6003 Hot Water Pipe Insulation Health 2014 2054 5.43 0.70 0.05 10.61 66% 0.11 1.37 66% 0.35 0.10 3 1 0.20 0.0																	1	1					
VA 6000 6008 Solar Water Heater Health 2014 2054 5.48 0.71 0.89 10.56 66% 0.31 0.10 2 1 0.26 0.00 0.00 0.00 VA 6000 6003 Hot Water Pipe Insulation Health 2014 2054 5.43 0.70 0.05 10.61 66% 0.01 1.37 66% 0.35 0.10 3 1 0.26 0.00 0.00 0.00 VA 7000 7000 Base Refrigerated Vending Machines Health 2014 2054 6.16 0.86 0.00 0.00 0.00 0.00 N/A N/A N/A N/A 0.02 0.00 0.00 VA 7000 7001 Vending Misers (Refrigerated glass-front units) Health 2014 2054 4.64 0.75 0.54 1.52 25% 0.04 0.01 12% 0.03 0.0 0 0 0 0.0 0 0 0 0 0 0																		1					
VA 7000 7000 Base Refrigerated Vending Machines Health 2014 2054 6.16 0.86 0.00 0.00 0% 0.00 0% NA NA NA NA NA NA NA NA 6.6 0.86 0.00 0.00 0.00 0% NA NA NA NA NA NA NA NA NA 6.6 0.86 0.00 0.00 0.00 0% NA													1.36					1					
VA 700 7001 Vending Misers (Refrigerated units) Health 2014 2054 5.17 0.79 0.98 1.98 16% 0.07 0.07 8% 0.03 0.0 0 2.04 0.98 0.07 VA 7000 7002 Vending Misers (Refrigerated glass-front units) Health 2014 2054 4.64 0.75 0.54 1.52 25% 0.04 0.10 12% 0.05 0.03 1 0 1.11 0 0.04 0.04 0.04 0.04 0.05 0.04 0.05 0.03 1 0 1.01 1.0 1.11 0 1.11 0 0.04 0.00																		1 N/A		6 16	0.06		
VA 7000 7002 Vending Misers (Refrigerated glass-front units)			7000 Base Refrigerated Verloing Macrilles 7001 Vending Misers (Refrigerated units)																	6.16	0.00		
VA 7100 7101 Vending Misers (Non-Refrigerated)	VA	7000	7002 Vending Misers (Refrigerated glass-front units)		2014	2054		0.75	0.54	1.52	25%	0.04	0.10	12%	0.05	0.03	1		1.11			0.54	0.04
VA 7200 7200 Base Oven Health 2014 2054 9.72 1.85 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A N/A 9.72 1.85 0.00 0.00 VA 7300 7300 Base Fryer Health 2014 2054 9.37 1.79 0.00 0.00 0% 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A N/A 9.37 1.79 0.00 0.00																				0.12	0.02		
VA 7300 7300 Base Fryer Health 2014 2054 9.37 1.79 0.00 0.00 0% 0.00 0% N/A N/A N/A N/A N/A 9.37 1.79 0.00 0.00																				9.72	1.85		
VA 7300 7301 Efficient Erver Health 2014 2054 8.77 1.67 0.60 0.60 6% 0.11 0.11 6% 0.43 0.43 2 2 0.46 0.00 0.00																							
	VA	7300	7301 Efficient Fryer	Health	2014	2054	8.77	1.67	0.60	0.60	6%	0.11	0.11	6%	0.43	0.43	2	2	0.16			0.00	0.00
VA 7400 7400 Base Steamer Health 2014 2054 8.41 1.61 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A N/A 8.41 1.61 0.00 0.00 0.00 0.00 0.00 0.00 0.0																							
VA 8000 8000 Base Heating, Heat Pump (7.7 HSPF) Health 2014 2054 17.94 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																				17.94	0.00		
VA 8100 8100 Base Heating, Other Electric Health 2014 2054 25.25 0.00 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A 25.25 0.00 0.00 0.00	VA	8100	8100 Base Heating, Other Electric	Health	2014	2054	25.25	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A			0.00	0.00
VA 9500 9500 Base Miscellaneous Health 2014 2054 378.95 52.75 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A 378.95 52.75 0.00 0.00																				378.95	52.75		
VA 9500 9501 Xmisc Health 2014 2054 378.95 52.75 0.00 0.00 0% 0.00 0.00 0% N/A N/A N/A N/A N/A 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.																				9.24	1 31		
VA 1030 1030 Basse Fidule-scenii Fixture, 44-1 6, 1EB, 2020 Loughing 2020 2054 9.24 1.31 0.00 0.00 0% 0.00 0.00 0% IVA																				J.24	1.31		
VA 1030 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 Lodging 2020 2054 7.23 1.02 1.05 2.01 22% 0.15 0.29 22% 0.05 0.04 0 0 1.37 1.05 0.15	VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Lodging	2020	2054	7.23	1.02	1.05	2.01	22%	0.15	0.29	22%	0.05	0.04	0	0	1.37			1.05	0.15

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
0	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
VA	Number 1030	Number Measure 1036 Lighting Control Tuneup (base 4L4'T8), 2020	Type Lodging	Year 2020	Year 2054	GWH 7.19	MW 1.02	Savings 0.03	2.05	Savings 22%	Savings 0.00	MW 0.29	Savings 22%	\$/kWH 0.05	\$/kWH 0.04	\$/kW	\$/kW	1.11	GWH	MW	0.03	0.00
VA	1030	1036 Eighting Control Fulledp (base 4L4 T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4 T8), 2020	Lodging	2020	2054	6.64	0.96	0.55	2.60	28%	0.06	0.25	27%	0.03	0.05	i	0	0.96			0.00	0.00
VA	1030	1034 ROB 4L4' LED Tube, 2020	Lodging	2020	2054	5.57	0.81	1.07	3.67	40%	0.15	0.50	38%	0.35	0.14	3	1	0.23			0.00	0.00
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Lodging	2020	2054	5.41	0.80	0.16	3.83	41%	0.01	0.51	39%	0.18	0.14	5	1	0.31			0.00	0.00
VA VA	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Lodging Lodging	2020 2020	2054 2054	4.95 37.39	0.74 5.29	0.46 0.00	4.29 0.00	46% 0%	0.07	0.57	44% 0%	0.30 N/A	0.15 N/A	2 N/A	1 N/A	0.26 N/A	37.39	5.29	0.00	0.00
VA	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Lodging	2020	2054	33.50	4.74	3.89	3.89	10%	0.55	0.55	10%	0.03	0.03	0	0	2.26	01.00	0.20	3.89	0.55
VA	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Lodging	2020	2054	29.24	4.14	4.26	8.15	22%	0.60	1.15	22%	0.06	0.05	0	0	1.08			4.26	0.60
VA VA	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Lodging	2020 2020	2054 2054	29.10 26.87	4.13 3.88	0.13 2.23	8.28 10.52	22% 28%	0.01 0.25	1.16 1.41	22% 27%	0.07 0.10	0.05 0.06	1	0	0.79			0.00	0.00
VA	1130	1136 Right Performance Lighting R/R - 25% Savings (base 2L4 16), 2020 1134 ROB 2L4' LED Tube, 2020	Lodging Lodging	2020	2054	25.57	3.70	1.30	11.82	32%	0.25	1.59	30%	0.10	0.08	2	1	0.69			0.00	0.00
VA	1130	1135 LED Troffer (base 2L4'T8), 2020	Lodging	2020	2054	23.39	3.39	2.18	14.00	37%	0.31	1.90	36%	0.37	0.13	3	1	0.22			0.00	0.00
VA	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Lodging	2020	2054	22.73	3.37	0.66	14.66	39%	0.02	1.92	36%	0.30	0.14	9	1	0.18	0.70	0.40	0.00	0.00
VA VA	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Lodging Lodging	2014 2014	2054 2054	0.73	0.10 0.10	0.00 0.02	0.00 0.02	0% 3%	0.00	0.00	0% 1%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.70	0.73	0.10	0.00	0.00
VA	1200	1201 ROB High Performance T8 (base other fluorescent)	Lodging	2014	2054	0.63	0.09	0.02	0.02	13%	0.00	0.01	11%	0.10	0.02	1	1	0.69			0.02	0.00
VA	1200	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Lodging	2014	2054	0.55	0.08	0.08	0.17	24%	0.01	0.02	22%	0.21	0.14	1	1	0.33			0.00	0.00
VA VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Lodging	2014 2014	2054 2054	0.51 0.47	0.07	0.04 0.04	0.22 0.25	30% 35%	0.00	0.03	27% 28%	0.23 0.20	0.16 0.17	2 6	1	0.30 0.28			0.00	0.00
VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Lodging Lodging	2014	2054	56.01	7.93	0.04	0.25	0%	0.00	0.03	0%	0.20 N/A	0.17 N/A	N/A	N/A	0.26 N/A	56.01	7.93	0.00	0.00
VA	1330	1332 LEDs (base incandescent flood) 2020	Lodging	2020	2054	10.81	1.53	45.20	45.20	81%	6.40	6.40	81%	0.01	0.01	0	0	8.95			45.20	6.40
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Lodging	2020	2054	20.16	2.85	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	20.16	2.85	0.00	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Lodging	2020 2020	2054 2054	4.23 14.84	0.60 2.10	15.94 0.00	15.94 0.00	79% 0%	2.26 0.00	2.26	79% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	7.54 N/A	14.84	2.10	15.94 0.00	2.26 0.00
VA	1530	1530 base incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Lodging Lodging	2020	2054	4.24	0.60	10.60	10.60	71%	1.50	1.50	71%	0.01	0.01	0	0	5.55	14.04	2.10	10.60	1.50
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Lodging	2020	2054	11.67	1.65	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	11.67	1.65	0.00	0.00
VA	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Lodging	2020	2054	8.44	1.19	3.23	3.23	28%	0.46	0.46	28%	0.09	0.09	1	1	0.81			0.00	0.00
VA VA	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Lodging Lodging	2020 2020	2054 2054	14.91 11.03	2.11 1.56	0.00 3.88	0.00 3.88	0% 26%	0.00 0.55	0.00 0.55	0% 26%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.07	14.91	2.11	0.00 3.88	0.00 0.55
VA	1800	1800 BaseMetal Halide, 465W	Lodging	2014	2054	29.88	4.23	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	29.88	4.23	0.00	0.00
VA	1800	1801 T5 (240W) (base metal halide)	Lodging	2014	2054	19.78	2.80	10.10	10.10	34%	1.43	1.43	34%	0.02	0.02	0	0	4.03			10.10	1.43
VA	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Lodging	2014	2054	18.26	2.63	1.52	11.62	39%	0.17	1.60	38%	0.05	0.02	0	0	1.42			1.52	0.17
VA VA	1800 1850	1806 Occupancy Sensor, High Bay T5 1850 Base CFL Exit Sign	Lodging Lodging	2014 2014	2054 2054	17.63 6.70	2.61 0.95	0.63	12.25	41% 0%	0.02	1.62 0.00	38% 0%	0.05 N/A	0.02 N/A	2 N/A	0 N/A	1.07 N/A	6.70	0.95	0.63	0.02
VA	1850	1851 LED Exit Sign	Lodging	2014	2054	3.78	0.54	2.91	2.91	44%	0.41	0.41	44%	0.03	0.03	0	0	2.00	0.70	0.55	2.91	0.41
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Lodging	2014	2054	43.47	0.37	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	43.47	0.37	0.00	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Lodging	2014	2054	39.90	0.27	3.56 20.70	3.56	8%	0.10 0.18	0.10	28%	0.05	0.05	2	2 8	1.46			3.56	0.10
VA VA	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Lodging Lodging	2014 2014	2054 2054	19.20 13.55	0.09	5.65	24.27 29.92	56% 69%	0.18	0.28 0.33	75% 87%	0.10 0.65	0.09 0.20	12 83	8 18	0.64 0.10			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Lodging	2014	2054	150.18	90.43	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	150.18	90.43	0.00	0.00
VA	2000	2002 Window Film (Standard) - Chiller	Lodging	2014	2054	144.75	87.16	5.43	5.43	4%	3.27	3.27	4%	0.03	0.03	0	0	2.93			5.43	3.27
VA VA	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	Lodging Lodging	2014 2014	2054 2054	132.40 129.34	79.72 78.84	12.36 3.05	17.78 20.84	12% 14%	7.44 0.88	10.71 11.59	12% 13%	0.05 0.04	0.04 0.04	0	0	2.23 1.90			12.36 3.05	7.44 0.88
VA	2000	2013 High Efficiency Chiller Motors	Lodging	2014	2054	129.34	78.84	0.01	20.84	14%	0.00	11.59	13%	0.04	0.04	0	0	1.43			0.01	0.00
VA	2000	2006 VSD for Chiller Pumps and Towers	Lodging	2014	2054	128.83	78.69	0.51	21.35	14%	0.15	11.74	13%	0.06	0.04	0	0	1.30			0.51	0.15
VA	2000	2008 New Economizer - Chiller	Lodging	2014	2054	81.45	72.03	47.38	68.73	46%	6.66	18.40	20%	0.06	0.06	0	0	0.98			0.00	0.00
VA VA	2000	2003 EMS - Chiller 2012 Duct Testing/Sealing - Chiller	Lodging Lodging	2014 2014	2054 2054	74.71 60.52	71.08 62.53	6.74 14.20	75.47 89.66	50% 60%	0.95 8.55	19.35 27.90	21% 31%	0.13 0.43	0.06 0.12	1	0	0.52 0.26			0.00	0.00
VA	2000	2004 Cool Roof - Chiller	Lodging	2014	2054	60.40	62.46	0.12	89.78	60%	0.07	27.97	31%	1.93	0.12	3	0	0.05			0.00	0.00
VA	2000	2011 Duct/Pipe Insulation - Chiller	Lodging	2014	2054	60.09	62.28	0.30	90.09	60%	0.18	28.15	31%	4.61	0.14	8	0	0.02			0.00	0.00
VA VA	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons 2115 Window Film (Standard) - DX	Lodging Lodging	2014 2014	2054 2054	383.60 363.95	230.99 219.16	0.00 19.65	0.00 19.65	0% 5%	0.00 11.83	0.00 11.83	0% 5%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.87	383.60	230.99	0.00 19.65	0.00 11.83
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons	Lodging	2014	2054	280.25	168.75	83.71	103.36	5% 27%	50.41	62.24	5% 27%	0.03	0.03	0	0	2.87			83.71	50.41
VA	2100	2108 Optimize Controls - DX	Lodging	2014	2054	275.11	168.03	5.13	108.49	28%	0.72	62.96	27%	0.08	0.04	1	0	0.65			0.00	0.00
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Lodging	2014	2054	271.25	166.91	3.87	112.36	29%	1.11	64.07	28%	0.15	0.05	1	0	0.47			0.00	0.00
VA VA	2100 2100	2106 Prog. Thermostat - DX 2112 Duct Testing/Sealing - DX	Lodging Lodging	2014 2014	2054 2054	263.28 247.27	165.79 156.16	7.97 16.01	120.32 136.33	31% 36%	1.12 9.64	65.19 74.83	28% 32%	0.14 0.31	0.05	1	0	0.40 0.35			0.00	0.00
VA	2100	2111 Economizer Repair - DX	Lodging	2014	2054	246.00	155.00	1.27	137.60	36%	1.15	75.98	33%	0.89	0.09	i	0	0.09			0.00	0.00
VA	2100	2107 Cool Roof - DX	Lodging	2014	2054	245.52	154.71	0.48	138.08	36%	0.29	76.27	33%	1.21	0.10	2	0	0.07			0.00	0.00
VA	2100 2100	2109 Economizer - DX	Lodging	2014	2054	241.48	154.15	4.03	142.12	37% 37%	0.57	76.84	33%	1.05	0.12	7	0	0.06			0.00	0.00
VA VA	2100 2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2114 Duct/Pipe Insulation - DX	Lodging Lodging	2014 2014	2054 2054	241.48 238.85	154.14 152.57	0.01 2.62	142.13 144.75	37% 38%	0.00 1.58	76.84 78.42	33% 34%	1.77 2.97	0.12	13 5	0	0.03			0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Lodging	2014	2054	297.25	178.99	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	297.25	178.99	0.00	0.00
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	2014	2054	260.49	156.85	36.76	36.76	12%	22.14	22.14	12%	0.03	0.03	0	0	3.96			36.76	22.14
VA	2300 2300	2300 Base PTAC, EER=8.3, 1 ton	Lodging	2014	2054	62.42	37.58	0.00	0.00	0% 14%	0.00	0.00	0% 14%	N/A	N/A	N/A	N/A	N/A 1.25	62.42	37.58	0.00	0.00
VA VA	2300	2301 HE PTAC, EER=9.6, 1 ton 2302 Occupancy Sensor (hotels)	Lodging Lodging	2014 2014	2054 2054	53.96 48.11	32.49 27.74	8.45 5.85	8.45 14.31	14% 23%	5.09 4.75	5.09 9.84	14% 26%	0.08 0.26	0.08 0.15	0	0	1.35 0.39			8.45 0.00	5.09 0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Lodging	2014	2054	250.99	53.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	250.99	53.08	0.00	0.00
VA	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Lodging	2014	2054	246.66	52.17	4.33	4.33	2%	0.92	0.92	2%	0.03	0.03	0	0	2.66			4.33	0.92
VA VA	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Lodging	2014 2014	2054 2054	212.47 0.00	37.30 0.00	34.19 0.00	38.52 0.00	15% 0%	14.87 0.00	15.78 0.00	30% 0%	0.97 N/A	0.86 N/A	2 N/A	2 N/A	0.10 N/A	0.00	0.00	0.00	0.00
VA	3100	3100 Base Fan Motor, 15np, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Lodging Lodging	2014	2054	43.39	9.18	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	43.39	9.18	0.00	0.00
VA	3200	3203 Air Handler Optimization, 40 HP	Lodging	2014	2054	38.86	8.95	4.53	4.53	10%	0.23	0.23	3%	0.02	0.02	0	0	2.25			4.53	0.23
VA	3200	3204 Demand Controlled Ventilation	Lodging	2014	2054	33.47	6.61	5.39	9.92	23%	2.34	2.57	28%	1.06	0.59	2	2	0.09			0.00	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Measure	Moneur				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt VA	Number 4000	Number Measure 4000 Base Built-Up Refrigeration System	Type	Year 2014	Year 2054	0.00	0.00	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	0.00	0.00	0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Lodging Lodging	2014	2054	141.67	20.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	141.67	20.71	0.00	0.00
VA	4100	4103 Night covers for display cases (self-contained)	Lodging	2014	2054	135.53	19.81	6.14	6.14	4%	0.90	0.90	4%	0.00	0.00	0	0	75.75			6.14	0.90
VA VA	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4109 Energy-Star Freezer, glass door	Lodging Lodging	2014 2014	2054 2054	133.81 131.77	19.56 19.27	1.72 2.04	7.85 9.89	6% 7%	0.25 0.30	1.15 1.45	6% 7%	0.00	0.00	0	0	28.54 22.28			1.72 2.04	0.25
VA	4100	4107 Energy-Star Freezer, solid door	Lodging	2014	2054	130.94	19.14	0.84	10.73	8%	0.30	1.57	8%	0.00	0.00	0	0	8.88			0.84	0.12
VA	4100	4106 Energy-Star Refrigerator, solid door	Lodging	2014	2054	130.36	19.06	0.57	11.30	8%	0.08	1.65	8%	0.01	0.00	0	0	7.07			0.57	0.08
VA VA	4100 4100	4110 Energy Star Ice Machines 4105 Bi-level LED Case Lighting (self-contained units) 2014	Lodging Lodging	2014 2014	2054 2054	129.30 129.26	18.90 18.90	1.06 0.04	12.37 12.40	9% 9%	0.16 0.01	1.81 1.81	9% 9%	0.02 0.33	0.00	0	0	2.62 0.18			1.06 0.00	0.16 0.00
VA	4100	4101 Strip curtains for walk-ins (self-contained)	Lodging	2014	2054	128.70	18.82	0.56	12.97	9%	0.08	1.90	9%	0.35	0.02	2	0	0.15			0.00	0.00
VA	5000	5000 Base Desktop PC	Lodging	2014	2054	9.10	1.35	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.10	1.35	0.00	0.00
VA VA	5000 5000	5002 Energy Star or Better PC 5001 PC Network Power Management Enabling	Lodging Lodging	2014 2014	2054 2054	7.19 3.86	1.07 0.82	1.91 3.33	1.91 5.24	21% 58%	0.28 0.25	0.28 0.53	21% 39%	0.01 0.02	0.01 0.02	0	0	3.97 3.06			1.91 3.33	0.28 0.25
VA	5100	5100 Base Laptop PC	Lodging	2014	2054	0.44	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.44	0.06	0.00	0.00
VA	5100	5102 Energy Star or Better Laptop	Lodging	2014	2054	0.35	0.05	0.08	0.08	19%	0.01	0.01	19%	0.01	0.01	0	0	5.20			0.08	0.01
VA VA	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Lodging Lodging	2014 2014	2054 2054	0.35 4.29	0.05 0.64	0.01 0.00	0.09	21% 0%	0.00	0.01 0.00	21% 0%	1.24 N/A	0.11 N/A	8 N/A	1 N/A	0.04 N/A	4.29	0.64	0.00	0.00
VA	5200	5201 Energy Star or Better Monitor - CRT	Lodging	2014	2054	1.88	0.28	2.41	2.41	56%	0.36	0.36	56%	0.00	0.00	0	0	41.36	20	0.01	2.41	0.36
VA	5200	5202 Monitor Power Management Enabling - CRT	Lodging	2014	2054	1.43	0.25	0.45	2.86	67%	0.03	0.39	61%	0.02	0.00	0	0	2.92			0.45	0.03
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)5300 Base Monitor, LCD	Lodging Lodging	2014 2014	2054 2054	1.31 1.90	0.23	0.11 0.00	2.97 0.00	69% 0%	0.02	0.41 0.00	64% 0%	0.21 N/A	0.01 N/A	1 N/A	0 N/A	0.26 N/A	1.90	0.28	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Lodging	2014	2054	1.71	0.25	0.19	0.19	10%	0.03	0.03	10%	0.01	0.01	0	0	6.66	1.50	0.20	0.19	0.03
VA	5300	5302 Monitor Power Management Enabling - LCD	Lodging	2014	2054	1.51	0.24	0.19	0.38	20%	0.01	0.04	15%	0.08	0.05	1	0	0.61			0.00	0.00
VA VA	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Lodging Lodging	2014 2014	2054 2054	1.39 2.65	0.23	0.12	0.50	27% 0%	0.00	0.05	17% 0%	0.22 N/A	0.09 N/A	6 N/A	1 N/A	0.21 N/A	2.65	0.39	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Lodging	2014	2054	2.39	0.35	0.26	0.26	10%	0.04	0.04	10%	0.00	0.00	0	0	32.75	2.00	0.00	0.26	0.04
VA	5400	5402 Copier Power Management Enabling	Lodging	2014	2054	2.29	0.35	0.10	0.35	13%	0.01	0.05	12%	0.09	0.03	.1.	0	0.60			0.00	0.00
VA VA	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Printer	Lodging Lodging	2014 2014	2054 2054	0.41	0.06	0.00 0.10	0.00 0.10	0% 25%	0.00 0.02	0.00 0.02	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.85	0.41	0.06	0.00 0.10	0.00 0.02
VA	5500	5501 Multifunction Power Management Enabling	Lodging	2014	2054	0.25	0.05	0.10	0.16	39%	0.02	0.02	32%	0.01	0.01	3	1	0.20			0.10	0.02
VA	5600	5600 Base Printer	Lodging	2014	2054	1.15	0.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.15	0.17	0.00	0.00
VA VA	5600 5600	5602 ENERGY STAR Printer	Lodging	2014	2054 2054	0.75	0.11 0.10	0.40 0.14	0.40 0.54	35% 47%	0.06 0.01	0.06	35% 41%	0.00	0.00	0	0	40.66			0.40	0.06
VA	5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Lodging Lodging	2014 2014	2054	0.61 40.24	5.98	0.14	0.00	0%	0.00	0.07	0%	0.06 N/A	0.02 N/A	N/A	N/A	0.92 N/A	40.24	5.98	0.00	0.00
VA	5700	5701 Data Center Improved Operations	Lodging	2014	2054	36.21	5.38	4.02	4.02	10%	0.60	0.60	10%	0.00	0.00	0	0	116.16			4.02	0.60
VA	5700	5702 Data Center Best Practices	Lodging	2014	2054	31.61	4.70	4.61	8.63	21%	0.68	1.28	21%	0.00	0.00	0	0	47.29			4.61	0.68
VA VA	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Lodging Lodging	2014 2014	2054 2054	29.84 62.44	4.43 8.42	1.77 0.00	10.40	26% 0%	0.26	1.55	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	24.53 N/A	62.44	8.42	1.77	0.26
VA	6000	6007 Heat Trap	Lodging	2014	2054	59.20	7.98	3.23	3.23	5%	0.44	0.44	5%	0.01	0.01	0	0	4.77	02.11	0.12	3.23	0.44
VA	6000	6006 Heat Recovery Unit	Lodging	2014	2054	51.51	6.95	7.70	10.93	18%	1.04	1.47	18%	0.02	0.02	0	0	3.57 2.46			7.70	1.04
VA VA	6000 6000	6001 Demand controlled circulating systems 6002 High Efficiency Water Heater (electric)	Lodging Lodging	2014 2014	2054 2054	49.58 48.58	6.69 6.55	1.93	12.86 13.85	21% 22%	0.26	1.73 1.87	21% 22%	0.03	0.02 0.02	0	0	2.46			1.93 0.99	0.26
VA	6000	6004 Tankless Water Heater	Lodging	2014	2054	44.94	6.06	3.64	17.50	28%	0.49	2.36	28%	0.05	0.03	0	0	1.53			3.64	0.49
VA	6000	6008 Solar Water Heater	Lodging	2014	2054	38.65	5.21	6.29	23.79	38%	0.85	3.21	38%	0.06	0.03	0	0	1.31			6.29	0.85
VA VA	6000 7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	Lodging Lodging	2014 2014	2054	37.99 15.02	5.12 2.44	0.66	24.45 0.00	39% 0%	0.09	3.30 0.00	39% 0%	0.07 N/A	0.04 N/A	1 N/A	0 N/A	1.02 N/A	15.02	2.44	0.66 0.00	0.09
VA	7000	7001 Vending Misers (Refrigerated units)	Lodging	2014	2054	12.67	2.26	2.35	2.35	16%	0.19	0.19	8%	0.02	0.02	0	0	2.09	15.02	2.44	2.35	0.19
VA	7000	7002 Vending Misers (Refrigerated glass-front units)	Lodging	2014	2054	11.40	2.15	1.27	3.62	24%	0.10	0.29	12%	0.05	0.03	1	0	1.14			1.27	0.10
VA VA	7100 7100	7100 Base Non-Refrigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	Lodging Lodging	2014 2014	2054 2054	0.09	0.01	0.00 0.04	0.00 0.04	0% 45%	0.00	0.00	0% 22%	N/A 0.41	N/A 0.41	N/A 5	N/A 5	N/A 0.12	0.09	0.01	0.00	0.00
VA	7200	7200 Base Oven	Lodging	2014	2054	2.97	0.61	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.97	0.61	0.00	0.00
VA	7300	7300 Base Fryer	Lodging	2014	2054	7.48	1.53	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.48	1.53	0.00	0.00
VA VA	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Lodging Lodging	2014 2014	2054 2054	1.24 24.82	0.25	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	1.24 24.82	0.25	0.00	0.00
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	2014	2054	23.42	0.00	1.40	1.40	6%	0.00	0.00	0%	0.02	0.02	N/A	N/A	2.43	24.02	0.00	1.40	0.00
VA	8100	8100 Base Heating, Other Electric	Lodging	2014	2054	19.91	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	19.91	0.00	0.00	0.00
VA VA	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Lodging Lodging	2014 2014	2054 2054	279.75 279.75	45.55 45.55	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	279.75	45.55	0.00	0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Data Centers	2020	2054	17.07	2.97	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	17.07	2.97	0.00	0.00
VA	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Data Centers		2054	17.02	2.97	0.05	0.05	0%	0.00	0.00	0%	0.01	0.01	0	0	5.21			0.05	0.00
VA VA	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Data Centers Data Centers		2054 2054	15.76 14.16	2.79	1.26 1.61	1.31 2.91	8% 17%	0.18 0.28	0.18 0.46	6% 16%	0.01 0.02	0.01 0.02	0	0	4.86 2.75			1.26 1.61	0.18 0.28
VA VA	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Data Centers Data Centers		2054	14.16 12.35	2.51	1.61	2.91 4.72	17% 28%	0.28	0.46	16% 26%	0.02	0.02	0	0	1.32			1.61	0.28
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Data Centers	2020	2054	11.42	2.15	0.93	5.65	33%	0.04	0.82	28%	0.07	0.04	2	Ö	0.79			0.00	0.00
VA VA	1030 1030	1034 ROB 4L4' LED Tube, 2020	Data Centers		2054 2054	9.58 8.76	1.83	1.84 0.82	7.49	44% 49%	0.32	1.14 1.28	38% 43%	0.30 0.25	0.10	2	1	0.25			0.00	0.00
VA VA	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Data Centers Data Centers		2054 2054	8.76 0.29	1.69 0.05	0.82	8.31 0.00	49% 0%	0.14	1.28 0.00	43% 0%	0.25 N/A	0.12 N/A	1 N/A	1 N/A	0.30 N/A	0.29	0.05	0.00	0.00
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Data Centers	2020	2054	0.29	0.05	0.00	0.00	0%	0.00	0.00	0%	0.02	0.02	0	0	3.03		2.00	0.00	0.00
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Data Centers		2054	0.27	0.05	0.02	0.02	8%	0.00	0.00	6%	0.03	0.03	0	0	2.82			0.02	0.00
VA VA	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Data Centers Data Centers		2054 2054	0.24	0.04	0.03	0.05 0.08	17% 28%	0.00 0.01	0.01 0.01	16% 26%	0.03	0.03 0.04	0	0	2.17 1.04			0.03	0.00 0.01
VA	1130	1134 ROB 2L4' LED Tube, 2020	Data Centers		2054	0.20	0.04	0.01	0.09	31%	0.00	0.01	30%	0.00	0.06	1	0	0.33			0.00	0.00
VA	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Data Centers		2054	0.18	0.03	0.01	0.11	36%	0.00	0.02	31%	0.13	0.07	3	0	0.42			0.00	0.00
VA	1130	1135 LED Troffer (base 2L4'T8), 2020	Data Centers	2020	2054	0.17	0.03	0.02	0.12	42%	0.00	0.02	37%	0.31	0.10	2	1	0.24			0.00	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		2020																SUPPLY		
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
Camt	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
VA	1200	1200 Base Other Fluorescent Fixture	Data Centers	2014	2054	0.63	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.63	0.11	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Data Centers	2014	2054	0.61	0.11	0.01	0.01	2%	0.00	0.00	1%	0.00	0.00	0	0	14.66			0.01	0.00
VA VA	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Data Centers Data Centers	2014	2054	0.57	0.10	0.05	0.06	9% 19%	0.01	0.01 0.02	7% 16%	0.03	0.03 0.06	0	0	2.24 0.67			0.05	0.01
VA	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Data Centers	2014	2054	0.44	0.09	0.07	0.18	29%	0.00	0.02	19%	0.13	0.09	3	1	0.44			0.00	0.00
VA	1200 1330	1202 ROB Low Watt High Performance T8 (base other fluorescent)	Data Centers		2054	0.39 5.27	0.08	0.06	0.24	38% 0%	0.01	0.03	28%	0.23 N/A	0.12	1	1	0.28			0.00	0.00
VA VA	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Data Centers Data Centers	2020	2054	1.04	0.92	0.00 4.24	0.00 4.24	0% 80%	0.00 0.74	0.00 0.74	0% 80%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 11.05	5.27	0.92	0.00 4.24	0.00 0.74
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Data Centers	2020	2054	1.90	0.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.90	0.33	0.00	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 20201530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Data Centers Data Centers	2020 2020	2054 2054	0.40 1.40	0.07	1.49 0.00	1.49 0.00	79% 0%	0.26 0.00	0.26 0.00	79% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	9.30 N/A	1.40	0.24	1.49 0.00	0.26
VA	1530	1530 base incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Data Centers	2020	2054	0.41	0.24	0.00	0.00	71%	0.00	0.00	71%	0.01	0.01	0	0	6.84	1.40	0.24	0.00	0.00
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Data Centers	2020	2054	1.07	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.07	0.19	0.00	0.00
VA VA	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Data Centers Data Centers	2020 2020	2054 2054	0.77 1.36	0.13 0.24	0.30	0.30	28% 0%	0.05 0.00	0.05 0.00	28% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	0.98 N/A	1.36	0.24	0.00	0.00
VA	1730	1730 Base CFL 23W to screw-in replacement (base CFL 23W) 2020	Data Centers	2020	2054	1.01	0.24	0.35	0.00	26%	0.06	0.06	26%	0.05	0.05	0	0	1.30	1.30	0.24	0.00	0.06
VA	1800	1800 BaseMetal Halide, 465W	Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Data Centers Data Centers	2014 2014	2054 2054	0.27	0.05	0.00 0.12	0.00 0.12	0% 44%	0.00 0.02	0.00 0.02	0% 44%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.09	0.27	0.05	0.00 0.12	0.00 0.02
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Data Centers		2054	4.01	0.03	0.00	0.00	0%	0.02	0.02	0%	N/A	N/A	N/A	N/A	N/A	4.01	0.04	0.00	0.02
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Data Centers		2054	3.65	0.04	0.36	0.36	9%	0.01	0.01	18%	0.02	0.02	1	1	3.10			0.36	0.01
VA VA	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Data Centers Data Centers	2014 2014	2054 2054	1.76 1.25	0.02	1.89 0.50	2.25 2.75	56% 69%	0.02	0.03	65% 77%	0.10 0.67	0.09 0.19	9 65	7 16	0.68			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Data Centers	2014	2054	44.99	11.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	44.99	11.07	0.00	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Data Centers	2014	2054	44.79	11.02	0.20	0.20	0%	0.05	0.05	0%	0.00	0.00	0	0	34.39			0.20	0.05
VA VA	2000	2005 Chiller Tune Up/Diagnostics 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Data Centers Data Centers		2054 2054	44.77 40.94	11.02	0.02 3.82	0.22 4.05	0% 9%	0.00	0.05	0% 9%	0.01	0.00	0	0	8.86 7.82			0.02 3.82	0.00
VA	2000	2006 VSD for Chiller Pumps and Towers	Data Centers		2054	40.66	10.05	0.29	4.33	10%	0.03	1.03	9%	0.01	0.01	0	0	5.78			0.29	0.03
VA	2000	2013 High Efficiency Chiller Motors	Data Centers	2014	2054	40.58	10.03	0.07	4.41	10%	0.02	1.04	9%	0.02	0.01	0	0	5.08			0.07	0.02
VA VA	2000 2000	2003 EMS - Chiller 2008 New Economizer - Chiller	Data Centers Data Centers		2054 2054	39.54 36.69	9.97 9.81	1.04 2.85	5.45 8.30	12% 18%	0.06 0.16	1.10 1.26	10% 11%	0.02 0.02	0.01 0.01	0	0	3.89 3.04			1.04 2.85	0.06 0.16
VA	2000	2002 Window Film (Standard) - Chiller	Data Centers		2054	36.67	9.81	0.01	8.32	18%	0.00	1.27	11%	0.02	0.01	0	0	2.02			0.01	0.00
VA	2000	2012 Duct Testing/Sealing - Chiller	Data Centers		2054	29.71	8.09	6.97	15.28	34%	1.72	2.98	27%	0.06	0.04	0	0	1.43			6.97	1.72
VA VA	2000 2000	2004 Cool Roof - Chiller 2011 Duct/Pipe Insulation - Chiller	Data Centers Data Centers	2014	2054 2054	29.61 29.52	8.07 8.05	0.09	15.38 15.47	34% 34%	0.02	3.00 3.03	27% 27%	0.09	0.04 0.04	0	0	0.81 0.10			0.00	0.00
VA	2100		Data Centers	2014	2054	25.66	6.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	25.66	6.32	0.00	0.00
VA	2100		Data Centers		2054	19.76	4.86	5.90	5.90	23%	1.45	1.45	23%	0.01	0.01	0	0	8.34			5.90	1.45
VA VA	2100 2100	2111 Economizer Repair - DX 2108 Optimize Controls - DX	Data Centers Data Centers	2014 2014	2054 2054	19.33 18.97	4.68 4.66	0.43	6.33 6.69	25% 26%	0.19 0.02	1.64 1.66	26% 26%	0.03 0.02	0.01 0.01	0	0	2.56 2.50			0.43 0.36	0.19 0.02
VA	2100	2109 Economizer - DX	Data Centers		2054	16.67	4.53	2.29	8.98	35%	0.13	1.79	28%	0.03	0.02	0	Ö	2.20			2.29	0.13
VA VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Data Centers	2014	2054	16.67	4.53 4.44	0.01	8.99 9.33	35% 36%	0.00	1.79 1.87	28% 30%	0.04	0.02	0	0	1.75			0.01	0.00
VA	2100 2100		Data Centers Data Centers	2014 2014	2054 2054	16.32 15.52	4.44	0.34	10.14	40%	0.08 0.05	1.87	30%	0.05 0.04	0.02 0.02	1	0	1.56 1.53			0.34	0.08
VA	2100	2112 Duct Testing/Sealing - DX	Data Centers	2014	2054	14.58	4.16	0.94	11.08	43%	0.23	2.15	34%	0.08	0.02	0	0	1.06			0.94	0.23
VA VA	2100 2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2107 Cool Roof - DX	Data Centers Data Centers		2054	14.58 14.45	4.16 4.13	0.00	11.08 11.21	43% 44%	0.00	2.15 2.18	34% 35%	0.08	0.02	1	0	0.77			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Data Centers		2054	14.45	4.13	0.12	11.30	44%	0.03	2.10	35%	0.10	0.02	4	0	0.08			0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Data Centers	2014	2054	3.29	0.81	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.29	0.81	0.00	0.00
VA VA	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Data Centers Data Centers	2014 2014	2054 2054	2.88	0.71	0.41	0.41 0.00	12% 0%	0.10 0.00	0.10 0.00	12% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	11.68 N/A	0.00	0.00	0.41 0.00	0.10 0.00
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Data Centers		2054	6.59	1.62	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.59	1.62	0.00	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	Data Centers	2014	2054	5.97	1.58	0.61	0.61	9%	0.04	0.04	2%	0.01	0.01	0	0	9.50			0.61	0.04
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	Data Centers Data Centers	2014 2014	2054 2054	5.88 5.54	1.56 1.41	0.10 0.34	0.71 1.05	11% 16%	0.02 0.15	0.06 0.21	4% 13%	0.01 0.30	0.01 0.10	0	0	6.97 0.33			0.10 0.00	0.02
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Data Centers	2014	2054	22.89	5.63	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	22.89	5.63	0.00	0.00
VA	3100	3102 Variable Speed Drive Control, 15 HP	Data Centers		2054	20.77	5.50	2.12	2.12	9%	0.13	0.13	2%	0.00	0.00	0	0	34.39			2.12	0.13
VA VA	3100 3100		Data Centers Data Centers	2014 2014	2054 2054	20.64 19.29	5.47 5.17	0.12 1.35	2.25 3.60	10% 16%	0.03	0.16 0.47	3% 8%	0.01 0.01	0.00 0.01	0	0	15.37 6.77			0.12 1.35	0.03
VA	3100	3103 Air Handler Optimization, 15 HP	Data Centers	2014	2054	17.47	5.06	1.82	5.42	24%	0.11	0.58	10%	0.01	0.01	0	0	5.37			1.82	0.11
VA	3100	3105 Energy Recovery Ventilation (ERV)	Data Centers		2054	17.04	4.86	0.43	5.85	26%	0.19	0.77	14%	0.11	0.02	0	0	0.93			0.00	0.00
VA VA	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Data Centers Data Centers		2054 2054	16.06 24.32	4.43 5.99	0.98	6.83	30% 0%	0.44	1.21	21% 0%	0.36 N/A	0.06 N/A	1 N/A	0 N/A	0.28 N/A	24.32	5.99	0.00	0.00
VA	3200	3202 Variable Speed Drive Control, 40 HP	Data Centers	2014	2054	22.06	5.85	2.26	2.26	9%	0.14	0.14	2%	0.01	0.01	0	0	6.83	27.32	5.55	2.26	0.14
VA	3200	3203 Air Handler Optimization, 40 HP	Data Centers	2014	2054	19.98	5.72	2.08	4.34	18%	0.13	0.27	5%	0.01	0.01	0	0	5.78			2.08	0.13
VA VA	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Data Centers Data Centers		2054 2054	19.89 18.75	5.69 5.19	0.09	4.43 5.57	18% 23%	0.02	0.29	5% 13%	0.05 0.32	0.01	0	0	1.73 0.30			0.09	0.02
VA	4000	4000 Base Built-Up Refrigeration System	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	Data Centers	2014	2054	3.64	0.68	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.64	0.68	0.00	0.00
VA VA	4100 4100		Data Centers Data Centers	2014 2014	2054 2054	3.64 3.57	0.68	0.00 0.07	0.00 0.07	0% 2%	0.00 0.01	0.00 0.01	0% 2%	0.00	0.00	0	0	30.26 27.78			0.00 0.07	0.00 0.01
VA	4100		Data Centers	2014	2054	3.57	0.67	0.00	0.07	2%	0.00	0.01	2%	0.00	0.00	0	0	12.12			0.00	0.00
VA	4100	4108 Energy-Star Refrigerator, glass door	Data Centers	2014	2054	3.57	0.67	0.00	0.07	2%	0.00	0.01	2%	0.01	0.00	0	0	10.25			0.00	0.00
VA VA	4100 4100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Data Centers Data Centers		2054 2054	3.57 3.57	0.67 0.67	0.00	0.07	2% 2%	0.00	0.01 0.01	2% 2%	0.01 0.02	0.00	0	0	9.82 3.64			0.00	0.00
*^	-100	1110 Energy star for machines	Jala Genters	2014	2004	3.31	0.07	0.00	0.00	270	0.00	0.01	270	0.02	0.00	U	U	J.U -1			0.00	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS													SUPPLY							
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Same	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic MW
VA	4100	4112 Reach-in unit occupancy sensors	Data Centers	2014	2054	3.56	0.67	0.00	0.08	2%	0.00	0.01	2%	0.27	0.00	1	0	0.26	GWII	IVIVV	0.00	0.00
VA VA	4100 5000	4105 Bi-level LED Case Lighting (self-contained units) 2014 5000 Base Desktop PC	Data Centers Data Centers	2014 2014	2054 2054	3.56 0.48	0.67	0.00	0.08	2% 0%	0.00	0.01 0.00	2% 0%	0.30 N/A	0.00 N/A	2 N/A	0 N/A	0.21 N/A	0.48	0.08	0.00	0.00
VA	5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Data Centers	2014	2054	0.46	0.06	0.00	0.00	44%	0.00	0.00	23%	0.01	0.01	0	0	3.79	0.40	0.08	0.00	0.00
VA	5000	5002 Energy Star or Better PC	Data Centers	2014	2054	0.21	0.05	0.06	0.27	56%	0.01	0.03	35%	0.03	0.02	0	0	2.09			0.06	0.01
VA VA	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Data Centers Data Centers	2014	2054	0.03	0.01	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.46	0.03	0.01	0.00 0.01	0.00
VA	5100	5101 Laptop Network Power Management Enabling	Data Centers	2014	2054	0.03	0.00	0.00	0.01	21%	0.00	0.00	21%	1.24	0.11	7	1	0.05			0.00	0.00
VA VA	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Data Centers Data Centers	2014	2054 2054	0.26 0.15	0.05	0.00 0.11	0.00 0.11	0% 43%	0.00	0.00	0% 43%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 56.87	0.26	0.05	0.00 0.11	0.00
VA	5200	5201 Energy Star of Better Monitor - CR1 5202 Monitor Power Management Enabling - CRT	Data Centers	2014	2054	0.13	0.03	0.11	0.11	50%	0.02	0.02	46%	0.00	0.00	0	0	4.41			0.11	0.02
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Data Centers		2054	0.12	0.02	0.01	0.14	54% 0%	0.00	0.02	50% 0%	0.14 N/A	0.01 N/A	1 N/A	0	0.41			0.00	0.00
VA VA	5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Data Centers Data Centers	2014 2014	2054 2054	0.13 0.11	0.02	0.00	0.00	0% 13%	0.00	0.00	13%	N/A 0.01	0.01	N/A 0	N/A 0	N/A 6.75	0.13	0.02	0.00	0.00
VA	5300	5302 Monitor Power Management Enabling - LCD	Data Centers	2014	2054	0.10	0.02	0.01	0.02	19%	0.00	0.00	16%	0.08	0.03	1	0	0.62			0.00	0.00
VA VA	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Data Centers Data Centers	2014 2014	2054 2054	0.09 0.11	0.02	0.01 0.00	0.03	25% 0%	0.00	0.00	18% 0%	0.24 N/A	0.08 N/A	5 N/A	1 N/A	0.20 N/A	0.11	0.02	0.00	0.00
VA	5400	5400 Base Copier 5401 Energy Star or Better Copier	Data Centers	2014	2054	0.10	0.02	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	0	0	34.21	0.11	0.02	0.00	0.00
VA	5400	5402 Copier Power Management Enabling	Data Centers	2014	2054	0.09	0.02	0.00	0.01	14%	0.00	0.00	12%	0.09	0.03	1	0	0.58			0.00	0.00
VA VA	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Printer	Data Centers Data Centers	2014	2054 2054	0.01	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.27	0.01	0.00	0.00	0.00
VA	5500	5501 Multifunction Power Management Enabling	Data Centers	2014	2054	0.01	0.00	0.00	0.01	38%	0.00	0.00	32%	0.28	0.10	3	1	0.19			0.00	0.00
VA VA	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Data Centers Data Centers	2014	2054 2054	0.04	0.01	0.00 0.01	0.00	0% 35%	0.00	0.00	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 42.62	0.04	0.01	0.00 0.01	0.00
VA	5600	5601 Printer Power Management Enabling	Data Centers	2014	2054	0.03	0.00	0.00	0.01	46%	0.00	0.00	41%	0.06	0.00	1	0	0.89			0.00	0.00
VA	5700	5700 Base Data Center/Server Room	Data Centers		2054	762.71	132.70	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A		762.71	132.70	0.00	0.00
VA VA	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Data Centers Data Centers		2054 2054	686.44 599.11	119.43 104.24	76.27 87.33	76.27 163.60	10% 21%	13.27 15.19	13.27 28.46	10% 21%	0.00	0.00	0	0	121.88 49.62			76.27 87.33	13.27 15.19
VA	5700	5703 Data Center State of the Art practices	Data Centers	2014	2054	565.56	98.40	33.55	197.15	26%	5.84	34.30	26%	0.00	0.00	0	0	25.73			33.55	5.84
VA	6000	6000 Base Water Heating	Data Centers		2054	0.38	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	0.38	0.07	0.00	0.00
VA VA	6000 6000	6007 Heat Trap 6002 High Efficiency Water Heater (electric)	Data Centers Data Centers		2054	0.36	0.06	0.02	0.02	5% 7%	0.00	0.00	5% 7%	0.08	0.08	0	1	0.88			0.00	0.00
VA	6000	6004 Tankless Water Heater	Data Centers	2014	2054	0.33	0.06	0.03	0.05	14%	0.00	0.01	14%	0.24	0.17	1	1	0.34			0.00	0.00
VA VA	6000 6000	6008 Solar Water Heater 6006 Heat Recovery Unit	Data Centers Data Centers	2014	2054 2054	0.15	0.03	0.18 0.01	0.23	60% 62%	0.03	0.04 0.04	60% 62%	0.28 0.62	0.26 0.27	2	1 2	0.29 0.11			0.00	0.00
VA	6000	6001 Demand controlled circulating systems	Data Centers	2014	2054	0.14	0.03	0.00	0.24	64%	0.00	0.04	64%	1.87	0.30	11	2	0.11			0.00	0.00
VA	7000	7000 Base Refrigerated Vending Machines	Data Centers		2054	0.25	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.25	0.04	0.00	0.00
VA VA	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Data Centers Data Centers		2054 2054	0.21	0.04	0.04 0.02	0.04	16% 24%	0.00	0.00 0.01	8% 12%	0.01 0.02	0.01 0.01	0	0	5.94 3.27			0.04 0.02	0.00
VA	7100	7100 Base Non-Refrigerated Vending Machines	Data Centers	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
VA VA	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Data Centers Data Centers		2054 2054	0.01	0.00	0.00	0.00	44% 0%	0.00	0.00	23% 0%	0.12 N/A	0.12 N/A	1 N/A	1 N/A	0.45 N/A	0.00	0.00	0.00	0.00
VA	7300	7300 Base Fryer	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA	7400	7400 Base Steamer	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	8000 8100	8000 Base Heating, Heat Pump (7.7 HSPF) 8100 Base Heating, Other Electric	Data Centers Data Centers		2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
VA	9500	9500 Base Miscellaneous	Data Centers		2054	3.84	0.67	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.84	0.67	0.00	0.00
VA	9500	9501 Xmisc	Data Centers		2054	3.84	0.67	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
VA VA	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	eligious Worsh eligious Worsh		2054 2054	69.16 62.00	11.74 10.52	0.00 7.17	0.00 7.17	0% 10%	0.00 1.22	0.00 1.22	0% 10%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.66	69.16	11.74	0.00 7.17	0.00 1.22
VA	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	eligious Worsh	2020	2054	61.68	10.50	0.32	7.49	11%	0.03	1.24	11%	0.05	0.04	1	0	1.17			0.32	0.03
VA VA	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	eligious Worsh eligious Worsh		2054 2054	57.00 49.75	9.87 8.64	4.67 7.25	12.16 19.41	18% 28%	0.63 1.23	1.87 3.10	16% 26%	0.07 0.09	0.05 0.07	1	0	1.05 0.73			4.67 0.00	0.63
VA	1030	1032 ROB 4L4 LED Tube, 2020	eligious Worsh		2054	41.74	7.28	8.02	27.43	40%	1.36	4.46	38%	0.58	0.07	3	1	0.73			0.00	0.00
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	eligious Worsh		2054	40.62	7.23	1.11	28.54	41%	0.05	4.51	38%	0.28	0.22	7	1	0.20			0.00	0.00
VA VA	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	eligious Worsh eligious Worsh		2054 2054	37.16 52.96	6.64 8.99	3.47 0.00	32.01 0.00	46% 0%	0.59 0.00	5.10 0.00	43% 0%	0.49 N/A	0.25 N/A	3 N/A	2 N/A	0.16 N/A	52.96	8.99	0.00	0.00
VA	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	eligious Worsh	2020	2054	47.96	8.14	5.00	5.00	9%	0.85	0.85	9%	0.05	0.05	0	0	1.32	02.00	0.00	5.00	0.85
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	eligious Worsh		2054	47.71	8.12	0.25	5.25	10%	0.02	0.87	10%	0.05	0.05	1	0	0.96			0.00	0.00
VA VA	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	eligious Worsh eligious Worsh		2054 2054	44.09 38.48	7.63 6.68	3.61 5.61	8.87 14.48	17% 27%	0.49 0.95	1.36 2.31	15% 26%	0.08 0.12	0.06 0.08	1	0 1	0.86 0.58			0.00	0.00
VA	1130	1134 ROB 2L4' LED Tube, 2020	eligious Worsh	2020	2054	36.62	6.36	1.86	16.34	31%	0.32	2.62	29%	0.47	0.13	3	1	0.17			0.00	0.00
VA VA	1130 1130	1135 LED Troffer (base 2L4T8), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	eligious Worsh eligious Worsh		2054 2054	33.50 32.60	5.83 5.80	3.13 0.89	19.46 20.36	37% 38%	0.53 0.04	3.15 3.19	35% 35%	0.59 0.47	0.20 0.21	3 12	1	0.13 0.12			0.00	0.00
VA	1200	1200 Base Other Fluorescent Fixture	eligious Worsh		2054	0.72	0.12	0.00	0.00	0%	0.04	0.00	0%	0.47 N/A	N/A	N/A	N/A	0.12 N/A	0.72	0.12	0.00	0.00
VA	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	eligious Worsh	2014	2054	0.70	0.12	0.02	0.02	3%	0.00	0.00	2%	0.03	0.03	0	0	1.68			0.02	0.00
VA VA	1200 1200	1201 ROB High Performance T8 (base other fluorescent) 1202 ROB Low Watt High Performance T8 (base other fluorescent)	eligious Worsh eligious Worsh		2054 2054	0.65 0.57	0.11 0.10	0.05 0.08	0.08 0.16	10% 22%	0.01 0.01	0.01 0.02	9% 20%	0.17 0.35	0.13 0.24	1 2	1 2	0.41 0.20			0.00	0.00
VA	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	eligious Worsh	2014	2054	0.52	0.09	0.04	0.20	28%	0.01	0.03	25%	0.36	0.27	3	2	0.20			0.00	0.00
VA	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	eligious Worsh		2054	0.48	0.09	0.04	0.24	33%	0.00	0.03	26%	0.31	0.27	8	2	0.18	07.77	474	0.00	0.00
VA VA	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	eligious Worsh eligious Worsh		2054 2054	27.77 4.96	4.71 0.84	0.00 22.81	0.00 22.81	0% 82%	0.00 3.87	0.00 3.87	0% 82%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.72	27.77	4.71	0.00 22.81	0.00 3.87
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	eligious Worsh	2020	2054	10.00	1.70	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.00	1.70	0.00	0.00
VA	1430	1432 LEDs (base incandescent A-line 72W) 2020	eligious Worsh	2020	2054	1.94	0.33	8.06	8.06	81%	1.37	1.37	81%	0.01	0.01	0	0	4.83			8.06	1.37

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	age			Mageura	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average	Marginal Capacity	Average					
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Energy Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm VA	1530	Number Measure 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Type eligious Worsh	Year 2020	Year 2054	7.36	MW 1.25	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	7.36	MW 1.25	0.00	0.00
VA	1530	1532 LEDs (base incandescent A-line 53W) 2020	eligious Worsh		2054	1.96	0.33	5.40	5.40	73%	0.92	0.92	73%	0.02	0.02	0	0	3.58	7.30		5.40	0.92
VA	1630 1630	1630 Base CFL 18W to screw-in replacement 2020	eligious Worsh		2054 2054	4.14	0.70	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.14	0.70	0.00	0.00
VA VA	1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	eligious Worsh eligious Worsh		2054	2.99 5.29	0.51 0.90	1.15 0.00	1.15 0.00	28% 0%	0.19 0.00	0.19 0.00	28% 0%	0.13 N/A	0.13 N/A	1 N/A	N/A	0.56 N/A	5.29	0.90	0.00	0.00
VA	1730	1731 LED screw-in replacement (base CFL 23W) 2020	eligious Worsh		2054	3.92	0.66	1.38	1.38	26%	0.23	0.23	26%	0.09	0.09	1	1	0.74			0.00	0.00
VA VA	1800 1800	1800 BaseMetal Halide, 465W 1801 T5 (240W) (base metal halide)	eligious Worsh eligious Worsh		2054 2054	3.51 2.33	0.60	0.00	0.00	0% 34%	0.00	0.00 0.20	0% 34%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.73	3.51	0.60	0.00 1.19	0.00
VA	1800	1806 Occupancy Sensor, High Bay T5	eligious Worsh		2054	2.25	0.39	0.08	1.26	36%	0.00	0.20	34%	0.08	0.03	2	0	0.73			0.00	0.00
VA VA	1800 1850	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1850 Base CFL Exit Sign	eligious Worsh eligious Worsh		2054 2054	2.08	0.37	0.17	1.43 0.00	41% 0%	0.02	0.23	38% 0%	0.14 N/A	0.04 N/A	1 N/A	0 N/A	0.50 N/A	2.02	0.34	0.00	0.00
VA	1850	1851 LED Exit Sign	eligious Worsh		2054	1.09	0.34	0.00	0.00	46%	0.00	0.16	46%	0.05	0.05	0	0	1.12	2.02	0.34	0.00	0.16
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	eligious Worsh		2054	25.23	1.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	25.23	1.95	0.00	0.00
VA VA	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	eligious Worsh eligious Worsh		2054 2054	24.75 11.91	1.85 0.85	0.48 12.84	0.48 13.32	2% 53%	0.11	0.11 1.10	5% 56%	0.07	0.07 0.16	0	0	1.33 0.43			0.48	0.11
VA	1900	1903 Bi-Level LED Outdoor Lighting	eligious Worsh	2014	2054	8.43	0.61	3.48	16.80	67%	0.24	1.34	69%	1.07	0.35	15	4	0.06			0.00	0.00
VA VA	2000 2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2010 Ceiling/roof Insulation - Chiller	eligious Worsh eligious Worsh		2054 2054	30.08 29.71	23.26 22.97	0.00 0.38	0.00	0% 1%	0.00 0.29	0.00 0.29	0% 1%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 3.23	30.08	23.26	0.00 0.38	0.00 0.29
VA	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	eligious Worsh		2054	27.17	21.01	2.54	2.91	10%	1.96	2.25	10%	0.04	0.04	0	0	1.66			2.54	1.96
VA	2000	2005 Chiller Tune Up/Diagnostics	eligious Worsh		2054	27.15	21.00	0.02	2.93	10%	0.01	2.26	10%	0.06	0.07	0	0	1.30			0.02	0.01
VA VA	2000	2013 High Efficiency Chiller Motors 2006 VSD for Chiller Pumps and Towers	eligious Worsh eligious Worsh		2054 2054	27.13 26.07	20.99	0.02 1.05	2.95 4.01	10% 13%	0.02	2.28	10% 12%	0.12	0.07	0	0	1.07 0.94			0.02	0.02
VA	2000	2003 EMS - Chiller	eligious Worsh		2054	24.82	20.32	1.25	5.26	17%	0.25	2.94	13%	0.14	0.09	1	Ö	0.53			0.00	0.00
VA VA	2000 2000	2012 Duct Testing/Sealing - Chiller 2002 Window Film (Standard) - Chiller	eligious Worsh eligious Worsh		2054 2054	20.26 20.13	16.79 16.69	4.56 0.13	9.83 9.95	33% 33%	3.53 0.10	6.47 6.57	28% 28%	0.40 1.45	0.24 0.25	1 2	0	0.31 0.07			0.00	0.00
VA	2000	2004 Cool Roof - Chiller	eligious Worsh		2054	20.13	16.66	0.13	9.99	33%	0.10	6.60	28%	6.31	0.28	8	0	0.07			0.00	0.00
VA	2000	2011 Duct/Pipe Insulation - Chiller	eligious Worsh	2014	2054	19.82	16.46	0.27	10.26	34%	0.21	6.81	29%	7.61	0.47	10	1	0.01			0.00	0.00
VA VA	2000 2100	2008 New Economizer - Chiller 2100 Base DX Packaged System, EER=10.3, 10 tons	eligious Worsh eligious Worsh		2054 2054	19.82 96.90	16.46 74.94	0.00	10.26 0.00	34% 0%	0.00	6.81 0.00	29% 0%	70236.15 N/A	0.59 N/A	354,039 N/A	1 N/A	0.00 N/A	96.90	74.94	0.00	0.00
VA	2100	2113 Ceiling/roof Insulation - DX	eligious Worsh		2054	96.90	74.94	0.00	0.00	0%	0.00	0.00	0%	0.04	0.04	0	0	3.32	96.90	74.94	0.00	0.00
VA	2100	2102 DX Packaged System, EER=13.4, 10 tons	eligious Worsh	2014	2054	74.61	57.70	22.29	22.29	23%	17.24	17.24	23%	0.07	0.07	0	0	1.76			22.29	17.24
VA VA	2100 2100	2105 DX Tune Up/ Advanced Diagnostics 2112 Duct Testing/Sealing - DX	eligious Worsh eligious Worsh		2054 2054	74.58 70.19	57.69 54.30	0.03 4.39	22.32 26.71	23% 28%	0.01 3.39	17.25 20.64	23% 28%	0.23 0.43	0.07 0.13	1	0	0.34 0.29			0.00	0.00
VA	2100	2106 Prog. Thermostat - DX	eligious Worsh		2054	68.60	53.98	1.59	28.30	29%	0.32	20.96	28%	0.24	0.13	1	Ö	0.25			0.00	0.00
VA VA	2100 2100	2108 Optimize Controls - DX 2115 Window Film (Standard) - DX	eligious Worsh eligious Worsh		2054 2054	67.46 67.20	53.75 53.55	1.14 0.26	29.44 29.70	30% 31%	0.23 0.20	21.18 21.39	28% 29%	0.25 1.19	0.14 0.15	1 2	0	0.22 0.08			0.00	0.00
VA	2100	2107 Cool Roof - DX	eligious Worsh		2054	67.20	53.45	0.26	29.70	31%	0.20	21.39	29%	6.09	0.15	8	0	0.08			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	eligious Worsh	2014	2054	66.64	53.12	0.43	30.26	31%	0.33	21.82	29%	7.28	0.27	9	0	0.01			0.00	0.00
VA VA	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	eligious Worsh eligious Worsh		2054 2054	78.85 69.10	60.98 53.44	0.00 9.75	0.00 9.75	0% 12%	0.00 7.54	0.00 7.54	0% 12%	N/A 0.07	N/A 0.07	N/A	N/A 0	N/A 1.64	78.85	60.98	0.00 9.75	0.00 7.54
VA	2300	2300 Base PTAC, EER=8.3, 1 ton	eligious Worsh		2054	78.27	60.53	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	78.27	60.53	0.00	0.00
VA	2300	2301 HE PTAC, EER=9.6, 1 ton	eligious Worsh		2054	67.67	52.33	10.60	10.60	14%	8.20	8.20	14%	0.16	0.16	0	0	0.71			0.00	0.00
VA VA	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	eligious Worsh eligious Worsh		2054 2054	72.92 71.66	20.72 20.36	0.00 1.26	0.00 1.26	0% 2%	0.00 0.36	0.00 0.36	0% 2%	N/A 0.13	N/A 0.13	N/A 0	N/A 0	N/A 0.70	72.92	20.72	0.00	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	eligious Worsh	2014	2054	50.40	18.85	21.26	22.52	31%	1.51	1.86	9%	0.10	0.10	1	1	0.67			0.00	0.00
VA VA	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91,0%	eligious Worsh		2054 2054	49.42 58.13	18.32 16.52	0.98	23.50	32% 0%	0.54	2.40	12% 0%	3.09 N/A	0.22 N/A	6 N/A	2 N/A	0.03 N/A	58.13	16.52	0.00	0.00
VA	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	eligious Worsh eligious Worsh		2054	49.74	14.37	8.39	8.39	14%	2.14	2.14	13%	0.06	0.06	0	0	1.34	56.15	10.52	8.39	2.14
VA	3100	3103 Air Handler Optimization, 15 HP	eligious Worsh		2054	46.33	14.13	3.41	11.80	20%	0.24	2.38	14%	0.08	0.07	1	0	0.71			0.00	0.00
VA VA	3100 3100	3102 Variable Speed Drive Control, 15 HP 3101 Fan Motor, 15hp, 1800rpm, 92.4%	eligious Worsh eligious Worsh		2054 2054	32.59 32.10	13.16 13.02	13.75 0.49	25.54 26.03	44% 45%	0.97 0.14	3.36 3.49	20% 21%	0.13 0.42	0.10 0.11	2	1	0.49 0.22			0.00	0.00
VA	3100	3105 Energy Recovery Ventilation (ERV)	eligious Worsh		2054	31.69	12.80	0.41	26.44	45%	0.22	3.72	23%	0.86	0.12	2	i	0.13			0.00	0.00
VA	3100	3107 Demand Controlled Ventilation	eligious Worsh		2054	31.07	12.46	0.62	27.06	47%	0.34	4.06	25%	3.92	0.21	7	1	0.03	40.40	40.44	0.00	0.00
VA VA	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	eligious Worsh eligious Worsh		2054 2054	46.13 42.97	13.11 12.88	0.00 3.16	0.00 3.16	0% 7%	0.00 0.22	0.00 0.22	0% 2%	N/A 0.07	N/A 0.07	N/A 1	N/A 1	N/A 0.83	46.13	13.11	0.00	0.00
VA	3200	3202 Variable Speed Drive Control, 40 HP	eligious Worsh	2014	2054	30.22	11.98	12.75	15.91	34%	0.90	1.13	9%	0.21	0.18	3	3	0.32			0.00	0.00
VA VA	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	eligious Worsh		2054 2054	30.10 29.51	11.94 11.62	0.12 0.59	16.03 16.62	35% 36%	0.03 0.32	1.16	9% 11%	1.02 3.28	0.19	4 6	3	0.09			0.00	0.00
VA	4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	eligious Worsh eligious Worsh		2054	0.00	0.00	0.00	0.00	0%	0.32	1.48 0.00	0%	3.26 N/A	0.29 N/A	N/A	N/A	0.03 N/A	0.00	0.00	0.00	0.00
VA	4100	4100 Base Self-Contained Refrigeration	eligious Worsh	2014	2054	98.51	14.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	98.51	14.83	0.00	0.00
VA VA	4100 4100	4103 Night covers for display cases (self-contained) 4104 Freezer-Cooler Replacement Gaskets (self-contained)	eligious Worsh eligious Worsh		2054 2054	97.55 96.17	14.69 14.48	0.95 1.39	0.95 2.34	1% 2%	0.14 0.21	0.14 0.35	1% 2%	0.00	0.00	0	0	19.78 18.82			0.95 1.39	0.14 0.21
VA	4100	4108 Energy-Star Refrigerator, glass door	eligious Worsh		2054	95.55	14.38	0.62	2.96	3%	0.09	0.45	3%	0.01	0.00	0	ō	6.37			0.62	0.09
VA	4100	4106 Energy-Star Refrigerator, solid door	eligious Worsh		2054	93.94	14.14	1.60	4.56	5%	0.24	0.69	5%	0.01	0.01	0	0	6.24			1.60	0.24
VA VA	4100 4100	4110 Energy Star Ice Machines 4112 Reach-in unit occupancy sensors	eligious Worsh eligious Worsh		2054 2054	91.85 91.84	13.83 13.83	2.09 0.01	6.65 6.67	7% 7%	0.31	1.00 1.00	7% 7%	0.03 0.28	0.01 0.01	0 2	0	2.27 0.23			2.09 0.00	0.31
VA	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	eligious Worsh	2014	2054	91.76	13.81	0.08	6.75	7%	0.01	1.02	7%	0.32	0.02	2	0	0.19			0.00	0.00
VA VA	5000 5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	eligious Worsh		2054 2054	9.54 5.24	1.44 1.11	0.00 4.30	0.00 4.30	0% 45%	0.00 0.33	0.00 0.33	0% 23%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.09	9.54	1.44	0.00 4.30	0.00
VA	5000	5002 Energy Star or Better PC	eligious Worsh eligious Worsh		2054	3.61	0.87	1.63	5.93	45% 62%	0.33	0.58	23% 40%	0.02	0.02	0	0	1.06			1.63	0.33
VA	5100	5100 Base Laptop PC	eligious Worsh	2014	2054	0.66	0.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.66	0.10	0.00	0.00
VA VA	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	eligious Worsh eligious Worsh		2054 2054	0.53 0.52	80.0 80.0	0.12 0.01	0.12 0.13	19% 21%	0.02	0.02 0.02	19% 21%	0.02 2.25	0.02 0.20	0 15	0	2.90 0.02			0.12 0.00	0.02
VA	5200	5200 Base Monitor, CRT	eligious Worsh		2054	1.67	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.67	0.25	0.00	0.00

APPENDIX H

Base Avoided Costs

Part			ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Second S					Moscure	Moseur					Porcont			Porcont									
Second				Building	Start	End	Total			Savings	GWH		Savings	MW	Cost	Cost	Cost	Cost	Cost Test				
Second															4111111	4,,,,,,,,,,		4,		GWH	MW		
Second Column Second Colum																							
200 200			5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	eligious Worsh	2014					1.17													
Value 1962 Valu																				1.99	0.30		
No. 1.500																							
Second Column Second Colum																							
Mathematical Control of Section																				3.87	0.59		
Second Second State Manufacture Signature Sign																							
May			5500 Base Multifunction	eligious Worsh	2014														N/A	0.51	0.08		
May May																		0					
Math																		N/A		1.56	0.24		
Section Sect			5602 ENERGY STAR Printer	eligious Worsh	2014												0						
Val. 1979																				0.00	1 22		
No. 100											-,-									0.00	1.22		
March Color Colo	VA	5700	5702 Data Center Best Practices	eligious Worsh	2014	2054	6.33	0.96	0.92	1.73	21%	0.14	0.26	21%	0.00	0.00	0	0	32.92			0.92	0.14
March Marc																	-	-		07.00	0.00		
Math																				27.02	3.99		
Math																							
Math																		-					
VA 100 Color Desire Control Enrichies forwising Systems System																		0					
VA 1700 7000 Base Refregemental Verdinal Machiners 81/90 at Words 2014 2015 4.50 0.75 0.00 0.0																		1					
VA 700				eligious Worsh	2014															4.50	0.75		
VA 7100 7100 1969 1969 1969 1969 291																							
VA																				0.00	0.00		
VA 700 7300 Part Par	VA	7100	7101 Vending Misers (Non-Refrigerated)					0.00	0.00	0.00	46%	0.00	0.00	23%	0.44	0.44	5	5	0.12			0.00	0.00
VA 7300 7300 Fillower Flywer																							
VA Follo Prop P											-,-									1.40	0.23		
VA Stool Stool Hase Pump Upgrades Cf SEERS, 8.2 + SEPF Stool Stool Hase Pump Upgrades Cf SEERS, 8.2 + SEPF Stool Stool Hase Pump Upgrades Cf SEERS, 8.2 + SEPF Stool Stool Hase Pump Upgrades Cf SEERS, 8.2 + SEPF Stool Stool Hase Pump Upgrades Cf SEERS, 8.2 + SEPF Stool Stool Hase Pump Upgrades Cf SEERS, 8.2 + SEPF Stool Stool Hase Pump Upgrades Cf SEERS, 8.2 + SEPF Stool Stool Hase Pump Upgrades SEERS, 8.2 + SEPF Stool Stool Hase Pump Upgrades SEERS, 8.2 + SEPF Stool Stool Stool																				1.23	0.20		
VA S100																				2.39	0.00		
VA																				10.53	0.00		
VA 1030 1038 Elegan Fluorescene Flature, 44-FB, 16B, 2020 Misc 2020 2054 41-68 70-38 80.0 0.00																							
VA 1030 1038 Highling Control Tuneup (base 4L4TB), 2020 Misc 2020 2054 41.52 70.20 21.55 11.56 31.55 33.40 85.60 4.01 4																							
VA 1030 1031 Rog High Performance Lighting RRR -25% Savings (base 44-TB), 2020 Misc 2020 2054 38 2.9 65.00 31.25 33.40 8% 4.20 4.38 6% 0.02 0.02 0.0 0.3.43 3.25 5.20 6.70 1.08 1.00																				414.67	70.38		
VA 1030 1013 ROB 4LF Inligh Performance T8 (86 W), 2020 2024 341,77 59,29 39,50 72,90 18% 6.70 11,08 16% 0.02 0.02 0.0 0. 3.03 3.05 39,50 6.70																	-	-					
VA 1030 1037 Cocupanny Sensor, 4L# Fluroscent Flutures, 2020 Misc 2020 2054 23.56 43.65 46.78 171.11 41% 7.94 26.73 30.8% 0.25 0.09 1 1 0.28 0.00 0	VA	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Misc	2020	2054	341.77	59.29	39.50	72.90	18%	6.70	11.08	16%	0.02	0.02		-	3.03			39.50	6.70
VA 1030 1034 ROB 4L4*ED Tube; 2020 Msc 2020 2054 243.56 43.65 46.78 171.11 41% 7.94 26.73 38% 0.25 0.09 1 1 1 0.28 0.00 0.00 0.00 VA 1130 1035 EDT Toffer (base 4L4*T8), 2020 Msc 2020 2054 243.56 43.65 0.00 0.00 0% 0.00 0% 0.00 0% NA																							
VA 1130 1103 LED Troffer (base 4,L4TB), 2020 Misc 2020 2054 317.87 5 3.89 0.00 0.00 0% 0% 0.00 0% 0% N/A																		1					
VA 1130 1138 Lighting Control Tuneup (base 2L4TB), 2020 Misc 2020 2054 15.87 53.75 1.66 1.66 1.96 1130 1138 High Performance T8 (68 W), 2020 Misc 2020 2054 264.36 45.85 27.58 53.17 17% 4.68 8.03 15% 0.02 0.02 0.0 2.96 0.0 2.96 2.93 3.34 2.93 3.25 2.93 3.25 11.10 1132 ROB 2L4 High Performance T8 (76 W), 2020 Misc 2020 2054 264.36 45.85 27.58 53.17 17% 4.68 8.03 15% 0.02 0.02 0.0 0.0 2.42 27.58 4.68 4.68 5.71 VA 1130 1132 ROB 2L4 LED Tube, 2020 Misc 2020 2054 21.95 73 38.25 11.15 97.95 31% 1.99 15.64 2.9% 0.05 0.03 0.0 1.16 1.0 0.36 0.00 0.00 0.00 0.00 0.00 0.00 0.	VA			Misc	2020		222.77	40.12	20.79	191.90			30.26	43%		0.10		1	0.34			0.00	0.00
VA 1130 1138 High Ferformance Lighting RR - 25% Savings (base 24,4T8), 2020 2054 291,94 50,53 29,39 25,88 88 3.22 3.35 6% 0.02 0.02 0.02 0.02 0.02 0.02 296 29,83 3.22 3.45 4.68 4.68 4.68 4.70 4.11																				317.53	53.89		
VA 1130 1131 ROB 2L4 High Performance T8 (86 W), 2020																							
VA 1130 1134 ROB 214* LED Tube, 2020 Misc 2020 2054 219.57 38.25 11.15 97.95 31% 1.89 15.64 29% 0.19 0.05 1 0 0.36 0.00 0	VA	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Misc	2020	2054	264.36	45.85	27.58	53.17	17%	4.68	8.03	15%	0.02	0.02	0	0	2.42			27.58	4.68
VA 1130 1135 LED Troffer (base 2L4TB), 2020 Misc 2020 2054 20.88 35.07 18.74 116.70 37% 31.8 18.82 35% 0.24 0.08 1 1 0.29 0.00 0																	-	-					
VA 1130 1137 Cocupancy Sensor, 2L4 Fluorescent Fixtures, 2020 Misc 2020 2054 195,48 34,85 5,35 122,05 38% 0.22 19,04 35% 0.15 0.09 4 1 0.36 0.00 0.																		0					
VA 1200 1203 Lighting Control Tuneup (base other fluorescent) Misc 2014 2054 4.20 0.72 0.14 0.14 3% 0.01 0.01 2% 0.01 0.01 0.01 0.0 0.5.21 0.14 0.01 0.01 0.00																		1					
VA 1200 1201 ROB High Performance T8 (base other fluorescent) Misc 2014 2054 3.88 0.67 0.32 0.45 10% 0.05 0.07 0.07 0.06 0 0 0.81 0.00 0.00																				4.34	0.74		
VA 1200 1205 High Performance Lighting R/R - 25% Sawings, Base Other Fluorescent Misc 2014 2054 3.59 0.63 0.29 0.75 17% 0.04 0.10 14% 0.10 0.07 1 1 0.70 0.00 0.00																	-	-					
VA 1200 1204 Cocupancy Sensor, 4LS Fluorescent Fixtures Misc 2014 2054 3.33 0.62 0.26 1.01 23% 0.01 0.12 18% 0.09 0.08 2 1 0.64 0.00 0.																	1	1					
VA 1330 1330 1330 1330 1330 1330 1330 1330 1332 12Ds (base incandescent Flood, 100W to Screw-in Replacement 2020 Misc 2020 2054 261.09 42.31 0.00 0.	VA	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Misc	2014	2054	3.33	0.62	0.26	1.01	23%	0.01	0.12	16%	0.09	0.08		1	0.64			0.00	0.00
VA 1330 1332 LEDs (base incandescent flood) 2020 Misc 2020 2054 57.45 9.75 203.64 203.64 78% 34.56 78% 0.00																				261.00	44.24		
VA 1430 14																				∠01.09	44.31		
VA 1430 1432 LEDs (base incandescent A-line 72W) 2020 Misc 2020 2054 22.39 3.80 71.61 71.61 76% 12.15 76% 0.00 0.00 0.00 0 0 12.18 71.61 12.15 76% 13.00 0.00 0.00 0.00 0 0 12.18 71.61 12.15 76% 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.	VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020		2020	2054	93.99	15.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A			N/A	93.99	15.95	0.00	0.00
VA 1530 1532 LEDs (base incandescent A-line 53W) 2020 Misc 2020 2054 22.17 3.76 47.02 47.02 68% 7.98 68% 0.01 0.01 0.01 0 0 8.86 47.02 7.98 VA 1630 1630 Base CFL 18W to screw-in replacement 2020 Misc 2020 2054 49.34 8.37 0.00 0.00 0% 0.00 0% 0.00 0% N/A N/A N/A N/A N/A N/A N/A 49.34 8.37 0.00 0.00 VA 1630 1631 LED screw-in replacement (base CFL 18W) 2020 Misc 2020 2054 63.05 10.70 0.00 0.00 0% 0.00 0% N/A	VA		1432 LEDs (base incandescent A-line 72W) 2020	Misc	2020	2054				71.61			12.15				0	0	12.18			71.61	
VA 1630 1630 Base CFL 18W to screw-in replacement (base CFL 18W) 2020 Misc 2020 2054 49.34 8.37 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																				69.19	11.74		
VA 1630 1631 LED screw-in replacement (base CFL 18W) 2020 Misc 2020 2054 35.67 6.05 13.67 2.8% 2.32 2.32 2.8% 0.05 0.05 0.05 0.01.15 13.67 2.32 VA 1730 1730 Base CFL 23W oscrew-in replacement (base CFL 23W) 2020 Misc 2020 2054 63.05 10.70 0.00 0.00 0% 0.00 0% NA NA NA NA NA NA NA 63.05 10.70 0.00 0.00 0.00 VA 1731 LED screw-in replacement (base CFL 23W) 2020 Misc 2020 2054 46.65 7.92 16.39 16.39 26% 2.78 2.78 2.78 2.78 2.78 2.78 2.78 2.78		1630									0%	0.00								49.34	8.37		
VA 1730 1731 LED screw-in replacement (base CFL 23W) 2020 Misc 2020 2054 46.65 7.92 16.39 16.39 26% 2.78 26% 0.04 0.04 0 0 1.53 16.39 2.78			1631 LED screw-in replacement (base CFL 18W) 2020		2020	2054			13.67		28%						0	0	1.15				
																				63.05	10.70		
																				85.35	14.48		

APPENDIX H

Base Avoided Costs

		ric Existing Construction		Year	2020																SUPPLY	
Vint				Measure					Total	Percent		Total	Percent	Marginal	Average	Marginal	Average					
		Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Cost Test	Base	Base	Economic	Economic
Sgn VA	nt Number 1800	Number Measure 1801 T5 (240W) (base metal halide)	Type Misc	Year 2014	Year 2054	GWH 56.49	MW 9.59	Savings 28.86	GWH 28.86	Savings 34%	Savings 4.90	MW 4.90	Savings 34%	\$/kWH 0.01	\$/kWH 0.01	\$/kW 0	\$/kW	8.49	GWH	MW	GWH 28.86	MW 4.90
VA	1800	1801 15 (240W) (base metal halide) 1806 Occupancy Sensor, High Bay T5	Misc	2014	2054	54.65	9.59	28.86 1.85	30.70	36%	0.08	4.90	34%	0.01	0.01	1	0	2.28			28.86 1.85	0.08
VA	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Misc	2014	2054	50.51	8.96	4.14	34.84	41%	0.56	5.53	38%	0.05	0.01	0	0	1.56			4.14	0.56
VA VA	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Misc Misc	2014 2014	2054 2054	9.40 5.06	1.60 0.86	0.00 4.34	0.00 4.34	0% 46%	0.00	0.00 0.74	0% 46%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.16	9.40	1.60	0.00 4.34	0.00
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Misc	2014	2054	89.16	6.90	0.00	0.00	0%	0.74	0.74	0%	0.03 N/A	0.03 N/A	N/A	N/A	2.16 N/A	89.16	6.90	0.00	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Misc	2014	2054	81.36	5.16	7.80	7.80	9%	1.74	1.74	25%	0.04	0.04	0	0	2.37			7.80	1.74
VA VA	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Misc Misc	2014 2014	2054 2054	39.15 27.71	1.89 1.09	42.21 11.44	50.01 61.45	56% 69%	3.27 0.80	5.01 5.81	73% 84%	0.09 0.59	0.08 0.18	1 8	1 2	0.77 0.12			0.00	0.00
VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Misc	2014	2054	81.13	62.75	0.00	0.00	0%	0.00	0.00	0%	0.59 N/A	0.16 N/A	N/A	N/A	0.12 N/A	81.13	62.75	0.00	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Misc	2014	2054	80.12	61.96	1.01	1.01	1%	0.78	0.78	1%	0.02	0.02	0	0	6.46			1.01	0.78
VA VA	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	Misc Misc	2014 2014	2054 2054	73.28 72.90	56.67 56.52	6.84 0.39	7.85 8.24	10% 10%	5.29 0.15	6.07 6.23	10% 10%	0.04 0.03	0.04 0.04	0	0	3.32 2.59			6.84 0.39	5.29 0.15
VA	2000	2003 Chiller Turie Op/Diagnostics 2013 High Efficiency Chiller Motors	Misc	2014	2054	72.83	56.47	0.06	8.30	10%	0.15	6.27	10%	0.03	0.04	0	0	2.59			0.06	0.15
VA	2000	2006 VSD for Chiller Pumps and Towers	Misc	2014	2054	70.00	55.36	2.83	11.13	14%	1.11	7.39	12%	0.05	0.04	0	0	1.87			2.83	1.11
VA VA	2000	2003 EMS - Chiller 2012 Duct Testing/Sealing - Chiller	Misc Misc	2014 2014	2054 2054	63.83 52.10	54.13 45.06	6.17 11.73	17.30 29.04	21% 36%	1.22 9.07	8.61 17.69	14% 28%	0.07 0.21	0.05 0.12	0	0	1.01 0.59			6.17 0.00	1.22 0.00
VA	2000	2002 Window Film (Standard) - Chiller	Misc	2014	2054	51.76	44.80	0.33	29.04	36%	0.26	17.09	29%	0.76	0.12	1	0	0.59			0.00	0.00
VA	2000	2004 Cool Roof - Chiller	Misc	2014	2054	51.66	44.72	0.10	29.47	36%	0.08	18.02	29%	3.31	0.13	4	0	0.03			0.00	0.00
VA VA	2000 2000	2011 Duct/Pipe Insulation - Chiller 2008 New Economizer - Chiller	Misc Misc	2014 2014	2054 2054	50.97 50.97	44.19 44.19	0.69 0.00	30.16 30.16	37% 37%	0.53	18.56 18.56	30% 30%	3.99 36828.01	0.22 0.28	5 185,639	0	0.02			0.00	0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Misc	2014	2054	312.72	241.85	0.00	0.00	0%	0.00	0.00	0%	N/A	0.26 N/A	N/A	N/A	N/A	312.72	241.85	0.00	0.00
VA	2100	2113 Ceiling/roof Insulation - DX	Misc	2014	2054	312.71	241.84	0.01	0.01	0%	0.01	0.01	0%	0.02	0.02	0	0	6.63			0.01	0.01
VA VA	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2105 DX Tune Up/ Advanced Diagnostics	Misc Misc	2014 2014	2054 2054	240.79 240.02	186.22 185.91	71.92 0.77	71.93 72.70	23% 23%	55.62 0.30	55.63 55.93	23% 23%	0.03 0.11	0.03 0.03	0	0	3.51 0.67			71.92 0.00	55.62 0.00
VA	2100	2112 Duct Testing/Sealing - DX	Misc	2014	2054	225.90	174.99	14.12	86.82	28%	10.92	66.85	28%	0.11	0.03	0	0	0.58			0.00	0.00
VA	2100	2106 Prog. Thermostat - DX	Misc	2014	2054	221.59	174.14	4.31	91.13	29%	0.86	67.71	28%	0.12	0.07	1	ō	0.50			0.00	0.00
VA	2100	2108 Optimize Controls - DX	Misc	2014	2054	217.91	173.41	3.68	94.82	30%	0.73	68.44	28%	0.13	0.07	1	0	0.44			0.00	0.00
VA VA	2100 2100	2115 Window Film (Standard) - DX 2107 Cool Roof - DX	Misc Misc	2014 2014	2054 2054	217.06 216.63	172.75 172.42	0.85	95.66 96.09	31% 31%	0.66 0.33	69.09 69.42	29% 29%	0.60 3.04	0.07 0.09	4	0	0.16 0.03			0.00	0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Misc	2014	2054	215.25	171.35	1.38	97.47	31%	1.07	70.49	29%	3.64	0.14	5	ō	0.03			0.00	0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Misc	2014	2054	297.00	229.69	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	297.00	229.69	0.00	0.00
VA VA	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Misc Misc	2014 2014	2054 2054	260.27 187.11	201.28 144.70	36.73 0.00	36.73 0.00	12% 0%	28.41 0.00	28.41 0.00	12% 0%	0.04 N/A	0.04 N/A	N/A	N/A	3.28 N/A	187.11	144.70	36.73 0.00	28.41 0.00
VA	2300	2301 HE PTAC, EER=9.6, 1 ton	Misc	2014	2054	161.77	125.11	25.34	25.34	14%	19.60	19.60	14%	0.08	0.08	0	0	1.43			25.34	19.60
VA	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Misc	2014	2054	351.21	99.79	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	351.21	99.79	0.00	0.00
VA VA	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP	Misc Misc	2014 2014	2054 2054	345.15 246.37	98.06 91.07	6.06 98.78	6.06 104.83	2% 30%	1.72 7.00	1.72 8.72	2% 9%	0.06 0.05	0.06 0.05	0	0	1.40 1.36			6.06 98.78	1.72 7.00
VA	3000	3003 Demand Controlled Ventilation	Misc	2014	2054	241.56	88.44	4.81	109.65	31%	2.63	11.35	11%	1.52	0.11	3	1	0.07			0.00	0.00
VA	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Misc	2014	2054	279.97	79.55	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	279.97	79.55	0.00	0.00
VA VA	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Misc Misc	2014 2014	2054 2054	239.56 223.16	69.24 68.07	40.41 16.41	40.41 56.81	14% 20%	10.31 1.16	10.31 11.47	13% 14%	0.03 0.04	0.03 0.03	0 1	0	2.68 1.41			40.41 16.41	10.31 1.16
VA	3100	3102 Variable Speed Drive Control, 15 HP	Misc	2014	2054	159.29	63.55	63.86	120.68	43%	4.52	16.00	20%	0.07	0.05	1	0	1.00			0.00	0.00
VA	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Misc	2014	2054	156.91	62.87	2.38	123.06	44% 45%	0.68	16.67	21%	0.20	0.05	1	0	0.44			0.00	0.00
VA VA	3100 3100	3105 Energy Recovery Ventilation (ERV) 3107 Demand Controlled Ventilation	Misc Misc	2014 2014	2054 2054	154.91 151.88	61.78 60.13	3.03	125.06 128.09	45% 46%	1.09 1.65	17.77 19.42	22% 24%	1.93	0.06 0.10	1	1	0.27 0.05			0.00	0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Misc	2014	2054	222.17	63.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	222.17	63.12	0.00	0.00
VA	3200	3203 Air Handler Optimization, 40 HP	Misc	2014	2054	206.95	62.04	15.22	15.22	7%	1.08	1.08	2%	0.03	0.03	0	0	1.65			15.22	1.08
VA VA	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	Misc Misc	2014 2014	2054 2054	147.72 147.14	57.85 57.68	59.23 0.59	74.44 75.03	34% 34%	4.20 0.17	5.27 5.44	8% 9%	0.10 0.50	0.09	1 2	1	0.64 0.18			0.00	0.00
VA	3200	3204 Demand Controlled Ventilation	Misc	2014	2054	144.26	56.11	2.88	77.90	35%	1.57	7.01	11%	1.61	0.15	3	2	0.06			0.00	0.00
VA	4000	4000 Base Built-Up Refrigeration System	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
VA VA	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Misc Misc	2014 2014	2054	306.76 299.24	46.18 45.05	0.00 7.52	0.00 7.52	0% 2%	0.00 1.13	0.00 1.13	0% 2%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 39.71	306.76	46.18	0.00 7.52	0.00 1.13
VA	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Misc	2014	2054	294.99	44.41	4.25	11.77	4%	0.64	1.77	4%	0.00	0.00	ő	0	37.07			4.25	0.64
VA	4100	4108 Energy-Star Refrigerator, glass door	Misc	2014	2054	293.75	44.22	1.24	13.00	4%	0.19	1.96	4%	0.01	0.00	0	0	12.55			1.24	0.19
VA VA	4100 4100	4106 Energy-Star Refrigerator, solid door 4110 Energy Star Ice Machines	Misc Misc	2014 2014	2054 2054	290.56 286.23	43.74 43.09	3.19 4.33	16.19 20.53	5% 7%	0.48 0.65	2.44 3.09	5% 7%	0.01 0.01	0.00	0	0	12.33 4.51			3.19 4.33	0.48 0.65
VA	4100	4112 Reach-in unit occupancy sensors	Misc	2014	2054	286.22	43.09	0.01	20.54	7%	0.00	3.09	7%	0.28	0.01	2	0	0.23			0.00	0.00
VA	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Misc	2014	2054	286.16	43.08	0.06	20.60	7%	0.01	3.10	7%	0.32	0.01	2	0	0.19			0.00	0.00
VA VA	5000 5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Misc Misc	2014	2054 2054	26.53 14.58	4.02 3.10	0.00 11.96	0.00 11.96	0% 45%	0.00 0.92	0.00 0.92	0% 23%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.18	26.53	4.02	0.00 11.96	0.00
VA	5000	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	Misc	2014	2054	10.03	2.41	4.54	16.50	45% 62%	0.92	1.61	23% 40%	0.01	0.01	0	0	2.12			4.54	0.92
VA	5100	5100 Base Laptop PC	Misc	2014	2054	1.52	0.23	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.52	0.23	0.00	0.00
VA VA	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Misc Misc	2014 2014	2054 2054	1.23 1.20	0.19 0.18	0.29	0.29 0.31	19% 21%	0.04	0.04 0.05	19% 21%	0.01 1.13	0.01 0.10	0 7	0	5.80 0.05			0.29 0.00	0.04
VA	5200	5200 Base Monitor, CRT	Misc	2014	2054	6.13	0.18	0.03	0.00	0%	0.00	0.00	0%	1.13 N/A	0.10 N/A	N/A	N/A	0.05 N/A	6.13	0.93	0.00	0.00
VA	5200	5201 Energy Star or Better Monitor - CRT	Misc	2014	2054	2.69	0.41	3.44	3.44	56%	0.52	0.52	56%	0.00	0.00	0	0	46.17			3.44	0.52
VA	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug lead controls Commercial Smart Strip (bace Monitor CRT)	Misc Misc	2014 2014	2054	2.01	0.35	0.68	4.12	67%	0.05	0.57	62% 64%	0.02	0.00	0	0	3.02			0.68	0.05
VA VA	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, I CD	Misc	2014	2054 2054	1.85 5.57	0.33	0.16	4.27 0.00	70% 0%	0.02	0.60	64% 0%	0.19 N/A	0.01 N/A	1 N/A	N/A	0.28 N/A	5.57	0.84	0.00	0.00
VA	5300	5301 Energy Star or Better Monitor - LCD	Misc	2014	2054	4.57	0.69	1.00	1.00	18%	0.15	0.15	18%	0.01	0.01	0	0	6.77		0.	1.00	0.15
VA	5300	5302 Monitor Power Management Enabling - LCD	Misc	2014	2054	4.41	0.68	0.16	1.16	21%	0.01	0.16	19%	0.07	0.02	1	0	0.68			0.00	0.00
VA	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Misc	2014	2054	4.07	0.67	0.33	1.49	27%	0.01	0.18	21%	0.21	0.06	5	1	0.22			0.00	0.00

DNV GL H-20 1/5/2015

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Moseure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt VA	Number 5400	Number Measure 5400 Base Copier	Type Misc	Year 2014	Year 2054	9.83	MW 1.49	Savings 0.00	GWH 0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	9.83	MW 1.49	0.00	0.00
VA	5400	5401 Energy Star or Better Copier	Misc	2014	2054	8.51	1.29	1.32	1.32	13%	0.20	0.20	13%	0.00	0.00	0	0	35.00	5.03	1.45	1.32	0.20
VA	5400	5402 Copier Power Management Enabling	Misc	2014	2054	8.09	1.26	0.42	1.74	18%	0.03	0.23	16%	0.09	0.02	1	0	0.61			0.00	0.00
VA VA	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Printer	Misc Misc	2014 2014	2054 2054	1.46 1.10	0.22	0.00 0.37	0.00 0.37	0% 25%	0.00 0.06	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.86	1.46	0.22	0.00 0.37	0.00
VA	5500	5501 Multifunction Power Management Enabling	Misc	2014	2054	0.92	0.15	0.18	0.55	37%	0.01	0.07	31%	0.23	0.08	3	1	0.22			0.00	0.00
VA VA	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Misc Misc	2014 2014	2054 2054	7.65 4.99	1.16 0.76	0.00 2.66	0.00 2.66	0% 35%	0.00 0.40	0.00 0.40	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 45.31	7.65	1.16	0.00 2.66	0.00
VA	5600	5601 Printer Power Management Enabling	Misc	2014	2054	4.17	0.69	0.82	3.48	45%	0.06	0.47	40%	0.05	0.00	1	0	1.02			0.82	0.06
VA	5700	5700 Base Data Center/Server Room	Misc	2014	2054	57.89	8.77	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	57.89	8.77	0.00	0.00
VA VA	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Misc Misc	2014 2014	2054 2054	52.10 45.47	7.89 6.89	5.79 6.63	5.79 12.42	10% 21%	0.88 1.00	0.88 1.88	10% 21%	0.00	0.00	0	0	117.62 47.88			5.79 6.63	0.88 1.00
VA	5700	5703 Data Center State of the Art practices	Misc	2014	2054	42.93	6.50	2.55	14.96	26%	0.39	2.27	26%	0.00	0.00	0	Ō	24.83			2.55	0.39
VA	6000	6000 Base Water Heating	Misc	2014	2054	92.42	13.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	92.42	13.64	0.00	0.00
VA VA	6000 6000	6007 Heat Trap 6002 High Efficiency Water Heater (electric)	Misc Misc	2014 2014	2054 2054	87.63 85.88	12.94 12.68	4.79 1.75	4.79 6.54	5% 7%	0.71 0.26	0.71 0.97	5% 7%	0.01 0.03	0.01 0.02	0	0	4.47 2.40			4.79 1.75	0.71 0.26
VA	6000	6004 Tankless Water Heater	Misc	2014	2054	79.44	11.73	6.44	12.98	14%	0.95	1.92	14%	0.05	0.03	0	0	1.71			6.44	0.95
VA VA	6000 6000	6003 Hot Water Pipe Insulation	Misc Misc	2014 2014	2054 2054	78.07 75.53	11.53 11.15	1.37 2.54	14.35 16.89	16% 18%	0.20 0.37	2.12 2.49	16% 18%	0.05 0.05	0.03 0.04	0	0	1.33 1.24			1.37 2.54	0.20 0.37
VA	6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	Misc	2014	2054	72.70	10.73	2.83	19.72	21%	0.42	2.49	21%	0.05	0.04	1	0	0.48			0.00	0.00
VA	7000	7000 Base Refrigerated Vending Machines	Misc	2014	2054	16.86	2.80	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.86	2.80	0.00	0.00
VA VA	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Misc Misc	2014 2014	2054 2054	14.16 12.68	2.58	2.70 1.48	2.70 4.18	16% 25%	0.23 0.12	0.23 0.35	8% 12%	0.03 0.05	0.03	0	0	1.99 1.09			2.70 1.48	0.23 0.12
VA	7100	7100 Base Non-Refrigerated Vending Machines	Misc	2014	2054	0.18	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.18	0.03	0.00	0.00
VA	7100	7101 Vending Misers (Non-Refrigerated)	Misc	2014	2054	0.10	0.02	0.08	0.08	46%	0.01	0.01	23%	0.44	0.44	5	5	0.12			0.00	0.00
VA VA	7200 7300	7200 Base Oven 7300 Base Fryer	Misc Misc	2014 2014	2054 2054	5.95 10.69	0.96 1.73	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	5.95 10.69	0.96 1.73	0.00	0.00
VA	7300	7301 Efficient Fryer	Misc	2014	2054	10.00	1.62	0.68	0.68	6%	0.11	0.11	6%	0.43	0.43	3	3	0.16			0.00	0.00
VA	7400 8000	7400 Base Steamer	Misc	2014 2014	2054	2.65	0.43	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A N/A	N/A	N/A	N/A	2.65	0.43	0.00	0.00
VA VA	8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc Misc	2014	2054 2054	45.34 42.78	0.00	2.56	0.00 2.56	0% 6%	0.00	0.00	0% 0%	N/A 0.03	0.03	N/A N/A	N/A N/A	N/A 2.18	45.34	0.00	0.00 2.56	0.00
VA	8100	8100 Base Heating, Other Electric	Misc	2014	2054	42.11	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	42.11	0.00	0.00	0.00
VA VA	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Misc Misc	2014 2014	2054 2054	803.83 803.83	133.64 133.64	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	803.83	133.64	0.00	0.00
NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Office	2020	2054	56.85	10.58	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	56.85	10.58	0.00	0.00
NC	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Office	2020	2054	56.82	10.58	0.03	0.03	0%	0.00	0.00	0%	0.01	0.01	0	0	6.45			0.03	0.00
NC NC	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Office Office	2020 2020	2054 2054	52.56 47.20	9.94 8.95	4.26 5.35	4.29 9.65	8% 17%	0.63 1.00	0.64 1.63	6% 15%	0.01 0.02	0.01 0.02	0	0	5.92 3.30			4.26 5.35	0.63 1.00
NC	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	2020	2054	41.20	7.83	6.01	15.65	28%	1.12	2.75	26%	0.04	0.03	0	o	1.58			6.01	1.12
NC NC	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Office Office	2020 2020	2054 2054	37.77 31.68	7.67 6.54	3.43 6.08	19.08 25.17	34% 44%	0.16 1.13	2.91 4.04	28% 38%	0.06 0.25	0.03	1	0	0.99			0.00	0.00
NC NC	1030	1034 ROB 4L4 LED Tube, 2020 1035 LED Troffer (base 4L4T8), 2020	Office	2020	2054	28.98	6.03	2.70	25.17	44%	0.50	4.04	38% 43%	0.25	0.08	1	1	0.29			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Office	2020	2054	0.96	0.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.96	0.18	0.00	0.00
NC NC	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Office Office	2020 2020	2054 2054	0.96 0.89	0.18 0.17	0.00 0.07	0.00 0.07	0% 8%	0.00 0.01	0.00 0.01	0% 6%	0.01 0.02	0.01 0.02	0	0	3.75 3.44			0.00 0.07	0.00 0.01
NC	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Office	2020	2054	0.80	0.15	0.09	0.17	17%	0.02	0.03	16%	0.02	0.02	0	0	2.60			0.09	0.02
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Office	2020	2054	0.69	0.13	0.10	0.27	28%	0.02	0.05	26%	0.05	0.03	0	0	1.25			0.10	0.02
NC NC	1130 1130	1134 ROB 2L4' LED Tube, 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Office Office	2020 2020	2054 2054	0.66 0.61	0.13 0.12	0.03	0.30 0.35	31% 37%	0.01 0.00	0.05 0.06	30% 31%	0.19 0.11	0.05 0.06	1 2	0	0.39 0.53			0.00	0.00
NC	1130	1135 LED Troffer (base 2L4'T8), 2020	Office	2020	2054	0.55	0.11	0.05	0.41	42%	0.01	0.07	36%	0.26	0.09	1	1	0.28			0.00	0.00
NC NC	1200 1200	1200 Base Other Fluorescent Fixture	Office	2014 2014	2054 2054	2.09	0.39	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 18.14	2.09	0.39	0.00	0.00
NC	1200	1203 Lighting Control Tuneup (base other fluorescent fixture) 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office Office	2014	2054	1.92	0.39	0.01	0.01	8%	0.00	0.00	6%	0.00	0.00	0	0	2.77			0.01	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	Office	2014	2054	1.72	0.33	0.20	0.36	17%	0.04	0.06	16%	0.08	0.05	0	0	0.81			0.00	0.00
NC NC	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Office Office	2014 2020	2054 2054	1.47 13.73	0.32 2.56	0.25 0.00	0.61 0.00	29% 0%	0.01 0.00	0.07	19% 0%	0.10 N/A	0.07 N/A	2 N/A	1 N/A	0.55 N/A	13.73	2.56	0.00	0.00
NC	1330	1332 LEDs (base incandescent flood) 2020	Office	2020	2054	2.40	0.45	11.33	11.33	83%	2.11	2.11	83%	0.01	0.01	0	0	11.74	10.70		11.33	2.11
NC NC	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	Office Office	2020 2020	2054 2054	4.94 0.94	0.92	0.00 4.00	0.00 4.00	0% 81%	0.00 0.75	0.00 0.75	0% 81%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.91	4.94	0.92	0.00 4.00	0.00 0.75
NC NC	1530	1432 LEDS (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Office	2020	2054	3.64	0.17	0.00	0.00	0%	0.75	0.75	81% 0%	0.01 N/A	0.01 N/A	N/A	N/A	9.91 N/A	3.64	0.68	0.00	0.75
NC	1530	1532 LEDs (base incandescent A-line 53W) 2020	Office	2020	2054	0.95	0.18	2.69	2.69	74%	0.50	0.50	74%	0.01	0.01	0	0	7.37			2.69	0.50
NC NC	1630 1630	1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	Office Office	2020 2020	2054 2054	0.25 0.18	0.05	0.00 0.07	0.00 0.07	0% 28%	0.00 0.01	0.00 0.01	0% 28%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 1.17	0.25	0.05	0.00 0.07	0.00 0.01
NC	1730	1730 Base CFL 23W to screw-in replacement (base CFL 18W) 2020	Office	2020	2054	0.18	0.03	0.07	0.07	28% 0%	0.00	0.00	28% 0%	0.05 N/A	0.05 N/A	N/A	N/A	1.17 N/A	0.32	0.06	0.07	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Office	2020	2054	0.23	0.04	0.08	0.08	26%	0.02	0.02	26%	0.04	0.04	0	0	1.56			0.08	0.02
NC NC	1800 1850	1800 BaseMetal Halide, 465W 1850 Base CFL Exit Sign	Office Office	2014 2014	2054 2054	0.00 0.52	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 0.52	0.00	0.00	0.00
NC	1850	1851 LED Exit Sign	Office	2014	2054	0.29	0.05	0.23	0.23	44%	0.04	0.04	44%	0.02	0.02	0	0	2.50			0.23	0.04
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Office	2014	2054	1.31	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.31	0.02	0.00	0.00
NC NC	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Office Office	2014 2014	2054 2054	1.19 0.57	0.01	0.12 0.62	0.12 0.74	9% 56%	0.01 0.01	0.01 0.01	30% 77%	0.04 0.08	0.04 0.08	1 6	1 4	1.80 0.77			0.12 0.00	0.01
NC	1900	1903 Bi-Level LED Outdoor Lighting	Office	2014	2054	0.40	0.00	0.17	0.90	69%	0.00	0.02	89%	0.54	0.16	44	9	0.12			0.00	0.00
NC NC	2000 2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2010 Ceiling/roof Insulation - Chiller	Office Office	2014 2014	2054 2054	0.75 0.75	0.53 0.52	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 19.08	0.75	0.53	0.00	0.00
INC	2000	2010 Gailing/1001 Insulation - Office	Office	2014	2004	0.75	0.32	0.00	0.00	U70	0.00	0.00	U76	0.01	0.01	U	U	15.00			0.00	0.00

APPENDIX H

Base Avoided Costs

			Existing Construction IVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
	ntage				Manager	Measure				Total	Percent		Total	Percent	Marginal	Average	Marginal						
	Base		easure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Cost Test	Base	Base	Economic	Economic
Sg NC	mt Number	on Nu	imber Measure 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Type Office	Year 2014	Year 2054	0.68	MW 0.48	Savings 0.06	GWH 0.07	Savings 9%	Savings 0.04	MW 0.05	Savings 9%	\$/kWH 0.03	\$/kWH 0.03	\$/kW 0	\$/kW	4.34	GWH	MW	GWH 0.06	MW 0.04
NC		000	2005 Chiller Tune Up/Diagnostics	Office	2014	2054	0.68	0.48	0.00	0.07	9%	0.04	0.05	9%	0.03	0.03	0	0	3.53			0.00	0.04
NC		000	2013 High Efficiency Chiller Motors	Office	2014	2054	0.68	0.48	0.00	0.07	9%	0.00	0.05	9%	0.04	0.03	0	0	2.83			0.00	0.00
NC NC		000	2006 VSD for Chiller Pumps and Towers 2003 FMS - Chiller	Office Office	2014 2014	2054 2054	0.68	0.48 0.47	0.00 0.05	0.07 0.12	10% 16%	0.00 0.01	0.05 0.06	9% 11%	0.03 0.05	0.03 0.04	0	0	2.60 1.48			0.00 0.05	0.00 0.01
NC		000	2008 New Economizer - Chiller	Office	2014	2054	0.59	0.46	0.04	0.16	22%	0.01	0.07	12%	0.06	0.04	0	0	1.12			0.04	0.01
NC		000	2002 Window Film (Standard) - Chiller	Office	2014	2054	0.59	0.46	0.00	0.16	22%	0.00	0.07	12%	0.09	0.04	0	0	1.02			0.00	0.00
NC NC		000	2012 Duct Testing/Sealing 2004 Cool Roof - Chiller	Office Office	2014 2014	2054 2054	0.48	0.38	0.11 0.00	0.27 0.28	36% 37%	0.08	0.14 0.14	27% 28%	0.16 0.23	0.09	0	0	0.76 0.41			0.00	0.00
NC		000	2011 Duct/Pipe Insulation - Chiller	Office	2014	2054	0.47	0.38	0.00	0.28	37%	0.00	0.15	28%	1.94	0.10	3	0	0.05			0.00	0.00
NC		100	2100 Base DX Packaged System, EER=10.3, 10 tons	Office	2014	2054	16.50	11.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.50	11.54	0.00	0.00
NC NC		100 100	2102 DX Packaged System, EER=13.4, 10 tons 2111 Economizer Repair - DX	Office Office	2014 2014	2054 2054	12.70 12.08	8.89 8.23	3.79 0.62	3.79 4.42	23% 27%	2.65 0.65	2.65 3.31	23% 29%	0.02 0.06	0.02 0.03	0	0	4.57 1.63			3.79 0.62	2.65 0.65
NC	2	100	2108 Optimize Controls - DX	Office	2014	2054	11.87	8.20	0.21	4.62	28%	0.04	3.35	29%	0.06	0.03	0	Ö	0.94			0.00	0.00
NO		100	2115 Window Film (Standard) - DX	Office	2014	2054	11.63	8.02	0.25	4.87	30%	0.17	3.52	30%	0.10	0.03	0	0	0.91			0.00	0.00
NC NC		100 100	2105 DX Tune Up/ Advanced Diagnostics 2109 Economizer - DX	Office Office	2014 2014	2054 2054	11.61 10.34	8.02 7.80	0.01 1.28	4.88 6.16	30% 37%	0.00 0.22	3.52 3.74	31% 32%	0.09	0.03 0.04	0	0	0.83 0.82			0.00	0.00
NC	2	100	2112 Aerosol Duct Sealing - DX	Office	2014	2054	9.71	7.36	0.63	6.79	41%	0.44	4.18	36%	0.20	0.06	0	Ö	0.61			0.00	0.00
NC		100	2106 Prog. Thermostat - DX	Office	2014	2054	9.50	7.32	0.21	6.99	42%	0.04	4.22	37%	0.11	0.06	1	0	0.57			0.00	0.00
NC NC		100 100	2107 Cool Roof - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office Office	2014 2014	2054 2054	9.42 9.42	7.26 7.26	0.08 0.00	7.07 7.08	43% 43%	0.06	4.28 4.28	37% 37%	0.26 0.21	0.06 0.06	0	0	0.37 0.31			0.00	0.00
NC		100	2114 Duct/Pipe Insulation - DX	Office	2014	2054	9.36	7.22	0.06	7.14	43%	0.04	4.32	37%	2.16	0.08	3	0	0.04			0.00	0.00
NC		200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Office	2014	2054	18.61	13.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.61	13.02	0.00	0.00
NC NC		200 300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Office Office	2014 2014	2054 2054	16.31 2.08	11.41 1.45	2.30 0.00	2.30 0.00	12% 0%	1.61 0.00	1.61 0.00	12% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	6.40 N/A	2.08	1.45	2.30 0.00	1.61 0.00
NC		000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Office	2014	2054	13.42	4.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.42	4.05	0.00	0.00
NC		000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Office	2014	2054	13.21	3.99	0.22	0.22	2%	0.07	0.07	2%	0.02	0.02	0	0	4.54			0.22	0.07
NC NC		000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Office Office	2014 2014	2054 2054	9.98 9.44	3.74 3.43	3.22 0.54	3.44 3.99	26% 30%	0.24 0.31	0.31 0.62	8% 15%	0.02 0.66	0.02 0.10	0 1	0	4.28 0.16			3.22 0.00	0.24 0.00
NC		100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	2014	2054	2.33	0.70	0.00	0.00	0%	0.00	0.02	0%	N/A	N/A	N/A	N/A	N/A	2.33	0.70	0.00	0.00
NC		100	3102 Variable Speed Drive Control, 15 HP	Office	2014	2054	1.76	0.66	0.57	0.57	24%	0.04	0.04	6%	0.00	0.00	0	0	15.75			0.57	0.04
NC NC		100 100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Office Office	2014 2014	2054 2054	1.75 1.63	0.66 0.62	0.01 0.12	0.58 0.69	25% 30%	0.00	0.05 0.08	7% 11%	0.01 0.02	0.00 0.01	0	0	7.56 3.35			0.01 0.12	0.00
NC		100	3103 Air Handler Optimization, 15 HP	Office	2014	2054	1.48	0.61	0.12	0.85	37%	0.03	0.09	13%	0.02	0.01	0	0	2.55			0.12	0.03
NC		100	3105 Energy Recovery Ventilation (ERV)	Office	2014	2054	1.44	0.59	0.03	0.88	38%	0.02	0.11	16%	0.25	0.02	0	0	0.45			0.00	0.00
NC NC		100 200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Office Office	2014 2014	2054 2054	1.36 1.47	0.55	0.08	0.96	41% 0%	0.04	0.15 0.00	22% 0%	0.79 N/A	0.08 N/A	1 N/A	1 N/A	0.13 N/A	1.47	0.44	0.00	0.00
NC		200	3203 Air Handler Optimization, 40 HP	Office	2014	2054	1.33	0.44	0.14	0.14	10%	0.00	0.00	2%	0.02	0.02	0	0	3.64	1.47	0.44	0.14	0.00
NC		200	3202 Variable Speed Drive Control, 40 HP	Office	2014	2054	1.00	0.41	0.32	0.46	32%	0.02	0.04	8%	0.02	0.02	0	0	2.83			0.32	0.02
NC NC		200 200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Office Office	2014 2014	2054 2054	1.00 0.94	0.41	0.00 0.05	0.47 0.52	32% 36%	0.00	0.04 0.07	8% 15%	0.11 0.72	0.02 0.09	0	0	0.85 0.15			0.00	0.00
NC		000	4000 Base Built-Up Refrigeration System	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC		100	4100 Base Self-Contained Refrigeration	Office	2014	2054	4.90	0.69	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.90	0.69	0.00	0.00
NC NC		100 100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4110 Energy Star Ice Machines	Office Office	2014 2014	2054 2054	4.81 4.80	0.67 0.67	0.09 0.01	0.09	2% 2%	0.01 0.00	0.01 0.01	2% 2%	0.00 0.02	0.00	0	0	24.82 3.26			0.09 0.01	0.01 0.00
NC		000	5000 Base Desktop PC	Office	2014	2054	8.14	1.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.14	1.13	0.00	0.00
NC	50	000	5001 PC Network Power Management Enabling	Office	2014	2054	4.39	0.87	3.75	3.75	46%	0.26	0.26	23%	0.01	0.01	0	0	4.60			3.75	0.26
NC NC		000 100	5002 Energy Star or Better PC 5100 Base Laptop PC	Office Office	2014 2014	2054 2054	3.41 0.20	0.73	0.98 0.00	4.72 0.00	58% 0%	0.14	0.40	35% 0%	0.02 N/A	0.01 N/A	0 N/A	0 N/A	2.28 N/A	0.20	0.03	0.98 0.00	0.14 0.00
NC		100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Office	2014	2054	0.20	0.03	0.04	0.04	19%	0.00	0.00	19%	0.01	0.01	0	0	6.22	0.20	0.03	0.00	0.00
NC	5	100	5101 Laptop Network Power Management Enabling	Office	2014	2054	0.16	0.02	0.00	0.04	21%	0.00	0.01	21%	1.03	0.09	7	1	0.05			0.00	0.00
NC NC		200 200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Office Office	2014 2014	2054 2054	2.91 1.67	0.40 0.23	0.00 1.24	0.00 1.24	0% 43%	0.00 0.17	0.00 0.17	0% 43%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 64.73	2.91	0.40	0.00 1.24	0.00 0.17
NC		200	5201 Energy Star of Better Monitor - CR1 5202 Monitor Power Management Enabling - CRT	Office	2014	2054	1.45	0.23	0.22	1.46	50%	0.17	0.17	46%	0.00	0.00	0	0	5.49			0.22	0.17
NC	52	200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Office	2014	2054	1.34	0.20	0.11	1.58	54%	0.02	0.20	50%	0.12	0.01	1	0	0.46			0.00	0.00
NC NC		300 300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Office Office	2014 2014	2054 2054	1.20 1.04	0.17 0.14	0.00 0.16	0.00 0.16	0% 13%	0.00 0.02	0.00	0% 13%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.91	1.20	0.17	0.00 0.16	0.00 0.02
NC		300	5301 Energy Star of Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Office	2014	2054	0.97	0.14	0.16	0.16	20%	0.02	0.02	16%	0.01	0.01	1	0	0.57			0.16	0.02
NC	5	300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Office	2014	2054	0.89	0.14	0.08	0.31	26%	0.00	0.03	18%	0.24	0.08	7	1	0.19			0.00	0.00
NC		100	5400 Base Copier	Office	2014	2054	3.29	0.46	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.29	0.46	0.00	0.00
NC NC		400 400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	Office Office	2014 2014	2054 2054	2.96 2.83	0.41 0.40	0.33 0.13	0.33 0.45	10% 14%	0.05 0.01	0.05 0.05	10% 12%	0.00 0.07	0.00 0.02	0 1	0	39.05 0.71			0.33	0.05 0.00
NC	55	500	5500 Base Multifunction	Office	2014	2054	0.45	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.45	0.06	0.00	0.00
NO		500	5502 ENERGY STAR Multi-Function Device	Office	2014	2054	0.34	0.05	0.11	0.11	25%	0.02	0.02	25%	0.01	0.01	0	0	10.57			0.11	0.02
NC NC		500 500	5501 Multifunction Power Management Enabling 5600 Base Printer	Office Office	2014 2014	2054 2054	0.28 4.28	0.04	0.06	0.18	39% 0%	0.00	0.02	32% 0%	0.21 N/A	0.08 N/A	3 N/A	1 N/A	0.24 N/A	4.28	0.59	0.00	0.00
NC	5 5	600	5602 ENERGY STAR Printer	Office	2014	2054	2.79	0.39	1.49	1.49	35%	0.21	0.21	35%	0.00	0.00	0	0	48.60	0	2.00	1.49	0.21
NC		500	5601 Printer Power Management Enabling	Office	2014	2054	2.28	0.35	0.51	2.00	47%	0.04	0.24	41%	0.05	0.01	1	0	1.10	1 24	0.10	0.51	0.04
NC NC		700 700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Office Office	2014 2014	2054 2054	1.34 1.21	0.19 0.17	0.00 0.13	0.00 0.13	0% 10%	0.00	0.00 0.02	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 173.26	1.34	0.19	0.00 0.13	0.00
NC	5	700	5702 Data Center Best Practices	Office	2014	2054	1.05	0.15	0.15	0.29	21%	0.02	0.04	21%	0.00	0.00	0	0	70.54			0.15	0.02
NO		700	5703 Data Center State of the Art practices	Office	2014	2054	0.99	0.14	0.06	0.35	26%	0.01	0.05	26%	0.00	0.00	0	0	36.58			0.06	0.01
NC NC		000	6000 Base Water Heating 6007 Heat Trap	Office Office	2014	2054 2054	3.14 2.98	0.42	0.00 0.16	0.00	0% 5%	0.00	0.00 0.02	0% 5%	N/A 0.01	N/A 0.01	N/A	N/A	N/A 4.57	3.14	0.42	0.00	0.00
140	- 0		ooo, noot map	Jilice	2014	2004	2.50	0.40	0.10	0.10	J /0	0.02	0.02	J /0	0.01	0.01	U	U	7.31			0.10	0.02

APPENDIX H

Base Avoided Costs

		c Existing Construction TIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vintage	יוטטה								Total			Total		Marginal	Average	Marginal	Average				301111	
Base		Measure	Building	Measure	Measure End	e Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity	Capacity Cost	Resource Cost Test	Base	Base	Economic	Economic
Sgmt Num		lumber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
NC NC	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Office Office	2014 2014	2054 2054	2.92 2.70	0.39	0.06 0.22	0.22 0.44	7% 14%	0.01	0.03	7% 14%	0.03 0.04	0.02 0.03	0	0	2.45 1.75			0.06 0.22	0.01 0.03
NC	6000	6008 Solar Water Heater	Office	2014	2054	1.26	0.17	1.44	1.88	60%	0.19	0.25	60%	0.05	0.05	Ö	ő	1.50			1.44	0.19
	6000	6003 Hot Water Pipe Insulation	Office	2014	2054	1.25	0.17	0.01	1.89	60%	0.00	0.26	60%	0.11	0.05	1	0	0.63			0.00	0.00
	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	Office Office	2014 2014	2054 2054	1.17	0.16 0.15	0.08	1.97 2.01	63% 64%	0.01	0.27 0.27	63% 64%	0.12 0.35	0.05 0.06	1	0	0.55 0.21			0.00	0.00
	7000	7000 Base Refrigerated Vending Machines	Office	2014	2054	1.93	0.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.93	0.28	0.00	0.00
NC	7000	7001 Vending Misers (Refrigerated units)	Office	2014	2054	1.62	0.26	0.31	0.31	16%	0.02	0.02	8%	0.03	0.03	0	0	1.98			0.31	0.02
	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Office Office	2014 2014	2054 2054	1.45 0.00	0.25	0.17 0.00	0.48	25% 0%	0.01	0.03	12% 0%	0.05 N/A	0.03 N/A	1 N/A	0 N/A	1.09 N/A	0.00	0.00	0.17 0.00	0.01
	7200	7100 Base Non-kerngerated vending Machines 7200 Base Oven	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	7300	7300 Base Fryer	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	7400	7400 Base Steamer	Office	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office Office	2014 2014	2054 2054	2.83 2.67	0.00	0.00 0.16	0.00 0.16	0% 6%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A N/A	N/A N/A	N/A 3.58	2.83	0.00	0.00 0.16	0.00
	8100	8100 Base Heating, Other Electric	Office	2014	2054	2.65	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.65	0.00	0.00	0.00
	9500	9500 Base Miscellaneous	Office	2014	2054	22.23	3.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	22.23	3.24	0.00	0.00
	9500	9501 Xmisc	Office	2014	2054	22.23	3.24	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A	N/A	N/A	0.00	0.70	0.16	0.00	0.00
NC NC	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1036 Lighting Control Tuneup (base 4L4'T8), 2020	Restaurant Restaurant	2020 2020	2054 2054	0.79 0.79	0.16 0.16	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.75	0.79	0.16	0.00	0.00
NC	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Restaurant	2020	2054	0.73	0.15	0.06	0.06	8%	0.01	0.01	6%	0.01	0.01	0	0	6.12			0.06	0.01
	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Restaurant	2020	2054	0.65	0.13	0.08	0.14	17%	0.01	0.02	16%	0.03	0.02	0	0	1.89			0.08	0.01
	1030 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Restaurant Restaurant	2020 2020	2054 2054	0.57	0.11	0.08 0.01	0.22	28% 29%	0.02	0.04 0.04	26% 26%	0.07 0.13	0.04 0.04	0	0	0.91 0.44			0.00	0.00
NC NC	1030	1037 Occupancy Sensor, 4L4 Problescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Restaurant	2020	2054	0.47	0.10	0.01	0.23	40%	0.00	0.04	38%	0.13	0.04	2	1	0.44			0.00	0.00
	1030	1035 LED Troffer (base 4L4'T8), 2020	Restaurant	2020	2054	0.43	0.09	0.04	0.36	45%	0.01	0.07	43%	0.33	0.16	2	1	0.22			0.00	0.00
	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Restaurant Restaurant	2020 2020	2054 2054	4.69 4.68	0.93	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.22	4.69	0.93	0.00	0.00
	1130	1136 Lighting Control Tuneup (base 2L418), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Restaurant	2020	2054	4.68	0.92	0.00	0.00	8%	0.00	0.00	6%	0.02	0.02	0	0	2.93			0.00	0.00
NC	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Restaurant	2020	2054	3.88	0.78	0.45	0.81	17%	0.09	0.14	16%	0.04	0.03	0	Ö	1.49			0.45	0.09
	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Restaurant	2020	2054	3.38	0.68	0.49	1.30	28%	0.10	0.24	26%	0.09	0.05	0	0	0.72			0.00	0.00
	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Restaurant Restaurant	2020 2020	2054 2054	3.22 2.95	0.65	0.16 0.27	1.47 1.74	31% 37%	0.03	0.27 0.33	30% 36%	0.32 0.40	0.08 0.13	2	0	0.23 0.18			0.00	0.00
	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Restaurant	2020	2054	2.90	0.59	0.04	1.78	38%	0.00	0.33	36%	0.40	0.13	5	1	0.18			0.00	0.00
	1200	1200 Base Other Fluorescent Fixture	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Restaurant	2020 2020	2054 2054	1.22	0.24	0.00 0.98	0.00 0.98	0% 80%	0.00 0.19	0.00	0% 80%	N/A	N/A	N/A 0	N/A 0	N/A	1.22	0.24	0.00	0.00
	1330 1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Restaurant Restaurant	2020	2054	0.24	0.05	0.98	0.98	80% 0%	0.19	0.19	80% 0%	0.01 N/A	0.01 N/A	N/A	N/A	8.08 N/A	0.44	0.09	0.98	0.19 0.00
	1430	1432 LEDs (base incandescent A-line 72W) 2020	Restaurant	2020	2054	0.09	0.02	0.34	0.34	79%	0.07	0.07	79%	0.01	0.01	0	0	6.80			0.34	0.07
	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Restaurant	2020	2054	0.32	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.32	0.06	0.00	0.00
NC NC	1530 1630	1532 LEDs (base incandescent A-line 53W) 2020 1630 Base CFL 18W to screw-in replacement 2020	Restaurant Restaurant	2020 2020	2054 2054	0.09	0.02	0.23 0.00	0.23	71% 0%	0.05 0.00	0.05 0.00	71% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	5.00 N/A	0.16	0.03	0.23 0.00	0.05 0.00
	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Restaurant	2020	2054	0.12	0.02	0.04	0.04	28%	0.01	0.01	28%	0.08	0.08	0	0	0.71	0.10	0.00	0.00	0.00
	1730	1730 Base CFL 23W to screw-in replacement 2020	Restaurant	2020	2054	0.20	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.20	0.04	0.00	0.00
NC NC	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Restaurant Restaurant	2020 2014	2054 2054	0.15	0.03	0.05	0.05	26% 0%	0.01 0.00	0.01 0.00	26% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	0.95 N/A	0.00	0.00	0.00	0.00
	1800	1801 T5 (240W) (base metal halide)	Restaurant	2014	2054	0.00	0.00	0.00	0.00	34%	0.00	0.00	34%	0.02	0.02	0	0	5.32	0.00	0.00	0.00	0.00
NC	1800	1806 Occupancy Sensor, High Bay T5	Restaurant	2014	2054	0.00	0.00	0.00	0.00	36%	0.00	0.00	34%	0.04	0.02	1	0	1.39			0.00	0.00
NC	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Restaurant	2014	2054	0.00	0.00	0.00	0.00	41%	0.00	0.00	38%	1.06	0.14	7	1	0.07			0.00	0.00
	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Restaurant Restaurant	2014 2014	2054 2054	0.11	0.02	0.00 0.07	0.00	0% 58%	0.00 0.01	0.00 0.01	0% 58%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.08	0.11	0.02	0.00 0.07	0.00 0.01
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Restaurant	2014	2054	1.83	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.83	0.12	0.00	0.00
NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Restaurant	2014	2054	1.52	0.06	0.31	0.31	17%	0.06	0.06	50%	0.07	0.07	0	0	1.27			0.31	0.06
NC NC	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Restaurant Restaurant	2014 2014	2054 2054	0.73	0.01	0.79 0.21	1.10 1.31	60% 72%	0.05	0.11	93% 104%	0.16 1.02	0.13 0.28	2 17	1 3	0.44			0.00	0.00
	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Restaurant	2014	2054	0.52	0.00	0.21	0.00	0%	0.01	0.13	0%	1.02 N/A	0.28 N/A	N/A	N/A	0.07 N/A	0.42	0.26	0.00	0.00
NC	2000	2010 Ceiling/roof Insulation - Chiller	Restaurant	2014	2054	0.39	0.24	0.03	0.03	7%	0.02	0.02	7%	0.02	0.02	0	0	7.73			0.03	0.02
	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Restaurant	2014	2054	0.35	0.22	0.03	0.06	15%	0.02	0.04	15%	0.02	0.02	0	0	5.22			0.03	0.02
	2000 2000	2005 Chiller Tune Up/Diagnostics 2003 EMS - Chiller	Restaurant Restaurant	2014 2014	2054 2054	0.35	0.22	0.00	0.06	15% 22%	0.00	0.04 0.04	15% 17%	0.02 0.04	0.02	0	0	4.40 1.86			0.00 0.03	0.00
	2000	2012 Duct Testing/Sealing	Restaurant	2014	2054	0.32	0.18	0.06	0.05	36%	0.04	0.04	31%	0.04	0.06	0	0	0.99			0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Restaurant	2014	2054	6.90	4.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.90	4.32	0.00	0.00
	2100 2100	2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	Restaurant Restaurant	2014 2014	2054 2054	6.90 5.31	4.32 3.32	0.00 1.59	0.00 1.59	0% 23%	0.00 0.99	0.00 0.99	0% 23%	0.01 0.02	0.01 0.02	0	0	8.33 5.90			0.00 1.59	0.00
	2100	2102 DX Packaged System, EER=13.4, 10 tons 2115 Window Film (Standard) - DX	Restaurant	2014	2054	4.93	3.32	0.39	1.59	23%	0.99	1.24	23% 29%	0.02	0.02	0	0	4.09			0.39	0.99
NC	2100	2108 Optimize Controls - DX	Restaurant	2014	2054	4.84	3.07	0.09	2.06	30%	0.01	1.25	29%	0.04	0.02	0	0	1.25			0.09	0.01
	2100	2105 DX Tune Up/ Advanced Diagnostics	Restaurant	2014	2054	4.84	3.07	0.00	2.06	30%	0.00	1.25	29%	0.07	0.02	0	0	1.10			0.00	0.00
	2100 2100	2106 Prog. Thermostat - DX 2112 Aerosol Duct Sealing - DX	Restaurant Restaurant	2014	2054 2054	4.73 4.46	3.05	0.11	2.17	31% 35%	0.02	1.27 1.43	29% 33%	0.06 0.13	0.02	0	0	0.92 0.87			0.00	0.00
	2100	2111 Economizer Repair - DX	Restaurant	2014	2054	4.46	2.75	0.14	2.58	37%	0.17	1.43	36%	0.13	0.03	0	0	0.72			0.00	0.00
NC	2100	2107 Cool Roof - DX	Restaurant	2014	2054	4.18	2.67	0.14	2.72	39%	0.09	1.65	38%	0.14	0.04	0	0	0.66			0.00	0.00
	2100 2100	2109 Economizer - DX	Restaurant Restaurant	2014 2014	2054 2054	4.10 4.10	2.65 2.65	0.09	2.80	41% 41%	0.01	1.66 1.67	39% 39%	0.15 0.15	0.05	1	0	0.42			0.00	0.00
	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2114 Duct/Pipe Insulation - DX	Restaurant	2014	2054	4.10 4.05	2.65	0.00	2.80	41% 41%	0.00	1.67	39%	0.15 1.55	0.05	1 2	0	0.41			0.00	0.00
.10	_100	Z Sacr. po modiation - DA	restaurant	2014	2004	7.00	2.02	0.00	2.00	7170	0.00	1.70	3370	1.55	0.01	-	0	0.00			0.00	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		tric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	age			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgn NC	nt Number 2200	Number Measure 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Type Restaurant	Year 2014	Year 2054	3.42	MW 2.14	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	3.42	MW 2.14	0.00	0.00
NC	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	2014	2054	3.00	1.88	0.42	0.42	12%	0.27	0.27	12%	0.01	0.01	0	0	8.27			0.42	0.27
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	Restaurant	2014	2054	1.27	0.80	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.27	0.80	0.00	0.00
NC NC	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Restaurant Restaurant	2014 2014	2054 2054	3.98 3.91	1.03 1.01	0.00	0.00 0.07	0% 2%	0.00 0.02	0.00 0.02	0% 2%	N/A 0.11	N/A 0.11	N/A 0	N/A 0	N/A 0.78	3.98	1.03	0.00	0.00
NC	3000	3002 Variable Speed Drive Control, 5 HP	Restaurant	2014	2054	2.72	0.93	1.19	1.26	32%	0.08	0.09	9%	0.09	0.09	1	1	0.76			0.00	0.00
NC	3000 3100	3003 Demand Controlled Ventilation	Restaurant	2014 2014	2054 2054	2.36	0.75	0.37	1.62	41% 0%	0.18	0.28	27% 0%	0.86 N/A	0.26 N/A	2 N/A	2	0.12	0.00	0.00	0.00	0.00
NC NC	3200	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Restaurant Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	4000	4000 Base Built-Up Refrigeration System	Restaurant	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	4100 4100		Restaurant	2014 2014	2054 2054	17.13 16.71	2.56 2.50	0.00 0.42	0.00 0.42	0% 2%	0.00	0.00	0% 2%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 13.90	17.13	2.56	0.00 0.42	0.00
NC	4100		Restaurant Restaurant	2014	2054	16.47	2.47	0.42	0.42	4%	0.06	0.06 0.10	4%	0.00	0.00	0	0	8.75			0.42	0.06
NC	4100	4109 Energy-Star Freezer, glass door	Restaurant	2014	2054	16.21	2.43	0.25	0.92	5%	0.04	0.14	5%	0.01	0.01	0	0	7.74			0.25	0.04
NC NC	4100 4100		Restaurant Restaurant	2014 2014	2054 2054	16.11 15.99	2.41 2.39	0.11 0.12	1.02 1.14	6% 7%	0.02 0.02	0.15	6% 7%	0.02 0.03	0.01	0	0	3.11 2.55			0.11 0.12	0.02 0.02
NC	4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Restaurant	2014	2054	15.74	2.39	0.12	1.14	8%	0.02	0.17	8%	0.03	0.01	0	0	2.55			0.12	0.02
NC	4100	4110 Energy Star Ice Machines	Restaurant	2014	2054	15.49	2.32	0.24	1.64	10%	0.04	0.24	10%	0.07	0.02	0	0	0.90			0.00	0.00
NC NC	4100 4100	4112 Reach-in unit occupancy sensors	Restaurant Restaurant	2014 2014	2054 2054	15.49 15.45	2.32	0.01 0.04	1.64 1.68	10% 10%	0.00 0.01	0.25 0.25	10% 10%	0.29 0.33	0.02 0.03	2	0	0.22 0.18			0.00	0.00
NC NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014 4101 Strip curtains for walk-ins (self-contained)	Restaurant	2014	2054	15.45	2.31	0.04	1.68	10%	0.01	0.25	10%	0.33	0.03	2	0	0.18			0.00	0.00
NC	5000	5000 Base Desktop PC	Restaurant	2014	2054	0.24	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.24	0.05	0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	Restaurant	2014	2054	0.13	0.04	0.11	0.11	45%	0.01	0.01	23%	0.02	0.02	0	0	2.69			0.11	0.01
NC NC	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	Restaurant Restaurant	2014 2014	2054 2054	0.09	0.03	0.04	0.15 0.00	63% 0%	0.01	0.02	41% 0%	0.04 N/A	0.03 N/A	0 N/A	0 N/A	1.36 N/A	0.01	0.00	0.04 0.00	0.01 0.00
NC	5100		Restaurant	2014	2054	0.01	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	3.80	0.01	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Restaurant	2014	2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	1.77	0.16	9	1	0.03			0.00	0.00
NC NC	5200 5200		Restaurant Restaurant	2014 2014	2054 2054	0.05	0.01	0.00	0.00	0% 56%	0.00 0.01	0.00 0.01	0% 56%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 30.23	0.05	0.01	0.00	0.00 0.01
NC	5200	5202 Monitor Power Management Enabling - CRT	Restaurant	2014	2054	0.02	0.00	0.03	0.03	67%	0.00	0.01	62%	0.00	0.00	0	0	1.97			0.03	0.00
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Restaurant	2014	2054	0.02	0.00	0.00	0.04	69%	0.00	0.01	64%	0.30	0.02	2	0	0.19			0.00	0.00
NC NC	5300 5300	5300 Base Monitor, LCD	Restaurant Restaurant	2014 2014	2054 2054	0.06	0.01	0.00 0.01	0.00 0.01	0% 20%	0.00	0.00	0% 20%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.33	0.06	0.01	0.00 0.01	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Restaurant	2014	2054	0.05	0.01	0.01	0.01	20%	0.00	0.00	20%	0.02	0.02	2	0	0.30			0.01	0.00
NC	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Restaurant	2014	2054	0.04	0.01	0.00	0.02	32%	0.00	0.00	25%	0.47	0.13	9	1	0.10			0.00	0.00
NC	5400		Restaurant	2014	2054	0.12	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.02	0.00	0.00
NC NC	5400 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	Restaurant Restaurant	2014 2014	2054 2054	0.11 0.10	0.02	0.02	0.02	15% 23%	0.00	0.00	15% 19%	0.00	0.00 0.05	0	0	22.54 0.36			0.02 0.00	0.00
NC	5500	5500 Base Multifunction	Restaurant	2014	2054	0.04	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
NC	5500		Restaurant	2014	2054	0.03	0.01	0.01	0.01	25%	0.00	0.00	25%	0.01	0.01	0	0	6.45			0.01	0.00
NC NC	5500 5600		Restaurant Restaurant	2014 2014	2054 2054	0.02	0.01	0.01 0.00	0.02	52% 0%	0.00	0.00	39% 0%	0.56 N/A	0.29 N/A	6 N/A	2 N/A	0.09 N/A	0.04	0.01	0.00	0.00
NC	5600		Restaurant	2014	2054	0.02	0.00	0.00	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	29.66	0.04	0.01	0.01	0.00
NC	5600		Restaurant	2014	2054	0.02	0.00	0.01	0.02	58%	0.00	0.00	47%	0.12	0.05	1	0	0.43			0.00	0.00
NC NC	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Restaurant Restaurant	2014 2014	2054 2054	0.05 0.05	0.01 0.01	0.00 0.01	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 106.53	0.05	0.01	0.00 0.01	0.00
NC	5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Restaurant	2014	2054	0.05	0.01	0.01	0.01	21%	0.00	0.00	21%	0.00	0.00	0	0	43.37			0.01	0.00
NC	5700	5703 Data Center State of the Art practices	Restaurant	2014	2054	0.04	0.01	0.00	0.01	26%	0.00	0.00	26%	0.00	0.00	0	0	22.49			0.00	0.00
NC	6000 6000		Restaurant	2014	2054 2054	2.97	0.50	0.00	0.00	0% 5%	0.00	0.00	0% 5%	N/A	N/A 0.01	N/A	N/A	N/A	2.97	0.50	0.00	0.00
NC NC	6000	6007 Heat Trap 6002 High Efficiency Water Heater (electric)	Restaurant Restaurant	2014	2054	2.81 2.76	0.47	0.15 0.06	0.15	5% 7%	0.03	0.03 0.04	5% 7%	0.01 0.01	0.01	0	0	10.74 5.79			0.15 0.06	0.03
NC	6000	6006 Heat Recovery Unit	Restaurant	2014	2054	1.32	0.22	1.43	1.64	55%	0.24	0.28	55%	0.01	0.01	0	ō	5.64			1.43	0.24
NC	6000		Restaurant	2014	2054	1.22	0.21	0.10	1.74	59%	0.02	0.29	59%	0.04	0.01	0	0	1.98			0.10	0.02
NC NC	6000 6000	6008 Solar Water Heater 6003 Hot Water Pipe Insulation	Restaurant Restaurant	2014 2014	2054 2054	1.05	0.18	0.17	1.91 1.93	65% 65%	0.03	0.32 0.33	65% 65%	0.05 0.06	0.02 0.02	0	0	1.70 1.32			0.17 0.02	0.03
NC	6000		Restaurant	2014	2054	0.99	0.17	0.04	1.97	67%	0.01	0.33	67%	0.18	0.02	1	0	0.42			0.00	0.00
NC	7000		Restaurant	2014	2054	0.20	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.20	0.04	0.00	0.00
NC NC	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Restaurant Restaurant	2014 2014	2054 2054	0.16 0.15	0.04	0.03 0.02	0.03 0.05	16% 25%	0.00	0.00	8% 12%	0.03 0.05	0.03	0	0	2.02 1.10			0.03 0.02	0.00
NC	7100	7100 Base Non-Refrigerated Vending Machines	Restaurant	2014	2054	0.00	0.00	0.02	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.02	0.00
NC	7200	7200 Base Oven	Restaurant	2014	2054	1.06	0.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.06	0.22	0.00	0.00
NC NC	7200 7300	7201 Convection Oven 7300 Base Fryer	Restaurant Restaurant	2014 2014	2054 2054	0.81 0.82	0.17 0.17	0.24	0.24	23% 0%	0.05 0.00	0.05 0.00	23% 0%	0.10 N/A	0.10 N/A	0 N/A	0 N/A	0.73 N/A	0.82	0.17	0.00	0.00
NC NC	7300		Restaurant Restaurant	2014	2054	0.82	0.17	0.00	0.00	0% 6%	0.00	0.00	0% 6%	N/A 0.32	0.32	N/A 2	N/A 2	N/A 0.22	0.62	0.17	0.00	0.00
NC	7400	7400 Base Steamer	Restaurant	2014	2054	0.75	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.75	0.15	0.00	0.00
NC	7400	7401 Efficient Steamer	Restaurant	2014	2054	0.23	0.05	0.52	0.52	69%	0.11	0.11	69%	0.05	0.05	0	0	1.59	0.40	0.00	0.52	0.11
NC NC	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant Restaurant	2014 2014	2054 2054	0.10	0.00	0.00 0.01	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.05	N/A 0.05	N/A N/A	N/A N/A	N/A 1.21	0.10	0.00	0.00	0.00
NC	8100	8100 Base Heating, Other Electric	Restaurant	2014	2054	0.09	0.00	0.00	0.00	0%	0.00	0.00	0%	0.05 N/A	N/A	N/A	N/A	N/A	0.26	0.00	0.00	0.00
NC	9500	9500 Base Miscellaneous	Restaurant	2014	2054	6.97	1.37	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.97	1.37	0.00	0.00
NC NC	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Restaurant Retail	2014 2020	2054 2054	6.97 41.00	1.37 7.42	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	41.00	7.42	0.00	0.00
NC	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Retail	2020	2054	37.89	6.97	3.11	3.11	8%	0.45	0.45	6%	0.02	0.02	0	0	4.09	71.00	1.42	3.11	0.45
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Retail	2020	2054	33.95	6.26	3.94	7.05	17%	0.71	1.16	16%	0.03	0.02	0	0	2.41			3.94	0.71

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ige			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure Number Measure	Building	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base	Economic GWH	Economic MW
NC NC	Number 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Type Retail	2020	2054	29.63	5.48	4.32	11.37	Savings 28%	Savings 0.78	1.94	Savings 26%	0.05	0.03	0	0	1.16	GWH	IVI VV	4.32	0.78
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Retail	2020	2054	29.20	5.46	0.43	11.80	29%	0.02	1.96	26%	0.10	0.04	2	0	0.57			0.00	0.00
NC NC	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Retail Retail	2020 2020	2054	24.50	4.61 4.23	4.70 2.09	16.50 18.59	40% 45%	0.85	2.81 3.19	38% 43%	0.31 0.26	0.11	2	1	0.23 0.28			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Retail	2020	2054	8.19	1.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.19	1.48	0.00	0.00
NC	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Retail	2020	2054	7.57	1.39	0.62	0.62	8%	0.09	0.09	6%	0.03	0.03	0	0	2.40			0.62	0.09
NC NC	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Retail Retail	2020 2020	2054 2054	6.78 5.92	1.25 1.09	0.79 0.86	1.41 2.27	17% 28%	0.14 0.16	0.23 0.39	16% 26%	0.03 0.07	0.03 0.04	0	0	1.91 0.91			0.79 0.00	0.14
NC	1130	1132 ROB 2L4 LEW Walt High Performance 16 (73 W), 2020	Retail	2020	2054	5.63	1.03	0.29	2.56	31%	0.05	0.39	30%	0.07	0.04	1	0	0.29			0.00	0.00
NC	1130	1135 LED Troffer (base 2L4T8), 2020	Retail	2020	2054	5.15	0.96	0.48	3.04	37%	0.09	0.53	36%	0.31	0.11	2	1	0.23			0.00	0.00
NC NC	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 20201200 Base Other Fluorescent Fixture	Retail Retail	2020 2014	2054 2054	5.08 0.06	0.95	0.07 0.00	3.11 0.00	38% 0%	0.00	0.53	36% 0%	0.20 N/A	0.11 N/A	5 N/A	1 N/A	0.28 N/A	0.06	0.01	0.00	0.00
NC	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Retail	2014	2054	0.06	0.01	0.00	0.00	8%	0.00	0.00	6%	0.06	0.06	0	0	1.23	0.00	0.01	0.00	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	Retail	2014	2054	0.05	0.01	0.01	0.01	17%	0.00	0.00	16%	0.10	0.08	1	1	0.60			0.00	0.00
NC NC	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Retail Retail	2014 2020	2054 2054	0.05 2.53	0.01	0.00	0.01 0.00	20%	0.00	0.00	16% 0%	0.12 N/A	0.09 N/A	3 N/A	1 N/A	0.48 N/A	2.53	0.46	0.00	0.00
NC	1330	1332 LEDs (base incandescent flood) 2020	Retail	2020	2054	0.43	0.08	2.10	2.10	83%	0.38	0.38	83%	0.01	0.01	0	0	9.17			2.10	0.38
NC	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Retail	2020	2054	0.91	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	0.91	0.16	0.00	0.00
NC NC	1530	1432 LEDs (base incandescent A-line 72W) 20201530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Retail Retail	2020 2020	2054 2054	0.17 0.67	0.03	0.74	0.74	82% 0%	0.13	0.13	82% 0%	0.01 N/A	0.01 N/A	N/A	N/A	7.74 N/A	0.67	0.12	0.74	0.13 0.00
NC	1530	1532 LEDs (base incandescent A-line 53W) 2020	Retail	2020	2054	0.17	0.03	0.50	0.50	75%	0.09	0.09	75%	0.01	0.01	0	0	5.77			0.50	0.09
NC NC	1630 1630	1630 Base CFL 18W to screw-in replacement 2020	Retail Retail	2020 2020	2054 2054	1.31 0.95	0.24	0.00	0.00 0.36	0% 28%	0.00 0.07	0.00 0.07	0% 28%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A	1.31	0.24	0.00	0.00
NC NC	1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Retail	2020	2054	1.67	0.17	0.36	0.00	28% 0%	0.07	0.07	28% 0%	0.06 N/A	0.06 N/A	N/A	N/A	0.94 N/A	1.67	0.30	0.00	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Retail	2020	2054	1.24	0.22	0.43	0.43	26%	0.08	0.08	26%	0.05	0.05	0	0	1.25			0.43	0.08
NC NC	1800 1850	1800 BaseMetal Halide, 465W 1850 Base CFL Exit Sign	Retail Retail	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC NC	1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Retail	2014	2054	0.30	0.05	0.00	0.00	56%	0.00	0.00	56%	0.04	0.04	0 0	N/A 0	1.45	0.30	0.05	0.00	0.00
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Retail	2014	2054	1.36	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.36	0.09	0.00	0.00
NC NC	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Retail Retail	2014 2014	2054 2054	1.32 0.64	0.08	0.03 0.69	0.03 0.72	2% 53%	0.01 0.04	0.01 0.05	7% 58%	0.04 0.10	0.04 0.10	0	0	1.98 0.66			0.03	0.01 0.00
NC	1900	1902 EED Oddoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Retail	2014	2054	0.45	0.04	0.09	0.72	67%	0.04	0.05	70%	0.10	0.10	11	3	0.00			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons 2102 DX Packaged System, EER=13.4, 10 tons	Retail Retail	2014 2014	2054 2054	24.20 18.64	20.00 15.40	0.00 5.57	0.00 5.57	0% 23%	0.00 4.60	0.00 4.60	0% 23%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 3.17	24.20	20.00	0.00 5.57	0.00 4.60
NC NC	2100		Retail	2014	2054	17.33	13.88	1.30	6.87	28%	1.52	6.12	23% 31%	0.04	0.04	0	0	1.13			1.30	1.52
NC	2100	2107 Cool Roof - DX	Retail	2014	2054	16.56	13.24	0.77	7.64	32%	0.64	6.76	34%	0.12	0.05	0	0	0.87			0.00	0.00
NC NC	2100 2100	2108 Optimize Controls - DX 2109 Economizer - DX	Retail Retail	2014 2014	2054 2054	16.29 14.90	13.19 12.89	0.27 1.39	7.91 9.30	33% 38%	0.06	6.82 7.11	34% 36%	0.10 0.13	0.06	0	0	0.56 0.50			0.00	0.00
NC	2100	2112 Aerosol Duct Sealing - DX	Retail	2014	2054	14.90	12.09	0.91	10.20	42%	0.30	7.11	39%	0.13	0.07	0	0	0.50			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Retail	2014	2054	13.61	12.06	0.39	10.59	44%	0.08	7.95	40%	0.17	0.09	1	0	0.35			0.00	0.00
NC NC	2100 2100	2115 Window Film (Standard) - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Retail Retail	2014 2014	2054 2054	13.56 13.56	12.02 12.01	0.05 0.01	10.64 10.65	44% 44%	0.04	7.99 7.99	40% 40%	0.38 0.29	0.09	0 1	0	0.27 0.23			0.00	0.00
NC	2100	2110 Dual Enthalpy Economizer Replaces Dry Build Economizer - DX 2114 Duct/Pipe Insulation - DX	Retail	2014	2054	13.46	11.93	0.10	10.65	44%	0.08	8.07	40%	3.43	0.09	4	0	0.23			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Retail	2014	2054	12.96	10.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.96	10.71	0.00	0.00
NC NC	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Retail Retail	2014 2014	2054 2054	11.36 1.11	9.38 0.92	1.60 0.00	1.60 0.00	12% 0%	1.32 0.00	1.32 0.00	12% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	4.44 N/A	1.11	0.92	1.60 0.00	1.32 0.00
NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Retail	2014	2054	15.33	4.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.33	4.29	0.00	0.00
NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Retail	2014	2054	15.08	4.23	0.24	0.24	2%	0.07	0.07	2%	0.02	0.02	0	0	3.79			0.24	0.07
NC NC	3000 3000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	10.56 9.45	3.91 3.32	4.52 1.11	4.76 5.87	31% 38%	0.32 0.59	0.38 0.98	9% 23%	0.02 1.16	0.02 0.23	0	0	3.59 0.09			4.52 0.00	0.32
NC	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Retail	2014	2054	0.53	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.53	0.15	0.00	0.00
NC	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Retail	2014	2054	0.46	0.13	0.08	0.08	14%	0.02	0.02	13%	0.03	0.03	0	0	2.72			0.08	0.02
NC NC	3100 3100		Retail Retail	2014 2014	2054 2054	0.41 0.29	0.13	0.05 0.12	0.12 0.25	23% 46%	0.00	0.02	15% 21%	0.03	0.03 0.05	0	0	2.08 0.97			0.05	0.00
NC	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Retail	2014	2054	0.29	0.12	0.00	0.25	46%	0.00	0.03	21%	0.21	0.05	1	0	0.43			0.00	0.00
NC	3100		Retail	2014	2054	0.27	0.11	0.02	0.27	50%	0.01	0.04	28%	0.46	0.08	1	0	0.25			0.00	0.00
NC NC	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93,0%	Retail Retail	2014 2014	2054 2054	0.24 0.53	0.09 0.15	0.03	0.29	55% 0%	0.01 0.00	0.06	38% 0%	1.59 N/A	0.22 N/A	3 N/A	1 N/A	0.06 N/A	0.53	0.15	0.00	0.00
NC	3200	3203 Air Handler Optimization, 40 HP	Retail	2014	2054	0.48	0.15	0.05	0.05	10%	0.00	0.00	3%	0.02	0.02	0	0	2.44	0.00	5.15	0.05	0.00
NC	3200	3202 Variable Speed Drive Control, 40 HP	Retail	2014	2054	0.34	0.14	0.14	0.20	37%	0.01	0.01	9%	0.06	0.05	1	1	1.16			0.14	0.01
NC NC	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	0.34	0.14 0.12	0.00 0.04	0.20 0.23	37% 44%	0.00 0.02	0.01 0.03	9% 22%	0.28 1.27	0.05 0.23	1 2	1 2	0.32			0.00	0.00
NC	4000	4000 Base Built-Up Refrigeration System	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.02	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	4100	4100 Base Self-Contained Refrigeration	Retail	2014	2054	5.88	0.89	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.88	0.89	0.00	0.00
NC NC	4100 4100	4109 Energy-Star Freezer, glass door 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Retail Retail	2014 2014	2054 2054	5.85 5.72	0.89	0.03 0.13	0.03 0.15	0% 3%	0.00 0.02	0.00 0.02	0% 3%	0.04 0.04	0.04 0.04	0	0	1.76 1.52			0.03 0.13	0.00 0.02
NC	4100	4107 Energy-Star Freezer, solid door	Retail	2014	2054	5.71	0.87	0.01	0.16	3%	0.00	0.02	3%	0.09	0.04	1	0	0.70			0.00	0.00
NC	4100		Retail	2014	2054	5.61	0.85	0.11	0.27	5%	0.02	0.04	5%	0.11	0.07	1	0	0.60			0.00	0.00
NC NC	4100 4100	4106 Energy-Star Refrigerator, solid door 4112 Reach-in unit occupancy sensors	Retail Retail	2014 2014	2054 2054	5.59 5.56	0.85 0.85	0.02 0.03	0.28 0.31	5% 5%	0.00	0.04 0.05	5% 5%	0.12 0.27	0.07 0.09	1 2	0	0.55 0.23			0.00	0.00
NC	4100	4110 Energy Star Ice Machines	Retail	2014	2054	5.56	0.84	0.01	0.32	5%	0.00	0.05	5%	0.32	0.09	2	1	0.20			0.00	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Retail	2014	2054	5.51	0.84	0.05	0.37	6%	0.01	0.06	6%	0.31	0.12	2	1	0.19			0.00	0.00
NC	4100	4101 Strip curtains for walk-ins (self-contained)	Retail	2014	2054	5.50	0.84	0.00	0.37	6%	0.00	0.06	6%	1.91	0.13	13	1	0.03			0.00	0.00

APPENDIX H

Base Avoided Costs

		ic Existing Construction		Year	2020																SUPPLY	
Vinta	ge			Maggura	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm1 NC	Number 5000	Number Measure 5000 Base Desktop PC	Type Retail	Year 2014	Year 2054	0.82	MW 0.15	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	0.82	MW 0.15	0.00	0.00
NC	5000	5002 Energy Star or Better PC	Retail	2014	2054	0.70	0.12	0.12	0.12	15%	0.02	0.02	15%	0.01	0.01	0	0	3.72	0.02	0.15	0.12	0.02
NC NC	5000 5100	5001 PC Network Power Management Enabling 5100 Base Laptop PC	Retail Retail	2014	2054 2054	0.38	0.10	0.31	0.44	53% 0%	0.03	0.05 0.00	35% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	2.93 N/A	0.01	0.00	0.31	0.03
NC	5100	5102 Energy Star or Better Laptop	Retail	2014	2054	0.01	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	4.83	0.01	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Retail	2014	2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	1.38	0.12	8	1	0.04			0.00	0.00
NC NC	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Retail Retail	2014 2014	2054 2054	0.25 0.11	0.05	0.00 0.14	0.00 0.14	0% 56%	0.00	0.00	0% 56%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 38.40	0.25	0.05	0.00 0.14	0.00
NC	5200	5202 Monitor Power Management Enabling - CRT	Retail	2014	2054	0.09	0.02	0.02	0.16	63%	0.00	0.03	60%	0.02	0.00	0	0	2.95			0.02	0.00
NC NC	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Retail Retail	2014 2014	2054 2054	0.09	0.02	0.01 0.00	0.17	66% 0%	0.00	0.03	63% 0%	0.21 N/A	0.01 N/A	1 N/A	0 N/A	0.26 N/A	0.08	0.01	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	Retail	2014	2054	0.07	0.01	0.01	0.01	14%	0.00	0.00	14%	0.01	0.01	0	0	4.55	0.00	0.01	0.01	0.00
NC NC	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Retail Retail	2014 2014	2054 2054	0.07	0.01	0.00	0.01 0.02	17% 24%	0.00	0.00	16% 17%	0.11	0.03 0.11	1 7	0	0.45 0.15			0.00	0.00
NC	5400	5400 Base Copier	Retail	2014	2054	0.50	0.09	0.00	0.02	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.50	0.09	0.00	0.00
NC	5400	5401 Energy Star or Better Copier	Retail	2014	2054	0.43	80.0	0.07	0.07	14%	0.01	0.01	14%	0.00	0.00	0	0	28.81			0.07	0.01
NC NC	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Retail Retail	2014 2014	2054 2054	0.41	0.07	0.02	0.09	18% 0%	0.00	0.01 0.00	16% 0%	0.11 N/A	0.03 N/A	1 N/A	N/A	0.50 N/A	0.08	0.01	0.00	0.00
NC	5500	5502 ENERGY STAR Multi-Function Device	Retail	2014	2054	0.06	0.01	0.02	0.02	25%	0.00	0.00	25%	0.01	0.01	0	0	8.20			0.02	0.00
NC NC	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Retail Retail	2014 2014	2054 2054	0.05	0.01	0.01	0.03	36% 0%	0.00	0.00	30% 0%	0.28 N/A	0.09 N/A	3 N/A	1 N/A	0.19 N/A	0.08	0.01	0.00	0.00
NC	5600	5602 ENERGY STAR Printer	Retail	2014	2054	0.05	0.01	0.03	0.03	35%	0.01	0.01	35%	0.00	0.00	0	0	37.69	0.00	0.01	0.03	0.01
NC NC	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Retail Retail	2014	2054 2054	0.05	0.01	0.01	0.04	44% 0%	0.00	0.01	39% 0%	0.06 N/A	0.01 N/A	1 N/A	0 N/A	0.87 N/A	0.00	0.01	0.00	0.00
NC	5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Retail	2014	2054	0.08	0.01	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	0	0	135.09	0.08	0.01	0.00	0.00
NC	5700	5702 Data Center Best Practices	Retail	2014	2054	0.06	0.01	0.01	0.02	21%	0.00	0.00	21%	0.00	0.00	0	0	55.00			0.01	0.00
NC NC	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Retail Retail	2014 2014	2054 2054	0.06 3.11	0.01 0.50	0.00	0.02	26% 0%	0.00	0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	28.52 N/A	3.11	0.50	0.00	0.00
NC	6000	6007 Heat Trap	Retail	2014	2054	2.95	0.47	0.16	0.16	5%	0.03	0.03	5%	0.02	0.02	0	0	3.20	****		0.16	0.03
NC NC	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Retail Retail	2014 2014	2054 2054	2.89 2.68	0.47 0.43	0.06 0.22	0.22 0.44	7% 14%	0.01 0.03	0.04 0.07	7% 14%	0.04 0.07	0.03 0.05	0	0	1.72 1.23			0.06 0.22	0.01 0.03
NC	6000	6008 Solar Water Heater	Retail	2014	2054	2.60	0.42	0.07	0.51	16%	0.01	0.08	16%	0.08	0.05	0	0	1.05			0.07	0.01
NC NC	6000 6000	6003 Hot Water Pipe Insulation	Retail Retail	2014 2014	2054 2054	2.56 2.48	0.41	0.04	0.55	18% 20%	0.01	0.09	18% 20%	0.08	0.05	0	0	0.92 0.72			0.00	0.00
NC	6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	Retail	2014	2054	2.48	0.40	0.08	0.68	20%	0.01	0.10	20%	0.09	0.06	1	0	0.72			0.00	0.00
NC	7000	7000 Base Refrigerated Vending Machines	Retail	2014	2054	1.91	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.91	0.34	0.00	0.00
NC NC	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Retail Retail	2014 2014	2054 2054	1.61 1.44	0.31	0.30	0.30	16% 24%	0.03	0.03	8% 12%	0.03	0.03	0	0	2.02			0.30	0.03
NC	7100	7100 Base Non-Refrigerated Vending Machines	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7200 7200	7200 Base Oven 7201 Convection Oven	Retail Retail	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 23%	0.00	0.00	0% 23%	N/A 0.09	N/A 0.09	N/A 1	N/A 1	N/A 0.76	0.01	0.00	0.00	0.00
NC	7300	7300 Base Fryer	Retail	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.09 N/A	0.09 N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	7300	7301 Efficient Fryer	Retail	2014	2054	0.00	0.00	0.00	0.00	6%	0.00	0.00	6%	0.30	0.30	2	2	0.23			0.00	0.00
NC NC	7400 7400	7400 Base Steamer 7401 Efficient Steamer	Retail Retail	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 64%	0.00	0.00	0% 64%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.94	0.00	0.00	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Retail	2014	2054	1.44	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.44	0.00	0.00	0.00
NC NC	8000 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	Retail Retail	2014 2014	2054 2054	1.36 0.39	0.00	0.08	0.08	6% 0%	0.00	0.00	0% 0%	0.04 N/A	0.04 N/A	N/A N/A	N/A N/A	1.66 N/A	0.39	0.00	0.08	0.00
NC	9500	9500 Base Miscellaneous	Retail	2014	2054	36.79	6.58	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	36.79	6.58	0.00	0.00
NC	9500 1030	9501 Xmisc	Retail	2014 2020	2054 2054	36.79	6.58 0.71	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A	N/A N/A	N/A	N/A	0.00	4.04	0.74	0.00	0.00
NC NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1036 Lighting Control Tuneup (base 4L4'T8), 2020	Grocery Grocery	2020	2054	4.64 4.64	0.71	0.00	0.00	0%	0.00	0.00	0%	N/A 0.01	0.01	N/A 0	N/A 0	N/A 4.92	4.64	0.71	0.00	0.00
NC	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Grocery	2020	2054	4.28	0.67	0.36	0.36	8%	0.04	0.04	6%	0.02	0.02	0	0	4.31			0.36	0.04
NC NC	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Grocery Grocery	2020 2020	2054 2054	3.85 3.36	0.60 0.52	0.44	0.79 1.28	17% 28%	0.07 0.07	0.11 0.18	15% 26%	0.04 0.08	0.03	0	0	1.38 0.66			0.44	0.07
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Grocery	2020	2054	3.31	0.52	0.05	1.33	29%	0.00	0.19	26%	0.12	0.05	3	0	0.48			0.00	0.00
NC NC	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Grocery Grocery	2020 2020	2054 2054	2.77 2.54	0.44	0.53 0.24	1.87 2.10	40% 45%	0.08	0.27 0.30	38% 43%	0.50 0.41	0.18 0.21	3	1	0.12 0.15			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Grocery	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Grocery	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	0.01	0.01	0	0	4.11			0.00	0.00
NC NC	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Grocery Grocery	2020 2020	2054 2054	0.02	0.00	0.00	0.00	8% 17%	0.00	0.00	6% 15%	0.02 0.05	0.02 0.04	0	0	3.60 1.10			0.00	0.00
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Grocery	2020	2054	0.01	0.00	0.00	0.00	27%	0.00	0.00	26%	0.11	0.06	1	Ō	0.53			0.00	0.00
NC NC	1130 1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1134 ROB 2L4' LED Tube, 2020	Grocery Grocery	2020 2020	2054 2054	0.01 0.01	0.00	0.00	0.00	28% 32%	0.00	0.00	26% 29%	0.20 0.40	0.07 0.11	6	0	0.27 0.15			0.00	0.00
NC	1130	1135 LED Troffer (base 2L4'T8), 2020	Grocery	2020	2054	0.01	0.00	0.00	0.01	38%	0.00	0.00	35%	0.51	0.17	3	1	0.12			0.00	0.00
NC NC	1200 1330	1200 Base Other Fluorescent Fixture	Grocery	2014 2020	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Grocery	2020	2054	0.42	0.06	0.00	0.00	81%	0.00	0.00	81%	0.01	0.01	0	0	5.17	0.42	0.00	0.00	0.00
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Grocery	2020	2054	0.15	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.15	0.02	0.00	0.00
NC NC	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Grocery Grocery	2020 2020	2054 2054	0.03	0.00	0.12	0.12 0.00	80% 0%	0.02	0.02	80% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	4.36 N/A	0.11	0.02	0.12 0.00	0.02
NC	1530	1532 LEDs (base incandescent A-line 53W) 2020	Grocery	2020	2054	0.03	0.00	0.08	0.08	72%	0.01	0.01	72%	0.02	0.02	0	0	3.22			0.08	0.01
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Grocery	2020	2054	0.67	0.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.67	0.10	0.00	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

DSM	ASSYST AD	ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ige			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Sam	Base t Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic MW
NC	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Grocery	2020	2054	0.48	0.07	0.19	0.19	28%	0.03	0.03	28%	0.12	0.12	1	1	0.48	GWH	141.44	0.00	0.00
NC	1730	1730 Base CFL 23W to screw-in replacement 2020	Grocery	2020	2054	0.85	0.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.85	0.13	0.00	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Grocery	2020	2054	0.63	0.10	0.22	0.22	26%	0.03	0.03	26%	0.09	0.09	1	1	0.64			0.00	0.00
NC NC	1800 1800	1800 BaseMetal Halide, 465W 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Grocery Grocery	2014 2014	2054 2054	0.19 0.17	0.03	0.00 0.01	0.00 0.01	0% 8%	0.00	0.00	0% 6%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.93	0.19	0.03	0.00 0.01	0.00
NC	1800	1801 T5 (240W) (base metal halide)	Grocery	2014	2054	0.12	0.02	0.06	0.07	39%	0.00	0.01	37%	0.02	0.01	0	0	4.91			0.06	0.01
NC	1800	1806 Occupancy Sensor, High Bay T5	Grocery	2014	2054	0.11	0.02	0.00	0.08	41%	0.00	0.01	38%	0.04	0.02	1	0	1.40			0.00	0.00
NC NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Grocery	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A	0.01	0.00	0.00	0.00
NC NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Grocery	2014	2054	0.01	0.00	0.00	0.00	2% 0%	0.00	0.00	2% 0%	0.03 N/A	0.03 N/A	N/A	N/A	1.75 N/A	0.18	0.00	0.00	0.00
NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Grocery	2014	2054	0.16	0.00	0.03	0.03	15%	0.00	0.00	49%	0.10	0.10	1	1	0.74	0.10	0.00	0.00	0.00
NC	1900	1902 LED Outdoor Area Lighting	Grocery	2014	2054	0.08	0.00	0.08	0.11	59%	0.00	0.00	93%	0.22	0.19	9	5	0.30			0.00	0.00
NC NC	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Grocery Grocery	2014 2014	2054 2054	0.05	0.00	0.02	0.13 0.00	71% 0%	0.00	0.00	104% 0%	1.40 N/A	0.39 N/A	65 N/A	11 N/A	0.05 N/A	0.00	0.00	0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Grocery	2014	2054	1.49	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.49	0.00	0.00	0.00
NC	2100	2113 Ceiling/roof Insulation - DX	Grocery	2014	2054	1.49	0.97	0.00	0.00	0%	0.00	0.00	0%	0.04	0.04	0	0	3.34			0.00	0.00
NC	2100	2102 DX Packaged System, EER=13.4, 10 tons	Grocery	2014	2054	1.15	0.75	0.34	0.34	23%	0.22	0.22	23%	0.04	0.04	0	0	2.89			0.34	0.22
NC NC	2100 2100	2115 Window Film (Standard) - DX 2107 Cool Roof - DX	Grocery Grocery	2014 2014	2054 2054	1.07 0.98	0.70 0.64	0.08 0.08	0.42 0.51	28% 34%	0.05 0.05	0.28 0.33	28% 34%	0.10 0.14	0.05 0.06	0	0	0.91 0.67			0.00	0.00
NC	2100	2107 Cool Rool - DX 2105 DX Tune Up/ Advanced Diagnostics	Grocery	2014	2054	0.98	0.64	0.00	0.51	34%	0.00	0.33	34%	0.14	0.06	0	0	0.50			0.00	0.00
NC	2100	2108 Optimize Controls - DX	Grocery	2014	2054	0.96	0.64	0.02	0.53	35%	0.00	0.33	34%	0.12	0.07	1	0	0.46			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Grocery	2014	2054	0.95	0.64	0.01	0.54	36%	0.00	0.34	35%	0.14	0.07	1	0	0.41			0.00	0.00
NC NC	2100 2100	2112 Aerosol Duct Sealing - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Grocery Grocery	2014 2014	2054 2054	0.89	0.60	0.06	0.60	40% 40%	0.04	0.37 0.37	38% 38%	0.29 0.84	0.09	0 5	0	0.39			0.00	0.00
NC	2100	2111 Economizer Repair - DX	Grocery	2014	2054	0.88	0.59	0.01	0.61	41%	0.00	0.38	39%	1.63	0.11	2	0	0.05			0.00	0.00
NC	2100	2109 Economizer - DX	Grocery	2014	2054	0.88	0.59	0.00	0.61	41%	0.00	0.38	39%	2.04	0.11	13	0	0.03			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	Grocery	2014	2054	0.87	0.58	0.01	0.62	42%	0.01	0.39	40%	3.94	0.20	6	0	0.02	1.00	0.67	0.00	0.00
NC NC	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery Grocery	2014 2014	2054 2054	1.02 0.89	0.67 0.58	0.00 0.13	0.00 0.13	0% 12%	0.00	0.00 0.08	0% 12%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.31	1.02	0.67	0.00 0.13	0.00 80.0
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	Grocery	2014	2054	0.17	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.17	0.11	0.00	0.00
NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Grocery	2014	2054	2.67	0.57	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.67	0.57	0.00	0.00
NC	3000 3000	3002 Variable Speed Drive Control, 5 HP	Grocery	2014 2014	2054 2054	1.85	0.53	0.83	0.83 0.86	31% 32%	0.04 0.01	0.04	7% 9%	0.03 0.07	0.03	1	1	1.84			0.83	0.04 0.01
NC NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	Grocery Grocery	2014	2054	1.81 1.56	0.52	0.03	1.12	42%	0.01	0.05 0.16	28%	1.37	0.04 0.34	3	2	1.22 0.07			0.03	0.00
NC	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Grocery	2014	2054	2.64	0.57	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.64	0.57	0.00	0.00
NC NC	3200 3200	3203 Air Handler Optimization, 40 HP 3204 Demand Controlled Ventilation	Grocery Grocery	2014 2014	2054 2054	2.37	0.55 0.41	0.27	0.27	10% 23%	0.01 0.14	0.01	3% 28%	0.02 1.04	0.02	0	0	2.22			0.27	0.01
NC	4000	4000 Base Built-Up Refrigeration System	Grocery	2014	2054	12.34	1.99	0.00	0.00	0%	0.00	0.00	20% 0%	N/A	0.56 N/A	N/A	N/A	0.09 N/A	12.34	1.99	0.00	0.00
NC	4000	4007 Efficient compressor motor	Grocery	2014	2054	12.31	1.98	0.02	0.02	0%	0.00	0.00	0%	0.02	0.02	0	0	3.94			0.02	0.00
NC	4000	4011 Demand Hot Gas Defrost	Grocery	2014	2054	12.01	1.93	0.31	0.33	3%	0.05	0.05	3%	0.02	0.02	0	0	3.64			0.31	0.05
NC NC	4000 4000	4009 Floating head pressure controls 4006 Electronically commutated evaporator fan motor	Grocery Grocery	2014 2014	2054 2054	11.98 11.13	1.93 1.86	0.03 0.85	0.36 1.21	3% 10%	0.00 0.07	0.06 0.12	3% 6%	0.02 0.02	0.02 0.02	0	0	3.35 3.02			0.03 0.85	0.00 0.07
NC	4000	4013 Anti-sweat (humidistat) controls	Grocery	2014	2054	10.97	1.85	0.16	1.37	11%	0.01	0.12	7%	0.04	0.02	1	0	1.48			0.16	0.01
NC	4000	4002 Strip curtains for walk-ins (built-up)	Grocery	2014	2054	10.66	1.80	0.31	1.68	14%	0.05	0.19	9%	0.04	0.03	0	0	1.39			0.31	0.05
NC	4000	4014 Freezer-Cooler Replacement Gaskets	Grocery	2014	2054	10.30	1.74	0.36	2.04	17%	0.06	0.24	12%	0.06	0.03	0	0	0.97			0.00	0.00
NC NC	4000 4000	4018 Oversized Air Cooled Condenser 4001 High-efficiency fan motors	Grocery Grocery	2014 2014	2054 2054	9.87 9.52	1.67 1.62	0.43 0.35	2.47 2.82	20% 23%	0.07 0.06	0.31 0.37	16% 19%	0.08 0.11	0.04 0.05	0	0	0.94 0.75			0.00	0.00
NC	4000	4004 Night covers for display cases	Grocery	2014	2054	8.97	1.62	0.54	3.36	27%	0.00	0.37	19%	0.07	0.05	N/A	0	0.66			0.00	0.00
NC	4000	4008 Compressor VSD retrofit	Grocery	2014	2054	8.42	1.57	0.56	3.92	32%	0.04	0.42	21%	0.10	0.06	1	1	0.62			0.00	0.00
NC NC	4000 4000	4010 Refrigeration Commissioning	Grocery	2014 2014	2054 2054	8.38 8.37	1.56 1.56	0.04	3.96 3.97	32% 32%	0.01	0.42	21% 21%	0.18 0.25	0.06	1	1	0.29			0.00	0.00
NC	4000	4005 Evaporator fan controller for MT walk-ins 4017 Multiplex Compressor System	Grocery Grocery	2014	2054	8.37	1.56	0.01	4.12	32%	0.00	0.42	21%	0.25	0.06	2	1	0.27			0.00	0.00
NC	4000	4016 LED Display Lighting	Grocery	2014	2054	7.64	1.45	0.58	4.70	38%	0.09	0.54	27%	0.44	0.11	3	1	0.14			0.00	0.00
NC	4000	4015 High R-Value Glass Doors	Grocery	2014	2054	7.52	1.43	0.12	4.82	39%	0.02	0.56	28%	1.97	0.16	12	1	0.03			0.00	0.00
NC NC	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Grocery Grocery	2014 2014	2054 2054	1.23 1.14	0.20 0.18	0.00 0.09	0.00	0% 7%	0.00 0.01	0.00 0.01	0% 7%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 173.74	1.23	0.20	0.00	0.00 0.01
NC	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Grocery	2014	2054	1.13	0.18	0.03	0.09	8%	0.00	0.02	8%	0.00	0.00	0	0	3.80			0.03	0.00
NC	4100	4109 Energy-Star Freezer, glass door	Grocery	2014	2054	1.06	0.17	0.07	0.17	14%	0.01	0.03	14%	0.03	0.01	0	0	2.32			0.07	0.01
NC	4100	4107 Energy-Star Freezer, solid door	Grocery	2014	2054	1.03	0.17	0.03	0.20	16%	0.00	0.03	16%	0.07	0.02	0	0	0.88			0.00	0.00
NC NC	4100 4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Grocery Grocery	2014	2054 2054	1.03	0.17	0.00	0.20 0.20	16% 16%	0.00	0.03	16% 16%	0.09 0.10	0.02 0.02	1	0	0.68 0.65			0.00	0.00
NC	4100	4110 Energy Star Ice Machines	Grocery	2014	2054	1.03	0.17	0.00	0.20	16%	0.00	0.03	16%	0.10	0.02	2	0	0.65			0.00	0.00
NC	4100	4112 Reach-in unit occupancy sensors	Grocery	2014	2054	1.03	0.17	0.00	0.20	16%	0.00	0.03	16%	0.31	0.02	2	0	0.21			0.00	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Grocery	2014	2054	1.02	0.16	0.01	0.21	17%	0.00	0.03	17%	0.35	0.03	2	0	0.17			0.00	0.00
NC NC	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Grocery Grocery	2014 2014	2054 2054	1.01 0.06	0.16 0.01	0.01 0.00	0.22	18% 0%	0.00	0.04 0.00	18% 0%	0.68 N/A	0.07 N/A	4 N/A	0 N/A	0.08 N/A	0.06	0.01	0.00	0.00
NC	5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Grocery	2014	2054	0.06	0.01	0.00	0.00	45%	0.00	0.00	23%	0.03	0.03	0	0	1.92	0.00	0.01	0.00	0.00
NC	5000	5002 Energy Star or Better PC	Grocery	2014	2054	0.02	0.01	0.01	0.04	63%	0.00	0.00	41%	0.06	0.04	0	0	0.96			0.00	0.00
NC	5100	5100 Base Laptop PC	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	19% 21%	0.00	0.00	19% 21%	0.02 2.48	0.02 0.22	0 14	0	2.68 0.02			0.00	0.00
NC	5200	5200 Base Monitor, CRT	Grocery	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	5200	5201 Energy Star or Better Monitor - CRT	Grocery	2014	2054	0.01	0.00	0.01	0.01	56%	0.00	0.00	56%	0.00	0.00	0	0	21.32			0.01	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

Part			ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
	Vinta	ige			Maggura	Maggura					Percent			Percent									
Second Column Second Colum					Start	End				Savings	GWH		Savings	MW	Cost	Cost	Cost	Cost	Cost Test				
Column C															4,,,,,,,,,,,,	4,	\$/kW	4,		GWH	MW		
No.	NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)		2014	2054		0.00	0.00	0.02	76%	0.00	0.00	67%	0.52	0.03		0	0.11			0.00	0.00
No.																				0.01	0.00		
March Marc																	-	1					
Math			5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Grocery															0.07				
No.																				0.05	0.01		
No.	NC	5400	5402 Copier Power Management Enabling	Grocery	2014	2054	0.03	0.01	0.01	0.02	31%	0.00	0.00	26%	0.24	0.09	3	1	0.23			0.00	0.00
See																				0.01	0.00		
SC SC SC SC SC SC SC SC	NC	5500	5501 Multifunction Power Management Enabling		2014	2054		0.00	0.00	0.00	46%	0.00	0.00	36%	0.64	0.30	7	2	0.08			0.00	0.00
No.																				0.01	0.00		
Fig. Section Property Section Sectio																		-					
No.																				0.02	0.00		
No. 100																							
No. 1000 1	NC	5700	5703 Data Center State of the Art practices	Grocery	2014	2054	0.02	0.00	0.00	0.01	26%	0.00	0.00	26%	0.00	0.00	Ō	ō	15.84			0.00	0.00
No.																				0.30	0.05		
Company Comp	NC	6000			2014	2054		0.04		0.02	7%	0.00		7%	0.06	0.04	-	-					0.00
Math																	0	-					
No.																	1	1					
No.	NC	6000				2054		0.02	0.00	0.20	66%	0.00	0.03	66%	0.26			1	0.28			0.00	0.00
No. 9700 7700 Working Memile (Inflemented Junish) Grossow 2014 2024 6 105 0.01 0.12 0.12 1.25 1.25 1.00 0.10 1.00 1.00 1.00 1.00 1.00 1.0																				0.71	0.11		
No.	NC	7000			2014	2054	0.59	0.10	0.12		16%	0.01	0.01	8%	0.03					0.7 1	0.11		
NO 7100 7101 Verding Mines (Mer-Engewiers) Grows 2014 2054 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																				0.00	0.00		
NO 7500 7500 Basis Physer (1964 00%) 100 000 000 000 00% 000 00% 000 000 00% 000 0																				0.00	0.00		
NO 7400 7400 Base Semmer NO 7400 7401 Efficiency 2014 2054 0.07 0.01 0.00 0.00 0.00 0.00 0.00 0.00																							
NC 8000 300 Basel Hand Flump (7 7 48)PF) Grossy 2014 2054 0.02 0.00 0.00 0.00 0.00 0.00 0.00 0.0																							
NO. 81008 Boot Heat Pump Upgrassed (S SEER, 82 24SPF)	NC	7400	7401 Efficient Steamer	Grocery		2054	0.02	0.00	0.05	0.05	69%	0.01	0.01	69%	0.04	0.04	0	0	1.84			0.05	0.01
NC 9500 9500 Base Missocilineous Grocey 214 2054 3.48 0.55 0.00 0.00 0.00 0% 0.00 0% NA NA NA NA NA NA NA NA 0.05 0.00 0.00 0.00 0.00 0% NA																				0.12	0.00		
NC 9500 9501 Xmisc Warehouse NC 1030 1033 Base Fluerescent Fixture, 4L-F18, 1EB, 2020 Warehouse Warehouse NC 1030 1033 ROB 4L4f High Performance T8 (68 V), 2020 102 255 4 276 4 31 251 251 8% 0.45 0.45 0.45 0.45 0.45 0.45 0.45 0.45																				0.05	0.00		
NC 1030 1031 Base Fluorescent Fluores, 44-Fla, 1EB, 2020 Warehouse 2020 2054 30.12 5.35 0.00 0.00 0,00 0,00 0,00 0,00 0,00 0,0																				3.48	0.55		
NC 1030 1038 RhgNer Performance Taylor Water High Performance Tayl																				30.12	5.35		
NC 1030 1037 Coupungy Sensor, 4.1 Housecoent Flutures, 2020 Warehouse 2020 2054 22.9 4.03 1.81 7.83 2.8% 0.26 1.33 2.9% 0.05 0.02 0 0 2.43 1.81 0.26 0.03 0.03 0.03 0.03 0.03 0.03 0.03 0.0																							
NC 1030 1034 FOCUMENTS SPRINGE, 142 FEUTINES, 2020 Warehouse 202 2054 18.17 3.8 3.49 11.55 40% 0.62 1.77 3.7% 0.16 0.06 1.0 0.45 0.00 0.00 NC 1030 1034 FOR BASE FLUORISCHE			1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020																				
NC 1303 1308 EBD Troffer (base 4L4TB), 2020 Warehouse 2020 2054 0.1 1.65	NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Warehouse	2020	2054	21.66	4.00	0.63	8.46	28%	0.03	1.35	25%	0.05	0.02		0	1.11			0.63	0.03
NC 1130 1131 Rose-Plurorescent Fixture, 24.718, 1EB, 2020 Warehouse 2020 2054 0.18 0.30 0.00 0.00 0% 0.00 0% 0.00 0% 0.00 0.00 0% 0.00 0% 0.00 0.00 0% 0.00 0.00 0% 0.00 0.00 0% 0.00 0.00 0% 0.00 0.00 0.00 0% 0.00 0.00 0% 0.00 0.00 0.00 0.00 0.00 0% 0.00 0.00 0.00 0.00 0% 0.00																	-						
NC 1130 1132 Righ Performance Lighting RR - 25% Savings (base 2L4T8), 2020 Warehouse 2L02 2054 0.15 0.03 0.02 0.00 0.00 12 5% 0.03 0.02 0.03 0.0 0.0 0.0 1.80 0.00 0.00 NC 1130 1134 ROB 2L4 LED Tube, 2020 Warehouse 2L02 2054 0.15 0.03 0.02 0.00 1.06 28% 0.00 0.01 25% 0.03 0.0 0.0 0.0 0.00 0.00 NC 1130 1135 LED Troffer (base 2L4T8), 2020 Warehouse 2L02 2054 0.13 0.02 0.01 0.08 37% 0.00 0.01 30% 0.13 0.04 1 0.0 0.56 0.00 0.00 NC 1130 1137 Occupancy Sensor, 2L4 Fluorescent Fixtures, 2020 Warehouse 2L02 2054 0.13 0.02 0.00 0.00 0.00 0.00 NC 1200 1205 High Performance Lighting RR - 25%, Savings, Base Other Fluorescent Warehouse 2L04 2054 0.03 0.01 0.00 0.00 0.00 0.00 0.00 NC 1200 1205 High Performance Lighting RR - 25%, Savings, Base Other Fluorescent Warehouse 2L04 2054 0.03 0.01 0.00 0.00 0.00 0.00 0.00 0.00																				0.21	0.04		
NC 1130 1134 ROB 24.14 LoW Wait High Performance T8 (75 W), 2020 Warehouse 2020 2054 0.15 0.03 0.02 0.06 28% 0.00 0.01 26% 0.03 0.03 0.0 0 1.80 0.00 0.00 0.00 0.00 0.00 0.0																							
NC 1130 1134 ROB 2Lf LED Tube, 2020																							
NC 1130 1137 Occupancy Sensor, 224 Fluorescent Fixtures, 2020 Warehouse 2014 2054 0.03 0.01 0.00 0.08 39% 0.00 0.01 38% 0.01 0.06 2 0 0.53 0.00 0.00 0.00 0.00 0.00 0.00 0.		1130	1134 ROB 2L4' LED Tube, 2020								31%				0.13		1	ō					0.00
NC 1200 1208 Base Other Fluorescent Fixture																							
NC 1200 1201 ROB High Performance T8 (base other fluorescent) Warehouse 2014 2054 0.02 0.00 0.00 0.01 17% 0.00 0.00 17% 0.06 0.04 1 0 0 1.17 0.00 0.00 0.00 0.00 0.00 0.0																				0.03	0.01		
NC 1200 1204 Occupancy Sensor, 4LS Fluorescent Fixtures																							
NC 1330 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 Warehouse 2020 2054 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0			1201 ROB High Performance 18 (base other fluorescent) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures																				
NC 1530 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 Warehouse 2020 2054 0.19 0.03 0.00 0.00 0% 0.00 0% 0.00 0% N/A			1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020																				
NC 1630 1630 Base CFL 18W to screw-in replacement 2020 Warehouse 2020 2054 0.14 0.02 0.05 0.05 28% 0.01 0.01 0.00 0% N/A N/A N/A N/A N/A N/A N/A N/A 0.19 0.03 0.00 0.00 0.00 0.00 0.00 0.00 0.0																							
NC 1730 1730 Base CFL 23W to screw-in replacement 2020 Warehouse 2020 2054 0.25 0.04 0.00 0.00 0.00 0.00 0.00 0.00 0.0																							
NC 1730 1731 LED screw-in replacement (base CFL 23W) 2020 Warehouse 2020 2054 0.18 0.03 0.06 0.06 26% 0.01 0.01 26% 0.03 0.03 0.03 0.03 0.02 2.36 0.06 0.01 0.01 0.01 0.00 0.00 0.00 0.0																				0.05	0.04		
NC 1800 1800 BaseMetal Halide, 455W Warehouse 2014 2054 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																				0.25	0.04		
NC 1850 1851 LED Exit Sign	NC	1800	1800 BaseMetal Halide, 465W	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A			0.00	0.00
NC 1900 1900 Base Outdoor High Pressure Sodium 250W Lamp Warehouse 2014 2054 0.16 0.00																				0.07	0.01		
NC 1900 1903 Bi-Level LED Outdoor Lighting Warehouse 2014 2054 0.06 0.00 0.02 0.11 66% 0.00 0.00 65% 0.33 0.11 27 8 0.19 0.00 0.00 NC 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons Warehouse 2014 2054 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0	NC	1900			2014	2054		0.00	0.00	0.00	0%	0.00	0.00	0%	N/A				N/A	0.16	0.00	0.00	
NC 2000 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons Warehouse 2014 2054 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0																							
																				0.00	0.00		
				Warehouse	2014	2054	2.75			0.00		0.00	0.00	0%								0.00	

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ic Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	age			Measure	e Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Sam		Measure Number Measure	Building Type	Start	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
NC	2100	2113 Ceiling/roof Insulation - DX	Warehouse	2014	2054	2.63	2.50	0.13	0.13	5%	0.12	0.12	5%	0.03	0.03	0	0	4.84	GWII	IVIVV	0.13	0.12
NC NC	2100 2100	2107 Cool Roof - DX 2108 Optimize Controls - DX	Warehouse Warehouse	2014	2054 2054	2.43	2.31	0.20 0.04	0.32 0.36	12% 13%	0.19 0.01	0.31 0.32	12% 12%	0.07 0.08	0.05 0.05	0	0	1.65 0.71			0.20 0.00	0.19 0.00
NC	2100	2102 DX Packaged System, EER=13.4, 10 tons	Warehouse	2014	2054	1.84	1.78	0.55	0.91	33%	0.52	0.84	32%	0.26	0.18	0	0	0.49			0.00	0.00
NC NC	2100 2100	2112 Aerosol Duct Sealing - DX 2115 Window Film (Standard) - DX	Warehouse Warehouse	2014 2014	2054 2054	1.73 1.66	1.67 1.60	0.11 0.07	1.02 1.09	37% 40%	0.10 0.07	0.94 1.02	36% 39%	1.71 1.52	0.35 0.43	2	0	0.08 0.07			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Warehouse	2014	2054	1.61	1.59	0.07	1.14	42%	0.07	1.02	39%	1.12	0.43	4	1	0.07			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	Warehouse	2014	2054	1.61	1.59	0.00	1.15	42%	0.00	1.03	39%	3.12	0.46	3	1	0.03			0.00	0.00
NC NC	2100 2200	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Warehouse Warehouse	2014 2014	2054 2054	1.61 0.00	1.59 0.00	0.00	1.15 0.00	42% 0%	0.00	1.03 0.00	39% 0%	2.06 N/A	0.47 N/A	8 N/A	1 N/A	0.03 N/A	0.00	0.00	0.00	0.00
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	Warehouse	2014	2054	1.32	1.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.32	1.25	0.00	0.00
NC NC	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Warehouse Warehouse	2014	2054 2054	5.72 5.62	1.77 1.74	0.00	0.00 0.10	0% 2%	0.00	0.00	0% 2%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.65	5.72	1.77	0.00 0.10	0.00
NC	3000	3002 Variable Speed Drive Control, 5 HP	Warehouse	2014	2054	3.97	1.61	1.65	1.75	31%	0.13	0.16	9%	0.02	0.02	0	o	3.34			1.65	0.13
NC NC	3000 3100	3003 Demand Controlled Ventilation	Warehouse Warehouse	2014	2054 2054	3.92 0.00	1.58	0.05	1.80 0.00	31% 0%	0.03	0.19 0.00	11% 0%	1.03 N/A	0.05 N/A	2 N/A	0 N/A	0.10 N/A	0.00	0.00	0.00	0.00
NC	3200	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Warehouse	2014	2054	1.90	0.59	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.90	0.59	0.00	0.00
NC	3200	3202 Variable Speed Drive Control, 40 HP	Warehouse	2014	2054	1.34	0.54	0.56	0.56	29%	0.04	0.04	8%	0.01	0.01	0	0	6.53			0.56	0.04
NC NC	3200 3200	3203 Air Handler Optimization, 40 HP 3204 Demand Controlled Ventilation	Warehouse Warehouse	2014 2014	2054 2054	1.21 1.19	0.53 0.52	0.13 0.02	0.69 0.70	36% 37%	0.01 0.01	0.05 0.06	9% 11%	0.04 1.12	0.02 0.04	0 2	0	1.58 0.09			0.13 0.00	0.01 0.00
NC	4000	4000 Base Built-Up Refrigeration System	Warehouse	2014	2054	0.96	0.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.96	0.18	0.00	0.00
NC NC	4000 4000	4018 Oversized Air Cooled Condenser 4010 Refrigeration Commissioning	Warehouse Warehouse	2014 2014	2054 2054	0.92 0.92	0.17 0.17	0.04	0.04	4% 5%	0.01	0.01 0.01	4% 5%	0.02	0.02 0.02	0	0	4.35 1.57			0.04	0.01
NC	4000	4006 Electronically commutated evaporator fan motor	Warehouse	2014	2054	0.86	0.17	0.06	0.10	10%	0.01	0.01	8%	0.06	0.02	1	0	1.14			0.06	0.00
NC	4000	4005 Evaporator fan controller for MT walk-ins	Warehouse	2014	2054	0.86	0.17	0.00	0.10	11%	0.00	0.01	8%	0.10	0.04	1	0	0.65			0.00	0.00
NC NC	4000 4000	4002 Strip curtains for walk-ins (built-up) 4001 High-efficiency fan motors	Warehouse Warehouse	2014 2014	2054 2054	0.82	0.16 0.16	0.03	0.14 0.16	14% 17%	0.01 0.00	0.02	11% 14%	0.10 0.26	0.06 0.09	1	0 1	0.53 0.31			0.00	0.00
NC	4100	4100 Base Self-Contained Refrigeration	Warehouse	2014	2054	1.43	0.27	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.43	0.27	0.00	0.00
NC NC	5000 5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Warehouse Warehouse	2014	2054	0.02	0.00	0.00	0.00	0% 44%	0.00	0.00	0% 23%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.82	0.02	0.00	0.00	0.00
NC	5000	5002 Energy Star or Better PC	Warehouse	2014	2054	0.01	0.00	0.00	0.01	63%	0.00	0.00	41%	0.02	0.01	Ō	ō	3.49			0.00	0.00
NC NC	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Warehouse Warehouse	2014	2054 2054	0.00	0.00	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.66	0.00	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Warehouse	2014	2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	0.69	0.06	4	0	0.08			0.00	0.00
NC	5200	5200 Base Monitor, CRT	Warehouse	2014	2054	0.03	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.01	0.00	0.00
NC NC	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Warehouse Warehouse	2014	2054	0.01 0.01	0.00	0.02	0.02	56% 70%	0.00	0.00	56% 63%	0.00 0.01	0.00	0	0	76.79 4.20			0.02	0.00
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Warehouse	2014	2054	0.01	0.00	0.00	0.02	73%	0.00	0.00	66%	0.13	0.01	1	ō	0.43			0.00	0.00
NC NC	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Warehouse Warehouse	2014	2054	0.00	0.00	0.00	0.00	0% 20%	0.00	0.00	0% 20%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.43	0.00	0.00	0.00	0.00
NC	5300	5302 Monitor Power Management Enabling - LCD	Warehouse	2014	2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	0.06	0.01	1	o	0.85			0.00	0.00
NC	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Warehouse	2014 2014	2054 2054	0.00	0.00	0.00	0.00	27% 0%	0.00	0.00	22% 0%	0.17 N/A	0.04 N/A	4	0	0.27	0.04	0.00	0.00	0.00
NC NC	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Warehouse Warehouse	2014	2054	0.01	0.00	0.00	0.00	12%	0.00	0.00	12%	0.00	0.00	N/A 0	N/A 0	N/A 59.20	0.01	0.00	0.00	0.00
NC	5400	5402 Copier Power Management Enabling	Warehouse	2014	2054	0.01	0.00	0.00	0.00	15%	0.00	0.00	14%	0.05	0.01	1	0	1.04			0.00	0.00
NC NC	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Warehouse Warehouse	2014	2054 2054	0.00	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 16.40	0.00	0.00	0.00	0.00
NC	5500	5501 Multifunction Power Management Enabling	Warehouse	2014	2054	0.00	0.00	0.00	0.00	32%	0.00	0.00	29%	0.13	0.03	2	ō	0.40			0.00	0.00
NC NC	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Warehouse Warehouse	2014	2054 2054	0.03	0.01	0.00	0.00 0.01	0% 35%	0.00	0.00	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 75.41	0.03	0.01	0.00 0.01	0.00
NC	5600	5601 Printer Power Management Enabling	Warehouse	2014	2054	0.02	0.00	0.00	0.01	41%	0.00	0.00	38%	0.03	0.01	0	0	1.82			0.00	0.00
NC	5700	5700 Base Data Center/Server Room	Warehouse	2014	2054	0.44	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.44	0.07	0.00	0.00
NC NC	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Warehouse Warehouse	2014 2014	2054 2054	0.40 0.35	0.07	0.04 0.05	0.04	10% 21%	0.01 0.01	0.01 0.02	10% 21%	0.00	0.00	0	0	119.82 48.78			0.04 0.05	0.01 0.01
NC	5700	5703 Data Center State of the Art practices	Warehouse	2014	2054	0.33	0.05	0.02	0.11	26%	0.00	0.02	26%	0.00	0.00	0	ō	25.30			0.02	0.00
NC NC	6000 6000	6000 Base Water Heating 6006 Heat Recovery Unit	Warehouse Warehouse	2014 2014	2054 2054	0.41	0.06	0.00	0.00	0% 7%	0.00	0.00	0% 7%	N/A 0.14	N/A 0.14	N/A 1	N/A 1	N/A 0.47	0.41	0.06	0.00	0.00
NC	6000	6007 Heat Trap	Warehouse	2014	2054	0.36	0.06	0.02	0.05	11%	0.00	0.01	11%	0.25	0.19	2	1	0.26			0.00	0.00
NC NC	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Warehouse Warehouse	2014 2014	2054 2054	0.36	0.06	0.01 0.03	0.05	13% 20%	0.00	0.01 0.01	13% 20%	0.52 0.79	0.23 0.42	3 5	1	0.14 0.10			0.00	0.00
NC	6000	6008 Solar Water Heater	Warehouse	2014	2054	0.33	0.03	0.03	0.08	47%	0.00	0.01	47%	0.79	0.42	6	5	0.10			0.00	0.00
NC	6000	6003 Hot Water Pipe Insulation	Warehouse	2014	2054	0.21	0.03	0.00	0.20	48%	0.00	0.03	48%	1.43	0.73	9	5	0.05			0.00	0.00
NC NC	6000 7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Warehouse Warehouse	2014 2014	2054 2054	0.21	0.03	0.00	0.20	49% 0%	0.00	0.03	49% 0%	1.60 N/A	0.74 N/A	10 N/A	5 N/A	0.05 N/A	0.00	0.00	0.00	0.00
NC	7100	7100 Base Non-Refrigerated Vending Machines	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7200 7300	7200 Base Oven 7300 Base Fryer	Warehouse Warehouse	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	7400	7400 Base Steamer	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	8100 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	Warehouse Warehouse	2014 2014	2054 2054	1.39 8.68	0.00 1.64	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	1.39 8.68	0.00 1.64	0.00	0.00
NC	9500	9501 Xmisc	Warehouse	2014	2054	8.68	1.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
NC NC	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1036 Lighting Control Tuneup (base 4L4'T8), 2020	School School	2020 2020	2054 2054	5.21 5.20	0.70	0.00 0.01	0.00 0.01	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.19	5.21	0.70	0.00 0.01	0.00
140	1030	1000 Eighting Control Fulloup (base TET TO), 2020	GGIIGGI	2020	2004	5.20	0.70	0.01	0.01	070	0.00	0.00	070	0.02	0.02	Ü	v	0.10			0.01	0.00

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
	tage	THE SOLLET ANALTSIS							Total			Total		Marginal	Average	Marginal					001121	
	Base	Measure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity	Capacity	Resource Cost Test	Base	Base	Economic	Economic
		Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
NC NC	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	School School	2020 2020	2054 2054	4.67 4.32	0.63	0.53 0.35	0.55 0.90	11% 17%	0.07 0.04	0.07 0.11	10% 16%	0.02 0.03	0.02 0.02	0	0	3.15 2.55			0.53 0.35	0.07 0.04
NC	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	School	2020	2054	3.77	0.52	0.55	1.45	28%	0.07	0.19	26%	0.05	0.03	0	0	1.40			0.55	0.07
NC NC		1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	School School	2020	2054 2054	3.16 2.89	0.44	0.61 0.27	2.05 2.32	39% 45%	0.08 0.04	0.27 0.30	38% 43%	0.31 0.26	0.12 0.13	2	1	0.25 0.30			0.00	0.00
NC		1035 LED Holler (base 4L4 16), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	School	2020	2054	2.70	0.40	0.27	2.52	48%	0.04	0.30	44%	0.26	0.13	5	1	0.30			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	School	2020	2054	0.33	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.33	0.04	0.00	0.00
NC NC		1131 ROB 2L4' High Performance T8 (86 W), 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	School School	2020 2020	2054 2054	0.29	0.04	0.03	0.03	10% 11%	0.00	0.00	10% 10%	0.03	0.03	0	0	2.49 1.93			0.03	0.00
NC		1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	School	2020	2054	0.29	0.04	0.00	0.03	17%	0.00	0.00	16%	0.03	0.03	0	0	1.74			0.00	0.00
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	School	2020	2054	0.24	0.03	0.03	0.09	28%	0.00	0.01	26%	0.06	0.04	0	0	1.10			0.03	0.00
NC NC	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	School School	2020 2020	2054 2054	0.23	0.03	0.01 0.02	0.10 0.12	31% 37%	0.00	0.01 0.02	30% 36%	0.26 0.32	0.07 0.11	2	1	0.31 0.24			0.00	0.00
NC		1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	School	2020	2054	0.19	0.03	0.02	0.12	41%	0.00	0.02	37%	0.32	0.11	8	1	0.24			0.00	0.00
NC		1200 Base Other Fluorescent Fixture	School	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00	0.00
NC NC		1203 Lighting Control Tuneup (base other fluorescent fixture) 1201 ROB High Performance T8 (base other fluorescent)	School School	2014 2014	2054 2054	0.02	0.00	0.00	0.00	2% 10%	0.00	0.00	1% 9%	0.02 0.09	0.02 0.08	0 1	0	2.63 0.78			0.00	0.00
NC		1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	School	2014	2054	0.02	0.00	0.00	0.00	35%	0.00	0.00	24%	0.09	0.08	5	2	0.78			0.00	0.00
NC	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	School	2014	2054	0.02	0.00	0.00	0.01	40%	0.00	0.00	28%	0.29	0.17	3	2	0.24			0.00	0.00
NC NC	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	School School	2020 2020	2054 2054	0.43	0.06	0.00 0.36	0.00 0.36	0% 83%	0.00 0.05	0.00 0.05	0% 83%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 10.33	0.43	0.06	0.00 0.36	0.00 0.05
NC		1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	School	2020	2054	0.07	0.01	0.00	0.00	0%	0.05	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.16	0.02	0.00	0.05
NC	1430	1432 LEDs (base incandescent A-line 72W) 2020	School	2020	2054	0.03	0.00	0.13	0.13	81%	0.02	0.02	81%	0.01	0.01	0	0	8.72			0.13	0.02
NC NC		1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	School School	2020 2020	2054 2054	0.11	0.02	0.00 0.09	0.00	0% 74%	0.00 0.01	0.00 0.01	0% 74%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.50	0.11	0.02	0.00	0.00 0.01
NC		1630 Base CFL 18W to screw-in replacement 2020	School	2020	2054	4.78	0.65	0.09	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.78	0.65	0.09	0.00
NC	1630	1631 LED screw-in replacement (base CFL 18W) 2020	School	2020	2054	3.46	0.47	1.32	1.32	28%	0.18	0.18	28%	0.06	0.06	0	0	1.05			1.32	0.18
NC		1730 Base CFL 23W to screw-in replacement 2020	School	2020	2054	6.11	0.83	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	6.11	0.83	0.00	0.00
NC NC	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	School School	2020 2014	2054 2054	4.52 0.68	0.61	1.59 0.00	1.59 0.00	26% 0%	0.21	0.21	26% 0%	0.05 N/A	0.05 N/A	0 N/A	N/A	1.40 N/A	0.68	0.09	1.59 0.00	0.21
NC	1800	1801 T5 (240W) (base metal halide)	School	2014	2054	0.45	0.06	0.23	0.23	34%	0.03	0.03	34%	0.02	0.02	0	0	4.76			0.23	0.03
NC		1805 High Performance Lighting R/R - 25% Savings (base metal halide)	School	2014	2054	0.42	0.06	0.03	0.26	39%	0.00	0.03	38%	0.02	0.02	0	0	3.02			0.03	0.00
NC NC		1806 Occupancy Sensor, High Bay T5 1850 Base CFL Exit Sign	School School	2014 2014	2054 2054	0.40	0.06	0.01 0.00	0.28 0.00	41% 0%	0.00	0.04	38% 0%	0.05 N/A	0.02 N/A	N/A	0 N/A	1.16 N/A	0.22	0.03	0.01 0.00	0.00
NC	1850	1851 LED Exit Sign	School	2014	2054	0.10	0.01	0.12	0.12	55%	0.02	0.02	55%	0.03	0.03	0	0	1.78			0.12	0.02
NC		1900 Base Outdoor High Pressure Sodium 250W Lamp	School	2014	2054	7.24	0.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.24	0.29	0.00	0.00
NC NC		1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	School School	2014 2014	2054 2054	5.86 2.82	0.11 -0.01	1.37 3.04	1.37 4.42	19% 61%	0.17 0.12	0.17	60% 102%	0.05 0.10	0.05	0	0	1.66 0.65			1.37 0.00	0.17
NC	1900	1903 Bi-Level LED Outdoor Lighting	School	2014	2054	1.99	-0.04	0.83	5.24	72%	0.03	0.33	113%	0.67	0.18	19	3	0.10			0.00	0.00
NC		2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	School	2014	2054	15.88	8.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.88	8.15	0.00	0.00
NC NC		2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2005 Chiller Tune Up/Diagnostics	School School	2014 2014	2054 2054	14.52 14.46	7.46 7.44	1.36 0.06	1.36 1.42	9% 9%	0.70 0.02	0.70 0.71	9% 9%	0.06 0.05	0.06 0.06	0	0	1.79 1.45			1.36 0.06	0.70
NC		2013 High Efficiency Chiller Motors	School	2014	2054	14.45	7.43	0.01	1.43	9%	0.01	0.72	9%	0.09	0.06	0	0	1.16			0.01	0.01
NC	2000	2006 VSD for Chiller Pumps and Towers	School	2014	2054	14.42	7.42	0.03	1.46	9% 14%	0.01	0.73	9%	0.07	0.06	0	0	1.09			0.03	0.01
NC NC		2003 EMS - Chiller 2004 Cool Roof - Chiller	School School	2014 2014	2054 2054	13.64 13.38	7.31 7.18	0.78	2.24 2.50	16%	0.11 0.13	0.84 0.97	10% 12%	0.12 0.19	0.08	0	0	0.61 0.46			0.00	0.00
NC	2000	2002 Window Film (Standard) - Chiller	School	2014	2054	13.31	7.14	0.07	2.57	16%	0.03	1.01	12%	0.22	0.09	Ö	Ö	0.40			0.00	0.00
NC		2012 Duct Testing/Sealing	School	2014	2054	11.10	6.01	2.21	4.77	30%	1.13	2.14	26%	0.31	0.19	1	0	0.34			0.00	0.00
NC NC		2008 New Economizer - Chiller 2011 Duct/Pipe Insulation - Chiller	School School	2014 2014	2054 2054	9.92 9.86	5.84 5.81	1.18 0.06	5.95 6.01	38% 38%	0.17 0.03	2.31 2.34	28% 29%	0.36 5.08	0.23 0.27	2 10	1	0.18 0.02			0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	School	2014	2054	24.78	12.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	24.78	12.72	0.00	0.00
NC		2113 Ceiling/roof Insulation - DX	School	2014	2054	24.76	12.71	0.02	0.02	0%	0.01	0.01	0%	0.02	0.02	0	0	4.63			0.02	0.01
NC NC	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	School School	2014 2014	2054 2054	19.07 19.06	9.79 9.79	5.70 0.00	5.71 5.71	23% 23%	2.92 0.00	2.93 2.93	23% 23%	0.05 0.16	0.05 0.05	0	0	1.89 0.40			5.70 0.00	2.92 0.00
NC	2100	2115 Window Film (Standard) - DX	School	2014	2054	18.89	9.70	0.18	5.89	24%	0.09	3.02	24%	0.23	0.06	ó	ō	0.37			0.00	0.00
NC		2105 DX Tune Up/ Advanced Diagnostics	School	2014	2054	18.84	9.69	0.05	5.94	24%	0.01	3.04	24%	0.19	0.06	1	0	0.37			0.00	0.00
NC NC	2100 2100	2108 Optimize Controls - DX 2112 Aerosol Duct Sealing - DX	School School	2014 2014	2054 2054	18.55 17.57	9.64 9.14	0.29 0.98	6.23 7.21	25% 29%	0.04 0.51	3.08 3.58	24% 28%	0.16 0.35	0.06 0.10	1	0	0.34 0.31			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	School	2014	2054	17.41	9.12	0.15	7.36	30%	0.02	3.60	28%	0.21	0.10	1	0	0.28			0.00	0.00
NC	2100	2107 Cool Roof - DX	School	2014	2054	17.11	8.96	0.31	7.67	31%	0.16	3.76	30%	0.39	0.12	1	0	0.22			0.00	0.00
NC NC	2100 2100	2111 Economizer Repair - DX 2109 Economizer - DX	School School	2014 2014	2054 2054	17.07 16.99	8.93 8.92	0.04	7.71 7.79	31% 31%	0.03 0.01	3.79 3.80	30% 30%	0.86 1.25	0.12 0.13	1 9	0	0.09 0.05			0.00	0.00
NC		2114 Duct/Pipe Insulation - DX	School	2014	2054	16.78	8.82	0.20	7.79	32%	0.10	3.90	31%	4.66	0.13	9	1	0.03			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	School	2014	2054	17.76	9.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	17.76	9.12	0.00	0.00
NC NC		2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	School School	2014 2014	2054 2054	15.57 24.65	7.99 12.65	2.20 0.00	2.20 0.00	12% 0%	1.13 0.00	1.13 0.00	12% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	2.24 N/A	24.65	12.65	2.20 0.00	1.13 0.00
NC		2301 HE PTAC, EER=9.6, 1 ton	School	2014	2054	24.65	10.94	3.34	3.34	14%	1.71	1.71	14%	0.11	0.11	0 0	N/A 0	0.89	24.00	12.00	0.00	0.00
NC	2300	2302 Occupancy Sensor (hotels)	School	2014	2054	17.98	8.81	3.33	6.66	27%	2.13	3.85	30%	0.35	0.23	1	0	0.27			0.00	0.00
NC	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	School	2014 2014	2054	5.22	1.02	0.00	0.00	0%	0.00	0.00	0% 4%	N/A	N/A	N/A	N/A 1	N/A 1.06	5.22	1.02	0.00	0.00
NC NC		3002 Variable Speed Drive Control, 5 HP 3001 Fan Motor, 5hp, 1800rpm, 89.5%	School School	2014	2054 2054	4.45 4.38	0.98	0.76	0.76	15% 16%	0.04 0.01	0.04 0.05	4% 5%	0.03	0.03 0.04	1 0	1	1.96			0.76	0.04
NC	3000	3003 Demand Controlled Ventilation	School	2014	2054	3.72	0.74	0.65	1.49	29%	0.23	0.28	28%	1.68	0.76	5	4	0.05			0.00	0.00
NC		3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	School	2014	2054	13.96	2.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.96	2.72	0.00	0.00
NC	3100	3102 Variable Speed Drive Control, 15 HP	School	2014	2054	11.92	2.62	2.04	2.04	15%	0.10	0.10	4%	0.04	0.04	1	1	1.62			2.04	0.10

APPENDIX H

Base Avoided Costs

		ic Existing Construction ITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	age			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
	Base	Measure Number Measure	Building	Start	End Year	Total GWH	Total MW	GWH Savings	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic MW
NC	t Number 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Type School	2014	2054	10.25	2.33	1.67	3.71	Savings 27%	Savings 0.30	0.40	Savings 15%	0.06	0.05	0	0	1.36	GWH	IVI VV	1.67	0.30
NC	3100	3103 Air Handler Optimization, 15 HP	School	2014	2054	9.26	2.28	1.00	4.71	34%	0.05	0.45	16%	0.06	0.05	1	1	0.91			0.00	0.00
NC NC	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3105 Energy Recovery Ventilation (ERV)	School School	2014 2014	2054 2054	9.17 8.69	2.26	0.09 0.48	4.80 5.28	34% 38%	0.02 0.17	0.47 0.63	17% 23%	0.15 0.56	0.05 0.10	1 2	1	0.54 0.18			0.00	0.00
NC	3100	3107 Demand Controlled Ventilation	School	2014	2054	7.39	1.64	1.30	6.58	47%	0.45	1.09	40%	2.26	0.53	6	3	0.04			0.00	0.00
NC	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	School	2014 2014	2054 2054	5.82 4.97	1.14	0.00	0.00	0% 15%	0.00	0.00	0% 4%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A	5.82	1.14	0.00	0.00
NC NC	3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	School School	2014	2054	4.97	1.09 1.09	0.85	0.85 0.86	15%	0.04	0.04	4% 4%	0.01	0.01	0	0	11.33 3.09			0.85 0.01	0.04
NC	3200	3203 Air Handler Optimization, 40 HP	School	2014	2054	4.48	1.07	0.48	1.34	23%	0.02	0.07	6%	0.05	0.02	1	ō	1.06			0.48	0.02
NC NC	3200 4000	3204 Demand Controlled Ventilation	School School	2014 2014	2054 2054	3.81 0.00	0.83	0.67 0.00	2.01 0.00	35% 0%	0.23	0.30	27% 0%	1.83 N/A	0.62 N/A	5 N/A	4 N/A	0.05 N/A	0.00	0.00	0.00	0.00
NC	4100	4000 Base Built-Up Refrigeration System 4100 Base Self-Contained Refrigeration	School	2014	2054	7.25	1.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.25	1.00	0.00	0.00
NC	4100	4103 Night covers for display cases (self-contained)	School	2014	2054	7.24	1.00	0.01	0.01	0%	0.00	0.00	0%	0.00	0.00	0	0	25.26			0.01	0.00
NC NC	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4109 Energy-Star Freezer, glass door	School School	2014 2014	2054 2054	7.14 7.08	0.99	0.10 0.06	0.11 0.16	1% 2%	0.01 0.01	0.01 0.02	1% 2%	0.00 0.01	0.00	0	0	15.98 10.45			0.10 0.06	0.01 0.01
NC	4100	4106 Energy-Star Refrigerator, solid door	School	2014	2054	6.95	0.96	0.13	0.30	4%	0.02	0.02	4%	0.01	0.00	0	0	6.33			0.00	0.02
NC	4100	4107 Energy-Star Freezer, solid door	School	2014	2054	6.92	0.96	0.02	0.32	4%	0.00	0.04	4%	0.01	0.01	0	0	4.14			0.02	0.00
NC NC	4100 4100	4108 Energy-Star Refrigerator, glass door 4110 Energy Star Ice Machines	School School	2014 2014	2054 2054	6.88	0.95	0.04	0.36	5% 7%	0.01	0.05	5% 7%	0.02	0.01	0	0	3.44 2.27			0.04	0.01
NC	4100	4112 Reach-in unit occupancy sensors	School	2014	2054	6.77	0.94	0.00	0.48	7%	0.02	0.07	7%	0.05	0.01	2	0	0.25			0.00	0.02
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	School	2014	2054	6.76	0.93	0.01	0.49	7%	0.00	0.07	7%	0.29	0.02	2	0	0.21			0.00	0.00
NC NC	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	School School	2014 2014	2054 2054	6.74 2.19	0.93 0.19	0.02	0.51	7% 0%	0.00	0.07	7% 0%	0.93 N/A	0.05 N/A	7 N/A	0 N/A	0.06 N/A	2.19	0.19	0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	School	2014	2054	1.20	0.14	0.99	0.99	45%	0.04	0.04	23%	0.01	0.01	0	0	4.10	2.13	0.15	0.99	0.04
NC	5000	5002 Energy Star or Better PC	School	2014	2054	0.85	0.11	0.35	1.33	61%	0.03	0.07	39%	0.02	0.02	0	0	2.09			0.35	0.03
NC NC	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	School School	2014 2014	2054 2054	0.30 0.24	0.03	0.00 0.06	0.00 0.06	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.56	0.30	0.03	0.00 0.06	0.00
NC	5100	5101 Laptop Network Power Management Enabling	School	2014	2054	0.24	0.02	0.01	0.06	21%	0.00	0.01	21%	1.13	0.10	13	1	0.05			0.00	0.00
NC	5200	5200 Base Monitor, CRT	School	2014	2054	1.28	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.28	0.11	0.00	0.00
NC NC	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	School School	2014 2014	2054 2054	0.56	0.05	0.72 0.16	0.72 0.87	56% 68%	0.06 0.01	0.06 0.07	56% 62%	0.00	0.00	0	0	44.25 2.81			0.72 0.16	0.06 0.01
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	School	2014	2054	0.37	0.04	0.03	0.90	71%	0.00	0.07	65%	0.20	0.01	2	0	0.26			0.00	0.00
NC	5300	5300 Base Monitor, LCD	School	2014	2054	0.31	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.31	0.03	0.00	0.00
NC NC	5300 5300	5301 Energy Star or Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	School School	2014 2014	2054 2054	0.26 0.25	0.02	0.06 0.01	0.06 0.06	18% 20%	0.00	0.00 0.01	18% 19%	0.01 0.09	0.01 0.02	0	0	5.01 0.52			0.06	0.00
NC	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	School	2014	2054	0.23	0.02	0.02	0.08	26%	0.00	0.01	20%	0.27	80.0	12	1	0.17			0.00	0.00
NC	5400	5400 Base Copier	School	2014	2054	0.61	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.61	0.05	0.00	0.00
NC NC	5400 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	School School	2014 2014	2054 2054	0.57 0.55	0.05	0.03 0.02	0.03	6% 10%	0.00	0.00	6% 8%	0.00	0.00	0	0	36.66 0.66			0.03	0.00
NC	5500	5500 Base Multifunction	School	2014	2054	0.07	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.07	0.01	0.00	0.00
NC NC	5500 5500	5502 ENERGY STAR Multi-Function Device 5501 Multifunction Power Management Enabling	School School	2014 2014	2054 2054	0.05	0.00	0.02 0.01	0.02	25% 39%	0.00	0.00	25% 32%	0.01 0.24	0.01 0.09	0 6	0	9.48 0.21			0.02	0.00
NC	5600	5600 Base Printer	School	2014	2054	1.02	0.00	0.00	0.00	0%	0.00	0.00	0%	0.24 N/A	0.09 N/A	N/A	N/A	N/A	1.02	0.09	0.00	0.00
NC	5600	5602 ENERGY STAR Printer	School	2014	2054	0.66	0.06	0.35	0.35	35%	0.03	0.03	35%	0.00	0.00	0	0	43.58			0.35	0.03
NC NC	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	School School	2014 2014	2054 2054	0.54 7.34	0.05	0.12 0.00	0.48	47% 0%	0.01 0.00	0.04	41% 0%	0.05 N/A	0.01 N/A	1 N/A	0 N/A	0.96 N/A	7.34	0.63	0.00	0.00
NC	5700	5700 Data Center Improved Operations	School	2014	2054	6.61	0.57	0.73	0.73	10%	0.06	0.06	10%	0.00	0.00	0	0	111.93	7.54	0.03	0.73	0.06
NC	5700	5702 Data Center Best Practices	School	2014	2054	5.77	0.50	0.84	1.58	21%	0.07	0.14	21%	0.00	0.00	0	0	45.57			0.84	0.07
NC NC	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	School School	2014 2014	2054 2054	5.45 2.13	0.47	0.32	1.90 0.00	26% 0%	0.03	0.16	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	23.63 N/A	2.13	0.17	0.32 0.00	0.03
NC	6000	6007 Heat Trap	School	2014	2054	2.02	0.16	0.11	0.11	5%	0.01	0.01	5%	0.04	0.04	1	1	1.60	2.10	0.17	0.11	0.01
NC	6000	6002 High Efficiency Water Heater (electric)	School	2014	2054	1.98	0.15	0.04	0.15	7%	0.00	0.01	7%	0.08	0.05	1	1	0.85			0.00	0.00
NC NC	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	School School	2014 2014	2054 2054	1.79 1.72	0.14	0.19	0.34 0.41	16% 19%	0.02 0.01	0.03	16% 19%	0.08 0.11	0.07 0.07	1	1	0.79 0.65			0.00	0.00
NC	6000	6004 Tankless Water Heater	School	2014	2054	1.59	0.12	0.13	0.54	25%	0.01	0.04	25%	0.14	0.09	2	1	0.52			0.00	0.00
NC	6000	6008 Solar Water Heater	School	2014	2054	1.48	0.12	0.11	0.65	31%	0.01	0.05	31%	0.17	0.10	2	1	0.45			0.00	0.00
NC NC	6000 7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	School School	2014 2014	2054 2054	1.47 1.48	0.11 0.13	0.02 0.00	0.67 0.00	31% 0%	0.00	0.05 0.00	31% 0%	0.18 N/A	0.10 N/A	2 N/A	1 N/A	0.38 N/A	1.48	0.13	0.00	0.00
NC	7000	7001 Vending Misers (Refrigerated units)	School	2014	2054	1.25	0.12	0.23	0.23	15%	0.01	0.01	8%	0.03	0.03	1	1	1.98			0.23	0.01
NC NC	7000 7100	7002 Vending Misers (Refrigerated glass-front units)	School School	2014 2014	2054 2054	1.13	0.11	0.12	0.35	24% 0%	0.01	0.02	12% 0%	0.05 N/A	0.03 N/A	1 N/A	1 N/A	1.09 N/A	0.05	0.00	0.12	0.01 0.00
NC NC	7100	7100 Base Non-Refrigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	School	2014	2054	0.05	0.00	0.00	0.00	44%	0.00	0.00	22%	0.43	0.43	10	10	0.12	0.05	0.00	0.00	0.00
NC	7200	7200 Base Oven	School	2014	2054	2.21	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.21	0.16	0.00	0.00
NC NC	7200 7300	7201 Convection Oven 7300 Base Fryer	School School	2014 2014	2054 2054	1.70	0.13	0.51 0.00	0.51	23% 0%	0.04	0.04	23%	0.41 N/A	0.41 N/A	5 N/A	5 N/A	0.16	0.06	0.00	0.00	0.00
NC NC	7300 7400	7300 Base Fryer 7400 Base Steamer	School School	2014 2014	2054 2054	0.06 0.48	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.06 0.48	0.00	0.00	0.00
NC	7400	7401 Efficient Steamer	School	2014	2054	0.18	0.01	0.31	0.31	63%	0.02	0.02	63%	0.17	0.17	2	2	0.39			0.00	0.00
NC	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF)	School	2014	2054	0.02	0.00	0.00	0.00	0% 6%	0.00	0.00	0%	N/A	N/A	N/A N/A	N/A N/A	N/A	0.02	0.00	0.00	0.00
NC NC	8000 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	School School	2014 2014	2054 2054	0.02 1.64	0.00	0.00	0.00	6% 0%	0.00	0.00	0% 0%	0.06 N/A	0.06 N/A	N/A N/A	N/A N/A	1.14 N/A	1.64	0.00	0.00	0.00
NC	9500	9500 Base Miscellaneous	School	2014	2054	8.43	0.73	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.43	0.73	0.00	0.00
NC NC	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	School Health	2014 2020	2054 2054	8.43 3.92	0.73	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	3.92	0.60	0.00	0.00
NC	1030	1036 Lighting Control Tuneup (base 4L4T8), 2020	Health	2020	2054	3.90	0.60	0.00	0.00	0%	0.00	0.00	0%	0.02	0.02	0	0	2.27	3.32	0.00	0.00	0.00
-		• • • • • • • • • • • • • • • • • • • •														-						

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	tage			Magazira	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity					
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm NC	nt Number 1030	Number Measure 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020	Type Health	Year 2020	Year 2054	3.60	MW 0.56	Savings 0.30	0.31	Savings 8%	Savings 0.04	0.04	Savings 6%	\$/kWH 0.04	\$/kWH 0.03	\$/kW 0	\$/kW	1.98	GWH	MW	0.30	0.04
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Health	2020	2054	3.23	0.50	0.37	0.69	18%	0.06	0.09	16%	0.04	0.04	0	0	1.52			0.37	0.06
NC	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Health	2020	2054	2.82	0.44	0.41	1.10	28%	0.06	0.16	26%	0.08	0.05	1	0	0.73			0.00	0.00
NC NC	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Health Health	2020 2020	2054 2054	2.62	0.43	0.20	1.30 1.72	33% 44%	0.01 0.06	0.16 0.23	27% 38%	0.14 0.50	0.07 0.17	4	1	0.39 0.14			0.00	0.00
NC	1030	1035 LED Troffer (base 4L4'T8), 2020	Health	2020	2054	2.01	0.34	0.19	1.91	49%	0.03	0.26	43%	0.42	0.20	3	1	0.16			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020	Health	2020	2054	0.47	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.47	0.07	0.00	0.00
NC NC	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Health Health	2020 2020	2054 2054	0.42	0.06	0.05 0.00	0.05 0.05	10% 11%	0.01 0.00	0.01 0.01	10% 11%	0.05 0.05	0.05 0.05	0 1	0	1.31 0.97			0.05 0.00	0.01
NC	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Health	2020	2054	0.39	0.06	0.03	0.08	18%	0.00	0.01	16%	0.08	0.06	1	0	0.84			0.00	0.00
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Health	2020	2054	0.34	0.05	0.05	0.13	28%	0.01	0.02	26%	0.10	0.08	1	1	0.58			0.00	0.00
NC NC	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Health Health	2020 2020	2054 2054	0.32	0.05	0.02	0.15 0.18	32% 37%	0.00	0.02	30% 36%	0.38 0.48	0.11	3	1	0.18 0.14			0.00	0.00
NC	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Health	2020	2054	0.27	0.05	0.02	0.20	42%	0.00	0.03	37%	0.29	0.18	8	1	0.19			0.00	0.00
NC	1200	1200 Base Other Fluorescent Fixture	Health	2014 2014	2054 2054	0.13	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A 0.01	N/A 0	N/A 0	N/A	0.13	0.02	0.00	0.00
NC NC	1200 1200	1203 Lighting Control Tuneup (base other fluorescent fixture) 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Health Health	2014	2054	0.13	0.02	0.00	0.00 0.01	1% 9%	0.00	0.00	1% 7%	0.01 0.09	0.01	1	1	6.12 0.74			0.00	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	Health	2014	2054	0.10	0.02	0.01	0.02	18%	0.00	0.00	16%	0.16	0.12	1	1	0.37			0.00	0.00
NC NC	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Health Health	2014 2020	2054 2054	0.08	0.02	0.02	0.04	34% 0%	0.00	0.00	20% 0%	0.17 N/A	0.14 N/A	5 N/A	2 N/A	0.33 N/A	0.24	0.04	0.00	0.00
NC	1330	1332 LEDs (base incandescent flood) 2020	Health	2020	2054	0.24	0.04	0.00	0.20	83%	0.00	0.03	83%	0.01	0.01	0	0	5.69	0.24	0.04	0.00	0.00
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Health	2020	2054	0.09	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.01	0.00	0.00
NC NC	1430 1530	1432 LEDs (base incandescent A-line 72W) 20201530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Health Health	2020 2020	2054 2054	0.02	0.00	0.07	0.07	82% 0%	0.01	0.01	82% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	4.80 N/A	0.06	0.01	0.07	0.01
NC	1530	1530 Base incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Health	2020	2054	0.00	0.00	0.00	0.05	75%	0.00	0.00	75%	0.02	0.02	0	0	3.58	0.06	0.01	0.00	0.00
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Health	2020	2054	0.09	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.01	0.00	0.00
NC NC	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Health Health	2020 2020	2054 2054	0.07	0.01	0.03	0.03	28% 0%	0.00	0.00	28% 0%	0.11 N/A	0.11 N/A	1 N/A	1 N/A	0.58 N/A	0.12	0.02	0.00	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Health	2020	2054	0.12	0.02	0.00	0.00	26%	0.00	0.00	26%	0.08	0.08	1	1	0.77	0.12	0.02	0.00	0.00
NC	1800	1800 BaseMetal Halide, 465W	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Health Health	2014	2054 2054	0.11	0.02	0.00	0.00	0% 12%	0.00	0.00	0% 12%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.89	0.11	0.02	0.00	0.00
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Health	2014	2054	0.35	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.35	0.00	0.00	0.00
NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Health	2014	2054	0.32	0.00	0.03	0.03	8%	0.00	0.00	25%	0.08	0.08	3	3	0.89			0.00	0.00
NC NC	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Health Health	2014 2014	2054 2054	0.16 0.11	0.00	0.17 0.05	0.19 0.24	56% 69%	0.00	0.00	73% 85%	0.17 1.07	0.15 0.33	18 127	12 28	0.39 0.06			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Health	2014	2054	2.64	1.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.64	1.45	0.00	0.00
NC NC	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2105 DX Tune Up/ Advanced Diagnostics	Health Health	2014 2014	2054 2054	2.03	1.12 1.11	0.61 0.03	0.61 0.64	23% 24%	0.33 0.01	0.33 0.34	23% 24%	0.03 0.11	0.03 0.04	0	0	2.99 0.63			0.61 0.00	0.33
NC	2100	2108 Optimize Controls - DX	Health	2014	2054	1.97	1.10	0.03	0.67	25%	0.00	0.35	24%	0.09	0.04	1	0	0.61			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Health	2014	2054	1.92	1.10	0.04	0.71	27%	0.01	0.35	24%	0.11	0.04	1	0	0.54			0.00	0.00
NC NC	2100 2100	2112 Aerosol Duct Sealing - DX 2115 Window Film (Standard) - DX	Health Health	2014 2014	2054 2054	1.81 1.80	1.03	0.12	0.83 0.84	31% 32%	0.06 0.01	0.42 0.42	29% 29%	0.23 0.29	0.07 0.07	0	0	0.46 0.29			0.00	0.00
NC	2100	2107 Cool Roof - DX	Health	2014	2054	1.79	1.03	0.01	0.84	32%	0.00	0.42	29%	0.77	0.08	i	0	0.11			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	Health	2014	2054	1.77	1.01	0.02	0.86	33%	0.01	0.43	30%	3.01	0.14	5	0	0.03			0.00	0.00
NC NC	2100 2100	2111 Economizer Repair - DX 2109 Economizer - DX	Health Health	2014 2014	2054 2054	1.77 1.77	1.01 1.01	0.00	0.86 0.86	33% 33%	0.00	0.43 0.43	30% 30%	27206.90 31674.79	0.15 0.18	32,812 246,502	0	0.00			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Health	2014	2054	5.27	2.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.27	2.90	0.00	0.00
NC	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	2014	2054	4.62	2.54	0.65	0.65	12%	0.36	0.36	12%	0.03	0.03	0	0	3.50			0.65	0.36
NC NC	2300 3000	2300 Base PTAC, EER=8.3, 1 ton 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Health Health	2014 2014	2054 2054	0.45 1.45	0.25	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.45 1.45	0.25	0.00	0.00
NC	3000	3002 Variable Speed Drive Control, 5 HP	Health	2014	2054	1.00	0.27	0.46	0.46	31%	0.02	0.02	8%	0.02	0.02	0	0	4.04	1.40	0.23	0.46	0.02
NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Health	2014	2054	0.98	0.27	0.02	0.47	33%	0.00	0.03	9%	0.03	0.02	0	0	2.62			0.02	0.00
NC NC	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Health Health	2014 2014	2054 2054	0.89 5.05	0.23 1.02	0.09	0.57 0.00	39% 0%	0.04	0.06	22% 0%	1.01 N/A	0.18 N/A	2 N/A	2 N/A	0.09 N/A	5.05	1.02	0.00	0.00
NC	3100	3102 Variable Speed Drive Control, 15 HP	Health	2014	2054	3.46	0.95	1.58	1.58	31%	0.08	0.08	7%	0.01	0.01	0	0	11.68	3.00		1.58	0.08
NC	3100		Health	2014	2054	3.46	0.95	0.01	1.59	32%	0.00	0.08	8%	0.02	0.01	0	0	4.63			0.01	0.00
NC NC	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3105 Energy Recovery Ventilation (ERV)	Health Health	2014 2014	2054 2054	2.95 2.76	0.85	0.50 0.19	2.09	41% 45%	0.09	0.17 0.25	17% 24%	0.03	0.01 0.04	0	0	2.51 0.32			0.50	0.09
NC	3100	3107 Demand Controlled Ventilation	Health	2014	2054	2.50	0.67	0.26	2.55	50%	0.11	0.36	35%	1.24	0.16	3	1	0.08			0.00	0.00
NC	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Health	2014	2054	5.36	1.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.36	1.09	0.00	0.00
NC NC	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Health Health	2014 2014	2054 2054	4.85 0.00	0.88	0.51 0.00	0.51 0.00	10% 0%	0.21 0.00	0.21 0.00	20% 0%	0.68 N/A	0.68 N/A	2 N/A	2 N/A	0.14 N/A	0.00	0.00	0.00	0.00
NC	4100	4100 Base Self-Contained Refrigeration	Health	2014	2054	1.30	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.30	0.19	0.00	0.00
NC	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Health	2014	2054	1.28	0.18	0.02	0.02	2%	0.00	0.00	2%	0.01	0.01	0	0	9.74			0.02	0.00
NC NC	4100 4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Health Health	2014 2014	2054 2054	1.27 1.27	0.18 0.18	0.00	0.02	2% 2%	0.00	0.00	2% 2%	0.02 0.02	0.01 0.01	0	0	3.40 3.32			0.00	0.00
NC	4100	4110 Energy Star Ice Machines	Health	2014	2054	1.26	0.18	0.00	0.03	3%	0.00	0.01	3%	0.02	0.02	0	0	1.22			0.00	0.00
NC	4100	4112 Reach-in unit occupancy sensors	Health	2014	2054	1.26	0.18	0.00	0.03	3%	0.00	0.01	3%	0.31	0.02	2	0	0.20			0.00	0.00
NC NC	4100 5000	4105 Bi-level LED Case Lighting (self-contained units) 2014 5000 Base Desktop PC	Health Health	2014 2014	2054 2054	1.26 0.63	0.18	0.00	0.04	3% 0%	0.00	0.01	3% 0%	0.36 N/A	0.02 N/A	2 N/A	0 N/A	0.17 N/A	0.63	0.09	0.00	0.00
NC	5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Health	2014	2054	0.63	0.09	0.00	0.29	46%	0.00	0.02	23%	0.02	0.02	0	0	2.31	0.03	0.05	0.00	0.00
NC	5000	5002 Energy Star or Better PC	Health	2014	2054	0.23	0.05	0.11	0.40	63%	0.02	0.04	40%	0.05	0.03	0	0	1.10			0.11	0.02

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta				Manager	Measure				Total	Percent		Total	Dozoont	Marginal	Average	Marginal	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity	Cost Test	Base	Base	Economic	Economic
Sgm NC	t Number 5100	Number Measure 5100 Base Laptop PC	Type Health	Year 2014	Year 2054	0.02	MW 0.00	Savings 0.00	GWH 0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	0.02	MW 0.00	GWH 0.00	0.00
NC	5100	5102 Energy Star or Better Laptop	Health	2014	2054	0.02	0.00	0.00	0.00	19%	0.00	0.00	19%	0.02	0.02	0	0	3.11	0.02	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Health	2014	2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	2.07	0.18	15	1	0.03			0.00	0.00
NC NC	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Health Health	2014 2014	2054 2054	0.19	0.03	0.00 0.10	0.00 0.10	0% 55%	0.00 0.01	0.00 0.01	0% 55%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 25.37	0.19	0.03	0.00 0.10	0.00 0.01
NC	5200	5202 Monitor Power Management Enabling - CRT	Health	2014	2054	0.06	0.01	0.03	0.13	70%	0.00	0.02	62%	0.03	0.01	0	0	1.50			0.03	0.00
NC NC	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Health Health	2014 2014	2054 2054	0.05 0.11	0.01	0.00	0.13 0.00	72% 0%	0.00	0.02	65% 0%	0.38 N/A	0.02 N/A	3 N/A	0 N/A	0.14 N/A	0.11	0.02	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	Health	2014	2054	0.09	0.01	0.02	0.02	20%	0.00	0.00	20%	0.02	0.02	0	0	2.74	0.11	0.02	0.02	0.00
NC NC	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Health Health	2014 2014	2054 2054	0.09	0.01	0.00 0.01	0.03	24% 30%	0.00	0.00	22% 23%	0.18 0.50	0.05 0.14	3 14	0	0.28			0.00	0.00
NC	5400	5400 Base Copier	Health	2014	2054	0.08	0.01	0.00	0.00	0%	0.00	0.00	0%	0.50 N/A	0.14 N/A	N/A	N/A	0.09 N/A	0.32	0.05	0.00	0.00
NC	5400 5400	5401 Energy Star or Better Copier	Health Health	2014 2014	2054	0.27	0.04	0.05	0.05	17% 22%	0.01	0.01	17% 19%	0.00	0.00	0	0	18.03			0.05	0.01
NC NC	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Health	2014	2054 2054	0.25	0.04	0.02	0.07	0%	0.00	0.01 0.00	0%	0.17 N/A	0.04 N/A	N/A	N/A	0.32 N/A	0.06	0.01	0.00	0.00
NC	5500	5502 ENERGY STAR Multi-Function Device	Health	2014	2054	0.04	0.01	0.02	0.02	25%	0.00	0.00	25%	0.01	0.01	0	0	5.29			0.02	0.00
NC NC	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Health Health	2014 2014	2054	0.04	0.01	0.01	0.02	36% 0%	0.00	0.00	31% 0%	0.40 N/A	0.13 N/A	6 N/A	1 N/A	0.13 N/A	0.07	0.01	0.00	0.00
NC	5600	5602 ENERGY STAR Printer	Health	2014	2054	0.04	0.01	0.02	0.02	35%	0.00	0.00	35%	0.00	0.00	0	0	24.30	0.07	0.01	0.02	0.00
NC NC	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Health Health	2014 2014	2054 2054	0.04 3.19	0.01 0.45	0.01 0.00	0.03	44% 0%	0.00	0.00	40% 0%	0.09 N/A	0.02 N/A	1 N/A	0 N/A	0.59 N/A	3.19	0.45	0.00	0.00
NC	5700	5700 base bata Center/Server Room 5701 Data Center Improved Operations	Health	2014	2054	2.87	0.45	0.00	0.32	10%	0.05	0.00	10%	0.00	0.00	0	0	86.68	3.19	0.45	0.00	0.00
NC	5700	5702 Data Center Best Practices	Health	2014	2054	2.51	0.36	0.37	0.68	21%	0.05	0.10	21%	0.00	0.00	0	0	35.29			0.37	0.05
NC NC	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Health Health	2014 2014	2054 2054	2.37 0.58	0.34	0.14 0.00	0.82	26% 0%	0.02	0.12	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	18.30 N/A	0.58	0.07	0.14 0.00	0.02
NC	6000	6001 Demand controlled circulating systems	Health	2014	2054	0.56	0.07	0.02	0.02	4%	0.00	0.00	4%	0.04	0.04	0	0	1.60			0.02	0.00
NC NC	6000 6000	6007 Heat Trap 6002 High Efficiency Water Heater (electric)	Health Health	2014 2014	2054 2054	0.53 0.52	0.07	0.03 0.01	0.05 0.06	9% 11%	0.00	0.01 0.01	9% 11%	0.05 0.09	0.04 0.05	0	0	1.41 0.76			0.03	0.00
NC	6000	6006 Heat Recovery Unit	Health	2014	2054	0.25	0.03	0.27	0.33	57%	0.03	0.04	57%	0.09	0.08	i	1	0.72			0.00	0.00
NC NC	6000 6000	6004 Tankless Water Heater 6008 Solar Water Heater	Health Health	2014 2014	2054 2054	0.23	0.03	0.02 0.03	0.35 0.38	60% 66%	0.00	0.04 0.05	60% 66%	0.30 0.35	0.09 0.11	2	1	0.26 0.22			0.00	0.00
NC NC	6000	6003 Hot Water Pipe Insulation	Health	2014	2054	0.20	0.03	0.03	0.38	67%	0.00	0.05	67%	0.35	0.11	3	1	0.22			0.00	0.00
NC	7000	7000 Base Refrigerated Vending Machines	Health	2014	2054	0.55	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.55	0.08	0.00	0.00
NC NC	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Health Health	2014 2014	2054 2054	0.46 0.41	0.07	0.09 0.05	0.09 0.14	16% 25%	0.01 0.00	0.01 0.01	8% 12%	0.03 0.05	0.03	0	0	2.00 1.09			0.09 0.05	0.01 0.00
NC	7100	7100 Base Non-Refrigerated Vending Machines	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Health Health	2014 2014	2054 2054	0.00	0.00	0.00	0.00	47% 0%	0.00	0.00	23%	0.43 N/A	0.43 N/A	6 N/A	6 N/A	0.12 N/A	0.09	0.02	0.00	0.00
NC	7300	7300 Base Gveri 7300 Base Fryer	Health	2014	2054	0.09	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.02	0.00	0.00
NC	7300	7301 Efficient Fryer	Health	2014	2054	0.12	0.02	0.01	0.01	6%	0.00	0.00	6%	1.32	1.32	7	7	0.05			0.00	0.00
NC NC	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Health Health	2014 2014	2054 2054	0.07 1.32	0.01	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.07 1.32	0.01	0.00	0.00
NC	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	2014	2054	1.25	0.00	0.07	0.07	6%	0.00	0.00	0%	0.02	0.02	N/A	N/A	2.95			0.07	0.00
NC NC	8100 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	Health Health	2014 2014	2054 2054	0.00 10.03	0.00 1.40	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 10.03	0.00 1.40	0.00	0.00
NC	9500	9501 Xmisc	Health	2014	2054	10.03	1.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00	10.03		0.00	0.00
NC NC	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Lodging	2020 2020	2054 2054	0.14	0.02	0.00 0.01	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.57	0.14	0.02	0.00 0.01	0.00
NC	1030	1031 ROB 4L4 High Performance To (66 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Lodging Lodging	2020	2054	0.12	0.02	0.01	0.01	22%	0.00	0.00	22%	0.03	0.03	0	0	1.23			0.01	0.00
NC	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Lodging	2020	2054	0.11	0.01	0.00	0.03	22%	0.00	0.00	22%	0.05	0.04	1	0	1.00			0.00	0.00
NC NC	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1034 ROB 4L4' LED Tube, 2020	Lodging Lodging	2020 2020	2054 2054	0.10	0.01	0.01	0.04	28% 40%	0.00	0.01	27% 38%	0.08	0.05	1	0	0.87			0.00	0.00
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Lodging	2020	2054	0.08	0.01	0.00	0.06	41%	0.00	0.01	39%	0.20	0.15	6	1	0.28			0.00	0.00
NC NC	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Lodging Lodging	2020 2020	2054 2054	0.07	0.01	0.01	0.06	46% 0%	0.00	0.01 0.00	44% 0%	0.34 N/A	0.17 N/A	2 N/A	1 N/A	0.24 N/A	0.55	0.08	0.00	0.00
NC	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Lodging	2020	2054	0.49	0.07	0.06	0.06	10%	0.01	0.00	10%	0.03	0.03	0	0	2.03	0.55	0.00	0.06	0.00
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Lodging	2020	2054	0.43	0.06	0.06	0.12	22%	0.01	0.02	22%	0.07	0.05	1	0	0.97			0.00	0.00
NC NC	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Lodging Lodging	2020 2020	2054 2054	0.43	0.06	0.00 0.03	0.12 0.15	22% 28%	0.00	0.02 0.02	22% 27%	0.07 0.11	0.05 0.07	1	0	0.71 0.62			0.00	0.00
NC	1130	1134 ROB 2L4' LED Tube, 2020	Lodging	2020	2054	0.38	0.05	0.02	0.17	32%	0.00	0.02	30%	0.32	0.09	2	1	0.25			0.00	0.00
NC NC	1130 1130	1135 LED Troffer (base 2L4'T8), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Lodging Lodging	2020 2020	2054 2054	0.34	0.05	0.03 0.01	0.21 0.22	37% 39%	0.00	0.03	36% 36%	0.41 0.33	0.14	3 10	1	0.20			0.00	0.00
NC	1200	1200 Base Other Fluorescent Fixture	Lodging	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	1200 1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Lodging	2014	2054	0.01	0.00	0.00	0.00	2% 12%	0.00	0.00	1%	0.02	0.02	0	0	2.43			0.00	0.00
NC NC	1200	1201 ROB High Performance T8 (base other fluorescent)1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Lodging Lodging	2014 2014	2054 2054	0.01 0.01	0.00	0.00	0.00	29%	0.00	0.00	11% 27%	0.11 0.26	0.10 0.18	2	1	0.62 0.27			0.00	0.00
NC	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Lodging	2014	2054	0.01	0.00	0.00	0.00	35%	0.00	0.00	28%	0.22	0.19	7	2	0.25		0.45	0.00	0.00
NC NC	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Lodging Lodging	2020 2020	2054 2054	1.11 0.19	0.16	0.00 0.92	0.00 0.92	0% 83%	0.00 0.13	0.00 0.13	0% 83%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.09	1.11	0.16	0.00 0.92	0.00 0.13
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Lodging	2020	2054	0.40	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.40	0.06	0.00	0.00
NC NC	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Lodging Lodging	2020 2020	2054 2054	0.07	0.01	0.33	0.33	82% 0%	0.05 0.00	0.05 0.00	82% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	5.99 N/A	0.29	0.04	0.33	0.05
NC	1530	1532 LEDs (base incandescent A-line 53W) 2020	Lodging	2020	2054	0.08	0.01	0.22	0.22	75%	0.03	0.03	75%	0.02	0.02	0	0	4.46			0.22	0.03
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Lodging	2020	2054	0.43	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.43	0.06	0.00	0.00

DNV GL *H-33* 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS															SUPPLY					
Vinta	ige			Moneuro	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm NC	Number 1630	Number Measure	Туре	Year 2020	Year 2054	0.31	MW 0.04	Savings 0.12	0.12	Savings 28%	Savings 0.02	MW	Savings	\$/kWH 0.10	\$/kWH 0.10	\$/kW	\$/kW	0.73	GWH	MW	0.00	MW
NC	1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Lodging Lodging	2020	2054	0.55	0.04	0.12	0.12	28% 0%	0.02	0.02	28% 0%	0.10 N/A	0.10 N/A	N/A	N/A	0.73 N/A	0.55	0.08	0.00	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Lodging	2020	2054	0.41	0.06	0.14	0.14	26%	0.02	0.02	26%	0.08	0.08	1	1	0.97			0.00	0.00
NC	1800	1800 BaseMetal Halide, 465W	Lodging	2014	2054	0.11	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.02	0.00	0.00
NC NC	1800 1800	1801 T5 (240W) (base metal halide) 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Lodging Lodging	2014 2014	2054 2054	0.07	0.01	0.04 0.01	0.04	34% 39%	0.01 0.00	0.01 0.01	34% 38%	0.02 0.05	0.02	0	0	3.63 1.27			0.04	0.01
NC	1800	1806 Occupancy Sensor, High Bay T5	Lodging	2014	2054	0.06	0.01	0.00	0.04	41%	0.00	0.01	38%	0.06	0.03	2	0	0.97			0.00	0.00
NC	1850	1850 Base CFL Exit Sign	Lodging	2014	2054	0.16	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.16	0.02	0.00	0.00
NC NC	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Lodging Lodging	2014 2014	2054	0.09 1.05	0.01	0.07	0.07	44% 0%	0.01	0.01	44% 0%	0.03 N/A	0.03 N/A	0 N/A	0 N/A	1.80 N/A	1.05	0.01	0.07	0.01
NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Lodging	2014	2054	1.03	0.01	0.04	0.04	4%	0.00	0.00	13%	0.05	0.05	2	2	1.39	1.05	0.01	0.04	0.00
NC	1900	1902 LED Outdoor Area Lighting	Lodging	2014	2054	0.49	0.00	0.52	0.57	54%	0.00	0.01	63%	0.11	0.10	12	10	0.60			0.00	0.00
NC NC	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Lodging Lodging	2014 2014	2054 2054	0.34	0.00	0.14 0.00	0.71 0.00	67% 0%	0.00	0.01 0.00	75% 0%	0.69 N/A	0.22 N/A	89 N/A	23 N/A	0.09 N/A	0.00	0.00	0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Lodging	2014	2054	10.34	6.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.34	6.22	0.00	0.00
NC	2100	2115 Window Film (Standard) - DX	Lodging	2014	2054	9.81	5.91	0.53	0.53	5%	0.32	0.32	5%	0.03	0.03	0	0	2.58			0.53	0.32
NC	2100	2102 DX Packaged System, EER=13.4, 10 tons	Lodging	2014	2054	7.55	4.55	2.26	2.79	27%	1.36	1.68	27%	0.05	0.05	0	0	2.07			2.26	1.36
NC NC	2100 2100	2108 Optimize Controls - DX 2105 DX Tune Up/ Advanced Diagnostics	Lodging Lodging	2014 2014	2054 2054	7.41 7.31	4.53 4.50	0.14 0.11	2.92 3.03	28% 29%	0.02	1.70 1.73	27% 28%	0.09 0.17	0.05 0.05	1	0	0.58 0.42			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	Lodging	2014	2054	7.09	4.47	0.21	3.25	31%	0.03	1.76	28%	0.16	0.06	i	0	0.36			0.00	0.00
NC	2100	2112 Aerosol Duct Sealing - DX	Lodging	2014	2054	6.66	4.21	0.43	3.68	36%	0.26	2.02	32%	0.35	0.09	1	0	0.32			0.00	0.00
NC NC	2100 2100	2111 Economizer Repair - DX 2107 Cool Roof - DX	Lodging Lodging	2014 2014	2054 2054	6.63 6.61	4.18 4.17	0.03	3.71 3.72	36% 36%	0.03	2.05 2.06	33% 33%	0.99 1.35	0.10 0.11	1 2	0	0.09			0.00	0.00
NC	2100	2109 Economizer - DX	Lodging	2014	2054	6.50	4.15	0.11	3.83	37%	0.02	2.07	33%	1.17	0.14	8	0	0.05			0.00	0.00
NC	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Lodging	2014	2054	6.50	4.15	0.00	3.83	37%	0.00	2.07	33%	1.97	0.14	14	0	0.03			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	Lodging	2014	2054	6.43	4.11	0.07	3.90	38%	0.04	2.11	34%	3.30 N/A	0.19 N/A	5	0	0.03	0.50		0.00	0.00
NC NC	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging Lodging	2014 2014	2054 2054	9.53 8.35	5.74 5.03	0.00 1.18	0.00 1.18	0% 12%	0.00 0.71	0.00 0.71	0% 12%	0.03	0.03	N/A 0	N/A 0	N/A 3.57	9.53	5.74	0.00 1.18	0.00 0.71
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	Lodging	2014	2054	8.66	5.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.66	5.22	0.00	0.00
NC	2300	2301 HE PTAC, EER=9.6, 1 ton	Lodging	2014	2054	7.49	4.51	1.17	1.17	14%	0.71	0.71	14%	0.09	0.09	0	0	1.21			1.17	0.71
NC NC	2300 3000	2302 Occupancy Sensor (hotels) 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Lodging Lodging	2014 2014	2054 2054	6.41 5.98	3.63 1.27	1.08 0.00	2.26	26% 0%	0.88	1.59 0.00	30% 0%	0.29 N/A	0.18 N/A	0 N/A	0 N/A	0.35 N/A	5.98	1.27	0.00	0.00
NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Lodging	2014	2054	5.88	1.24	0.10	0.10	2%	0.02	0.02	2%	0.03	0.03	0	0	2.39	5.50	1.27	0.10	0.02
NC	3000	3003 Demand Controlled Ventilation	Lodging	2014	2054	5.06	0.89	0.81	0.92	15%	0.35	0.38	30%	1.07	0.96	2	2	0.09			0.00	0.00
NC NC	3100 3200	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Lodging Lodging	2014 2014	2054 2054	0.00 1.03	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 1.03	0.00 0.22	0.00	0.00
NC	3200	3203 Air Handler Optimization, 40 HP	Lodging	2014	2054	0.93	0.22	0.00	0.00	10%	0.00	0.00	3%	0.03	0.03	1	1	2.02	1.03	0.22	0.00	0.00
NC	3200	3204 Demand Controlled Ventilation	Lodging	2014	2054	0.80	0.16	0.13	0.24	23%	0.06	0.06	28%	1.18	0.65	3	3	0.08			0.00	0.00
NC	4000	4000 Base Built-Up Refrigeration System	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Lodging Lodging	2014 2014	2054 2054	3.43 3.33	0.50 0.49	0.00 0.10	0.00 0.10	0% 3%	0.00 0.02	0.00 0.02	0% 3%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 68.13	3.43	0.50	0.00 0.10	0.00 0.02
NC	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Lodging	2014	2054	3.28	0.48	0.04	0.15	4%	0.01	0.02	4%	0.00	0.00	0	0	26.03			0.04	0.01
NC	4100	4109 Energy-Star Freezer, glass door	Lodging	2014	2054	3.23	0.47	0.05	0.20	6%	0.01	0.03	6%	0.00	0.00	0	0	20.32			0.05	0.01
NC NC	4100 4100	4107 Energy-Star Freezer, solid door 4106 Energy-Star Refrigerator, solid door	Lodging Lodging	2014 2014	2054 2054	3.21 3.19	0.47	0.02	0.22 0.24	6% 7%	0.00	0.03	6% 7%	0.01	0.00	0	0	8.09 6.44			0.02	0.00
NC	4100	4110 Energy Star Ice Machines	Lodging	2014	2054	3.17	0.46	0.03	0.26	8%	0.00	0.04	8%	0.03	0.01	0	0	2.39			0.03	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Lodging	2014	2054	3.17	0.46	0.00	0.26	8%	0.00	0.04	8%	0.36	0.01	2	0	0.17			0.00	0.00
NC NC	4100 5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Lodging	2014 2014	2054 2054	3.15 0.42	0.46	0.01 0.00	0.28	8% 0%	0.00	0.04	8% 0%	0.39 N/A	0.02 N/A	3 N/A	0 N/A	0.14 N/A	0.42	0.06	0.00	0.00
NC	5000	5000 Base Desktop PC 5002 Energy Star or Better PC	Lodging Lodging	2014	2054	0.42	0.05	0.00	0.00	21%	0.00	0.00	21%	0.02	0.02	0	0	3.57	0.42	0.06	0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	Lodging	2014	2054	0.18	0.04	0.15	0.24	58%	0.01	0.02	39%	0.02	0.02	0	0	2.75			0.15	0.01
NC NC	5100 5100	5100 Base Laptop PC	Lodging	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 19%	0.00	0.00	0% 19%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.68	0.01	0.00	0.00	0.00
NC NC	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Lodging Lodging	2014	2054	0.01	0.00	0.00	0.00	19% 21%	0.00	0.00	19% 21%	1.38	0.01	9	1	4.68 0.04			0.00	0.00
NC	5200	5200 Base Monitor, CRT	Lodging	2014	2054	0.24	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.24	0.04	0.00	0.00
NC	5200	5201 Energy Star or Better Monitor - CRT	Lodging	2014	2054	0.10	0.02	0.13	0.13	56%	0.02	0.02	56%	0.00	0.00	0	0	37.23			0.13	0.02
NC NC	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Lodging Lodging	2014 2014	2054 2054	0.08	0.01	0.03	0.16 0.17	67% 69%	0.00	0.02 0.02	61% 64%	0.02 0.23	0.00	0	0	2.63 0.23			0.03	0.00
NC	5300	5300 Base Monitor, LCD	Lodging	2014	2054	0.11	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.02	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	Lodging	2014	2054	0.10	0.01	0.01	0.01	10%	0.00	0.00	10%	0.01	0.01	0	0	4.61			0.01	0.00
NC NC	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Lodging	2014 2014	2054 2054	0.09	0.01	0.01	0.02	20% 27%	0.00	0.00	15% 17%	0.12 0.32	0.07	9	1	0.42			0.00	0.00
NC NC	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Lodging Lodging	2014	2054	0.08	0.01	0.01	0.03	27% 0%	0.00	0.00	17% 0%	0.32 N/A	0.13 N/A	N/A	1 N/A	0.15 N/A	0.17	0.03	0.00	0.00
NC	5400	5401 Energy Star or Better Copier	Lodging	2014	2054	0.16	0.02	0.02	0.02	10%	0.00	0.00	10%	0.00	0.00	0	0	29.48			0.02	0.00
NC	5400	5402 Copier Power Management Enabling	Lodging	2014	2054	0.15	0.02	0.01	0.02	13%	0.00	0.00	12%	0.10	0.03	1	0	0.54	0.00	0.00	0.00	0.00
NC NC	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Lodging Lodging	2014 2014	2054 2054	0.02	0.00	0.00 0.01	0.00 0.01	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.96	0.02	0.00	0.00 0.01	0.00
NC	5500	5501 Multifunction Power Management Enabling	Lodging	2014	2054	0.02	0.00	0.00	0.01	39%	0.00	0.00	32%	0.28	0.11	4	1	0.18			0.00	0.00
NC	5600	5600 Base Printer	Lodging	2014	2054	0.14	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.14	0.02	0.00	0.00
NC NC	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Lodging Lodging	2014 2014	2054 2054	0.09	0.01 0.01	0.05 0.02	0.05 0.07	35% 47%	0.01	0.01 0.01	35% 41%	0.00 0.06	0.00 0.02	0	0	36.59 0.83			0.05	0.01
NC	5700	5700 Base Data Center/Server Room	Lodging	2014	2054	2.94	0.44	0.02	0.07	0%	0.00	0.00	0%	N/A	0.02 N/A	N/A	N/A	0.63 N/A	2.94	0.44	0.00	0.00
NC	5700	5701 Data Center Improved Operations	Lodging	2014	2054	2.65	0.39	0.29	0.29	10%	0.04	0.04	10%	0.00	0.00	0	0	116.16			0.29	0.04
NC	5700	5702 Data Center Best Practices	Lodging	2014	2054	2.31	0.34	0.34	0.63	21%	0.05	0.09	21%	0.00	0.00	0	0	47.29			0.34	0.05

APPENDIX H

Commercial Electric Existing Construction

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS																SUPPLY				
Vinta	ge			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm1 NC	Number 5700	Number Measure 5703 Data Center State of the Art practices	Type Lodging	Year 2014	Year 2054	2.18	MW 0.32	Savings 0.13	0.76	Savings 26%	Savings 0.02	0.11	Savings 26%	\$/kWH 0.00	\$/kWH 0.00	\$/kW 0	\$/kW 0	TRC 24.53	GWH	MW	0.13	0.02
NC	6000	6000 Base Water Heating	Lodging	2014	2054	2.12	0.29	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.12	0.29	0.00	0.00
NC NC	6000	6007 Heat Trap 6006 Heat Recovery Unit	Lodging Lodging	2014 2014	2054	2.01 1.75	0.27	0.11 0.26	0.11 0.37	5% 18%	0.01 0.04	0.01 0.05	5% 18%	0.01 0.02	0.01 0.02	0	0	4.29 3.21			0.11	0.01
NC	6000	6001 Demand controlled circulating systems	Lodging	2014	2054	1.68	0.23	0.07	0.44	21%	0.01	0.06	21%	0.03	0.02	Ō	0	2.22			0.07	0.01
NC	6000	6002 High Efficiency Water Heater (electric)	Lodging	2014 2014	2054 2054	1.65	0.22	0.03	0.47 0.59	22% 28%	0.00	0.06	22% 28%	0.04	0.02	0	0	1.93 1.37			0.03	0.00
NC NC	6000	6004 Tankless Water Heater 6008 Solar Water Heater	Lodging Lodging	2014	2054	1.53 1.31	0.21 0.18	0.12	0.59	28% 38%	0.02	0.08 0.11	28% 38%	0.06 0.07	0.03 0.04	0	0	1.37			0.12	0.02
NC	6000	6003 Hot Water Pipe Insulation	Lodging	2014	2054	1.29	0.17	0.02	0.83	39%	0.00	0.11	39%	0.08	0.04	1	0	0.92			0.00	0.00
NC NC	7000 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Lodging Lodging	2014 2014	2054 2054	0.62 0.52	0.10	0.00 0.10	0.00 0.10	0% 16%	0.00 0.01	0.00 0.01	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.01	0.62	0.10	0.00 0.10	0.00 0.01
NC	7000	7002 Vending Misers (Refrigerated glass-front units)	Lodging	2014	2054	0.46	0.09	0.06	0.16	25%	0.00	0.01	12%	0.05	0.03	1	0	1.10			0.06	0.00
NC NC	7100 7100	7100 Base Non-Refrigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	Lodging Lodging	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 47%	0.00	0.00	0% 23%	N/A 0.43	N/A 0.43	N/A 5	N/A 5	N/A 0.12	0.00	0.00	0.00	0.00
NC	7200	7200 Base Oven	Lodging	2014	2054	0.15	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.15	0.03	0.00	0.00
NC	7300 7400	7300 Base Fryer	Lodging	2014	2054	0.18	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.18	0.04	0.00	0.00
NC NC	8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Lodging Lodging	2014 2014	2054 2054	0.09	0.02	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.09 1.37	0.02	0.00	0.00
NC	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	2014	2054	1.29	0.00	0.08	0.08	6%	0.00	0.00	0%	0.03	0.03	N/A	N/A	2.19			0.08	0.00
NC NC	8100 9500	8100 Base Heating, Other Electric 9500 Base Miscellaneous	Lodging Lodging	2014 2014	2054 2054	0.66 7.41	0.00 1.21	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.66 7.41	0.00 1.21	0.00	0.00
NC	9500	9501 Xmisc	Lodging	2014	2054	7.41	1.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00
NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Data Centers	2020	2054	0.32	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.32	0.06	0.00	0.00
NC NC	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Data Centers Data Centers		2054 2054	0.30	0.05	0.02 0.03	0.02 0.05	7% 17%	0.00 0.01	0.00 0.01	6% 15%	0.02 0.03	0.02 0.02	0	0	4.14 2.35			0.02 0.03	0.00 0.01
NC	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Data Centers	2020	2054	0.24	0.04	0.03	0.09	27%	0.01	0.01	26%	0.06	0.04	0	0	1.13			0.03	0.01
NC NC	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Data Centers Data Centers		2054 2054	0.22	0.04	0.02	0.11	33% 44%	0.00	0.02 0.02	28% 38%	0.08 0.36	0.04	2	0	0.66 0.21			0.00	0.00
NC	1030	1035 LED Troffer (base 4L4T8), 2020	Data Centers		2054	0.17	0.03	0.03	0.14	49%	0.00	0.02	43%	0.30	0.12	2	1	0.25			0.00	0.00
NC	1130	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020	Data Centers		2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC NC	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Data Centers Data Centers		2054	0.01	0.00	0.00	0.00	7% 17%	0.00	0.00	6% 16%	0.03	0.03	0	0	2.41 1.85			0.00	0.00
NC	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Data Centers	2020	2054	0.00	0.00	0.00	0.00	28%	0.00	0.00	26%	0.07	0.05	Ō	Ō	0.89			0.00	0.00
NC NC	1130 1130	1134 ROB 2L4' LED Tube, 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Data Centers Data Centers		2054 2054	0.00	0.00	0.00	0.00	31% 37%	0.00	0.00	30% 31%	0.27 0.16	0.07 0.09	2	0	0.28 0.35			0.00	0.00
NC NC	1130	1137 Occupancy Sensor, 2L4 Fluorescent Fixtures, 2020 1135 LED Troffer (base 2L4T8), 2020	Data Centers Data Centers		2054	0.00	0.00	0.00	0.00	37% 42%	0.00	0.00	37%	0.16	0.09	2	1	0.35			0.00	0.00
NC	1200	1200 Base Other Fluorescent Fixture	Data Centers	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC NC	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Data Centers Data Centers		2054 2054	0.01	0.00	0.00	0.00	7% 17%	0.00	0.00	6% 16%	0.04 0.11	0.04	0 1	0	1.94 0.58			0.00	0.00
NC	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Data Centers	2014	2054	0.01	0.00	0.00	0.00	28%	0.00	0.00	19%	0.15	0.11	3	1	0.37			0.00	0.00
NC NC	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Data Centers		2054	0.10	0.02	0.00	0.00	0% 83%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	0.10	0.02	0.00	0.00
NC NC	1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Data Centers Data Centers		2054 2054	0.02	0.00	0.08	0.08	0%	0.01	0.01 0.00	83% 0%	0.01 N/A	0.01 N/A	N/A	N/A	8.13 N/A	0.04	0.01	0.08	0.01 0.00
NC	1430	1432 LEDs (base incandescent A-line 72W) 2020	Data Centers	2020	2054	0.01	0.00	0.03	0.03	82%	0.01	0.01	82%	0.01	0.01	0	0	6.86			0.03	0.01
NC NC	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Data Centers Data Centers		2054	0.03	0.00	0.00	0.00	0% 75%	0.00	0.00	0% 75%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.12	0.03	0.00	0.00 0.02	0.00
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Data Centers	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Data Centers		2054	0.01	0.00	0.01	0.01	28%	0.00	0.00	28%	0.07	0.07	0	0	0.83	0.00	0.00	0.00	0.00
NC NC	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Data Centers Data Centers		2054 2054	0.03	0.00	0.00 0.01	0.00 0.01	0% 26%	0.00	0.00	0% 26%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.11	0.03	0.00	0.00 0.01	0.00
NC	1800	1800 BaseMetal Halide, 465W	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Data Centers Data Centers		2054 2054	0.01	0.00	0.00	0.00	0% 44%	0.00	0.00	0% 44%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.78	0.01	0.00	0.00	0.00
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Data Centers		2054	0.08	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.08	0.00	0.00	0.00
NC	1900	1902 LED Outdoor Area Lighting	Data Centers		2054	0.04	0.00	0.04	0.04	52%	0.00	0.00	52%	0.11	0.11	10	10	0.63			0.00	0.00
NC NC	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Data Centers Data Centers		2054 2054	0.03	0.00 0.16	0.01 0.00	0.05 0.00	66% 0%	0.00	0.00	65% 0%	0.72 N/A	0.24 N/A	70 N/A	22 N/A	0.09 N/A	0.66	0.16	0.00	0.00
NC	2000	2010 Ceiling/roof Insulation - Chiller	Data Centers	2014	2054	0.65	0.16	0.00	0.00	0%	0.00	0.00	0%	0.00	0.00	0	0	22.49	0.00	0.10	0.00	0.00
NC NC	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2006 VSD for Chiller Pumps and Towers	Data Centers Data Centers		2054	0.60 0.59	0.15	0.06	0.06	9% 10%	0.01 0.00	0.01 0.01	9% 9%	0.02	0.02 0.02	0	0	5.12 3.78			0.06	0.01
NC	2000	2013 High Efficiency Chiller Motors	Data Centers		2054	0.59	0.15	0.00	0.06	10%	0.00	0.01	9%	0.02	0.02	0	0	3.76			0.00	0.00
NC	2000	2003 EMS - Chiller	Data Centers	2014	2054	0.58	0.15	0.02	0.08	12%	0.00	0.02	10%	0.03	0.02	0	0	2.55			0.02	0.00
NC NC	2000 2000	2008 New Economizer - Chiller 2002 Window Film (Standard) - Chiller	Data Centers Data Centers		2054 2054	0.54 0.54	0.14 0.14	0.04 0.00	0.12 0.12	18% 18%	0.00	0.02 0.02	11% 11%	0.03 0.05	0.02 0.02	1	0	1.99 1.32			0.04	0.00
NC	2000	2012 Duct Testing/Sealing	Data Centers	2014	2054	0.43	0.12	0.10	0.22	34%	0.03	0.04	27%	0.09	0.05	0	0	0.94			0.00	0.00
NC	2000	2004 Cool Roof - Chiller	Data Centers	2014	2054	0.43	0.12	0.00	0.22	34%	0.00	0.04	27%	0.14	0.05	1	0	0.53			0.00	0.00
NC NC	2000 2100	2011 Duct/Pipe Insulation - Chiller 2100 Base DX Packaged System, EER=10.3, 10 tons	Data Centers Data Centers		2054 2054	0.43	0.12	0.00	0.23	34% 0%	0.00	0.04	27% 0%	1.13 N/A	0.06 N/A	5 N/A	0 N/A	0.06 N/A	0.37	0.09	0.00	0.00
NC	2100	2102 DX Packaged System, EER=13.4, 10 tons	Data Centers	2014	2054	0.29	0.07	0.09	0.09	23%	0.02	0.02	23%	0.01	0.01	0	0	5.45			0.09	0.02
NC NC	2100 2100	2111 Economizer Repair - DX 2108 Optimize Controls - DX	Data Centers Data Centers		2054 2054	0.28	0.07	0.00 0.01	0.09 0.10	24% 26%	0.00	0.02 0.02	25% 25%	0.04 0.03	0.02 0.02	0 1	0	1.68 1.65			0.00 0.01	0.00
NC	2100	2109 Economizer - DX	Data Centers		2054	0.24	0.07	0.03	0.13	35%	0.00	0.03	28%	0.04	0.02	1	0	1.45			0.01	0.00
NC	2100	2115 Window Film (Standard) - DX	Data Centers		2054	0.24	0.07	0.01	0.13	36%	0.00	0.03	29%	0.07	0.02	0	0	1.03			0.01	0.00
NC	2100	2106 Prog. Thermostat - DX	Data Centers	2014	2054	0.23	0.06	0.01	0.15	39%	0.00	0.03	30%	0.06	0.03	1	0	1.01			0.01	0.00

DNV GL H-35 1/5/2015

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	ige			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm NC	Number 2100	Number Measure 2112 Aerosol Duct Sealing - DX	Type Data Centers	Year 2014	Year 2054	0.21	MW 0.06	Savings 0.01	0.16	Savings 43%	Savings 0.00	0.03	Savings 33%	\$/kWH 0.12	\$/kWH 0.04	\$/kW 0	\$/kW	0.70	GWH	MW	0.00	0.00
NC	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Data Centers	2014	2054	0.21	0.06	0.00	0.16	43%	0.00	0.03	33%	0.12	0.04	2	0	0.51			0.00	0.00
NC	2100 2100	2107 Cool Roof - DX	Data Centers	2014	2054 2054	0.21	0.06	0.00	0.16 0.16	43% 44%	0.00	0.03	34%	0.16	0.04	1 5	0	0.45			0.00	0.00
NC NC	2100 2200	2114 Duct/Pipe Insulation - DX 2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Data Centers Data Centers		2054	0.21	0.06	0.00	0.16	44% 0%	0.00	0.03	34% 0%	1.32 N/A	0.05 N/A	N/A	N/A	0.05 N/A	0.05	0.01	0.00	0.00
NC	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Data Centers	2014	2054	0.04	0.01	0.01	0.01	12%	0.00	0.00	12%	0.01	0.01	0	0	7.64			0.01	0.00
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	Data Centers Data Centers	2014 2014	2054 2054	0.10	0.02	0.00	0.00	0% 2%	0.00	0.00	0% 2%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 5.03	0.10	0.02	0.00	0.00
NC	3000	3002 Variable Speed Drive Control, 5 HP	Data Centers		2054	0.07	0.02	0.02	0.02	26%	0.00	0.00	8%	0.01	0.01	0	0	4.84			0.02	0.00
NC	3000	3003 Demand Controlled Ventilation	Data Centers	2014	2054	0.07	0.02	0.00	0.03	30%	0.00	0.00	15%	0.55	0.09	1	1	0.18	0.00	0.00	0.00	0.00
NC NC	3100 3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3102 Variable Speed Drive Control, 15 HP	Data Centers Data Centers	2014	2054 2054	0.33	0.08	0.00	0.00	0% 24%	0.00	0.00	0% 6%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 17.82	0.33	80.0	0.00	0.00
NC	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Data Centers	2014	2054	0.25	0.08	0.00	0.08	25%	0.00	0.01	7%	0.01	0.00	0	ō	8.36			0.00	0.00
NC	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Data Centers	2014 2014	2054 2054	0.23	0.07	0.02	0.10 0.12	30% 36%	0.00	0.01	11% 13%	0.02	0.01 0.01	0	0	3.68			0.02 0.02	0.00
NC NC	3100	3103 Air Handler Optimization, 15 HP 3105 Energy Recovery Ventilation (ERV)	Data Centers Data Centers		2054	0.21	0.07	0.02	0.12	38%	0.00	0.01 0.01	16%	0.02	0.01	0	0	2.93 0.51			0.02	0.00
NC	3100	3107 Demand Controlled Ventilation	Data Centers	2014	2054	0.20	0.06	0.01	0.14	42%	0.01	0.02	22%	0.65	0.07	1	1	0.15			0.00	0.00
NC	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Data Centers	2014	2054	0.36	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.36	0.09	0.00	0.00
NC NC	3200 3200	3203 Air Handler Optimization, 40 HP 3202 Variable Speed Drive Control, 40 HP	Data Centers Data Centers	2014	2054 2054	0.32	0.09	0.03	0.03 0.11	9% 32%	0.00	0.00 0.01	2% 8%	0.01 0.02	0.01 0.02	0	0	4.17 3.20			0.03	0.00
NC	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	Data Centers	2014	2054	0.24	0.08	0.00	0.11	32%	0.00	0.01	8%	0.02	0.02	0	0	0.94			0.00	0.00
NC	3200	3204 Demand Controlled Ventilation	Data Centers	2014	2054	0.23	0.07	0.01	0.13	36%	0.01	0.01	15%	0.60	0.08	1	1	0.16			0.00	0.00
NC NC	4000 4100	4000 Base Built-Up Refrigeration System 4100 Base Self-Contained Refrigeration	Data Centers Data Centers	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	4100	4104 Base Self-Contained Reinigeration 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Data Centers	2014	2054	0.07	0.01	0.00	0.00	2%	0.00	0.00	2%	0.00	0.00	0	0	22.67	0.07	0.01	0.00	0.00
NC	5000	5000 Base Desktop PC	Data Centers		2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	Data Centers		2054	0.01	0.00	0.01	0.01	44%	0.00	0.00	23%	0.02	0.02	0	0	3.22			0.01	0.00
NC NC	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	Data Centers Data Centers		2054 2054	0.01	0.00	0.00	0.01 0.00	56% 0%	0.00	0.00	35% 0%	0.03 N/A	0.02 N/A	0 N/A	0 N/A	1.78 N/A	0.00	0.00	0.00	0.00
NC	5100	5102 Energy Star or Better Laptop	Data Centers		2054	0.00	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	4.64	0.00	0.00	0.00	0.00
NC	5100	5101 Laptop Network Power Management Enabling	Data Centers		2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	1.46	0.13	8	1	0.04			0.00	0.00
NC NC	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Data Centers Data Centers	2014	2054 2054	0.01	0.00	0.00	0.00 0.01	0% 43%	0.00	0.00	0% 43%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 48.34	0.01	0.00	0.00 0.01	0.00
NC	5200	5202 Monitor Power Management Enabling - CRT	Data Centers		2054	0.01	0.00	0.00	0.01	50%	0.00	0.00	46%	0.01	0.00	0	0	3.75			0.00	0.00
NC	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Data Centers		2054	0.01	0.00	0.00	0.01	54%	0.00	0.00	50%	0.16	0.01	1	0	0.35			0.00	0.00
NC NC	5300 5300	5300 Base Monitor, LCD	Data Centers Data Centers	2014	2054 2054	0.01	0.00	0.00	0.00	0% 13%	0.00	0.00	0% 13%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.42	0.01	0.00	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Data Centers	2014	2054	0.00	0.00	0.00	0.00	19%	0.00	0.00	16%	0.01	0.01	1	0	0.40			0.00	0.00
NC	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Data Centers	2014	2054	0.00	0.00	0.00	0.00	25%	0.00	0.00	18%	0.37	0.12	8	1	0.13			0.00	0.00
NC NC	5400 5400	5400 Base Copier	Data Centers		2054 2054	0.02	0.00	0.00	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 29.08	0.02	0.00	0.00	0.00
NC NC	5400 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	Data Centers Data Centers	2014 2014	2054	0.02	0.00	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	1	0	0.49			0.00	0.00
NC	5500	5500 Base Multifunction	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	5500	5502 ENERGY STAR Multi-Function Device	Data Centers	2014	2054	0.00	0.00	0.00	0.00	25%	0.00	0.00	25%	0.01	0.01	0	0	7.88			0.00	0.00
NC NC	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Data Centers Data Centers		2054 2054	0.00	0.00	0.00	0.00	38% 0%	0.00	0.00	32% 0%	0.32 N/A	0.11 N/A	4 N/A	1 N/A	0.16 N/A	0.00	0.00	0.00	0.00
NC	5700	5700 Base Data Center/Server Room	Data Centers		2054	18.10	3.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.10	3.15	0.00	0.00
NC	5700	5701 Data Center Improved Operations	Data Centers		2054	16.29	2.83	1.81	1.81	10%	0.31	0.31	10%	0.00	0.00	0	0	129.50			1.81	0.31
NC NC	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Data Centers Data Centers	2014	2054 2054	14.22 13.42	2.47	2.07 0.80	3.88 4.68	21% 26%	0.36	0.68	21% 26%	0.00	0.00	0	0	52.72 27.34			2.07 0.80	0.36
NC	6000	6000 Base Water Heating	Data Centers	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	6000	6007 Heat Trap	Data Centers		2054	0.01	0.00	0.00	0.00	5%	0.00	0.00	5%	0.04	0.04	0	0	1.59			0.00	0.00
NC NC	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Data Centers Data Centers	2014 2014	2054 2054	0.01	0.00	0.00	0.00	7% 14%	0.00	0.00	7% 14%	0.09 0.13	0.05 0.09	1	0	0.86 0.61			0.00	0.00
NC NC	6000	6008 Solar Water Heater	Data Centers Data Centers		2054	0.01	0.00	0.00	0.00	60%	0.00	0.00	60%	0.13	0.09	1	1	0.52			0.00	0.00
NC	6000	6003 Hot Water Pipe Insulation	Data Centers	2014	2054	0.01	0.00	0.00	0.01	60%	0.00	0.00	60%	0.34	0.14	2	1	0.22			0.00	0.00
NC NC	6000 6000	6006 Heat Recovery Unit	Data Centers Data Centers	2014 2014	2054 2054	0.01	0.00	0.00	0.01	63% 64%	0.00	0.00	63% 64%	0.35	0.15 0.17	2 6	1	0.19			0.00	0.00
NC	7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Data Centers Data Centers		2054	0.01	0.00	0.00	0.01	0%	0.00	0.00	0%	1.05 N/A	0.17 N/A	N/A	N/A	0.07 N/A	0.00	0.00	0.00	0.00
NC	7100	7100 Base Non-Refrigerated Vending Machines	Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	7200	7200 Base Oven	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7300 7400	7300 Base Fryer 7400 Base Steamer	Data Centers Data Centers		2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Data Centers		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	8100	8100 Base Heating, Other Electric	Data Centers	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC NC	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Data Centers Data Centers		2054 2054	0.09	0.01	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	0.09	0.01	0.00	0.00
NC NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	eligious Worsh		2054	0.09	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	0.79	0.13	0.00	0.00
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	eligious Worsh	2020	2054	0.71	0.12	0.08	0.08	10%	0.01	0.01	10%	0.05	0.05	0	0	1.36			0.08	0.01
NC	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	eligious Worsh		2054	0.71	0.12	0.00	0.08	10%	0.00	0.01	10%	0.05	0.05	1	0	0.96			0.00	0.00
NC NC	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	eligious Worsh eligious Worsh		2054 2054	0.66 0.57	0.11 0.10	0.05 0.08	0.14 0.22	17% 28%	0.01 0.01	0.02 0.04	16% 26%	0.08 0.11	0.06 0.08	1	0 1	0.87 0.60			0.00	0.00
NC	1030		eligious Worsh		2054	0.48	0.08	0.09	0.31	39%	0.02	0.05	38%	0.70	0.26	4	2	0.11			0.00	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ge			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Cam	Base Number	Measure Number Measure	Building Type	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base	Economic GWH	Economic MW
NC	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	eligious Worsh	2020	2054	0.47	0.08	0.01	0.33	41%	0.00	0.05	38%	0.35	0.27	8	2	0.16	GWII	IAIAA	0.00	0.00
NC	1030	1035 LED Troffer (base 4L4'T8), 2020	eligious Worsh	2020	2054	0.43	0.08	0.04	0.37	46%	0.01	0.06	43%	0.60	0.30	4	2	0.13			0.00	0.00
NC NC	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	eligious Worsh eligious Worsh		2054	0.61	0.10	0.00	0.00	0% 9%	0.00	0.00	0% 9%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.09	0.61	0.10	0.00	0.00
NC	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	eligious Worsh		2054	0.55	0.09	0.00	0.06	9%	0.00	0.01	9%	0.07	0.06	1	0	0.79			0.00	0.00
NC	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	eligious Worsh		2054	0.51	0.09	0.04	0.10	16% 27%	0.01	0.02	15%	0.10	0.08	1	1	0.71			0.00	0.00
NC NC	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	eligious Worsh eligious Worsh	2020	2054	0.44	0.08	0.06	0.16	30%	0.01 0.00	0.03	26% 29%	0.14	0.10	3	1	0.48			0.00	0.00
NC	1130	1135 LED Troffer (base 2L4'T8), 2020	eligious Worsh	2020	2054	0.39	0.07	0.04	0.22	36%	0.01	0.04	35%	0.72	0.25	4	2	0.11			0.00	0.00
NC NC	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	eligious Worsh		2054 2054	0.37	0.07	0.01 0.00	0.23	38% 0%	0.00	0.04	35% 0%	0.59 N/A	0.26 N/A	14 N/A	2 N/A	0.09 N/A	0.01	0.00	0.00	0.00
NC	1200	1200 base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	eligious Worsh eligious Worsh		2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	0.04	0.04	0	0	1.38	0.01	0.00	0.00	0.00
NC	1200	1201 ROB High Performance T8 (base other fluorescent)	eligious Worsh	2014	2054	0.01	0.00	0.00	0.00	8%	0.00	0.00	8%	0.20	0.20	1	1	0.35			0.00	0.00
NC NC	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	eligious Worsh eligious Worsh		2054 2054	0.01	0.00	0.00	0.00	25% 31%	0.00	0.00	24% 26%	0.43 0.39	0.35 0.36	3 9	2	0.17 0.14			0.00	0.00
NC	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	eligious Worsh		2054	1.41	0.00	0.00	0.00	0%	0.00	0.00	0%	0.39 N/A	N/A	N/A	N/A	0.14 N/A	1.41	0.24	0.00	0.00
NC	1330	1332 LEDs (base incandescent flood) 2020	eligious Worsh	2020	2054	0.24	0.04	1.17	1.17	83%	0.20	0.20	83%	0.02	0.02	0	0	4.47			1.17	0.20
NC NC	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	eligious Worsh eligious Worsh		2054 2054	0.51	0.09	0.00 0.41	0.00 0.41	0% 82%	0.00 0.07	0.00 0.07	0% 82%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.78	0.51	0.09	0.00 0.41	0.00 0.07
NC	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	eligious Worsh		2054	0.03	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.37	0.06	0.00	0.00
NC	1530	1532 LEDs (base incandescent A-line 53W) 2020	eligious Worsh		2054	0.10	0.02	0.28	0.28	75%	0.05	0.05	75%	0.02	0.02	0	0	2.82			0.28	0.05
NC NC	1630 1630	1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	eligious Worsh eligious Worsh	2020 2020	2054 2054	0.35 0.25	0.06	0.00 0.10	0.00 0.10	0% 28%	0.00 0.02	0.00 0.02	0% 28%	N/A 0.15	N/A 0.15	N/A 1	N/A 1	N/A 0.46	0.35	0.06	0.00	0.00
NC	1730	1730 Base CFL 23W to screw-in replacement 2020	eligious Worsh		2054	0.44	0.04	0.00	0.00	0%	0.02	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.44	0.08	0.00	0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	eligious Worsh		2054	0.33	0.06	0.12	0.12	26%	0.02	0.02	26%	0.11	0.11	1	1	0.61			0.00	0.00
NC NC	1800 1800	1800 BaseMetal Halide, 465W 1801 T5 (240W) (base metal halide)	eligious Worsh eligious Worsh		2054 2054	1.77 1.17	0.30	0.00	0.00	0% 34%	0.00	0.00	0% 34%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.24	1.77	0.30	0.00	0.00
NC	1800	1806 Occupancy Sensor, High Bay T5	eligious Worsh		2054	1.13	0.20	0.04	0.64	36%	0.00	0.10	34%	0.03	0.03	2	0	0.60			0.00	0.00
NC	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	eligious Worsh	2014	2054	1.05	0.19	0.09	0.72	41%	0.01	0.11	38%	0.17	0.05	.1	0	0.41			0.00	0.00
NC NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	eligious Worsh eligious Worsh		2054 2054	0.04	0.01	0.00 0.02	0.00 0.02	0% 46%	0.00	0.00	0% 46%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 0.92	0.04	0.01	0.00	0.00
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	eligious Worsh		2054	0.56	0.04	0.02	0.02	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.56	0.04	0.00	0.00
NC	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	eligious Worsh		2054	0.50	0.03	0.05	0.05	10%	0.01	0.01	28%	0.09	0.09	0	0	0.99			0.00	0.00
NC NC	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	eligious Worsh eligious Worsh		2054 2054	0.24	0.01	0.26 0.07	0.32	57% 69%	0.02	0.03 0.04	75% 86%	0.22 1.41	0.19 0.42	3 20	2	0.32 0.05			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	eligious Worsh	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	eligious Worsh		2054	4.00	3.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.00	3.10	0.00	0.00
NC NC	2100 2100	2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	eligious Worsh eligious Worsh		2054 2054	4.00 3.08	3.10 2.38	0.00 0.92	0.00 0.92	0% 23%	0.00 0.71	0.00 0.71	0% 23%	0.05	0.05 0.08	0	0	2.77 1.47			0.00 0.92	0.00 0.71
NC	2100	2112 Aerosol Duct Sealing - DX	eligious Worsh	2014	2054	2.90	2.24	0.18	1.10	28%	0.14	0.85	28%	0.51	0.15	1	0	0.24			0.00	0.00
NC	2100	2106 Prog. Thermostat - DX	eligious Worsh		2054	2.83	2.23	0.07	1.17	29%	0.01	0.87	28%	0.29	0.16	1	0	0.21			0.00	0.00
NC NC	2100 2100	2108 Optimize Controls - DX 2115 Window Film (Standard) - DX	eligious Worsh eligious Worsh		2054 2054	2.79 2.78	2.22	0.05 0.01	1.21 1.23	30% 31%	0.01 0.01	0.87 0.88	28% 29%	0.30 1.43	0.16 0.18	2	0	0.18 0.07			0.00	0.00
NC	2100	2107 Cool Roof - DX	eligious Worsh		2054	2.77	2.21	0.01	1.23	31%	0.00	0.89	29%	7.28	0.21	9	0	0.01			0.00	0.00
NC	2100	2114 Duct/Pipe Insulation - DX	eligious Worsh		2054	2.75	2.19	0.02	1.25	31%	0.01	0.90	29%	8.70	0.33	11	0	0.01			0.00	0.00
NC NC	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	eligious Worsh eligious Worsh		2054 2054	3.33 2.92	2.57 2.26	0.00 0.41	0.00 0.41	0% 12%	0.00 0.32	0.00 0.32	0% 12%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 1.37	3.33	2.57	0.00 0.41	0.00 0.32
NC	2300	2300 Base PTAC, EER=8.3, 1 ton	eligious Worsh	2014	2054	0.06	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.04	0.00	0.00
NC NC	2300 2300	2301 HE PTAC, EER=9.6, 1 ton 2302 Occupancy Sensor (hotels)	eligious Worsh eligious Worsh	2014 2014	2054 2054	0.05	0.04	0.01 0.01	0.01 0.02	14% 27%	0.01 0.01	0.01 0.01	14% 30%	0.20 0.63	0.20 0.41	0	0	0.60 0.18			0.00	0.00
NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	eligious Worsh		2054	1.61	0.03	0.00	0.02	0%	0.00	0.00	0%	0.63 N/A	0.41 N/A	N/A	N/A	0.16 N/A	1.61	0.46	0.00	0.00
NC	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	eligious Worsh	2014	2054	1.59	0.45	0.03	0.03	2%	0.01	0.01	2%	0.15	0.15	1	1	0.59			0.00	0.00
NC	3000 3000	3002 Variable Speed Drive Control, 5 HP	eligious Worsh		2054	1.11	0.42	0.48	0.51	31%	0.03	0.04	9%	0.12	0.12	2	1	0.56			0.00	0.00
NC NC	3000	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	eligious Worsh eligious Worsh		2054 2054	1.09 1.29	0.41	0.02 0.00	0.53 0.00	33% 0%	0.01 0.00	0.05 0.00	12% 0%	3.72 N/A	0.27 N/A	N/A	N/A	0.03 N/A	1.29	0.37	0.00	0.00
NC	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	eligious Worsh	2014	2054	1.10	0.32	0.19	0.19	14%	0.05	0.05	13%	0.07	0.07	0	0	1.12	-		0.19	0.05
NC NC	3100 3100	3103 Air Handler Optimization, 15 HP	eligious Worsh		2054 2054	1.03	0.31	0.08 0.31	0.26 0.57	20% 44%	0.01	0.05 0.07	14% 20%	0.09 0.16	0.08 0.12	1 2	0	0.59 0.41			0.00	0.00
NC	3100	3102 Variable Speed Drive Control, 15 HP 3101 Fan Motor, 15hp, 1800rpm, 92.4%	eligious Worsh eligious Worsh		2054	0.72	0.29	0.01	0.57	45%	0.02	0.07	21%	0.16	0.12	2	1	0.41			0.00	0.00
NC	3100	3105 Energy Recovery Ventilation (ERV)	eligious Worsh		2054	0.70	0.28	0.01	0.59	46%	0.00	0.08	23%	1.04	0.14	2	1	0.11			0.00	0.00
NC	3100 3200	3107 Demand Controlled Ventilation	eligious Worsh		2054 2054	0.68	0.28	0.01 0.00	0.60	47% 0%	0.01	0.09	25% 0%	4.72 N/A	0.25 N/A	9	2	0.02 N/A	1.00	0.20	0.00	0.00
NC NC	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	eligious Worsh eligious Worsh		2054	1.02 0.95	0.29	0.00	0.00	0% 7%	0.00	0.00	0% 2%	N/A 0.08	0.08	N/A 1	N/A 1	N/A 0.69	1.02	0.29	0.00	0.00
NC	3200	3202 Variable Speed Drive Control, 40 HP	eligious Worsh	2014	2054	0.67	0.27	0.29	0.36	35%	0.02	0.03	9%	0.25	0.22	4	3	0.26			0.00	0.00
NC NC	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	eligious Worsh		2054 2054	0.66 0.65	0.26	0.00	0.36	35% 36%	0.00	0.03	9% 11%	1.22 3.94	0.22	4	3 4	0.07			0.00	0.00
NC NC	3200 4000	4000 Base Built-Up Refrigeration System	eligious Worsh eligious Worsh		2054	0.65	0.26	0.01	0.37	36% 0%	0.01	0.03	11% 0%	3.94 N/A	0.35 N/A	N/A	4 N/A	0.03 N/A	0.00	0.00	0.00	0.00
NC	4100	4100 Base Self-Contained Refrigeration	eligious Worsh	2014	2054	2.27	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.27	0.34	0.00	0.00
NC	4100		eligious Worsh		2054	2.24	0.34	0.03	0.03	1%	0.00	0.00	1%	0.00	0.00	0	0	15.89			0.03	0.00
NC NC	4100 5000	4110 Energy Star Ice Machines 5000 Base Desktop PC	eligious Worsh eligious Worsh		2054 2054	2.23 0.96	0.34 0.15	0.01 0.00	0.04	2% 0%	0.00	0.01 0.00	2% 0%	0.03 N/A	0.01 N/A	0 N/A	0 N/A	1.96 N/A	0.96	0.15	0.01 0.00	0.00
NC	5000	5001 PC Network Power Management Enabling	eligious Worsh	2014	2054	0.53	0.11	0.43	0.43	45%	0.03	0.03	23%	0.03	0.03	0	0	1.75		2.10	0.43	0.03
NC	5000	5002 Energy Star or Better PC	eligious Worsh		2054	0.36	0.09	0.17	0.60	62%	0.03	0.06	40%	0.06	0.04	0	0	0.89	0.00	0.00	0.00	0.00
NC	5100	5100 Base Laptop PC	eligious Worsh	∠014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS													SUPPLY							
Vint	age			Measure	Measure	,			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Cam	Base It Number	Measure Number Measure	Building Type	Start	End Year	Total GWH	Total MW	GWH Savings	Savings	GWH	MW Savings	Savings MW	MW	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic MW
NC	5100	5102 Energy Star or Better Laptop	eligious Worsh	2014	2054	0.02	0.00	0.00	GWH 0.00	Savings 19%	0.00	0.00	Savings 19%	0.02	0.02	0	0	2.42	GWH	IVIVV	0.00	0.00
NC NC	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	eligious Worsh eligious Worsh		2054 2054	0.02	0.00	0.00	0.00	21% 0%	0.00	0.00	21% 0%	2.69 N/A	0.24 N/A	18 N/A	2 N/A	0.02 N/A	0.26	0.04	0.00	0.00
NC	5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	eligious Worsh		2054	0.26	0.04	0.14	0.14	56%	0.00	0.00	56%	0.00	0.00	0	0	19.31	0.26	0.04	0.14	0.00
NC	5200	5202 Monitor Power Management Enabling - CRT	eligious Worsh		2054	0.08	0.01	0.03	0.17	67%	0.00	0.02	62%	0.04	0.01	1	0	1.26			0.03	0.00
NC NC	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	eligious Worsh eligious Worsh		2054 2054	0.08	0.01	0.01	0.18	70% 0%	0.00	0.02	64% 0%	0.46 N/A	0.03 N/A	N/A	N/A	0.12 N/A	0.05	0.01	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	eligious Worsh	2014	2054	0.04	0.01	0.01	0.01	18%	0.00	0.00	18%	0.03	0.03	0	0	2.18			0.01	0.00
NC NC	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	eligious Worsh eligious Worsh		2054 2054	0.04	0.01	0.00	0.01 0.01	21% 27%	0.00	0.00	19% 21%	0.23 0.66	0.05 0.19	3 17	0 2	0.22 0.07			0.00	0.00
NC	5400	5400 Base Copier	eligious Worsh	2014	2054	1.02	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.02	0.15	0.00	0.00
NC NC	5400 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	eligious Worsh eligious Worsh		2054 2054	0.88	0.13 0.13	0.14 0.04	0.14 0.18	13% 18%	0.02	0.02	13% 16%	0.00 0.21	0.00 0.05	0	0	14.64 0.26			0.14	0.02
NC	5500	5500 Base Multifunction	eligious Worsh		2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC NC	5500 5500	5502 ENERGY STAR Multi-Function Device	eligious Worsh		2054 2054	0.02	0.00	0.01	0.01	25% 37%	0.00	0.00	25% 31%	0.01	0.01	0 7	0	4.12 0.09			0.01	0.00
NC	5600	5501 Multifunction Power Management Enabling 5600 Base Printer	eligious Worsh eligious Worsh		2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	0.56 N/A	0.19 N/A	N/A	N/A	N/A	0.03	0.01	0.00	0.00
NC	5600 5600	5602 ENERGY STAR Printer	eligious Worsh		2054	0.02	0.00	0.01	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	18.95			0.01	0.00
NC NC	5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	eligious Worsh eligious Worsh		2054 2054	0.02	0.00	0.00	0.02	45% 0%	0.00	0.00	40% 0%	0.12 N/A	0.03 N/A	2 N/A	0 N/A	0.42 N/A	0.08	0.01	0.00	0.00
NC	5700	5701 Data Center Improved Operations	eligious Worsh	2014	2054	0.08	0.01	0.01	0.01	10%	0.00	0.00	10%	0.00	0.00	0	0	67.63			0.01	0.00
NC NC	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	eligious Worsh eligious Worsh		2054 2054	0.07	0.01 0.01	0.01 0.00	0.02	21% 26%	0.00	0.00	21% 26%	0.00	0.00	0	0	27.53 14.28			0.01 0.00	0.00
NC	6000	6000 Base Water Heating	eligious Worsh	2014	2054	0.37	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.37	0.06	0.00	0.00
NC NC	6000 6000	6007 Heat Trap	eligious Worsh		2054 2054	0.35 0.35	0.05	0.02	0.02	5% 7%	0.00	0.00	5% 7%	0.03	0.03 0.04	0	0	1.87 1.00			0.02 0.01	0.00
NC	6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	eligious Worsh eligious Worsh		2054	0.32	0.05	0.01	0.05	14%	0.00	0.00	14%	0.07	0.04	1	1	0.72			0.00	0.00
NC	6000	6003 Hot Water Pipe Insulation	eligious Worsh	2014	2054	0.31	0.05	0.01	0.06	16%	0.00	0.01	16%	0.13	0.08	1	1	0.55			0.00	0.00
NC NC	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	eligious Worsh eligious Worsh		2054 2054	0.30	0.04	0.01 0.01	0.07	18% 22%	0.00	0.01 0.01	18% 22%	0.13 0.37	0.09 0.13	1 2	1	0.52 0.20			0.00	0.00
NC	7000	7000 Base Refrigerated Vending Machines	eligious Worsh	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7100 7200	7100 Base Non-Refrigerated Vending Machines 7200 Base Oven	eligious Worsh eligious Worsh	2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	7300	7300 Base Fryer	eligious Worsh		2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	7400 8000	7400 Base Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	eligious Worsh	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00	0.00
NC	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	eligious Worsh eligious Worsh		2054	0.13	0.00	0.00	0.00	6%	0.00	0.00	0%	0.07	0.07	N/A	N/A	0.91	0.13	0.00	0.00	0.00
NC	8100	8100 Base Heating, Other Electric	eligious Worsh	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	9500 9500	9500 Base Miscellaneous 9501 Xmisc	eligious Worsh eligious Worsh	2014	2054 2054	8.84 8.84	1.47 1.47	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	8.84	1.47	0.00	0.00
NC	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Misc	2020	2054	5.29	0.90	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.29	0.90	0.00	0.00
NC NC	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Misc Misc	2020 2020	2054 2054	5.29 4.89	0.90 0.84	0.00 0.40	0.00 0.40	0% 8%	0.00 0.05	0.00 0.05	0% 6%	0.01 0.02	0.01 0.02	0	0	4.07 3.66			0.00 0.40	0.00 0.05
NC	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Misc	2020	2054	4.38	0.76	0.51	0.91	17%	0.09	0.14	16%	0.02	0.02	0	0	3.05			0.51	0.09
NC NC	1030 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Misc Misc	2020 2020	2054 2054	3.82 3.71	0.66	0.56	1.46 1.58	28% 30%	0.09	0.23 0.24	26% 27%	0.04	0.03	0	0	1.46 0.72			0.56	0.09
NC	1030	1037 Occupancy Senson, 424 Fluorescent Fixtures, 2020	Misc	2020	2054	3.11	0.56	0.60	2.17	41%	0.10	0.34	38%	0.05	0.03	1	1	0.72			0.00	0.00
NC	1030	1035 LED Troffer (base 4L4'T8), 2020	Misc	2020	2054	2.85	0.51	0.27	2.44	46%	0.05	0.39	43%	0.20	0.10	1	1	0.34			0.00	0.00
NC NC	1130 1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1136 Lighting Control Tuneup (base 2L4'T8), 2020	Misc Misc	2020 2020	2054 2054	4.05 4.05	0.69 0.69	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.31	4.05	0.69	0.00	0.00
NC	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Misc	2020	2054	3.74	0.65	0.31	0.31	8%	0.04	0.04	6%	0.02	0.02	0	0	2.97			0.31	0.04
NC NC	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Misc Misc	2020 2020	2054 2054	3.39 2.96	0.59 0.51	0.35 0.43	0.66 1.09	16% 27%	0.06 0.07	0.10 0.17	15% 25%	0.02 0.05	0.02 0.04	0	0	2.43 1.17			0.35	0.06 0.07
NC	1130	1134 ROB 2L4' LED Tube, 2020	Misc	2020	2054	2.81	0.49	0.14	1.23	31%	0.02	0.20	29%	0.19	0.05	1	ō	0.36			0.00	0.00
NC NC	1130 1130	1135 LED Troffer (base 2L4'T8), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Misc Misc	2020 2020	2054 2054	2.57 2.50	0.45 0.44	0.24 0.07	1.47 1.55	36% 38%	0.04 0.00	0.24 0.24	35% 35%	0.24 0.15	0.08 0.09	1	1	0.29 0.36			0.00	0.00
NC	1200	1200 Base Other Fluorescent Fixture	Misc	2014	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00	0.00
NC	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Misc	2014	2054	0.06	0.01	0.00	0.00	0% 8%	0.00	0.00	0%	0.01	0.01	0	0	5.21			0.00	0.00
NC NC	1200 1200	1201 ROB High Performance T8 (base other fluorescent) 1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Misc Misc	2014 2014	2054 2054	0.05 0.05	0.01	0.00	0.00 0.01	15%	0.00	0.00	8% 13%	0.07 0.10	0.07 0.08	0 1	1	0.84 0.72			0.00	0.00
NC	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Misc	2014	2054	0.04	0.01	0.00	0.01	21%	0.00	0.00	15%	0.09	0.09	2	1	0.63			0.00	0.00
NC NC	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Misc Misc	2020 2020	2054 2054	24.26 4.12	4.12 0.70	0.00 20.13	0.00 20.13	0% 83%	0.00 3.42	0.00 3.42	0% 83%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 11.21	24.26	4.12	0.00 20.13	0.00 3.42
NC	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Misc	2020	2054	8.73	1.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.73	1.48	0.00	0.00
NC NC	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Misc Misc	2020 2020	2054 2054	1.62 6.43	0.27 1.09	7.12 0.00	7.12 0.00	82% 0%	1.21 0.00	1.21 0.00	82% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	9.46 N/A	6.43	1.09	7.12 0.00	1.21 0.00
NC	1530	1530 Base incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Misc	2020	2054	1.64	0.28	4.79	4.79	75%	0.81	0.81	75%	0.01	0.01	0	0	7.05	0.43		4.79	0.00
NC	1630	1630 Base CFL 18W to screw-in replacement 2020	Misc	2020	2054	0.78	0.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.78	0.13	0.00	0.00
NC NC	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Misc Misc	2020 2020	2054 2054	0.56 0.99	0.10 0.17	0.22	0.22	28% 0%	0.04	0.04 0.00	28% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.15 N/A	0.99	0.17	0.22	0.04 0.00
NC	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Misc	2020	2054	0.73	0.12	0.26	0.26	26%	0.04	0.04	26%	0.04	0.04	0	0	1.53			0.26	0.04
NC NC	1800 1800	1800 BaseMetal Halide, 465W 1801 T5 (240W) (base metal halide)	Misc Misc	2014 2014	2054 2054	3.54 2.34	0.60 0.40	0.00 1.20	0.00 1.20	0% 34%	0.00 0.20	0.00 0.20	0% 34%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.49	3.54	0.60	0.00 1.20	0.00 0.20
NC	1800	1806 Occupancy Sensor, High Bay T5	Misc	2014	2054	2.27	0.39	0.08	1.27	36%	0.00	0.21	34%	0.02	0.01	1	0	2.28			0.08	0.00

APPENDIX H

Base Avoided Costs

		ric Existing Construction DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vinta	ige			Measure	Measure	•			Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Sam	Base t Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base	Base MW	Economic GWH	Economic
NC	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Misc	2014	2054	2.09	0.37	0.17	1.44	41%	0.02	0.23	38%	0.05	0.01	0	0	1.56			0.17	0.02
NC NC	1850 1850	1850 Base CFL Exit Sign 1851 LED Exit Sign	Misc Misc	2014 2014	2054 2054	0.26 0.14	0.04	0.00 0.12	0.00 0.12	0% 46%	0.00 0.02	0.00 0.02	0% 46%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.16	0.26	0.04	0.00 0.12	0.00 0.02
NC	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Misc	2014	2054	1.53	0.12	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.53	0.12	0.00	0.00
NC NC	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Misc Misc	2014 2014	2054 2054	1.40 0.68	0.09	0.13 0.73	0.13 0.86	9% 56%	0.03	0.03	25% 72%	0.04	0.04 0.08	0	0	2.37 0.77			0.13	0.03
NC NC	1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Misc	2014	2054	0.68	0.03	0.73	1.06	69%	0.06	0.09	72% 84%	0.09	0.08	1 8	1 2	0.77			0.00	0.00
NC	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	2100 2100	2100 Base DX Packaged System, EER=10.3, 10 tons 2113 Ceiling/roof Insulation - DX	Misc Misc	2014 2014	2054 2054	3.24	2.51 2.51	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 6.63	3.24	2.51	0.00	0.00
NC NC	2100	2102 DX Packaged System, EER=13.4, 10 tons	Misc	2014	2054	2.49	1.93	0.00	0.00	23%	0.00	0.00	23%	0.02	0.02	0	0	3.51			0.00	0.00
NC	2100	2105 DX Tune Up/ Advanced Diagnostics	Misc	2014	2054	2.49	1.93	0.00	0.75	23%	0.00	0.58	23%	0.11	0.03	0	0	0.67			0.00	0.00
NC NC	2100 2100	2112 Aerosol Duct Sealing - DX 2106 Prog. Thermostat - DX	Misc Misc	2014 2014	2054 2054	2.35	1.82 1.81	0.15	0.89 0.94	28% 29%	0.11	0.69 0.70	28% 28%	0.21	0.06	0	0	0.58			0.00	0.00
NC	2100	2108 Optimize Controls - DX	Misc	2014	2054	2.26	1.80	0.04	0.94	30%	0.01	0.70	28%	0.12	0.07	1	0	0.51			0.00	0.00
NC	2100	2115 Window Film (Standard) - DX	Misc	2014	2054	2.25	1.79	0.01	0.98	30%	0.01	0.71	28%	0.59	0.07	1	0	0.17			0.00	0.00
NC NC	2100 2100	2107 Cool Roof - DX 2114 Duct/Pipe Insulation - DX	Misc Misc	2014	2054 2054	2.25	1.79 1.78	0.00	0.99 1.00	31% 31%	0.00	0.72	29% 29%	3.03 3.63	0.09	4 5	0	0.03			0.00	0.00
NC	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Misc	2014	2054	17.26	13.35	0.00	0.00	0%	0.00	0.73	0%	3.63 N/A	0.14 N/A	N/A	N/A	0.03 N/A	17.26	13.35	0.00	0.00
NC	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	2014	2054	15.13	11.70	2.14	2.14	12%	1.65	1.65	12%	0.04	0.04	0	0	3.28			2.14	1.65
NC NC	2300 2300	2300 Base PTAC, EER=8.3, 1 ton 2301 HE PTAC, EER=9.6, 1 ton	Misc Misc	2014 2014	2054 2054	4.26 3.69	3.30 2.85	0.00 0.58	0.00 0.58	0% 14%	0.00 0.45	0.00 0.45	0% 14%	N/A 0.08	N/A 0.08	N/A 0	N/A 0	N/A 1.43	4.26	3.30	0.00 0.58	0.00 0.45
NC	2300	2302 Occupancy Sensor (hotels)	Misc	2014	2054	3.13	2.29	0.55	1.13	27%	0.45	1.00	30%	0.06	0.03	0	0	0.43			0.00	0.00
NC	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Misc	2014	2054	9.78	2.78	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.78	2.78	0.00	0.00
NC NC	3000 3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3002 Variable Speed Drive Control, 5 HP	Misc Misc	2014 2014	2054 2054	9.61 6.72	2.73 2.53	0.17 2.89	0.17 3.06	2% 31%	0.05 0.20	0.05 0.25	2% 9%	0.06 0.05	0.06 0.05	0	0	1.40 1.33			0.17 2.89	0.05 0.20
NC	3000	3003 Demand Controlled Ventilation	Misc	2014	2054	6.59	2.45	0.13	3.19	33%	0.20	0.23	12%	1.56	0.03	3	i	0.07			0.00	0.00
NC	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Misc	2014	2054	7.79	2.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.79	2.21	0.00	0.00
NC NC	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Misc Misc	2014 2014	2054 2054	6.67 6.21	1.93 1.90	1.12 0.46	1.12 1.58	14% 20%	0.29	0.29 0.32	13% 14%	0.03 0.04	0.03	0	0	2.68 1.41			1.12 0.46	0.29
NC	3100	3102 Variable Speed Drive Control, 15 HP	Misc	2014	2054	4.34	1.76	1.87	3.45	44%	0.13	0.45	20%	0.07	0.05	1	ō	0.98			0.00	0.00
NC	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Misc	2014	2054	4.28	1.74	0.06	3.52	45%	0.02	0.47	21%	0.21	0.05	1	0	0.43			0.00	0.00
NC NC	3100 3100	3105 Energy Recovery Ventilation (ERV) 3107 Demand Controlled Ventilation	Misc Misc	2014 2014	2054 2054	4.22 4.14	1.71 1.67	0.05 0.08	3.57 3.65	46% 47%	0.03	0.50 0.55	23% 25%	0.43 1.97	0.06 0.10	1	0	0.26 0.05			0.00	0.00
NC	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Misc	2014	2054	6.19	1.76	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.19	1.76	0.00	0.00
NC	3200	3203 Air Handler Optimization, 40 HP	Misc	2014	2054	5.76	1.73	0.42	0.42	7%	0.03	0.03	2%	0.03	0.03	0	0	1.65			0.42	0.03
NC NC	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	Misc Misc	2014 2014	2054 2054	4.03 4.01	1.60 1.60	1.73	2.16	35% 35%	0.12	0.15 0.16	9% 9%	0.10 0.51	0.09	1 2	1	0.63			0.00	0.00
NC	3200	3204 Demand Controlled Ventilation	Misc	2014	2054	3.93	1.56	0.02	2.25	36%	0.04	0.20	11%	1.65	0.15	3	2	0.06			0.00	0.00
NC	4000	4000 Base Built-Up Refrigeration System	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC NC	4100 4100	4100 Base Self-Contained Refrigeration 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Misc Misc	2014 2014	2054 2054	10.36 10.21	1.56 1.54	0.00 0.15	0.00 0.15	0% 1%	0.00 0.02	0.00 0.02	0% 1%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 38.00	10.36	1.56	0.00 0.15	0.00 0.02
NC	4100	4108 Energy-Star Refrigerator, glass door	Misc	2014	2054	10.20	1.54	0.01	0.15	1%	0.00	0.02	1%	0.00	0.00	0	ō	12.86			0.01	0.00
NC	4100	4106 Energy-Star Refrigerator, solid door	Misc	2014	2054	10.19	1.53	0.01	0.17	2%	0.00	0.03	2%	0.01	0.00	0	0	12.69			0.01	0.00
NC NC	4100 4100	4110 Energy Star Ice Machines 4112 Reach-in unit occupancy sensors	Misc Misc	2014	2054 2054	10.17 10.17	1.53 1.53	0.02	0.18 0.18	2% 2%	0.00	0.03	2% 2%	0.01	0.00	0 2	0	4.68 0.24			0.02	0.00
NC	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Misc	2014	2054	10.17	1.53	0.00	0.18	2%	0.00	0.03	2%	0.30	0.00	2	Ō	0.20			0.00	0.00
NC	5000	5000 Base Desktop PC	Misc	2014	2054	0.72	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.72	0.11	0.00	0.00
NC NC	5000 5000	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	Misc Misc	2014 2014	2054 2054	0.40	0.08	0.33 0.12	0.33 0.45	45% 62%	0.03 0.02	0.03 0.04	23% 40%	0.01 0.03	0.01 0.02	0	0	4.18 2.12			0.33 0.12	0.03 0.02
NC	5100	5100 Base Laptop PC	Misc	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00	0.00
NC	5100	5102 Energy Star or Better Laptop	Misc	2014	2054	0.02	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	5.80			0.00	0.00
NC NC	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Misc Misc	2014 2014	2054 2054	0.02	0.00	0.00	0.01	21% 0%	0.00	0.00	21% 0%	1.13 N/A	0.10 N/A	N/A	N/A	0.05 N/A	0.24	0.04	0.00	0.00
NC	5200	5201 Energy Star or Better Monitor - CRT	Misc	2014	2054	0.11	0.02	0.13	0.13	56%	0.02	0.02	56%	0.00	0.00	0	0	46.17	0.21	0.01	0.13	0.02
NC	5200	5202 Monitor Power Management Enabling - CRT	Misc	2014	2054	0.08	0.01	0.03	0.16	67%	0.00	0.02	62%	0.02	0.00	0	0	3.02			0.03	0.00
NC NC	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Misc Misc	2014 2014	2054 2054	0.07	0.01	0.01 0.00	0.17	70% 0%	0.00	0.02	64% 0%	0.19 N/A	0.01 N/A	1 N/A	0 N/A	0.28 N/A	0.10	0.01	0.00	0.00
NC	5300	5301 Energy Star or Better Monitor - LCD	Misc	2014	2054	0.08	0.01	0.02	0.02	18%	0.00	0.00	18%	0.01	0.01	0	0	5.21			0.02	0.00
NC	5300 5300	5302 Monitor Power Management Enabling - LCD	Misc	2014 2014	2054	0.08	0.01	0.00	0.02	21% 27%	0.00	0.00	19% 21%	0.10 0.28	0.02	1 7	0	0.52			0.00	0.00
NC NC	5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Misc Misc	2014	2054 2054	0.07	0.01	0.01 0.00	0.03	0%	0.00	0.00	0%	0.28 N/A	0.08 N/A	N/A	N/A	0.17 N/A	0.23	0.04	0.00	0.00
NC	5400	5401 Energy Star or Better Copier	Misc	2014	2054	0.20	0.03	0.03	0.03	13%	0.00	0.00	13%	0.00	0.00	0	0	35.00			0.03	0.00
NC	5400	5402 Copier Power Management Enabling 5500 Base Multifunction	Misc	2014 2014	2054	0.19	0.03	0.01	0.04	18% 0%	0.00	0.01	16% 0%	0.09	0.02 N/A	1	0	0.61	0.02	0.00	0.00	0.00
NC NC	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Misc Misc	2014	2054 2054	0.02	0.00	0.00 0.01	0.00 0.01	0% 25%	0.00	0.00	0% 25%	N/A 0.01	0.01	N/A 0	N/A 0	N/A 9.86	0.02	0.00	0.00 0.01	0.00
NC	5500	5501 Multifunction Power Management Enabling	Misc	2014	2054	0.01	0.00	0.00	0.01	37%	0.00	0.00	31%	0.23	0.08	3	1	0.22			0.00	0.00
NC NC	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Misc	2014	2054 2054	0.16	0.02	0.00 0.06	0.00	0% 35%	0.00	0.00 0.01	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A	N/A 45.21	0.16	0.02	0.00	0.00
NC NC	5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Misc	2014	2054	0.10	0.02	0.06	0.06	35% 45%	0.01	0.01	35% 40%	0.00	0.00	1	0	45.31 1.02			0.06	0.01
NC	5700	5700 Base Data Center/Server Room	Misc	2014	2054	2.15	0.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.15	0.33	0.00	0.00
NC NC	5700 5700	5701 Data Center Improved Operations 5702 Data Center Best Practices	Misc Misc	2014 2014	2054 2054	1.94	0.29	0.22 0.25	0.22 0.46	10% 21%	0.03	0.03 0.07	10% 21%	0.00	0.00	0	0	117.62 47.88			0.22	0.03
NC NC	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Misc	2014	2054	1.69	0.26 0.24	0.25	0.46	21% 26%	0.04	0.07	21% 26%	0.00	0.00	0	0	47.88 24.83			0.25	0.04
	2.00															-	-					

APPENDIX H

Base Avoided Costs

		tric Existing Construction																				
		DITIVE SUPPLY ANALYSIS		Year	2020																SUPPLY	
Vint	ige			Measure					Total	B		Total	D	Marginal	Average	Marginal	Average	Total				
	_								Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity		_	_		
0	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgm		Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	
NC	6000		Misc	2014	2054	4.94	0.73	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.94	0.73	0.00	0.00
NC	6000		Misc	2014	2054	4.68	0.69	0.26	0.26	5%	0.04	0.04	5%	0.01	0.01	0	0	4.47			0.26	0.04
NC	6000		Misc	2014	2054	4.59	0.68	0.09	0.35	7%	0.01	0.05	7%	0.03	0.02	0	0	2.40			0.09	0.01
NC	6000		Misc	2014	2054	4.24	0.63	0.34	0.69	14%	0.05	0.10	14%	0.05	0.03	0	0	1.71			0.34	0.05
NC NC	6000		Misc Misc	2014 2014	2054 2054	4.16 4.02	0.61 0.59	0.08 0.14	0.78	16% 18%	0.01 0.02	0.11 0.13	16% 18%	0.05	0.03 0.04	0	0	1.33 1.24			0.08 0.14	0.01 0.02
NC	6000		Misc	2014	2054	3.87	0.59		0.91 1.06	22%			22%	0.05		0	0	0.48				
	7000						0.57	0.15			0.02	0.16		0.15	0.05	1	U N//A		0.00	0.40	0.00	0.00
NC NC	7000		Misc Misc	2014 2014	2054 2054	0.60 0.51	0.10	0.00 0.09	0.00	0% 16%	0.00	0.00 0.01	0% 8%	N/A 0.03	N/A 0.03	N/A	N/A	N/A 2.02	0.60	0.10	0.00	0.00 0.01
NC			Misc	2014	2054	0.46			0.09	24%	0.01		12%		0.03	0	0					
NC	7000 7100		Misc	2014	2054	0.46	0.09	0.05 0.00	0.15	24% 0%	0.00	0.01 0.00	0%	0.05 N/A	0.03 N/A	N/A	N/A	1.10 N/A	0.01	0.00	0.05 0.00	0.00
					2054		0.00			45%					0.43	IWA	INA	0.12	0.01	0.00		
NC NC	7100 7200		Misc Misc	2014 2014	2054	0.00	0.00	0.00	0.00	45% 0%	0.00	0.00	23% 0%	0.43 N/A	0.43 N/A	N/A	N/A	0.12 N/A	0.01	0.00	0.00	0.00
NC	7300		Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	7300		Misc	2014	2054	0.00	0.00	0.00	0.00	6%	0.00	0.00	6%	0.46	0.46	IWA 2	IN/A	0.15	0.00	0.00	0.00	0.00
NC	7400		Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.46 N/A	0.46 N/A	N/A	N/A	0.15 N/A	0.00	0.00	0.00	0.00
NC	8000		Misc	2014	2054	3.96	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.96	0.00	0.00	0.00
	8000			2014	2054	3.73		0.00	0.00	6%		0.00				N/A		2.18	3.30	0.00		0.00
NC NC	8100		Misc Misc	2014	2054	0.12	0.00	0.22	0.22	0%	0.00	0.00	0% 0%	0.03 N/A	0.03 N/A	N/A N/A	N/A N/A	2.18 N/A	0.12	0.00	0.22	0.00
NC	9500		Misc	2014	2054	22.38	3.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	22.38	3.72	0.00	0.00
NC	9500			2014		22.38	3.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00	22.30	3.12		0.00
NC	9500	9501 XMISC	Misc	2014	2054	22.38	3.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00	0.00

APPENDIX H

Base Avoided Costs

		ew Construction		.,		.,															OLIDBI ::	
DSM ASSY Vintage	YST ADDITIV	E SUPPLY ANALYSIS		Year	2020	Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY	
Vilitage				Measure	Measure	9			Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity					
Bas	se Mea	sure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt Nu	mber Num		Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA	100	100 Base Bldg Design - 15%	Office	2014	2053	45.23		0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	45.23	10.30	0.00	0.00
VA VA	100 200	101 High Performance Building/Int Design - Tier 1 15% - Office 200 Base Bldg Design - 30%	Office Office	2014 2014	2053 2053	38.32 36.18		6.91 0.00	6.91 0.00	15% 0%	2.01 0.00	2.01 0.00	20% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	2.15 N/A	36.18	8.24	6.91 0.00	2.01 0.00
VA	200	200 Base Bidg Design - 30% 201 High Performance Building/Int Design - Tier 2 30% - Office	Office	2014	2053	25.13	5.03	11.05	11.05	31%	3.21	3.21	39%	0.03	0.03	0	0	3.01	30.10	0.24	11.05	3.21
VA	300	300 Base Bldg Design - 50%	Office	2014	2053	8.14	1.85	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.14	1.85	0.00	0.00
VA	300	301 High Performance Building/Int Design - Tier 3 50% - Office	Office	2014	2053	4.00	0.65	4.14	4.14	51%	1.21	1.21	65%	0.03	0.03	0	0	2.86			4.14	1.21
VA	400	400 Base Bldg Design - 70%	Office	2014	2053	0.90	0.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.90	0.21	0.00	0.00
VA	400 100	401 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office	Office	2014 2014	2053 2053	0.26 1.89	0.02	0.64	0.64	71%	0.19	0.19	91% 0%	0.04 N/A	0.04 N/A	0	0 N/A	2.55 N/A	4.00	0.43	0.64	0.19
NC NC	100	100 Base Bldg Design - 15% 101 High Performance Building/Int Design - Tier 1 15% - Office	Office Office	2014	2053	1.60	0.43	0.00	0.00	0% 15%	0.00	0.00	20%	0.04	0.04	N/A 0	N/A 0	2.56	1.89	0.43	0.00	0.00
NC	200	200 Base Bldg Design - 30%	Office	2014	2053	1.51	0.34	0.29	0.29	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.51	0.34	0.29	0.00
NC	200	201 High Performance Building/Int Design - Tier 2 30% - Office	Office	2014	2053	1.05	0.21	0.46	0.46	31%	0.13	0.13	39%	0.03	0.03	0	0	3.58			0.46	0.13
NC	300	300 Base Bldg Design - 50%	Office	2014	2053	0.34	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.34	0.08	0.00	0.00
NC	300	301 High Performance Building/Int Design - Tier 3 50% - Office	Office	2014	2053	0.17	0.03	0.17	0.17	51%	0.05	0.05	65%	0.03	0.03	0	0	3.41			0.17	0.05
NC NC	400 400	400 Base Bldg Design - 70% 401 High Performance Building/Int Decign Tigs 4 Near Zero Energy (60 75%) Office	Office Office	2014 2014	2053 2053	0.04	0.01	0.00	0.00	0% 71%	0.00 0.01	0.00 0.01	0% 91%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.04	0.04	0.01	0.00 0.03	0.00
VA	100	401 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Office 100 Base Bldg Design - 15%	Restaurant	2014	2053	19.73		0.03	0.00	0%	0.00	0.00	0%	0.03 N/A	0.03 N/A	N/A	N/A	3.04 N/A	19.73	4.18	0.03	0.00
VA	100	102 High Performance Building/Int Design - Tier 1 15% - Restaurant	Restaurant	2014	2053	16.73	3.36	3.00	3.00	15%	0.81	0.81	20%	0.05	0.05	0	0	1.78	10.70	0	3.00	0.81
VA	200	200 Base Bldg Design - 30%	Restaurant	2014	2053	15.79	3.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.79	3.34	0.00	0.00
VA	200	202 High Performance Building/Int Design - Tier 2 30% - Restaurant	Restaurant	2014	2053	10.98		4.80	4.80	30%	1.30	1.30	39%	0.04	0.04	0	0	2.49			4.80	1.30
VA	300	300 Base Bldg Design - 50%	Restaurant	2014	2053	3.55	0.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.55	0.75	0.00	0.00
VA VA	300 400	302 High Performance Building/Int Design - Tier 3 50% - Restaurant 400 Base Bldg Design - 70%	Restaurant Restaurant	2014 2014	2053 2053	1.75	0.26	1.80 0.00	1.80	51% 0%	0.49	0.49	65% 0%	0.04 N/A	0.04 N/A	0 N/A	0 N/A	2.37 N/A	0.39	0.08	1.80	0.49
VA	400	402 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaurant	Restaurant	2014	2053	0.11	0.00	0.28	0.28	71%	0.08	0.08	91%	0.04	0.04	0	0	2.11	0.55	0.00	0.28	0.08
NC	100	100 Base Bldg Design - 15%	Restaurant	2014	2053	0.52	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.52	0.11	0.00	0.00
NC	100	102 High Performance Building/Int Design - Tier 1 15% - Restaurant	Restaurant	2014	2053	0.44	0.09	0.08	0.08	15%	0.02	0.02	20%	0.04	0.04	0	0	2.12			0.08	0.02
NC	200	200 Base Bldg Design - 30%	Restaurant	2014	2053	0.42	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.42	0.09	0.00	0.00
NC	200	202 High Performance Building/Int Design - Tier 2 30% - Restaurant	Restaurant	2014	2053	0.29	0.05	0.13	0.13	30%	0.03	0.03	39%	0.03	0.03	0	0	2.97			0.13	0.03
NC NC	300 300	300 Base Bldg Design - 50% 302 High Performance Building/Int Design - Tier 3 50% - Restaurant	Restaurant Restaurant	2014 2014	2053 2053	0.09	0.02	0.00	0.00	0% 51%	0.00	0.00	0% 65%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.83	0.09	0.02	0.00	0.00
NC	400	400 Base Bldg Design - 70%	Restaurant	2014	2053	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	400	402 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Restaurant	Restaurant	2014	2053	0.00	0.00	0.01	0.01	71%	0.00	0.00	91%	0.04	0.04	0	0	2.52			0.01	0.00
VA	100	100 Base Bldg Design - 15%	Retail	2014	2053	40.98	9.62	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	40.98	9.62	0.00	0.00
VA	100	103 High Performance Building/Int Design - Tier 1 15% - Retail	Retail	2014	2053	34.72		6.26	6.26	15%	1.88	1.88	20%	0.09	0.09	0	0	1.03			6.26	1.88
VA	200	200 Base Bldg Design - 30%	Retail	2014	2053	32.78	7.69 4.69	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	32.78	7.69	0.00	0.00 3.00
VA VA	200 300	203 High Performance Building/Int Design - Tier 2 30% - Retail 300 Base Bldg Design - 50%	Retail Retail	2014 2014	2053 2053	22.77 7.38	1.73	10.01 0.00	10.01 0.00	31% 0%	3.00 0.00	3.00 0.00	39% 0%	0.06 N/A	0.06 N/A	N/A	N/A	1.44 N/A	7.38	1.73	10.01 0.00	0.00
VA	300	303 High Performance Building/Int Design - Tier 3 50% - Retail	Retail	2014	2053	3.62	0.61	3.75	3.75	51%	1.13	1.13	65%	0.07	0.07	0	0	1.37	7.30	1.73	3.75	1.13
VA	400	400 Base Bldg Design - 70%	Retail	2014	2053	0.82	0.19	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.82	0.19	0.00	0.00
VA	400	403 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Retail	Retail	2014	2053	0.24	0.02	0.58	0.58	71%	0.18	0.18	91%	0.07	0.07	0	0	1.22			0.58	0.18
NC	100	100 Base Bldg Design - 15%	Retail	2014	2053	1.09	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.09	0.25	0.00	0.00
NC	100 200	103 High Performance Building/Int Design - Tier 1 15% - Retail	Retail Retail	2014 2014	2053 2053	0.92	0.21	0.17	0.17	15%	0.05	0.05	20% 0%	0.07 N/A	0.07 N/A	0	0	1.23	0.07	0.00	0.17	0.05 0.00
NC NC	200	200 Base Bldg Design - 30% 203 High Performance Building/Int Design - Tier 2 30% - Retail	Retail	2014	2053	0.87	0.20	0.00	0.00	0% 31%	0.00	0.00	39%	0.05	0.05	N/A 0	N/A 0	N/A 1.72	0.87	0.20	0.00 0.27	0.00
NC	300	300 Base Bldg Design - 50%	Retail	2014	2053	0.20	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.20	0.05	0.00	0.00
NC	300	303 High Performance Building/Int Design - Tier 3 50% - Retail	Retail	2014	2053	0.10	0.02	0.10	0.10	51%	0.03	0.03	65%	0.06	0.06	0	0	1.64			0.10	0.03
NC	400	400 Base Bldg Design - 70%	Retail	2014	2053	0.02	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.01	0.00	0.00
NC	400	403 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Retail	Retail	2014	2053	0.01	0.00	0.02	0.02	71%	0.00	0.00	91%	0.06	0.06	0	0	1.46			0.02	0.00
VA VA	100 100	100 Base Bldg Design - 15%	Grocery Grocery	2014 2014	2053 2053	8.82 7.49	1.49	0.00 1.33	0.00 1.33	0% 15%	0.00 0.29	0.00 0.29	0% 20%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.67	8.82	1.49	0.00 1.33	0.00
VA	200	104 High Performance Building/Int Design - Tier 1 15% - Grocery 200 Base Bldg Design - 30%	Grocery	2014	2053	7.49	1.19	0.00	0.00	0%	0.29	0.29	0%	0.03 N/A	0.03 N/A	N/A	N/A	N/A	7.06	1.19	0.00	0.29
VA	200	204 High Performance Building/Int Design - Tier 2 30% - Grocery	Grocery	2014	2053	4.93	0.73	2.13	2.13	30%	0.46	0.46	39%	0.02	0.02	0	0	3.73			2.13	0.46
VA	300	300 Base Bldg Design - 50%	Grocery	2014	2053	1.59	0.27	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.59	0.27	0.00	0.00
VA	300	304 High Performance Building/Int Design - Tier 3 50% - Grocery	Grocery	2014	2053	0.79	0.09	0.80	0.80	50%	0.17	0.17	65%	0.02	0.02	0	0	3.55			0.80	0.17
VA	400	400 Base Bldg Design - 70%	Grocery	2014	2053	0.18	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	0.18	0.03	0.00	0.00
VA NC	400 100	404 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Grocery 100 Base Bldg Design - 15%	Grocery Grocery	2014 2014	2053 2053	0.05	0.00	0.12	0.12 0.00	70% 0%	0.03	0.03	91% 0%	0.03 N/A	0.03 N/A	0 N/A	N/A	3.17 N/A	0.23	0.04	0.12 0.00	0.03
NC	100	100 Base Bidg Design - 15% 104 High Performance Building/Int Design - Tier 1 15% - Grocery	Grocery	2014	2053	0.23	0.04	0.00	0.04	15%	0.00	0.00	20%	0.03	0.03	0	0	3.18	0.23	0.04	0.00	0.00
NC	200	200 Base Bldg Design - 30%	Grocery	2014	2053	0.19	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.19	0.03	0.00	0.00
NC	200	204 High Performance Building/Int Design - Tier 2 30% - Grocery	Grocery	2014	2053	0.13	0.02	0.06	0.06	30%	0.01	0.01	39%	0.02	0.02	0	0	4.45			0.06	0.01
NC	300	300 Base Bldg Design - 50%	Grocery	2014	2053	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
NC NC	300 400	304 High Performance Building/Int Design - Tier 3 50% - Grocery 400 Base Bldg Design - 70%	Grocery Grocery	2014 2014	2053 2053	0.02	0.00	0.02	0.02	50% 0%	0.00	0.00	65% 0%	0.02 N/A	0.02 N/A	0 N/A	0 N/A	4.24 N/A	0.00	0.00	0.02 0.00	0.00
NC NC	400	400 Base Bidg Design - 70% 404 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Grocery	Grocery	2014 2014	2053	0.00	0.00	0.00	0.00	70%	0.00	0.00	0% 91%	N/A 0.02	0.02	N/A 0	N/A 0	N/A 3.77	0.00	0.00	0.00	0.00
VA	100	100 Base Bldg Design - 15%	Warehouse	2014	2053	16.15		0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.15	3.16	0.00	0.00
VA	100	105 High Performance Building/Int Design - Tier 1 15% - Warehouse	Warehouse	2014	2053	13.70		2.45	2.45	15%	0.62	0.62	20%	0.10	0.10	0	0	0.84			0.00	0.00
VA	200	200 Base Bldg Design - 30%	Warehouse	2014	2053	12.92		0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	12.92	2.53	0.00	0.00
VA	200	205 High Performance Building/Int Design - Tier 2 30% - Warehouse	Warehouse	2014	2053	8.99	1.54	3.93	3.93	30%	0.98	0.98	39%	0.07	0.07	0	0	1.17			3.93	0.98
VA VA	300 300	300 Base Bldg Design - 50% 205 High Performance Building/let Design Tior 3 50% Warehouse	Warehouse Warehouse	2014	2053	2.91	0.57	0.00	0.00	0%	0.00	0.00	0% 65%	N/A	N/A	N/A 0	N/A 0	N/A	2.91	0.57	0.00	0.00 0.37
VA VA	400	305 High Performance Building/Int Design - Tier 3 50% - Warehouse 400 Base Bldg Design - 70%	Warehouse	2014 2014	2053 2053	1.43 0.32	0.20	1.47 0.00	1.47 0.00	51% 0%	0.37 0.00	0.37 0.00	0%	0.08 N/A	0.08 N/A	N/A	N/A	1.12 N/A	0.32	0.06	1.47 0.00	0.37
VA	400	400 Base Bidg Design - 70% 405 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Warehouse	Warehouse	2014	2053	0.32	0.06	0.00	0.00	71%	0.06	0.06	91%	0.09	0.09	0	0	1.00	0.32	0.00	0.00	0.00
NC	100	100 Base Bldg Design - 15%	Warehouse	2014	2053	0.40	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.40	80.0	0.00	0.00
NC	100	105 High Performance Building/Int Design - Tier 1 15% - Warehouse	Warehouse	2014	2053	0.34	0.06	0.06	0.06	15%	0.02	0.02	20%	0.09	0.09	0	0	1.00			0.00	0.00

APPENDIX H

Base Avoided Costs

		ew Construction																				
DSM ASSY Vintage	ST ADDITIV	E SUPPLY ANALYSIS		Year	2020	Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY	
			Destroite e	Measure	Measure		Total	01411	Energy	Percent	MW	Capacity	Percent MW	Energy	Energy	Capacity		Resource	D	D	F	F
Sgmt Num		sure ber Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	Savings	Savings MW	Savings	Cost \$/kWH	Cost \$/kWH	\$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
NC	200	200 Base Bldg Design - 30%	Warehouse	2014	2053	0.32	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	0.32	0.06	0.00	0.00
NC NC	200 300	205 High Performance Building/Int Design - Tier 2 30% - Warehouse 300 Base Bldg Design - 50%	Warehouse Warehouse	2014 2014	2053 2053	0.22	0.04	0.10 0.00	0.10 0.00	30% 0%	0.02 0.00	0.02	39% 0%	0.06 N/A	0.06 N/A	0 N/A	N/A	1.40 N/A	0.07	0.01	0.10 0.00	0.02 0.00
NC	300	305 High Performance Building/Int Design - Tier 3 50% - Warehouse	Warehouse	2014	2053	0.04	0.00	0.04	0.04	51%	0.01	0.01	65%	0.07	0.07	0	0	1.33			0.04	0.01
NC NC	400 400	400 Base Bldg Design - 70% 405 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Warehouse	Warehouse Warehouse	2014 2014	2053 2053	0.01	0.00	0.00 0.01	0.00 0.01	0% 71%	0.00	0.00	0% 91%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.19	0.01	0.00	0.00 0.01	0.00
VA	100	100 Base Bldg Design - 15%	School	2014	2053	10.20	1.55	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	10.20	1.55	0.00	0.00
VA VA	100 200	106 High Performance Building/Int Design - Tier 1 15% - School 200 Base Bldg Design - 30%	School School	2014 2014	2053 2053	8.64 8.16	1.25	1.56 0.00	1.56 0.00	15% 0%	0.30	0.30	20%	0.12 N/A	0.12 N/A	1 N/A	1 N/A	0.69 N/A	8.16	1.24	0.00	0.00
VA	200	206 High Performance Building/Int Design - Tier 2 30% - School	School	2014	2053	5.67	0.76	2.49	2.49	31%	0.48	0.48	39%	0.09	0.09	0	0	0.97			0.00	0.00
VA VA	300 300	300 Base Bldg Design - 50% 306 High Performance Building/Int Design - Tier 3 50% - School	School School	2014 2014	2053 2053	1.84 0.90	0.28	0.00	0.00 0.93	0% 51%	0.00 0.18	0.00 0.18	0% 65%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.92	1.84	0.28	0.00	0.00
VA	400	400 Base Bldg Design - 70%	School	2014	2053	0.90	0.10	0.93	0.93	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.92 N/A	0.20	0.03	0.00	0.00
VA	400	406 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - School	School	2014	2053	0.06	0.00	0.15	0.15	71%	0.03	0.03	91%	0.10	0.10	1	1	0.82			0.00	0.00
NC NC	100 100	100 Base Bldg Design - 15% 106 High Performance Building/Int Design - Tier 1 15% - School	School School	2014 2014	2053 2053	0.92	0.14	0.00 0.14	0.00 0.14	0% 15%	0.00	0.00	0% 20%	N/A 0.10	N/A 0.10	N/A 1	N/A 1	N/A 0.82	0.92	0.14	0.00	0.00
NC	200	200 Base Bldg Design - 30%	School	2014	2053	0.73	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.73	0.11	0.00	0.00
NC NC	200 300	206 High Performance Building/Int Design - Tier 2 30% - School 300 Base Bldg Design - 50%	School School	2014 2014	2053 2053	0.51	0.07	0.22	0.22	31% 0%	0.04	0.04	39% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.15 N/A	0.16	0.03	0.22	0.04
NC	300	306 High Performance Building/Int Design - Tier 3 50% - School	School	2014	2053	0.08	0.01	0.08	0.08	51%	0.02	0.02	65%	0.08	0.08	0	0	1.10			0.08	0.02
NC NC	400 400	400 Base Bldg Design - 70%	School School	2014 2014	2053 2053	0.02	0.00	0.00	0.00 0.01	0% 71%	0.00	0.00	0% 91%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.98	0.02	0.00	0.00	0.00
VA	100	406 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - School 100 Base Bldg Design - 15%	Health	2014	2053	13.16	2.46	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.96 N/A	13.16	2.46	0.00	0.00
VA	100	107 High Performance Building/Int Design - Tier 1 15% - Health	Health	2014	2053	11.17	1.98	1.99	1.99	15%	0.48	0.48	20%	0.12	0.12	.1.	.1	0.70			0.00	0.00
VA VA	200 200	200 Base Bldg Design - 30% 207 High Performance Building/Int Design - Tier 2 30% - Health	Health Health	2014 2014	2053 2053	10.53 7.34	1.97 1.20	0.00 3.19	0.00 3.19	0% 30%	0.00 0.77	0.00 0.77	0% 39%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.97	10.53	1.97	0.00	0.00
VA	300	300 Base Bldg Design - 50%	Health	2014	2053	2.37	0.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.37	0.44	0.00	0.00
VA VA	300 400	307 High Performance Building/Int Design - Tier 3 50% - Health 400 Base Bldg Design - 70%	Health Health	2014 2014	2053 2053	1.17 0.26	0.15	1.19	1.19	50% 0%	0.29	0.29	65% 0%	0.09 N/A	0.09 N/A	0 N/A	0 N/A	0.93 N/A	0.26	0.05	0.00	0.00
VA	400	407 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Health	Health	2014	2053	0.28	0.00	0.00	0.00	71%	0.04	0.04	91%	0.10	0.10	0	0	0.83	0.26	0.05	0.00	0.00
NC	100	100 Base Bldg Design - 15%	Health	2014	2053	0.35	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.35	0.07	0.00	0.00
NC NC	100 200	107 High Performance Building/Int Design - Tier 1 15% - Health 200 Base Bldg Design - 30%	Health Health	2014	2053 2053	0.30	0.05	0.05	0.05	15% 0%	0.01 0.00	0.01	20% 0%	0.10 N/A	0.10 N/A	0 N/A	0 N/A	0.83 N/A	0.28	0.05	0.00	0.00
NC	200	207 High Performance Building/Int Design - Tier 2 30% - Health	Health	2014	2053	0.19	0.03	0.08	0.08	30%	0.02	0.02	39%	0.07	0.07	0	0	1.16			0.08	0.02
NC NC	300 300	300 Base Bldg Design - 50% 307 High Performance Building/Int Design - Tier 3 50% - Health	Health Health	2014 2014	2053 2053	0.06	0.01	0.00	0.00	0% 50%	0.00	0.00 0.01	0% 65%	N/A 0.08	N/A 0.08	N/A 0	N/A 0	N/A 1.11	0.06	0.01	0.00	0.00
NC	400	400 Base Bldg Design - 70%	Health	2014	2053	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	400	407 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Health	Health	2014	2053	0.00	0.00	0.00	0.00	71%	0.00	0.00	91%	0.09	0.09	0	0	0.99			0.00	0.00
VA VA	100 100	100 Base Bldg Design - 15% 108 High Performance Building/Int Design - Tier 1 15% - Lodging	Lodging Lodging	2014 2014	2053 2053	17.04 14.46	3.30 2.66	0.00 2.58	0.00 2.58	0% 15%	0.00 0.64	0.00 0.64	0% 20%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.93	17.04	3.30	0.00	0.00
VA	200	200 Base Bldg Design - 30%	Lodging	2014	2053	13.63	2.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.63	2.64	0.00	0.00
VA VA	200 300	208 High Performance Building/Int Design - Tier 2 30% - Lodging 300 Base Bldg Design - 50%	Lodging Lodging	2014 2014	2053 2053	9.51 3.07	1.61 0.59	4.12 0.00	4.12 0.00	30% 0%	1.03 0.00	1.03 0.00	39% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.31 N/A	3.07	0.59	4.12 0.00	1.03 0.00
VA	300	308 High Performance Building/Int Design - Tier 3 50% - Lodging	Lodging	2014	2053	1.52	0.33	1.55	1.55	50%	0.39	0.39	65%	0.07	0.07	0	0	1.25	3.07	0.55	1.55	0.39
VA	400	400 Base Bldg Design - 70%	Lodging	2014	2053	0.34	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.34	0.07	0.00	0.00
VA NC	400 100	408 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodging 100 Base Bldg Design - 15%	Lodging Lodging	2014 2014	2053 2053	0.10 0.45	0.01	0.24	0.24	71% 0%	0.06	0.06	91% 0%	0.08 N/A	0.08 N/A	0 N/A	0 N/A	1.11 N/A	0.45	0.09	0.24	0.06
NC	100	108 High Performance Building/Int Design - Tier 1 15% - Lodging	Lodging	2014	2053	0.38	0.07	0.07	0.07	15%	0.02	0.02	20%	0.08	0.08	0	0	1.11			0.07	0.02
NC NC	200 200	200 Base Bldg Design - 30% 208 High Performance Building/Int Design - Tier 2 30% - Lodging	Lodging Lodging	2014 2014	2053 2053	0.36	0.07	0.00	0.00	0% 30%	0.00	0.00	0% 39%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.56	0.36	0.07	0.00	0.00
NC	300	300 Base Bldg Design - 50%	Lodging	2014	2053	0.08	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.08	0.02	0.00	0.00
NC NC	300 400	308 High Performance Building/Int Design - Tier 3 50% - Lodging 400 Base Bldg Design - 70%	Lodging	2014 2014	2053 2053	0.04	0.01	0.04	0.04	50% 0%	0.01 0.00	0.01	65% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.49 N/A	0.01	0.00	0.04	0.01 0.00
NC	400	400 Base Bidg Design - 70% 408 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Lodging	Lodging Lodging	2014	2053	0.00	0.00	0.00	0.00	71%	0.00	0.00	91%	0.07	0.07	0	0	1.32	0.01	0.00	0.00	0.00
VA	100	100 Base Bldg Design - 15%	Data Centers	2014	2053	7.21	1.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.21	1.26	0.00	0.00
VA VA	100 200	109 High Performance Building/Int Design - Tier 1 15% - Data Centers 200 Base Bldg Design - 30%	Data Centers Data Centers	2014 2014	2053 2053	6.13 5.77	1.01 1.00	1.09	1.09 0.00	15% 0%	0.24	0.24	20% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	6.84 N/A	5.77	1.00	1.09 0.00	0.24 0.00
VA	200	209 High Performance Building/Int Design - Tier 2 30% - Data Centers	Data Centers	2014	2053	4.03	0.61	1.74	1.74	30%	0.39	0.39	39%	0.01	0.01	0	0	9.58			1.74	0.39
VA VA	300 300	300 Base Bldg Design - 50% 309 High Performance Building/Int Design - Tier 3 50% - Data Centers	Data Centers Data Centers	2014 2014	2053 2053	1.30 0.65	0.23	0.00 0.65	0.00 0.65	0% 50%	0.00 0.15	0.00 0.15	0% 65%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.12	1.30	0.23	0.00 0.65	0.00 0.15
VA	400	400 Base Bldg Design - 70%	Data Centers Data Centers	2014	2053	0.05	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	9.12 N/A	0.14	0.03	0.00	0.00
VA	400	409 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Data Centers	Data Centers	2014	2053	0.04	0.00	0.10	0.10	70%	0.02	0.02	91%	0.01	0.01	0	0	8.13			0.10	0.02
NC NC	100 100	100 Base Bldg Design - 15% 109 High Performance Building/Int Design - Tier 1 15% - Data Centers	Data Centers Data Centers	2014 2014	2053 2053	0.16 0.14	0.03	0.00 0.02	0.00 0.02	0% 15%	0.00 0.01	0.00 0.01	0% 20%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.15	0.16	0.03	0.00 0.02	0.00 0.01
NC	200	200 Base Bldg Design - 30%	Data Centers	2014	2053	0.13	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.13	0.02	0.00	0.00
NC NC	200 300	209 High Performance Building/Int Design - Tier 2 30% - Data Centers 300 Base Bldg Design - 50%	Data Centers Data Centers	2014 2014	2053 2053	0.09	0.01	0.04	0.04	30% 0%	0.01 0.00	0.01 0.00	39% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	11.42 N/A	0.03	0.01	0.04	0.01 0.00
NC	300	309 High Performance Building/Int Design - Tier 3 50% - Data Centers	Data Centers Data Centers	2014	2053	0.03	0.00	0.00	0.00	50%	0.00	0.00	65%	0.01	0.01	0	0	10.87	0.03	0.01	0.00	0.00
NC	400	400 Base Bldg Design - 70%	Data Centers	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00	0.00
NC VA	400 100	409 High Performance Building/Int Design - Tier 4 Near Zero Energy (60-75%) - Data Centers 100 Base Bldg Design - 15%	Data Centers Religious Worship	2014 2014	2053 2053	0.00 9.51	0.00 1.87	0.00	0.00	70% 0%	0.00	0.00	91% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	9.69 N/A	9.51	1.87	0.00	0.00
VA	100	111 High Performance Building/Int Design - Tier 1 15% - Religious Worship	Religious Worship	2014	2053	8.06	1.50	1.45	1.45	15%	0.36	0.36	20%	0.17	0.17	1	1	0.52			0.00	0.00
VA VA	200	200 Base Bldg Design - 30% 211 High Performance Building/Int Design - Tier 2 30% - Religious Worship	Religious Worship Religious Worship	2014 2014	2053 2053	7.61 5.30	1.49 0.91	0.00 2.31	0.00 2.31	0% 30%	0.00 0.58	0.00 0.58	0% 39%	N/A 0.12	N/A 0.12	N/A 0	N/A 0	N/A 0.73	7.61	1.49	0.00	0.00
V/A	200	211 Figure Gronnance Bullungrint Design - Hel 2 30% - Religious Wolship	rengious worship	2014	2000	5.30	0.91	2.31	2.31	30%	0.00	0.50	39%	0.12	U. 12	U	U	0.73			0.00	0.00

DNV GL H-2 1/5/2015

APPENDIX H

Base Avoided Costs

		ectric New Construction																				
		ADDITIVE SUPPLY ANALYSIS		Year	2020	Year	2014														SUPPLY	
Vintag	je								Total			Total		Marginal	Average	Marginal	Average					/
				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource				
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base		
Sgmt	Number		Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
VA	300		Religious Worship	2014	2053	1.71	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.71	0.34	0.00	0.00
VA	300		Religious Worship	2014	2053	0.84	0.12	0.87	0.87	51%	0.22	0.22	65%	0.13	0.13	0	0	0.70			0.00	0.00
VA	400		Religious Worship	2014	2053	0.19	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.19	0.04	0.00	0.00
VA	400			2014	2053	0.06	0.00	0.13	0.13	71%	0.03	0.03	91%	0.14	0.14	.1	.1	0.62			0.00	0.00
NC	100		Religious Worship	2014	2053	0.25	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.25	0.05	0.00	0.00
NC	100		Religious Worship	2014	2053	0.21	0.04	0.04	0.04	15%	0.01	0.01	20%	0.14	0.14	1		0.62			0.00	0.00
NC	200		Religious Worship	2014	2053	0.20	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.20	0.04	0.00	0.00
NC	200		Religious Worship	2014	2053	0.14	0.02	0.06	0.06	30%	0.02	0.02	39%	0.10	0.10	0	0	0.87			0.00	0.00
NC	300		Religious Worship	2014	2053	0.05	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.01	0.00	0.00
NC	300		Religious Worship	2014	2053	0.02	0.00	0.02	0.02	51%	0.01	0.01	65%	0.11	0.11	0	0	0.83			0.00	0.00
NC	400		Religious Worship	2014	2053	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
NC	400			2014	2053	0.00	0.00	0.00	0.00	71%	0.00	0.00	91%	0.12 N/A	0.12	0	0	0.74	39.46	7.74	0.00	0.00
VA	100		Misc	2014 2014	2053 2053	39.46 33.46	7.74 6.23	0.00	0.00	0% 15%	0.00 1.51	0.00 1.51	0% 20%	0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.93	39.46	7.74	0.00	0.00
VA			Misc	2014	2053			6.00	6.00					0.09 N/A			-		04.57	0.40		
VA	200 200		Misc	2014	2053	31.57 21.97	6.19	0.00 9.59	0.00	0% 30%	0.00 2.42	0.00 2.42	0% 39%		N/A 0.07	N/A 0	N/A 0	N/A	31.57	6.19	0.00 9.59	0.00 2.42
VA	300		Misc Misc	2014	2053	21.97	3.78 1.39	0.00	9.59 0.00	0%	0.00	0.00	0%	0.07 N/A	0.07 N/A	N/A	N/A	1.30 N/A	7.10	1.39	0.00	0.00
VA VA	300		Misc	2014	2053	3.50	0.49	3.60	3.60	51%	0.00	0.00	65%	0.07	0.07	0	0	1.23	7.10	1.39	3.60	0.00
VA VA	400		Misc	2014	2053	0.79	0.49	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	1.23 N/A	0.79	0.15	0.00	0.00
VΔ	400			2014	2053	0.73	0.13	0.56	0.56	71%	0.00	0.14	91%	0.08	0.08	0	0	1.10	0.75	0.13	0.56	0.14
NC	100		Misc	2014	2053	1.10	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.10	0.22	0.00	0.00
NC	100		Misc	2014	2053	0.93	0.17	0.00	0.00	15%	0.04	0.04	20%	0.08	0.08	0	0	1.10	1.10	0.22	0.17	0.04
NC.	200		Misc	2014	2053	0.88	0.17	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.88	0.17	0.00	0.00
NC.	200		Misc	2014	2053	0.61	0.11	0.27	0.27	30%	0.07	0.07	39%	0.06	0.06	0	0	1.55	5.50	5.17	0.27	0.07
NC	300		Misc	2014	2053	0.20	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.20	0.04	0.00	0.00
NC	300		Misc	2014	2053	0.10	0.01	0.10	0.10	51%	0.03	0.03	65%	0.06	0.06	0	0	1.47			0.10	0.03
NC	400		Misc	2014	2053	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
NC	400		Misc	2014	2053	0.01	0.00	0.02	0.02	71%	0.00	0.00	91%	0.07	0.07	0	0	1.31		2.50	0.02	0.00
		5														-	-					

APPENDIX H

Base Avoided Costs

DSM ASSYS'	T ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
vintage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource			
		easure Imber Measure	Building	Start	End	Total	Total	GWH Savings	Savings	GWH Savings	MW	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base	Base	Economic
Sgmt No Opt-Out/Ex	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Type Office	2020	2054	151.74	28.25	0.00	0.00	0%	Savings 0.00	0.00	5avings 0%	N/A	N/A	N/A	N/A	N/A	151.74	28.25	0.00
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Office	2020	2054	150.56	28.14	1.18	1.18	1%	0.11	0.11	0%	0.01	0.01	0	0	6.72			1.18
Opt-Out/Ex	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Office	2020	2054	139.27	26.46	11.29	12.47	8%	1.68	1.79	6%	0.01	0.01	0	0	6.12			11.29
Opt-Out/Ex Opt-Out/Ex	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office Office	2020 2020	2054 2054	125.08 113.50	23.81	14.19 11.58	26.66 38.24	18% 25%	2.64	4.43 6.59	16% 23%	0.02	0.02	0	0	3.41 1.19			14.19 11.58
Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	2020	2054	103.97	21.22	9.53	47.77	31%	0.44	7.03	25%	0.05	0.03	1	Ö	1.06			9.53
Opt-Out/Ex	1030	1034 ROB 4L4' LED Tube, 2020	Office	2020	2054	87.22	18.10	16.75	64.52	43%	3.12	10.15	36%	0.24	0.08	1	1	0.32			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Office Office	2020 2020	2054 2054	79.77 2.57	16.71 0.48	7.45 0.00	71.97 0.00	47% 0%	1.39 0.00	11.54 0.00	41% 0%	0.20 N/A	0.10 N/A	1 N/A	1 N/A	0.38 N/A	2.57	0.48	0.00
Opt-Out/Ex	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Office	2020	2054	2.55	0.48	0.02	0.02	1%	0.00	0.00	0%	0.01	0.01	0	0	3.90	2.01	0.40	0.02
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Office	2020	2054	2.35	0.45	0.19	0.21	8%	0.03	0.03	6%	0.02	0.02	0	0	3.56			0.19
Opt-Out/Ex	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Office Office	2020 2020	2054 2054	2.11 1.84	0.40	0.24	0.46 0.72	18% 28%	0.05	0.08	16% 26%	0.02	0.02	0	0	2.69 1.29			0.24 0.27
Opt-Out/Ex Opt-Out/Ex	1130	1132 ROB 2L4 Low Watt High Performance 18 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	Office	2020	2054	1.84	0.35	0.27	0.72	28% 32%	0.05	0.13	26% 30%	0.05	0.03	1	0	0.41			0.27
Opt-Out/Ex	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Office	2020	2054	1.60	0.33	0.15	0.96	37%	0.01	0.15	31%	0.10	0.06	2	0	0.54			0.00
Opt-Out/Ex	1130	1135 LED Troffer (base 2L4'T8), 2020	Office	2020	2054	1.47	0.30	0.14	1.10	43%	0.03	0.17	37%	0.25	0.08	.1.	.1	0.29			0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Office Office	2014 2014	2054 2054	5.57 5.30	1.04 1.01	0.00 0.27	0.00	0% 5%	0.00 0.02	0.00 0.02	0% 2%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 18.89	5.57	1.04	0.00 0.27
Opt-Out/Ex	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	2014	2054	4.90	0.95	0.40	0.66	12%	0.02	0.02	8%	0.00	0.00	0	0	2.75			0.40
Opt-Out/Ex	1200	1201 ROB High Performance T8 (base other fluorescent)	Office	2014	2054	4.39	0.86	0.51	1.17	21%	0.09	0.18	17%	0.08	0.04	0	0	0.81			0.00
Opt-Out/Ex	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Office Office	2014 2020	2054 2054	3.75 51.51	0.83 9.59	0.64	1.81	33% 0%	0.03	0.21	20%	0.10 N/A	0.06 N/A	2	1	0.54	-4 -4	9.59	0.00
Opt-Out/Ex Opt-Out/Ex	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Office	2020	2054	12.41	2.31	39.10	39.10	76%	7.28	7.28	76%	0.00	0.00	N/A 0	N/A 0	N/A 16.88	51.51	9.59	39.10
Opt-Out/Ex	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Office	2020	2054	18.54	3.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.54	3.45	0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	Office	2020	2054	4.83	0.90	13.72	13.72	74%	2.55	2.55	74%	0.00	0.00	0	0	14.15			13.72
Opt-Out/Ex Opt-Out/Ex	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Office Office	2020 2020	2054 2054	13.65 4.73	2.54 0.88	0.00 8.92	0.00 8.92	0% 65%	0.00 1.66	0.00 1.66	0% 65%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 10.19	13.65	2.54	0.00 8.92
Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020	Office	2020	2054	3.37	0.63	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.37	0.63	0.00
Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Office	2020	2054	2.43	0.45	0.93	0.93	28%	0.17	0.17	28%	0.05	0.05	0	0	1.22			0.93
Opt-Out/Ex	1730	1730 Base CFL 23W to screw-in replacement 2020	Office Office	2020	2054 2054	4.30	0.80	0.00	0.00	0% 26%	0.00	0.00 0.21	0%	N/A	N/A 0.04	N/A 0	N/A 0	N/A	4.30	0.80	0.00
Opt-Out/Ex Opt-Out/Ex	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Office	2020 2014	2054	3.18 0.00	0.59 0.00	1.12	1.12 0.00	26%	0.21 0.00	0.21	26% 0%	0.04 N/A	0.04 N/A	N/A	N/A	1.62 N/A	0.00	0.00	1.12 0.00
Opt-Out/Ex	1850	1850 Base CFL Exit Sign	Office	2014	2054	1.80	0.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.80	0.33	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	Office	2014	2054	1.01	0.19	0.79	0.79	44%	0.15	0.15	44%	0.02	0.02	0	0	2.61			0.79
Opt-Out/Ex Opt-Out/Ex	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Office Office	2014 2014	2054 2054	12.31 9.85	0.17 0.06	0.00 2.46	0.00 2.46	0% 20%	0.00	0.00	0% 66%	N/A 0.05	N/A 0.05	N/A 1	N/A 1	N/A 1.63	12.31	0.17	0.00 2.46
Opt-Out/Ex	1900	1902 LED Outdoor Area Lighting	Office	2014	2054	4.74	-0.01	5.11	7.57	61%	0.07	0.18	108%	0.09	0.03	7	3	0.70			0.00
Opt-Out/Ex	1900	1903 Bi-Level LED Outdoor Lighting	Office	2014	2054	3.35	-0.03	1.39	8.96	73%	0.02	0.20	118%	0.59	0.16	48	7	0.11			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Office Office	2014	2054 2054	19.03 18.94	13.31	0.00	0.00	0% 0%	0.00	0.00	0%	N/A	N/A 0.01	N/A 0	N/A 0	N/A 19.88	19.03	13.31	0.00
Opt-Out/Ex	2000 2000	2010 Ceiling/roof Insulation - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Office	2014 2014	2054	17.32	13.25 12.12	0.08 1.62	0.08 1.70	9%	0.06 1.13	0.06 1.19	0% 9%	0.01 0.03	0.01	0	0	4.52			0.08 1.62
Opt-Out/Ex	2000	2013 High Efficiency Chiller Motors	Office	2014	2054	17.29	12.10	0.03	1.73	9%	0.02	1.21	9%	0.04	0.03	ō	ō	2.96			0.03
Opt-Out/Ex	2000	2006 VSD for Chiller Pumps and Towers	Office	2014	2054	17.18	12.06	0.11	1.85	10%	0.04	1.25	9%	0.03	0.03	0	0	2.71			0.11
Opt-Out/Ex Opt-Out/Ex	2000 2000	2003 EMS - Chiller 2008 New Economizer - Chiller	Office Office	2014 2014	2054 2054	15.98 14.95	11.85 11.67	1.20 1.03	3.05 4.08	16% 21%	0.21 0.18	1.46 1.64	11% 12%	0.05 0.05	0.03 0.04	0	0	1.55 1.17			1.20 1.03
Opt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	Office	2014	2054	14.94	11.67	0.00	4.08	21%	0.00	1.65	12%	0.09	0.04	ō	0	1.06			0.00
Opt-Out/Ex	2000	2012 Duct Testing/Sealing	Office	2014	2054	12.10	9.68	2.84	6.92	36%	1.99	3.63	27%	0.15	0.08	0	0	0.79			0.00
Opt-Out/Ex	2000 2000	2004 Cool Roof - Chiller 2011 Duct/Pipe Insulation - Chiller	Office Office	2014 2014	2054 2054	12.07 12.03	9.65 9.63	0.04 0.04	6.96 7.00	37% 37%	0.03	3.66 3.68	27% 28%	0.22 1.86	0.09 0.10	0	0	0.43 0.05			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Office	2014	2054	86.33	60.40	0.04	0.00	0%	0.03	0.00	0%	N/A	0.10 N/A	N/A	N/A	0.05 N/A	86.33	60.40	0.00
Opt-Out/Ex	2100	2102 DX Packaged System, EER=13.4, 10 tons	Office	2014	2054	66.48	46.51	19.86	19.86	23%	13.89	13.89	23%	0.02	0.02	0	0	4.76			19.86
Opt-Out/Ex Opt-Out/Ex	2100 2100	2111 Economizer Repair - DX 2108 Optimize Controls - DX	Office Office	2014 2014	2054 2054	63.48 62.40	43.37 43.18	2.99 1.08	22.85 23.93	26% 28%	3.14 0.19	17.03 17.22	28% 29%	0.05 0.06	0.03	0	0	1.70 0.98			2.99 0.00
Opt-Out/Ex	2100	2115 Window Film (Standard) - DX	Office	2014	2054	61.11	42.27	1.29	25.22	29%	0.19	18.12	30%	0.00	0.03	0	0	0.95			0.00
Opt-Out/Ex	2100	2109 Economizer - DX	Office	2014	2054	54.39	41.10	6.72	31.94	37%	1.17	19.30	32%	0.07	0.04	ō	ō	0.86			0.00
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Office	2014	2054	51.08	38.79	3.31	35.25	41%	2.31	21.61	36%	0.19	0.05	0	0	0.64			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2106 Prog. Thermostat - DX 2107 Cool Roof - DX	Office Office	2014 2014	2054 2054	50.00 49.57	38.60 38.30	1.09	36.33 36.76	42% 43%	0.19 0.30	21.80 22.10	36% 37%	0.10 0.25	0.06	1 0	0	0.59 0.38			0.00
Opt-Out/Ex	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office	2014	2054	49.56	38.30	0.01	36.77	43%	0.00	22.10	37%	0.20	0.06	1	0	0.32			0.00
Opt-Out/Ex	2100	2114 Duct/Pipe Insulation - DX	Office	2014	2054	49.24	38.07	0.32	37.09	43%	0.22	22.33	37%	2.07	0.08	3	0	0.05			0.00
Opt-Out/Ex	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Office	2014	2054 2054	58.94	41.24	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	58.94	41.24	0.00
Opt-Out/Ex Opt-Out/Ex	2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Office Office	2014 2014	2054	51.65 9.44	36.14 6.61	7.29 0.00	7.29 0.00	12% 0%	5.10 0.00	5.10 0.00	12% 0%	0.02 N/A	0.02 N/A	N/A	N/A	6.66 N/A	9.44	6.61	7.29 0.00
Opt-Out/Ex	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Office	2014	2054	46.72	14.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	46.72	14.10	0.00
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Office	2014	2054	45.96	13.88	0.76	0.76	2%	0.23	0.23	2%	0.02	0.02	0	0	4.73			0.76
Opt-Out/Ex Opt-Out/Ex	3000 3000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Office Office	2014 2014	2054 2054	34.57 32.69	13.02 11.94	11.39 1.88	12.15 14.03	26% 30%	0.86 1.08	1.09 2.17	8% 15%	0.01 0.64	0.02 0.10	0	0	4.43 0.17			11.39 0.00
Opt-Out/Ex	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Office	2014	2054	8.09	2.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.09	2.44	0.00
Opt-Out/Ex	3100	3102 Variable Speed Drive Control, 15 HP	Office	2014	2054	6.09	2.29	2.01	2.01	25%	0.15	0.15	6%	0.00	0.00	0	0	16.30			2.01
Opt-Out/Ex Opt-Out/Ex	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Office Office	2014 2014	2054 2054	6.05 5.65	2.28 2.17	0.04 0.40	2.04 2.44	25% 30%	0.01 0.11	0.16 0.27	7% 11%	0.01 0.02	0.00 0.01	0	0	7.84 3.47			0.04 0.40
Opt-Out/Ex	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3103 Air Handler Optimization, 15 HP	Office	2014	2054	5.11	2.17	0.40	2.44	30%	0.11	0.27	11%	0.02	0.01	0	0	2.65			0.40
Opt-Out/Ex	3100	3105 Energy Recovery Ventilation (ERV)	Office	2014	2054	4.99	2.06	0.12	3.10	38%	0.07	0.38	16%	0.25	0.02	Ō	Ō	0.47			0.00
Opt-Out/Ex	3100	3107 Demand Controlled Ventilation	Office	2014	2054	4.72	1.91	0.27	3.37	42%	0.16	0.54	22%	0.77	0.08	1	0	0.14			0.00

H-1 DNV GL 1/5/2015

APPENDIX H

Base Avoided Costs

Part			empt/Nonjurisdictional Existing				Year	2014														SUPPLY
Part		I ADDITIVE	SUPPLY ANALYSIS				rear	2014														SUPPLY
Part	R	aco M	225112	Building			Total	Total	GWH			MW								Rasa	Base	Economic
Second S																						
Second																				5.10	1.54	
Declaration Color																						
Second S																		-				
Second S																				0.00	0.00	
Control Cont																						
Column C	Opt-Out/Ex		4103 Night covers for display cases (self-contained)			2054	13.58		0.13			0.02		1%			0	-	53.19			
Change C																		-				
Concess Conc																						
Concolute 100																		-				
Secology 1-10 1-1																		-				
Controlled 1000 1																		-				
Discription Control			4105 Bi-level LED Case Lighting (self-contained units) 2014															-				
Control Cont																				E 60	0.70	
Control Cont																				5.00	0.70	
Control Cont	Opt-Out/Ex	5000	5002 Energy Star or Better PC	Office	2014	2054	2.35	0.51	0.67	3.25	58%	0.09	0.27	35%	0.02	0.01	0	0	2.37			0.67
Second S																				0.51	0.07	
Controlled 100																						
Control Cont	Opt-Out/Ex		5200 Base Monitor, CRT			2054			0.00		0%	0.00	0.00	0%		N/A			N/A	1.19	0.16	0.00
Constraint Section S																						
Conclusion Con																						
Cyclude Soul																	N/A			1.06	0.15	
Geo-Confect Ground Groun																						
Cyclo Cycl																		-				
Conclusion Service S																				1.95	0.27	
Conclusion Con																	-	-				
Opt-Op-Line 500 SSIZE PREFIXED SSIZE PREFIXED SSIZE PREFIXED SSIZE PREFIXED SSIZE PREFIXED SSIZE SSIZE SSIZE PREFIXED SSIZE																		-		0.33	0.05	
Circle C																				0.33	0.05	
Opt-Out- Section	Opt-Out/Ex																					
Opt-Quigner Solid Printer Power Management Enabling Office 2014 2054 1,03 0,16 0,23 0,00 0,0																				1.93	0.27	
Opt-Quille 5700 5700 Base Data Center(Server Room Office 2014 2054 13.4 17.5 1.26 1.26																						
Opt-Quil-B Opt	Opt-Out/Ex	5700	5700 Base Data Center/Server Room	Office	2014	2054	12.60	1.75	0.00		0%	0.00		0%		N/A			N/A	12.60	1.75	0.00
CP-1-QUI-ED																						
Cyt-Quif- Good Good Base Water Heating Good Go		0.00			20		0.00			2.70					0.00	0.00			. 0. 10			
Opt-Outlie 6000 6002 High Efficiency Water Heater Coffice 2014 2054 10.74 14.55 0.22 7% 0.03 0.11 7% 0.03 0.02 0 0 2.55 0.22 0.81		6000		Office	2014	2054		1.56		0.00	0%	0.00		0%		N/A	N/A	N/A	N/A	11.55	1.56	
CPI-OUIED GOOD GOOD GOOD Tankless Water Heater Clffice Clf 2014 2054 9.33 1.34 0.81 1.62 14% 0.11 0.22 14% 0.04 0.03 0 0 1 8.2 1.82 0.62 0.07 0				Office													-	-				
Opt-Out-Dec Color																		-				
Opt-Outlier 6000 6006 Head Recovery Unit 6000 6001 beamad controlled circulating systems Office 2014 2054 4.70 0.56 0.31 7.39 6.4% 0.02 0.10 6.4% 0.31 0.05 2 0 0.22 0.00 Opt-Outlier 7000 7000 Base Refrigerated Vending Machines Office 2014 2054 2.10 0.31 0.00 0.	Opt-Out/Ex		6008 Solar Water Heater	Office	2014	2054			5.28	6.91	60%	0.71	0.93	60%	0.05	0.05			1.56			5.28
OFFICIAL PRINCE 6000 6011 Demand controlled circulating systems Office 2014 2054 4.17 0.56 0.13 7.39 64% 0.02 1.00 64% 0.03 0.05 2 0 0.02 5 0.00 0.																						
Opt-OutE 7000 700																		-				
Opt-Outlies 7000 7002 Vending Misers (Refrigerated glass-Front units) Office 2014 2054 1.58 0.27 0.19 0.52 25% 0.01 0.00	Opt-Out/Ex	7000	7000 Base Refrigerated Vending Machines	Office	2014	2054	2.10	0.31	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.10	0.31	0.00
Opt-Our Description Opt-Our Description Office 2014 2054																						
Opt-Out/Ep 7100 7101 Vending Misers (Non-Refrigerated) Office 2014 2054 0.03 0.01 0.03 0.03 46% 0.00 0.00 0.00 23% 0.44 0.44 6 6 6 0.12 0.00 0.																				0.05	0.01	
Opt-Out/Ep 7300 Base Flyer Office 2014 2054 0.39 0.06 0.00 0																				0.00	0.01	
Opt-Out/Ep 7400 7400 Base Steamer Office 2014 2054 0.81 0.12 0.00																						
Opt-Out/Ex 8000 8000 Base Heating, Hear Pump (7.7 HSPF) Office 2014 2054 8.56 0.00																						
Opt-Out/Ex 8000 8001 Heat Pump Úpgrade (15 SEER, 8.2 HSPF) Office 2014 2054 8.08 0.00 0.48 0.48 6.9 0.00																						
Opt-Out/Ex 9500 9500 Base Miscellaneous Office 2014 2054 74.29 10.81 0.00																						
Opt-Out/Ex 950 Strains Str																						
Opt-Out/Ex 1030 1030 Base Fluorescent Fixture, 4L4TR, 1EB, 2020 Retail 2020 2054 17,68 3.20 0.00 0.																				14.20	10.01	
Opt-Out/Ex 1030 1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 Retail 2020 2054 16.30 3.00 1.34 1.38 8% 0.19 0.20 6% 0.02 0.02 0 0 4.08 1.34 Opt-Out/Ex 1030 1031 ROB 4L4* High Performance T8 (68 W), 2020 Retail 2020 2054 14.61 2.70 1.70 1.70 1.70 1.70 0.51 1.76 0.02 0 0 2.41 1.70 1.70 0.00 0.05 1.88 0.27 0.05 1 0 0.22 0.00 0 2.41 1.70 1.70 1.70 1.70 0.31 0.50 16% 0.02 0.02 0 0 2.41 1.70 0.00 0 0.00 0 2.41 1.70 0.00 0.00 0.00 0.00 0.02 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.00 0.0	Opt-Out/Ex	1030	1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	Retail	2020	2054	17.68	3.20	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	17.68	3.20	0.00
Opt-OuVE 1030 1031 ROB 4L4 High Performance T8 (86 W), 2020 Retail 2020 2054 14.61 2.70 1.70 3.07 17% 0.31 0.50 16% 0.03 0.02 0 0 2.41 1.70 0.																						
Opt-Out/Ex 1030 1032 ROB 4L4* Low Watt High Performance T8 (75 W), 2020 Retail 2020 2054 14.25 2.63 0.36 3.43 19% 0.07 0.57 18% 0.27 0.05 1 0 0.22 0.00 Opt-Out/Ex 1030 1037 Occupancy Sensor, 4L4* Fluorescent Fixtures, 2020 Retail 2020 2054 14.04 2.62 0.21 3.84 21% 0.01 0.58 18% 0.09 0.05 2 0 0.64 0.00 Opt-Out/Ex 1030 1034 ROB 4L4* LED Tube, 2020 Retail 2020 2054 11.78 2.21 2.26 5.90 33% 0.41 0.99 31% 0.28 0.14 2 1 0.64 0.00 Opt-Out/Ex 1030 1035 LED Troffer (base 4L4T8), 2020 Retail 2020 2054 10.77 2.03 1.01 6.91 39% 0.18 1.17 36% 0.23 0.15 1 0.26 0.00																						
Opt-Out/Ex 1030 1034 ROB 4L4 LED Tube, 2020 Retail 2020 2054 11.78 2.21 2.26 5.90 33% 0.41 0.99 31% 0.28 0.14 2 1 0.26 0.00 Opt-Out/Ex 1030 1035 LED Troffer (base 4L4TB), 2020 Retail 2020 2054 10.77 2.03 1.01 6.91 39% 0.18 1.17 36% 0.23 0.15 1 1 0.31 0.00																						
Opt-Out/Ex 1030 1035 LED Troffer (base 4L4T8), 2020 Retail 2020 2054 10.77 2.03 1.01 6.91 39% 0.18 1.17 36% 0.23 0.15 1 1 0.31 0.00																		0				
																	_	1				
Opti-Outlies 1100 1100 Date 1100 responsibility (International Control of the Con	Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Retail	2020	2054	3.53	0.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.53	0.64	0.00

APPENDIX H

Base Avoided Costs

	ST ADDITIVE	SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		easure	Building	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base	Economic GWH
Sgmt N Opt-Out/Ex	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Type Retail	2020	2054	3.52	0.64	0.01	0.01	0%	0.00	0.00	0%	0.02	0.02	0	0	2.65	GWH	IVIVV	0.01
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Retail	2020	2054	3.26	0.60	0.27	0.28	8%	0.04	0.04	6%	0.03	0.03	0	0	2.39			0.27
Opt-Out/Ex Opt-Out/Ex	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Retail Retail	2020 2020	2054 2054	2.92 2.55	0.54 0.47	0.34 0.37	0.61 0.99	17% 28%	0.06 0.07	0.10 0.17	16% 26%	0.03 0.07	0.03 0.04	0	0	1.90 0.91			0.34 0.00
Opt-Out/Ex	1130	1134 ROB 2L4' LED Tube, 2020	Retail	2020	2054	2.42	0.45	0.12	1.11	31%	0.02	0.19	30%	0.25	0.07	1	0	0.29			0.00
Opt-Out/Ex	1130	1135 LED Troffer (base 2L4'T8), 2020	Retail	2020	2054	2.22	0.41	0.21	1.32	37%	0.04	0.23	36%	0.31	0.11	2 5	1	0.23			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1200	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020 1200 Base Other Fluorescent Fixture	Retail Retail	2020 2014	2054 2054	2.18 0.03	0.41	0.03	1.35 0.00	38% 0%	0.00	0.23	36% 0%	0.20 N/A	0.11 N/A	N/A	N/A	0.28 N/A	0.03	0.00	0.00
Opt-Out/Ex	1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	Retail	2014	2054	0.03	0.00	0.00	0.00	1%	0.00	0.00	1%	0.01	0.01	0	0	8.19			0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent 1201 ROB High Performance T8 (base other fluorescent)	Retail Retail	2014 2014	2054 2054	0.03 0.02	0.00	0.00	0.00 0.01	9% 18%	0.00	0.00	7% 16%	0.06 0.10	0.05 0.08	0	0	1.22 0.59			0.00
Opt-Out/Ex	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Retail	2014	2054	0.02	0.00	0.00	0.01	21%	0.00	0.00	17%	0.12	0.08	3	1	0.47			0.00
Opt-Out/Ex	1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Retail	2020	2054	6.70	1.21	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.70	1.21	0.00
Opt-Out/Ex Opt-Out/Ex	1330 1430	1332 LEDs (base incandescent flood) 2020 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Retail Retail	2020 2020	2054 2054	1.17 2.41	0.21 0.44	5.52 0.00	5.52 0.00	82% 0%	1.00 0.00	1.00 0.00	82% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	9.44 N/A	2.41	0.44	5.52 0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	Retail	2020	2054	0.46	0.08	1.95	1.95	81%	0.35	0.35	81%	0.01	0.01	0	0	7.97			1.95
Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Retail	2020	2054	1.77	0.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.77	0.32	0.00
Opt-Out/Ex Opt-Out/Ex	1530 1630	1532 LEDs (base incandescent A-line 53W) 2020 1630 Base CFL 18W to screw-in replacement 2020	Retail Retail	2020 2020	2054 2054	0.46 1.96	0.08 0.35	1.31 0.00	1.31 0.00	74% 0%	0.24 0.00	0.24 0.00	74% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	5.92 N/A	1.96	0.35	1.31 0.00
Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Retail	2020	2054	1.42	0.26	0.54	0.54	28%	0.10	0.10	28%	0.06	0.06	0	0	0.94		0.00	0.00
Opt-Out/Ex	1730	1730 Base CFL 23W to screw-in replacement 2020	Retail	2020	2054	2.51	0.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.51	0.45	0.00
Opt-Out/Ex Opt-Out/Ex	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Retail Retail	2020 2014	2054 2054	1.85 0.00	0.34	0.65 0.00	0.65 0.00	26% 0%	0.12	0.12 0.00	26% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.25 N/A	0.00	0.00	0.65 0.00
Opt-Out/Ex	1850	1850 Base CFL Exit Sign	Retail	2014	2054	0.22	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.22	0.04	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	Retail Retail	2014	2054	0.10	0.02	0.13	0.13	56%	0.02	0.02	56%	0.04	0.04 N/A	0	0	1.45	0.00	0.04	0.13
Opt-Out/Ex Opt-Out/Ex	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Retail	2014 2014	2054 2054	3.60 2.79	0.24 0.08	0.00 0.81	0.00 0.81	0% 23%	0.00 0.16	0.00 0.16	0% 66%	N/A 0.06	0.06	N/A 0	N/A 0	N/A 1.53	3.60	0.24	0.00 0.81
Opt-Out/Ex	1900	1902 LED Outdoor Area Lighting	Retail	2014	2054	1.34	-0.01	1.45	2.26	63%	0.09	0.25	106%	0.13	0.10	2	1	0.53			0.00
Opt-Out/Ex Opt-Out/Ex	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Retail Retail	2014 2014	2054 2054	0.95	-0.04 0.40	0.39	2.65	74% 0%	0.02	0.27 0.00	116% 0%	0.86 N/A	0.22 N/A	14 N/A	2 N/A	0.08 N/A	0.48	0.40	0.00
Opt-Out/Ex	2000	2010 Ceiling/roof Insulation - Chiller	Retail	2014	2054	0.46	0.40	0.00	0.00	1%	0.00	0.00	1%	0.03	0.03	0	0	4.91	0.46	0.40	0.00
Opt-Out/Ex	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Retail	2014	2054	0.43	0.36	0.04	0.04	9%	0.03	0.04	9%	0.04	0.04	0	0	3.01			0.04
Opt-Out/Ex Opt-Out/Ex	2000 2000	2003 EMS - Chiller 2012 Duct Testing/Sealing	Retail Retail	2014 2014	2054 2054	0.40 0.32	0.35 0.29	0.04	0.08 0.16	17% 33%	0.01 0.06	0.04 0.11	11% 27%	0.08 0.23	0.06 0.14	0	0	0.94 0.56			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Retail	2014	2054	16.88	13.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	16.88	13.95	0.00
Opt-Out/Ex	2100	2102 DX Packaged System, EER=13.4, 10 tons	Retail	2014	2054	13.00	10.74	3.88	3.88	23%	3.21	3.21	23%	0.04	0.04	0	0	3.17			3.88
Opt-Out/Ex Opt-Out/Ex	2100 2100	2111 Economizer Repair - DX 2107 Cool Roof - DX	Retail Retail	2014 2014	2054 2054	12.09 11.56	9.68 9.24	0.91 0.54	4.79 5.33	28% 32%	1.06	4.27 4.71	31% 34%	0.08	0.05	0	0	1.13 0.87			0.91
Opt-Out/Ex	2100	2108 Optimize Controls - DX	Retail	2014	2054	11.37	9.20	0.19	5.52	33%	0.04	4.76	34%	0.10	0.06	0	0	0.56			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2109 Economizer - DX 2112 Aerosol Duct Sealing - DX	Retail Retail	2014 2014	2054 2054	10.40 9.77	8.99 8.47	0.97 0.63	6.49 7.12	38% 42%	0.21 0.52	4.96 5.49	36% 39%	0.13 0.31	0.07	1	0	0.50 0.42			0.00
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX 2106 Prog. Thermostat - DX	Retail	2014	2054	9.77	8.47	0.63	7.12	42% 44%	0.52	5.49	39% 40%	0.31	0.09	1	0	0.42			0.00
Opt-Out/Ex	2100	2115 Window Film (Standard) - DX	Retail	2014	2054	9.46	8.38	0.03	7.42	44%	0.03	5.57	40%	0.38	0.09	0	0	0.27			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2114 Duct/Pipe Insulation - DX	Retail Retail	2014 2014	2054 2054	9.46 9.39	8.38 8.32	0.00 0.07	7.43 7.50	44% 44%	0.00	5.57 5.63	40% 40%	0.29 3.43	0.09 0.12	1 4	0	0.23 0.03			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Retail	2014	2054	6.27	5.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	6.27	5.18	0.00
Opt-Out/Ex	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	2014	2054	5.50	4.54	0.78	0.78	12%	0.64	0.64	12%	0.03	0.03	0	0	4.44			0.78
Opt-Out/Ex Opt-Out/Ex	2300 3000	2300 Base PTAC, EER=8.3, 1 ton 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Retail Retail	2014 2014	2054 2054	1.11 11.44	0.91 3.21	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	1.11 11.44	0.91 3.21	0.00
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Retail	2014	2054	11.26	3.15	0.00	0.18	2%	0.05	0.05	2%	0.02	0.02	0	0	3.79	11.44	3.21	0.18
Opt-Out/Ex	3000	3002 Variable Speed Drive Control, 5 HP	Retail	2014	2054	7.88	2.92	3.38	3.56	31%	0.24	0.29	9%	0.02	0.02	0	0	3.59			3.38
Opt-Out/Ex Opt-Out/Ex	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Retail Retail	2014 2014	2054 2054	7.06 0.40	2.48 0.11	0.83	4.38 0.00	38% 0%	0.44	0.73 0.00	23% 0%	1.16 N/A	0.23 N/A	2 N/A	1 N/A	0.09 N/A	0.40	0.11	0.00
Opt-Out/Ex	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Retail	2014	2054	0.34	0.10	0.06	0.06	14%	0.01	0.01	13%	0.03	0.03	0	0	2.72	0.10	0.11	0.06
Opt-Out/Ex	3100	3103 Air Handler Optimization, 15 HP	Retail Retail	2014	2054	0.31	0.09	0.03	0.09 0.18	23% 46%	0.00	0.02	15%	0.03 0.07	0.03	0	0	2.08 0.97			0.03
Opt-Out/Ex Opt-Out/Ex	3100 3100	3102 Variable Speed Drive Control, 15 HP 3101 Fan Motor, 15hp, 1800rpm, 92.4%	Retail	2014 2014	2054 2054	0.22 0.21	0.09	0.09	0.18	46% 46%	0.01	0.02	21% 21%	0.07	0.05 0.05	1	0	0.43			0.00
Opt-Out/Ex	3100	3105 Energy Recovery Ventilation (ERV)	Retail	2014	2054	0.20	0.08	0.01	0.20	50%	0.01	0.03	28%	0.46	0.08	1	Ō	0.25			0.00
Opt-Out/Ex	3100	3107 Demand Controlled Ventilation	Retail	2014	2054	0.18 0.40	0.07	0.02	0.22	55%	0.01	0.04	38%	1.59	0.22 N/A	3	1	0.06	0.40	0.44	0.00
Opt-Out/Ex Opt-Out/Ex	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3203 Air Handler Optimization, 40 HP	Retail Retail	2014 2014	2054 2054	0.40	0.11 0.11	0.00 0.04	0.00 0.04	0% 10%	0.00	0.00	0% 3%	N/A 0.02	0.02	N/A 0	N/A 0	N/A 2.44	0.40	0.11	0.00 0.04
Opt-Out/Ex	3200	3202 Variable Speed Drive Control, 40 HP	Retail	2014	2054	0.25	0.10	0.11	0.15	37%	0.01	0.01	9%	0.06	0.05	1	1	1.16			0.11
Opt-Out/Ex Opt-Out/Ex	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Retail Retail	2014 2014	2054 2054	0.25 0.22	0.10 0.09	0.00	0.15 0.17	37% 44%	0.00	0.01 0.02	9% 22%	0.28 1.27	0.05 0.23	1	1 2	0.32 0.08			0.00
Opt-Out/Ex	4000	4000 Base Built-Up Refrigeration System	Retail	2014	2054	0.22	0.09	0.03	0.00	0%	0.00	0.02	0%	N/A	0.23 N/A	N/A	N/A	0.06 N/A	0.00	0.00	0.00
Opt-Out/Ex	4100	4100 Base Self-Contained Refrigeration	Retail	2014	2054	9.21	1.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.21	1.40	0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4103 Night covers for display cases (self-contained) 4109 Energy-Star Freezer, glass door	Retail Retail	2014 2014	2054 2054	9.03	1.37 1.37	0.18 0.04	0.18 0.21	2% 2%	0.03 0.01	0.03	2% 2%	0.01 0.04	0.01 0.01	0	0	5.83 1.72			0.18 0.04
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door 4104 Freezer-Cooler Replacement Gaskets (self-contained)	Retail	2014	2054	8.80	1.34	0.04	0.41	4%	0.03	0.03	4%	0.04	0.01	0	0	1.50			0.19
Opt-Out/Ex	4100	4107 Energy-Star Freezer, solid door	Retail	2014	2054	8.79	1.34	0.02	0.42	5%	0.00	0.06	5%	0.09	0.03	1	0	0.69			0.00
Opt-Out/Ex	4100 4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Retail Retail	2014 2014	2054 2054	8.64 8.62	1.31 1.31	0.15	0.57 0.59	6% 6%	0.02	0.09	6% 6%	0.11 0.12	0.05	1	0	0.59 0.54			0.00
Opt-Out/Ex	4100	4112 Reach-in unit occupancy sensors	Retail	2014	2054	8.58	1.30	0.04	0.63	7%	0.01	0.10	7%	0.28	0.06	2	0	0.23			0.00
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Retail	2014	2054	8.56	1.30	0.02	0.65	7%	0.00	0.10	7%	0.32	0.07	2	0	0.20			0.00

APPENDIX H

Base Avoided Costs

		empt/Nonjurisdictional Existing SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	33.12.7.13.2.13.3		Measure		· oui	2014		Total	Percent		Total	Bereit	Marginal	Average	Marginal		Total			00.12.
В	Base Me	easure	Building	Start	Measure End	Total	Total	GWH	Energy Savings	GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic
Sgmt N Opt-Out/Ex	lumber Nu 4100	mber Measure 4105 Bi-level LED Case Lighting (self-contained units) 2014	Type Retail	Year 2014	Year 2054	GWH 8.49	MW 1.29	Savings 0.07	0.72	Savings 8%	Savings 0.01	MW 0.11	Savings 8%	\$/kWH 0.32	\$/kWH 0.10	\$/kW 2	\$/kW	0.19	GWH	MW	GWH 0.00
Opt-Out/Ex	4100	4103 Briever LED Case Lighting (self-contained units) 2014 4101 Strip curtains for walk-ins (self-contained)	Retail	2014	2054	8.48	1.29	0.07	0.72	8%	0.00	0.11	8%	1.94	0.10	13	1	0.19			0.00
Opt-Out/Ex	5000	5000 Base Desktop PC	Retail	2014	2054	0.43	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.43	0.08	0.00
Opt-Out/Ex Opt-Out/Ex	5000 5000	5002 Energy Star or Better PC 5001 PC Network Power Management Enabling	Retail Retail	2014 2014	2054 2054	0.36 0.20	0.06 0.05	0.06 0.16	0.06 0.23	15% 53%	0.01 0.01	0.01 0.03	15% 35%	0.01 0.02	0.01 0.02	0	0	3.72 2.93			0.06 0.16
Opt-Out/Ex	5100	5100 Base Laptop PC	Retail	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
Opt-Out/Ex	5100	5102 Energy Star or Better Laptop	Retail	2014	2054	0.01	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	4.83			0.00
Opt-Out/Ex Opt-Out/Ex	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Retail Retail	2014 2014	2054 2054	0.01 0.14	0.00 0.02	0.00	0.00	21% 0%	0.00	0.00	21% 0%	1.38 N/A	0.12 N/A	8 N/A	1 N/A	0.04 N/A	0.14	0.02	0.00
Opt-Out/Ex	5200	5201 Energy Star or Better Monitor - CRT	Retail	2014	2054	0.06	0.01	0.08	0.08	56%	0.01	0.01	56%	0.00	0.00	0	0	38.40	0.11	0.02	0.08
Opt-Out/Ex	5200	5202 Monitor Power Management Enabling - CRT	Retail	2014	2054	0.05	0.01	0.01	0.09	63%	0.00	0.01	60%	0.02	0.00	0	0	2.95			0.01
Opt-Out/Ex Opt-Out/Ex	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Retail Retail	2014 2014	2054 2054	0.05 0.06	0.01 0.01	0.00	0.09	66% 0%	0.00	0.02	63% 0%	0.21 N/A	0.01 N/A	1 N/A	0 N/A	0.26 N/A	0.06	0.01	0.00
Opt-Out/Ex	5300	5301 Energy Star or Better Monitor - LCD	Retail	2014	2054	0.05	0.01	0.01	0.01	14%	0.00	0.00	14%	0.01	0.01	0	0	5.92	0.00	0.01	0.01
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	Retail	2014	2054	0.05	0.01	0.00	0.01	17%	0.00	0.00	16%	0.09	0.02	1	0	0.58			0.00
Opt-Out/Ex Opt-Out/Ex	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Retail Retail	2014 2014	2054 2054	0.05 0.21	0.01 0.04	0.00 0.00	0.01 0.00	24% 0%	0.00	0.00	17% 0%	0.25 N/A	0.08 N/A	5 N/A	1 N/A	0.19 N/A	0.21	0.04	0.00
Opt-Out/Ex	5400	5401 Energy Star or Better Copier	Retail	2014	2054	0.18	0.03	0.03	0.03	14%	0.01	0.01	14%	0.00	0.00	0	0	28.81	0.21	0.01	0.03
Opt-Out/Ex	5400	5402 Copier Power Management Enabling	Retail	2014	2054	0.17	0.03	0.01	0.04	18%	0.00	0.01	16%	0.11	0.03	1	0	0.50			0.00
Opt-Out/Ex Opt-Out/Ex	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Retail Retail	2014 2014	2054 2054	0.03 0.02	0.01 0.00	0.00 0.01	0.00 0.01	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.20	0.03	0.01	0.00 0.01
Opt-Out/Ex	5500	5501 Multifunction Power Management Enabling	Retail	2014	2054	0.02	0.00	0.00	0.01	36%	0.00	0.00	30%	0.01	0.09	3	1	0.19			0.00
Opt-Out/Ex	5600	5600 Base Printer	Retail	2014	2054	0.09	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.02	0.00
Opt-Out/Ex Opt-Out/Ex	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Retail Retail	2014 2014	2054 2054	0.06 0.05	0.01 0.01	0.03 0.01	0.03 0.04	35% 44%	0.01 0.00	0.01 0.01	35% 39%	0.00 0.06	0.00 0.01	0	0	37.69 0.87			0.03
Opt-Out/Ex	5700	5700 Base Data Center/Server Room	Retail	2014	2054	0.37	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.37	0.07	0.00
Opt-Out/Ex	5700	5701 Data Center Improved Operations	Retail	2014	2054	0.33	0.06	0.04	0.04	10%	0.01	0.01	10%	0.00	0.00	0	0	135.09			0.04
Opt-Out/Ex Opt-Out/Ex	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Retail Retail	2014 2014	2054 2054	0.29 0.28	0.05 0.05	0.04 0.02	0.08 0.10	21% 26%	0.01	0.01 0.02	21% 26%	0.00	0.00	0	0	55.00 28.52			0.04 0.02
Opt-Out/Ex	6000	6000 Base Water Heating	Retail	2014	2054	1.76	0.03	0.02	0.00	0%	0.00	0.02	0%	N/A	N/A	N/A	N/A	N/A	1.76	0.28	0.02
Opt-Out/Ex	6000	6007 Heat Trap	Retail	2014	2054	1.67	0.27	0.09	0.09	5%	0.01	0.01	5%	0.02	0.02	0	0	3.20			0.09
Opt-Out/Ex Opt-Out/Ex	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Retail Retail	2014 2014	2054 2054	1.63 1.51	0.26 0.24	0.03 0.12	0.12 0.25	7% 14%	0.01 0.02	0.02 0.04	7% 14%	0.04 0.07	0.03 0.05	0	0	1.72 1.23			0.03 0.12
Opt-Out/Ex	6000	6008 Solar Water Heater	Retail	2014	2054	1.47	0.24	0.12	0.25	16%	0.02	0.04	16%	0.07	0.05	0	0	1.25			0.12
Opt-Out/Ex	6000	6003 Hot Water Pipe Insulation	Retail	2014	2054	1.44	0.23	0.02	0.31	18%	0.00	0.05	18%	0.08	0.05	0	0	0.92			0.00
Opt-Out/Ex	6000 6000	6006 Heat Recovery Unit	Retail Retail	2014 2014	2054 2054	1.40 1.38	0.22 0.22	0.05	0.36	20% 22%	0.01	0.06	20% 22%	0.09	0.06	1	0	0.72			0.00
Opt-Out/Ex Opt-Out/Ex	7000	6001 Demand controlled circulating systems 7000 Base Refrigerated Vending Machines	Retail	2014	2054	0.44	0.22	0.02	0.38	0%	0.00	0.06	0%	0.13 N/A	0.06 N/A	N/A	N/A	0.57 N/A	0.44	0.08	0.00
Opt-Out/Ex	7000	7001 Vending Misers (Refrigerated units)	Retail	2014	2054	0.37	0.07	0.07	0.07	16%	0.01	0.01	8%	0.03	0.03	0	0	2.00			0.07
Opt-Out/Ex	7000	7002 Vending Misers (Refrigerated glass-front units)	Retail	2014	2054	0.33	0.07	0.04	0.11	25%	0.00	0.01	12%	0.05	0.03	1	0	1.09	0.00	0.00	0.04
Opt-Out/Ex Opt-Out/Ex	7100 7100	7100 Base Non-Refrigerated Vending Machines 7101 Vending Misers (Non-Refrigerated)	Retail Retail	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 46%	0.00	0.00	0% 23%	N/A 0.44	N/A 0.44	N/A 5	N/A 5	N/A 0.12	0.00	0.00	0.00
Opt-Out/Ex	7200	7200 Base Oven	Retail	2014	2054	0.28	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.28	0.05	0.00
Opt-Out/Ex	7200	7201 Convection Oven	Retail	2014	2054	0.21	0.04	0.06	0.06	23%	0.01	0.01	23%	0.13	0.13	1	1	0.53	0.05	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	7300 7300	7300 Base Fryer 7301 Efficient Fryer	Retail Retail	2014 2014	2054 2054	0.05 0.05	0.01 0.01	0.00	0.00	0% 6%	0.00	0.00	0% 6%	N/A 0.43	N/A 0.43	N/A 2	N/A 2	N/A 0.16	0.05	0.01	0.00
Opt-Out/Ex	7400	7400 Base Steamer	Retail	2014	2054	0.20	0.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.20	0.04	0.00
Opt-Out/Ex	7400	7401 Efficient Steamer	Retail	2014	2054	0.07	0.01	0.13	0.13	64%	0.02	0.02	64%	0.05	0.05	0	0	1.35			0.13
Opt-Out/Ex Opt-Out/Ex	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail Retail	2014 2014	2054 2054	0.31 0.29	0.00	0.00 0.02	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.04	N/A 0.04	N/A N/A	N/A N/A	N/A 1.66	0.31	0.00	0.00 0.02
Opt-Out/Ex	8100	8100 Base Heating, Other Electric	Retail	2014	2054	1.14	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.14	0.00	0.00
Opt-Out/Ex	9500	9500 Base Miscellaneous	Retail	2014	2054	27.46	4.91	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	27.46	4.91	0.00
Opt-Out/Ex Opt-Out/Ex	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4T8, 1EB, 2020	Retail Grocery	2014 2020	2054 2054	27.46 0.33	4.91 0.05	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	0.33	0.05	0.00
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Grocery	2020	2054	0.33	0.05	0.00	0.00	0%	0.00	0.00	0%	0.01	0.01	0	0	4.92	2.30	2.00	0.00
Opt-Out/Ex	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Grocery	2020	2054	0.31	0.05	0.03	0.03	8%	0.00	0.00	6%	0.02	0.02	0	0	4.31			0.03
Opt-Out/Ex Opt-Out/Ex	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Grocery Grocery	2020 2020	2054 2054	0.28 0.25	0.04 0.04	0.03	0.06 0.08	17% 25%	0.00	0.01 0.01	15% 23%	0.04 0.11	0.03	0	0	1.38 0.49			0.03
Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Grocery	2020	2054	0.25	0.04	0.00	0.09	26%	0.00	0.01	24%	0.11	0.06	3	0	0.50			0.00
Opt-Out/Ex	1030	1034 ROB 4L4' LED Tube, 2020	Grocery	2020	2054	0.21	0.03	0.04	0.13	38%	0.01	0.02	35%	0.48	0.19	3	1	0.13			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Grocery Grocery	2020 2020	2054 2054	0.19 0.00	0.03	0.02 0.00	0.14 0.00	43% 0%	0.00	0.02	41% 0%	0.40 N/A	0.22 N/A	3 N/A	2 N/A	0.15 N/A	0.00	0.00	0.00
Opt-Out/Ex	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.01	0.01	0	0	4.11	0.00	0.00	0.00
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	8%	0.00	0.00	6%	0.02	0.02	0	0	3.60			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Grocery Grocery	2020 2020	2054 2054	0.00	0.00	0.00	0.00	17% 27%	0.00	0.00	15% 26%	0.05 0.11	0.04 0.06	0	0	1.09 0.52			0.00
Opt-Out/Ex	1130	1132 ROB 2L4 Low Watt High Performance 18 (75 W), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	27%	0.00	0.00	26%	0.11	0.06	6	0	0.52			0.00
Opt-Out/Ex	1130	1134 ROB 2L4' LED Tube, 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	32%	0.00	0.00	29%	0.40	0.10	3	1	0.15			0.00
Opt-Out/Ex	1130	1135 LED Troffer (base 2L4'T8), 2020	Grocery	2020	2054	0.00	0.00	0.00	0.00	38%	0.00	0.00	35%	0.51	0.17	3	1	0.12	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1200 1330	1200 Base Other Fluorescent Fixture 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Grocery Grocery	2014 2020	2054 2054	0.00	0.00 0.02	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 0.10	0.00	0.00
Opt-Out/Ex	1330	1332 LEDs (base incandescent flood) 2020	Grocery	2020	2054	0.04	0.01	0.06	0.06	62%	0.01	0.01	62%	0.01	0.01	0	0	10.39			0.06
Opt-Out/Ex	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Grocery	2020	2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	Grocery	2020	2054	0.01	0.00	0.02	0.02	60%	0.00	0.00	60%	0.01	0.01	0	0	8.59			0.02

APPENDIX H

Base Avoided Costs

		cempt/Nonjurisdictional Existing				V	0044														SUPPLY
Vintage	I ADDITIVE	E SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
В.	ase M	easure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity Cost	Resource Cost Test	Base	Base	Economic
		umber Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH
Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Grocery	2020	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1530 1630	1532 LEDs (base incandescent A-line 53W) 2020 1630 Base CFL 18W to screw-in replacement 2020	Grocery Grocery	2020 2020	2054 2054	0.01 0.01	0.00	0.01 0.00	0.01 0.00	50% 0%	0.00	0.00	50% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	5.82 N/A	0.01	0.00	0.01 0.00
Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Grocery	2020	2054	0.01	0.00	0.00	0.00	28%	0.00	0.00	28%	0.12	0.12	1	1	0.48			0.00
Opt-Out/Ex	1730	1730 Base CFL 23W to screw-in replacement 2020	Grocery	2020	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Grocery Grocery	2020 2014	2054 2054	0.01	0.00	0.00	0.00	26% 0%	0.00	0.00	26% 0%	0.09 N/A	0.09 N/A	1 N/A	1 N/A	0.64 N/A	0.02	0.00	0.00
Opt-Out/Ex	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Grocery	2014	2054	0.02	0.00	0.00	0.00	8%	0.00	0.00	6%	0.01	0.01	0	0	9.93	0.02	0.00	0.00
Opt-Out/Ex	1800 1800	1801 T5 (240W) (base metal halide)	Grocery	2014 2014	2054	0.01	0.00	0.01	0.01	39% 41%	0.00	0.00	37%	0.02 0.04	0.01	0 1	0	4.91			0.01
Opt-Out/Ex Opt-Out/Ex	1850	1806 Occupancy Sensor, High Bay T5 1850 Base CFL Exit Sign	Grocery Grocery	2014	2054 2054	0.01	0.00	0.00	0.01	41% 0%	0.00	0.00	38% 0%	0.04 N/A	0.02 N/A	N/A	N/A	1.40 N/A	0.00	0.00	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	Grocery	2014	2054	0.00	0.00	0.00	0.00	2%	0.00	0.00	2%	0.03	0.03	0	0	1.75			0.00
Opt-Out/Ex Opt-Out/Ex	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Grocery	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 20%	0.00	0.00	0% 66%	N/A 0.11	N/A 0.11	N/A 1	N/A 1	N/A 0.69	0.01	0.00	0.00
Opt-Out/Ex	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Grocery Grocery	2014	2054	0.00	0.00	0.00	0.00	62%	0.00	0.00	107%	0.11	0.11	10	5	0.69			0.00
Opt-Out/Ex	1900	1903 Bi-Level LED Outdoor Lighting	Grocery	2014	2054	0.00	0.00	0.00	0.00	73%	0.00	0.00	117%	1.49	0.39	69	10	0.04			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Grocery	2014	2054	0.01	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2013 High Efficiency Chiller Motors	Grocery Grocery	2014 2014	2054 2054	0.01 0.01	0.01 0.01	0.00	0.00	9% 11%	0.00	0.00	9% 11%	0.04 0.07	0.04 0.05	0	0	2.76 1.76			0.00
Opt-Out/Ex	2000	2006 VSD for Chiller Pumps and Towers	Grocery	2014	2054	0.01	0.01	0.00	0.00	20%	0.00	0.00	16%	0.05	0.05	0	0	1.54			0.00
Opt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	Grocery	2014	2054	0.01	0.00	0.00	0.00	26%	0.00	0.00	21%	0.10	0.06	0	0	0.94			0.00
Opt-Out/Ex Opt-Out/Ex	2000	2003 EMS - Chiller 2004 Cool Roof - Chiller	Grocery Grocery	2014 2014	2054 2054	0.01	0.00	0.00	0.00	33% 38%	0.00	0.00	23% 28%	0.09 0.15	0.07	1	0	0.78			0.00
Opt-Out/Ex	2000	2012 Duct Testing/Sealing	Grocery	2014	2054	0.00	0.00	0.00	0.00	50%	0.00	0.00	40%	0.13	0.08	0	0	0.02			0.00
Opt-Out/Ex	2000	2011 Duct/Pipe Insulation - Chiller	Grocery	2014	2054	0.00	0.00	0.00	0.00	51%	0.00	0.00	41%	4.68	0.20	7	0	0.02			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2100	2008 New Economizer - Chiller 2100 Base DX Packaged System, EER=10.3, 10 tons	Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	51% 0%	0.00	0.00	41% 0%	50270.28 N/A	0.20 N/A	316,012 N/A	0 N/A	0.00 N/A	0.29	0.19	0.00
Opt-Out/Ex	2100	2110 Base DX Packaged System, EER=10.3, 10 tons 2113 Ceiling/roof Insulation - DX	Grocery Grocery	2014	2054	0.29	0.19	0.00	0.00	0%	0.00	0.00	0%	0.04	0.04	N/A 0	N/A 0	3.34	0.29	0.19	0.00
Opt-Out/Ex	2100	2102 DX Packaged System, EER=13.4, 10 tons	Grocery	2014	2054	0.22	0.14	0.07	0.07	23%	0.04	0.04	23%	0.04	0.04	0	0	2.89			0.07
Opt-Out/Ex	2100	2115 Window Film (Standard) - DX	Grocery	2014	2054	0.21	0.13	0.02	0.08	28%	0.01	0.05	28%	0.10	0.05	0	0	0.91			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2107 Cool Roof - DX 2108 Optimize Controls - DX	Grocery Grocery	2014 2014	2054 2054	0.19 0.19	0.12 0.12	0.02	0.10 0.10	34% 35%	0.01 0.00	0.06 0.06	34% 34%	0.14 0.12	0.06 0.07	0 1	0	0.67 0.46			0.00
Opt-Out/Ex	2100	2106 Prog. Thermostat - DX	Grocery	2014	2054	0.18	0.12	0.00	0.10	36%	0.00	0.06	34%	0.14	0.07	i	0	0.41			0.00
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Grocery	2014	2054	0.17	0.12	0.01	0.12	40%	0.01	0.07	38%	0.29	0.09	0	0	0.39			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2111 Economizer Repair - DX	Grocery Grocery	2014 2014	2054 2054	0.17	0.12 0.11	0.00	0.12 0.12	40% 41%	0.00	0.07 0.07	38% 39%	0.84 1.63	0.09	5	0	0.07			0.00
Opt-Out/Ex	2100	2109 Economizer - DX	Grocery	2014	2054	0.17	0.11	0.00	0.12	41%	0.00	0.07	39%	2.04	0.11	13	0	0.03			0.00
Opt-Out/Ex	2100	2114 Duct/Pipe Insulation - DX	Grocery	2014	2054	0.17	0.11	0.00	0.12	42%	0.00	0.08	40%	3.93	0.20	6	0	0.02			0.00
Opt-Out/Ex	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	2014 2014	2054 2054	0.03	0.02 0.01	0.00	0.00	0% 12%	0.00	0.00	0%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.31	0.03	0.02	0.00
Opt-Out/Ex Opt-Out/Ex	2300	2300 Base PTAC, EER=8.3, 1 ton	Grocery Grocery	2014	2054	0.02	0.01	0.00	0.00	0%	0.00	0.00	12% 0%	0.03 N/A	0.03 N/A	N/A	N/A	3.31 N/A	0.01	0.01	0.00
Opt-Out/Ex	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Grocery	2014	2054	0.28	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.28	0.06	0.00
Opt-Out/Ex	3000 3000	3002 Variable Speed Drive Control, 5 HP	Grocery	2014	2054	0.19	0.06	0.09	0.09	31% 32%	0.00	0.00	7%	0.03	0.03	1	1	1.84 1.22			0.09
Opt-Out/Ex Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5% 3003 Demand Controlled Ventilation	Grocery Grocery	2014 2014	2054 2054	0.19	0.05	0.00	0.09 0.12	32% 42%	0.00 0.01	0.01 0.02	9% 28%	1.37	0.04 0.34	0 3	2	0.07			0.00
Opt-Out/Ex	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Grocery	2014	2054	0.28	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.28	0.06	0.00
Opt-Out/Ex Opt-Out/Ex	3200 3200	3203 Air Handler Optimization, 40 HP 3204 Demand Controlled Ventilation	Grocery Grocery	2014 2014	2054 2054	0.25 0.21	0.06	0.03	0.03	10% 23%	0.00 0.02	0.00 0.02	3% 28%	0.02 1.04	0.02	0	0	2.22 0.09			0.03
Opt-Out/Ex	4000	4000 Base Built-Up Refrigeration System	Grocery	2014	2054	1.40	0.22	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.40	0.22	0.00
Opt-Out/Ex	4000	4007 Efficient compressor motor	Grocery	2014	2054	1.39	0.22	0.00	0.00	0%	0.00	0.00	0%	0.02	0.02	0	0	3.94			0.00
Opt-Out/Ex	4000 4000	4011 Demand Hot Gas Defrost 4009 Floating head pressure controls	Grocery	2014 2014	2054 2054	1.36 1.36	0.22 0.22	0.03	0.04 0.04	3% 3%	0.01	0.01	3% 3%	0.02 0.02	0.02 0.02	0	0	3.64 3.35			0.03
Opt-Out/Ex	4000	4006 Electronically commutated evaporator fan motor	Grocery	2014	2054	1.26	0.22	0.10	0.14	10%	0.00	0.01	6%	0.02	0.02	0	0	3.02			0.10
Opt-Out/Ex	4000	4013 Anti-sweat (humidistat) controls	Grocery	2014	2054	1.24	0.21	0.02	0.16	11%	0.00	0.02	7%	0.04	0.02	1	0	1.48			0.02
Opt-Out/Ex Opt-Out/Ex	4000 4000	4002 Strip curtains for walk-ins (built-up) 4014 Freezer-Cooler Replacement Gaskets	Grocery Grocery	2014 2014	2054 2054	1.19 1.15	0.20	0.05 0.04	0.20 0.25	15% 18%	0.01 0.01	0.02 0.03	10% 13%	0.04	0.03	0	0	1.37 0.96			0.05 0.00
Opt-Out/Ex	4000	4018 Oversized Air Cooled Condenser	Grocery	2014	2054	1.15	0.19	0.04	0.25	21%	0.01	0.03	17%	0.08	0.03	0	0	0.96			0.00
Opt-Out/Ex	4000	4001 High-efficiency fan motors	Grocery	2014	2054	1.06	0.18	0.04	0.33	24%	0.01	0.04	20%	0.11	0.05	1	0	0.74			0.00
Opt-Out/Ex	4000	4004 Night covers for display cases	Grocery	2014	2054	1.00	0.18	0.06	0.39	28%	0.00	0.04	20%	0.07	0.05	N/A	0	0.65			0.00
Opt-Out/Ex Opt-Out/Ex	4000 4000	4008 Compressor VSD retrofit 4010 Refrigeration Commissioning	Grocery Grocery	2014 2014	2054 2054	0.94	0.18 0.18	0.06	0.46 0.46	33% 33%	0.01 0.00	0.05 0.05	22% 22%	0.10 0.18	0.06	1	1	0.61			0.00
Opt-Out/Ex	4000	4005 Evaporator fan controller for MT walk-ins	Grocery	2014	2054	0.93	0.17	0.00	0.46	33%	0.00	0.05	22%	0.25	0.06	3	1	0.27			0.00
Opt-Out/Ex	4000	4017 Multiplex Compressor System	Grocery	2014	2054	0.92	0.17	0.02	0.48	34%	0.00	0.05	23%	0.27	0.07	2	1	0.26			0.00
Opt-Out/Ex	4000 4000	4016 LED Display Lighting 4015 High R-Value Glass Doors	Grocery	2014 2014	2054 2054	0.84	0.16 0.16	0.07	0.55 0.57	40% 40%	0.01	0.06 0.07	29% 30%	0.45 2.02	0.12	3 13	1	0.13			0.00
Opt-Out/Ex	4100	4100 Base Self-Contained Refrigeration	Grocery	2014	2054	0.83	0.16	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.16	0.03	0.00
Opt-Out/Ex	4100	4103 Night covers for display cases (self-contained)	Grocery	2014	2054	0.16	0.02	0.00	0.00	3%	0.00	0.00	3%	0.00	0.00	0	0	173.50			0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained) 4109 Energy-Star Freezer, glass door	Grocery Grocery	2014 2014	2054 2054	0.15 0.14	0.02	0.00 0.01	0.01 0.01	4% 9%	0.00	0.00	4% 9%	0.01 0.03	0.00 0.02	0	0	3.98 2.43			0.00 0.01
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door 4107 Energy-Star Freezer, solid door	Grocery	2014	2054	0.14	0.02	0.01	0.01	11%	0.00	0.00	9% 11%	0.03	0.02	0	0	0.93			0.00
Opt-Out/Ex	4100	4108 Energy-Star Refrigerator, glass door	Grocery	2014	2054	0.14	0.02	0.00	0.02	11%	0.00	0.00	11%	0.09	0.03	1	ō	0.72			0.00
Opt-Out/Ex	4100	4106 Energy-Star Refrigerator, solid door	Grocery	2014	2054	0.14	0.02	0.00	0.02	11%	0.00	0.00	11%	0.09	0.03	1	0	0.69			0.00
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Grocery	2014	2054	0.14	0.02	0.00	0.02	11%	0.00	0.00	11%	0.24	0.03	1	0	0.27			0.00

DNV GL H-5 1/5/2015

APPENDIX H

Base Avoided Costs

	T ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Manufact		Manadasal		Total			SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		pasure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt No Opt-Out/Ex	umber Nu 4100	Measure 4112 Reach-in unit occupancy sensors	Type Grocery	Year 2014	Year 2054	0.14	0.02	Savings 0.00	0.02	Savings 11%	Savings 0.00	0.00	Savings 11%	\$/kWH 0.29	\$/kWH 0.03	\$/kW	\$/kW	0.22	GWH	MW	0.00
Opt-Out/Ex	4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Grocery	2014	2054	0.14	0.02	0.00	0.02	12%	0.00	0.00	12%	0.34	0.04	2	0	0.18			0.00
Opt-Out/Ex	4100	4101 Strip curtains for walk-ins (self-contained)	Grocery	2014	2054	0.14	0.02	0.00	0.02	13%	0.00	0.00	13%	0.65	0.11	4	1	0.08			0.00
Opt-Out/Ex Opt-Out/Ex	5000 5000	5000 Base Desktop PC 5001 PC Network Power Management Enabling	Grocery Grocery	2014 2014	2054 2054	0.01 0.00	0.00	0.00	0.00	0% 45%	0.00	0.00	0% 23%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.92	0.01	0.00	0.00
Opt-Out/Ex	5000	5002 Energy Star or Better PC	Grocery	2014	2054	0.00	0.00	0.00	0.00	63%	0.00	0.00	41%	0.06	0.04	0	0	0.96			0.00
Opt-Out/Ex	5100	5100 Base Laptop PC	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5100 5100	5102 Energy Star or Better Laptop 5101 Laptop Network Power Management Enabling	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	19% 21%	0.00	0.00	19% 21%	0.02 2.48	0.02 0.22	0 14	0	2.68 0.02			0.00
Opt-Out/Ex	5200	5200 Base Monitor, CRT	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	5200	5201 Energy Star or Better Monitor - CRT	Grocery	2014	2054	0.00	0.00	0.00	0.00	56%	0.00	0.00	56%	0.00	0.00	0	0	21.32			0.00
Opt-Out/Ex Opt-Out/Ex	5200 5200	5202 Monitor Power Management Enabling - CRT 5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	73% 76%	0.00	0.00	65% 67%	0.05 0.52	0.01 0.03	1 3	0	1.00 0.11			0.00
Opt-Out/Ex	5300	5300 Base Monitor, LCD	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	5300	5301 Energy Star or Better Monitor - LCD	Grocery	2014	2054	0.00	0.00	0.00	0.00	20%	0.00	0.00	20%	0.02	0.02	0	0	3.05			0.00
Opt-Out/Ex Opt-Out/Ex	5300 5300	5302 Monitor Power Management Enabling - LCD 5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	31% 36%	0.00	0.00	26% 27%	0.19 0.53	0.08 0.15	2 12	1	0.26 0.09			0.00
Opt-Out/Ex	5400	5400 Base Copier	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.55 N/A	0.15 N/A	N/A	N/A	0.09 N/A	0.00	0.00	0.00
Opt-Out/Ex	5400	5401 Energy Star or Better Copier	Grocery	2014	2054	0.00	0.00	0.00	0.00	20%	0.00	0.00	20%	0.00	0.00	0	0	14.87			0.00
Opt-Out/Ex	5400	5402 Copier Power Management Enabling	Grocery	2014	2054	0.00	0.00	0.00	0.00	31%	0.00	0.00	26%	0.24	0.09	3	1	0.23			0.00
Opt-Out/Ex Opt-Out/Ex	5500 5500	5500 Base Multifunction 5502 ENERGY STAR Multi-Function Device	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 25%	0.00	0.00	0% 25%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.55	0.00	0.00	0.00
Opt-Out/Ex	5500	5501 Multifunction Power Management Enabling	Grocery	2014	2054	0.00	0.00	0.00	0.00	46%	0.00	0.00	36%	0.64	0.30	7	2	0.08			0.00
Opt-Out/Ex	5600	5600 Base Printer	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	5600 5600	5602 ENERGY STAR Printer	Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	35% 53%	0.00	0.00	35% 44%	0.00 0.14	0.00 0.05	0	0	20.93 0.38			0.00
Opt-Out/Ex Opt-Out/Ex	5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Grocery Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	0.14 N/A	0.05 N/A	N/A	N/A	0.36 N/A	0.00	0.00	0.00
Opt-Out/Ex	5700	5701 Data Center Improved Operations	Grocery	2014	2054	0.00	0.00	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	0	0	75.03			0.00
Opt-Out/Ex	5700	5702 Data Center Best Practices	Grocery	2014	2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	0.00	0.00	0	0	30.54			0.00
Opt-Out/Ex Opt-Out/Ex	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	26% 0%	0.00	0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	15.84 N/A	0.03	0.00	0.00
Opt-Out/Ex	6000	6007 Heat Trap	Grocery	2014	2054	0.03	0.00	0.00	0.00	5%	0.00	0.00	5%	0.03	0.03	0	0	2.23	0.00	0.00	0.00
Opt-Out/Ex	6000	6002 High Efficiency Water Heater (electric)	Grocery	2014	2054	0.03	0.00	0.00	0.00	7%	0.00	0.00	7%	0.06	0.04	0	0	1.20			0.00
Opt-Out/Ex Opt-Out/Ex	6000 6000	6006 Heat Recovery Unit 6004 Tankless Water Heater	Grocery Grocery	2014 2014	2054 2054	0.01 0.01	0.00	0.01 0.00	0.02	55% 59%	0.00	0.00	55% 59%	0.07 0.19	0.07 0.07	0	0	0.92 0.41			0.00
Opt-Out/Ex	6000	6008 Solar Water Heater	Grocery	2014	2054	0.01	0.00	0.00	0.02	65%	0.00	0.00	65%	0.19	0.07	1	1	0.41			0.00
Opt-Out/Ex	6000	6001 Demand controlled circulating systems	Grocery	2014	2054	0.01	0.00	0.00	0.02	66%	0.00	0.00	66%	0.26	0.09	2	1	0.28			0.00
Opt-Out/Ex Opt-Out/Ex	6000 7000	6003 Hot Water Pipe Insulation 7000 Base Refrigerated Vending Machines	Grocery Grocery	2014 2014	2054 2054	0.01 0.03	0.00 0.01	0.00	0.02	66% 0%	0.00	0.00	66% 0%	0.28 N/A	0.09 N/A	2 N/A	1 N/A	0.26 N/A	0.03	0.01	0.00
Opt-Out/Ex	7000	7000 Base Reinigerated vertaining Macrimes 7001 Vending Misers (Refrigerated units)	Grocery	2014	2054	0.03	0.00	0.00	0.00	16%	0.00	0.00	8%	0.03	0.03	0	0	2.01	0.03	0.01	0.00
Opt-Out/Ex	7000	7002 Vending Misers (Refrigerated glass-front units)	Grocery	2014	2054	0.02	0.00	0.00	0.01	25%	0.00	0.00	12%	0.05	0.03	1	0	1.10			0.00
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Grocery	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Grocery Grocery	2014 2014	2054 2054	0.00	0.00	0.00	0.00	46% 0%	0.00	0.00	23% 0%	0.43 N/A	0.43 N/A	5 N/A	5 N/A	0.12 N/A	0.04	0.00	0.00
Opt-Out/Ex	7300	7300 Base Fryer	Grocery	2014	2054	0.05	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.01	0.00
Opt-Out/Ex	7400	7400 Base Steamer	Grocery	2014	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	7400 8000	7401 Efficient Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	Grocery Grocery	2014 2014	2054 2054	0.02	0.00	0.05	0.05	69% 0%	0.01	0.01 0.00	69% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.11 N/A	0.00	0.00	0.05
Opt-Out/Ex	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	2014	2054	0.00	0.00	0.00	0.00	6%	0.00	0.00	0%	0.04	0.04	N/A	N/A	1.37	0.00	0.00	0.00
Opt-Out/Ex	8100	8100 Base Heating, Other Electric	Grocery	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Grocery Grocery	2014 2014	2054 2054	0.36 0.36	0.06 0.06	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	0.36	0.06	0.00
Opt-Out/Ex	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Warehouse	2014	2054	2.87	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.87	0.51	0.00
Opt-Out/Ex	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Warehouse	2020	2054	2.64	0.47	0.24	0.24	8%	0.04	0.04	8%	0.02	0.02	0	0	2.91			0.24
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Warehouse	2020	2054	2.59	0.46	0.04	0.28	10%	0.00	0.05	9%	0.03	0.02	0	0	1.70			0.04
Opt-Out/Ex Opt-Out/Ex	1030 1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Warehouse Warehouse	2020 2020	2054 2054	2.27 2.10	0.41 0.38	0.32 0.17	0.60 0.77	21% 27%	0.06 0.02	0.10 0.13	20% 25%	0.05 0.05	0.03	0	0	1.34 1.33			0.32 0.17
Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Warehouse	2020	2054	2.04	0.38	0.06	0.83	29%	0.00	0.13	26%	0.09	0.04	2	0	0.61			0.00
Opt-Out/Ex	1030	1034 ROB 4L4' LED Tube, 2020	Warehouse	2020	2054	1.71	0.32	0.33	1.16	40%	0.06	0.19	37%	0.28	0.11	2	1	0.25			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1130	1035 LED Troffer (base 4L4'T8), 2020 1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Warehouse Warehouse	2020 2020	2054 2054	1.57 0.02	0.30	0.15 0.00	1.31 0.00	46% 0%	0.03	0.21 0.00	42% 0%	0.24 N/A	0.12 N/A	1 N/A	1 N/A	0.30 N/A	0.02	0.00	0.00
Opt-Out/Ex	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Warehouse	2020	2054	0.02	0.00	0.00	0.00	10%	0.00	0.00	10%	0.03	0.03	0	0	2.25	0.02	0.00	0.00
Opt-Out/Ex	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Warehouse	2020	2054	0.02	0.00	0.00	0.00	12%	0.00	0.00	11%	0.03	0.03	0	0	1.60			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Warehouse Warehouse	2020 2020	2054 2054	0.02 0.01	0.00	0.00	0.00 0.01	18% 29%	0.00	0.00	16% 27%	0.05 0.06	0.04 0.05	0	0	1.44 0.98			0.00
Opt-Out/Ex	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	Warehouse Warehouse	2020	2054 2054	0.01	0.00	0.00	0.01	29% 32%	0.00	0.00	30%	0.06	0.05	1	0	0.98			0.00
Opt-Out/Ex	1130	1135 LED Troffer (base 2L4'T8), 2020	Warehouse	2020	2054	0.01	0.00	0.00	0.01	38%	0.00	0.00	36%	0.29	0.10	2	1	0.24			0.00
Opt-Out/Ex	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Warehouse	2020	2054	0.01	0.00	0.00	0.01	40%	0.00	0.00	36%	0.19	0.10	4	1	0.29	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Warehouse Warehouse	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 10%	0.00	0.00	0% 5%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 16.81	0.00	0.00	0.00
Opt-Out/Ex	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Warehouse	2014	2054	0.00	0.00	0.00	0.00	17%	0.00	0.00	10%	0.03	0.01	0	0	2.30			0.00
Opt-Out/Ex	1200	1201 ROB High Performance T8 (base other fluorescent)	Warehouse	2014	2054	0.00	0.00	0.00	0.00	25%	0.00	0.00	19%	0.10	0.05	1	0	0.59			0.00
Opt-Out/Ex Opt-Out/Ex	1200 1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Warehouse Warehouse	2014 2020	2054 2054	0.00	0.00	0.00	0.00	31% 0%	0.00	0.00	20% 0%	0.12 N/A	0.06 N/A	3 N/A	1 N/A	0.46 N/A	0.00	0.00	0.00
Opt-Out/EX	1330	1999 base incandescent rigod, 1999 to Sciew-III Replacement 2020	vvaienouse	2020	2004	0.00	0.00	0.00	0.00	U7/0	0.00	0.00	U70	IN/M	IN/M	IN/M	IN/M	IN/M	0.00	0.00	0.00

APPENDIX H

Base Avoided Costs

	T ADDITIVE	SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		asure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost \$/kWH	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Opt-Out/Ex	umber Nu 1430	mber Measure 1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Type Warehouse	2020	Year 2054	0.09	0.02	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	N/A	\$/kWH N/A	\$/kW N/A	\$/kW N/A	TRC N/A	0.09	0.02	0.00
Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Warehouse	2020	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00
Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020	Warehouse	2020	2054	0.12	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A 0	N/A 0	N/A	0.12	0.02	0.00
Opt-Out/Ex Opt-Out/Ex	1630 1730	1631 LED screw-in replacement (base CFL 18W) 2020 1730 Base CFL 23W to screw-in replacement 2020	Warehouse Warehouse	2020 2020	2054 2054	0.09 0.15	0.02 0.03	0.03	0.03	28% 0%	0.01	0.01 0.00	28% 0%	0.06 N/A	0.06 N/A	N/A	N/A	0.98 N/A	0.15	0.03	0.00
Opt-Out/Ex	1730	1731 LED screw-in replacement (base CFL 23W) 2020	Warehouse	2020	2054	0.11	0.02	0.04	0.04	26%	0.01	0.01	26%	0.05	0.05	0	0	1.31			0.04
Opt-Out/Ex Opt-Out/Ex	1800 1800	1800 BaseMetal Halide, 465W	Warehouse Warehouse	2014 2014	2054 2054	1.73 1.15	0.31	0.00	0.00	0% 34%	0.00	0.00	0% 34%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.34	1.73	0.31	0.00
Opt-Out/Ex	1800	1801 T5 (240W) (base metal halide) 1806 Occupancy Sensor, High Bay T5	Warehouse	2014	2054	1.15	0.20	0.04	0.62	36%	0.00	0.10	34%	0.01	0.01	1	0	1.90			0.04
Opt-Out/Ex	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Warehouse	2014	2054	1.03	0.19	0.08	0.71	41%	0.01	0.12	38%	0.05	0.02	0	0	1.49			0.08
Opt-Out/Ex	1850	1850 Base CFL Exit Sign	Warehouse	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Warehouse Warehouse	2014 2014	2054 2054	0.00 0.64	0.00 0.01	0.01	0.01	69% 0%	0.00	0.00	69% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.15 N/A	0.64	0.01	0.01
Opt-Out/Ex	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Warehouse	2014	2054	0.52	0.00	0.13	0.13	20%	0.01	0.01	66%	0.06	0.06	1	1	1.28			0.13
Opt-Out/Ex	1900	1902 LED Outdoor Area Lighting	Warehouse	2014	2054	0.25	0.00	0.27	0.40	61%	0.00	0.01	108%	0.11	0.10	8 61	4	0.56			0.00
Opt-Out/Ex Opt-Out/Ex	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Warehouse Warehouse	2014 2014	2054 2054	0.18 0.00	0.00	0.07 0.00	0.47	73% 0%	0.00	0.01 0.00	118% 0%	0.74 N/A	0.20 N/A	61 N/A	9 N/A	0.09 N/A	0.00	0.00	0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Warehouse	2014	2054	1.46	1.38	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.46	1.38	0.00
Opt-Out/Ex	2100	2113 Ceiling/roof Insulation - DX	Warehouse	2014	2054	1.39	1.32	0.07	0.07	5%	0.06	0.06	5%	0.05	0.05	0	0	2.69			0.07
Opt-Out/Ex Opt-Out/Ex	2100 2100	2107 Cool Roof - DX 2108 Optimize Controls - DX	Warehouse Warehouse	2014 2014	2054 2054	1.29 1.27	1.22 1.22	0.10 0.02	0.17 0.19	12% 13%	0.10 0.01	0.16 0.17	12% 12%	0.12	0.09	0	0	0.92			0.00
Opt-Out/Ex	2100	2102 DX Packaged System, EER=13.4, 10 tons	Warehouse	2014	2054	0.97	0.94	0.02	0.19	33%	0.01	0.44	32%	0.13	0.10	Ó	0	0.35			0.00
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Warehouse	2014	2054	0.92	0.88	0.06	0.54	37%	0.06	0.50	36%	3.07	0.62	3	1	0.05			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2115 Window Film (Standard) - DX 2106 Prog. Thermostat - DX	Warehouse Warehouse	2014 2014	2054 2054	0.88 0.85	0.85 0.84	0.04	0.58 0.60	40% 42%	0.04 0.01	0.54 0.54	39% 39%	2.74	0.77 0.82	3	1	0.04			0.00
Opt-Out/Ex	2100	2106 Prog. Thermostat - DX 2114 Duct/Pipe Insulation - DX	Warehouse	2014	2054	0.85	0.84	0.03	0.60	42% 42%	0.00	0.54	39%	5.62	0.82	6	1	0.03			0.00
Opt-Out/Ex	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Warehouse	2014	2054	0.85	0.84	0.00	0.61	42%	0.00	0.55	39%	3.71	0.84	14	1	0.02			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Warehouse	2014	2054	0.79	0.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.79	0.75	0.00
Opt-Out/Ex Opt-Out/Ex	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, FFR=8.3, 1 ton	Warehouse Warehouse	2014 2014	2054 2054	0.69	0.66	0.10	0.10	12% 0%	0.09	0.09	12% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	2.78 N/A	0.04	0.04	0.10
Opt-Out/Ex	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Warehouse	2014	2054	0.82	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.82	0.25	0.00
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Warehouse	2014	2054	0.81	0.25	0.01	0.01	2%	0.00	0.00	2%	0.05	0.05	0	0	2.03			0.01
Opt-Out/Ex Opt-Out/Ex	3000 3000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Warehouse Warehouse	2014 2014	2054 2054	0.57 0.56	0.23 0.23	0.24 0.01	0.25 0.26	31% 31%	0.02	0.02 0.03	9% 11%	0.04 1.85	0.04	0	0	1.85 0.06			0.24 0.00
Opt-Out/Ex	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Warehouse	2014	2054	0.00	0.23	0.00	0.20	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Warehouse	2014	2054	0.27	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.27	0.08	0.00
Opt-Out/Ex Opt-Out/Ex	3200 3200	3202 Variable Speed Drive Control, 40 HP 3203 Air Handler Optimization, 40 HP	Warehouse Warehouse	2014 2014	2054 2054	0.19 0.17	0.08 80.0	0.08	0.08	29% 36%	0.01 0.00	0.01	8% 9%	0.02 0.06	0.02 0.03	0	0	3.63 0.88			0.08
Opt-Out/Ex	3200	3204 Demand Controlled Ventilation	Warehouse	2014	2054	0.17	0.08	0.02	0.10	37%	0.00	0.01	11%	2.02	0.03	4	1	0.05			0.00
Opt-Out/Ex	4000	4000 Base Built-Up Refrigeration System	Warehouse	2014	2054	1.96	0.37	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.96	0.37	0.00
Opt-Out/Ex	4000 4000	4018 Oversized Air Cooled Condenser	Warehouse Warehouse	2014 2014	2054 2054	1.88 1.87	0.36 0.35	0.08	0.08	4% 5%	0.02	0.02 0.02	4% 5%	0.03	0.03	0	0	2.42 0.87			0.08
Opt-Out/Ex Opt-Out/Ex	4000	4010 Refrigeration Commissioning 4006 Electronically commutated evaporator fan motor	Warehouse	2014	2054	1.87	0.35	0.01	0.09	5% 10%	0.00	0.02	5% 8%	0.06	0.03	1	1	0.63			0.00
Opt-Out/Ex	4000	4005 Evaporator fan controller for MT walk-ins	Warehouse	2014	2054	1.75	0.34	0.01	0.21	11%	0.00	0.03	8%	0.19	0.08	2	1	0.36			0.00
Opt-Out/Ex	4000	4002 Strip curtains for walk-ins (built-up)	Warehouse	2014	2054	1.68	0.33	0.07	0.28	14%	0.01	0.04	11%	0.19	0.10	1	1	0.30			0.00
Opt-Out/Ex Opt-Out/Ex	4000 4100	4001 High-efficiency fan motors 4100 Base Self-Contained Refrigeration	Warehouse Warehouse	2014 2014	2054 2054	1.63 0.52	0.32 0.10	0.05 0.00	0.33	17% 0%	0.01 0.00	0.05 0.00	14% 0%	0.47 N/A	0.16 N/A	2 N/A	1 N/A	0.17 N/A	0.52	0.10	0.00
Opt-Out/Ex	4100	4101 Strip curtains for walk-ins (self-contained)	Warehouse	2014	2054	0.52	0.10	0.01	0.01	2%	0.00	0.00	2%	0.16	0.16	1	1	0.34	0.02	0.10	0.00
Opt-Out/Ex	5000	5000 Base Desktop PC	Warehouse	2014	2054	0.12	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.02	0.00
Opt-Out/Ex Opt-Out/Ex	5000 5000	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	Warehouse Warehouse	2014 2014	2054 2054	0.07 0.05	0.02 0.01	0.05 0.02	0.05 0.08	44% 63%	0.00	0.00 0.01	23% 41%	0.01 0.03	0.01 0.02	0	0	3.79 1.94			0.05 0.02
Opt-Out/Ex	5100	5100 Base Laptop PC	Warehouse	2014	2054	0.03	0.00	0.02	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.02
Opt-Out/Ex	5100	5102 Energy Star or Better Laptop	Warehouse	2014	2054	0.01	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	5.37			0.00
Opt-Out/Ex Opt-Out/Ex	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Warehouse Warehouse	2014 2014	2054 2054	0.01 0.02	0.00	0.00	0.00	21% 0%	0.00	0.00	21% 0%	1.24 N/A	0.11 N/A	7 N/A	1 N/A	0.04 N/A	0.02	0.00	0.00
Opt-Out/Ex	5200	5200 Base Monitor, CR1 5201 Energy Star or Better Monitor - CRT	Warehouse	2014	2054	0.02	0.00	0.00	0.00	56%	0.00	0.00	56%	0.00	0.00	0	0	42.66	0.02	0.00	0.00
Opt-Out/Ex	5200	5202 Monitor Power Management Enabling - CRT	Warehouse	2014	2054	0.01	0.00	0.00	0.02	70%	0.00	0.00	63%	0.02	0.01	0	0	2.33			0.00
Opt-Out/Ex	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Warehouse	2014	2054	0.01	0.00	0.00	0.02	73%	0.00	0.00	66%	0.23	0.01	1	0	0.24	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Warehouse Warehouse	2014 2014	2054 2054	0.02 0.02	0.00	0.00	0.00	0% 20%	0.00	0.00	0% 20%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 6.08	0.02	0.00	0.00
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	Warehouse	2014	2054	0.02	0.00	0.00	0.00	21%	0.00	0.00	21%	0.08	0.01	1	0	0.61			0.00
Opt-Out/Ex	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Warehouse	2014	2054	0.01	0.00	0.00	0.01	27%	0.00	0.00	22%	0.24	0.06	5	0	0.20			0.00
Opt-Out/Ex Opt-Out/Ex	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Warehouse Warehouse	2014 2014	2054 2054	0.03	0.01 0.00	0.00	0.00	0% 12%	0.00	0.00	0% 12%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 32.89	0.03	0.01	0.00
Opt-Out/Ex	5400	5401 Energy Star of Better Copier 5402 Copier Power Management Enabling	Warehouse	2014	2054	0.03	0.00	0.00	0.00	15%	0.00	0.00	14%	0.00	0.00	1	0	0.58			0.00
Opt-Out/Ex	5500	5500 Base Multifunction	Warehouse	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex	5500	5502 ENERGY STAR Multi-Function Device	Warehouse	2014	2054	0.01	0.00	0.00	0.00	25%	0.00	0.00	25%	0.01	0.01	0	0	9.11			0.00
Opt-Out/Ex Opt-Out/Ex	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Warehouse Warehouse	2014 2014	2054 2054	0.00	0.00 0.01	0.00	0.00	32% 0%	0.00	0.00	29% 0%	0.24 N/A	0.06 N/A	N/A	N/A	0.22 N/A	0.03	0.01	0.00
Opt-Out/Ex	5600	5602 ENERGY STAR Printer	Warehouse	2014	2054	0.02	0.00	0.01	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	41.89			0.01
Opt-Out/Ex	5600 5700	5601 Printer Power Management Enabling	Warehouse	2014	2054	0.02	0.00	0.00	0.01	41% 0%	0.00	0.00	38%	0.05	0.01	1	0 N/A	1.01	0.67	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Warehouse Warehouse	2014 2014	2054 2054	0.37 0.33	0.06 0.05	0.00 0.04	0.00	0% 10%	0.00 0.01	0.00 0.01	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 119.82	0.37	0.06	0.00 0.04
Opt-Out/Ex	5700	5702 Data Center Best Practices	Warehouse	2014	2054	0.29	0.05	0.04	0.04	21%	0.01	0.01	21%	0.00	0.00	0	0	48.78			0.04

H-7 1/5/2015 DNV GL

APPENDIX H

Base Avoided Costs

	T ADDITIVE	SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		asure	Building	Start	End	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base MW	Economic GWH
Opt-Out/Ex	5700	5703 Data Center State of the Art practices	Type Warehouse	2014	2054	0.27	0.05	0.02	0.09	26%	0.00	0.02	26%	0.00	0.00	0	0	25.30	GWH	IVIVV	0.02
Opt-Out/Ex	6000	6000 Base Water Heating	Warehouse	2014	2054	0.14	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.14	0.02	0.00
Opt-Out/Ex Opt-Out/Ex	6000 6000	6006 Heat Recovery Unit 6007 Heat Trap	Warehouse Warehouse	2014 2014	2054 2054	0.13 0.12	0.02 0.02	0.01 0.01	0.01 0.02	7% 11%	0.00	0.00	7% 11%	0.25 0.45	0.25 0.33	2	2	0.26 0.15			0.00
Opt-Out/Ex	6000	6002 High Efficiency Water Heater (electric)	Warehouse	2014	2054	0.12	0.02	0.00	0.02	13%	0.00	0.00	13%	0.93	0.42	6	3	0.08			0.00
Opt-Out/Ex	6000	6004 Tankless Water Heater	Warehouse	2014	2054	0.11	0.02	0.01	0.03	20%	0.00	0.00	20%	1.42	0.75	9	5 8	0.06			0.00
Opt-Out/Ex Opt-Out/Ex	6000 6000	6008 Solar Water Heater 6003 Hot Water Pipe Insulation	Warehouse Warehouse	2014 2014	2054 2054	0.07 0.07	0.01 0.01	0.04	0.07 0.07	47% 48%	0.01	0.01 0.01	47% 48%	1.66 2.58	1.28 1.31	11 16	8	0.05			0.00
Opt-Out/Ex	6000	6001 Demand controlled circulating systems	Warehouse	2014	2054	0.07	0.01	0.00	0.07	49%	0.00	0.01	49%	2.88	1.34	18	9	0.03			0.00
Opt-Out/Ex Opt-Out/Ex	7000 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Warehouse Warehouse	2014 2014	2054 2054	0.10 0.08	0.02 0.02	0.00 0.02	0.00 0.02	0% 16%	0.00	0.00	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.00	0.10	0.02	0.00 0.02
Opt-Out/Ex	7000	7002 Vending Misers (Refrigerated glass-front units)	Warehouse	2014	2054	0.08	0.02	0.02	0.02	25%	0.00	0.00	12%	0.05	0.03	1	0	1.10			0.02
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Warehouse	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Warehouse Warehouse	2014 2014	2054 2054	0.00	0.00 0.01	0.00	0.00	45% 0%	0.00	0.00	23% 0%	0.44 N/A	0.44 N/A	5 N/A	5 N/A	0.12 N/A	0.03	0.01	0.00
Opt-Out/Ex	7300	7300 Base Fryer	Warehouse	2014	2054	0.07	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.07	0.01	0.00
Opt-Out/Ex	7400	7400 Base Steamer	Warehouse	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	8000 8000	8000 Base Heating, Heat Pump (7.7 HSPF) 8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Warehouse Warehouse	2014 2014	2054 2054	0.01 0.01	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 0%	N/A 0.03	N/A 0.03	N/A N/A	N/A N/A	N/A 1.90	0.01	0.00	0.00
Opt-Out/Ex	8100	8100 Base Heating, Other Electric	Warehouse	2014	2054	0.11	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.11	0.00	0.00
Opt-Out/Ex	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Warehouse Warehouse	2014 2014	2054 2054	2.24	0.42	0.00	0.00	0% 0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A	2.24	0.42	0.00
Opt-Out/Ex Opt-Out/Ex	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	School	2014	2054	3.64	0.42	0.00	0.00	0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	3.64	0.49	0.00
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	School	2020	2054	3.60	0.49	0.04	0.04	1%	0.00	0.00	1%	0.02	0.02	0	0	2.61			0.04
Opt-Out/Ex	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	School	2020	2054	3.23	0.44	0.37	0.41	11% 18%	0.05	0.05	11%	0.03	0.03	0	0	2.55			0.37
Opt-Out/Ex Opt-Out/Ex	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	School School	2020 2020	2054 2054	2.99 2.87	0.41 0.40	0.24 0.12	0.65 0.77	21%	0.03 0.02	0.08	16% 19%	0.03 0.20	0.03 0.05	1	0	2.07 0.35			0.24 0.00
Opt-Out/Ex	1030	1034 ROB 4L4' LED Tube, 2020	School	2020	2054	2.41	0.33	0.46	1.23	34%	0.06	0.16	32%	0.35	0.17	3	1	0.22			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1035 LED Troffer (base 4L4'T8), 2020	School School	2020 2020	2054 2054	2.28 2.08	0.33	0.13 0.19	1.36 1.56	37% 43%	0.00	0.16 0.19	33% 38%	0.18 0.31	0.17 0.18	5	1 2	0.31 0.25			0.00
Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	School	2020	2054	0.23	0.30	0.19	0.00	0%	0.00	0.00	0%	0.31 N/A	0.16 N/A	N/A	N/A	0.25 N/A	0.23	0.03	0.00
Opt-Out/Ex	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	School	2020	2054	0.21	0.03	0.02	0.02	10%	0.00	0.00	10%	0.03	0.03	0	0	2.04			0.02
Opt-Out/Ex Opt-Out/Ex	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	School School	2020 2020	2054 2054	0.20 0.19	0.03	0.00 0.02	0.03 0.04	11% 18%	0.00	0.00	11% 16%	0.03 0.05	0.03 0.04	0	0	1.58 1.41			0.00 0.02
Opt-Out/Ex	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	School	2020	2054	0.16	0.02	0.02	0.04	28%	0.00	0.01	27%	0.08	0.05	1	0	0.89			0.00
Opt-Out/Ex	1130	1134 ROB 2L4' LED Tube, 2020	School	2020	2054	0.16	0.02	0.01	0.07	32%	0.00	0.01	30%	0.32	0.08	2	1	0.25			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1135 LED Troffer (base 2L4'T8), 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	School School	2020 2020	2054 2054	0.14	0.02	0.01	0.09	38% 41%	0.00	0.01	36% 37%	0.40	0.13	3 10	1	0.20			0.00
Opt-Out/Ex	1200	1200 Base Other Fluorescent Fixture	School	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
Opt-Out/Ex	1200 1200	1203 Lighting Control Tuneup (base other fluorescent fixture)	School School	2014 2014	2054 2054	0.02	0.00	0.00	0.00	6% 14%	0.00	0.00	3% 11%	0.02 0.11	0.02 0.07	0	0	2.15 0.61			0.00
Opt-Out/Ex	1200	1201 ROB High Performance T8 (base other fluorescent) 1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	School	2014	2054	0.02	0.00	0.00	0.00	37%	0.00	0.00	25%	0.11	0.07	1 6	2	0.61			0.00
Opt-Out/Ex	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	School	2014	2054	0.01	0.00	0.00	0.01	41%	0.00	0.00	29%	0.37	0.18	3	2	0.19			0.00
Opt-Out/Ex Opt-Out/Ex	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	School School	2020 2020	2054 2054	0.05 0.02	0.01 0.00	0.00	0.00	0% 67%	0.00	0.00	0% 67%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 16.50	0.05	0.01	0.00 0.03
Opt-Out/Ex	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	School	2020	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	School	2020	2054	0.01	0.00	0.01	0.01	64%	0.00	0.00	64%	0.00	0.00	0	0	13.70			0.01
Opt-Out/Ex Opt-Out/Ex	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	School School	2020 2020	2054 2054	0.01 0.01	0.00	0.00 0.01	0.00 0.01	0% 54%	0.00	0.00	0% 54%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.46	0.01	0.00	0.00 0.01
Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020	School	2020	2054	0.25	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.25	0.03	0.00
Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	School	2020	2054	0.18	0.02	0.07	0.07	28%	0.01	0.01	28%	0.08	0.08	1	1	0.86			0.00
Opt-Out/Ex Opt-Out/Ex	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	School School	2020 2020	2054 2054	0.32 0.23	0.04 0.03	0.00	0.00 0.08	0% 26%	0.00 0.01	0.00 0.01	0% 26%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.15	0.32	0.04	0.00
Opt-Out/Ex	1800	1800 BaseMetal Halide, 465W	School	2014	2054	1.31	0.18	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.31	0.18	0.00
Opt-Out/Ex	1800	1801 T5 (240W) (base metal halide)	School	2014	2054	0.87	0.12	0.44	0.44 0.51	34% 39%	0.06	0.06	34% 38%	0.02	0.02	0	0	3.90			0.44
Opt-Out/Ex Opt-Out/Ex	1800 1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1806 Occupancy Sensor, High Bay T5	School School	2014 2014	2054 2054	0.80 0.78	0.11 0.11	0.06	0.51	39% 41%	0.01	0.07 0.07	38%	0.03	0.02 0.02	2	0	2.47 0.95			0.06
Opt-Out/Ex	1850	1850 Base CFL Exit Sign	School	2014	2054	0.04	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.00	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	School	2014	2054	0.02	0.00	0.02	0.02	55%	0.00	0.00	55%	0.04	0.04 N/A	0	0	1.46	4.00	0.05	0.02
Opt-Out/Ex Opt-Out/Ex	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	School School	2014 2014	2054 2054	1.30 1.19	0.05 0.04	0.00 0.11	0.00 0.11	0% 9%	0.00 0.01	0.00 0.01	0% 28%	N/A 0.05	0.05	N/A 0	N/A 0	N/A 1.55	1.30	0.05	0.00 0.11
Opt-Out/Ex	1900	1902 LED Outdoor Area Lighting	School	2014	2054	0.57	0.01	0.62	0.73	56%	0.02	0.04	75%	0.11	0.10	3	2	0.60			0.00
Opt-Out/Ex Opt-Out/Ex	1900 2000	1903 Bi-Level LED Outdoor Lighting 2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	School School	2014 2014	2054 2054	0.40 3.60	0.01 1.85	0.17 0.00	0.90 0.00	69% 0%	0.01 0.00	0.04	87% 0%	0.72 N/A	0.22 N/A	20 N/A	4 N/A	0.09 N/A	3.60	1.85	0.00
Opt-Out/Ex	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	School	2014	2054	3.29	1.69	0.00	0.31	9%	0.16	0.00	9%	0.07	0.07	0	0	1.47	3.00	1.00	0.00
Opt-Out/Ex	2000	2013 High Efficiency Chiller Motors	School	2014	2054	3.29	1.69	0.00	0.31	9%	0.00	0.16	9%	0.12	0.08	0	0	0.95			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2006 VSD for Chiller Pumps and Towers 2003 FMS - Chiller	School School	2014 2014	2054 2054	3.28 3.11	1.69 1.66	0.01 0.18	0.32	9% 14%	0.00	0.16 0.19	9% 10%	0.09	0.08 0.10	0	0	0.89 0.50			0.00
Opt-Out/Ex	2000	2004 Cool Roof - Chiller	School	2014	2054	3.05	1.63	0.16	0.49	15%	0.03	0.19	12%	0.14	0.10	0	0	0.38			0.00
Opt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	School	2014	2054	3.03	1.62	0.02	0.57	16%	0.01	0.22	12%	0.26	0.12	1	0	0.33			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2012 Duct Testing/Sealing 2008 New Economizer - Chiller	School School	2014 2014	2054 2054	2.53	1.37	0.50 0.27	1.07 1.34	30% 37%	0.26	0.48 0.52	26% 28%	0.38	0.24	1	1	0.28			0.00
Opt-Out/Ex	2000	2011 Duct/Pipe Insulation - Chiller	School	2014	2054	2.25	1.32	0.01	1.35	38%	0.01	0.53	29%	6.18	0.34	12	1	0.01			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	School	2014	2054	1.83	0.94	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.83	0.94	0.00

APPENDIX H

Base Avoided Costs

	ADDITIVE	SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		easure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt Nu Opt-Out/Ex	2100	umber Measure 2113 Ceiling/roof Insulation - DX	Type School	2014	Year 2054	1.83	0.94	Savings 0.00	0.00	Savings 0%	Savings 0.00	0.00	Savings 0%	\$/kWH 0.03	\$/kWH 0.03	\$/kW	\$/kW	3.79	GWH	MW	0.00
Opt-Out/Ex	2100	2102 DX Packaged System, EER=13.4, 10 tons	School	2014	2054	1.41	0.72	0.42	0.42	23%	0.22	0.22	23%	0.07	0.06	0	0	1.54			0.42
Opt-Out/Ex	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	School	2014	2054	1.41	0.72	0.00	0.42	23%	0.00	0.22	23%	0.19	0.07	1	0	0.33			0.00
Opt-Out/Ex	2100 2100	2115 Window Film (Standard) - DX 2108 Optimize Controls - DX	School School	2014 2014	2054 2054	1.40 1.38	0.72 0.71	0.01	0.44 0.46	24% 25%	0.01	0.22 0.23	24% 24%	0.29	0.07	1	0	0.30			0.00
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	School	2014	2054	1.30	0.68	0.02	0.53	29%	0.04	0.26	28%	0.42	0.00	1	0	0.25			0.00
Opt-Out/Ex	2100	2106 Prog. Thermostat - DX	School	2014	2054	1.29	0.68	0.01	0.54	30%	0.00	0.27	28%	0.26	0.13	2	0	0.23			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2107 Cool Roof - DX 2111 Economizer Repair - DX	School School	2014 2014	2054 2054	1.27 1.24	0.66 0.65	0.02 0.02	0.57 0.59	31% 32%	0.01 0.02	0.28 0.30	29% 31%	0.47 1.04	0.14 0.18	1	0	0.18 0.08			0.00
Opt-Out/Ex	2100	2111 Economizer Repair - DX 2109 Economizer - DX	School	2014	2054	1.24	0.65	0.02	0.60	32%	0.02	0.30	31%	1.04	0.18	11	0	0.08			0.00
Opt-Out/Ex	2100	2114 Duct/Pipe Insulation - DX	School	2014	2054	1.22	0.64	0.01	0.61	33%	0.01	0.30	32%	5.79	0.33	11	1	0.01			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	School	2014	2054	1.83	0.94	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.83	0.94	0.00
Opt-Out/Ex Opt-Out/Ex	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, FER=8.3, 1 ton	School School	2014 2014	2054 2054	1.61	0.83	0.23	0.23	12% 0%	0.12	0.12	12% 0%	0.05 N/A	0.05 N/A	0 N/A	0 N/A	1.83 N/A	1.83	0.94	0.23
Opt-Out/Ex	2300	2301 HE PTAC, EER=9.6, 1 ton	School	2014	2054	1.59	0.81	0.25	0.25	14%	0.13	0.13	14%	0.14	0.14	0	0	0.73	1.00	0.01	0.00
Opt-Out/Ex	2300	2302 Occupancy Sensor (hotels)	School	2014	2054	1.34	0.66	0.25	0.50	27%	0.16	0.29	30%	0.43	0.28	1	0	0.22			0.00
Opt-Out/Ex Opt-Out/Ex	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3001 Fan Motor, 5hp, 1800rpm, 89.5%	School School	2014 2014	2054 2054	0.87	0.17 0.17	0.00 0.01	0.00 0.01	0% 2%	0.00	0.00	0% 2%	N/A 0.06	N/A 0.06	N/A 0	N/A 0	N/A 1.34	0.87	0.17	0.00 0.01
Opt-Out/Ex	3000	3003 Demand Controlled Ventilation	School	2014	2054	0.85	0.17	0.01	0.01	16%	0.00	0.00	28%	1.75	1.57	5	5	0.05			0.00
Opt-Out/Ex	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	School	2014	2054	2.32	0.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.32	0.45	0.00
Opt-Out/Ex	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	School	2014	2054	2.00	0.40	0.33	0.33	14%	0.06	0.06	13%	0.06	0.06	0	0	1.30			0.33
Opt-Out/Ex Opt-Out/Ex	3100 3100	3103 Air Handler Optimization, 15 HP 3101 Fan Motor, 15hp, 1800rpm, 92.4%	School School	2014 2014	2054 2054	1.80 1.79	0.39 0.38	0.19 0.02	0.52 0.54	22% 23%	0.01 0.00	0.07 0.07	15% 16%	0.06 0.16	0.06 0.06	1	0	0.88 0.52			0.00
Opt-Out/Ex	3100	3105 Energy Recovery Ventilation (ERV)	School	2014	2054	1.69	0.35	0.09	0.63	27%	0.03	0.10	23%	0.58	0.14	2	1	0.17			0.00
Opt-Out/Ex	3100	3107 Demand Controlled Ventilation	School	2014	2054	1.44	0.26	0.25	0.88	38%	0.09	0.19	42%	2.36	0.78	7	4	0.04			0.00
Opt-Out/Ex Opt-Out/Ex	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0% 3201 Fan Motor, 40hp, 1800rpm, 94.1%	School School	2014 2014	2054 2054	0.97 0.97	0.19 0.19	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.96	0.97	0.19	0.00
Opt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP	School	2014	2054	0.87	0.18	0.00	0.10	10%	0.00	0.00	3%	0.05	0.05	1	1	1.02			0.00
Opt-Out/Ex	3200	3204 Demand Controlled Ventilation	School	2014	2054	0.74	0.14	0.13	0.23	23%	0.05	0.05	27%	1.91	1.12	5	5	0.05			0.00
Opt-Out/Ex	4000 4100	4000 Base Built-Up Refrigeration System	School	2014	2054 2054	0.00	0.00 0.18	0.00	0.00	0% 0%	0.00	0.00	0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 1.31	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	School School	2014 2014	2054	1.31 1.21	0.18	0.00	0.00	7%	0.00 0.01	0.00 0.01	0% 7%	0.00	0.00	0	N/A 0	21.04	1.31	0.18	0.00 0.10
Opt-Out/Ex	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	School	2014	2054	1.20	0.17	0.02	0.11	9%	0.00	0.02	9%	0.00	0.00	Ö	Ö	12.13			0.02
Opt-Out/Ex	4100	4109 Energy-Star Freezer, glass door	School	2014	2054	1.18	0.16	0.01	0.13	10%	0.00	0.02	10%	0.01	0.00	0	0	7.93			0.01
Opt-Out/Ex Opt-Out/Ex	4100 4100	4106 Energy-Star Refrigerator, solid door 4107 Energy-Star Freezer, solid door	School School	2014 2014	2054 2054	1.15 1.14	0.16 0.16	0.03 0.01	0.16 0.17	12% 13%	0.00	0.02 0.02	12% 13%	0.01	0.01 0.01	0	0	4.78 3.09			0.03
Opt-Out/Ex	4100	4108 Energy-Star Refrigerator, glass door	School	2014	2054	1.13	0.16	0.01	0.18	14%	0.00	0.02	14%	0.02	0.01	ő	0	2.57			0.01
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	School	2014	2054	1.11	0.15	0.02	0.20	15%	0.00	0.03	15%	0.04	0.01	0	0	1.69			0.02
Opt-Out/Ex Opt-Out/Ex	4100 4100	4112 Reach-in unit occupancy sensors 4105 Bi-level LED Case Lighting (self-contained units) 2014	School School	2014 2014	2054 2054	1.11 1.11	0.15 0.15	0.00	0.20 0.20	15% 16%	0.00	0.03	15% 16%	0.34 0.39	0.01 0.02	2	0	0.19 0.15			0.00
Opt-Out/Ex	4100	4101 Strip curtains for walk-ins (self-contained)	School	2014	2054	1.10	0.15	0.00	0.21	16%	0.00	0.03	16%	1.26	0.02	9	0	0.04			0.00
Opt-Out/Ex	5000	5000 Base Desktop PC	School	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex	5000 5000	5001 PC Network Power Management Enabling 5002 Energy Star or Better PC	School School	2014 2014	2054 2054	0.02	0.00	0.01 0.01	0.01 0.02	45% 61%	0.00	0.00	23% 39%	0.01 0.03	0.01 0.02	0	0	3.35 1.71			0.01
Opt-Out/Ex Opt-Out/Ex	5100	5100 Base Laptop PC	School	2014	2054	0.01	0.00	0.00	0.02	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex	5100	5102 Energy Star or Better Laptop	School	2014	2054	0.01	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	4.55			0.00
Opt-Out/Ex	5100 5200	5101 Laptop Network Power Management Enabling	School	2014 2014	2054 2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	1.38 N/A	0.12 N/A	16 N/A	1	0.04 N/A	0.00	0.00	0.00
Opt-Out/Ex	5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	School School	2014	2054	0.02	0.00	0.00	0.00	0% 56%	0.00	0.00	0% 56%	0.00	0.00	0	N/A 0	36.20	0.02	0.00	0.00
Opt-Out/Ex	5200	5202 Monitor Power Management Enabling - CRT	School	2014	2054	0.01	0.00	0.00	0.02	68%	0.00	0.00	62%	0.02	0.00	ō	ō	2.30			0.00
Opt-Out/Ex	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	School	2014	2054	0.01	0.00	0.00	0.02	71%	0.00	0.00	65%	0.24 N/A	0.01	3	0	0.21	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	School School	2014 2014	2054 2054	0.02 0.01	0.00	0.00	0.00	0% 18%	0.00	0.00	0% 18%	0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.33	0.02	0.00	0.00
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	School	2014	2054	0.01	0.00	0.00	0.00	20%	0.00	0.00	19%	0.09	0.02	2	0	0.55			0.00
Opt-Out/Ex	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	School	2014	2054	0.01	0.00	0.00	0.00	26%	0.00	0.00	20%	0.26	0.07	12	1	0.18	0.04	0.00	0.00
Opt-Out/Ex	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	School School	2014 2014	2054 2054	0.04	0.00	0.00	0.00	0% 6%	0.00	0.00	0% 6%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 29.99	0.04	0.00	0.00
Opt-Out/Ex	5400	5402 Copier Power Management Enabling	School	2014	2054	0.03	0.00	0.00	0.00	10%	0.00	0.00	8%	0.10	0.04	2	1	0.54			0.00
Opt-Out/Ex	5500	5500 Base Multifunction	School	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex	5500 5500	5502 ENERGY STAR Multi-Function Device 5501 Multifunction Power Management Enabling	School School	2014 2014	2054 2054	0.00	0.00	0.00	0.00	25% 39%	0.00	0.00	25% 32%	0.01 0.30	0.01	0 7	0	7.76 0.17			0.00
Opt-Out/Ex	5600	5600 Base Printer	School	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex	5600	5602 ENERGY STAR Printer	School	2014	2054	0.02	0.00	0.01	0.01	35%	0.00	0.00	35%	0.00	0.00	0	0	35.66			0.01
Opt-Out/Ex	5600 5700	5601 Printer Power Management Enabling	School School	2014 2014	2054 2054	0.01 1.55	0.00 0.13	0.00	0.01	47% 0%	0.00	0.00	41% 0%	0.06 N/A	0.02 N/A	1 N/A	0 N/A	0.79 N/A	1.55	0.10	0.00
Opt-Out/Ex Opt-Out/Ex	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	School	2014	2054	1.55	0.13	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	N/A 0	N/A 0	N/A 125.92	1.05	0.13	0.00
Opt-Out/Ex	5700	5702 Data Center Best Practices	School	2014	2054	1.21	0.10	0.18	0.33	21%	0.02	0.03	21%	0.00	0.00	Ö	0	51.26			0.18
Opt-Out/Ex	5700	5703 Data Center State of the Art practices	School	2014	2054	1.15	0.10	0.07	0.40	26%	0.01	0.03	26%	0.00	0.00	0	0	26.59	0.54	0.07	0.07
Opt-Out/Ex Opt-Out/Ex	6000 6000	6000 Base Water Heating 6007 Heat Trap	School School	2014 2014	2054 2054	0.54 0.51	0.04 0.04	0.00	0.00	0% 5%	0.00	0.00	0% 5%	N/A 0.05	N/A 0.05	N/A 1	N/A 1	N/A 1.31	0.54	0.04	0.00
Opt-Out/Ex	6000	6002 High Efficiency Water Heater (electric)	School	2014	2054	0.50	0.04	0.03	0.03	7%	0.00	0.00	7%	0.10	0.06	1	1	0.69			0.00
Opt-Out/Ex	6000	6006 Heat Recovery Unit	School	2014	2054	0.45	0.04	0.05	0.09	16%	0.00	0.01	16%	0.10	0.08	1	1	0.64			0.00
Opt-Out/Ex Opt-Out/Ex	6000 6000	6001 Demand controlled circulating systems 6004 Tankless Water Heater	School School	2014 2014	2054 2054	0.44	0.03	0.02	0.10 0.14	19% 25%	0.00	0.01 0.01	19% 25%	0.13 0.17	0.09	2	1	0.53			0.00
Opt-Out/EX	0000	0004 Talikiess Water Heater	SCHOOL	2014	2004	0.40	0.03	0.03	0.14	2070	0.00	0.01	20%	0.17	0.11	2		0.43			0.00

DNV GL H-9 1/5/2015

APPENDIX H

Base Avoided Costs

	T ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal		Marginal		Total			SUPPLY
Vintage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Average Energy	Capacity	Average Capacity				
		easure mber Measure	Building Type	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base MW	Economic
Opt-Out/Ex	6000	6008 Solar Water Heater	School	2014	2054	0.37	0.03	0.03	0.16	31%	0.00	0.01	31%	0.20	0.13	3	2	0.37	GWH	IVIVV	0.00
Opt-Out/Ex	7000	7000 Base Refrigerated Vending Machines	School	2014	2054	0.12	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	School School	2014 2014	2054 2054	0.11 0.10	0.01 0.01	0.01 0.01	0.01 0.02	10% 16%	0.00	0.00	5% 8%	0.02 0.04	0.02	0	0	2.49 1.33			0.01 0.01
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	School	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	7100	7101 Vending Misers (Non-Refrigerated)	School	2014	2054	0.00	0.00	0.00	0.00	30%	0.00	0.00	15%	0.34	0.34	8	8	0.15			0.00
Opt-Out/Ex Opt-Out/Ex	7200 7200	7200 Base Oven 7201 Convection Oven	School School	2014 2014	2054 2054	0.34 0.26	0.03 0.02	0.00	0.00	0% 23%	0.00 0.01	0.00	0% 23%	N/A 0.31	N/A 0.31	N/A 4	N/A 4	N/A 0.21	0.34	0.03	0.00
Opt-Out/Ex	7300	7300 Base Fryer	School	2014	2054	0.04	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.00	0.00
Opt-Out/Ex	7400	7400 Base Steamer	School	2014	2054	0.26	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.26	0.02	0.00
Opt-Out/Ex Opt-Out/Ex	7400 8000	7401 Efficient Steamer 8000 Base Heating, Heat Pump (7.7 HSPF)	School School	2014 2014	2054 2054	0.10 0.00	0.01	0.17 0.00	0.17	63% 0%	0.01 0.00	0.01 0.00	63% 0%	0.11 N/A	0.11 N/A	1 N/A	1 N/A	0.62 N/A	0.00	0.00	0.00
Opt-Out/Ex	8100	8100 Base Heating, Other Electric	School	2014	2054	0.24	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.24	0.00	0.00
Opt-Out/Ex	9500	9500 Base Miscellaneous	School	2014	2054	1.71	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.71	0.15	0.00
Opt-Out/Ex Opt-Out/Ex	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	School Health	2014 2020	2054	1.71 16.35	0.15 2.49	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	16.35	2.49	0.00
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Health	2020	2054	16.01	2.46	0.34	0.34	2%	0.02	0.02	1%	0.03	0.03	0	0	1.90	10.00	2.10	0.34
Opt-Out/Ex	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Health	2020	2054	14.79	2.32	1.23	1.57	10%	0.15	0.17	7%	0.04	0.04	0	0	1.63			1.23
Opt-Out/Ex Opt-Out/Ex	1030 1030	1031 ROB 4L4' High Performance T8 (86 W), 2020 1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Health Health	2020 2020	2054 2054	13.25 13.09	2.08 2.06	1.54 0.16	3.11 3.26	19% 20%	0.23 0.02	0.40	16% 17%	0.05 1.07	0.04 0.09	0 7	0	1.25 0.06			1.54 0.00
Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Health	2020	2054	12.44	2.04	0.66	3.92	24%	0.02	0.45	18%	0.14	0.09	4	1	0.39			0.00
Opt-Out/Ex	1030	1034 ROB 4L4' LED Tube, 2020	Health	2020	2054	10.43	1.73	2.00	5.92	36%	0.30	0.76	30%	0.53	0.25	3	2	0.13			0.00
Opt-Out/Ex	1030 1130	1035 LED Troffer (base 4L4'T8), 2020	Health Health	2020	2054 2054	9.54 1.97	1.60	0.89	6.81	42% 0%	0.14	0.89	36%	0.44 N/A	0.27 N/A	3	2	0.15	4.07	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Health	2020 2020	2054	1.97	0.30 0.27	0.00	0.00	10%	0.00	0.00	0% 10%	0.05	0.05	N/A 0	N/A 0	N/A 1.09	1.97	0.30	0.00 0.21
Opt-Out/Ex	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Health	2020	2054	1.73	0.27	0.04	0.24	12%	0.00	0.03	11%	0.06	0.06	1	0	0.80			0.00
Opt-Out/Ex	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4T8), 2020	Health	2020	2054	1.60	0.25	0.13	0.37	19%	0.02	0.05	17%	0.10	0.07	1	1	0.69			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020 1134 ROB 2L4' LED Tube, 2020	Health Health	2020 2020	2054 2054	1.39 1.33	0.22 0.21	0.20	0.58	29% 33%	0.03 0.01	0.08	27% 30%	0.13	0.09	1	1	0.47			0.00
Opt-Out/Ex	1130	1135 LED Troffer (base 2L4'T8), 2020	Health	2020	2054	1.21	0.19	0.11	0.76	38%	0.02	0.11	36%	0.59	0.20	4	i	0.12			0.00
Opt-Out/Ex	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Health	2020	2054	1.15	0.19	0.06	0.82	42%	0.00	0.11	37%	0.33	0.21	9	2	0.17			0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Health Health	2014 2014	2054 2054	0.53 0.49	0.08	0.00 0.04	0.00 0.04	0% 7%	0.00	0.00	0% 4%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.10	0.53	0.08	0.00 0.04
Opt-Out/Ex	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Health	2014	2054	0.45	0.08	0.04	0.04	14%	0.00	0.01	9%	0.12	0.01	1	1	0.58			0.00
Opt-Out/Ex	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Health	2014	2054	0.38	0.07	0.07	0.15	28%	0.00	0.01	12%	0.15	0.11	4	2	0.36			0.00
Opt-Out/Ex	1200	1201 ROB High Performance T8 (base other fluorescent)	Health	2014	2054	0.34	0.06	0.04	0.19	35%	0.01	0.02	20%	0.24	0.14	2	2	0.25			0.00
Opt-Out/Ex Opt-Out/Ex	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Health Health	2020 2020	2054 2054	1.07 0.18	0.16	0.00	0.00	0% 83%	0.00 0.13	0.00	0% 83%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 4.74	1.07	0.16	0.00 0.88
Opt-Out/Ex	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Health	2020	2054	0.38	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.38	0.06	0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	Health	2020	2054	0.07	0.01	0.31	0.31	82%	0.05	0.05	82%	0.02	0.02	0	0	4.00			0.31
Opt-Out/Ex Opt-Out/Ex	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Health Health	2020 2020	2054 2054	0.28 0.07	0.04 0.01	0.00 0.21	0.00 0.21	0% 75%	0.00	0.00	0% 75%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.98	0.28	0.04	0.00 0.21
Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020	Health	2020	2054	0.09	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.09	0.01	0.00
Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Health	2020	2054	0.06	0.01	0.02	0.02	28%	0.00	0.00	28%	0.13	0.13	.1.	.1	0.49			0.00
Opt-Out/Ex Opt-Out/Ex	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Health Health	2020 2020	2054 2054	0.11	0.02	0.00	0.00	0% 26%	0.00	0.00	0% 26%	N/A 0.10	N/A 0.10	N/A 1	N/A 1	N/A 0.65	0.11	0.02	0.00
Opt-Out/Ex	1800	1800 BaseMetal Halide, 465W	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	1850	1850 Base CFL Exit Sign	Health	2014	2054	0.45	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.45	0.07	0.00
Opt-Out/Ex	1850 1900	1851 LED Exit Sign 1900 Base Outdoor High Pressure Sodium 250W Lamp	Health Health	2014 2014	2054 2054	0.39 1.86	0.06	0.05	0.05 0.00	12% 0%	0.01	0.01	12% 0%	0.04 N/A	0.04 N/A	0	0 N/A	1.58 N/A	1.86	0.02	0.05
Opt-Out/Ex Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Social 250W Lamp 1901 Outdoor Lighting Controls (Photocell/Timeclock)	Health	2014	2054	1.81	0.02	0.00	0.05	3%	0.00	0.00	9%	0.09	0.09	N/A 3	3	0.78	1.00	0.02	0.00
Opt-Out/Ex	1900	1902 LED Outdoor Area Lighting	Health	2014	2054	0.87	0.01	0.94	0.99	53%	0.01	0.01	60%	0.19	0.18	20	17	0.34			0.00
Opt-Out/Ex	1900	1903 Bi-Level LED Outdoor Lighting	Health	2014	2054	0.61	0.00	0.26	1.25	67%	0.00	0.01	72%	1.22	0.40	145	39	0.05			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Health Health	2014 2014	2054 2054	32.62 29.84	17.93 16.40	0.00 2.78	0.00 2.78	0% 9%	0.00 1.53	0.00 1.53	0% 9%	N/A 0.05	N/A 0.05	N/A 0	N/A 0	N/A 2.38	32.62	17.93	0.00 2.78
Opt-Out/Ex	2000	2006 VSD for Chiller Pumps and Towers	Health	2014	2054	29.77	16.38	0.07	2.85	9%	0.02	1.55	9%	0.05	0.05	Ö	0	1.58			0.07
Opt-Out/Ex	2000	2013 High Efficiency Chiller Motors	Health	2014	2054	29.67	16.33	0.10	2.95	9%	0.05	1.60	9%	0.07	0.05	0	0	1.53			0.10
Opt-Out/Ex Opt-Out/Ex	2000 2000	2003 EMS - Chiller 2012 Duct Testing/Sealing	Health Health	2014 2014	2054 2054	26.85 21.75	15.97 13.16	2.82 5.10	5.77 10.87	18% 33%	0.36 2.80	1.96 4.77	11% 27%	0.08 0.25	0.06 0.15	1 0	0	0.90 0.44			0.00
Opt-Out/Ex	2000	2008 New Economizer - Chiller	Health	2014	2054	19.29	12.84	2.46	13.34	41%	0.32	5.09	28%	0.19	0.16	2	0	0.31			0.00
Opt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	Health	2014	2054	19.26	12.83	0.03	13.37	41%	0.02	5.10	28%	0.41	0.16	1	0	0.21			0.00
Opt-Out/Ex	2000	2004 Cool Roof - Chiller	Health	2014	2054	19.20	12.80	0.05	13.42	41% 42%	0.03	5.13	29%	1.07	0.16	2	0	0.08			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2100	2011 Duct/Pipe Insulation - Chiller 2100 Base DX Packaged System, EER=10.3, 10 tons	Health Health	2014 2014	2054 2054	18.99 32.62	12.68 17.93	0.22	13.64 0.00	42% 0%	0.12 0.00	5.25 0.00	29% 0%	4.17 N/A	0.22 N/A	N/A	N/A	0.02 N/A	32.62	17.93	0.00
Opt-Out/Ex	2100	2102 DX Packaged System, EER=13.4, 10 tons	Health	2014	2054	25.12	13.81	7.50	7.50	23%	4.12	4.12	23%	0.04	0.04	0	0	2.50			7.50
Opt-Out/Ex	2100	2108 Optimize Controls - DX	Health Health	2014	2054 2054	24.66 24.15	13.75	0.46	7.96 8.47	24%	0.06	4.18	23% 24%	0.10 0.13	0.04	1	0	0.51 0.45			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2106 Prog. Thermostat - DX 2112 Aerosol Duct Sealing - DX	Health Health	2014 2014	2054	24.15 22.68	13.68 12.87	0.51 1.47	9.94	26% 30%	0.07 0.81	4.25 5.06	24% 28%	0.13	0.05 0.08	0	0	0.45			0.00
Opt-Out/Ex	2100	2115 Window Film (Standard) - DX	Health	2014	2054	22.56	12.81	0.12	10.06	31%	0.07	5.12	29%	0.35	0.09	1	0	0.25			0.00
Opt-Out/Ex	2100	2107 Cool Roof - DX	Health	2014	2054	22.49	12.77	0.07	10.13	31%	0.04	5.16	29%	0.91	0.09	2	0	0.09			0.00
Opt-Out/Ex	2100	2114 Duct/Pipe Insulation - DX 2111 Economizer Repair - DX	Health Health	2014	2054 2054	22.24	12.63 12.63	0.25	10.38 10.38	32% 32%	0.14	5.30 5.30	30% 30%	3.56 32188.47	0.17	6 38,820	0	0.02			0.00
Opt-Out/Ex	2100	2109 Economizer - DX	Health	2014	2054	22.24	12.63	0.00	10.38	32%	0.00	5.30	30%	37474.44	0.18	291,636	0	0.00			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Health	2014	2054	18.27	10.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.27	10.04	0.00

DNV GL H-10 1/5/2015

APPENDIX H

Base Avoided Costs

DSM ASSYS'	T ADDITIVE	SUPPLY ANALYSIS				Year	2014		Total			Total		Marginal	Average	Marginal	Average	Total			SUPPLY
viiitage				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource			
		easure Imber Measure	Building Type	Start	End Year	Total	Total MW	GWH Savings	Savings	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base GWH	Base	Economic
Opt-Out/Ex	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	2014	2054	16.01	8.80	2.26	2.26	12%	1.24	1.24	12%	0.03	0.03	0	0	2.91			2.26
Opt-Out/Ex	2300	2300 Base PTAC, EER=8.3, 1 ton	Health	2014	2054	18.27	10.04	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	18.27	10.04	0.00
Opt-Out/Ex Opt-Out/Ex	3000 3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5% 3002 Variable Speed Drive Control, 5 HP	Health Health	2014 2014	2054 2054	6.05 4.15	1.23 1.14	0.00 1.90	0.00 1.90	0% 31%	0.00	0.00	0% 7%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.36	6.05	1.23	0.00 1.90
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Health	2014	2054	4.08	1.12	0.07	1.97	33%	0.01	0.11	9%	0.04	0.02	0	0	2.18			0.07
Opt-Out/Ex	3000	3003 Demand Controlled Ventilation	Health	2014	2054	3.69	0.96	0.39	2.36	39%	0.16	0.27	22%	1.21	0.22	3	2	0.08	04.00	4.07	0.00
Opt-Out/Ex Opt-Out/Ex	3100 3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0% 3102 Variable Speed Drive Control, 15 HP	Health Health	2014 2014	2054 2054	21.03 14.44	4.27 3.95	0.00 6.59	0.00 6.59	0% 31%	0.00 0.32	0.00 0.32	0% 7%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 9.73	21.03	4.27	0.00 6.59
Opt-Out/Ex	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Health	2014	2054	14.41	3.94	0.03	6.63	32%	0.01	0.33	8%	0.02	0.01	0	0	3.86			0.03
Opt-Out/Ex Opt-Out/Ex	3100 3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit 3105 Energy Recovery Ventilation (ERV)	Health Health	2014 2014	2054 2054	12.31 11.51	3.56 3.23	2.10 0.80	8.72 9.52	41% 45%	0.38 0.33	0.71 1.04	17% 24%	0.04 0.38	0.01 0.04	0 1	0	2.09 0.27			2.10 0.00
Opt-Out/Ex	3100	3107 Demand Controlled Ventilation	Health	2014	2054	10.41	2.78	1.10	10.62	50%	0.33	1.49	35%	1.49	0.19	4	1	0.06			0.00
Opt-Out/Ex	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Health	2014	2054	22.35	4.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	22.35	4.54	0.00
Opt-Out/Ex Opt-Out/Ex	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Health Health	2014 2014	2054 2054	20.22 0.00	3.65 0.00	2.13 0.00	2.13 0.00	10% 0%	0.89	0.89	20% 0%	0.82 N/A	0.82 N/A	2 N/A	2 N/A	0.11 N/A	0.00	0.00	0.00
Opt-Out/Ex	4100	4100 Base Self-Contained Refrigeration	Health	2014	2054	3.02	0.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	3.02	0.44	0.00
Opt-Out/Ex	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Health	2014	2054	2.98	0.43	0.05	0.05	2%	0.01	0.01	2%	0.01	0.01	0	0	8.12			0.05
Opt-Out/Ex Opt-Out/Ex	4100 4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Health Health	2014 2014	2054 2054	2.90 2.80	0.42 0.41	0.07 0.10	0.12 0.22	4% 7%	0.01 0.01	0.02 0.03	4% 7%	0.02 0.02	0.02 0.02	0	0	2.84			0.07 0.10
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Health	2014	2054	2.68	0.39	0.12	0.34	11%	0.02	0.05	11%	0.07	0.02	o	0	0.97			0.00
Opt-Out/Ex	4100	4112 Reach-in unit occupancy sensors	Health	2014	2054	2.68	0.39	0.00	0.34	11%	0.00	0.05	11%	0.41	0.04	3	0	0.16			0.00
Opt-Out/Ex Opt-Out/Ex	4100 5000	4105 Bi-level LED Case Lighting (self-contained units) 2014 5000 Base Desktop PC	Health Health	2014 2014	2054 2054	2.67 0.44	0.39 0.06	0.01 0.00	0.35 0.00	12% 0%	0.00	0.05 0.00	12% 0%	0.47 N/A	0.05 N/A	3 N/A	0 N/A	0.13 N/A	0.44	0.06	0.00
Opt-Out/Ex	5000	5001 PC Network Power Management Enabling	Health	2014	2054	0.24	0.05	0.21	0.21	46%	0.01	0.01	23%	0.03	0.03	0	0	1.93	0	0.00	0.21
Opt-Out/Ex	5000	5002 Energy Star or Better PC	Health	2014	2054	0.16	0.04	0.08	0.28	63%	0.01	0.03	40%	0.06	0.03	0	0	0.92			0.00
Opt-Out/Ex Opt-Out/Ex	5100 5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Health Health	2014 2014	2054 2054	0.05 0.04	0.01 0.01	0.00 0.01	0.00 0.01	0% 19%	0.00	0.00	0% 19%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.59	0.05	0.01	0.00 0.01
Opt-Out/Ex	5100	5101 Laptop Network Power Management Enabling	Health	2014	2054	0.04	0.01	0.00	0.01	21%	0.00	0.00	21%	2.48	0.22	17	2	0.02			0.00
Opt-Out/Ex	5200	5200 Base Monitor, CRT	Health	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5300 5300	5300 Base Monitor, LCD 5301 Energy Star or Better Monitor - LCD	Health Health	2014 2014	2054 2054	0.12 0.10	0.02 0.01	0.00 0.02	0.00 0.02	0% 20%	0.00	0.00	0% 20%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.96	0.12	0.02	0.00 0.02
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	Health	2014	2054	0.10	0.01	0.01	0.03	24%	0.00	0.00	22%	0.16	0.04	2	0	0.30			0.00
Opt-Out/Ex	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Health	2014	2054	0.09	0.01	0.01	0.04	30%	0.00	0.00	23%	0.46	0.13	13	1	0.10			0.00
Opt-Out/Ex Opt-Out/Ex	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Health Health	2014 2014	2054 2054	0.22 0.18	0.03	0.00 0.04	0.00 0.04	0% 17%	0.00 0.01	0.00 0.01	0% 17%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 15.02	0.22	0.03	0.00 0.04
Opt-Out/Ex	5400	5402 Copier Power Management Enabling	Health	2014	2054	0.17	0.03	0.01	0.05	22%	0.00	0.01	19%	0.20	0.05	3	0	0.27			0.00
Opt-Out/Ex	5500	5500 Base Multifunction	Health	2014	2054	0.05	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.05	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	5500 5500	5502 ENERGY STAR Multi-Function Device 5501 Multifunction Power Management Enabling	Health Health	2014 2014	2054 2054	0.03	0.00	0.01 0.00	0.01 0.02	25% 36%	0.00	0.00	25% 31%	0.01 0.48	0.01 0.15	0 7	0	4.40 0.11			0.01 0.00
Opt-Out/Ex	5600	5600 Base Printer	Health	2014	2054	0.18	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.18	0.02	0.00
Opt-Out/Ex	5600	5602 ENERGY STAR Printer	Health	2014	2054	0.11	0.02	0.06	0.06	35%	0.01	0.01	35%	0.00	0.00	0	0	20.25			0.06
Opt-Out/Ex Opt-Out/Ex	5600 5700	5601 Printer Power Management Enabling 5700 Base Data Center/Server Room	Health Health	2014 2014	2054 2054	0.10 7.01	0.02 1.00	0.02 0.00	0.08	44% 0%	0.00	0.01 0.00	40% 0%	0.10 N/A	0.02 N/A	1 N/A	0 N/A	0.49 N/A	7.01	1.00	0.00
Opt-Out/Ex	5700	5701 Data Center Improved Operations	Health	2014	2054	6.31	0.90	0.70	0.70	10%	0.10	0.10	10%	0.00	0.00	0	0	72.24			0.70
Opt-Out/Ex Opt-Out/Ex	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Health Health	2014 2014	2054 2054	5.50 5.19	0.78	0.80 0.31	1.50 1.81	21% 26%	0.11 0.04	0.21	21% 26%	0.00	0.00	0	0	29.41 15.25			0.80 0.31
Opt-Out/Ex	6000	6000 Base Water Heating	Health	2014	2054	0.00	0.74	0.00	0.00	0%	0.04	0.26	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	7000	7000 Base Refrigerated Vending Machines	Health	2014	2054	0.74	0.10	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.74	0.10	0.00
Opt-Out/Ex Opt-Out/Ex	7000 7000	7001 Vending Misers (Refrigerated units) 7002 Vending Misers (Refrigerated glass-front units)	Health Health	2014 2014	2054 2054	0.62 0.56	0.10 0.09	0.12 0.07	0.12 0.19	16% 25%	0.01	0.01 0.01	8% 12%	0.03 0.05	0.03	0 1	0	2.00 1.09			0.12 0.07
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Health	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex	7100	7101 Vending Misers (Non-Refrigerated)	Health	2014	2054	0.01	0.00	0.01	0.01	47%	0.00	0.00	23%	0.43	0.43	6	6	0.12			0.00
Opt-Out/Ex Opt-Out/Ex	7200 7300	7200 Base Oven 7300 Base Fryer	Health Health	2014 2014	2054 2054	0.39	0.07 0.13	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.39	0.07	0.00
Opt-Out/Ex	7300	7301 Efficient Fryer	Health	2014	2054	0.62	0.13	0.00	0.00	6%	0.00	0.00	6%	31.87	31.87	167	167	0.00	0.00	0.13	0.00
Opt-Out/Ex	7400	7400 Base Steamer	Health	2014	2054	0.47	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.47	0.09	0.00
Opt-Out/Ex Opt-Out/Ex	8000 8100	8000 Base Heating, Heat Pump (7.7 HSPF) 8100 Base Heating, Other Electric	Health Health	2014 2014	2054 2054	0.00	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00
Opt-Out/Ex	9500	9500 Base Miscellaneous	Health	2014	2054	50.19	6.99	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	50.19	6.99	0.00
Opt-Out/Ex	9500	9501 Xmisc	Health	2014	2054	50.19	6.99	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Lodging Lodging	2020 2020	2054 2054	0.03 0.02	0.00	0.00	0.00	0% 10%	0.00	0.00	0% 10%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 2.86	0.03	0.00	0.00
Opt-Out/Ex	1030	1031 ROB 4L4 Flight Performance To (66 W), 2020	Lodging	2020	2054	0.02	0.00	0.00	0.00	17%	0.00	0.00	17%	0.02	0.02	1	0	0.76			0.00
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Lodging	2020	2054	0.02	0.00	0.00	0.00	17%	0.00	0.00	17%	0.04	0.05	1	0	1.18			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020 1034 ROB 4L4' LED Tube, 2020	Lodging Lodging	2020 2020	2054 2054	0.02	0.00	0.00	0.01	23% 36%	0.00	0.00	22% 34%	0.07	0.05	1 2	0	1.02			0.00
Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Lodging	2020	2054	0.02	0.00	0.00	0.01	38%	0.00	0.00	35%	0.33	0.15	5	1	0.33			0.00
Opt-Out/Ex	1030	1035 LED Troffer (base 4L4T8), 2020	Lodging	2020	2054	0.01	0.00	0.00	0.01	43%	0.00	0.00	40%	0.29	0.17	2	1	0.28	0.4.	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1130 Base Fluorescent Fixture, 2L4T8, 1EB, 2020 1131 ROB 2L4' High Performance T8 (86 W), 2020	Lodging Lodging	2020 2020	2054 2054	0.11	0.01 0.01	0.00 0.01	0.00 0.01	0% 10%	0.00	0.00	0% 10%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.26	0.11	0.01	0.00 0.01
Opt-Out/Ex	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Lodging	2020	2054	0.08	0.01	0.01	0.02	22%	0.00	0.00	22%	0.06	0.05	0	0	1.08			0.01
Opt-Out/Ex	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Lodging	2020	2054	0.08	0.01	0.00	0.02	22%	0.00	0.00	22%	0.07	0.05	1	0	0.79			0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020 1134 ROB 2L4' LED Tube, 2020	Lodging Lodging	2020 2020	2054 2054	0.08	0.01	0.01 0.00	0.03	28% 32%	0.00	0.00	27% 30%	0.10	0.06	1 2	0	0.69			0.00
			99	_020	_50.		2.0.	2.00	2.00	/0	2.00	2.00	-570		2.00	-					

DNV GL H-11 1/5/2015

APPENDIX H

Base Avoided Costs

	T ADDITIVE	SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		easure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt No Opt-Out/Ex	umber Nu 1130	Measure	Type Lodging	Year 2020	Year 2054	0.07	0.01	Savings 0.01	0.04	Savings 37%	Savings 0.00	0.01	Savings 36%	\$/kWH 0.37	\$/kWH 0.13	\$/kW 3	\$/kW	0.22	GWH	MW	0.00
Opt-Out/Ex	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Lodging	2020	2054	0.06	0.01	0.00	0.04	39%	0.00	0.01	36%	0.31	0.14	9	1	0.18			0.00
Opt-Out/Ex	1200	1200 Base Other Fluorescent Fixture	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1203 Lighting Control Tuneup (base other fluorescent fixture) 1201 ROB High Performance T8 (base other fluorescent)	Lodging Lodging	2014 2014	2054 2054	0.00	0.00	0.00	0.00	3% 13%	0.00	0.00	1% 11%	0.02 0.10	0.02	0	0	2.70 0.69			0.00
Opt-Out/Ex	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Lodging	2014	2054	0.00	0.00	0.00	0.00	30%	0.00	0.00	27%	0.23	0.16	2	1	0.30			0.00
Opt-Out/Ex	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Lodging	2014	2054	0.00	0.00	0.00	0.00	35%	0.00	0.00	28%	0.21	0.17	6	1	0.26			0.00
Opt-Out/Ex Opt-Out/Ex	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Lodging Lodging	2020 2020	2054 2054	0.16 0.03	0.02	0.00 0.13	0.00 0.13	0% 81%	0.00 0.02	0.00 0.02	0% 81%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.95	0.16	0.02	0.00 0.13
Opt-Out/Ex	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Lodging	2020	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	Lodging	2020	2054	0.01	0.00	0.05	0.05	79%	0.01	0.01	79%	0.01	0.01	0	0	7.54			0.05
Opt-Out/Ex Opt-Out/Ex	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Lodging Lodging	2020 2020	2054 2054	0.04 0.01	0.01 0.00	0.00	0.00	0% 71%	0.00	0.00	0% 71%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 5.55	0.04	0.01	0.00
Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020	Lodging	2020	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.00	0.00
Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Lodging	2020	2054	0.02	0.00	0.01	0.01	28%	0.00	0.00	28%	0.09	0.09	1	1	0.81			0.00
Opt-Out/Ex Opt-Out/Ex	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Lodging Lodging	2020 2020	2054 2054	0.04	0.01 0.00	0.00 0.01	0.00 0.01	0% 26%	0.00	0.00	0% 26%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.07	0.04	0.01	0.00 0.01
Opt-Out/Ex	1800	1800 BaseMetal Halide, 465W	Lodging	2014	2054	0.03	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.08	0.01	0.00
Opt-Out/Ex	1800	1801 T5 (240W) (base metal halide)	Lodging	2014	2054	0.06	0.01	0.03	0.03	34%	0.00	0.00	34%	0.02	0.02	0	0	4.03			0.03
Opt-Out/Ex	1800	1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Lodging	2014	2054	0.05	0.01	0.00	0.03	39%	0.00	0.00	38%	0.05	0.02	0	0	1.42			0.00
Opt-Out/Ex Opt-Out/Ex	1800 1850	1806 Occupancy Sensor, High Bay T5 1850 Base CFL Exit Sign	Lodging Lodging	2014 2014	2054 2054	0.05	0.01	0.00	0.03	41% 0%	0.00	0.00	38% 0%	0.05 N/A	0.02 N/A	2 N/A	0 N/A	1.07 N/A	0.02	0.00	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	Lodging	2014	2054	0.01	0.00	0.01	0.01	44%	0.00	0.00	44%	0.03	0.03	0	0	2.00	0.02	0.00	0.01
Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Lodging	2014	2054	0.12	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1900 1900	1901 Outdoor Lighting Controls (Photocell/Timeclock) 1902 LED Outdoor Area Lighting	Lodging Lodging	2014 2014	2054 2054	0.10 0.05	0.00	0.02 0.05	0.02 0.08	20% 61%	0.00	0.00	66% 108%	0.06 0.11	0.06 0.10	2 13	2 6	1.26 0.56			0.02
Opt-Out/Ex	1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Loaging	2014	2054	0.05	0.00	0.05	0.08	73%	0.00	0.00	118%	0.11	0.10	95	14	0.56			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Lodging	2014	2054	0.43	0.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.43	0.26	0.00
Opt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	Lodging	2014	2054	0.41	0.25	0.02	0.02	4%	0.01	0.01	4%	0.03	0.03	0	0	2.93			0.02
Opt-Out/Ex Opt-Out/Ex	2000 2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons 2013 High Efficiency Chiller Motors	Lodging Lodging	2014 2014	2054 2054	0.37 0.37	0.23 0.23	0.03	0.05 0.05	12% 12%	0.02	0.03	12% 12%	0.05 0.08	0.04 0.04	0	0	2.23 1.47			0.03
Opt-Out/Ex	2000	2006 VSD for Chiller Pumps and Towers	Lodging	2014	2054	0.37	0.23	0.00	0.05	12%	0.00	0.03	12%	0.06	0.05	ō	ō	1.33			0.00
Opt-Out/Ex	2000	2008 New Economizer - Chiller	Lodging	2014	2054	0.24	0.21	0.14	0.19	44%	0.02	0.05	20%	0.06	0.06	0	0	1.00			0.14
Opt-Out/Ex Opt-Out/Ex	2000 2000	2003 EMS - Chiller 2012 Duct Testing/Sealing	Lodging Lodging	2014 2014	2054 2054	0.22 0.18	0.20 0.18	0.02 0.04	0.21 0.25	49% 59%	0.00 0.02	0.05 0.08	21% 30%	0.13 0.42	0.06 0.12	1	0	0.53 0.26			0.00
Opt-Out/Ex	2000	2004 Cool Roof - Chiller	Lodging	2014	2054	0.17	0.18	0.04	0.25	59%	0.02	0.08	30%	1.89	0.12	3	0	0.25			0.00
Opt-Out/Ex	2000	2011 Duct/Pipe Insulation - Chiller	Lodging	2014	2054	0.17	0.18	0.00	0.25	59%	0.00	0.08	31%	4.50	0.14	7	0	0.02			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Lodging	2014	2054	1.09	0.65	0.00	0.00	0% 5%	0.00	0.00	0% 5%	N/A 0.03	N/A	N/A 0	N/A 0	N/A 2.87	1.09	0.65	0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2115 Window Film (Standard) - DX 2102 DX Packaged System, EER=13.4, 10 tons	Lodging Lodging	2014 2014	2054 2054	1.03 0.79	0.62 0.48	0.06 0.24	0.06	5% 27%	0.03	0.03 0.18	5% 27%	0.03	0.03	0	0	2.87			0.06 0.24
Opt-Out/Ex	2100	2108 Optimize Controls - DX	Lodging	2014	2054	0.78	0.48	0.01	0.31	28%	0.00	0.18	27%	0.08	0.04	1	Ö	0.65			0.00
Opt-Out/Ex	2100	2106 Prog. Thermostat - DX	Lodging	2014	2054	0.76	0.47	0.02	0.33	30%	0.00	0.18	28%	0.14	0.05	1	0	0.40			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2112 Aerosol Duct Sealing - DX 2111 Economizer Repair - DX	Lodging Lodging	2014 2014	2054 2054	0.71 0.71	0.44	0.05 0.00	0.38 0.38	35% 35%	0.03	0.21 0.21	32% 32%	0.31 0.88	0.08	1	0	0.36			0.00
Opt-Out/Ex	2100	2107 Cool Roof - DX	Lodging	2014	2054	0.70	0.44	0.00	0.38	35%	0.00	0.21	33%	1.20	0.09	2	0	0.10			0.00
Opt-Out/Ex	2100	2109 Economizer - DX	Lodging	2014	2054	0.69	0.44	0.01	0.39	36%	0.00	0.21	33%	1.04	0.12	7	0	0.06			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX 2114 Duct/Pipe Insulation - DX	Lodging	2014 2014	2054 2054	0.69 0.69	0.44 0.43	0.00	0.39 0.40	36% 37%	0.00	0.21	33% 34%	1.75 2.93	0.12 0.17	12 5	0	0.04			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Lodging Lodging	2014	2054	0.89	0.43	0.00	0.40	0%	0.00	0.22	0%	2.93 N/A	N/A	N/A	N/A	0.03 N/A	0.84	0.51	0.00
Opt-Out/Ex	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	2014	2054	0.74	0.44	0.10	0.10	12%	0.06	0.06	12%	0.03	0.03	0	0	3.96			0.10
Opt-Out/Ex	2300	2300 Base PTAC, EER=8.3, 1 ton	Lodging	2014	2054	0.18	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.18	0.11	0.00
Opt-Out/Ex Opt-Out/Ex	2300 2300	2301 HE PTAC, EER=9.6, 1 ton 2302 Occupancy Sensor (hotels)	Lodging Lodging	2014 2014	2054 2054	0.15 0.13	0.09 0.07	0.02 0.02	0.02 0.05	14% 26%	0.01 0.02	0.01 0.03	14% 30%	0.08 0.26	0.08 0.16	0	0	1.35 0.39			0.02
Opt-Out/Ex	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Lodging	2014	2054	0.71	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.71	0.15	0.00
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Lodging	2014	2054	0.70	0.15	0.01	0.01	2%	0.00	0.00	2%	0.03	0.03	0	0	2.66			0.01
Opt-Out/Ex Opt-Out/Ex	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Lodging Lodging	2014 2014	2054 2054	0.60	0.11	0.10	0.11	15% 0%	0.04	0.04	30% 0%	0.97 N/A	0.86 N/A	2 N/A	2 N/A	0.10 N/A	0.00	0.00	0.00
Opt-Out/Ex	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Lodging	2014	2054	0.12	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.12	0.03	0.00
Opt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP	Lodging	2014	2054	0.11	0.03	0.01	0.01	10%	0.00	0.00	3%	0.02	0.02	0	0	2.25			0.01
Opt-Out/Ex Opt-Out/Ex	3200 4000	3204 Demand Controlled Ventilation 4000 Base Built-Up Refrigeration System	Lodging Lodging	2014 2014	2054 2054	0.09	0.02	0.02	0.03	23% 0%	0.01 0.00	0.01 0.00	28% 0%	1.06 N/A	0.59 N/A	2 N/A	2 N/A	0.09 N/A	0.00	0.00	0.00
Opt-Out/Ex	4100	4100 Base Self-Contained Refrigeration	Lodging	2014	2054	0.40	0.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.40	0.06	0.00
Opt-Out/Ex	4100	4103 Night covers for display cases (self-contained)	Lodging	2014	2054	0.38	0.06	0.02	0.02	4%	0.00	0.00	4%	0.00	0.00	0	0	75.70			0.02
Opt-Out/Ex	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Lodging	2014	2054	0.38	0.06	0.00	0.02	6%	0.00	0.00	6%	0.00	0.00	0	0	28.53			0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4109 Energy-Star Freezer, glass door 4107 Energy-Star Freezer, solid door	Lodging Lodging	2014 2014	2054 2054	0.37	0.05 0.05	0.01	0.03	7% 8%	0.00	0.00	7% 8%	0.00	0.00	0	0	22.27 8.87			0.01
Opt-Out/Ex	4100	4106 Energy-Star Refrigerator, solid door	Lodging	2014	2054	0.37	0.05	0.00	0.03	8%	0.00	0.00	8%	0.01	0.00	0	0	7.07			0.00
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Lodging	2014	2054	0.37	0.05	0.00	0.04	9%	0.00	0.01	9%	0.02	0.00	0	0	2.62			0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4105 Bi-level LED Case Lighting (self-contained units) 2014	Lodging	2014 2014	2054 2054	0.37 0.36	0.05 0.05	0.00	0.04 0.04	9% 10%	0.00	0.01 0.01	9% 10%	0.33 0.35	0.00	2	0	0.18 0.15			0.00
Opt-Out/Ex	5000	4101 Strip curtains for walk-ins (self-contained) 5000 Base Desktop PC	Lodging Lodging	2014	2054	0.36	0.05	0.00	0.04	0%	0.00	0.01	0%	0.35 N/A	0.03 N/A	N/A	N/A	0.15 N/A	0.03	0.00	0.00
Opt-Out/Ex	5000	5002 Energy Star or Better PC	Lodging	2014	2054	0.02	0.00	0.01	0.01	21%	0.00	0.00	21%	0.01	0.01	0	0	3.97			0.01
Opt-Out/Ex	5000	5001 PC Network Power Management Enabling	Lodging	2014	2054	0.01	0.00	0.01	0.01	58%	0.00	0.00	39%	0.02	0.02	0	0	3.06	0.00	0.00	0.01
Opt-Out/Ex	5100	5100 Base Laptop PC	Lodging	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00

DNV GL H-12 1/5/2015

APPENDIX H

Base Avoided Costs

	T ADDITIVE	SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		asure mher Measure	Building	Start	End	Total	Total MW	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test	Base	Base	Economic
Sgmt No Opt-Out/Ex	umber Nu 5100	mber Measure 5102 Energy Star or Better Laptop	Type Lodging	Year 2014	Year 2054	0.00	0.00	Savings 0.00	0.00	Savings 19%	Savings 0.00	0.00	Savings 19%	\$/kWH 0.01	0.01	\$/ kW	\$/ KW	5.20	GWH	MW	GWH 0.00
Opt-Out/Ex	5100	5101 Laptop Network Power Management Enabling	Lodging	2014	2054	0.00	0.00	0.00	0.00	21%	0.00	0.00	21%	1.24	0.11	8	1	0.04			0.00
Opt-Out/Ex Opt-Out/Ex	5200 5200	5200 Base Monitor, CRT 5201 Energy Star or Better Monitor - CRT	Lodging Lodging	2014 2014	2054 2054	0.01 0.00	0.00	0.00	0.00	0% 56%	0.00	0.00	0% 56%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 41.36	0.01	0.00	0.00
Opt-Out/Ex	5200	5202 Monitor Power Management Enabling - CRT	Lodging	2014	2054	0.00	0.00	0.00	0.01	67%	0.00	0.00	61%	0.02	0.00	0	ō	2.92			0.00
Opt-Out/Ex Opt-Out/Ex	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Lodging Lodging	2014 2014	2054 2054	0.00 0.01	0.00	0.00	0.01 0.00	69% 0%	0.00	0.00	64% 0%	0.21 N/A	0.01 N/A	1 N/A	0 N/A	0.26 N/A	0.01	0.00	0.00
Opt-Out/Ex	5300	5301 Energy Star or Better Monitor - LCD	Lodging	2014	2054	0.00	0.00	0.00	0.00	10%	0.00	0.00	10%	0.01	0.01	0	0	6.66	0.01	0.00	0.00
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	Lodging	2014	2054	0.00	0.00	0.00	0.00	20%	0.00	0.00	15%	0.08	0.05	1	0	0.61			0.00
Opt-Out/Ex Opt-Out/Ex	5300 5400	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD) 5400 Base Copier	Lodging Lodging	2014 2014	2054 2054	0.00 0.01	0.00	0.00	0.00	27% 0%	0.00	0.00	17% 0%	0.22 N/A	0.09 N/A	6 N/A	1 N/A	0.21 N/A	0.01	0.00	0.00
Opt-Out/Ex	5400	5401 Energy Star or Better Copier	Lodging	2014	2054	0.01	0.00	0.00	0.00	10%	0.00	0.00	10%	0.00	0.00	0	0	32.75			0.00
Opt-Out/Ex Opt-Out/Ex	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Lodging Lodging	2014 2014	2054 2054	0.01	0.00	0.00	0.00	13% 0%	0.00	0.00	12% 0%	0.09 N/A	0.03 N/A	1 N/A	0 N/A	0.60 N/A	0.00	0.00	0.00
Opt-Out/Ex	5500	5502 ENERGY STAR Multi-Function Device	Lodging	2014	2054	0.00	0.00	0.00	0.00	25%	0.00	0.00	25%	0.01	0.01	0	0	8.85	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Lodging Lodging	2014 2014	2054 2054	0.00	0.00	0.00	0.00	39% 0%	0.00	0.00	32% 0%	0.26 N/A	0.09 N/A	3 N/A	1 N/A	0.20 N/A	0.00	0.00	0.00
Opt-Out/Ex	5600	5602 ENERGY STAR Printer	Lodging	2014	2054	0.00	0.00	0.00	0.00	35%	0.00	0.00	35%	0.00	0.00	0	0	40.66	0.00	0.00	0.00
Opt-Out/Ex	5600	5601 Printer Power Management Enabling	Lodging	2014	2054	0.00	0.00	0.00	0.00	47%	0.00	0.00	41%	0.06	0.02	1	0	0.92			0.00
Opt-Out/Ex Opt-Out/Ex	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Lodging Lodging	2014 2014	2054 2054	0.11 0.10	0.02	0.00	0.00 0.01	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 116.16	0.11	0.02	0.00
Opt-Out/Ex	5700	5702 Data Center Best Practices	Lodging	2014	2054	0.09	0.01	0.01	0.02	21%	0.00	0.00	21%	0.00	0.00	0	Ō	47.29			0.01
Opt-Out/Ex	5700 6000	5703 Data Center State of the Art practices 6000 Base Water Heating	Lodging	2014 2014	2054 2054	0.08	0.01 0.02	0.01 0.00	0.03	26% 0%	0.00	0.00	26% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	24.53 N/A	0.18	0.02	0.01
Opt-Out/Ex Opt-Out/Ex	6000	6007 Heat Trap	Lodging Lodging	2014	2054	0.18	0.02	0.00	0.00	5%	0.00	0.00	5%	0.01	0.01	0	0	4.77	0.16	0.02	0.00
Opt-Out/Ex	6000	6006 Heat Recovery Unit	Lodging	2014	2054	0.15	0.02	0.02	0.03	18%	0.00	0.00	18%	0.02	0.02	0	0	3.57			0.02
Opt-Out/Ex Opt-Out/Ex	6000 6000	6001 Demand controlled circulating systems 6002 High Efficiency Water Heater (electric)	Lodging Lodging	2014 2014	2054 2054	0.14 0.14	0.02 0.02	0.01 0.00	0.04 0.04	21% 22%	0.00	0.00 0.01	21% 22%	0.03	0.02 0.02	0	0	2.46 2.14			0.01
Opt-Out/Ex	6000	6004 Tankless Water Heater	Lodging	2014	2054	0.13	0.02	0.01	0.05	28%	0.00	0.01	28%	0.05	0.03	0	0	1.53			0.01
Opt-Out/Ex Opt-Out/Ex	6000 6000	6008 Solar Water Heater 6003 Hot Water Pipe Insulation	Lodging Lodging	2014 2014	2054 2054	0.11 0.11	0.01 0.01	0.02	0.07 0.07	38% 39%	0.00	0.01 0.01	38% 39%	0.06 0.07	0.03 0.04	0	0	1.31 1.02			0.02
Opt-Out/Ex	7000	7000 Base Refrigerated Vending Machines	Lodging	2014	2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00
Opt-Out/Ex	7000	7001 Vending Misers (Refrigerated units)	Lodging	2014	2054	0.04	0.01	0.01	0.01	16%	0.00	0.00	8%	0.03	0.03	0	0	2.01			0.01
Opt-Out/Ex Opt-Out/Ex	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Lodging Lodging	2014 2014	2054 2054	0.03	0.01 0.00	0.00	0.01 0.00	25% 0%	0.00	0.00	12% 0%	0.05 N/A	0.03 N/A	1 N/A	0 N/A	1.10 N/A	0.00	0.00	0.00
Opt-Out/Ex	7100	7101 Vending Misers (Non-Refrigerated)	Lodging	2014	2054	0.00	0.00	0.00	0.00	47%	0.00	0.00	23%	0.43	0.43	5	5	0.12			0.00
Opt-Out/Ex Opt-Out/Ex	7200 7300	7200 Base Oven 7300 Base Fryer	Lodging Lodging	2014 2014	2054 2054	0.01	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.01	0.00	0.00
Opt-Out/Ex	7400	7400 Base Steamer	Lodging	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
Opt-Out/Ex	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Lodging	2014	2054	0.07	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.07	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	8000 8100	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 8100 Base Heating, Other Electric	Lodging Lodging	2014 2014	2054 2054	0.07 0.06	0.00	0.00	0.00	6% 0%	0.00	0.00	0% 0%	0.02 N/A	0.02 N/A	N/A N/A	N/A N/A	2.43 N/A	0.06	0.00	0.00
Opt-Out/Ex	9500	9500 Base Miscellaneous	Lodging	2014	2054	0.79	0.13	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.79	0.13	0.00
Opt-Out/Ex Opt-Out/Ex	9500 1030	9501 Xmisc 1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Lodging Data Centers	2014 2020	2054 2054	0.79 17.77	0.13 3.09	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 N/A	17.77	3.09	0.00
Opt-Out/Ex	1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Data Centers	2020	2054	17.71	3.09	0.05	0.05	0%	0.00	0.00	0%	0.01	0.01	0	0	4.43		0.00	0.05
Opt-Out/Ex Opt-Out/Ex	1030 1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Data Centers Data Centers	2020 2020	2054 2054	16.40 14.73	2.90 2.61	1.31 1.67	1.36 3.03	8% 17%	0.18 0.29	0.19 0.48	6% 16%	0.02	0.02	0	0	4.13 2.34			1.31 1.67
Opt-Out/Ex	1030	1032 ROB 4L4 High Performance T8 (80 W), 2020	Data Centers	2020	2054	13.37	2.37	1.36	4.40	25%	0.24	0.72	23%	0.03	0.02	0	0	0.82			0.00
Opt-Out/Ex	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Data Centers	2020	2054	12.31	2.32	1.06	5.46	31%	0.05	0.77	25%	0.08	0.05	2	0	0.69			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Data Centers Data Centers	2020 2020	2054 2054	10.33 9.44	1.98 1.83	1.98 0.88	7.44 8.32	42% 47%	0.35 0.15	1.11 1.27	36% 41%	0.34 0.29	0.13	2	1	0.22 0.26			0.00
Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Data Centers	2020	2054	0.30	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.30	0.05	0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Data Centers Data Centers	2020 2020	2054 2054	0.30 0.28	0.05 0.05	0.00 0.02	0.00 0.02	0% 8%	0.00	0.00	0% 6%	0.02	0.02 0.03	0	0	2.57 2.40			0.00 0.02
Opt-Out/Ex	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Data Centers	2020	2054	0.25	0.03	0.02	0.02	17%	0.01	0.00	16%	0.03	0.03	0	0	1.84			0.03
Opt-Out/Ex	1130 1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Data Centers Data Centers	2020 2020	2054 2054	0.22	0.04	0.03	0.08	28% 31%	0.01	0.01	26% 30%	0.07 0.27	0.05	0	0	0.88 0.28			0.00
Opt-Out/Ex Opt-Out/Ex	1130	1134 ROB 2L4' LED Tube, 2020 1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Data Centers Data Centers	2020	2054	0.21	0.04	0.01	0.09	37%	0.00	0.02 0.02	30%	0.27	0.07	3	1	0.28			0.00
Opt-Out/Ex	1130	1135 LED Troffer (base 2L4'T8), 2020	Data Centers	2020	2054	0.17	0.03	0.02	0.13	42%	0.00	0.02	37%	0.37	0.12	2	1	0.20			0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Data Centers Data Centers	2014 2014	2054 2054	0.65 0.64	0.11 0.11	0.00 0.01	0.00 0.01	0% 2%	0.00	0.00	0% 1%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 12.46	0.65	0.11	0.00 0.01
Opt-Out/Ex	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Data Centers	2014	2054	0.59	0.11	0.05	0.06	9%	0.01	0.01	7%	0.04	0.03	0	Ō	1.91			0.05
Opt-Out/Ex	1200 1200	1201 ROB High Performance T8 (base other fluorescent)	Data Centers Data Centers	2014 2014	2054 2054	0.53 0.46	0.09	0.06	0.12 0.19	19% 30%	0.01	0.02	16% 19%	0.11 0.15	0.07 0.10	1 3	0	0.57 0.36			0.00
Opt-Out/Ex	1330	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Data Centers Data Centers	2014	2054	0.46 5.49	0.09	0.07	0.19	30% 0%	0.00	0.02	19% 0%	0.15 N/A	0.10 N/A	N/A	1 N/A	0.36 N/A	5.49	0.96	0.00
Opt-Out/Ex	1330	1332 LEDs (base incandescent flood) 2020	Data Centers	2020	2054	1.08	0.19	4.41	4.41	80%	0.77	0.77	80%	0.01	0.01	0	0	9.39			4.41
Opt-Out/Ex	1430 1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020 1432 LEDs (base incandescent A-line 72W) 2020	Data Centers Data Centers	2020 2020	2054 2054	1.98 0.42	0.34 0.07	0.00 1.56	0.00 1.56	0% 79%	0.00 0.27	0.00 0.27	0% 79%	N/A 0.01	N/A 0.01	N/A 0	N/A	N/A 7.91	1.98	0.34	0.00 1.56
Opt-Out/Ex	1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Data Centers	2020	2054	1.45	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.45	0.25	0.00
Opt-Out/Ex	1530 1630	1532 LEDs (base incandescent A-line 53W) 2020 1630 Base CFL 18W to screw-in replacement 2020	Data Centers	2020	2054	0.42	0.07	1.03	1.03	71% 0%	0.18	0.18	71% 0%	0.01 N/A	0.01 N/A	0 N/A	0	5.82 N/A	4.44	0.19	1.03
Opt-Out/Ex Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020 1631 LED screw-in replacement (base CFL 18W) 2020	Data Centers Data Centers	2020	2054 2054	1.11 0.80	0.19	0.00	0.00 0.31	28%	0.00	0.00	0% 28%	0.07	0.07	N/A 0	N/A 0	0.83	1.11	0.19	0.00
Opt-Out/Ex	1730	1730 Base CFL 23W to screw-in replacement 2020	Data Centers	2020	2054	1.42	0.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.42	0.25	0.00

DNV GL H-13 1/5/2015

APPENDIX H

Base Avoided Costs

	T ADDITIVE	E SUPPLY ANALYSIS				Year	2014		Total			Total		Manadarat		Manadaad		Total			SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
		leasure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt No Opt-Out/Ex	umber N 1730	umber Measure 1731 LED screw-in replacement (base CFL 23W) 2020	Type Data Centers	Year 2020	Year 2054	1.05	0.18	Savings 0.37	0.37	Savings 26%	Savings 0.06	0.06	Savings 26%	\$/kWH 0.06	\$/kWH 0.06	\$/kW	\$/kW	1.11	GWH	MW	0.37
Opt-Out/Ex	1800	1800 BaseMetal Halide, 465W	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	1850 1850	1850 Base CFL Exit Sign 1851 LFD Exit Sign	Data Centers Data Centers	2014 2014	2054 2054	0.28	0.05	0.00	0.00 0.12	0% 44%	0.00 0.02	0.00 0.02	0% 44%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.78	0.28	0.05	0.00 0.12
Opt-Out/Ex	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Data Centers	2014	2054	4.17	0.05	0.12	0.12	0%	0.02	0.02	0%	0.03 N/A	0.03 N/A	N/A	N/A	N/A	4.17	0.05	0.00
Opt-Out/Ex	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Data Centers	2014	2054	2.80	0.02	1.37	1.37	33%	0.03	0.03	66%	0.04	0.04	2	2	1.86			1.37
Opt-Out/Ex Opt-Out/Ex	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Data Centers Data Centers	2014 2014	2054 2054	1.35	0.00	1.45 0.38	2.82 3.21	68% 77%	0.02	0.05 0.05	101% 109%	0.16 1.07	0.10 0.22	14 104	6 14	0.42			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Data Centers	2014	2054	36.02	8.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	36.02	8.87	0.00
Opt-Out/Ex Opt-Out/Ex	2000	2010 Ceiling/roof Insulation - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Data Centers Data Centers	2014 2014	2054 2054	35.86 32.80	8.83 8.07	0.16 3.06	0.16 3.22	0% 9%	0.04	0.04 0.79	0% 9%	0.00 0.02	0.00 0.02	0	0	22.49 5.12			0.16 3.06
Opt-Out/Ex	2000	2006 VSD for Chiller Pumps and Towers	Data Centers Data Centers	2014	2054	32.57	8.05	0.23	3.45	10%	0.75	0.79	9%	0.02	0.02	0	0	3.78			0.23
Opt-Out/Ex	2000	2013 High Efficiency Chiller Motors	Data Centers	2014	2054	32.51	8.03	0.06	3.51	10%	0.01	0.83	9%	0.03	0.02	0	0	3.32			0.06
Opt-Out/Ex Opt-Out/Ex	2000 2000	2003 EMS - Chiller 2008 New Economizer - Chiller	Data Centers Data Centers	2014 2014	2054	31.68 29.39	7.99 7.86	0.84 2.29	4.35 6.63	12% 18%	0.05	0.88 1.01	10% 11%	0.03	0.02 0.02	0	0	2.55 1.99			0.84 2.29
Opt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	Data Centers	2014	2054	29.38	7.85	0.01	6.64	18%	0.00	1.01	11%	0.05	0.02	o o	0	1.32			0.01
Opt-Out/Ex	2000	2012 Duct Testing/Sealing	Data Centers	2014	2054	23.80	6.48	5.58	12.22	34%	1.37	2.39	27%	0.09	0.05	0	0	0.94			0.00
Opt-Out/Ex Opt-Out/Ex	2000 2000	2004 Cool Roof - Chiller 2011 Duct/Pipe Insulation - Chiller	Data Centers Data Centers	2014 2014	2054 2054	23.72 23.65	6.46 6.44	0.07 0.07	12.30 12.37	34% 34%	0.02 0.02	2.40	27% 27%	0.14 1.13	0.05 0.06	5	0	0.53 0.06			0.00
Opt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Data Centers	2014	2054	20.54	5.06	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	20.54	5.06	0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2102 DX Packaged System, EER=13.4, 10 tons 2111 Economizer Repair - DX	Data Centers Data Centers	2014 2014	2054 2054	15.82 15.47	3.89 3.74	4.72 0.34	4.72 5.07	23% 25%	1.16 0.15	1.16 1.31	23% 26%	0.01 0.04	0.01 0.02	0	0	5.45 1.68			4.72 0.34
Opt-Out/Ex	2100	2108 Optimize Controls - DX	Data Centers	2014	2054	15.18	3.73	0.29	5.36	26%	0.02	1.33	26%	0.03	0.02	1	0	1.64			0.29
Opt-Out/Ex	2100	2109 Economizer - DX	Data Centers	2014	2054	13.35	3.62	1.83	7.19	35%	0.10	1.43	28%	0.04	0.02	1	0	1.44			1.83
Opt-Out/Ex Opt-Out/Ex	2100 2100	2115 Window Film (Standard) - DX 2106 Prog. Thermostat - DX	Data Centers Data Centers	2014 2014	2054 2054	13.07 12.43	3.56 3.52	0.28 0.64	7.47 8.11	36% 39%	0.07	1.50 1.54	30% 30%	0.07	0.03	0	0	1.02			0.28 0.64
Opt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Data Centers	2014	2054	11.68	3.33	0.76	8.87	43%	0.19	1.72	34%	0.12	0.04	ò	0	0.69			0.00
Opt-Out/Ex	2100	2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Data Centers	2014	2054	11.67	3.33	0.00	8.87	43%	0.00	1.72	34%	0.12	0.04	2	0	0.50			0.00
Opt-Out/Ex Opt-Out/Ex	2100 2100	2107 Cool Roof - DX 2114 Duct/Pipe Insulation - DX	Data Centers Data Centers	2014 2014	2054 2054	11.57 11.50	3.31 3.29	0.10 0.07	8.97 9.04	44% 44%	0.02	1.75 1.77	35% 35%	0.16 1.33	0.04 0.05	1 5	0	0.45			0.00
Opt-Out/Ex	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Data Centers	2014	2054	2.63	0.65	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.63	0.65	0.00
Opt-Out/Ex Opt-Out/Ex	2200 2300	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF) 2300 Base PTAC, EER=8.3, 1 ton	Data Centers Data Centers	2014 2014	2054 2054	2.31 0.00	0.57 0.00	0.33	0.33	12% 0%	0.08	0.08	12% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	7.64 N/A	0.00	0.00	0.33
Opt-Out/Ex	3000	3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Data Centers	2014	2054	5.27	1.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	5.27	1.30	0.00
Opt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Data Centers	2014	2054	5.19	1.28	0.09	0.09	2%	0.02	0.02	2%	0.02	0.02	0	0	5.03			0.09
Opt-Out/Ex Opt-Out/Ex	3000 3000	3002 Variable Speed Drive Control, 5 HP 3003 Demand Controlled Ventilation	Data Centers Data Centers	2014 2014	2054 2054	3.92	1.20 1.10	1.27 0.23	1.35 1.58	26% 30%	0.08	0.10	8% 15%	0.01 0.55	0.01 0.09	0	0	4.84 0.18			1.27 0.00
Opt-Out/Ex	3100	3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Data Centers	2014	2054	18.33	4.51	0.23	0.00	0%	0.00	0.20	0%	0.55 N/A	0.09 N/A	N/A	N/A	0.16 N/A	18.33	4.51	0.00
Opt-Out/Ex	3100	3102 Variable Speed Drive Control, 15 HP	Data Centers	2014	2054	13.84	4.23	4.48	4.48	24%	0.28	0.28	6%	0.00	0.00	0	0	17.82			4.48
Opt-Out/Ex Opt-Out/Ex	3100 3100	3101 Fan Motor, 15hp, 1800rpm, 92.4% 3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Data Centers Data Centers	2014 2014	2054 2054	13.76 12.86	4.21 4.01	0.08	4.57 5.47	25% 30%	0.02	0.30	7% 11%	0.01	0.00	0	0	8.36 3.68			0.08
Opt-Out/Ex	3100	3103 Air Handler Optimization, 15 HP	Data Centers	2014	2054	11.65	3.93	1.21	6.68	36%	0.08	0.58	13%	0.02	0.01	0	0	2.93			1.21
Opt-Out/Ex	3100	3105 Energy Recovery Ventilation (ERV)	Data Centers	2014	2054	11.36	3.81	0.29	6.97	38%	0.13	0.70	16%	0.21	0.02	0	0	0.51			0.00
Opt-Out/Ex Opt-Out/Ex	3100 3200	3107 Demand Controlled Ventilation 3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Data Centers Data Centers	2014 2014	2054 2054	10.70 19.47	3.52 4.79	0.65	7.62	42% 0%	0.29	0.99	22% 0%	0.65 N/A	0.07 N/A	1 N/A	1 N/A	0.15 N/A	19.47	4.79	0.00
Opt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP	Data Centers	2014	2054	17.63	4.68	1.84	1.84	9%	0.11	0.11	2%	0.01	0.01	0	0	4.17	10.11	0	1.84
Opt-Out/Ex	3200	3202 Variable Speed Drive Control, 40 HP	Data Centers	2014	2054	13.32	4.41	4.31	6.15	32%	0.27	0.38	8%	0.02	0.02	0	0	3.20			4.31
Opt-Out/Ex Opt-Out/Ex	3200 3200	3201 Fan Motor, 40hp, 1800rpm, 94.1% 3204 Demand Controlled Ventilation	Data Centers Data Centers	2014 2014	2054 2054	13.26 12.50	4.40 4.06	0.06 0.76	6.21 6.98	32% 36%	0.01 0.34	0.40	8% 15%	0.09	0.02	0	1	0.94			0.00
Opt-Out/Ex	4000	4000 Base Built-Up Refrigeration System	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4100 Base Self-Contained Refrigeration 4109 Energy-Star Freezer, glass door	Data Centers Data Centers	2014 2014	2054 2054	3.79 3.79	0.71 0.71	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 25.72	3.79	0.71	0.00
Opt-Out/Ex	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Data Centers	2014	2054	3.79	0.70	0.07	0.07	2%	0.00	0.00	2%	0.00	0.00	0	0	23.61			0.07
Opt-Out/Ex	4100	4107 Energy-Star Freezer, solid door	Data Centers	2014	2054	3.72	0.70	0.00	0.07	2%	0.00	0.01	2%	0.01	0.00	0	0	10.30			0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Data Centers Data Centers	2014 2014	2054 2054	3.72 3.71	0.70 0.70	0.00	0.08 0.08	2% 2%	0.00	0.01 0.01	2% 2%	0.01 0.01	0.00	0	0	8.71 8.35			0.00
Opt-Out/Ex	4100	4110 Energy Star Ice Machines	Data Centers	2014	2054	3.71	0.70	0.00	0.08	2%	0.00	0.02	2%	0.02	0.00	0	0	3.10			0.00
Opt-Out/Ex	4100	4112 Reach-in unit occupancy sensors	Data Centers	2014	2054	3.71	0.70	0.00	80.0	2%	0.00	0.02	2%	0.31	0.00	2	0	0.22			0.00
Opt-Out/Ex Opt-Out/Ex	4100 4100	4105 Bi-level LED Case Lighting (self-contained units) 2014 4101 Strip curtains for walk-ins (self-contained)	Data Centers Data Centers	2014 2014	2054 2054	3.71 3.71	0.70	0.00	0.08	2% 2%	0.00	0.02 0.02	2% 2%	0.36 8.40	0.00	2 45	0	0.18 0.01			0.00
Opt-Out/Ex	5000	5000 Base Desktop PC	Data Centers	2014	2054	0.50	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.50	0.09	0.00
Opt-Out/Ex	5000 5000	5001 PC Network Power Management Enabling	Data Centers Data Centers	2014 2014	2054 2054	0.28	0.07	0.22	0.22	44% 56%	0.02	0.02	23% 35%	0.02	0.02	0	0	3.22 1.78			0.22
Opt-Out/Ex	5100	5002 Energy Star or Better PC 5100 Base Laptop PC	Data Centers Data Centers	2014	2054	0.22	0.06	0.06	0.28	0%	0.00	0.03	35% 0%	0.03 N/A	0.02 N/A	N/A	N/A	1.78 N/A	0.04	0.01	0.06
Opt-Out/Ex	5100	5102 Energy Star or Better Laptop	Data Centers	2014	2054	0.03	0.01	0.01	0.01	19%	0.00	0.00	19%	0.01	0.01	0	0	4.64			0.01
Opt-Out/Ex	5100 5200	5101 Laptop Network Power Management Enabling 5200 Base Monitor, CRT	Data Centers Data Centers	2014 2014	2054 2054	0.03 0.21	0.00 0.04	0.00	0.01	21% 0%	0.00	0.00	21% 0%	1.46 N/A	0.13 N/A	8 N/A	1 N/A	0.04 N/A	0.21	0.04	0.00
Opt-Out/Ex	5200	5201 Energy Star or Better Monitor - CRT	Data Centers	2014	2054	0.12	0.04	0.00	0.00	43%	0.02	0.00	43%	0.00	0.00	0	0	48.34	V.2.1	0.04	0.09
Opt-Out/Ex	5200	5202 Monitor Power Management Enabling - CRT	Data Centers	2014	2054	0.10	0.02	0.01	0.10	50%	0.00	0.02	46%	0.01	0.00	0	0	3.75			0.01
Opt-Out/Ex Opt-Out/Ex	5200 5300	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT) 5300 Base Monitor, LCD	Data Centers Data Centers	2014 2014	2054 2054	0.10	0.02 0.02	0.01 0.00	0.11	54% 0%	0.00	0.02	50% 0%	0.16 N/A	0.01 N/A	1 N/A	0 N/A	0.35 N/A	0.13	0.02	0.00
Opt-Out/Ex	5300	5301 Energy Star or Better Monitor - LCD	Data Centers	2014	2054	0.11	0.02	0.02	0.02	13%	0.00	0.00	13%	0.01	0.01	0	0	5.74	2.10		0.02
Opt-Out/Ex	5300	5302 Monitor Power Management Enabling - LCD	Data Centers	2014	2054	0.11	0.02	0.01	0.03	19% 25%	0.00	0.00	16%	0.10	0.04	1 6	0	0.52			0.00
Opt-Out/Ex	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Data Centers	2014	2054	0.10	0.02	0.01	0.03	25%	0.00	0.00	18%	0.29	0.10	ь	1	0.17			0.00

DNV GL H-14 1/5/2015

APPENDIX H

Base Avoided Costs

		empt/Nonjurisdictional Existing SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage	OI ADDITIVE	OUT ET ANALIGIO				rear	2014		Total			Total		Marginal	Average	Marginal	Average	Total			001121
В	Base Me	easure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy	Energy	Capacity	Capacity	Resource Cost Test	Base	Base	Economic
		imber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH
Opt-Out/Ex Opt-Out/Ex	5400 5400	5400 Base Copier 5401 Energy Star or Better Copier	Data Centers Data Centers	2014 2014	2054 2054	0.11	0.02 0.02	0.00 0.01	0.00 0.01	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 29.08	0.11	0.02	0.00 0.01
Opt-Out/Ex	5400	5402 Copier Power Management Enabling	Data Centers	2014	2054	0.10	0.02	0.00	0.02	14%	0.00	0.00	12%	0.11	0.03	1	Ō	0.49			0.00
Opt-Out/Ex	5500	5500 Base Multifunction	Data Centers	2014	2054 2054	0.01	0.00	0.00	0.00	0% 25%	0.00	0.00	0%	N/A	N/A	N/A	N/A 0	N/A	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	5500 5500	5502 ENERGY STAR Multi-Function Device 5501 Multifunction Power Management Enabling	Data Centers Data Centers	2014 2014	2054	0.01 0.01	0.00	0.00	0.00 0.01	25% 38%	0.00	0.00	25% 32%	0.01 0.32	0.01 0.11	0 4	1	7.88 0.16			0.00
Opt-Out/Ex	5600	5600 Base Printer	Data Centers	2014	2054	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Data Centers Data Centers	2014 2014	2054 2054	0.03 0.02	0.00	0.02	0.02 0.02	35% 46%	0.00	0.00	35% 41%	0.00 0.07	0.00 0.02	0	0	36.22 0.76			0.02
Opt-Out/Ex	5700	5700 Base Data Center/Server Room	Data Centers Data Centers	2014	2054	992.35	172.65	0.00	0.02	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	992.35	172.65	0.00
Opt-Out/Ex	5700	5701 Data Center Improved Operations	Data Centers	2014	2054	893.12	155.39	99.24	99.24	10%	17.27	17.27	10%	0.00	0.00	0	0	129.50			99.24
Opt-Out/Ex Opt-Out/Ex	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Data Centers Data Centers	2014 2014	2054 2054	779.49 735.84	135.62 128.02	113.63 43.65	212.86 256.51	21% 26%	19.77 7.59	37.03 44.63	21% 26%	0.00	0.00	0	0	52.72 27.34			113.63 43.65
Opt-Out/Ex	6000	6000 Base Water Heating	Data Centers	2014	2054	0.47	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.47	0.08	0.00
Opt-Out/Ex	6000	6007 Heat Trap	Data Centers	2014	2054	0.45	0.08	0.02	0.02	5%	0.00	0.00	5%	0.08	0.08	0	0	0.88			0.00
Opt-Out/Ex Opt-Out/Ex	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Data Centers Data Centers	2014 2014	2054 2054	0.44 0.40	0.08 0.07	0.01 0.03	0.03 0.07	7% 14%	0.00 0.01	0.01 0.01	7% 14%	0.16 0.24	0.10 0.17	1	1	0.48 0.34			0.00
Opt-Out/Ex	6000	6008 Solar Water Heater	Data Centers	2014	2054	0.19	0.03	0.21	0.28	60%	0.04	0.05	60%	0.28	0.26	2	1	0.29			0.00
Opt-Out/Ex	6000	6003 Hot Water Pipe Insulation	Data Centers	2014	2054	0.19	0.03	0.00	0.28	60%	0.00	0.05	60%	0.62	0.26	4	1	0.12			0.00
Opt-Out/Ex Opt-Out/Ex	6000 6000	6006 Heat Recovery Unit 6001 Demand controlled circulating systems	Data Centers Data Centers	2014 2014	2054 2054	0.17 0.17	0.03	0.01 0.01	0.30 0.30	63% 64%	0.00	0.05 0.05	63% 64%	0.63 1.89	0.28 0.30	4 11	2	0.11 0.04			0.00
Opt-Out/Ex	7000	7000 Base Refrigerated Vending Machines	Data Centers	2014	2054	0.31	0.05	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.31	0.05	0.00
Opt-Out/Ex	7000	7001 Vending Misers (Refrigerated units)	Data Centers	2014	2054	0.26	0.05	0.05	0.05	16%	0.00	0.00	8%	0.01	0.01	0	0	5.94			0.05
Opt-Out/Ex Opt-Out/Ex	7000 7100	7002 Vending Misers (Refrigerated glass-front units) 7100 Base Non-Refrigerated Vending Machines	Data Centers Data Centers	2014 2014	2054 2054	0.23 0.01	0.05 0.00	0.03	0.07 0.00	24% 0%	0.00	0.01	12% 0%	0.02 N/A	0.01 N/A	0 N/A	0 N/A	3.27 N/A	0.01	0.00	0.03
Opt-Out/Ex	7100	7101 Vending Misers (Non-Refrigerated)	Data Centers	2014	2054	0.01	0.00	0.01	0.01	44%	0.00	0.00	23%	0.12	0.12	1	1	0.45			0.00
Opt-Out/Ex	7200	7200 Base Oven	Data Centers	2014	2054	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A N/A	N/A N/A	N/A N/A	N/A	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	7300 7400	7300 Base Fryer 7400 Base Steamer	Data Centers Data Centers	2014 2014	2054 2054	0.00 0.01	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00	0.00	0.00
Opt-Out/Ex	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Data Centers	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex	8100	8100 Base Heating, Other Electric	Data Centers	2014	2054	0.58	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.58	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	9500 9500	9500 Base Miscellaneous 9501 Xmisc	Data Centers Data Centers	2014 2014	2054 2054	4.70 4.70	0.82 0.82	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A 0.00	4.70	0.82	0.00
Opt-Out/Ex	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Misc	2020	2054	9.64	1.64	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	9.64	1.64	0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020	Misc Misc	2020 2020	2054 2054	9.53 8.81	1.63 1.53	0.11 0.72	0.11 0.83	1% 9%	0.01 0.10	0.01 0.11	1% 6%	0.01 0.02	0.01 0.02	0	0	4.07 3.62			0.11 0.72
Opt-Out/Ex	1030	1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020 1031 ROB 4L4' High Performance T8 (86 W), 2020	Misc	2020	2054	7.89	1.37	0.72	1.75	18%	0.10	0.11	16%	0.02	0.02	0	0	3.01			0.72
Opt-Out/Ex	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Misc	2020	2054	7.80	1.36	0.09	1.84	19%	0.02	0.28	17%	0.45	0.04	3	0	0.13			0.00
Opt-Out/Ex Opt-Out/Ex	1030 1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020 1034 ROB 4L4' LED Tube, 2020	Misc Misc	2020 2020	2054 2054	7.62 6.39	1.35 1.14	0.18 1.23	2.02 3.25	21% 34%	0.01 0.21	0.28 0.49	17% 30%	0.07 0.22	0.04 0.11	2	0	0.85 0.32			0.00
Opt-Out/Ex	1030	1034 ROB 4L4 LED 1006, 2020 1035 LED Troffer (base 4L4'T8), 2020	Misc	2020	2054	5.85	1.14	0.55	3.79	39%	0.21	0.49	36%	0.22	0.11	1	1	0.32			0.00
Opt-Out/Ex	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Misc	2020	2054	7.38	1.25	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	7.38	1.25	0.00
Opt-Out/Ex Opt-Out/Ex	1130 1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020 1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Misc Misc	2020 2020	2054 2054	7.29 6.74	1.25 1.17	0.09 0.55	0.09 0.64	1% 9%	0.01	0.01 0.08	1% 6%	0.02	0.02 0.02	0	0	3.31 2.94			0.09 0.55
Opt-Out/Ex	1130	1131 ROB 2L4' High Performance T8 (86 W), 2020	Misc	2020	2054	6.11	1.06	0.64	1.28	17%	0.07	0.19	15%	0.02	0.02	0	0	2.40			0.64
Opt-Out/Ex	1130	1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Misc	2020	2054	5.33	0.93	0.78	2.05	28%	0.13	0.32	26%	0.05	0.03	0	0	1.15			0.78
Opt-Out/Ex Opt-Out/Ex	1130 1130	1134 ROB 2L4' LED Tube, 2020 1135 LED Troffer (base 2L4'T8), 2020	Misc Misc	2020 2020	2054 2054	5.07 4.64	0.89 0.81	0.26 0.43	2.31 2.74	31% 37%	0.04 0.07	0.37 0.44	29% 35%	0.19 0.25	0.05 0.08	1	0	0.36 0.28			0.00
Opt-Out/Ex	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Misc	2020	2054	4.53	0.81	0.43	2.85	39%	0.00	0.44	35%	0.25	0.08	4	1	0.28			0.00
Opt-Out/Ex	1200	1200 Base Other Fluorescent Fixture	Misc	2014	2054	0.10	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.10	0.02	0.00
Opt-Out/Ex Opt-Out/Ex	1200 1200	1203 Lighting Control Tuneup (base other fluorescent fixture) 1201 ROB High Performance T8 (base other fluorescent)	Misc Misc	2014 2014	2054 2054	0.09	0.02	0.01	0.01 0.01	7% 14%	0.00	0.00	3% 10%	0.01	0.01	0	0	5.21 0.78			0.01
Opt-Out/Ex	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Misc	2014	2054	0.08	0.02	0.01	0.02	20%	0.00	0.00	12%	0.08	0.05	2	1	0.72			0.00
Opt-Out/Ex	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Misc	2014	2054	0.07	0.01	0.01	0.03	26%	0.00	0.00	17%	0.11	0.07	1	1	0.63			0.00
Opt-Out/Ex Opt-Out/Ex	1330 1330	1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020 1332 LEDs (base incandescent flood) 2020	Misc Misc	2020 2020	2054 2054	11.75 2.48	1.99 0.42	0.00 9.27	0.00 9.27	0% 79%	0.00 1.57	0.00 1.57	0% 79%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 13.91	11.75	1.99	0.00 9.27
Opt-Out/Ex	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Misc	2020	2054	4.23	0.72	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.23	0.72	0.00
Opt-Out/Ex	1430	1432 LEDs (base incandescent A-line 72W) 2020	Misc	2020	2054	0.97	0.16	3.26	3.26	77%	0.55	0.55	77%	0.01	0.01	0	0	11.70			3.26
Opt-Out/Ex Opt-Out/Ex	1530 1530	1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Misc Misc	2020 2020	2054 2054	3.11 0.96	0.53 0.16	0.00 2.15	0.00 2.15	0% 69%	0.00 0.37	0.00 0.37	0% 69%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 8.55	3.11	0.53	0.00 2.15
Opt-Out/Ex	1630	1630 Base CFL 18W to screw-in replacement 2020	Misc	2020	2054	1.90	0.32	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.90	0.32	0.00
Opt-Out/Ex	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Misc	2020	2054	1.38	0.23	0.53	0.53	28%	0.09	0.09	28%	0.05	0.05	0	0	1.15			0.53
Opt-Out/Ex Opt-Out/Ex	1730 1730	1730 Base CFL 23W to screw-in replacement 2020 1731 LED screw-in replacement (base CFL 23W) 2020	Misc Misc	2020 2020	2054 2054	2.43 1.80	0.41 0.31	0.00 0.63	0.00 0.63	0% 26%	0.00 0.11	0.00 0.11	0% 26%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 1.53	2.43	0.41	0.00 0.63
Opt-Out/Ex	1800	1800 BaseMetal Halide, 465W	Misc	2014	2054	4.40	0.75	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	4.40	0.75	0.00
Opt-Out/Ex	1800	1801 T5 (240W) (base metal halide)	Misc	2014	2054	2.91	0.49	1.49	1.49	34%	0.25	0.25	34%	0.01	0.01	0	0	8.49			1.49
Opt-Out/Ex Opt-Out/Ex	1800 1800	1806 Occupancy Sensor, High Bay T5 1805 High Performance Lighting R/R - 25% Savings (base metal halide)	Misc Misc	2014 2014	2054 2054	2.81 2.60	0.49 0.46	0.10 0.21	1.58 1.79	36% 41%	0.00	0.26 0.28	34% 38%	0.02 0.05	0.01 0.01	0	0	2.28 1.56			0.10 0.21
Opt-Out/Ex	1850	1850 Base CFL Exit Sign	Misc	2014	2054	0.52	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.52	0.09	0.00
Opt-Out/Ex	1850	1851 LED Exit Sign	Misc	2014	2054	0.28	0.05	0.24	0.24	46%	0.04	0.04	46%	0.03	0.03	0	0	2.16	7.04	0.57	0.24
Opt-Out/Ex Opt-Out/Ex	1900 1900	1900 Base Outdoor High Pressure Sodium 250W Lamp 1902 LED Outdoor Area Lighting	Misc Misc	2014 2014	2054 2054	7.31 3.52	0.57 0.27	0.00 3.79	0.00 3.79	0% 52%	0.00 0.29	0.00 0.29	0% 52%	N/A 0.08	N/A 0.08	N/A 1	N/A 1	N/A 0.84	7.31	0.57	0.00
Opt-Out/Ex	1900	1903 Bi-Level LED Outdoor Lighting	Misc	2014	2054	2.49	0.20	1.03	4.82	66%	0.07	0.37	65%	0.54	0.18	8	2	0.13			0.00
Opt-Out/Ex	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Misc	2014	2054	2.28	1.76	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	2.28	1.76	0.00

APPENDIX H

Base Avoided Costs

			empt/Nonjurisdictional Existing SUPPLY ANALYSIS				Year	2014														SUPPLY
	ntage	ADDITIVE	OUT ET ANALTOID				rear	2014		Total	_		Total		Marginal	Average	Marginal	Average	Total			001121
	Ba	ise Me	easure	Building	Measure Start	Measure End	Total	Total	GWH	Energy Savings	Percent GWH	MW	Capacity Savings	Percent MW	Energy Cost	Energy Cost	Capacity Cost	Capacity	Resource Cost Test	Base	Base	Economic
	,		imber Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH
	pt-Out/Ex pt-Out/Ex	2000 2000	2010 Ceiling/roof Insulation - Chiller 2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Misc Misc	2014 2014	2054 2054	2.25 2.06	1.74 1.59	0.03 0.19	0.03 0.22	1% 10%	0.02 0.15	0.02 0.17	1% 10%	0.02 0.04	0.02 0.04	0	0	6.46 3.32			0.03 0.19
	pt-Out/Ex	2000	2013 High Efficiency Chiller Motors	Misc	2014	2054	2.06	1.59	0.00	0.22	10%	0.00	0.17	10%	0.06	0.04	0	0	2.14			0.00
	pt-Out/Ex pt-Out/Ex	2000 2000	2006 VSD for Chiller Pumps and Towers 2003 EMS - Chiller	Misc Misc	2014 2014	2054 2054	1.98 1.80	1.56 1.53	0.08 0.17	0.30	13% 21%	0.03	0.20 0.24	12% 14%	0.05 0.07	0.04 0.05	0	0	1.88 1.02			0.08 0.17
	pt-Out/Ex	2000	2012 Duct Testing/Sealing	Misc	2014	2054	1.47	1.27	0.17	0.48	35%	0.03	0.49	28%	0.07	0.03	0	0	0.59			0.00
	pt-Out/Ex	2000	2002 Window Film (Standard) - Chiller	Misc	2014	2054	1.46	1.26	0.01	0.82	36%	0.01	0.50	28%	0.76	0.12	1	0	0.13			0.00
	pt-Out/Ex pt-Out/Ex	2000 2000	2004 Cool Roof - Chiller 2011 Duct/Pipe Insulation - Chiller	Misc Misc	2014 2014	2054 2054	1.46 1.44	1.26 1.25	0.00 0.02	0.82 0.84	36% 37%	0.00 0.02	0.50 0.52	29% 29%	3.29 3.97	0.13 0.22	4 5	0	0.03 0.02			0.00
	pt-Out/Ex	2000	2008 New Economizer - Chiller	Misc	2014	2054	1.44	1.25	0.02	0.84	37%	0.02	0.52	29%	36634.21	0.22	184,662	0	0.02			0.00
O	pt-Out/Ex	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Misc	2014	2054	53.61	41.46	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	53.61	41.46	0.00
	pt-Out/Ex pt-Out/Ex	2100 2100	2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	Misc Misc	2014 2014	2054 2054	53.61 41.28	41.46 31.92	0.00 12.33	0.00 12.33	0% 23%	0.00 9.53	0.00 9.54	0% 23%	0.02	0.02 0.03	0	0	6.63 3.51			0.00 12.33
	pt-Out/Ex	2100	2112 Aerosol Duct Sealing - DX	Misc	2014	2054	38.85	30.04	2.43	14.76	28%	1.88	11.41	28%	0.03	0.06	0	0	0.58			0.00
	pt-Out/Ex	2100	2106 Prog. Thermostat - DX	Misc	2014	2054	38.11	29.90	0.74	15.50	29%	0.15	11.56	28%	0.12	0.07	1	0	0.51			0.00
	pt-Out/Ex pt-Out/Ex	2100 2100	2108 Optimize Controls - DX 2115 Window Film (Standard) - DX	Misc Misc	2014 2014	2054 2054	37.47 37.33	29.77 29.66	0.63 0.15	16.13 16.28	30% 30%	0.13 0.11	11.69 11.80	28% 28%	0.13 0.59	0.07 0.07	1	0	0.44 0.17			0.00 0.00
	pt-Out/Ex	2100	2107 Cool Roof - DX	Misc	2014	2054	37.25	29.60	0.13	16.35	31%	0.06	11.86	29%	3.03	0.09	4	0	0.03			0.00
O	pt-Out/Ex	2100	2114 Duct/Pipe Insulation - DX	Misc	2014	2054	37.02	29.42	0.24	16.59	31%	0.18	12.04	29%	3.62	0.14	5	0	0.03			0.00
	pt-Out/Ex pt-Out/Ex	2200 2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF) 2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc Misc	2014 2014	2054 2054	6.61 5.79	5.11 4.48	0.00 0.82	0.00 0.82	0% 12%	0.00 0.63	0.00 0.63	0% 12%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 3.28	6.61	5.11	0.00 0.82
	pt-Out/Ex	2300	2300 Base PTAC, EER=8.3, 1 ton	Misc	2014	2054	6.61	5.11	0.02	0.02	0%	0.00	0.00	0%	N/A	0.04 N/A	N/A	N/A	3.26 N/A	6.61	5.11	0.00
O	pt-Out/Ex	2300	2301 HE PTAC, EER=9.6, 1 ton	Misc	2014	2054	5.72	4.42	0.90	0.90	14%	0.69	0.69	14%	0.08	0.08	0	0	1.43			0.90
	pt-Out/Ex pt-Out/Ex	2300 3000	2302 Occupancy Sensor (hotels) 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Misc Misc	2014 2014	2054 2054	4.86 19.47	3.56 5.53	0.86 0.00	1.76 0.00	27% 0%	0.86	1.55 0.00	30% 0%	0.26 N/A	0.17 N/A	0 N/A	0 N/A	0.43 N/A	19.47	5.53	0.00 0.00
	pt-Out/Ex	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Misc	2014	2054	19.13	5.44	0.34	0.34	2%	0.10	0.10	2%	0.06	0.06	0	0	1.40	15.47	3.33	0.34
O	pt-Out/Ex	3000	3002 Variable Speed Drive Control, 5 HP	Misc	2014	2054	13.38	5.03	5.75	6.09	31%	0.41	0.50	9%	0.05	0.05	1	1	1.33			5.75
	pt-Out/Ex pt-Out/Ex	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Misc Misc	2014 2014	2054 2054	13.12 15.52	4.89 4.41	0.26 0.00	6.35 0.00	33% 0%	0.14 0.00	0.65 0.00	12% 0%	1.56 N/A	0.11 N/A	3 N/A	1 N/A	0.07 N/A	15.52	4.41	0.00
	pt-Out/Ex	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Misc	2014	2054	13.28	3.84	2.24	2.24	14%	0.57	0.57	13%	0.03	0.03	0	0	2.68	15.52	4.41	2.24
O	pt-Out/Ex	3100	3103 Air Handler Optimization, 15 HP	Misc	2014	2054	12.37	3.77	0.91	3.15	20%	0.06	0.64	14%	0.04	0.03	1	0	1.41			0.91
	pt-Out/Ex pt-Out/Ex	3100 3100	3102 Variable Speed Drive Control, 15 HP 3101 Fan Motor, 15hp, 1800rpm, 92.4%	Misc Misc	2014 2014	2054 2054	8.65 8.52	3.51 3.47	3.72 0.13	6.87 7.00	44% 45%	0.26 0.04	0.90 0.94	20% 21%	0.07 0.21	0.05 0.05	1	0	0.98 0.43			0.00
	pt-Out/Ex	3100	3101 Fan Motor, 15np, 18001pm, 92.4% 3105 Energy Recovery Ventilation (ERV)	Misc	2014	2054	8.41	3.41	0.13	7.00	46%	0.04	1.00	23%	0.43	0.05	1	0	0.43			0.00
O	pt-Out/Ex	3100	3107 Demand Controlled Ventilation	Misc	2014	2054	8.25	3.32	0.16	7.27	47%	0.09	1.09	25%	1.97	0.10	4	1	0.05			0.00
	pt-Out/Ex	3200 3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Misc Misc	2014 2014	2054 2054	12.31 11.47	3.50 3.44	0.00	0.00 0.84	0% 7%	0.00	0.00	0%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.65	12.31	3.50	0.00
	pt-Out/Ex pt-Out/Ex	3200	3203 Air Handler Optimization, 40 HP 3202 Variable Speed Drive Control, 40 HP	Misc	2014	2054	8.02	3.44	3.45	4.29	35%	0.06	0.06	2% 9%	0.03	0.03	1	1	0.63			0.84
O	pt-Out/Ex	3200	3201 Fan Motor, 40hp, 1800rpm, 94.1%	Misc	2014	2054	7.99	3.19	0.03	4.33	35%	0.01	0.31	9%	0.51	0.09	2	1	0.17			0.00
	pt-Out/Ex	3200 4000	3204 Demand Controlled Ventilation	Misc Misc	2014 2014	2054 2054	7.83 0.00	3.10 0.00	0.16 0.00	4.48 0.00	36% 0%	0.09	0.40 0.00	11% 0%	1.65 N/A	0.15 N/A	3 N/A	2 N/A	0.06 N/A	0.00	0.00	0.00
	pt-Out/Ex pt-Out/Ex	4100	4000 Base Built-Up Refrigeration System 4100 Base Self-Contained Refrigeration	Misc	2014	2054	13.77	2.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	13.77	2.07	0.00
O	pt-Out/Ex	4100	4103 Night covers for display cases (self-contained)	Misc	2014	2054	12.53	1.89	1.24	1.24	9%	0.19	0.19	9%	0.00	0.00	0	0	39.56			1.24
	pt-Out/Ex pt-Out/Ex	4100 4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Misc Misc	2014 2014	2054 2054	12.35 12.19	1.86 1.83	0.18 0.17	1.42 1.58	10% 11%	0.03 0.02	0.21 0.24	10% 11%	0.00 0.01	0.00	0	0	34.58 11.71			0.18 0.17
	pt-Out/Ex	4100	4108 Energy-Star Refrigerator, glass door 4106 Energy-Star Refrigerator, solid door	Misc	2014	2054	11.76	1.63	0.17	2.01	15%	0.02	0.24	15%	0.01	0.00	0	0	11.40			0.17
O	pt-Out/Ex	4100	4110 Energy Star Ice Machines	Misc	2014	2054	11.72	1.76	0.05	2.05	15%	0.01	0.31	15%	0.02	0.00	ō	Ō	4.07			0.05
	pt-Out/Ex	4100	4112 Reach-in unit occupancy sensors	Misc	2014	2054	11.72	1.76	0.00	2.05	15%	0.00	0.31	15%	0.31	0.00	2	0	0.21			0.00
	pt-Out/Ex pt-Out/Ex	4100 5000	4105 Bi-level LED Case Lighting (self-contained units) 2014 5000 Base Desktop PC	Misc Misc	2014 2014	2054 2054	11.71 0.48	1.76 0.07	0.01	2.07	15% 0%	0.00	0.31	15% 0%	0.35 N/A	0.00 N/A	2 N/A	0 N/A	0.17 N/A	0.48	0.07	0.00
0	pt-Out/Ex	5000	5001 PC Network Power Management Enabling	Misc	2014	2054	0.26	0.06	0.21	0.21	45%	0.02	0.02	23%	0.01	0.01	0	0	4.18			0.21
	pt-Out/Ex pt-Out/Ex	5000 5100	5002 Energy Star or Better PC 5100 Base Laptop PC	Misc Misc	2014 2014	2054 2054	0.18 0.01	0.04	0.08	0.30	62% 0%	0.01 0.00	0.03	40% 0%	0.03 N/A	0.02 N/A	0 N/A	0 N/A	2.12 N/A	0.01	0.00	0.08
	pt-Out/Ex pt-Out/Ex	5100	5100 base Laptop PC 5102 Energy Star or Better Laptop	Misc	2014	2054	0.01	0.00	0.00	0.00	19%	0.00	0.00	19%	0.01	0.01	0	0	5.80	0.01	0.00	0.00
O	pt-Out/Ex	5100	5101 Laptop Network Power Management Enabling	Misc	2014	2054	0.01	0.00	0.00	0.00	21%	0.00	0.00	21%	1.13	0.10	7	1	0.05			0.00
	pt-Out/Ex	5200 5200	5200 Base Monitor, CRT	Misc Misc	2014 2014	2054 2054	0.04	0.01 0.00	0.00	0.00 0.02	0% 56%	0.00	0.00	0% 56%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 46.17	0.04	0.01	0.00 0.02
	pt-Out/Ex pt-Out/Ex	5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Misc	2014	2054	0.02	0.00	0.02	0.02	67%	0.00	0.00	62%	0.00	0.00	0	0	3.02			0.02
O	pt-Out/Ex	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Misc	2014	2054	0.01	0.00	0.00	0.03	70%	0.00	0.00	64%	0.19	0.01	1	Ō	0.28			0.00
	pt-Out/Ex	5300	5300 Base Monitor, LCD	Misc	2014	2054	0.06	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.06	0.01	0.00
	pt-Out/Ex pt-Out/Ex	5300 5300	5301 Energy Star or Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Misc Misc	2014 2014	2054 2054	0.05 0.05	0.01 0.01	0.01 0.00	0.01 0.01	18% 21%	0.00	0.00	18% 19%	0.01 0.07	0.01 0.02	0 1	0	6.77 0.68			0.01 0.00
O	pt-Out/Ex	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Misc	2014	2054	0.05	0.01	0.00	0.02	27%	0.00	0.00	21%	0.21	0.06	5	1	0.22			0.00
	pt-Out/Ex	5400	5400 Base Copier	Misc Misc	2014 2014	2054	0.11 0.10	0.02	0.00	0.00	0% 13%	0.00	0.00	0%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A	0.11	0.02	0.00
	pt-Out/Ex pt-Out/Ex	5400 5400	5401 Energy Star or Better Copier 5402 Copier Power Management Enabling	Misc	2014 2014	2054 2054	0.10	0.01 0.01	0.01 0.00	0.01 0.02	13% 18%	0.00	0.00	13% 16%	0.00	0.00	1	0	35.00 0.61			0.01
O	pt-Out/Ex	5500	5500 Base Multifunction	Misc	2014	2054	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00
	pt-Out/Ex	5500	5502 ENERGY STAR Multi-Function Device	Misc	2014	2054	0.01	0.00	0.00	0.00	25%	0.00	0.00	25%	0.01	0.01	0	0	9.86			0.00
	pt-Out/Ex pt-Out/Ex	5500 5600	5501 Multifunction Power Management Enabling 5600 Base Printer	Misc Misc	2014 2014	2054 2054	0.01 0.04	0.00 0.01	0.00	0.01	37% 0%	0.00	0.00	31% 0%	0.23 N/A	0.08 N/A	3 N/A	1 N/A	0.22 N/A	0.04	0.01	0.00
0	pt-Out/Ex	5600	5602 ENERGY STAR Printer	Misc	2014	2054	0.03	0.00	0.02	0.02	35%	0.00	0.00	35%	0.00	0.00	0	0	45.31	0.01	0.01	0.02
	pt-Out/Ex	5600	5601 Printer Power Management Enabling	Misc	2014	2054	0.02	0.00	0.00	0.02	45%	0.00	0.00	40%	0.05	0.01	1	0	1.02			0.00
	pt-Out/Ex pt-Out/Ex	5700 5700	5700 Base Data Center/Server Room 5701 Data Center Improved Operations	Misc Misc	2014 2014	2054 2054	5.32 4.79	0.81 0.73	0.00	0.00 0.53	0% 10%	0.00	0.00	0% 10%	N/A 0.00	N/A 0.00	N/A	N/A 0	N/A 117.62	5.32	0.81	0.00
9	Ouv L	0.00	Conton improvou Operationa	.71130	-017	-007		0.70	0.00	0.00	. 5 /0	0.00	0.00	.070	0.00	0.00	J	9	02			0.00

APPENDIX H

Base Avoided Costs

	ST ADDITIV	VE SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource			
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt I	Number 5700	Number Measure 5702 Data Center Best Practices	Type Misc	Year 2014	Year 2054	4.18	0.63	Savings 0.61	1.14	Savings 21%	Savings 0.09	0.17	Savings 21%	\$/kWH 0.00	\$/kWH 0.00	\$/kW	\$/kW	47.88	GWH	MW	0.61
Opt-Out/Ex	5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Misc	2014	2054	3.95	0.60	0.01	1.14	26%	0.09	0.17	26%	0.00	0.00	0	0	24.83			0.23
Opt-Out/Ex	6000	6000 Base Water Heating	Misc	2014	2054	0.77	0.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.77	0.11	0.00
Opt-Out/Ex	6000	6007 Heat Trap	Misc	2014	2054	0.73	0.11	0.04	0.04	5%	0.01	0.01	5%	0.01	0.01	0	0	4.47			0.04
Opt-Out/Ex Opt-Out/Ex	6000 6000	6002 High Efficiency Water Heater (electric) 6004 Tankless Water Heater	Misc Misc	2014 2014	2054 2054	0.72 0.66	0.11 0.10	0.01 0.05	0.05 0.11	7% 14%	0.00 0.01	0.01 0.02	7% 14%	0.03	0.02	0	0	2.40 1.71			0.01 0.05
Opt-Out/Ex	6000	6003 Hot Water Pipe Insulation	Misc	2014	2054	0.65	0.10	0.01	0.12	16%	0.00	0.02	16%	0.05	0.03	0	0	1.33			0.01
Opt-Out/Ex	6000	6006 Heat Recovery Unit	Misc	2014	2054	0.63	0.09	0.02	0.14	18%	0.00	0.02	18%	0.05	0.04	0	0	1.24			0.02
Opt-Out/Ex	6000	6001 Demand controlled circulating systems	Misc	2014	2054	0.60	0.09	0.02	0.17	22%	0.00	0.02	22%	0.15	0.05	1	0	0.48	0.40	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	7000 7000	7000 Base Refrigerated Vending Machines 7001 Vending Misers (Refrigerated units)	Misc Misc	2014 2014	2054 2054	0.12 0.10	0.02 0.02	0.00 0.02	0.00 0.02	0% 16%	0.00	0.00	0% 8%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 1.99	0.12	0.02	0.00 0.02
Opt-Out/Ex	7000	7002 Vending Misers (Refrigerated glass-front units)	Misc	2014	2054	0.09	0.02	0.01	0.03	25%	0.00	0.00	12%	0.05	0.03	1	ō	1.09			0.01
Opt-Out/Ex	7100	7100 Base Non-Refrigerated Vending Machines	Misc	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	7100 7200	7101 Vending Misers (Non-Refrigerated) 7200 Base Oven	Misc Misc	2014 2014	2054 2054	0.00 0.56	0.00	0.00	0.00	46% 0%	0.00	0.00	23% 0%	0.44 N/A	0.44 N/A	5 N/A	5 N/A	0.12 N/A	0.56	0.09	0.00
Opt-Out/Ex	7300	7300 Base Erver	Misc	2014	2054	1.16	0.09	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.16	0.09	0.00
Opt-Out/Ex	7300	7301 Efficient Fryer	Misc	2014	2054	1.08	0.18	0.07	0.07	6%	0.01	0.01	6%	1.65	1.65	10	10	0.04			0.00
Opt-Out/Ex	7400	7400 Base Steamer	Misc	2014	2054	0.07	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.07	0.01	0.00
Opt-Out/Ex Opt-Out/Ex	8000 8100	8000 Base Heating, Heat Pump (7.7 HSPF) 8100 Base Heating, Other Electric	Misc Misc	2014 2014	2054 2054	0.00 5.50	0.00	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	0.00 5.50	0.00	0.00
Opt-Out/Ex	9500	9500 Base Miscellaneous	Misc	2014	2054	44.56	7.41	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	44.56	7.41	0.00
Opt-Out/Ex	9500	9501 Xmisc	Misc	2014	2054	44.56	7.41	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00
VA	1030	1030 Base Fluorescent Fixture, 4L4'T8, 1EB, 2020	Non-Jurisdictional	2020	2054	1,337.88	237.97	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1,337.88	237.97	0.00
VA VA	1030 1030	1036 Lighting Control Tuneup (base 4L4'T8), 2020 1038 High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	1,323.24 1,223.50	236.69 222.57	14.64 99.75	14.64 114.38	1% 9%	1.29 14.12	1.29 15.41	1% 6%	0.01 0.02	0.01 0.02	0	0	4.40 3.95			14.64 99.75
VA	1030	1031 ROB 4L4' High Performance T8 (86 W), 2020	Non-Jurisdictional	2020	2054	1,097.81	200.21	125.69	240.07	18%	22.36	37.77	16%	0.02	0.02	0	0	2.95			125.69
VA	1030	1032 ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Non-Jurisdictional	2020	2054	958.13	175.36	139.68	379.75	28%	24.84	62.61	26%	0.04	0.03	Ō	Ō	1.41			139.68
VA	1030	1037 Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Non-Jurisdictional	2020	2054	915.80	173.51	42.33	422.08	32%	1.85	64.46	27%	0.07	0.03	2	0	0.79			0.00
VA VA	1030 1030	1034 ROB 4L4' LED Tube, 2020 1035 LED Troffer (base 4L4'T8), 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	768.24 702.66	147.27 135.60	147.56 65.58	569.64 635.22	43% 47%	26.25 11.67	90.71 102.37	38% 43%	0.27	0.09	2	1	0.27			0.00
VA	1130	1130 Base Fluorescent Fixture, 2L4'T8, 1EB, 2020	Non-Jurisdictional	2020	2054	266.78	47.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.33 N/A	266.78	47.45	0.00
VA	1130	1136 Lighting Control Tuneup (base 2L4'T8), 2020	Non-Jurisdictional	2020	2054	263.81	47.19	2.97	2.97	1%	0.26	0.26	1%	0.02	0.02	0	0	3.08			2.97
VA	1130	1138 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Non-Jurisdictional	2020	2054	243.92	44.38	19.89	22.85	9%	2.82	3.08	6%	0.03	0.02	0	0	2.77			19.89
VA VA	1130 1130	1131 ROB 2L4' High Performance T8 (86 W), 2020 1132 ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	219.71 191.76	40.07 35.10	24.21 27.95	47.07 75.02	18% 28%	4.31 4.97	7.38 12.36	16% 26%	0.03 0.06	0.03 0.04	0	0	2.34 1.12			24.21 27.95
VA	1130	1134 ROB 2L4 LED Tube, 2020	Non-Jurisdictional	2020	2054	182.49	33.45	9.27	84.29	32%	1.65	14.00	30%	0.00	0.04	1	0	0.35			0.00
VA	1130	1137 Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Non-Jurisdictional	2020	2054	174.42	33.10	8.06	92.35	35%	0.35	14.36	30%	0.13	0.06	3	0	0.43			0.00
VA	1130	1135 LED Troffer (base 2L4'T8), 2020	Non-Jurisdictional	2020	2054	159.53	30.45	14.89	107.24	40%	2.65	17.00	36%	0.28	0.09	2	1	0.27			0.00
VA VA	1200 1200	1200 Base Other Fluorescent Fixture 1203 Lighting Control Tuneup (base other fluorescent fixture)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	25.29 23.60	4.50 4.35	0.00 1.69	0.00 1.69	0% 7%	0.00 0.15	0.00 0.15	0% 3%	N/A 0.01	N/A 0.01	N/A 0	N/A 0	N/A 7.12	25.29	4.50	0.00 1.69
VA	1200	1205 High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Non-Jurisdictional	2014	2054	21.82	4.10	1.78	3.47	14%	0.15	0.13	9%	0.07	0.04	1	0	1.01			1.78
VA	1200	1201 ROB High Performance T8 (base other fluorescent)	Non-Jurisdictional	2014	2054	19.86	3.75	1.97	5.43	21%	0.35	0.75	17%	0.09	0.06	1	0	0.70			0.00
VA	1200	1204 Occupancy Sensor, 4L8' Fluorescent Fixtures	Non-Jurisdictional	2014	2054	17.91	3.66	1.95	7.38	29%	0.09	0.84	19%	0.10	0.07	2	1	0.55			0.00
VA VA	1200 1330	1202 ROB Low Watt High Performance T8 (base other fluorescent) 1330 Base Incandescent Flood, 100W to Screw-in Replacement 2020	Non-Jurisdictional Non-Jurisdictional	2014 2020	2054 2054	15.63 235.95	3.26 41.97	2.28 0.00	9.66 0.00	38% 0%	0.41 0.00	1.24 0.00	28% 0%	0.21 N/A	0.10 N/A	1 N/A	1 N/A	0.30 N/A	235.95	41.97	0.00
VA	1330	1332 LEDs (base incandescent flood) 2020	Non-Jurisdictional	2020	2054	58.86	10.47	177.09	177.09	75%	31.50	31.50	75%	0.00	0.00	0	0	16.04	200.00	11.01	177.09
VA	1430	1430 Base Incandescent A-Line Lamp, 72W to Screw-in Replacement 2020	Non-Jurisdictional	2020	2054	84.94	15.11	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	84.94	15.11	0.00
VA VA	1430 1530	1432 LEDs (base incandescent A-line 72W) 2020 1530 Base Incandescent A-Line Lamp, 53W to Screw-in Replacement 2020	Non-Jurisdictional Non-Jurisdictional	2020 2020	2054 2054	22.87 62.53	4.07 11.12	62.08 0.00	62.08 0.00	73% 0%	11.04 0.00	11.04 0.00	73% 0%	0.00 N/A	0.00 N/A	0 N/A	0 N/A	13.43 N/A	62.53	44.40	62.08 0.00
VA VA	1530	1530 Base incandescent A-Line Lamp, 53W to Screw-in Replacement 2020 1532 LEDs (base incandescent A-line 53W) 2020	Non-Jurisdictional	2020	2054	22.33	3.97	40.20	40.20	64%	7.15	7.15	64%	0.01	0.01	N/A 0	N/A 0	9.63	62.53	11.12	40.20
VA	1630	1630 Base CFL 18W to screw-in replacement 2020	Non-Jurisdictional	2020	2054	78.05	13.88	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	78.05	13.88	0.00
VA	1630	1631 LED screw-in replacement (base CFL 18W) 2020	Non-Jurisdictional	2020	2054	56.43	10.04	21.62	21.62	28%	3.85	3.85	28%	0.05	0.05	0	0	1.12			21.62
VA	1730	1730 Base CFL 23W to screw-in replacement 2020	Non-Jurisdictional	2020 2020	2054	99.73 73.80	17.74 13.13	0.00	0.00 25.93	0%	0.00	0.00	0%	N/A 0.04	N/A	N/A 0	N/A 0	N/A	99.73	17.74	0.00
VA VA	1730 1800	1731 LED screw-in replacement (base CFL 23W) 2020 1800 BaseMetal Halide, 465W	Non-Jurisdictional Non-Jurisdictional	2020	2054 2054	179.43	31.92	25.93 0.00	0.00	26% 0%	4.61 0.00	4.61 0.00	26% 0%	0.04 N/A	0.04 N/A	N/A	N/A	1.49 N/A	179.43	31.92	25.93 0.00
VA	1800	1801 T5 (240W) (base metal halide)	Non-Jurisdictional	2014	2054	118.76	21.12	60.66	60.66	34%	10.79	10.79	34%	0.01	0.01	0	0	7.29			60.66
VA	1800	1806 Occupancy Sensor, High Bay T5	Non-Jurisdictional	2014	2054	114.95	20.96	3.81	64.47	36%	0.17	10.96	34%	0.03	0.01	1	0	1.91			3.81
VA VA	1800 1850	1805 High Performance Lighting R/R - 25% Savings (base metal halide) 1850 Base CFL Exit Sign	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	106.29 14.79	19.73 2.63	8.67 0.00	73.14 0.00	41% 0%	1.23 0.00	12.18 0.00	38% 0%	0.04 N/A	0.02 N/A	0 N/A	0 N/A	1.87 N/A	14.79	2.63	8.67 0.00
VA	1850	1851 LED Exit Sign	Non-Jurisdictional	2014	2054	8.14	1.45	6.66	6.66	45%	1.18	1.18	45%	0.03	0.03	0	0	2.22	14.75	2.03	6.66
VA	1900	1900 Base Outdoor High Pressure Sodium 250W Lamp	Non-Jurisdictional	2014	2054	214.61	8.98	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	214.61	8.98	0.00
VA	1900	1901 Outdoor Lighting Controls (Photocell/Timeclock)	Non-Jurisdictional	2014	2054	199.35	7.01	15.26	15.26	7%	1.97	1.97	22%	0.04	0.04	0	0	2.02			15.26
VA VA	1900 1900	1902 LED Outdoor Area Lighting 1903 Bi-Level LED Outdoor Lighting	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	95.93 67.81	2.69 1.62	103.42 28.12	118.69 146.80	55% 68%	4.33 1.06	6.30 7.36	70% 82%	0.09 0.58	0.08	2 15	2	0.75			0.00
VA VA	2000	2000 Base Centrifugal Chiller, 0.58 kW/ton, 500 tons	Non-Jurisdictional	2014	2054	639.79	471.58	0.00	0.00	0%	0.00	0.00	82% 0%	0.58 N/A	0.18 N/A	N/A	N/A	0.11 N/A	639.79	471.58	0.00
VA	2000	2010 Ceiling/roof Insulation - Chiller	Non-Jurisdictional	2014	2054	634.60	467.75	5.20	5.20	1%	3.83	3.83	1%	0.01	0.01	0	0	11.39			5.20
VA	2000	2001 Centrifugal Chiller, 0.51 kW/ton, 500 tons	Non-Jurisdictional	2014	2054	580.42	427.82	54.17	59.37	9%	39.93	43.76	9%	0.05	0.05	0	0	2.59			54.17
VA VA	2000 2000	2005 Chiller Tune Up/Diagnostics 2013 High Efficiency Chiller Motors	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	577.09 575.85	426.58 425.67	3.33 1.24	62.70 63.94	10% 10%	1.24 0.91	45.00 45.91	10% 10%	0.04	0.04 0.05	0	0	2.06 1.67			3.33 1.24
VA VA	2000	2013 Fight Efficiency Chiller Motors 2006 VSD for Chiller Pumps and Towers	Non-Jurisdictional	2014	2054	564.16	425.67	11.68	75.63	10%	4.35	50.26	10%	0.08	0.05	0	0	1.50			1.24
VA	2000	2003 EMS - Chiller	Non-Jurisdictional	2014	2054	542.51	417.28	21.66	97.28	15%	4.04	54.30	12%	0.08	0.06	0	0	0.87			0.00
VA	2000	2012 Duct Testing/Sealing - Chiller	Non-Jurisdictional	2014	2054	441.10	342.53	101.41	198.69	31%	74.75	129.05	27%	0.25	0.15	0	0	0.49			0.00
VA	2000	2002 Window Film (Standard) - Chiller	Non-Jurisdictional	2014	2054	433.63 398.83	337.03	7.47	206.16 240.97	32% 38%	5.50 6.50	134.55	29% 30%	0.35	0.16 0.18	0	0	0.28			0.00
VA	2000	2008 New Economizer - Chiller	Non-Jurisdictional	2014	2054	398.83	330.53	34.81	240.97	38%	0.50	141.04	30%	0.30	0.18	2	U	0.22			0.00

DNV GL H-17 1/5/2015

APPENDIX H

Base Avoided Costs

		VE SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintag	е			Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy		Average Capacity	Total Resource			
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt VA	Number 2000	Number Measure 2004 Cool Roof - Chiller	Type Non-Jurisdictional	2014	Year 2054	397.35	MW 329.45	Savings 1.47	242.44	Savings 38%	Savings 1.08	MW 142.13	Savings 30%	\$/kWH 0.67	\$/kWH 0.18	\$/kW	\$/kW	0.14	GWH	MW	GWH 0.00
VA	2000	2011 Duct/Pipe Insulation - Chiller	Non-Jurisdictional	2014	2054	394.07	327.03	3.28	245.72	38%	2.42	144.55	31%	3.41	0.23	5	0	0.03			0.00
VA	2100	2100 Base DX Packaged System, EER=10.3, 10 tons	Non-Jurisdictional	2014	2054	788.26	581.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	788.26	581.01	0.00
VA VA	2100 2100	2113 Ceiling/roof Insulation - DX 2102 DX Packaged System, EER=13.4, 10 tons	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	788.25 606.95	581.01 447.37	0.01 181.30	0.01 181.30	0% 23%	0.00 133.63	0.00 133.64	0% 23%	0.01	0.01	0	0	11.66 2.73			0.01 181.30
VA	2100	2108 Optimize Controls - DX	Non-Jurisdictional	2014	2054	596.73	445.47	10.23	191.53	24%	1.91	135.54	23%	0.10	0.04	1	0	0.57			0.00
VA	2100	2105 DX Tune Up/ Advanced Diagnostics	Non-Jurisdictional	2014	2054	594.65	444.69	2.08	193.61	25%	0.77	136.32	23%	0.14	0.05	0	0	0.52			0.00
VA VA	2100 2100	2111 Economizer Repair - DX 2112 Duct Testing/Sealing - DX	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	586.00 550.95	435.43 409.59	8.64 35.05	202.25 237.31	26% 30%	9.27 25.84	145.58 171.42	25% 30%	0.20 0.28	0.05 0.09	0	0	0.46 0.43			0.00
VA VA	2100	2112 Duct Testing/Sealing - DX 2106 Prog. Thermostat - DX	Non-Jurisdictional	2014	2054	532.42	409.59	18.53	255.84	30%	25.84 3.46	171.42	30%	0.28	0.09	1	0	0.43			0.00
VA	2100	2115 Window Film (Standard) - DX	Non-Jurisdictional	2014	2054	524.69	400.43	7.73	263.57	33%	5.70	180.58	31%	0.35	0.10	o o	0	0.28			0.00
VA	2100	2109 Economizer - DX	Non-Jurisdictional	2014	2054	501.30	396.07	23.38	286.95	36%	4.36	184.94	32%	0.29	0.11	2	0	0.22			0.00
VA VA	2100 2100	2107 Cool Roof - DX 2110 Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	498.63 498.59	394.10 394.09	2.68	289.63 289.67	37% 37%	1.97 0.01	186.91 186.92	32% 32%	0.66 0.66	0.12	1 4	0	0.15			0.00
VA	2100	2114 Duct/Pipe Insulation - DX	Non-Jurisdictional	2014	2054	495.38	391.73	3.20	292.87	37%	2.36	189.28	33%	3.34	0.12	5	0	0.10			0.00
VA	2200	2200 Base Heat Pump (13 SEER, 7.7 HSPF)	Non-Jurisdictional	2014	2054	342.49	252.44	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	342.49	252.44	0.00
VA	2200	2201 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Non-Jurisdictional	2014	2054	300.13	221.22	42.36	42.36	12%	31.22	31.22	12%	0.03	0.03	0	0	3.83	500.00	204.44	42.36
VA VA	2300 3000	2300 Base PTAC, EER=8.3, 1 ton 3000 Base Fan Motor, 5hp, 1800rpm, 87.5%	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	530.62 488.60	391.11 143.21	0.00	0.00	0% 0%	0.00	0.00	0% 0%	N/A N/A	N/A N/A	N/A N/A	N/A N/A	N/A N/A	530.62 488.60	391.11 143.21	0.00
VA	3000	3002 Variable Speed Drive Control, 5 HP	Non-Jurisdictional	2014	2054	390.32	136.02	98.28	98.28	20%	7.19	7.19	5%	0.02	0.02	0	0	2.66	100.00		98.28
VA	3000	3001 Fan Motor, 5hp, 1800rpm, 89.5%	Non-Jurisdictional	2014	2054	383.78	134.10	6.54	104.82	21%	1.92	9.11	6%	0.05	0.03	0	0	1.99			6.54
VA VA	3000 3100	3003 Demand Controlled Ventilation 3100 Base Fan Motor, 15hp, 1800rpm, 91.0%	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	368.87 254.70	125.76 74.65	14.91 0.00	119.73 0.00	25% 0%	8.35 0.00	17.45 0.00	12% 0%	1.11 N/A	0.16 N/A	2 N/A	1 N/A	0.09 N/A	254.70	74.65	0.00
VA	3100	3102 Variable Speed Drive Control, 15 HP	Non-Jurisdictional	2014	2054	203.47	70.91	51.23	51.23	20%	3.75	3.75	5%	0.01	0.01	0	0	9.62	234.70	74.00	51.23
VA	3100	3101 Fan Motor, 15hp, 1800rpm, 92.4%	Non-Jurisdictional	2014	2054	201.36	70.29	2.11	53.34	21%	0.62	4.37	6%	0.02	0.01	ō	0	4.36			2.11
VA	3100	3104 Electronically Commutated Motors (ECM) on an Air Handler Unit	Non-Jurisdictional	2014	2054	179.83	64.62	21.53	74.87	29%	5.67	10.04	13%	0.04	0.02	0	0	1.85			21.53
VA VA	3100 3100	3103 Air Handler Optimization, 15 HP 3105 Energy Recovery Ventilation (ERV)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	165.03 161.67	63.53 61.65	14.80 3.37	89.67 93.03	35% 37%	1.08 1.88	11.12 13.01	15% 17%	0.04 0.45	0.02 0.04	1	0	1.44 0.26			14.80 0.00
VA	3100	3107 Demand Controlled Ventilation	Non-Jurisdictional	2014	2054	155.39	58.13	6.28	99.32	39%	3.52	16.52	22%	1.37	0.12	2	1	0.08			0.00
VA	3200	3200 Base Fan Motor, 40hp, 1800rpm, 93.0%	Non-Jurisdictional	2014	2054	196.01	57.45	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	196.01	57.45	0.00
VA VA	3200	3203 Air Handler Optimization, 40 HP	Non-Jurisdictional	2014	2054 2054	179.88 143.70	56.27	16.13 36.18	16.13 52.31	8% 27%	1.18	1.18	2%	0.03	0.03	0	0	2.04			16.13
VA VA	3200 3200	3202 Variable Speed Drive Control, 40 HP 3201 Fan Motor, 40hp, 1800rpm, 94.1%	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054	143.70	53.62 53.45	0.60	52.31	27%	2.65 0.18	3.83 4.00	7% 7%	0.04	0.03	1	0	1.75 0.50			36.18 0.00
VA	3200	3204 Demand Controlled Ventilation	Non-Jurisdictional	2014	2054	137.54	50.34	5.56	58.47	30%	3.11	7.12	12%	1.20	0.15	2	1	0.09			0.00
VA	4000	4000 Base Built-Up Refrigeration System	Non-Jurisdictional	2014	2054	0.00	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.00	0.00	0.00
VA VA	4100 4100	4100 Base Self-Contained Refrigeration 4103 Night covers for display cases (self-contained)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	395.15 385.17	57.43 55.98	0.00 9.98	0.00 9.98	0% 3%	0.00 1.45	0.00 1.45	0% 3%	N/A 0.00	N/A 0.00	N/A 0	N/A 0	N/A 72.87	395.15	57.43	0.00 9.98
VA	4100	4104 Freezer-Cooler Replacement Gaskets (self-contained)	Non-Jurisdictional	2014	2054	378.91	55.07	6.26	16.24	4%	0.91	2.36	4%	0.00	0.00	0	0	29.76			6.26
VA	4100	4109 Energy-Star Freezer, glass door	Non-Jurisdictional	2014	2054	377.75	54.90	1.16	17.40	4%	0.17	2.53	4%	0.00	0.00	0	0	17.92			1.16
VA VA	4100 4100	4106 Energy-Star Refrigerator, solid door 4108 Energy-Star Refrigerator, glass door	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	372.61 367.40	54.16 53.40	5.13 5.22	22.53 27.75	6% 7%	0.75 0.76	3.28 4.03	6% 7%	0.00 0.01	0.00	0	0	16.91 8.02			5.13 5.22
VA VA	4100	4108 Energy-Star Reingerator, glass door 4107 Energy-Star Freezer, solid door	Non-Jurisdictional	2014	2054	366.92	53.40	0.47	28.23	7% 7%	0.76	4.03	7% 7%	0.01	0.00	0	0	7.11			0.47
VA	4100	4110 Energy Star Ice Machines	Non-Jurisdictional	2014	2054	361.12	52.49	5.80	34.02	9%	0.84	4.94	9%	0.01	0.00	0	0	6.09			5.80
VA	4100	4112 Reach-in unit occupancy sensors	Non-Jurisdictional	2014	2054	361.05	52.48	0.07	34.09	9%	0.01	4.96	9%	0.32	0.01	2	0	0.20			0.00
VA VA	4100 4100	4105 Bi-level LED Case Lighting (self-contained units) 2014 4101 Strip curtains for walk-ins (self-contained)	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	360.88 360.66	52.45 52.42	0.17 0.22	34.26 34.48	9% 9%	0.02	4.98 5.01	9% 9%	0.37 14.92	0.01	3 103	0	0.16 0.00			0.00
VA	5000	5000 Base Desktop PC	Non-Jurisdictional	2014	2054	68.50	9.95	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	68.50	9.95	0.00
VA	5000	5001 PC Network Power Management Enabling	Non-Jurisdictional	2014	2054	37.28	7.66	31.22	31.22	46%	2.29	2.29	23%	0.01	0.01	0	0	4.20			31.22
VA VA	5000 5100	5002 Energy Star or Better PC	Non-Jurisdictional	2014 2014	2054 2054	27.36 6.06	6.22 0.88	9.92 0.00	41.14 0.00	60% 0%	1.44 0.00	3.73 0.00	37% 0%	0.03 N/A	0.02 N/A	0 N/A	0 N/A	2.10 N/A	6.06	0.88	9.92 0.00
VA	5100	5100 Base Laptop PC 5102 Energy Star or Better Laptop	Non-Jurisdictional Non-Jurisdictional	2014	2054	4.91	0.88	1.15	1.15	19%	0.00	0.00	19%	0.01	0.01	0	0	5.75	6.06	0.00	1.15
VA	5100	5101 Laptop Network Power Management Enabling	Non-Jurisdictional	2014	2054	4.81	0.70	0.10	1.25	21%	0.01	0.18	21%	1.13	0.10	8	1	0.05			0.00
VA	5200	5200 Base Monitor, CRT	Non-Jurisdictional	2014	2054	14.74	2.14	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.74	2.14	0.00
VA VA	5200 5200	5201 Energy Star or Better Monitor - CRT 5202 Monitor Power Management Enabling - CRT	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	7.34 5.86	1.07 0.96	7.40 1.47	7.40 8.88	50% 60%	1.08 0.11	1.08 1.18	50% 55%	0.00 0.01	0.00	0	0	51.88 3.83			7.40 1.47
VA	5200	5203 Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Non-Jurisdictional	2014	2054	5.40	0.89	0.46	9.34	63%	0.07	1.25	58%	0.16	0.01	1	0	0.34			0.00
VA	5300	5300 Base Monitor, LCD	Non-Jurisdictional	2014	2054	15.83	2.30	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.83	2.30	0.00
VA VA	5300 5300	5301 Energy Star or Better Monitor - LCD 5302 Monitor Power Management Enabling - LCD	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	13.36 12.63	1.94 1.89	2.47 0.73	2.47 3.20	16% 20%	0.36 0.05	0.36 0.41	16% 18%	0.01 0.07	0.01 0.02	0	0	6.90 0.68			2.47
VA	5300	5303 Plug-load controls - Commercial Smart Strip (base monitor LCD)	Non-Jurisdictional	2014	2054	11.65	1.85	0.73	4.18	26%	0.03	0.45	19%	0.07	0.02	6	1	0.03			0.00
VA	5400	5400 Base Copier	Non-Jurisdictional	2014	2054	19.09	2.77	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	19.09	2.77	0.00
VA	5400	5401 Energy Star or Better Copier	Non-Jurisdictional	2014	2054	16.86	2.45	2.23	2.23	12%	0.32	0.32	12%	0.00	0.00	0	0	35.39			2.23
VA VA	5400 5500	5402 Copier Power Management Enabling 5500 Base Multifunction	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	16.08 2.74	2.39	0.78	3.01	16% 0%	0.06	0.38	14% 0%	0.08 N/A	0.02 N/A	1 N/A	0 N/A	0.63 N/A	2.74	0.40	0.00
VA	5500	5502 ENERGY STAR Multi-Function Printer	Non-Jurisdictional	2014	2054	2.05	0.30	0.69	0.69	25%	0.10	0.10	25%	0.01	0.01	0	0	9.78		0.10	0.69
VA	5500	5501 Multifunction Power Management Enabling	Non-Jurisdictional	2014	2054	1.70	0.27	0.35	1.04	38%	0.03	0.13	32%	0.23	0.08	3	1	0.22			0.00
VA VA	5600 5600	5600 Base Printer 5602 ENERGY STAR Printer	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	22.50 14.67	3.27 2.13	0.00 7.83	0.00 7.83	0% 35%	0.00 1.14	0.00 1.14	0% 35%	N/A 0.00	N/A 0.00	N/A 0	N/A	N/A 44.94	22.50	3.27	0.00 7.83
VA VA	5600 5600	5602 ENERGY STAR Printer 5601 Printer Power Management Enabling	Non-Jurisdictional Non-Jurisdictional	2014	2054 2054	14.67 12.14	2.13 1.95	7.83 2.54	7.83 10.36	35% 46%	1.14 0.19	1.14	35% 40%	0.00	0.00	1	0	44.94 1.01			7.83 2.54
VA	5700	5700 Base Data Center/Server Room	Non-Jurisdictional	2014	2054	143.83	20.89	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	143.83	20.89	0.00
VA	5700	5701 Data Center Improved Operations	Non-Jurisdictional	2014	2054	129.45 112 98	18.80	14.38 16.47	14.38 30.85	10% 21%	2.09	2.09	10%	0.00	0.00	0	0	116.58 47.46			14.38
VA VA	5700 5700	5702 Data Center Best Practices 5703 Data Center State of the Art practices	Non-Jurisdictional Non-Jurisdictional	2014 2014	2054 2054	112.98 106.65	16.41 15.49	16.47 6.33	30.85 37.18	21% 26%	2.39 0.92	4.48 5.40	21% 26%	0.00	0.00	0	0	47.46 24.61			16.47 6.33
VA	6000	6000 Base Water Heating	Non-Jurisdictional	2014	2054	76.92	10.87	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	76.92	10.87	0.00


DNV GL H-18 1/5/2015

APPENDIX H

Comme	rcial Opt-Out	/Exempt/Nonjurisdictional Existing																			
	SYST ADDIT	VE SUPPLY ANALYSIS				Year	2014														SUPPLY
Vintage									Total			Total		Marginal	Average	Marginal	Average	Total			
				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity		Resource			
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic
Sgmt	Number	Number Measure	Туре	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH
VA	6000	6007 Heat Trap	Non-Jurisdictional	2014	2054	72.94	10.31	3.98	3.98	5%	0.56	0.56	5%	0.02	0.02	0	0	4.20			3.98
VA	6000	6002 High Efficiency Water Heater (electric)	Non-Jurisdictional	2014	2054	71.48	10.10	1.46	5.44	7%	0.21	0.77	7%	0.03	0.02	0	0	2.26			1.46
VA	6000	6004 Tankless Water Heater	Non-Jurisdictional	2014	2054	66.12	9.34	5.36	10.80	14%	0.76	1.53	14%	0.05	0.03	0	0	1.61			5.36
VA	6000	6008 Solar Water Heater	Non-Jurisdictional	2014	2054	48.53	6.86	17.59	28.39	37%	2.49	4.01	37%	0.06	0.05	0	0	1.38			17.59
VA	6000	6003 Hot Water Pipe Insulation	Non-Jurisdictional	2014	2054	47.91	6.77	0.62	29.01	38%	0.09	4.10	38%	0.08	0.05	1	0	0.92			0.00
VA	6000	6006 Heat Recovery Unit	Non-Jurisdictional	2014	2054	45.57	6.44	2.34	31.35	41%	0.33	4.43	41%	0.08	0.05	1	0	0.80			0.00
VA	6000	6001 Demand controlled circulating systems	Non-Jurisdictional	2014	2054	44.03	6.22	1.54	32.89	43%	0.22	4.65	43%	0.24	0.06	2	0	0.30			0.00
VA	7000	7000 Base Refrigerated Vending Machines	Non-Jurisdictional	2014	2054	25.15	3.92	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	25.15	3.92	0.00
VA	7000	7001 Vending Misers (Refrigerated units)	Non-Jurisdictional	2014	2054	21.46	3.63	3.69	3.69	15%	0.29	0.29	7%	0.04	0.04	1	1	1.16			3.69
VA	7000	7002 Vending Misers (Refrigerated glass-front units)	Non-Jurisdictional	2014	2054	19.46	3.47	2.00	5.70	23%	0.16	0.44	11%	0.08	0.06	1	1	0.63			0.00
VA	7100	7100 Base Non-Refrigerated Vending Machines	Non-Jurisdictional	2014	2054	0.45	0.07	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.45	0.07	0.00
VA	7100	7101 Vending Misers (Non-Refrigerated)	Non-Jurisdictional	2014	2054	0.26	0.05	0.19	0.19	42%	0.01	0.01	21%	0.86	0.86	11	11	0.06			0.00
VA	7200	7200 Base Oven	Non-Jurisdictional	2014	2054	72.06	11.40	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	72.06	11.40	0.00
VA	7300	7300 Base Fryer	Non-Jurisdictional	2014	2054	36.07	5.71	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	36.07	5.71	0.00
VA	7300	7301 Efficient Fryer	Non-Jurisdictional	2014	2054	34.88	5.52	1.19	1.19	3%	0.19	0.19	3%	0.42	0.42	3	3	0.17			0.00
VA	7400	7400 Base Steamer	Non-Jurisdictional	2014	2054	72.69	11.50	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	72.69	11.50	0.00
VA	8000	8000 Base Heating, Heat Pump (7.7 HSPF)	Non-Jurisdictional	2014	2054	15.57	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	15.57	0.00	0.00
VA	8000	8001 Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Non-Jurisdictional	2014	2054	14.70	0.00	0.88	0.88	6%	0.00	0.00	0%	0.03	0.03	N/A	N/A	2.18			0.88
VA	8100	8100 Base Heating, Other Electric	Non-Jurisdictional	2014	2054	34.88	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	34.88	0.00	0.00
VA	9500	9500 Base Miscellaneous	Non-Jurisdictional	2014	2054	894.20	139.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	894.20	139.33	0.00
VA	9500	9501 Xmisc	Non-Jurisdictional	2014	2054	894.20	139.33	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	0.00			0.00

APPENDIX H


Base Avoided Costs



DNV GL 1/5/2015 H-20


APPENDIX H

Base Avoided Costs



APPENDIX H


Base Avoided Costs



DNV GL H-22 1/5/2015


APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs



APPENDIX H


Base Avoided Costs



DNV GL 1/5/2015 H-31


APPENDIX H

Base Avoided Costs



APPENDIX H


Base Avoided Costs



DNV GL H-33 1/5/2015


APPENDIX H

Base Avoided Costs



APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs




APPENDIX H

Base Avoided Costs



APPENDIX H



APPENDIX H

		pt/Nonjurisdictional New Construction UPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage				Measure	Measure				Total Energy	Percent		Total Capacity	Percent	Marginal Energy	Average Energy	Marginal Capacity	Average Capacity	Total Resource				
Sgmt	Base Number	Measure Number Measure	Building Type	Start Year	End Year	Total GWH	Total MW	GWH Savings	Savings GWH	GWH Savings	MW Savings	Savings MW	MW Savings	Cost \$/kWH	Cost \$/kWH	Cost \$/kW	Cost \$/kW	Cost Test TRC	Base GWH	Base MW	Economic GWH	Economic MW
Opt-Out/Ex Opt-Out/Ex	100 100		Office Office	2014 2014	2053 2053	6.32 5.36	1.44 1.16	0.00 0.97	0.00 0.97	0% 15%	0.00 0.28	0.00 0.28	0% 20%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 2.15	6.32	1.44	0.00	0.00 0.28
Opt-Out/Ex	200		Office	2014	2053	5.06	1.15	0.00	0.00	0%	0.28	0.28	20%	0.04 N/A	0.04 N/A	N/A	N/A	2.15 N/A	5.06	1.15	0.97	0.28
Opt-Out/Ex	200		Office	2014	2053	3.51	0.70	1.54	1.54	31%	0.45	0.45	39%	0.03	0.03	0	0	3.01			1.54	0.45
Opt-Out/Ex Opt-Out/Ex	300 300		Office Office	2014	2053	1.14 0.56	0.26	0.00 0.58	0.00	0% 51%	0.00	0.00	0% 65%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 2.86	1.14	0.26	0.00 0.58	0.00
Opt-Out/Ex	400		Office	2014	2053	0.13	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.13	0.03	0.00	0.00
Opt-Out/Ex	400		Office	2014	2053	0.04	0.00	0.09	0.09	71%	0.03	0.03	91%	0.04	0.04	0	0	2.55			0.09	0.03
Opt-Out/Ex Opt-Out/Ex	100 100		Retail Retail	2014 2014	2053 2053	0.81	0.19 0.15	0.00 0.12	0.00 0.12	0% 15%	0.00	0.00	0% 20%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 1.03	0.81	0.19	0.00 0.12	0.00
Opt-Out/Ex	200	200 Base Bldg Design - 30%	Retail	2014	2053	0.65	0.15	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.65	0.15	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 300		Retail Retail	2014 2014	2053 2053	0.45 0.15	0.09	0.20	0.20	31% 0%	0.06	0.06	39% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.44 N/A	0.15	0.03	0.20	0.06
Opt-Out/Ex	300		Retail	2014	2053	0.13	0.03	0.07	0.07	51%	0.02	0.00	65%	0.07	0.07	0	0	1.37	0.15	0.03	0.07	0.02
Opt-Out/Ex	400		Retail	2014	2053	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	400 100		Retail Grocery	2014 2014	2053 2053	0.00	0.00	0.01 0.00	0.01	71% 0%	0.00	0.00	91% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.22 N/A	0.02	0.00	0.01	0.00
Opt-Out/Ex	100	104 High Performance Building/Int Design - Tier 1 1!	Grocery	2014	2053	0.02	0.00	0.00	0.00	15%	0.00	0.00	20%	0.03	0.03	0	0	2.67			0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 200		Grocery	2014 2014	2053 2053	0.02	0.00	0.00	0.00 0.01	0% 30%	0.00	0.00	0% 39%	N/A 0.02	N/A 0.02	N/A 0	N/A 0	N/A 3.73	0.02	0.00	0.00 0.01	0.00
Opt-Out/Ex	300		Grocery	2014	2053	0.00	0.00	0.00	0.00	0%	0.00	0.00	39% 0%	0.02 N/A	0.02 N/A	N/A	N/A	3.73 N/A	0.00	0.00	0.00	0.00
Opt-Out/Ex	300	304 High Performance Building/Int Design - Tier 3 5	Grocery	2014	2053	0.00	0.00	0.00	0.00	50%	0.00	0.00	65%	0.02	0.02	0	0	3.55			0.00	0.00
Opt-Out/Ex Opt-Out/Ex	400 400		Grocery	2014	2053	0.00	0.00	0.00	0.00	0% 70%	0.00	0.00	0% 91%	N/A 0.03	N/A 0.03	N/A 0	N/A 0	N/A 3.17	0.00	0.00	0.00	0.00
Opt-Out/Ex	100		Warehouse	2014	2053	0.10	0.02	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.10	0.02	0.00	0.00
Opt-Out/Ex	100		Warehouse	2014	2053	0.09	0.02	0.02	0.02	15%	0.00	0.00	20%	0.10	0.10	0	0	0.84			0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 200		Warehouse	2014 2014	2053 2053	0.08	0.02	0.00	0.00	0% 30%	0.00 0.01	0.00 0.01	0% 39%	N/A 0.07	N/A 0.07	N/A 0	N/A 0	N/A 1.17	0.08	0.02	0.00	0.00 0.01
Opt-Out/Ex	300	300 Base Bldg Design - 50%	Warehouse	2014	2053	0.02	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.02	0.00	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	300 400		Warehouse Warehouse	2014 2014	2053	0.01	0.00	0.01	0.01	51% 0%	0.00	0.00	65% 0%	0.08 N/A	0.08 N/A	0 N/A	0 N/A	1.12 N/A	0.00	0.00	0.01	0.00
Opt-Out/Ex	400			2014	2053	0.00	0.00	0.00	0.00	71%	0.00	0.00	91%	0.09	0.09	0	0	1.00	0.00	0.00	0.00	0.00
Opt-Out/Ex	100		School	2014	2053	0.19	0.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.19	0.03	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	100 200		School School	2014 2014	2053 2053	0.16 0.15	0.02	0.03	0.03	15% 0%	0.01	0.01	20% 0%	0.12 N/A	0.12 N/A	1 N/A	1 N/A	0.69 N/A	0.15	0.02	0.00	0.00
Opt-Out/Ex	200	206 High Performance Building/Int Design - Tier 2 3	School	2014	2053	0.10	0.01	0.05	0.05	31%	0.01	0.01	39%	0.09	0.09	0	0	0.97			0.00	0.00
Opt-Out/Ex	300		School	2014	2053	0.03	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	300 400		School School	2014 2014	2053 2053	0.02	0.00	0.02	0.02	51% 0%	0.00	0.00	65% 0%	0.09 N/A	0.09 N/A	0 N/A	0 N/A	0.92 N/A	0.00	0.00	0.00	0.00
Opt-Out/Ex	400		School	2014	2053	0.00	0.00	0.00	0.00	71%	0.00	0.00	91%	0.10	0.10	1	1	0.82			0.00	0.00
Opt-Out/Ex Opt-Out/Ex	100 100		Health Health	2014 2014	2053 2053	1.74 1.48	0.33 0.26	0.00 0.26	0.00 0.26	0% 15%	0.00	0.00 0.06	0% 20%	N/A 0.12	N/A 0.12	N/A	N/A	N/A 0.70	1.74	0.33	0.00	0.00
Opt-Out/Ex	200		Health	2014	2053	1.39	0.26	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.39	0.26	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 300		Health Health	2014 2014	2053 2053	0.97	0.16 0.06	0.42	0.42	30% 0%	0.10 0.00	0.10 0.00	39% 0%	0.09 N/A	0.09 N/A	0 N/A	0 N/A	0.97 N/A	0.31	0.06	0.00	0.00
Opt-Out/Ex	300		Health	2014	2053	0.31	0.06	0.00	0.00	50%	0.00	0.00	65%	0.09	0.09	0 0	0 0	0.93	0.31	0.06	0.00	0.00
Opt-Out/Ex	400	400 Base Bldg Design - 70%	Health	2014	2053	0.03	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.03	0.01	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	400 100		Health Lodging	2014 2014	2053 2053	0.01	0.00 0.01	0.02	0.02	71% 0%	0.01 0.00	0.01 0.00	91% 0%	0.10 N/A	0.10 N/A	0 N/A	0 N/A	0.83 N/A	0.05	0.01	0.00	0.00
Opt-Out/Ex	100		Lodging	2014	2053	0.04	0.01	0.01	0.01	15%	0.00	0.00	20%	0.09	0.09	0	0	0.93	0.05	0.01	0.00	0.00
Opt-Out/Ex	200		Lodging	2014	2053	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00
Opt-Out/Ex	200 300		Lodging Lodging	2014 2014	2053 2053	0.03	0.00	0.01	0.01	30% 0%	0.00	0.00	39% 0%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.31 N/A	0.01	0.00	0.01	0.00
Opt-Out/Ex	300	308 High Performance Building/Int Design - Tier 3 5	Lodging	2014	2053	0.00	0.00	0.00	0.00	50%	0.00	0.00	65%	0.07	0.07	0	0	1.25			0.00	0.00
Opt-Out/Ex	400 400		Lodging Lodging	2014	2053	0.00	0.00	0.00	0.00	0% 71%	0.00	0.00	0% 91%	N/A 0.08	N/A 0.08	N/A 0	N/A 0	N/A 1.11	0.00	0.00	0.00	0.00
Opt-Out/Ex	100		Data Centers	2014	2053	8.83	1.54	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	8.83	1.54	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	100 200	109 High Performance Building/Int Design - Tier 1 1:	Data Centers Data Centers	2014 2014	2053 2053	7.50 7.07	1.24 1.23	1.33	1.33	15% 0%	0.30	0.30	20% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	6.84 N/A	7.07	1.23	1.33	0.30
Opt-Out/Ex	200			2014	2053	4.94	0.75	2.13	2.13	30%	0.00	0.00	39%	0.01	0.01	N/A 0	N/A 0	9.58	7.07	1.23	2.13	0.00
Opt-Out/Ex	300	300 Base Bldg Design - 50%	Data Centers	2014	2053	1.59	0.28	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.59	0.28	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	300 400		Data Centers Data Centers	2014 2014	2053 2053	0.79 0.18	0.10	0.80	0.80	50% 0%	0.18	0.18	65% 0%	0.01 N/A	0.01 N/A	0 N/A	0 N/A	9.12 N/A	0.18	0.03	0.80	0.18
Opt-Out/Ex	400	409 High Performance Building/Int Design - Tier 4 N		2014	2053	0.05	0.00	0.12	0.12	70%	0.03	0.03	91%	0.01	0.01	0	0	8.13			0.12	0.03
Opt-Out/Ex	100	100 Base Bldg Design - 15%	on-Jurisdiction	2014	2053	0.38	0.08	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.38	80.0	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	100 200		n-Jurisdiction n-Jurisdiction	2014 2014	2053 2053	0.32	0.06 0.06	0.06	0.06	15% 0%	0.02	0.02	20% 0%	0.06 N/A	0.06 N/A	0 N/A	0 N/A	1.53 N/A	0.30	0.06	0.06	0.02
Opt-Out/Ex	200	210 High Performance Building/Int Design - Tier 2 3fd	on-Jurisdiction	2014	2053	0.21	0.04	0.09	0.09	30%	0.03	0.03	39%	0.04	0.04	0	0	2.14			0.09	0.03
Opt-Out/Ex Opt-Out/Ex	300 300		on-Jurisdiction	2014 2014	2053 2053	0.07	0.01 0.01	0.00	0.00	0% 51%	0.00 0.01	0.00 0.01	0% 65%	N/A 0.04	N/A 0.04	N/A 0	N/A 0	N/A 2.03	0.07	0.01	0.00	0.00 0.01
Opt-Out/Ex	400	400 Base Bldg Design - 70%	on-Jurisdiction	2014	2053	0.01	0.00	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.01	0.00	0.00	0.00
Opt-Out/Ex	400	410 High Performance Building/Int Design - Tier 4 No		2014	2053	0.00	0.00	0.01	0.01	71%	0.00	0.00	91%	0.05	0.05	0	0	1.81			0.01	0.00
Opt-Out/Ex Opt-Out/Ex	100 100		Misc Misc	2014 2014	2053 2053	2.19 1.85	0.43 0.35	0.00	0.00	0% 15%	0.00	0.00	0% 20%	N/A 0.09	N/A 0.09	N/A 0	N/A 0	N/A 0.93	2.19	0.43	0.00	0.00
Opt-Out/Ex	200	200 Base Bldg Design - 30%	Misc	2014	2053	1.75	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.75	0.34	0.00	0.00
Opt-Out/Ex Opt-Out/Ex	200 300		Misc Misc	2014	2053 2053	1.22	0.21	0.53	0.53	30%	0.13	0.13	39%	0.07 N/A	0.07 N/A	0 N/A	0 N/A	1.30 N/A	0.39	0.08	0.53	0.13
Opt-Out/Ex	300			2014	2053	0.39	0.08	0.00	0.00	0% 51%	0.00	0.00	65%	0.07	0.07	N/A 0	N/A 0	1.23	0.39	0.08	0.00	0.00
Opt-Out/Ex	400		Misc	2014	2053	0.04	0.01	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	0.04	0.01	0.00	0.00

APPENDIX H

		npt/Nonjurisdictional New Construction SUPPLY ANALYSIS				Year	2014														SUPPLY	
Vintage									Total			Total		Marginal	Average	Marginal	Average	Total				
				Measure	Measure				Energy	Percent		Capacity	Percent	Energy	Energy	Capacity	Capacity	Resource				/
	Base	Measure	Building	Start	End	Total	Total	GWH	Savings	GWH	MW	Savings	MW	Cost	Cost	Cost	Cost	Cost Test	Base	Base	Economic	Economic
Sgmt	Number	Number Measure	Type	Year	Year	GWH	MW	Savings	GWH	Savings	Savings	MW	Savings	\$/kWH	\$/kWH	\$/kW	\$/kW	TRC	GWH	MW	GWH	MW
Opt-Out/Ex	400	 412 High Performance Building/Int Design 	gn - Tier 4 N Misc	2014	2053	0.01	0.00	0.03	0.03	71%	0.01	0.01	91%	0.08	0.08	0	0	1.10			0.03	0.01
VA	100	0 100 Base Bldg Design - 15%	Ion-Jurisdiction	2014	2053	79.60	16.85	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	79.60	16.85	0.00	0.00
VA	100	0 110 High Performance Building/Int Design	gn - Tier 1 15on-Jurisdiction	2014	2053	67.47	13.57	12.13	12.13	15%	3.29	3.29	20%	0.06	0.06	0	0	1.53			12.13	3.29
VA	200	0 200 Base Bldg Design - 30%	Ion-Jurisdiction	2014	2053	63.68	13.48	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	63.68	13.48	0.00	0.00
VA	200	 210 High Performance Building/Int Design 	gn - Tier 2 3(on-Jurisdiction	2014	2053	44.28	8.22	19.40	19.40	30%	5.26	5.26	39%	0.04	0.04	0	0	2.14			19.40	5.26
VA	300	0 300 Base Bldg Design - 50%	Ion-Jurisdiction	2014	2053	14.33	3.03	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	14.33	3.03	0.00	0.00
VA	300	0 310 High Performance Building/Int Design	gn - Tier 3 5(on-Jurisdiction	2014	2053	7.05	1.06	7.28	7.28	51%	1.97	1.97	65%	0.04	0.04	0	0	2.03			7.28	1.97
VA	400	0 400 Base Bldg Design - 70%	lon-Jurisdiction	2014	2053	1.59	0.34	0.00	0.00	0%	0.00	0.00	0%	N/A	N/A	N/A	N/A	N/A	1.59	0.34	0.00	0.00
VA	400	0 410 High Performance Building/Int Design	gn - Tier 4 Non-Jurisdiction	2014	2053	0.46	0.03	1.13	1.13	71%	0.31	0.31	91%	0.05	0.05	0	0	1.81			1.13	0.31

I MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL

DNV·GL

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL VA Residential: All Existing Measures Ranked by Economic Potential (GWh)

VA Residential: All Existing Measures Ranked by Economic Potential (GWh)										
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use				
1	Direct Feedback	Single Family	1164.81	1.11	1164.81	Whole Bldg (Retrofit)				
2	ECM Furnace Fan (variable speed motor) - Cooling	Single Family	779.92	3.60	779.92	Furnace Fan				
3	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family	566.21	25.34	566.21	Lighting				
4	2nd Refrigerator Recycling	Single Family	459.50	2.13	459.50	Refrigeration				
5	LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	374.63	51.27	374.63	Lighting				
6	Indirect Feedback	Single Family	372.52	2.38	372.52	Whole Bldg (Retrofit)				
7	Heat Pump Water Heater - Energy Star	Single Family	325.48	1.03	325.48	Water Heating				
8	LEDs (base Halogen 2.5 hrs/day) 2020	Single Family	313.63	9.12	313.63	Lighting				
9	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	295.05	1.23	295.05	Cooling				
10	Air Source Heat Pump (resistance heating)	Single Family	248.28	4.77	248.28	Space Heating				
11	ROB 2L4'T8, 1EB	Single Family	209.84	1.68	209.84	Lighting				
12	Variable-Speed Pool Pump (<1 hp)	Single Family	201.08	1.90	201.08	Pool Pump				
13	High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family	193.94	1.40	193.94	Clothes Dryer				
14	LEDs (base Halogen 6 hrs/day) 2020	Single Family	191.09	17.02	191.09	Lighting				
15	Refrigerator (Energy Star)	Single Family	156.08	1.81	156.08	Refrigeration				
16	Proper Refrigerant Charging and Air Flow (CAC)	Single Family	148.83	1.10	148.83	Cooling				
17	DHW Tank Wrap	Single Family	141.00	1.09	141.00	Water Heating				
18	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Single Family	136.23	5.05	136.23	Lighting				
19	Energy Star LCD TV	Single Family	109.45	15.36	109.45	Electronics				
20	ECM Furnace Fan (variable speed motor) - Cooling	Multi-Family	103.26	3.60	103.26	Furnace Fan				
21	Drain Water Heat Recovery (GFX)	Single Family	96.60	1.43	96.60	Water Heating				
22	Pipe Wrap	Single Family	84.80	3.93	84.80	Water Heating				
23	Low Flow Showerhead 1.5 Gal/Min	Single Family	79.18	2.48	79.18	Water Heating				
24	Air Source Heat Pump (resistance heating)	Multi-Family	78.94	5.50	78.94	Space Heating				
25	LEDs (base Halogen 0.5 hrs/day) 2020	Single Family	70.40	1.68	70.40	Lighting				
26	Heat Pump Water Heater - Energy Star - Early Replacement	Single Family	69.53	1.00	69.53	Water Heating				
27	Indirect Feedback	Multi-Family	61.02	1.55	61.02	Whole Bldg (Retrofit)				
28	Freezer - Early Replacement (Energy Star)	Single Family	56.26	1.41	56.26	Freezer				
29	Faucent Aerators	Single Family	52.41	1.22	52.41	Water Heating				
30	Energy Star Desktop PC	Single Family	49.81	14.43	49.81	Miscellaneous				
31	High Efficiency CD (EF=3.01 w/moisture sensor)	Multi-Family	47.51	1.96	47.51	Clothes Dryer				
32	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Multi-Family	45.64	25.39	45.64	Lighting				
33	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replacement)	Single Family	45.56	1.08	45.56	Cooling				
34	LEDs (base Halogen 2.5 hrs/day) 2020	Multi-Family	45.14	9.12	45.14	Lighting				
35	Refrigerator (Energy Star)	Multi-Family	44.90	1.50	44.90	Refrigeration				

DNV-GL

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL

VA Residential: All Existing Measures Ranked by Economic Potential (GWh)										
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use				
36	LEDs (base CFL 2.5 hrs/day) 2020	Single Family	38.96	1.45	38.96	Lighting				
37	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Multi-Family	38.63	1.19	38.63	Cooling				
38	Programmable Thermostat (HP heating)	Single Family	36.82	1.36	36.82	Space Heating				
39	Freezer (Energy Star)	Single Family	36.77	1.17	36.77	Refrigeration				
40	LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Multi-Family	31.23	51.29	31.23	Lighting				
41	Plug Load Controls - Smart Power Strip (base Desktop PC)	Multi-Family	29.41	1.09	29.41	Miscellaneous				
42	Self Install Weatherization (HP heating)	Single Family	27.62	2.64	27.62	Space Heating				
43	Drain Water Heat Recovery (GFX)	Multi-Family	27.03	1.10	27.03	Water Heating				
44	Programmable Thermostat (HP cooling)	Single Family	26.56	1.65	26.56	Cooling				
45	LEDs (base Halogen 6 hrs/day) 2020	Multi-Family	25.86	16.95	25.86	Lighting				
46	LEDs (base CFL 6 hrs/day) 2020	Single Family	25.66	2.96	25.66	Lighting				
47	Low Flow Showerhead 1.5 Gal/Min	Multi-Family	25.39	2.85	25.39	Water Heating				
48	Energy Star DVD Player	Single Family	24.96	3.89	24.96	Electronics				
49	Pipe Wrap	Multi-Family	24.43	3.10	24.43	Water Heating				
50	Self Install Weatherization (CAC)	Single Family	23.66	6.31	23.66	Cooling				
51	Energy Star LCD TV	Multi-Family	20.66	15.62	20.66	Electronics				
52	Duct Insulation (HP heating)	Single Family	20.40	9.83	20.40	Space Heating				
53	Self Install Weatherization (HP cooling)	Single Family	19.92	2.28	19.92	Cooling				
54	Door Weatherization (resistance heating)	Single Family	16.10	1.20	16.10	Space Heating				
55	ROB 2L4'T8, 1EB	Multi-Family	16.07	1.69	16.07	Lighting				
56	2nd Freezer Recycling	Single Family	15.85	2.94	15.85	Freezer				
57	Faucent Aerators	Multi-Family	15.34	1.61	15.34	Water Heating				
58	Duct Insulation (HP cooling)	Single Family	14.71	9.11	14.71	Cooling				
59	Programmable Thermostat (resistance heating)	Single Family	14.44	1.75	14.44	Space Heating				
60	Door Weatherization (HP heating)	Multi-Family	13.39	1.00	13.39	Space Heating				
61	Door Weatherization (resistance heating)	Multi-Family	13.26	1.60	13.26	Space Heating				
62	Hot water turndown 10 degrees	Single Family	12.66	2.72	12.66	Water Heating				
63	Programmable Thermostat (CAC)	Single Family	12.34	2.29	12.34	Cooling				
64	Return Duct Modification (CAC)	Single Family	12.10	1.82	12.10	Cooling				
65	Energy Star Laptop PC	Single Family	12.07	2.16	12.07	Miscellaneous				
66	Energy Star Plasma TV	Single Family	11.80	6.96	11.80	Electronics				
67	Door Weatherization (HP cooling)	Multi-Family	11.61	1.34	11.61	Cooling				
68	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Multi-Family	11.21	5.04	11.21	Lighting				
69	Self Install Weatherization	Single Family	10.83	2.48	10.83	Space Heating				
70	LEDs (base Halogen 0.5 hrs/day) 2020	Multi-Family	10.72	1.80	10.72	Lighting				

DNV-GL

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL

A Residential: All Existing Measures Ranked by Economic Potential (GWh)									
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use			
71	Hot water turndown 5 degrees	Single Family	9.36	2.73	9.36	Water Heating			
72	Energy Star Desktop PC	Multi-Family	9.10	14.28	9.10	Miscellaneous			
73	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replacement)	Multi-Family	6.98	1.22	6.98	Cooling			
74	Door Weatherization (CAC early replacement)	Single Family	6.37	1.13	6.37	Cooling			
75	Programmable Thermostat (HP heating early replacement)	Single Family	6.20	1.29	6.20	Space Heating			
76	Self Install Weatherization (CAC early replacement)	Single Family	5.84	5.80	5.84	Cooling			
77	Self Install Weatherization (HP heating)	Multi-Family	5.72	2.06	5.72	Space Heating			
78	Hot water turndown 10 degrees	Multi-Family	5.39	2.08	5.39	Water Heating			
79	Energy Star DVD Player	Multi-Family	5.12	4.04	5.12	Electronics			
80	Self Install Weatherization	Multi-Family	4.70	2.72	4.70	Space Heating			
81	Self Install Weatherization (HP heating early replacement)	Single Family	4.65	2.52	4.65	Space Heating			
82	LEDs (base CFL 2.5 hrs/day) 2020	Multi-Family	4.41	1.44	4.41	Lighting			
83	Hot water turndown 5 degrees	Multi-Family	3.99	2.09	3.99	Water Heating			
84	Self Install Weatherization (HP cooling)	Multi-Family	3.88	2.28	3.88	Cooling			
85	Proper Refrigerant Charging and Air	Multi-Family	3.83	1.18	3.83	Cooling			
86	Flow (CAC early replacement) Duct Insulation (HP heating early	Single Family	3.43	9.38	3.43	Space Heating			
87	replacement) Self Install Weatherization (HP cooling	Single Family	3.03	1.97	3.03	Cooling			
88	Early Replacement) Hot water turndown 15 degrees	Single Family	2.98	2.70	2.98	Water Heating			
89	LEDs (base CFL 6 hrs/day) 2020	Multi-Family	2.98	2.98	2.98	Lighting			
90	Duct Insulation (HP heating)	Multi-Family	2.96	3.36	2.96	Space Heating			
91	Duct Insulation (CAC early replacement)	Single Family	2.85	8.90	2.85	Cooling			
92	Freezer - Early Replacement (Energy	Multi-Family	2.81	1.29	2.81	Freezer			
93	Star) 2nd Refrigerator Recycling	Multi-Family	2.59	1.10	2.59	Refrigeration			
94	Self Install Weatherization (CAC)	Multi-Family	2.51	4.25	2.51	Cooling			
95	Energy Star Laptop PC	Multi-Family	2.38	2.14	2.38	Miscellaneous			
96	Door Weatherization (HP heating early	Multi-Family	2.36	1.00	2.36	Space Heating			
97	replacement) Duct Insulation (HP cooling Early	Single Family	2.24	7.85	2.24	Cooling			
98	Replacement) Duct Insulation (CAC)	Single Family	2.22	1.22	2.22	Cooling			
99	Door Weatherization (CAC early	Multi-Family	2.20	1.59	2.20	Cooling			
100	replacement) Door Weatherization (HP cooling Early	Multi-Family	2.05	1.34	2.05	Cooling			
101	Replacement) Duct Insulation (HP cooling)	Multi-Family	2.00	3.99	2.00	Cooling			
102	Programmable Thermostat (CAC early	Single Family	2.00	2.10	2.00	Cooling			
103	replacement) Return Duct Modification (CAC early	Single Family	1.96	1.67	1.96	Cooling			
104	replacement) Freezer (Energy Star)	Multi-Family	1.91	1.10	1.91	Refrigeration			
105	Energy Star Plasma TV	Multi-Family	1.68	7.28	1.68	Electronics			
103	Lifergy Star Flasifia TV	indici-i alliliy	1.00	7.20	1.00	LIECTI UTIICS			

VA Resid	dential: All Existing Measures Rank					
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
106	Self Install Weatherization (HP heating early replacement)	Multi-Family	1.37	2.80	1.37	Space Heating
107	Hot water turndown 15 degrees	Multi-Family	1.27	2.07	1.27	Water Heating
108	Self Install Weatherization (RAC)	Single Family	1.25	2.95	1.25	Cooling
109	Hot water turndown 20 degrees	Single Family	1.13	2.70	1.13	Water Heating
110	Self Install Weatherization (CAC early replacement)	Multi-Family	0.80	7.28	0.80	Cooling
111	Duct Insulation (HP heating early replacement)	Multi-Family	0.71	4.56	0.71	Space Heating
112	Self Install Weatherization (HP cooling Early Replacement)	Multi-Family	0.70	2.33	0.70	Cooling
113	Door Weatherization (RAC)	Multi-Family	0.66	1.94	0.66	Cooling
114	Hot water turndown 20 degrees	Multi-Family	0.48	2.06	0.48	Water Heating
115	Duct Insulation (CAC early replacement)	Multi-Family	0.38	4.75	0.38	Cooling
116	Duct Insulation (HP cooling Early Replacement)	Multi-Family	0.36	4.07	0.36	Cooling
117	Programmable Thermostat (CAC early replacement)	Multi-Family	0.34	1.35	0.34	Cooling
118	Self Install Weatherization (RAC)	Multi-Family	0.22	8.63	0.22	Cooling
119	Door Weatherization (CAC)	Single Family	31.33	0.98	0.00	Cooling
119	14 SEER (12.15 EER) Split-System Air Conditioner (CAC)	Single Family	114.89	0.81	0.00	Cooling
119	15 SEER (12.72 EER) Split-System Air Conditioner (CAC)	Single Family	100.65	0.68	0.00	Cooling
119	Proper Sizing and Quality Install (CAC)	Single Family	162.94	0.62	0.00	Cooling
119	17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	Single Family	152.54	0.47	0.00	Cooling
119	Crawlspace insulation (CAC)	Single Family	8.70	0.42	0.00	Cooling
119	Ceiling R-0 to R-38 Insulation (CAC)	Single Family	38.18	0.40	0.00	Cooling
119	Ceiling R-0 to R-49 Insulation (CAC)	Single Family	0.55	0.04	0.00	Cooling
119	Comprehensive Shell Air Sealing - Inf. Reduction (CAC)	Single Family	59.82	0.26	0.00	Cooling
119	WINDOWS - Default With Sunscreen (CAC)	Single Family	122.95	0.23	0.00	Cooling
119	Ceiling Fans (CAC)	Single Family	12.66	0.19	0.00	Cooling
119	Ceiling R-11 to R-38 Insulaton (CAC)	Single Family	23.41	0.15	0.00	Cooling
119	Ceiling R-11 to R-49 Insulation (CAC)	Single Family	1.00	0.03	0.00	Cooling
119	Duct Testing and Sealing (CAC)	Single Family	4.67	0.10	0.00	Cooling
119	Ceiling R-19 to R-38 Insulation (CAC)	Single Family	6.07	0.09	0.00	Cooling
119	WINDOWS - Double-Glazed Clear to Energy Star (CAC)	Single Family	5.27	0.08	0.00	Cooling
119	Cool Roof (CAC)	Single Family	18.31	0.07	0.00	Cooling
119	Ceiling R-19 to R-49 Insulation (CAC)	Single Family	0.55	0.03	0.00	Cooling
119	Whole House Fans (CAC)	Single Family	27.75	0.06	0.00	Cooling
119	Window Film (CAC)	Single Family	34.85	0.05	0.00	Cooling
119	Wall Blow-in R-0 to R-13 Insulation (CAC)	Single Family	2.05	0.04	0.00	Cooling
119	AC Filter Changes (CAC)	Single Family	4.24	0.04	0.00	Cooling

VA Resi	dential: All Existing Measures Ranl	ked by Econo	mic Potentia	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
119	AC Maintenance and/or tune-up (CAC)	Single Family	4.41	0.03	0.00	Cooling
119	Basement insulation R-13 (CAC)	Single Family	4.30	0.03	0.00	Cooling
119	Floor R-0 to R-19 Insulation-Batts (CAC)	Single Family	0.23	0.03	0.00	Cooling
119	Proper Refrigerant Charging and Air Flow (CAC early replacement)	Single Family	27.32	0.98	0.00	Cooling
119	Cool Roof (CAC early replacement)	Single Family	31.62	0.73	0.00	Cooling
119	Whole House Fans (CAC early replacement)	Single Family	49.68	0.60	0.00	Cooling
119	Proper Sizing and Quality Install (CAC early replacement)	Single Family	24.70	0.46	0.00	Cooling
119	Crawlspace insulation (CAC early replacement)	Single Family	1.26	0.34	0.00	Cooling
119	Ceiling R-0 to R-38 Insulation (CAC early replacement)	Single Family	5.52	0.33	0.00	Cooling
119	Basement insulation R-13 (CAC early replacement)	Single Family	7.50	0.30	0.00	Cooling
119	Ceiling R-0 to R-49 Insulation (CAC early replacement)	Single Family	0.08	0.03	0.00	Cooling
119	WINDOWS - Double-Glazed Clear to Energy Star (CAC early replacement)	Single Family	2.70	0.24	0.00	Cooling
119	Duct Testing and Sealing (CAC early replacement)	Single Family	1.68	0.20	0.00	Cooling
119	Comprehensive Shell Air Sealing - Inf. Reduction (CAC early replacement)	Single Family	8.10	0.20	0.00	Cooling
119	Ceiling Fans (CAC early replacement)	Single Family	1.58	0.14	0.00	Cooling
119	Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Single Family	3.52	0.13	0.00	Cooling
119	Ceiling R-11 to R-49 Insulation (CAC early replacement)	Single Family	0.15	0.03	0.00	Cooling
119	Window Film (CAC early replacement)	Single Family	12.35	0.10	0.00	Cooling
119	WINDOWS - Default With Sunscreen (CAC early replacement)	Single Family	7.27	0.08	0.00	Cooling
119	Ceiling R-19 to R-38 Insulation (CAC early replacement)	Single Family	0.81	0.07	0.00	Cooling
119	Ceiling R-19 to R-49 Insulation (CAC early replacement)	Single Family	0.08	0.02	0.00	Cooling
119	Wall Blow-in R-0 to R-13 Insulation (CAC early replacement)	Single Family	0.30	0.04	0.00	Cooling
119	AC Filter Changes (CAC early replacement)	Single Family	0.61	0.03	0.00	Cooling
119	AC Maintenance and/or tune-up (CAC early replacement)	Single Family	0.64	0.03	0.00	Cooling
119	14 SEER (12.15 EER) Split-System Air Conditioner w/ Ouality Install - Early	Single Family	3.66	0.02	0.00	Cooling
119	Floor R-0 to R-19 Insulation-Batts (CAC early replacement)	Single Family	0.03	0.02	0.00	Cooling
119	Proper Refrigerant Charging and Air Flow (HP cooling)	Single Family	103.83	0.86	0.00	Cooling
119	Door Weatherization (HP cooling)	Single Family	21.86	0.77	0.00	Cooling
119	Cool Roof (HP cooling)	Single Family	137.91	0.63	0.00	Cooling
119	Whole House Fans (HP cooling)	Single Family	216.68	0.52	0.00	Cooling
119	Proper Sizing and Quality Install (HP cooling)	Single Family	93.84	0.36	0.00	Cooling
119	Crawlspace insulation (HP cooling)	Single Family	5.58	0.30	0.00	Cooling
119	Ceiling R-0 to R-38 Insulation (HP cooling)	Single Family	24.70	0.29	0.00	Cooling
119	Basement insulation R-13 (HP cooling)	Single Family	33.33	0.26	0.00	Cooling
119	Ceiling R-0 to R-49 Insulation (HP cooling)	Single Family	0.76	0.06	0.00	Cooling

Description Proper Replacement Proper Replace	VA Resi	dential: All Existing Measures Ran	ked by Econo	mic Potentia	al (GWh)		
Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling) WINDOWS - Double-Glazed Clear to Energy Start (HP cooling) WINDOWS - Double-Glazed Clear to Energy Start (HP cooling) Single Family 11.29 0.13 0.00 Cooling	Rank	Measure Name					End Use
119 NROBUCTO (NEP COOLING) Single Family 11.29 0.13 0.00 Cooling	119		Single Family	7.54	0.18	0.00	Cooling
WINDOWS - Double-Glazed Clear to Enerry Star (HP cooling) Ceiling Rans (HP cooling) Ceiling Rans (HP cooling) Ceiling Rans (HP cooling) Single Family 1.1, 9 0.11 0.00 Cooling	119		Single Family	36.42	0.18	0.00	Cooling
Ceiling Fans (HP cooling)	119	WINDOWS - Double-Glazed Clear to	Single Family	11.29	0.13	0.00	Cooling
Colling R-11 to R-9 Insulation (HP cooling B-mily 1-48	119		Single Family	7.01	0.12	0.00	Cooling
Celling R-11 to R-49 Insulation (HP Floor R-0 to R-19 Insulation Easts (HP Single Family Celling R-19 to R-39 Insulation (HP Cooling R-19 to R-49 Insulation (HP Cooling R-1	119	,	Single Family	15.99	0.11	0.00	Cooling
Floor R-0 to R-19 Insulation-Batts (HP Cooling R-19 to R-38 Insulation (HP Cooling R-10 to R-39 Insulation (HP Cooling Early Replacement)	119	Ceiling R-11 to R-49 Insulation (HP	Single Family	1.48	0.05	0.00	Cooling
Ceiling R-19 to R-38 Insulation (HP colong R-19 to R-49 Insulation (HP colong R-19 to R-49 Insulation (HP colong R-19 to R-49 Insulation (HP colong R-19 to R-19 to R-49 Insulation (HP colong R-19 to R-19	119	Floor R-0 to R-19 Insulation-Batts (HP	Single Family	0.63	0.08	0.00	Cooling
Ceiling R-19 to R-49 Insulation (HP colon)	119	Ceiling R-19 to R-38 Insulation (HP	Single Family	3.94	0.06	0.00	Cooling
Heat Pump Filter Replacement Single Family 3.08 0.03 0.00 Cooling	119	Ceiling R-19 to R-49 Insulation (HP	Single Family	0.84	0.05	0.00	Cooling
119	119		Single Family	3.08	0.03	0.00	Cooling
Heat pump tune up Single Family 3.19 0.02 0.00 Cooling	119	`	Single Family	2.49	0.02	0.00	Cooling
119	119		Single Family	3.19	0.02	0.00	Cooling
Door Weatherization (HP cooling Early Replacement) Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement)	119	` `	Single Family	3.35	0.86	0.00	Cooling
Proper Refrigerant Charqing and Air Flow (HP cooling Early Replacement) Capiling Farly Far	119	Door Weatherization (HP cooling Early	Single Family	4.16	0.83	0.00	Cooling
Cool Roof (HP cooling Early Replacement) Single Family 20.92 0.54 0.00 Cooling	119	Proper Refrigerant Charging and Air	Single Family	15.49	0.73	0.00	Cooling
Whole House Fans (HP cooling early replacement) Proper Sizing and Quality Install (HP cooling Early Replacement) Crawlspace insulation (HP cooling Early Replacement) Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement) Cooling Early Replacement) Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early Replacement) Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early Replacement) Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early Replacement) Single Family	119	Cool Roof (HP cooling Early	Single Family	20.92	0.54	0.00	Cooling
Proper Sizing and Quality Install (HP cooling Early Replacement)	119	Whole House Fans (HP cooling early	Single Family	32.86	0.45	0.00	Cooling
119	119	Proper Sizing and Quality Install (HP	Single Family	14.23	0.31	0.00	Cooling
119	119	Crawlspace insulation (HP cooling Early	Single Family	0.84	0.26	0.00	Cooling
Basement insulation R-13 (HP cooling Early Replacement)	119	Ceiling R-0 to R-38 Insulation (HP	Single Family	3.75	0.25	0.00	Cooling
119	119	Basement insulation R-13 (HP cooling	Single Family	5.05	0.22	0.00	Cooling
Duct Testing and Sealing (HP cooling Early Replacement) Early Replacement) Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Valled Family Single Family Singl	119	Ceiling R-0 to R-49 Insulation (HP	Single Family	0.11	0.05	0.00	Cooling
Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Ceiling Fans (HP cooling early replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-39 Insulation (HP cooling Early Replacement) Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-39 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-39 Insulation (HP cooling Early Replacement) Single Family Single Family D.10 Single Family D.22 D.04 D.00 Cooling	119	Duct Testing and Sealing (HP cooling	Single Family	1.14	0.16	0.00	Cooling
WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Single Family 1.71 0.11 0.00 Cooling	119	Comprehensive Shell Air Sealing - Inf.	Single Family	5.52	0.15	0.00	Cooling
Ceiling Fans (HP cooling early replacement) Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement) Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-10 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-10 to R-13 Insulation (HP cooling Early Replacement) Single Family Ceiling R-10 to R-13 Insulation (HP cooling Early Replacement) Single Family Ceiling R-10 to R-13 Insulation (HP cooling Early Replacement) Single Family Ceiling R-10 to R-10	119	WINDOWS - Double-Glazed Clear to	Single Family	1.71	0.11	0.00	Cooling
Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-49 Insulation (HP coling R-11 to R-49 Insulation (HP cooling Early Replacement) Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement	119	Ceiling Fans (HP cooling early	Single Family	1.06	0.10	0.00	Cooling
Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family O.60 O.05 O.00 Cooling Cooling Cooling Heat Pump Filter Replacement Single Family O.47 O.02 O.00 Cooling Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement) Heat pump tune up Single Family O.47 O.02 O.00 Cooling Cooling Cooling Cooling Cooling O.47 O.02 O.00 Cooling Cooling Cooling	119	Ceiling R-11 to R-38 Insulaton (HP	Single Family	2.42	0.10	0.00	Cooling
Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Single Family Ceiling R-19 to R-38 Insulation (HP cooling Early Replacem	119	Ceiling R-11 to R-49 Insulation (HP	Single Family	0.22	0.04	0.00	Cooling
Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Heat Pump Filter Replacement Single Family O.47 O.02 O.00 Cooling Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement) Heat pump tune up Single Family O.38 O.02 O.00 Cooling Cooling Cooling	119	Floor R-0 to R-19 Insulation-Batts (HP	Single Family	0.10	0.07	0.00	Cooling
Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Heat Pump Filter Replacement Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement) Heat pump tune up Single Family 0.13 0.04 0.00 Cooling 0.00 Cooling 0.38 0.02 0.00 Cooling Cooling 119 Heat pump tune up Single Family 0.48 0.01 0.00 Cooling	119	Ceiling R-19 to R-38 Insulation (HP	Single Family	0.60	0.05	0.00	Cooling
Heat Pump Filter Replacement Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement) Heat pump tune up Single Family O.47 O.02 O.00 Cooling O.00 Cooling O.00 Cooling O.00 Cooling O.00 Cooling O.00 Cooling	119	Ceiling R-19 to R-49 Insulation (HP	Single Family	0.13	0.04	0.00	Cooling
119 cooling Early Replacement) Single Family 0.38 0.02 0.00 Cooling 119 Heat pump tune up Single Family 0.48 0.01 0.00 Cooling	119		Single Family	0.47	0.02	0.00	Cooling
Heat pump tune up Single Family 0.48 0.01 0.00 Cooling	119	`	Single Family	0.38	0.02	0.00	Cooling
Door Weatherization (RAC) Single Family 1.81 0.50 0.00 Cooling	119		Single Family	0.48	0.01	0.00	Cooling
	119	Door Weatherization (RAC)	Single Family	1.81	0.50	0.00	Cooling

	VA Resi	dential: All Existing Measures Ran	ked by Econo	mic Potentia	al (GWh)		
Whole House Fans (RAC) HE Room Air Conditioner - CEE Tier 1 EER I. 3 Single Family 17.91 0.34 0.00 Cooling	Rank	Measure Name					End Use
HE Room AI Filter Replacement Single Family Single Family Leiling R-19 to R-38 Insulation (RAC) Single Family Leiling R-19 to R-38 Insulation (RAC) Single Family Leiling R-19 to R-39 Insulation (RAC) Single Family Leiling R-10 to R-49 Insulation (RAC) Single Family Leiling R-10 to R-39	119	Cool Roof (RAC)	Single Family	11.40	0.41	0.00	Cooling
The color of the	119	Whole House Fans (RAC)	Single Family	17.91	0.34	0.00	Cooling
119 Window Film (RAC)	119		Single Family	4.48	0.26	0.00	Cooling
19	119	Window Film (RAC)	Single Family	15.83	0.20	0.00	Cooling
Eneroy Star (RAC) Comprehensive Shell Air Sealing - Inf. Reduction (RAC) Single Family 0.94 0.02 0.00 Cooling	119	Ceiling R-0 to R-38 Insulation (RAC)	Single Family	1.59	0.15	0.00	Cooling
Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	119		Single Family	0.86	0.12	0.00	Cooling
Ceiling R-0 to R-49 Insulation (RAC) Single Family 0.04 0.02 0.00 Cooling	119	Comprehensive Shell Air Sealing - Inf.	Single Family	3.11	0.12	0.00	Cooling
Ceiling R-11 to R-38 Insulation (RAC) Single Family 1.02 0.06 0.00 Cooling	119		Single Family	0.04	0.02	0.00	Cooling
Ceiling R-11 to R-49 Insulation (RAC)	119	Ceiling Fans (RAC)	Single Family	0.50	0.07	0.00	Cooling
Wall Blow-in R-0 to R-13 Insulation (RAC) Single Family Celling R-19 to R-38 Insulation (RAC) Single Family Celling R-19 to R-49 Insulation (RAC) Single Family Celling R-10 to R-38 Insulation (HP heating) Single Family Celling R-10 to R-39 Insulation (HP heating) Single Family Celling R-10 to R-49 Insulation (HP heating) Single Family Celling R-10 to R-49 Insulation (HP heating) Single Family Celling R-10 to R-49 Insulation (HP heating) Single Family Celling R-10 to R-49 Insulation (HP heating) Single Family Celling R-10 to R-49 Insulation (HP heating) Single Family Celling R-10 to R-49 Insulation (HP heating) Single Family Celling R-11 to R-38 Insulation (HP heating) Single Family Celling R-11 to R-39 Insulation (HP heating) Single Family Celling R-10 to R-49 Insulation (HP heating) Single Family Celling R-11 to R-38 Insulation (HP heating) Single Family Celling R-11 to R-39 Insulation (HP heating) Single Family Celling R-11 to R-39 Insulation (HP heating) Single Family Celling R-11 to R-39 Insulation (HP heating) Celling R-11 to R-39 Insulation (HP heating) Single Family Celling R-11 to R-39 Insulation (HP heating) Single Family Celling R-11 to R-39 Insulation (HP heating) Celling R-10 to R-49 Insulation (HP heating) Celling R-10 to R-49 Insulation (HP heating) Celling R-10 to R-49 Insulation (HP heat	119	Ceiling R-11 to R-38 Insulaton (RAC)	Single Family	1.02	0.06	0.00	Cooling
119 (RAC) Single Family 0.23 0.04 0.00 Cooling 119 Ceiling R-19 to R-38 Insulation (RAC) Single Family 0.25 0.03 0.00 Cooling 119 Ceiling R-19 to R-49 Insulation (RAC) Single Family 0.25 0.03 0.00 Cooling 119 Room AC Filter Replacement EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early replacement) 10% better than Energy Star Dehumidifier ROB (35-45 oints/day) Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heatina) Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heatina) How the third is provided to 16+ SEER/8.7+ HSPF (HP heatina) Single Family 3.13 0.13 0.00 Cooling 119 Crawlspace insulation (HP heating) Single Family 3.84 0.50 0.00 Space Heating 119 Crawlspace insulation (HP heating) Single Family 2.22.45 0.80 0.00 Space Heating 119 Crawlspace insulation (HP heating) Single Family 13.85 0.59 0.00 Space Heating 119 Ceiling R-0 to R-38 Insulation (HP heating) Single Family 454.58 0.55 0.00 Space Heating 119 Basement insulation R-13 (HP heating) Single Family 454.58 0.53 0.00 Space Heating 119 Comprehensive Shell Air Sealing - Inf Reduction (HP heatina) Reduction (HP heatina) 119 Comprehensive Shell Air Sealing - Inf Reduction (HP heatina) Single Family 1.48 0.08 0.00 Space Heating 110 Culling R-11 to R-38 Insulation (HP heating) Single Family 1.40 0.26 0.00 Space Heating 110 Ceiling R-10 to R-10 Insulation (HP heatina) Ceiling R-11 to R-39 Insulation (HP heating) Single Family 1.24 0.12 0.00 Space Heating 110 Ceiling R-19 to R-30 Insulation (HP heating) Ceiling R-19 to R-30 Insulation (HP heating) Single Family 1.24 0.12 0.00 Space Heating 110 Ceiling R-19 to R-30 Insulation (HP heating)	119	Ceiling R-11 to R-49 Insulation (RAC)	Single Family	0.09	0.02	0.00	Cooling
WINDOWS - Default With Sunscreen (RAC) Celling R-19 to R-38 Insulation (RAC) Single Family Celling R-19 to R-38 Insulation (RAC) Single Family Celling R-19 to R-49 Insulation (RAC) Single Family Celling R-11 (Searly replacement) Single Family Celling R-10 to R-39 Insulation (HP heating) Celling R-10 to R-49 Insulation (HP heating) Celling R-10 to R-49 Insulation (HP heating) Celling R-10 to R-49 Insulation (HP heating) Celling R-10 to R-39 Insulation (HP heating) Celling R-11 to R-39 Insulation (HP heating) Celling R-19 to R-39 Insulation (HP heating) Celling R-19 to R-39 Insulation (HP heating) Celling R-19 to R	119		Single Family	0.23	0.04	0.00	Cooling
Ceiling R-19 to R-38 Insulation (RAC) Single Family 0.25 0.03 0.00 Cooling	119	WINDOWS - Default With Sunscreen	Single Family	2.49	0.04	0.00	Cooling
119	119		Single Family	0.25	0.03	0.00	Cooling
EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early replacement) 10% better than Energy Star Dehumidifier ROB (35-45 pints/day) Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating) Single Family 3.84 0.50 0.00 Cooling	119	Ceiling R-19 to R-49 Insulation (RAC)	Single Family	0.05	0.02	0.00	Cooling
Tier 1 EER 11.3 (early replacement)	119	Room AC Filter Replacement	Single Family	0.21	0.02	0.00	Cooling
119	119		Single Family	3.13	0.13	0.00	Cooling
Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating) Door Weatherization (HP heating) Single Family 21.69 0.68 0.00 Space Heating	119	10% better than Energy Star	Single Family	3.84	0.50	0.00	Cooling
119 Door Weatherization (HP heating) Single Family 21.69 0.68 0.00 Space Heating	119	Heat pump upgrade to 16+ SEER/8.7+	Single Family	222.45	0.80	0.00	Space Heating
Ceiling R-0 to R-38 Insulation (HP heating) Single Family 61.45 0.56 0.00 Space Heating	119		Single Family	21.69	0.68	0.00	Space Heating
heating) heat Recovery Ventilators (HP heating) heat Recovery Ventilators (HP heating) lip Basement insulation R-13 (HP heating) Ceiling R-0 to R-49 Insulation (HP heating) lip Ceriling R-0 to R-49 Insulation (HP heating) Duct Testing and Sealing (HP heating) lip WINDOWS - Double-Glazed Clear to Energy Star (HP heating) Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-11 to R-49 Insulation (HP heating) Floor R-0 to R-19 Insulation (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating) Single Family 1.48 0.08 0.00 Space Heating 71.62 0.29 0.00 Space Heating 71.62 0.29 0.00 Space Heating 71.62 0.29 0.00 Space Heating 14.03 0.26 0.00 Space Heating 15ingle Family 16ingle Family 17ingle Family 17i	119	Crawlspace insulation (HP heating)	Single Family	13.85	0.59	0.00	Space Heating
Heat Recovery Ventilators (HP heating) Basement insulation R-13 (HP heating) Ceiling R-0 to R-49 Insulation (HP heating) Ceiling R-10 to R-49 Insulation (HP heating) Ceiling R-10 to R-49 Insulation (HP heating) Single Family 1.48 0.08 0.00 Space Heating 0.00 Space Heating 1.48 0.08 0.00 Space Heating 1.49 Comprehensive Shell Air Sealing - Inf. Reduction (HP heating) Duct Testing and Sealing (HP heating) WINDOWS - Double-Glazed Clear to Energy Star (HP heating) Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-11 to R-49 Insulation (HP heating) Floor R-0 to R-19 Insulation (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating) Single Family Single Family 1.24 0.12 0.00 Space Heating Ceiling R-19 to R-38 Insulation (HP heating) Single Family Single Family 1.24 0.12 0.00 Space Heating Ceiling R-19 to R-38 Insulation (HP heating) Single Family Single Family 1.25 0.08 0.00 Space Heating Space Heating Single Family 1.26 0.00 Space Heating Single Family 1.27 0.00 Space Heating Single Family 1.27 0.00 Space Heating Single Family 1.27 0.00 Space Heating Single Family 1.28 1.29 1.20	119	,	Single Family	61.45	0.56	0.00	Space Heating
Ceiling R-0 to R-49 Insulation (HP heating) Comprehensive Shell Air Sealing - Inf. Reduction (HP heating) Duct Testing and Sealing (HP heating) WINDOWS - Double-Glazed Clear to Energy Star (HP heating) Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-11 to R-49 Insulation (HP heating) Floor R-0 to R-19 Insulation-Batts (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-39 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Single Family Single Family Ceiling R-19 to R-49 Insulation (HP heating) Single Family Single Family 1.24 Ceiling R-19 to R-49 Insulation (HP heating) Single Family Single Family 1.24 Ceiling R-19 to R-49 Insulation (HP heating) Single Family Single Family Single Family 1.25 Concerns Conc	119		Single Family	454.58	0.53	0.00	Space Heating
119	119	Basement insulation R-13 (HP heating)	Single Family	64.80	0.40	0.00	Space Heating
Comprehensive Shell Air Sealing - Inf. Reduction (HP heating) Duct Testing and Sealing (HP heating) WINDOWS - Double-Glazed Clear to Energy Star (HP heating) Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-10 to R-49 Insulation HP heating) Floor R-0 to R-19 Insulation HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Single Family Single Family Single Family 1.24 0.12 0.00 Space Heating Single Family 7.75 0.10 0.00 Space Heating Single Family 1.65 0.08 0.00 Space Heating Single Family 1.65 0.08 0.00 Space Heating Single Family 1.775 0.10 Space Heating Single Family Single Family 1.65 0.08 0.00 Space Heating Space Heating Single Family 1.775 0.10 Space Heating Single Family Single Family Single Family Single Family Single Family Single Family	119	,	Single Family	1.48	0.08	0.00	Space Heating
Duct Testing and Sealing (HP heating) WINDOWS - Double-Glazed Clear to Energy Star (HP heating) Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-11 to R-49 Insulation (HP heating) Floor R-0 to R-19 Insulation (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating) Single Family 124 Ceiling R-19 to R-38 Insulation (HP heating) Single Family 1.24 Ceiling R-19 to R-38 Insulation (HP heating) Single Family Single Family 1.65 Ceiling R-19 to R-49 Insulation (HP heating) Single Family Single Family Single Family 1.65 Ceiling R-19 to R-49 Insulation (HP heating) Single Family	119	Comprehensive Shell Air Sealing - Inf.	Single Family	71.62	0.29	0.00	Space Heating
Energy Star (HP heating) Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-11 to R-49 Insulation (HP heating) Floor R-0 to R-19 Insulation-Batts (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating) Single Family 2.91 0.00 Space Heating 1.24 0.12 0.00 Space Heating 1.25 0.00 Space Heating 1.26 0.00 Space Heating 1.27 0.00 Space Heating 1.28 0.00 Space Heating 1.29 0.00 Space Heating 1.20 0.00 Space Heating	119		Single Family	14.03	0.26	0.00	Space Heating
Ceiling R-11 to R-38 Insulation (HP heating) Ceiling R-11 to R-49 Insulation (HP heating) Single Family	119		Single Family	21.31	0.19	0.00	Space Heating
Ceiling R-11 to R-49 Insulation (HP heating) Floor R-0 to R-19 Insulation-Batts (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating) Ceiling R-10 to R-49 Insulation (HP heating) Single Family 1.24 O.12 O.00 Space Heating 7.75 O.10 O.00 Space Heating 1.65 O.08 O.00 Space Heating Single Family 1.65 O.08 O.00 Space Heating Single Family 1.65 O.08 O.00 Space Heating Single Family 1.779 O.00 Space Heating	119	Ceiling R-11 to R-38 Insulaton (HP	Single Family	31.45	0.17	0.00	Space Heating
Floor R-0 to R-19 Insulation-Batts (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating) Floor R-0 to R-19 Insulation (HP Single Family 1.24 0.12 0.00 Space Heating 1.25 0.00 Space Heating 1.26 0.00 Space H	119	Ceiling R-11 to R-49 Insulation (HP	Single Family	2.91	0.08	0.00	Space Heating
Ceiling R-19 to R-38 Insulation (HP heating) Ceiling R-19 to R-49 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating) Ceiling R-19 to R-38 Insulation (HP heating) Single Family Single Family 1.65 0.10 0.00 Space Heating Single Family 1.65 0.08 0.00 Space Heating Single Family 127.79 0.04 0.00 Space Heating	119	Floor R-0 to R-19 Insulation-Batts (HP	Single Family	1.24	0.12	0.00	Space Heating
Ceiling R-19 to R-49 Insulation (HP heating) Ground Source Heat Pump with Desuperheater (HP heating) Single Family 1.65 0.08 0.00 Space Heating Single Family 127.79 0.04 0.00 Space Heating	119	Ceiling R-19 to R-38 Insulation (HP	Single Family	7.75	0.10	0.00	Space Heating
Ground Source Heat Pump with Desuperheater (HP heating) Single Family 127.79 0.04 0.00 Space Heating	119	Ceiling R-19 to R-49 Insulation (HP	Single Family	1.65	0.08	0.00	Space Heating
	119	Ground Source Heat Pump with	Single Family	127.79	0.04	0.00	Space Heating
	119		Single Family	5.51	0.04	0.00	Space Heating

Heat pump tune up	VA Resi	dential: All Existing Measures Ranl	ked by Econo	mic Potentia	al (GWh)		
Wall Blow-in R-0 to R-13 Insulation (HP heating) Heat pump upgrade to 16+ SEER/8.7+ Heat pump upgrade pump	Rank	Measure Name					End Use
Heat pump upgrade to 16+ SEER/8.7+	119	Heat pump tune up	Single Family	5.74	0.03	0.00	Space Heating
HSPF (HP heating early replacement) Provided Prov	119	•	Single Family	4.44	0.03	0.00	Space Heating
Door Weatherization (HP heating early crawisper enlacement) Single Family 2.33 0.56 0.00 Space Heating Single Family 2.35 0.56 0.00 Space Heating Single Family 2.36 0.51 0.00 Space Heating Single Family 2.36 0.50 0.00 Space Heating Single Family 2.36 0.25 0.08 0.00 Space Heating Single Family 2.36 0.28 0.00 Space Heating Single Family 2.36 0.25 0.00 Space Heating Single Family 2.36 0.27 0.00 Space Heating Single Family	119	HSPF (HP heating early replacement)	Single Family	37.46	0.76	0.00	Space Heating
19	119	Door Weatherization (HP heating early replacement)	Single Family	3.83	0.68	0.00	Space Heating
heating early replacement) Single Family 10.34 0.34 0.00 Space Heating early replacement Celling R-0 to R-9 insulation (HP heating early replacement) Single Family 10.90 0.38 0.00 Space Heating Celling R-0 to R-9 insulation (HP heating early replacement) Celling R-0 to R-19 insulation (HP heating early replacement) Celling R-11 to R-9 insulation (HP heating early replacement) Celling R-11 to R-9 insulation (HP heating early replacement) Celling R-11 to R-9 insulation (HP heating early replacement) Celling R-11 to R-9 insulation (HP heating early replacement) Celling R-11 to R-9 insulation (HP heating early replacement) Celling R-11 to R-9 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to R-19 insulation (HP heating early replacement) Celling R-10 to	119	replacement)	Single Family	2.33	0.56	0.00	Space Heating
19	119	heating early replacement)	Single Family	10.34	0.54	0.00	Space Heating
Single Family 10.90 1.38 1.00	119	early replacement)	Single Family	76.51	0.51	0.00	Space Heating
heating early replacement)	119	early replacement)	Single Family	10.90	0.38	0.00	Space Heating
119	119	heating early replacement)	Single Family	0.25	0.08	0.00	Space Heating
119	119	Reduction (HP heating early	Single Family	12.06	0.28	0.00	Space Heating
Eneray Star (HP heating early Ceiling R-11 to R-38 Insulation (HP heating early replacement) Ceiling R-11 to R-38 Insulation (HP heating early replacement) Floor R-0 to R-19 Insulation batts (HP heating early replacement) Floor R-0 to R-19 Insulation batts (HP heating early replacement) Floor R-0 to R-19 Insulation batts (HP heating early replacement) Floor R-0 to R-19 Insulation batts (HP heating early replacement) Floor R-0 to R-19 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating early replacement) Floor R-0 to R-13 Insulation (HP heating) Floor R-0 to R-13 Insu	119	5 5 5	Single Family	2.36	0.25	0.00	Space Heating
Celling R-11 to R-38 Insulation (HP heating early replacement)	119		Single Family	3.59	0.18	0.00	Space Heating
Ceiling R-11 to R-49 Insulation (HP heating early replacement) Floor R-0 to R-19 Insulation-Batts (HP heating early replacement) Ceiling R-19 to R-38 Insulation (HP heating early replacement) Ceiling R-19 to R-39 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-10 to R-13 Insulation (HP heating early replacement) Ceiling R-10 to R-13 Insulation (HP heating early replacement) Ceiling R-10 to R-31 Insulation (HP heating early replacement) Ceiling R-10 to R-31 Insulation (HP heating early replacement) Ceiling R-10 to R-38 Insulation (resistance heating) Heat Recovery Ventilators (resistance heating) Basement insulation (resistance heating) Ceiling R-10 to R-49 Insulation (resistance heating) Ceiling R-10 to R-49 Insulation (resistance heating) Floor R-0 to R-19 Insulation (resistance heating) Ceiling R-11 to R-38 Insulation (resistance heating) Ceiling R-10 to R-38 Insul	119	Ceiling R-11 to R-38 Insulaton (HP	Single Family	5.29	0.17	0.00	Space Heating
Floor R-0 to R-19 Insulation-Batts (HP heating early replacement)	119	Ceiling R-11 to R-49 Insulation (HP	Single Family	0.49	0.07	0.00	Space Heating
Ceiling R-19 to R-38 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-19 to R-49 Insulation (HP heating early replacement) Ceiling R-10 to R-38 Insulation (HP heating early replacement) Ceiling R-0 to R-38 Insulation (HP heating early replacement) Ceiling R-0 to R-38 Insulation (HP heating early replacement) Ceiling R-0 to R-38 Insulation (HP heating early replacement) Ceiling R-0 to R-38 Insulation (HP heating early replacement) Ceiling R-0 to R-38 Insulation (HP heating early replacement) Ceiling R-0 to R-49 Insulation (resistance heating) Crawlspace insulation (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Ceiling R-10 to R-49 Insulation (resistance he	119	Floor R-0 to R-19 Insulation-Batts (HP	Single Family	0.21	0.12	0.00	Space Heating
Ceiling R-19 to R-49 Insulation (HP heating aerly replacement) Ground Source Heat Pump with Desuperheater (HP heating aerly replacement) Single Family Desuperheater (HP heating aerly prolated early Single Family Desuperheater (HP heating) Single Family Desuperheater (HP heating) Single Family Desuperheater (HP heating) Single Family Desuperheater (HP heating aerly prolated early Desuperheater (HP heating) Single Family Desuperheater (Fesistance heating) Desuperheater (Fesistance heating) Heat pump tune up (heating) Single Family Desuperheater (Fesistance heating) Desuperheater (Fesistance heat	119	Ceiling R-19 to R-38 Insulation (HP	Single Family	1.30	0.09	0.00	Space Heating
Ground Source Heat Pump with Desuperheater (HP heating early Desuperheater (HP heating early Desuperheater (HP heating early Desuperheater (HP heating early Desuperheater (HP heating) Single Family 0.93 0.04 0.00 Space Heating 119 Heat pump tune up (heating) Single Family 0.97 0.03 0.00 Space Heating 119 Heat pump tune up (heating) Single Family 0.97 0.03 0.00 Space Heating 119 Ceiling R-0 to R-38 Insulation (resistance heating) (resistance heating) (resistance heating) Single Family 28.68 0.63 0.00 Space Heating 119 Heat Recovery Ventilators (resistance heating) Single Family 195.75 0.55 0.00 Space Heating 119 Ceiling R-0 to R-49 Insulation (resistance heating) Single Family 4.14 0.42 0.00 Space Heating 119 Ceiling R-0 to R-49 Insulation (resistance heating) Single Family 0.53 0.07 0.00 Space Heating 119 Ceiling R-11 to R-38 Insulation (resistance heating) Single Family 10.28 0.22 0.00 Space Heating 119 Ceiling R-11 to R-38 Insulation (resistance heating) Single Family 10.28 0.22 0.00 Space Heating 119 Ceiling R-11 to R-38 Insulation (resistance heating) Single Family 10.28 0.22 0.00 Space Heating 119 Ceiling R-11 to R-38 Insulation (resistance heating) Single Family 10.28 0.22 0.00 Space Heating 119 Ceiling R-10 to R-39 Insulation (resistance heating) Single Family 10.28 0.20 0.00 Space Heating 119 Ceiling R-10 to R-39 Insulation (resistance heating) Single Family 0.74 0.18 0.00 Space Heating 119 Ceiling R-10 to R-39 Insulation (resistance heating) Single Family 0.59 0.07 0.00 Space Heating 119 Ceiling R-10 to R-39 Insulation (resistance heating) Single Family 0.59 0.07 0.00 Space Heating 119 Ceiling R-10 to R-39 Insulation (resistance heating) Single Family 0.59 0.07 0.00 Space Heating 119 Ceiling R-10 to R-49 Insulation Single Family 0.59 0.07 0.00 Space Heating 119 Ceiling R-10 to R-49 Insulation Single Family 0.59 0.07 0.00 Space Heating 119 Ceiling R-10 to R-40 Insulation Single Family 0.59 0.07 0.00 Space Heating 119 Ceiling R-10 to R-40 Insulation Single Family 0.59 0.07 0.00 Space Heating 119 Ceiling	119	Ceiling R-19 to R-49 Insulation (HP	Single Family	0.28	0.07	0.00	Space Heating
Heat Pump Filter Replacement (heating) Single Family 0.93 0.04 0.00 Space Heating	119	Ground Source Heat Pump with	Single Family	21.51	0.04	0.00	Space Heating
Wall Blow-in R-0 to R-13 Insulation (HP heating early replacement) Ceiling R-0 to R-38 Insulation (resistance heating)	119		Single Family	0.93	0.04	0.00	Space Heating
heating early replacement) Ceiling R-0 to R-38 Insulation (resistance heating) Heat Recovery Ventilators (resistance heating) Crawlspace insulation (resistance heating) Basement insulation R-13 (resistance heating) Crawlspace insulation (resistance heating) Basement insulation R-13 (resistance heating) Crawlspace insulation R-13 (resistance heating) Crawlspace insulation (resistance heating) Basement insulation R-13 (resistance heating) Crawlspace insulation (resistance heating) Basement insulation R-13 (resistance heating) Crawlspace insulation R-13 (resistance heating) Basement insulation R-13 (resistance heating) Crawlspace insulation R-13 (resistance heating) Crawlspace insulation R-13 (resistance heating) Basement insulation R-13 (resistance heating) Cresistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Colling R-11 to R-38 Insulation (resistance heating) Floor R-0 to R-19 Insulation Colling R-11 to R-49 Insulation (resistance heating) Colling R-11 to R-38 Insulation (resistance heating) Colling R-11 to R-38 Insulation (resistance heating) Colling R-19 to R-38 Insulation (resistance heating) Ground Source Heat Pump with Desuperheater (resistance heating) Wall Blow-in R-0 to R-13 Insulation	119		Single Family	0.97	0.03	0.00	Space Heating
(resistance heating) Heat Recovery Ventilators (resistance heating) Heat Recovery Ventilators (resistance heating) Crawlspace insulation (resistance heating) Basement insulation R-13 (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) WINDOWS - Double-Glazed Clear to Energy Star (resistance heating) Ceiling R-11 to R-38 Insulation (resistance heating) Ceiling R-10 to R-49 Insulation Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Geround Source Heat Pump with Desuperheater (resistance heating) Wall Blow-in R-0 to R-13 Insulation	119	heating early replacement)	Single Family	0.75	0.02	0.00	Space Heating
heating) Crawlspace insulation (resistance heating) Basement insulation R-13 (resistance heating) Basement insulation R-13 (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) WINDOWS - Double-Glazed Clear to Energy Star (resistance heating) Ceiling R-11 to R-38 Insulation (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-38 Insulation Ceiling R-11 to R-38 Insulation (resistance heating) Ceiling R-11 to R-39 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Geiling R-19 to R-49 Insulation (resistance heating) Single Family 1.05 Single Family 3.74 0.11 0.00 Space Heating Single Family 0.59 0.07 0.00 Space Heating	119	_	Single Family	28.68	0.63	0.00	Space Heating
heating) Basement insulation R-13 (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) WINDOWS - Double-Glazed Clear to Enerav Star (resistance heating) Ceiling R-11 to R-38 Insulation (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation Ceiling R-19 to R-38 Insulation Ceiling R-19 to R-38 Insulation Ceiling R-19 to R-38 Insulation Ceiling R-19 to R-49 Insulation Ceiling R-19 to R-38 Insulation Ceiling R-19 to R-49 Insulation Ceiling R-19 to R-49 Insulation Ceiling R-19 to R-38 Insulation Ceiling R-19 to R-49 Insulation Ceiling R-19 to R-49 Insulatio	119	•	Single Family	195.75	0.55	0.00	Space Heating
119	119	heating)	Single Family	4.14	0.42	0.00	Space Heating
Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) WINDOWS - Double-Glazed Clear to Energy Star (resistance heating) Ceiling R-11 to R-38 Insulation (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ground Source Heat Pump with Desuperheater (resistance heating) Wall Blow-in R-0 to R-13 Insulation Wall Blow-in R-0 to R-13 Insulation Single Family O.53 O.07 O.00 Space Heating 10.28 O.22 O.00 Space Heating 11.28 O.19 O.00 Space Heating O.74 O.18 O.07 O.00 Space Heating O.74 O.11 O.00 Space Heating Single Family O.59 O.77 O.00 Space Heating Single Family O.59 O.77 O.00 Space Heating Single Family O.59 O.77 O.70 O.70 Space Heating Single Family O.79 Single Family O.79 Single Family O.79 O.70 Space Heating Single Family O.79 Single Family O.79 O.70 Space Heating Single Family O.79 O.70 Space Heating Single Family O.79 O.70 O.70 Space Heating Single Family O.79 O.70 O	119	heating)	Single Family	42.74	0.41	0.00	Space Heating
Reduction (resistance heating) WINDOWS - Double-Glazed Clear to Energy Star (resistance heating) Ceiling R-11 to R-38 Insulaton (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation (resistance heating) Ceiling R-11 to R-49 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Single Family Single Family Single Family Single Family	119	_	Single Family	0.53	0.07	0.00	Space Heating
WINDOWS - Double-Glazed Clear to Energy Star (resistance heating) Ceiling R-11 to R-38 Insulaton (resistance heating) Single Family 10.28 0.22 0.00 Space Heating 119 Floor R-0 to R-19 Insulation-Batts (resistance heating) Single Family 0.74 0.18 0.00 Space Heating 119 Ceiling R-11 to R-49 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Single Family 1.05 0.07 0.00 Space Heating 119 Ceiling R-19 to R-49 Insulation (resistance heating) Single Family 0.59 0.07 0.00 Space Heating 119 Ground Source Heat Pump with Desuperheater (resistance heating) Single Family 0.59 0.07 0.00 Space Heating 119 Single Family 0.59 0.07 0.00 Space Heating 119 Single Family 0.59 0.07 0.00 Space Heating 119 Single Family 0.59 0.00 0.00 Space Heating 119 0.00 Spac	119		Single Family	29.98	0.29	0.00	Space Heating
Ceiling R-11 to R-38 Insulaton (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Single Family O.74 O.00 Space Heating Single Family O.59 O.07 O.00 Space Heating Single Family Single Family O.59 O.00 Space Heating Single Family O.59 O.00 Space Heating Single Family O.59 O.00 Space Heating	119	WINDOWS - Double-Glazed Clear to	Single Family	10.28	0.22	0.00	Space Heating
Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ground Source Heat Pump with Desuperheater (resistance heating) Wall Blow-in R-0 to R-13 Insulation Single Family O.74 O.18 O.00 Space Heating 3.74 O.11 O.00 Space Heating Single Family Single Family 4.92 O.00 Space Heating Single Family	119	Ceiling R-11 to R-38 Insulaton (resistance heating)	Single Family	14.38	0.19	0.00	Space Heating
Ceiling R-11 to R-49 Insulation (resistance heating) Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ground Source Heat Pump with Desuperheater (resistance heating) Wall Blow-in R-0 to R-13 Insulation Ceiling R-11 to R-49 Insulation Single Family 3.74 0.11 0.00 Space Heating 0.59 0.07 0.00 Space Heating 4.92 0.00 Space Heating Single Family	119	Floor R-0 to R-19 Insulation-Batts	Single Family	0.74	0.18	0.00	Space Heating
Ceiling R-19 to R-38 Insulation (resistance heating) Ceiling R-19 to R-49 Insulation (resistance heating) Ground Source Heat Pump with Desuperheater (resistance heating) Wall Blow-in R-0 to R-13 Insulation Single Family	119	Ceiling R-11 to R-49 Insulation (resistance heating)	Single Family	1.05	0.07	0.00	Space Heating
Ceiling R-19 to R-49 Insulation (resistance heating) Ground Source Heat Pump with Desuperheater (resistance heating) Wall Blow-in R-0 to R-13 Insulation Ceiling R-19 to R-49 Insulation Single Family	119	Ceiling R-19 to R-38 Insulation	Single Family	3.74	0.11	0.00	Space Heating
Ground Source Heat Pump with Desuperheater (resistance heating) Wall Blow-in R-0 to R-13 Insulation Single Family 2.85 0.00 0.00 Space Heating	119	Ceiling R-19 to R-49 Insulation	Single Family	0.59	0.07	0.00	Space Heating
Wall Blow-in R-0 to R-13 Insulation Single Family 2.85 0.04 0.00 Space Heating	119	Ground Source Heat Pump with Desuperheater (resistance heating)	Single Family	4.92	0.00	0.00	Space Heating
(resistance neating)	119	Wall Blow-in R-0 to R-13 Insulation (resistance heating)	Single Family	2.85	0.04	0.00	Space Heating

Rank Measure Name Type Technical GWh TRC GWh	VA Resi	dential: All Existing Measures Ran	ked by Econo	mic Potentia	al (GWh)		
Refrigeration - Early Replacement (Energy Star) Continue Single Family Single Family	Rank	Measure Name	_				End Use
Cineray Star Single Family 913.38 0.45 0.00 Mater Heating 119 Energy Star CW CEET Iter 2 (MEF=2.0) Single Family 2.77 0.02 0.00 Water Heating 119 Energy Star CW CEET Iter 2 (MEF=2.0) Single Family 2.27 0.02 0.00 Water Heating 119 Energy Star Dishwasher (EF=0.72) Single Family 2.27 0.02 0.00 Water Heating 119 Energy Star Dishwasher (EF=0.72) Single Family 430.98 0.09 0.00 Clothes Dryer 119 Energy Star Dishwasher (EF=0.72) Single Family 430.98 0.09 0.00 Clothes Dryer 119 Energy Star Dishwasher (EF=0.72) Single Family 430.98 0.09 0.00 Clothes Dryer 119 Energy Star Dishwasher (EF=0.72) Single Family 430.98 0.09 0.00 Dishwashers 119 PV-Powered Pool Pumps Single Family 9.13 0.04 0.00 Dishwashers 119 PV-Powered Pool Pumps Single Family 0.94 0.01 0.00 Electronics 119 Piug Load Controls - Smart Power Strip (base Daskor DrV) Single Family 5.99 0.04 0.00 Electronics 119 Piug Load Controls - Smart Power Strip (base Daskor DrV) 119 Piug Load Controls - Smart Power Strip (base Daskor DrV) 119 Programmable Thermostat (CAC) Multi-Family 10.480 0.65 0.00 Miscellaneous 119 Programmable Thermostat (CAC) Multi-Family 1.05.1 0.79 0.00 Cooling 119 Programmable Thermostat (CAC) Multi-Family 1.05.1 0.79 0.00 Cooling 119 Programmable Thermostat (CAC) Multi-Family 0.28 0.61 0.00 Cooling 119 Energy Star Dishwashers Multi-Family 0.79 0.58 0.00 Cooling 119 Energy Star Dishwashers Multi-Family 1.05.1 0.71 0.00 Cooling 119 Camprelmensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 0.75 0.34 0.00 Cooling 119 Crawlspace insulation (CAC) Multi-Family 7.54 0.44 0.00 Cooling 119 Crawlspace insulation (CAC) Multi-Family 7.54 0.44 0.00 Cooling 119 Ceiling R-10 to R-38 Insulation (CAC) Multi-Family 7.50 0.15 0.00 Cooling 119 Ceiling R-10 to	119		Single Family	9.50	0.29	0.00	Lighting
Energy Star CW CEE Tier 2 (MEF=2.0) Single Family 2.77 0.02 0.00 Water Heating	119	, ,	Single Family	62.96	0.59	0.00	Refrigeration
119 Energy Star Dishwasher (EF=0.72) Single Family 17.95 0.06 0.00 Clothes Washer 119 Energy Star CW CEE Tier 2 (MEF=2.0) Single Family 17.95 0.06 0.00 Clothes Washer 119 Heat Pump Dryer Single Family 430.98 0.09 0.00 Clothes Dryer 119 Energy Star Dishwasher (EF=0.72) Single Family 9.13 0.04 0.00 Dishwashers 119 PV-Powered Pool Pumps Single Family 73.96 0.07 0.00 Pool Pump 119 Pug Load Controls - Smart Power Strip Chase LCD TV) Chase LCD TV] Chase LCD TV] Chase LCD TV] Pug Load Controls - Smart Power Strip Chase CRT TVI Chase Desktop PC) Pug Load Controls - Smart Power Strip Chase Desktop PC) Door Weatherization (CAC) Multi-Family 7.51 0.96 0.00 Electronics 119 Proparmable Thermostat (CAC) Multi-Family 0.79 0.00 Cooling 119 Proper Refrigerant Charging and Air Flow (CAC) Multi-Family 0.28 0.61 0.00 Cooling 119 Return Duct Modification (CAC) Multi-Family 0.79 0.58 0.00 Cooling 119 To SEER (12.15 EER) Spit-System Air Conditioner (CAC) Multi-Family 0.79 0.58 0.00 Cooling 119 Ceiling Fans (CAC) Multi-Family 0.79 0.58 0.00 Cooling 119 Ceiling Fans (CAC) Multi-Family 0.79 0.58 0.00 Cooling 119 Ceiling Fans (CAC) Multi-Family 0.79 0.58 0.00 Cooling 119 Ceiling Ran CAC) Multi-Family 0.79 0.58 0.00 Cooling 119 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 0.79 0.11 0.00 Cooling 119 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 0.79 0.11 0.00 Cooling 119 Ceiling Ran CAC Multi-Family 0.79 0.11 0.00 Cooling 119 Ceiling Ran CAC Multi-Family 0.79 0.11 0.00 Cooling 119 Ceiling Ran CAC Multi-Family 0.79 0.11 0.00 Cooling 110 Ceiling Ran CAC Multi-Family 0.79 0.11 0.00 Cooling 110 Ceiling Ran CAC Multi-Family 0.79 0.11 0.00 Cooling	119	Solar Domestic Water Heating	Single Family	913.38	0.45	0.00	Water Heating
Energy Star CW CEE Tier 2 (MEF=2.0) Single Family 17.95 0.06 0.00 Clothes Washer	119	Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family	2.77	0.02	0.00	Water Heating
Heat Pump Dryer Single Family 430,98 0.09 0.00 Clothes Dryer	119	Energy Star Dishwasher (EF=0.72)	Single Family	2.27	0.02	0.00	Water Heating
119 Energy Star Dishwasher (EF=0.72) Single Family 9.13 0.04 0.00 Dishwashers	119	Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family	17.95	0.06	0.00	Clothes Washer
PV-Powered Pool Pumps Single Family 73.96 0.07 0.00 Pool Pump Plug Load Controls - Smart Power Strip Single Family 0.94 0.01 0.00 Electronics Smart Power Strip (base Josana TV) Single Family 0.94 0.01 0.00 Electronics Smart Power Strip (base JCD TV) Plug Load Controls - Smart Power Strip (base JCD TV) Plug Load Controls - Smart Power Strip (base DVD Jolver) Plug Load Controls - Smart Power Strip (base DVD Jolver) Plug Load Controls - Smart Power Strip (base DVD Jolver) Plug Load Controls - Smart Power Strip (base DVD Jolver) Plug Load Controls - Smart Power Strip (base DVD Jolver) Plug Load Controls - Smart Power Strip (base Desktop PC) Door Weatherization (CAC) Multi-Family 10.480 0.65 0.00 Miscellaneous Miscellaneous	119	Heat Pump Dryer	Single Family	430.98	0.09	0.00	Clothes Dryer
Plug Load Controls - Smart Power Strip (hase plasma TV)	119	Energy Star Dishwasher (EF=0.72)	Single Family	9.13	0.04	0.00	Dishwashers
119	119	PV-Powered Pool Pumps	Single Family	73.96	0.07	0.00	Pool Pump
Plug Load Controls - Smart Power Strip (base LCD TV)	119		Single Family	0.94	0.01	0.00	Electronics
Plug Load Controls - Smart Power Strip (base CRT TV)	119	Plug Load Controls - Smart Power Strip	Single Family	4.35	0.01	0.00	Electronics
Plug Load Controls - Smart Power Strip (base DVD plaver)	119	Plug Load Controls - Smart Power Strip	Single Family	5.99	0.04	0.00	Electronics
Plug Load Controls - Smart Power Strip (base Deskton PC) Door Weatherization (CAC) Multi-Family 7.51 0.96 0.00 Cooling	119	Plug Load Controls - Smart Power Strip	Single Family	19.83	0.07	0.00	Electronics
119	119	Plug Load Controls - Smart Power Strip	Single Family	104.80	0.65	0.00	Miscellaneous
Proper Refrigerant Charging and Air Flow (CAC) Multi-Family 10.51 0.71 0.00 Cooling	119		Multi-Family	7.51	0.96	0.00	Cooling
Flow (CAC)	119	Programmable Thermostat (CAC)	Multi-Family	1.15	0.79	0.00	Cooling
Duct Insulation (CAC) Multi-Family 0.28 0.61 0.00 Cooling	119		Multi-Family	10.51	0.71	0.00	Cooling
119	119		Multi-Family	0.28	0.61	0.00	Cooling
119	119	Return Duct Modification (CAC)	Multi-Family	0.79	0.58	0.00	Cooling
119	119	. , , ,	Multi-Family	8.64	0.52	0.00	Cooling
119 17 SEER (12.28 EER) Split-System Air Conditioner (CAC) Multi-Family 12.58 0.34 0.00 Cooling 119 Crawlspace insulation (CAC) Multi-Family 0.37 0.31 0.00 Cooling 119 Ceiling Fans (CAC) Multi-Family 5.64 0.25 0.00 Cooling 119 Proper Sizing and Quality Install (CAC) Multi-Family 9.72 0.18 0.00 Cooling 119 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 4.11 0.16 0.00 Cooling 119 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 7.20 0.15 0.00 Cooling 119 Duct Testing and Sealing (CAC) Multi-Family 1.76 0.13 0.00 Cooling 119 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 1.99 0.12 0.00 Cooling 119 WINDOWS - Default With Sunscreen (CAC) Multi-Family 5.20 0.08 0.00 Cooling 119 Ceiling R-11 to R-38 Insulation (CAC) Mul	119	15 SEER (12.72 EER) Split-System Air	Multi-Family	7.54	0.44	0.00	Cooling
119 Crawlspace insulation (CAC) Multi-Family 0.37 0.31 0.00 Cooling 119 Ceiling Fans (CAC) Multi-Family 5.64 0.25 0.00 Cooling 119 Proper Sizing and Quality Install (CAC) Multi-Family 9.72 0.18 0.00 Cooling 119 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 4.11 0.16 0.00 Cooling 119 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 7.20 0.15 0.00 Cooling 119 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 1.76 0.13 0.00 Cooling 119 Duct Testing and Sealing (CAC) Multi-Family 1.99 0.12 0.00 Cooling 119 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.09 0.01 0.00 Cooling 119 WINDOWS - Default With Sunscreen (CAC) Multi-Family 5.20 0.08 0.00 Cooling 119 Ceiling R-11 to R-38 Insulation (CAC) Multi-Fa	119	17 SEER (12.28 EER) Split-System Air	Multi-Family	12.58	0.34	0.00	Cooling
119 Proper Sizing and Quality Install (CAC) Multi-Family 9.72 0.18 0.00 Cooling 119 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 4.11 0.16 0.00 Cooling 119 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 7.20 0.15 0.00 Cooling 119 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 1.76 0.13 0.00 Cooling 119 Duct Testing and Sealing (CAC) Multi-Family 1.99 0.12 0.00 Cooling 119 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.09 0.01 0.00 Cooling 119 WINDOWS - Default With Sunscreen (CAC) Multi-Family 5.20 0.08 0.00 Cooling 119 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 1.04 0.05 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 2.19 0.05 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) <	119		Multi-Family	0.37	0.31	0.00	Cooling
119 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 4.11 0.16 0.00 Cooling 119 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 7.20 0.15 0.00 Cooling 119 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 1.76 0.13 0.00 Cooling 119 Duct Testing and Sealing (CAC) Multi-Family 1.99 0.12 0.00 Cooling 119 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.09 0.01 0.00 Cooling 119 WINDOWS - Default With Sunscreen (CAC) Multi-Family 5.20 0.08 0.00 Cooling 119 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 1.04 0.05 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 2.19 0.05 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 0.62 0.04 0.00 Cooling 110 Cooling Cooling Cooling Cooling 111 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 0.62 0.04 0.00 Cooling 110 Cooling Cooling CAC) Cooling 111 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling 110 Cooling CACC CACC CACC CACCC CACCCC CACCCCCCCC	119	Ceiling Fans (CAC)	Multi-Family	5.64	0.25	0.00	Cooling
Reduction (CAC)	119	Proper Sizing and Quality Install (CAC)	Multi-Family	9.72	0.18	0.00	Cooling
119 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 7.20 0.15 0.00 Cooling 119 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 1.76 0.13 0.00 Cooling 119 Duct Testing and Sealing (CAC) Multi-Family 1.99 0.12 0.00 Cooling 119 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.09 0.01 0.00 Cooling 119 WINDOWS - Default With Sunscreen (CAC) Multi-Family 5.20 0.08 0.00 Cooling 119 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 1.04 0.05 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 2.19 0.05 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling	119		Multi-Family	4.11	0.16	0.00	Cooling
Energy Star (CAC)	119		Multi-Family	7.20	0.15	0.00	Cooling
119 Duct Testing and Sealing (CAC) Multi-Family 1.99 0.12 0.00 Cooling 119 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.09 0.01 0.00 Cooling 119 WINDOWS - Default With Sunscreen (CAC) Multi-Family 5.20 0.08 0.00 Cooling 119 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 1.04 0.05 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 2.19 0.05 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling	119		Multi-Family	1.76	0.13	0.00	Cooling
119 WINDOWS - Default With Sunscreen (CAC) Multi-Family 5.20 0.08 0.00 Cooling 119 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 1.04 0.05 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 2.19 0.05 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling	119		Multi-Family	1.99	0.12	0.00	Cooling
119	119	Ceiling R-0 to R-49 Insulation (CAC)	Multi-Family	0.09	0.01	0.00	Cooling
119 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 1.04 0.05 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 2.19 0.05 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling	119		Multi-Family	5.20	0.08	0.00	Cooling
Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.62 0.04 0.00 Cooling	119		Multi-Family	1.04	0.05	0.00	Cooling
(CAC) Multi-ramily 0.62 0.04 0.00 Cooling	119	Cool Roof (CAC)	Multi-Family	2.19	0.05	0.00	Cooling
	119		Multi-Family	0.62	0.04	0.00	Cooling
, , , , , , , , , , , , , , , , , , , ,	119	(CAC) Window Film (CAC)	Multi-Family	3.90	0.04	0.00	Cooling

VA Resi	dential: All Existing Measures Ranl	ked by Econo	mic Potentia	ıl (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
119	Whole House Fans (CAC)	Multi-Family	3.65	0.04	0.00	Cooling
119	Ceiling R-11 to R-49 Insulation (CAC)	Multi-Family	0.04	0.01	0.00	Cooling
119	Ceiling R-19 to R-38 Insulation (CAC)	Multi-Family	0.11	0.03	0.00	Cooling
119	Ceiling R-19 to R-49 Insulation (CAC)	Multi-Family	0.01	0.01	0.00	Cooling
119	Floor R-0 to R-19 Insulation-Batts (CAC)	Multi-Family	0.31	0.02	0.00	Cooling
119	Basement insulation R-13 (CAC)	Multi-Family	0.13	0.02	0.00	Cooling
119	AC Filter Changes (CAC)	Multi-Family	0.17	0.01	0.00	Cooling
119	AC Maintenance and/or tune-up (CAC)	Multi-Family	0.18	0.01	0.00	Cooling
119	Return Duct Modification (CAC early	Multi-Family	0.23	0.98	0.00	Cooling
119	replacement) Crawlspace insulation (CAC early replacement)	Multi-Family	0.14	0.66	0.00	Cooling
119	Cool Roof (CAC early replacement)	Multi-Family	4.44	0.59	0.00	Cooling
119	Whole House Fans (CAC early replacement)	Multi-Family	6.88	0.44	0.00	Cooling
119	WINDOWS - Double-Glazed Clear to	Multi-Family	0.71	0.30	0.00	Cooling
119	Energy Star (CAC early replacement) Proper Sizing and Quality Install (CAC	Multi-Family	3.25	0.28	0.00	Cooling
119	early replacement) Duct Testing and Sealing (CAC early	Multi-Family	0.73	0.25	0.00	Cooling
119	replacement) Comprehensive Shell Air Sealing - Inf.	Multi-Family	1.08	0.24	0.00	Cooling
119	Reduction (CAC early replacement) Ceiling R-0 to R-38 Insulation (CAC	Multi-Family	1.89	0.22	0.00	Cooling
119	early replacement) Ceiling R-0 to R-49 Insulation (CAC	Multi-Family	0.03	0.02	0.00	Cooling
119	early replacement) Basement insulation R-13 (CAC early	, Multi-Family	0.23	0.16	0.00	Cooling
119	replacement) Ceiling Fans (CAC early replacement)	Multi-Family	0.53	0.13	0.00	Cooling
119	Ceiling R-11 to R-38 Insulaton (CAC	Multi-Family	0.30	0.09	0.00	Cooling
119	early replacement) WINDOWS - Default With Sunscreen	Multi-Family	0.94	0.08	0.00	Cooling
119	(CAC early replacement) Wall Blow-in R-0 to R-13 Insulation	Multi-Family	0.17	0.07	0.00	Cooling
119	(CAC early replacement) Ceiling R-11 to R-49 Insulation (CAC	Multi-Family	0.01	0.02	0.00	Cooling
119	early replacement) Window Film (CAC early replacement)	Multi-Family	0.85	0.05	0.00	Cooling
119	Ceiling R-19 to R-38 Insulation (CAC	Multi-Family	0.03	0.05	0.00	Cooling
119	early replacement) Ceiling R-19 to R-49 Insulation (CAC	Multi-Family	0.00	0.02	0.00	Cooling
119	early replacement) 14 SEER (12.15 EER) Split-System Air	, Multi-Family	0.90	0.03	0.00	Cooling
119	Conditioner w/ Quality Install - Early Floor R-0 to R-19 Insulation-Batts (CAC	Multi-Family	0.09	0.03	0.00	Cooling
119	early replacement) AC Filter Changes (CAC early	Multi-Family	0.05	0.02	0.00	Cooling
119	replacement) AC Maintenance and/or tune-up (CAC	Multi-Family	0.05	0.02	0.00	Cooling
119	early replacement) Proper Refrigerant Charging and Air	Multi-Family	13.59	0.83	0.00	Cooling
119	Flow (HP cooling) Programmable Thermostat (HP cooling)	Multi-Family	3.48	0.58	0.00	Cooling
119	Crawlspace insulation (HP cooling)	Multi-Family	0.60	0.46	0.00	Cooling
119	Cool Roof (HP cooling)	Multi-Family	19.19	0.40	0.00	Cooling
119	Cool Roof (Tir Coolling)	inului-i aililiy	19.17	0.41	0.00	Cooling

Name	VA Resi	dential: All Existing Measures Ranl	ced by Econo	mic Potentia	ıl (GWh)		
Duct Testing and Sealing (HP cooling) Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling) Colling Reduction (HP cooling) Celling R-10 to R-38 Insulation (HP cooling) Celling R-10 to R-49 Insulation (HP cooling) Multi-Family 0.542 0.19 0.00 Cooling Multi-Family 0.11 0.14 0.00 Cooling Multi-Family 0.11 0.14 0.00 Cooling Multi-Family 0.12 0.00 Cooling Multi-Family 0.12 0.00 Cooling Multi-Family 0.12 0.00 Cooling Multi-Family 0.12 0.00 Cooling Multi-Family 0.13 0.10 0.00 Cooling Multi-Family 0.13 0.10 0.00 Cooling Multi-Family 0.13 0.03 0.00 Cooling Multi-Family 0.15 0.04 0.00 Cooling Multi-Family 0.15 0.00 Cooling Cooling Multi-Family 0.26 0.01 0.00 Cooling Multi-Family 0.27 0.01 0.00 Cooling Multi-Family 0.28 0.30 0.30 0.00 Cooling Cooling Cooling Early Replacement) Multi-Family 0.48 0.00 Cooling C	Rank	Measure Name	_				End Use
Comprehensive Shell Air Sealing - Inf. Reduction (HP coolino) Ceiling R-0 to R-38 Insulation (HP coolino) Ceiling R-0 to R-38 Insulation (HP coolino) Proper Sizing and Quality Install (HP coolino) Multi-Family 0.26 0.03 0.00 Cooling Multi-Family 0.26 0.00 Cooling Multi-Family 0.27 0.00 Cooling Multi-Family 0.28 0.00 Cooling Multi-Family 0.28 0.00 Cooling Multi-Family 0.28 0.00 Cooling Multi-Family 0.29 0.00 Cooling Multi-Family 0.29 0.00 Cooling Multi-Family 0.20 0.00 Cooling Coolin	119	Whole House Fans (HP cooling)	Multi-Family	29.74	0.30	0.00	Cooling
Reduction (HP cooling)	119	Duct Testing and Sealing (HP cooling)	Multi-Family	3.65	0.20	0.00	Cooling
Ceiling R-0 to R-38 Insulation (HP cooling and Quality Install (HP cooling and Quality Install (HP cooling and Quality Install (HP cooling R-0 to R-19 Insulation (HP cooling R-0 to R	119		Multi-Family	5.42	0.19	0.00	Cooling
119	119	Ceiling R-0 to R-38 Insulation (HP	Multi-Family	9.59	0.18	0.00	Cooling
Celling R-10 to R-49 Insulation (HP cooling) Multi-Family 0.26 0.03 0.00 Cooling	119	Proper Sizing and Quality Install (HP	Multi-Family	10.11	0.14	0.00	Cooling
Basement insulation R-13 (HP cooling) Wulti-Family 1.03 0.12 0.00 Cooling WINDOWS - Double-Glazed Clear to Eneray Star (HP coolino) Ceiling Fans (HP coolino) Multi-Family 2.31 0.10 0.00 Cooling Multi-Family Ceiling R-11 to R-38 Insulation (HP coolino) Multi-Family 1.35 0.06 0.00 Cooling Ceiling R-11 to R-38 Insulation (HP coolino) Multi-Family 0.13 0.03 0.00 Cooling Ceiling R-19 to R-38 Insulation (HP coolino) Multi-Family 0.15 0.04 0.00 Cooling Ceiling R-19 to R-38 Insulation (HP coolino) Multi-Family 0.15 0.04 0.00 Cooling Multi-Family 0.70 0.01 0.00 Cooling Multi-Family 0.70 0.70 Cooling Cooling Multi-Family 0.70 0.70 Cooling	119	Ceiling R-0 to R-49 Insulation (HP	Multi-Family	0.26	0.03	0.00	Cooling
Eneray Star (HP cooling)	119		Multi-Family	1.03	0.12	0.00	Cooling
Ceiling Fans (HP cooling)	119		Multi-Family	2.31	0.10	0.00	Cooling
Cooling Cool	119		Multi-Family	2.36	0.10	0.00	Cooling
Celling R-11 to R-49 Insulation (HP cooling Early Replacement) Cooling	119	` `	Multi-Family	1.35	0.06	0.00	Cooling
Floor R-O to R-19 Insulation-Batts (HP cooling Ceiling R-19 to R-38 Insulation (HP cooling Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Multi-Family cooling Ceiling R-19 to R-39 Insulation (HP cooling Early Replacement) Multi-Family cooling cooli	119	Ceiling R-11 to R-49 Insulation (HP	Multi-Family	0.13	0.03	0.00	Cooling
Celling R-19 to R-38 Insulation (HP cooling R-19 to R-49 Insulation (HP cooling R-19 to R-13 Insulation (HP cooling R-19 to R-13 Insulation (HP cooling R-19 to R-19 Insulat	119	Floor R-0 to R-19 Insulation-Batts (HP	Multi-Family	0.90	0.05	0.00	Cooling
Ceiling R-19 to R-49 Insulation (HP cooling 200ling) Wall Blow-in R-0 to R-13 Insulation (HP cooling) Wall Blow-in R-0 to R-13 Insulation (HP cooling) Multi-Family 0.70 0.01 0.00 Cooling	119	Ceiling R-19 to R-38 Insulation (HP	Multi-Family	0.15	0.04	0.00	Cooling
119 Wall Blow-in R-0 to R-13 Insulation (HP cooling Cooling) 119 Heat Pump Filter Replacement 119 Heat pump tune up 119 Heat pump tune up 119 Heat pump tune up 119 Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement) 119 Replacement Replacement 119 Replacement Replacement Replacement 119 Replacement Replacement Replacement Replacement 119 Replacement Re	119	Ceiling R-19 to R-49 Insulation (HP	Multi-Family	0.03	0.03	0.00	Cooling
Heat Pump Filter Replacement Multi-Family 0.26 0.01 0.00 Cooling	119	Wall Blow-in R-0 to R-13 Insulation (HP	Multi-Family	0.70	0.01	0.00	Cooling
Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement)	119		Multi-Family	0.26	0.01	0.00	Cooling
Flow (HP cooling Early Replacement) Crawlspace insulation (HP cooling Early Replacement) Replacement) Programmable Thermostat (HP cooling Early Replacement) Multi-Family 0.63 0.44 0.00 Cooling	119	Heat pump tune up	Multi-Family	0.27	0.01	0.00	Cooling
119	119		Multi-Family	2.46	0.85	0.00	Cooling
Programmable Thermostat (HP cooling	119	Crawlspace insulation (HP cooling Early	Multi-Family	0.11	0.48	0.00	Cooling
119	119	Programmable Thermostat (HP cooling	Multi-Family	0.63	0.44	0.00	Cooling
Whole House Fans (HP cooling early replacement) Duct Testing and Sealing (HP cooling Early Replacement) Duct Testing and Sealing (HP cooling Early Replacement) Multi-Family 0.66 0.20 0.00 Cooling	119	Cool Roof (HP cooling Early	Multi-Family	3.47	0.42	0.00	Cooling
Duct Testing and Sealing (HP cooling Early Replacement)	119	Whole House Fans (HP cooling early	Multi-Family	5.37	0.31	0.00	Cooling
Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement) Proper Sizing and Quality Install (HP cooling Early Replacement) Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) Early Replacement) Basement insulation R-13 (HP cooling Early Replacement) WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Floor R-0 to R-19 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-39 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-39 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-39 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement)	119	Duct Testing and Sealing (HP cooling	Multi-Family	0.66	0.20	0.00	Cooling
Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement) Proper Sizing and Quality Install (HP cooling Early Replacement) Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) Basement insulation R-13 (HP cooling Early Replacement) WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Ceiling Fans (HP cooling early replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-10 to R-19 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.03 0.04 0.00 Cooling Cooling Early Replacement)	119	Comprehensive Shell Air Sealing - Inf.	Multi-Family	0.98	0.20	0.00	Cooling
Proper Sizing and Quality Install (HP cooling Early Replacement) Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) Basement insulation R-13 (HP cooling Early Replacement) Basement insulation R-13 (HP cooling Early Replacement) WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Ceiling Fans (HP cooling Early Ceiling Fans (HP cooling Early Ceiling Fans (HP cooling Early Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.03 0.04 0.00 Cooling Cooling Cooling Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.03 0.04 0.00 Cooling Co	119	Ceiling R-0 to R-38 Insulation (HP	Multi-Family	1.73	0.18	0.00	Cooling
Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement) Basement insulation R-13 (HP cooling Early Replacement) WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Ceiling Fans (HP cooling early replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-10 to R-19 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.03 0.04 0.00 Cooling Cooli	119	Proper Sizing and Quality Install (HP	Multi-Family	1.83	0.14	0.00	Cooling
Basement insulation R-13 (HP cooling Early Replacement) WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Ceiling Fans (HP cooling early replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Floor R-0 to R-19 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-10 to R-19 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.03 0.04 0.00 Cooling Cooling Cooling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.03 0.00 Cooling Cooling Cooling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.03 0.00 Cooling Cooling Cooling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.03 0.00 Cooling Cooling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.03 0.00 Cooling Ceoling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.03 0.00 Cooling Ceoling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.01 0.03 0.00 Cooling Ceoling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.01 0.03 0.00 Cooling Ceoling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.01 0.03 0.00 Ceoling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.01 0.03 0.00 Ceoling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.01 0.00 Ceoling Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.01 0.00 Ceoling Ceiling R-19 to R-38 Insulation (HP Multi-Family 0.01 0.01 0.00 Ceoling Ceiling R-19 to R-38 Insulation (HP Multi-Family 0.01 0.01 0.00 Ceoling Ceiling R-19 to R-38 Insulation (HP Multi-Family 0.01 0.01 0.00 Ceoling Ceiling R-19 to R-38 Insulation (HP Multi-Family 0.01 0.01 0.00 Ceoling Ceiling R-19 to R-38 Insulation (HP Multi-Family 0.01 0.01 0.00 Ceoling Ceiling R-19 to R-38 Insulation (HP Multi-Family 0	119	Ceiling R-0 to R-49 Insulation (HP	Multi-Family	0.05	0.03	0.00	Cooling
WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early Ceiling Fans (HP cooling early replacement) Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP Ceiling R-19 to R-49 Insulation (HP Ceiling R-19 to R-49 Insulation (HP Multi-Family Ceiling R-19 to R-49 Insulation (HP	119	Basement insulation R-13 (HP cooling	Multi-Family	0.19	0.12	0.00	Cooling
Ceiling Fans (HP cooling early replacement)	119	WINDOWS - Double-Glazed Clear to	Multi-Family	0.42	0.10	0.00	Cooling
119 Ceiling R-11 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Multi-Family Cooling Cooling R-19 to R-49 Insulation (HP Multi-Family Cooling R-19 to R-38	119	Ceiling Fans (HP cooling early	Multi-Family	0.43	0.10	0.00	Cooling
119 Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement) Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Ceiling R-19 to R-38 Insulation (HP Ceiling R-19 to R-38 Insulation (HP Ceiling R-19 to R-38 Insulation (HP Ceiling R-19 to R-49 Insulation (HP Ceil	119	Ceiling R-11 to R-38 Insulaton (HP	Multi-Family	0.24	0.06	0.00	Cooling
Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement) Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Multi-Family Ceilin	119	Ceiling R-11 to R-49 Insulation (HP	Multi-Family	0.02	0.03	0.00	Cooling
Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement) Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.03 0.04 0.00 Cooling	119	Floor R-0 to R-19 Insulation-Batts (HP	Multi-Family	0.16	0.05	0.00	Cooling
Ceiling R-19 to R-49 Insulation (HP Multi-Family 0.01 0.03 0.00 Cooling	119	Ceiling R-19 to R-38 Insulation (HP	Multi-Family	0.03	0.04	0.00	Cooling
	119	Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)	Multi-Family	0.01	0.03	0.00	Cooling

	dential: All Existing Measures Rank				-	
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
119	Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement)	Multi-Family	0.13	0.01	0.00	Cooling
119	Heat Pump Filter Replacement	Multi-Family	0.05	0.01	0.00	Cooling
119	Heat pump tune up	Multi-Family	0.05	0.01	0.00	Cooling
119	Cool Roof (RAC)	Multi-Family	1.46	0.79	0.00	Cooling
119	Whole House Fans (RAC)	Multi-Family	2.26	0.58	0.00	Cooling
119	Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	Multi-Family	0.51	0.46	0.00	Cooling
119	WINDOWS - Double-Glazed Clear to Energy Star (RAC)	Multi-Family	0.22	0.38	0.00	Cooling
119	HE Room Air Conditioner - CEE Tier 1 EER 11.3	Multi-Family	0.51	0.36	0.00	Cooling
119	Ceiling R-0 to R-38 Insulation (RAC)	Multi-Family	0.64	0.30	0.00	Cooling
119	Ceiling R-0 to R-49 Insulation (RAC)	Multi-Family	0.02	0.05	0.00	Cooling
119	Ceiling Fans (RAC)	Multi-Family	0.19	0.20	0.00	Cooling
119	Window Film (RAC)	Multi-Family	0.65	0.17	0.00	Cooling
119	Wall Blow-in R-0 to R-13 Insulation	Multi-Family	0.07	0.11	0.00	Cooling
119	(RAC) WINDOWS - Default With Sunscreen	Multi-Family	0.31	0.11	0.00	Cooling
119	(RAC) Ceiling R-11 to R-38 Insulaton (RAC)	Multi-Family	0.08	0.10	0.00	Cooling
119	Ceiling R-11 to R-49 Insulation (RAC)	Multi-Family	0.01	0.04	0.00	Cooling
119	Ceiling R-19 to R-38 Insulation (RAC)	Multi-Family	0.01	0.06	0.00	Cooling
119	Ceiling R-19 to R-49 Insulation (RAC)	Multi-Family	0.00	0.04	0.00	Cooling
119	Room AC Filter Replacement	Multi-Family	0.02	0.02	0.00	Cooling
119	EER 8.5 RAC Early Replacement, CEE	Multi-Family	0.15	0.08	0.00	Cooling
119	Tier 1 EER 11.3 (early replacement) 10% better than Energy Star	Multi-Family	0.49	0.49	0.00	Cooling
119	Dehumidifier ROB (35-45 pints/day) Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	Multi-Family	31.38	0.61	0.00	Space Heating
119	Crawlspace insulation (HP heating)	Multi-Family	1.08	0.47	0.00	Space Heating
119	Programmable Thermostat (HP heating)	Multi-Family	6.10	0.45	0.00	Space Heating
119	Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Multi-Family	13.74	0.30	0.00	Space Heating
119	Duct Testing and Sealing (HP heating)	Multi-Family	8.57	0.27	0.00	Space Heating
119	Ceiling R-0 to R-38 Insulation (HP heating)	Multi-Family	23.59	0.25	0.00	Space Heating
119	Ceiling R-0 to R-49 Insulation (HP heating)	Multi-Family	0.71	0.05	0.00	Space Heating
119	Basement insulation R-13 (HP heating)	Multi-Family	2.82	0.18	0.00	Space Heating
119	Heat Recovery Ventilators (HP heating)	Multi-Family	54.80	0.17	0.00	Space Heating
119	WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Multi-Family	4.78	0.12	0.00	Space Heating
119	Ceiling R-11 to R-38 Insulaton (HP heating)	Multi-Family	2.95	0.08	0.00	Space Heating
119	Ceiling R-11 to R-49 Insulation (HP heating)	Multi-Family	0.27	0.04	0.00	Space Heating
119	Floor R-0 to R-19 Insulation-Batts (HP heating)	Multi-Family	1.97	0.06	0.00	Space Heating
119	Ground Source Heat Pump with Desuperheater (HP heating)	Multi-Family	17.29	0.03	0.00	Space Heating

DNV·GL

VA Resi	dential: All Existing Measures Rank	ked by Econo	mic Potentia	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
119	Ceiling R-19 to R-38 Insulation (HP heating)	Multi-Family	0.30	0.04	0.00	Space Heating
119	Ceiling R-19 to R-49 Insulation (HP heating)	Multi-Family	0.06	0.03	0.00	Space Heating
119	Wall Blow-in R-0 to R-13 Insulation (HP heating)	Multi-Family	1.39	0.02	0.00	Space Heating
119	Heat Pump Filter Replacement	Multi-Family	0.51	0.01	0.00	Space Heating
119	Heat pump tune up	Multi-Family	0.53	0.01	0.00	Space Heating
119	Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early replacement)	Multi-Family	7.61	0.84	0.00	Space Heating
119	Crawlspace insulation (HP heating early replacement)	Multi-Family	0.26	0.64	0.00	Space Heating
119	Programmable Thermostat (HP heating early replacement)	Multi-Family	1.48	0.62	0.00	Space Heating
119	Comprehensive Shell Air Sealing - Inf. Reduction (HP heating early	Multi-Family	3.33	0.41	0.00	Space Heating
119	Duct Testing and Sealing (HP heating early replacement)	Multi-Family	2.08	0.37	0.00	Space Heating
119	Ceiling R-0 to R-38 Insulation (HP heating early replacement)	Multi-Family	5.72	0.34	0.00	Space Heating
119	Ceiling R-0 to R-49 Insulation (HP	Multi-Family	0.17	0.07	0.00	Space Heating
119	heating early replacement) Basement insulation R-13 (HP heating	Multi-Family	0.69	0.25	0.00	Space Heating
119	early replacement) Heat Recovery Ventilators (HP heating	Multi-Family	13.29	0.23	0.00	Space Heating
119	early replacement) WINDOWS - Double-Glazed Clear to	Multi-Family	1.16	0.16	0.00	Space Heating
119	Energy Star (HP heating early Ceiling R-11 to R-38 Insulaton (HP	Multi-Family	0.72	0.11	0.00	Space Heating
119	heating early replacement) Ceiling R-11 to R-49 Insulation (HP	Multi-Family	0.07	0.05	0.00	Space Heating
119	heating early replacement) Floor R-0 to R-19 Insulation-Batts (HP	Multi-Family	0.48	0.08	0.00	Space Heating
119	heating early replacement) Ground Source Heat Pump with	Multi-Family	4.19	0.04	0.00	Space Heating
119	Desuperheater (HP heating early Ceiling R-19 to R-38 Insulation (HP	Multi-Family	0.07	0.05	0.00	Space Heating
119	heating early replacement) Ceiling R-19 to R-49 Insulation (HP	Multi-Family	0.02	0.04	0.00	Space Heating
119	heating early replacement) Wall Blow-in R-0 to R-13 Insulation (HP	Multi-Family	0.34	0.02	0.00	Space Heating
119	heating early replacement) Heat Pump Filter Replacement (heating)	Multi-Family	0.12	0.02	0.00	Space Heating
119	Heat pump tune up (heating)	Multi-Family	0.13	0.01	0.00	Space Heating
119	Programmable Thermostat (resistance heating)	Multi-Family	5.49	0.87	0.00	Space Heating
119	Crawlspace insulation (resistance	Multi-Family	1.08	0.75	0.00	Space Heating
119	heating) Comprehensive Shell Air Sealing - Inf.	Multi-Family	12.33	0.43	0.00	Space Heating
119	Reduction (resistance heating) Ceiling R-0 to R-38 Insulation	Multi-Family	23.59	0.40	0.00	Space Heating
119	(resistance heating) Ceiling R-0 to R-49 Insulation	Multi-Family	0.56	0.06	0.00	Space Heating
119	(resistance heating) Basement insulation R-13 (resistance	Multi-Family	3.98	0.27	0.00	Space Heating
119	heating) WINDOWS - Double-Glazed Clear to	Multi-Family	6.35	0.25	0.00	Space Heating
119	Energy Star (resistance heating) Heat Recovery Ventilators (resistance	, Multi-Family	48.63	0.24	0.00	Space Heating
119	heating) Ceiling R-11 to R-38 Insulaton	, Multi-Family	2.91	0.13	0.00	Space Heating
119	(resistance heating) Floor R-0 to R-19 Insulation-Batts	, Multi-Family	2.53	0.12	0.00	Space Heating
119	(resistance heating) Ceiling R-11 to R-49 Insulation	Multi-Family	0.21	0.04	0.00	Space Heating
	(resistance heating)	. ,				

VA Resid	dential: All Existing Measures Rank	ced by Econo	mic Potentia			
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
119	Ground Source Heat Pump with Desuperheater (resistance heating)	Multi-Family	-0.18	0.00	0.00	Space Heating
119	Ceiling R-19 to R-38 Insulation (resistance heating)	Multi-Family	0.34	0.07	0.00	Space Heating
119	Ceiling R-19 to R-49 Insulation (resistance heating)	Multi-Family	0.05	0.04	0.00	Space Heating
119	Wall Blow-in R-0 to R-13 Insulation (resistance heating)	Multi-Family	1.93	0.04	0.00	Space Heating
119	LEDs (base CFL 0.5 hrs/day) 2020	Multi-Family	1.07	0.29	0.00	Lighting
119	Refrigerator - Early Replacement (Energy Star)	Multi-Family	15.67	0.42	0.00	Refrigeration
119	DHW Tank Wrap	Multi-Family	38.84	0.87	0.00	Water Heating
119	Heat Pump Water Heater - Energy Star	Multi-Family	89.91	0.84	0.00	Water Heating
119	Solar Domestic Water Heating	Multi-Family	88.00	0.36	0.00	Water Heating
119	Energy Star CW CEE Tier 2 (MEF=2.0)	Multi-Family	2.01	0.03	0.00	Water Heating
119	Energy Star Dishwasher (EF=0.72)	Multi-Family	1.03	0.02	0.00	Water Heating
119	Heat Pump Water Heater - Energy Star - Early Replacement	Multi-Family	19.32	0.83	0.00	Water Heating
119	Energy Star CW CEE Tier 2 (MEF=2.0)	Multi-Family	3.92	0.06	0.00	Clothes Washer
119	Heat Pump Dryer	Multi-Family	105.57	0.12	0.00	Clothes Dryer
119	Energy Star Dishwasher (EF=0.72)	Multi-Family	2.15	0.04	0.00	Dishwashers
119	Plug Load Controls - Smart Power Strip (base plasma TV)	Multi-Family	0.23	0.02	0.00	Electronics
119	Plug Load Controls - Smart Power Strip (base LCD TV)	Multi-Family	1.37	0.02	0.00	Electronics
119	Plug Load Controls - Smart Power Strip (base CRT TV)	Multi-Family	1.73	0.08	0.00	Electronics
119	Plug Load Controls - Smart Power Strip (base DVD player)	Multi-Family	4.17	0.08	0.00	Electronics
119	Direct Feedback	Multi-Family	183.04	0.73	0.00	Whole Bldg (Retrofit)

	dential: All Existing Measures Rank					
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
1	Direct Feedback	Single Family	64.05	1.27	64.05	Whole Bldg (Retrofit)
2	ECM Furnace Fan (variable speed motor) - Cooling	Single Family	38.07	3.62	38.07	Furnace Fan
3	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Single Family	22.11	25.34	22.11	Lighting
4	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Single Family	20.53	1.27	20.53	Cooling
5	Indirect Feedback	Single Family	20.48	2.70	20.48	Whole Bldg (Retrofit)
6	2nd Refrigerator Recycling	Single Family	17.49	2.22	17.49	Refrigeration
7	Air Source Heat Pump (resistance heating)	Single Family	15.91	3.67	15.91	Space Heating
8	ROB 2L4'T8, 1EB	Single Family	14.64	1.69	14.64	Lighting
9	LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Single Family	14.63	51.29	14.63	Lighting
10	LEDs (base Halogen 2.5 hrs/day) 2020	Single Family	12.24	9.11	12.24	Lighting
11	Variable-Speed Pool Pump (<1 hp)	Single Family	9.74	1.90	9.74	Pool Pump
12	High Efficiency CD (EF=3.01 w/moisture sensor)	Single Family	9.33	1.44	9.33	Clothes Dryer
13	Refrigerator (Energy Star)	Single Family	7.53	1.81	7.53	Refrigeration
14	LEDs (base Halogen 6 hrs/day) 2020	Single Family	7.47	17.03	7.47	Lighting
15	Drain Water Heat Recovery (GFX)	Single Family	6.62	1.23	6.62	Water Heating
16	Pipe Wrap	Single Family	5.81	3.39	5.81	Water Heating
17	Low Flow Showerhead 1.5 Gal/Min	Single Family	5.42	2.13	5.42	Water Heating
18	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Single Family	5.31	5.04	5.31	Lighting
19	ECM Furnace Fan (variable speed motor) - Cooling	Multi-Family	5.04	3.62	5.04	Furnace Fan
20	Energy Star LCD TV	Single Family	3.77	14.37	3.77	Electronics
21	Air Source Heat Pump (resistance heating)	Multi-Family	3.77	5.18	3.77	Space Heating
22	Faucent Aerators	Single Family	3.59	1.05	3.59	Water Heating
23	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replacement)	Single Family	3.57	1.25	3.57	Cooling
24	Freezer - Early Replacement (Energy Star)	Single Family	3.56	1.41	3.56	Freezer
25	2nd Freezer Recycling	Single Family	3.51	3.48	3.51	Freezer
26	Programmable Thermostat (HP heating)	Single Family	3.33	1.16	3.33	Space Heating
27	Indirect Feedback	Multi-Family	3.05	1.61	3.05	Whole Bldg (Retrofit)
28	Freezer (Energy Star)	Single Family	2.77	1.38	2.77	Refrigeration
29	LEDs (base Halogen 0.5 hrs/day) 2020	Single Family	2.76	1.69	2.76	Lighting
30	Programmable Thermostat (HP cooling)	Single Family	2.50	1.32	2.50	Cooling
31	High Efficiency CD (EF=3.01 w/moisture sensor)	Multi-Family	2.30	2.10	2.30	Clothes Dryer
32	LEDs (base Halogen (Specialty) 2.5 hrs/day) 2020	Multi-Family	2.24	25.27	2.24	Lighting
33	Self Install Weatherization (HP heating)	Single Family	2.19	2.14	2.19	Space Heating
34	Refrigerator (Energy Star)	Multi-Family	2.17	1.49	2.17	Refrigeration
35	LEDs (base Halogen 2.5 hrs/day) 2020	Multi-Family	2.14	9.11	2.14	Lighting

NC Resi	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use			
36	Energy Star Desktop PC	Single Family	2.09	14.45	2.09	Miscellaneous			
37	LEDs (base CFL 2.5 hrs/day) 2020	Single Family	2.05	1.46	2.05	Lighting			
38	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling)	Multi-Family	1.87	1.12	1.87	Cooling			
39	Self Install Weatherization (HP cooling)	Single Family	1.65	2.37	1.65	Cooling			
40	LEDs (base Halogen (Specialty) 6 hrs/day) 2020	Multi-Family	1.54	51.33	1.54	Lighting			
41	Plug Load Controls - Smart Power Strip (base Desktop PC)	Multi-Family	1.42	1.08	1.42	Miscellaneous			
42	Duct Insulation (HP heating)	Single Family	1.37	7.97	1.37	Space Heating			
43	LEDs (base CFL 6 hrs/day) 2020	Single Family	1.33	2.94	1.33	Lighting			
44	Drain Water Heat Recovery (GFX)	Multi-Family	1.26	1.08	1.26	Water Heating			
45	Programmable Thermostat (resistance heating)	Single Family	1.25	1.33	1.25	Space Heating			
46	LEDs (base Halogen 6 hrs/day) 2020	Multi-Family	1.23	17.00	1.23	Lighting			
47	Low Flow Showerhead 1.5 Gal/Min	Multi-Family	1.19	2.82	1.19	Water Heating			
48	Pipe Wrap	Multi-Family	1.14	3.07	1.14	Water Heating			
49	Duct Insulation (HP cooling)	Single Family	1.03	9.46	1.03	Cooling			
50	Energy Star DVD Player	Single Family	0.88	3.59	0.88	Electronics			
51	Hot water turndown 10 degrees	Single Family	0.87	2.39	0.87	Water Heating			
52	Self Install Weatherization	Single Family	0.82	1.91	0.82	Space Heating			
53	Energy Star Plasma TV	Single Family	0.80	6.51	0.80	Electronics			
54	ROB 2L4'T8, 1EB	Multi-Family	0.78	1.69	0.78	Lighting			
55	Energy Star LCD TV	Multi-Family	0.77	11.98	0.77	Electronics			
56	Faucent Aerators	Multi-Family	0.72	1.59	0.72	Water Heating			
57	Self Install Weatherization (CAC)	Single Family	0.66	5.42	0.66	Cooling			
58	Programmable Thermostat (HP heating early replacement)	Single Family	0.65	1.28	0.65	Space Heating			
59	Door Weatherization (HP heating)	Multi-Family	0.65	1.00	0.65	Space Heating			
60	Hot water turndown 5 degrees	Single Family	0.64	2.38	0.64	Water Heating			
61	Door Weatherization (resistance heating)	Multi-Family	0.63	1.60	0.63	Space Heating			
62	Door Weatherization (HP cooling)	Multi-Family	0.56	1.34	0.56	Cooling			
63	LEDs (base Halogen (Specialty) 0.5 hrs/day) 2020	Multi-Family	0.56	5.07	0.56	Lighting			
64	LEDs (base Halogen 0.5 hrs/day) 2020	Multi-Family	0.52	1.84	0.52	Lighting			
65	Energy Star Desktop PC	Multi-Family	0.44	14.26	0.44	Miscellaneous			
66	Programmable Thermostat (HP cooling Early Replacement)	Single Family	0.44	1.30	0.44	Cooling			
67	Self Install Weatherization (HP heating early replacement)	Single Family	0.43	2.36	0.43	Space Heating			
68	Energy Star Laptop PC	Single Family	0.40	2.17	0.40	Miscellaneous			
69	Programmable Thermostat (CAC)	Single Family	0.39	1.59	0.39	Cooling			
70	Heat pump upgrade to (16+ SEER, 8.7+ HSPF) (HP cooling Early Replacement)	Multi-Family	0.34	1.15	0.34	Cooling			

RankMeasure NameBuilding TypeTechnical GWhMeasure TRC GWh71Self Install Weatherization (HP cooling Early Replacement)Single Family0.292.330.2972Return Duct Modification (CAC)Single Family0.281.260.2873Self Install Weatherization (HP heating) Pouct Insulation (HP heating early replacement)Multi-Family0.281.940.2874Duct Insulation (HP heating early replacement)Single Family0.278.820.2775Hot water turndown 10 degreesMulti-Family0.262.050.2676Self Install WeatherizationMulti-Family0.222.560.22	Cooling Cooling Space Heating Space Heating Water Heating Space Heating Lighting
Farly Replacement) Return Duct Modification (CAC) Single Family 0.29 2.33 0.29 72 Return Duct Modification (CAC) Single Family 0.28 1.26 0.28 73 Self Install Weatherization (HP heating) Duct Insulation (HP heating early replacement) Final Pamily Nulti-Family 0.28 Single Family 0.28 0.27 8.82 0.27 Multi-Family 0.26 2.05 0.26	Cooling Space Heating Space Heating Water Heating Space Heating
73 Self Install Weatherization (HP heating) Multi-Family 0.28 1.94 0.28 74 Duct Insulation (HP heating early replacement) Single Family 0.27 8.82 0.27 75 Hot water turndown 10 degrees Multi-Family 0.26 2.05 0.26	Space Heating Space Heating Water Heating Space Heating
Duct Insulation (HP heating early replacement) No.27 8.82 0.27 Hot water turndown 10 degrees Multi-Family 0.26 2.05 0.26	Space Heating Water Heating Space Heating
74 replacement) Single Family 0.27 8.82 0.27 75 Hot water turndown 10 degrees Multi-Family 0.26 2.05 0.26	Water Heating Space Heating
75 Hot water turndown 10 degrees Multi-Family 0.26 2.05 0.26	Space Heating
76 Self Install Weatherization Multi-Family 0.22 2.56 0.22	
	Lighting
77 LEDs (base CFL 2.5 hrs/day) 2020 Multi-Family 0.21 1.44 0.21	
78 Hot water turndown 15 degrees Single Family 0.20 2.38 0.20	Water Heating
79 Hot water turndown 5 degrees Multi-Family 0.19 2.07 0.19	Water Heating
Proper Refrigerant Charging and Air Multi-Family 0.19 1.13 0.19	Cooling
81 Energy Star DVD Player Multi-Family 0.19 3.06 0.19	Electronics
82 Self Install Weatherization (HP cooling) Multi-Family 0.19 2.15 0.19	Cooling
83 Duct Insulation (HP cooling Early Single Family 0.18 9.33 0.18	Cooling
84 LEDs (base CFL 6 hrs/day) 2020 Multi-Family 0.14 2.98 0.14	Lighting
85 Duct Insulation (HP heating) Multi-Family 0.14 3.36 0.14	Space Heating
86 Freezer - Early Replacement (Energy Multi-Family 0.14 1.29 0.14 Star)	Freezer
87 2nd Refrigerator Recycling Multi-Family 0.12 1.10 0.12	Refrigeration
88 Self Install Weatherization (CAC) Multi-Family 0.12 4.06 0.12	Cooling
89 Energy Star Laptop PC Multi-Family 0.12 2.14 0.12	Miscellaneous
90 Door Weatherization (HP heating early Multi-Family 0.11 1.01 0.11	Space Heating
91 Self Install Weatherization (CAC early replacement) Single Family 0.11 5.10 0.11	Cooling
Door Weatherization (CAC early multi-Family 0.11 1.59 0.11	Cooling
Door Weatherization (HP cooling Early Multi-Family 0.10 1.34 0.10	Cooling
94 Duct Insulation (HP cooling) Multi-Family 0.10 3.99 0.10	Cooling
95 Freezer (Energy Star) Multi-Family 0.09 1.10 0.09	Refrigeration
96 Self Install Weatherization (RAC) Single Family 0.09 1.84 0.09	Cooling
97 Hot water turndown 20 degrees Single Family 0.08 2.37 0.08	Water Heating
98 Duct Insulation (CAC early replacement) Single Family 0.07 7.81 0.07	Cooling
99 Self Install Weatherization (HP heating early replacement) Multi-Family 0.07 2.65 0.07	Space Heating
Programmable Thermostat (CAC early Single Family 0.07 1.49 0.07	Cooling
101 Energy Star Plasma TV Multi-Family 0.06 5.59 0.06	Electronics
102 Hot water turndown 15 degrees Multi-Family 0.06 2.05 0.06	Water Heating
Duct Insulation (CAC) Single Family 0.05 1.05 0.05	Cooling
Return Duct Modification (CAC early single Family 0.05 1.19 0.05	Cooling
Self Install Weatherization (CAC early replacement) Multi-Family 0.04 6.88 0.04	Cooling

Rank Measure Name Building Type Technical GWh Measure TRC GWh Economic GWh 106 Duct Insulation (HP heating early replacement) Multi-Family 0.03 4.58 0.03 107 Self Install Weatherization (HP cooling Early Replacement) Multi-Family 0.03 2.20 0.03 108 Door Weatherization (RAC) Multi-Family 0.03 1.94 0.03 109 Hot water turndown 20 degrees Multi-Family 0.02 2.04 0.02 110 Duct Insulation (CAC early replacement) Multi-Family 0.02 4.77 0.02 111 Duct Insulation (HP cooling Early Replacement) Multi-Family 0.02 4.08 0.02 112 Self Install Weatherization (RAC) Multi-Family 0.01 8.12 0.01 113 Proper Refrigerant Charging and Air Flow (CAC) Single Family 3.49 0.94 0.00 113 Door Weatherization (CAC) Single Family 0.69 0.69 0.00 113 14 SEER (12.15 EER) Split-System Air Conditioner (CAC) <td< th=""><th>Space Heating Cooling Cooling Water Heating Cooling Cooling</th></td<>	Space Heating Cooling Cooling Water Heating Cooling
106	Cooling Cooling Water Heating Cooling Cooling Cooling Cooling Cooling Cooling Cooling Cooling
Self Install Weatherization (HP cooling Early Replacement) Multi-Family 0.03 2.20 0.03 108 Door Weatherization (RAC) Multi-Family 0.03 1.94 0.03 1.94 0.03 1.94 0.03 1.94 0.03 1.94 0.03 1.94 0.03 1.94 0.03 1.94 0.03 1.94 0.03 1.94 0.02 1.09 1.09 1.002 1.002 1.002 1.002 1.002 1.002 1.002 1.002 1.002 1.003 1.002 1.002 1.003 1.002 1.003 1.002 1.003 1.004 1.003 1.004 1.004 1.005 1	Cooling Water Heating Cooling Cooling Cooling Cooling Cooling Cooling Cooling Cooling
108 Door Weatherization (RAC) Multi-Family 0.03 1.94 0.03 109 Hot water turndown 20 degrees Multi-Family 0.02 2.04 0.02 110 Duct Insulation (CAC early replacement) Multi-Family 0.02 4.77 0.02 111 Duct Insulation (HP cooling Early Replacement) Multi-Family 0.02 4.08 0.02 112 Self Install Weatherization (RAC) Multi-Family 0.01 8.12 0.01 113 Proper Refrigerant Charging and Air Flow (CAC) Single Family 3.49 0.94 0.00 113 Door Weatherization (CAC) Single Family 0.87 0.84 0.00 113 14 SEER (12.15 EER) Split-System Air Conditioner (CAC) Single Family 2.69 0.69 0.00 113 15 SEER (12.72 EER) Split-System Air Conditioner (CAC) Single Family 2.35 0.58 0.00	Water Heating Cooling Cooling Cooling Cooling Cooling Cooling Cooling Cooling
110Duct Insulation (CAC early replacement)Multi-Family0.024.770.02111Duct Insulation (HP cooling Early Replacement)Multi-Family0.024.080.02112Self Install Weatherization (RAC)Multi-Family0.018.120.01113Proper Refrigerant Charging and Air Flow (CAC)Single Family3.490.940.00113Door Weatherization (CAC)Single Family0.870.840.0011314 SEER (12.15 EER) Split-System Air Conditioner (CAC)Single Family2.690.690.0011315 SEER (12.72 EER) Split-System Air Conditioner (CAC)Single Family2.350.580.00	Cooling Cooling Cooling Cooling Cooling Cooling Cooling
111 Duct Insulation (HP cooling Early Replacement) Multi-Family 0.02 4.08 0.02 112 Self Install Weatherization (RAC) Multi-Family 0.01 8.12 0.01 113 Proper Refrigerant Charging and Air Flow (CAC) Single Family 3.49 0.94 0.00 113 Door Weatherization (CAC) Single Family 0.87 0.84 0.00 113 14 SEER (12.15 EER) Split-System Air Conditioner (CAC) Single Family 2.69 0.69 0.00 113 15 SEER (12.72 EER) Split-System Air Conditioner (CAC) Single Family 2.35 0.58 0.00	Cooling Cooling Cooling Cooling Cooling Cooling
Replacement	Cooling Cooling Cooling Cooling Cooling
112 Self Install Weatherization (RAC) Multi-Family 0.01 8.12 0.01 113 Proper Refrigerant Charging and Air Flow (CAC) Single Family 3.49 0.94 0.00 113 Door Weatherization (CAC) Single Family 0.87 0.84 0.00 113 14 SEER (12.15 EER) Split-System Air Conditioner (CAC) Single Family 2.69 0.69 0.00 113 15 SEER (12.72 EER) Split-System Air Conditioner (CAC) Single Family 2.35 0.58 0.00	Cooling Cooling Cooling Cooling
113 Flow (CAC) Single Family 3.49 0.94 0.00 113 Door Weatherization (CAC) Single Family 0.87 0.84 0.00 113 SEER (12.15 EER) Split-System Air Conditioner (CAC) Single Family 2.69 0.69 0.00 113 SEER (12.72 EER) Split-System Air Conditioner (CAC) Single Family 2.35 0.58 0.00 113 Conditioner (CAC) Single Family 2.35 0.58 0.00 114 SEER (12.15 EER) Split-System Air Conditioner (CAC) Single Family 2.35 0.58 0.00 115 SEER (12.72 EER) Split-System Air Conditioner (CAC) Single Family 0.87 0.84 0.00 116 Single Family 0.87 0.84 0.00 117 Single Family 0.87 0.84 0.00 118 Single Family 2.69 0.69 0.00 119 Single Family 0.87 0.84 0.00 110 Single Family 0.87 0.84 0.00 111 Single Family 0.87 0.84 0.00 112 Single Family 0.87 0.84 0.00 113 Single Family 0.87 0.84 0.00 114 SEER (12.15 EER) Split-System Air Conditioner (CAC) 0.69 0.00 115 SEER (12.72 EER) Split-System Air Conditioner (CAC) 0.00 117 Single Family 0.87 0.84 0.00 118 Single Family 0.87 0.84 0.00 119 Single Family 0.87 0.84 0.00 110 Single Family 0.87 0.84 0.00 111 Single Family 0.87 0.84 0.00 112 Single Family 0.87 0.84 0.00 113 Single Family 0.87 0.84 0.00 114 SEER (12.72 EER) Split-System Air Single Family 0.87 0.84 0.00 115 SEER (12.72 EER) Split-System Air Single Family 0.87 0.84 0.00 115 SEER (12.72 EER) Split-System Air Single Family 0.87 0.87 0.84 0.00 115 SEER (12.72 EER) Split-System Air Single Family 0.87 0.87 0.84 0.00 117 SINGLE FAMILY 0.87 0	Cooling Cooling Cooling
113 Door Weatherization (CAC) Single Family 0.87 0.84 0.00 113 14 SEER (12.15 EER) Split-System Air Conditioner (CAC) Single Family 2.69 0.69 0.00 113 15 SEER (12.72 EER) Split-System Air Conditioner (CAC) Single Family 2.35 0.58 0.00	Cooling Cooling
Conditioner (CAC) Single Family 2.69 0.69 0.00 113 Conditioner (CAC) Single Family 2.69 0.69 0.00 113 Conditioner (CAC) Single Family 2.35 0.58 0.00	Cooling
113 15 SEER (12.72 EER) Split-System Air Conditioner (CAC) Single Family 2.35 0.58 0.00	
	Cooling
113 17 SEER (12.28 EER) Split-System Air Conditioner (CAC) Single Family 3.95 0.45 0.00	
Proper Sizing and Quality Install (CAC) Single Family 3.43 0.39 0.00	Cooling
Crawlspace insulation (CAC) Single Family 0.30 0.33 0.00	Cooling
Ceiling R-0 to R-38 Insulation (CAC) Single Family 0.62 0.30 0.00	Cooling
113 WINDOWS - Default With Sunscreen (CAC) Single Family 3.03 0.24 0.00	Cooling
Ceiling R-0 to R-49 Insulation (CAC) Single Family 0.01 0.02 0.00	Cooling
Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Single Family 1.27 0.20 0.00	Cooling
113 Ceiling Fans (CAC) Single Family 0.25 0.18 0.00	Cooling
Ceiling R-11 to R-38 Insulaton (CAC) Single Family 0.69 0.11 0.00	Cooling
Ceiling R-11 to R-49 Insulation (CAC) Single Family 0.03 0.02 0.00	Cooling
Duct Testing and Sealing (CAC) Single Family 0.11 0.09 0.00	Cooling
WINDOWS - Double-Glazed Clear to Energy Star (CAC) Single Family 0.12 0.08 0.00	Cooling
113 Ceiling R-19 to R-38 Insulation (CAC) Single Family 0.08 0.06 0.00	Cooling
113 Cool Roof (CAC) Single Family 0.43 0.06 0.00	Cooling
Ceiling R-19 to R-49 Insulation (CAC) Single Family 0.01 0.02 0.00	Cooling
113 Window Film (CAC) Single Family 0.84 0.05 0.00	Cooling
Wall Blow-in R-0 to R-13 Insulation (CAC) Single Family 0.04 0.04 0.00	Cooling
113 Whole House Fans (CAC) Single Family 0.64 0.04 0.00	Cooling
113 AC Filter Changes (CAC) Single Family 0.10 0.02 0.00	Cooling
Basement insulation R-13 (CAC) Single Family 0.02 0.02 0.00	Cooling
AC Maintenance and/or tune-up (CAC) Single Family 0.10 0.02 0.00	Cooling
Floor R-0 to R-19 Insulation-Batts (CAC) Single Family 0.03 0.02 0.00	Cooling
Proper Refrigerant Charging and Air Single Family 0.67 0.88 0.00	Cooling
Flow (CAC early replacement) Door Weatherization (CAC early replacement) 113 Flow (CAC early replacement) Single Family Single Family 0.67 0.88 0.00 0.00 0.00	Cooling

NC Resi	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)							
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use		
113	Cool Roof (CAC early replacement)	Single Family	0.76	0.55	0.00	Cooling		
113	Whole House Fans (CAC early replacement)	Single Family	1.21	0.42	0.00	Cooling		
113	Proper Sizing and Quality Install (CAC early replacement)	Single Family	0.59	0.32	0.00	Cooling		
113	Crawlspace insulation (CAC early replacement)	Single Family	0.04	0.28	0.00	Cooling		
113	WINDOWS - Double-Glazed Clear to Energy Star (CAC early replacement)	Single Family	0.07	0.26	0.00	Cooling		
113	Basement insulation R-13 (CAC early replacement)	Single Family	0.04	0.24	0.00	Cooling		
113	Ceiling R-0 to R-38 Insulation (CAC early replacement)	Single Family	0.09	0.24	0.00	Cooling		
113	Ceiling R-0 to R-49 Insulation (CAC	Single Family	0.00	0.02	0.00	Cooling		
113	early replacement) Duct Testing and Sealing (CAC early	Single Family	0.04	0.19	0.00	Cooling		
113	replacement) Comprehensive Shell Air Sealing - Inf.	Single Family	0.20	0.18	0.00	Cooling		
113	Reduction (CAC early replacement) Ceiling Fans (CAC early replacement)	Single Family	0.03	0.13	0.00	Cooling		
113	Window Film (CAC early replacement)	Single Family	0.31	0.10	0.00	Cooling		
113	Ceiling R-11 to R-38 Insulaton (CAC	Single Family	0.10	0.09	0.00	Cooling		
113	early replacement) WINDOWS - Default With Sunscreen	Single Family	0.18	0.08	0.00	Cooling		
113	(CAC early replacement) Ceiling R-11 to R-49 Insulation (CAC	Single Family	0.00	0.02	0.00	Cooling		
113	early replacement) Ceiling R-19 to R-38 Insulation (CAC	Single Family	0.01	0.05	0.00	Cooling		
113	early replacement) Ceiling R-19 to R-49 Insulation (CAC	Single Family	0.00	0.02	0.00	Cooling		
113	early replacement) Wall Blow-in R-0 to R-13 Insulation	Single Family	0.01	0.04	0.00	Cooling		
113	(CAC early replacement) 14 SEER (12.15 EER) Split-System Air	Single Family	0.09	0.03	0.00	Cooling		
113	Conditioner w/ Quality Install - Early AC Filter Changes (CAC early	Single Family	0.01	0.02	0.00	Cooling		
113	replacement) AC Maintenance and/or tune-up (CAC	Single Family	0.02	0.02	0.00	Cooling		
113	early replacement) Floor R-0 to R-19 Insulation-Batts (CAC	Single Family	0.00	0.02	0.00	Cooling		
113	early replacement) Proper Refrigerant Charging and Air	Single Family	7.22	0.89	0.00	Cooling		
113	Flow (HP cooling) Door Weatherization (HP cooling)	Single Family	1.79	0.79	0.00	Cooling		
113	Cool Roof (HP cooling)	Single Family	9.57	0.79	0.00	Cooling		
	Proper Sizing and Quality Install (HP	Single Family	7.97	0.36	0.00	Cooling		
113 113	cooling) Whole House Fans (HP cooling)	Single Family	13.78	0.48	0.00	-		
	, , ,	,				Cooling		
113	Crawlspace insulation (HP cooling) Ceiling R-0 to R-38 Insulation (HP	Single Family	0.58	0.29	0.00	Cooling		
113	cooling)	Single Family	1.18	0.26	0.00	Cooling		
113	Basement insulation R-13 (HP cooling) Ceiling R-0 to R-49 Insulation (HP	Single Family	0.48	0.25	0.00	Cooling		
113	cooling)	Single Family	0.04	0.05	0.00	Cooling		
113	Duct Testing and Sealing (HP cooling) Comprehensive Shell Air Sealing - Inf.	Single Family	0.54	0.19	0.00	Cooling		
113	Reduction (HP cooling) WINDOWS - Double-Glazed Clear to	Single Family	2.62	0.19	0.00	Cooling		
113	Energy Star (HP cooling)	Single Family	0.81	0.16	0.00	Cooling		
113	Ceiling Fans (HP cooling)	Single Family	0.43	0.14	0.00	Cooling		

NC Residential: All Existing Measures Ranked by Economic Potential (GWh)							
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use	
113	Ceiling R-11 to R-38 Insulaton (HP cooling)	Single Family	1.44	0.11	0.00	Cooling	
113	Ceiling R-11 to R-49 Insulation (HP cooling)	Single Family	0.13	0.05	0.00	Cooling	
113	Floor R-0 to R-19 Insulation-Batts (HP cooling)	Single Family	0.22	0.07	0.00	Cooling	
113	Ceiling R-19 to R-38 Insulation (HP cooling)	Single Family	0.16	0.06	0.00	Cooling	
113	Ceiling R-19 to R-49 Insulation (HP cooling)	Single Family	0.03	0.05	0.00	Cooling	
113	Heat Pump Filter Replacement	Single Family	0.22	0.03	0.00	Cooling	
113	Wall Blow-in R-0 to R-13 Insulation (HP cooling)	Single Family	0.16	0.02	0.00	Cooling	
113	Heat pump tune up	Single Family	0.23	0.02	0.00	Cooling	
113	Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement)	Single Family	1.26	0.87	0.00	Cooling	
113	Door Weatherization (HP cooling Early Replacement)	Single Family	0.36	0.90	0.00	Cooling	
113	Cool Roof (HP cooling Early Replacement)	Single Family	1.66	0.55	0.00	Cooling	
113	Proper Sizing and Quality Install (HP cooling Early Replacement)	Single Family	1.38	0.48	0.00	Cooling	
113	Whole House Fans (HP cooling early replacement)	Single Family	2.39	0.38	0.00	Cooling	
113	Crawlspace insulation (HP cooling Early Replacement)	Single Family	0.10	0.28	0.00	Cooling	
113	Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	Single Family	0.20	0.25	0.00	Cooling	
113	Basement insulation R-13 (HP cooling Early Replacement)	Single Family	0.08	0.25	0.00	Cooling	
113	Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement)	Single Family	0.01	0.05	0.00	Cooling	
113	Duct Testing and Sealing (HP cooling Early Replacement)	Single Family	0.09	0.19	0.00	Cooling	
113	Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early	Single Family	0.45	0.18	0.00	Cooling	
113	WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early	Single Family	0.14	0.16	0.00	Cooling	
113	Ceiling Fans (HP cooling early replacement)	Single Family	0.07	0.13	0.00	Cooling	
113	Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)	Single Family	0.25	0.10	0.00	Cooling	
113	Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement)	Single Family	0.02	0.05	0.00	Cooling	
113	Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement)	Single Family	0.04	0.07	0.00	Cooling	
113	Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)	Single Family	0.03	0.06	0.00	Cooling	
113	Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)	Single Family	0.01	0.05	0.00	Cooling	
113	Heat Pump Filter Replacement	Single Family	0.04	0.03	0.00	Cooling	
113	Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement)	Single Family	0.03	0.02	0.00	Cooling	
113	Heat pump tune up	Single Family	0.04	0.02	0.00	Cooling	
113	Door Weatherization (RAC)	Single Family	0.13	0.31	0.00	Cooling	
113	Cool Roof (RAC)	Single Family	0.69	0.22	0.00	Cooling	
113	HE Room Air Conditioner - CEE Tier 1 EER 11.3	Single Family	0.33	0.19	0.00	Cooling	
113	Window Film (RAC)	Single Family	1.17	0.17	0.00	Cooling	
113	Whole House Fans (RAC)	Single Family	0.82	0.13	0.00	Cooling	
113	WINDOWS - Double-Glazed Clear to Energy Star (RAC)	Single Family	0.05	0.09	0.00	Cooling	

DNV·GL

NC Resid	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)							
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use		
113	Ceiling R-0 to R-38 Insulation (RAC)	Single Family	0.07	0.08	0.00	Cooling		
113	Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	Single Family	0.19	0.07	0.00	Cooling		
113	Ceiling R-0 to R-49 Insulation (RAC)	Single Family	0.00	0.01	0.00	Cooling		
113	Ceiling Fans (RAC)	Single Family	0.03	0.05	0.00	Cooling		
113	Wall Blow-in R-0 to R-13 Insulation (RAC)	Single Family	0.01	0.03	0.00	Cooling		
113	Ceiling R-11 to R-38 Insulaton (RAC)	Single Family	0.08	0.03	0.00	Cooling		
113	WINDOWS - Default With Sunscreen (RAC)	Single Family	0.15	0.03	0.00	Cooling		
113	Ceiling R-11 to R-49 Insulation (RAC)	Single Family	0.01	0.01	0.00	Cooling		
113	Ceiling R-19 to R-38 Insulation (RAC)	Single Family	0.01	0.02	0.00	Cooling		
113	Ceiling R-19 to R-49 Insulation (RAC)	Single Family	0.00	0.01	0.00	Cooling		
113	Room AC Filter Replacement	Single Family	0.01	0.01	0.00	Cooling		
113	EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early replacement)	Single Family	0.27	0.11	0.00	Cooling		
113	10% better than Energy Star Dehumidifier ROB (35-45 pints/day)	Single Family	0.23	0.50	0.00	Cooling		
113	Door Weatherization (HP heating)	Single Family	1.88	0.60	0.00	Space Heating		
113	Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	Single Family	14.65	0.63	0.00	Space Heating		
113	Heat Recovery Ventilators (HP heating)	Single Family	31.32	0.44	0.00	Space Heating		
113	Crawlspace insulation (HP heating)	Single Family	0.47	0.34	0.00	Space Heating		
113	Ceiling R-0 to R-38 Insulation (HP heating)	Single Family	2.22	0.31	0.00	Space Heating		
113	Basement insulation R-13 (HP heating)	Single Family	0.39	0.30	0.00	Space Heating		
113	Ceiling R-0 to R-49 Insulation (HP heating)	Single Family	0.07	0.06	0.00	Space Heating		
113	Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Single Family	5.00	0.24	0.00	Space Heating		
113	Duct Testing and Sealing (HP heating)	Single Family	0.98	0.22	0.00	Space Heating		
113	WINDOWS - Double-Glazed Clear to Energy Star (HP heating) Ceiling R-11 to R-38 Insulaton (HP	Single Family	1.49	0.18	0.00	Space Heating		
113	heating)	Single Family	2.74	0.13	0.00	Space Heating		
113	Ceiling R-11 to R-49 Insulation (HP heating)	Single Family	0.25	0.06	0.00	Space Heating		
113	Floor R-0 to R-19 Insulation-Batts (HP heating)	Single Family	0.19	0.09	0.00	Space Heating		
113	Ceiling R-19 to R-38 Insulation (HP heating)	Single Family	0.30	0.07	0.00	Space Heating		
113	Ground Source Heat Pump with Desuperheater (HP heating)	Single Family	8.75	0.03	0.00	Space Heating		
113	Ceiling R-19 to R-49 Insulation (HP heating)	Single Family	0.06	0.05	0.00	Space Heating		
113	Heat Pump Filter Replacement	Single Family	0.38	0.04	0.00	Space Heating		
113	Wall Blow-in R-0 to R-13 Insulation (HP heating)	Single Family	0.28	0.03	0.00	Space Heating		
113	Heat pump tune up	Single Family	0.40	0.02	0.00	Space Heating		
113	Door Weatherization (HP heating early replacement)	Single Family	0.38	0.69	0.00	Space Heating		
113	Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating early replacement)	Single Family	2.86	0.70	0.00	Space Heating		
113	Heat Recovery Ventilators (HP heating early replacement)	Single Family	6.11	0.49	0.00	Space Heating		

DNV·GL

NC Resi	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)							
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use		
113	Crawlspace insulation (HP heating early replacement)	Single Family	0.52	0.38	0.00	Space Heating		
113	Ceiling R-0 to R-38 Insulation (HP heating early replacement)	Single Family	0.42	0.33	0.00	Space Heating		
113	Basement insulation R-13 (HP heating early replacement)	Single Family	0.43	0.33	0.00	Space Heating		
113	Ceiling R-0 to R-49 Insulation (HP heating early replacement)	Single Family	0.01	0.07	0.00	Space Heating		
113	Comprehensive Shell Air Sealing - Inf. Reduction (HP heating early	Single Family	0.94	0.26	0.00	Space Heating		
113	Duct Testing and Sealing (HP heating early replacement)	Single Family	0.18	0.24	0.00	Space Heating		
113	WINDOWS - Double-Glazed Clear to	Single Family	0.28	0.20	0.00	Space Heating		
113	Energy Star (HP heating early Ceiling R-11 to R-38 Insulaton (HP	Single Family	0.52	0.14	0.00	Space Heating		
113	heating early replacement) Ceiling R-11 to R-49 Insulation (HP	Single Family	0.05	0.06	0.00	Space Heating		
113	heating early replacement) Floor R-0 to R-19 Insulation-Batts (HP	Single Family	0.20	0.10	0.00	Space Heating		
113	heating early replacement) Ceiling R-19 to R-38 Insulation (HP	Single Family	0.06	0.07	0.00	Space Heating		
113	heating early replacement) Ground Source Heat Pump with	Single Family	1.63	0.03	0.00	Space Heating		
113	Desuperheater (HP heating early Ceiling R-19 to R-49 Insulation (HP	Single Family	0.01	0.05	0.00	Space Heating		
113	heating early replacement) Heat Pump Filter Replacement (heating)	Single Family	0.07	0.04	0.00	Space Heating		
113	Wall Blow-in R-0 to R-13 Insulation (HP	,						
	heating early replacement)	Single Family	0.05	0.03	0.00	Space Heating		
113	Heat pump tune up (heating) Door Weatherization (resistance	Single Family	0.07	0.03	0.00	Space Heating		
113	heating) Heat Recovery Ventilators (resistance	Single Family	1.21	0.92	0.00	Space Heating		
113	heating) Ceiling R-0 to R-38 Insulation	Single Family	12.81	0.43	0.00	Space Heating		
113	(resistance heating)	Single Family	0.98	0.33	0.00	Space Heating		
113	Crawlspace insulation (resistance heating)	Single Family	0.41	0.30	0.00	Space Heating		
113	Basement insulation R-13 (resistance heating)	Single Family	0.59	0.29	0.00	Space Heating		
113	Ceiling R-0 to R-49 Insulation (resistance heating)	Single Family	0.02	0.05	0.00	Space Heating		
113	Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) WINDOWS - Double-Glazed Clear to	Single Family	2.01	0.23	0.00	Space Heating		
113	WINDOWS - Double-Glazed Clear to Energy Star (resistance heating)	Single Family	0.69	0.20	0.00	Space Heating		
113	Ceiling R-11 to R-38 Insulaton (resistance heating)	Single Family	1.21	0.13	0.00	Space Heating		
113	Floor R-0 to R-19 Insulation-Batts (resistance heating)	Single Family	0.25	0.12	0.00	Space Heating		
113	Ceiling R-11 to R-49 Insulation (resistance heating)	Single Family	0.09	0.05	0.00	Space Heating		
113	Ceiling R-19 to R-38 Insulation (resistance heating)	Single Family	0.14	0.08	0.00	Space Heating		
113	Ceiling R-19 to R-49 Insulation	Single Family	0.02	0.05	0.00	Space Heating		
113	(resistance heating) Ground Source Heat Pump with Desuperheater (resistance heating)	Single Family	0.33	0.00	0.00	Space Heating		
113	Wall Blow-in R-0 to R-13 Insulation	Single Family	0.17	0.04	0.00	Space Heating		
113	(resistance heating) LEDs (base CFL 0.5 hrs/day) 2020	Single Family	0.51	0.30	0.00	Lighting		
113	Refrigerator - Early Replacement	Single Family	3.05	0.59	0.00	Refrigeration		
113	(Energy Star) DHW Tank Wrap	Single Family	9.10	0.96	0.00	Water Heating		
113	Heat Pump Water Heater - Energy Star	Single Family	23.02	0.85	0.00	Water Heating		
	2.1.2.3) Otal							

Rank Measure Name Suilding Technical GWh TRC G	NC Resi	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)							
Energy Star CW CEE Tier 2 (MEF=2.0) Single Family 0.19 0.01 0.00 Water Heating	Rank	Measure Name	_				End Use		
113 Energy Star Dishwasher (EF=0.72) Heat Pump Water Heater - Energy Star Early Replacement Single Family 4.76 0.86 0.00 Water Heating Single Family 4.76 0.86 0.00 Water Heating Single Family 4.76 0.86 0.00 Water Heating Single Family 0.81 0.05 0.00 Clothes Washer CEF=0.72) Single Family 0.81 0.05 0.00 Clothes Washer CEF=0.72 Single Family 0.81 0.05 0.00 Clothes Dryer Single Family 0.24 0.04 0.00 Dishwashers CEF=0.72 Single Family 0.24 0.04 0.00 Dishwashers CEF=0.72 Single Family 0.06 0.01 0.00 Electronics Controls - Smart Power Strip Chase plasma TV Power Strip Chase plasma TV Power Strip Chase Power Chase Power Strip Chase Power Strip Chase Power Strip Chase	113	Solar Domestic Water Heating	Single Family	62.64	0.39	0.00	Water Heating		
Heat Pump Water Heater - Energy Star Early Replacement	113	Energy Star CW CEE Tier 2 (MEF=2.0)	Single Family	0.19	0.01	0.00	Water Heating		
Energy Star CW CEE Tier 2 (MEF=2.0) Single Family 4.76 0.86 0.00 Clothes Washer	113	, ,	Single Family	0.15	0.01	0.00	Water Heating		
113	113	•	Single Family	4.76	0.86	0.00	Water Heating		
113 Energy Star Dishwasher (EF=0.72) Single Family 0.24 0.04 0.00 Dishwashers	113		Single Family	0.81	0.05	0.00	Clothes Washer		
113	113	Heat Pump Dryer	Single Family	20.73	0.09	0.00	Clothes Dryer		
Plug Load Controls - Smart Power Strip (base plasma TV) Single Family 0.06 0.01 0.00 Electronics Plug Load Controls - Smart Power Strip (base District of Controls - Smart Power Strip (base CRT TV) Single Family 0.15 0.01 0.00 Electronics Plug Load Controls - Smart Power Strip (base CRT TV) Single Family 0.31 0.04 0.00 Electronics Electronics Smart Power Strip (base CRT TV) Single Family 0.70 0.07 0.00 Electronics Electronics Smart Power Strip (base DVD plaver) Single Family 0.70 0.07 0.00 Electronics Electronics Smart Power Strip (base Desktoo PC) Single Family 0.70 0.07 0.00 Miscellaneous Electronics Electronics	113	Energy Star Dishwasher (EF=0.72)	Single Family	0.24	0.04	0.00	Dishwashers		
Chase plasma TV Single Family 0.06 0.01 0.00 Electronics	113	PV-Powered Pool Pumps	Single Family	3.58	0.07	0.00	Pool Pump		
Plug Load Controls - Smart Power Strip (base LCD TV) Single Family (Dase LCD TV) Plug Load Controls - Smart Power Strip (base DVD plaver) Single Family (Dase CRT TV) Plug Load Controls - Smart Power Strip (base DVD plaver) Single Family (Dase DVD plaver) Plug Load Controls - Smart Power Strip (base Desktoo PC) Plug Load Controls - Smart Power Strip (base Desktoo PC) Plug Load Controls - Smart Power Strip (base Desktoo PC) Plug Load Controls - Smart Power Strip (base Desktoo PC) Plug Load Controls - Smart Power Strip (base Desktoo PC) Multi-Family (Dase Desktoo PC) Proper Refrigerant Charging and Air Flow (CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant Charging and Air Flow (CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Multi-Family (Dase Desktoo PC) Proper Refrigerant CAC) Proper Refrigerant CAC) Proper Refrigerant CAC) Proper Refrigerant CAC) Pro	113		Single Family	0.06	0.01	0.00	Electronics		
Plug Load Controls - Smart Power Strip (base CRT TV)	113	Plug Load Controls - Smart Power Strip	Single Family	0.15	0.01	0.00	Electronics		
Plug Load Controls - Smart Power Strip (base DVD player)	113	Plug Load Controls - Smart Power Strip	Single Family	0.31	0.04	0.00	Electronics		
Plug Load Controls - Smart Power Strip (base Desktop PC)	113	Plug Load Controls - Smart Power Strip	Single Family	0.70	0.07	0.00	Electronics		
113	113	Plug Load Controls - Smart Power Strip	Single Family	4.39	0.65	0.00	Miscellaneous		
113	113		Multi-Family	0.37	0.97	0.00	Cooling		
Duct Insulation (CAC) Multi-Family 0.01 0.62 0.00 Cooling	113		Multi-Family	0.52	0.68	0.00	Cooling		
113	113		Multi-Family	0.01	0.62	0.00	Cooling		
113 Conditioner (CAC) Multi-Family 0.43 0.50 0.00 Cooling 113 Return Duct Modification (CAC) Multi-Family 0.04 0.45 0.00 Cooling 113 15 SEER (12.72 EER) Split-System Air Conditioner (CAC) Multi-Family 0.37 0.42 0.00 Cooling 113 Ceiling Fans (CAC) Multi-Family 0.31 0.35 0.00 Cooling 113 Crawlspace insulation (CAC) Multi-Family 0.02 0.33 0.00 Cooling 113 Crawlspace insulation (CAC) Multi-Family 0.58 0.30 0.00 Cooling 113 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 0.41 0.17 0.00 Cooling 113 Cooling Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 0.21 0.16 0.00 Cooling 113 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 0.10 0.15 0.00 Cooling 114 Duct Testing and Sealing (CAC) Multi-Family 0.41 0.13 0.00 Cooling 115 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.10 0.11 0.00 Cooling 116 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.26 0.08 0.00 Cooling 117 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.26 0.08 0.00 Cooling 118 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.11 0.05 0.00 Cooling 119 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 110 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.19 0.04 0.00 Cooling 111 Multi-Family 0.19 0.04 0.00 Cooling 112 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling	113	Programmable Thermostat (CAC)	Multi-Family	0.05	0.60	0.00	Cooling		
113 Return Duct Modification (CAC) Multi-Family 0.04 0.45 0.00 Cooling 113 15 SEER (12.72 EER) Split-System Air Conditioner (CAC) Multi-Family 0.37 0.42 0.00 Cooling 113 Ceiling Fans (CAC) Multi-Family 0.31 0.35 0.00 Cooling 113 Crawlspace insulation (CAC) Multi-Family 0.02 0.33 0.00 Cooling 113 T SEER (12.28 EER) Split-System Air Conditioner (CAC) Multi-Family 0.58 0.30 0.00 Cooling 113 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 0.41 0.17 0.00 Cooling 113 Cooling R-0 to R-38 Insulation (CAC) Multi-Family 0.21 0.16 0.00 Cooling 113 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 0.10 0.15 0.00 Cooling 113 Proper Sizing and Quality Install (CAC) Multi-Family 0.41 0.13 0.00 Cooling 114 Duct Testing and Sealing (CAC) Multi-Family 0.41 0.13 0.00 Cooling 115 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.00 0.01 0.00 Cooling 116 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.26 0.08 0.00 Cooling 117 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.11 0.05 0.00 Cooling 118 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.11 0.05 0.00 Cooling 110 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.19 0.04 0.00 Cooling 111 Multi-Family 0.19 0.04 0.00 Cooling 112 Cool Roof (CAC) Multi-Family 0.19 0.04 0.00 Cooling 113 Cool Roof (CAC) Multi-Family 0.19 0.04 0.00 Cooling 114 Cool Roof (CAC) Multi-Family 0.19 0.04 0.00 Cooling 115 Cool Roof (CAC) Multi-Family 0.19 0.04 0.00 Cooling 116 Cool Roof (CAC) Multi-Family 0.19 0.04 0.00 Cooling 117 Cool Roof (CAC) Multi-Family 0.19 0.04 0.00 Cooling 118 Cool Roof (CAC) Multi-Family 0.19 0.04 0.00 Coolin	113	, , , ,	Multi-Family	0.43	0.50	0.00	Cooling		
113 Conditioner (CAC) Multi-Family 0.37 0.42 0.00 Cooling 113 Ceiling Fans (CAC) Multi-Family 0.31 0.35 0.00 Cooling 113 Crawlspace insulation (CAC) Multi-Family 0.02 0.33 0.00 Cooling 113 Crawlspace insulation (CAC) Multi-Family 0.58 0.30 0.00 Cooling 113 Cooling R-0 to R-38 Insulation (CAC) Multi-Family 0.41 0.17 0.00 Cooling 113 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 0.21 0.16 0.00 Cooling 113 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 0.10 0.15 0.00 Cooling 113 Proper Sizing and Quality Install (CAC) Multi-Family 0.41 0.13 0.00 Cooling 114 Duct Testing and Sealing (CAC) Multi-Family 0.10 0.11 0.00 Cooling 115 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.26 0.08 0.00 Cooling 116 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.26 0.08 0.00 Cooling 117 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.11 0.05 0.00 Cooling 118 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 119 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.11 0.05 0.00 Cooling 110 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling 111 Cooling Cooling Cooling Cooling Cooling Cooling Cooling Cooling 111 Cooling Cooling Caccooling Cacco	113		Multi-Family	0.04	0.45	0.00	Cooling		
113 Ceiling Fans (CAC) Multi-Family 0.31 0.35 0.00 Cooling 113 Crawlspace insulation (CAC) Multi-Family 0.02 0.33 0.00 Cooling 113 Crawlspace insulation (CAC) Multi-Family 0.58 0.30 0.00 Cooling 113 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 0.41 0.17 0.00 Cooling 113 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 0.21 0.16 0.00 Cooling 113 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 0.10 0.15 0.00 Cooling 113 Proper Sizing and Quality Install (CAC) Multi-Family 0.41 0.13 0.00 Cooling 113 Duct Testing and Sealing (CAC) Multi-Family 0.10 0.11 0.00 Cooling 113 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 0.05 0.05 0.00 Cooling 113 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 114 Ceiling R-0 to R-13 Insulation Multi-Family 0.11 0.05 0.00 Cooling 115 Wall Blow-in R-0 to R-13 Insulation Multi-Family 0.01 0.04 0.00 Cooling 116 Cool Roof (CAC) Multi-Family 0.01 0.04 0.00 Cooling 117 Ceiling R-0 to R-13 Insulation Multi-Family 0.01 0.04 0.00 Cooling 118 Ceiling R-0 to R-13 Insulation Multi-Family 0.01 0.04 0.00 Cooling 119 Ceiling R-0 to R-13 Insulation Multi-Family 0.11 0.05 0.00 Cooling 110 Ceoling R-0 to R-13 Insulation Multi-Family 0.19 0.04 0.00 Cooling 111 Ceiling R-0 to R-13 Insulation Multi-Family 0.19 0.04 0.00 Cooling	113	, , , ,	Multi-Family	0.37	0.42	0.00	Cooling		
17 SEER (12.28 EER) Split-System Air Conditioner (CAC)	113		Multi-Family	0.31	0.35	0.00	Cooling		
Conditioner (CAC) Conditioner (CAC) Ceiling R-0 to R-38 Insulation (CAC) Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Energy Star (CAC) Multi-Family Ceiling R-0 to R-38 Insulation (CAC) Multi-Family Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family Colling Multi-Family Colling Multi-Family Colling Cooling Multi-Family Colling Cooling Multi-Family Colling R-0 to R-49 Insulation (CAC) Multi-Family Cooling Multi-Family Cooling Cool Roof (CAC) Multi-Family Cool Multi-Family Cool Cooling Multi-Family Cool Cooling Multi-Family Cool Cooling Multi-Family Cool Multi-Family Cool Cooling	113	Crawlspace insulation (CAC)	Multi-Family	0.02	0.33	0.00	Cooling		
113 Ceiling R-0 to R-38 Insulation (CAC) Multi-Family 0.41 0.17 0.00 Cooling 113 Comprehensive Shell Air Sealing - Inf. Reduction (CAC) Multi-Family 0.21 0.16 0.00 Cooling 113 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 0.10 0.15 0.00 Cooling 113 Proper Sizing and Quality Install (CAC) Multi-Family 0.41 0.13 0.00 Cooling 113 Duct Testing and Sealing (CAC) Multi-Family 0.10 0.11 0.00 Cooling 113 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.00 0.01 0.00 Cooling 113 WINDOWS - Default With Sunscreen (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 0.05 0.05 0.00 Cooling 114 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 115 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.03 0.04 0.00 Cooling 116 0.00 Cooling Cooling 117 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling 118 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling 119 Cooling Cooling Cooling Cooling 110 Cooling CAC) Multi-Family 0.19 0.04 0.00 Cooling 111 Cooling CACO CACO CACO COoling 112 Cooling CACO CACO	113		Multi-Family	0.58	0.30	0.00	Cooling		
113 Reduction (CAC) Multi-Family 0.21 0.16 0.00 Cooling 113 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 0.10 0.15 0.00 Cooling 113 Proper Sizing and Quality Install (CAC) Multi-Family 0.41 0.13 0.00 Cooling 113 Duct Testing and Sealing (CAC) Multi-Family 0.10 0.11 0.00 Cooling 113 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.00 0.01 0.00 Cooling 113 WINDOWS - Default With Sunscreen (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 0.05 0.05 0.00 Cooling 114 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 115 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.03 0.04 0.00 Cooling 116 117 118 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 117 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling 118 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling 119 Cooling Cooling Cooling Cooling 110 Cooling Cooling Cooling Cooling 111 Cooling Cooling Cooling Cooling Cooling 112 Cooling Cooling Cooling Cooling Cooling 113 Cooling C	113		Multi-Family	0.41	0.17	0.00	Cooling		
113 WINDOWS - Double-Glazed Clear to Energy Star (CAC) Multi-Family 0.10 0.15 0.00 Cooling 113 Proper Sizing and Quality Install (CAC) Multi-Family 0.41 0.13 0.00 Cooling 113 Duct Testing and Sealing (CAC) Multi-Family 0.10 0.11 0.00 Cooling 113 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.00 0.01 0.00 Cooling 113 WINDOWS - Default With Sunscreen (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.05 0.05 0.00 Cooling 113 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 113 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.03 0.04 0.00 Cooling 113 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling	113		Multi-Family	0.21	0.16	0.00	Cooling		
113 Proper Sizing and Quality Install (CAC) Multi-Family 0.41 0.13 0.00 Cooling 113 Duct Testing and Sealing (CAC) Multi-Family 0.10 0.11 0.00 Cooling 113 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.00 0.01 0.00 Cooling 113 WINDOWS - Default With Sunscreen (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.05 0.05 0.00 Cooling 113 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 113 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.03 0.04 0.00 Cooling 113 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling	113	WINDOWS - Double-Glazed Clear to	Multi-Family	0.10	0.15	0.00	Cooling		
113 Ceiling R-0 to R-49 Insulation (CAC) Multi-Family 0.00 0.01 0.00 Cooling 113 WINDOWS - Default With Sunscreen (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.05 0.05 0.00 Cooling 113 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 113 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.03 0.04 0.00 Cooling 113 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling	113		Multi-Family	0.41	0.13	0.00	Cooling		
113 WINDOWS - Default With Sunscreen (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 0.05 0.05 0.00 Cooling 113 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 113 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.03 0.04 0.00 Cooling 113 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling	113	Duct Testing and Sealing (CAC)	Multi-Family	0.10	0.11	0.00	Cooling		
113 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.26 0.08 0.00 Cooling 113 Ceiling R-11 to R-38 Insulation (CAC) Multi-Family 0.05 0.05 0.00 Cooling 113 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 113 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.03 0.04 0.00 Cooling 114 Multi-Family 0.19 0.04 0.00 Cooling 115 Cooling Cooling Cooling 116 Cac Cac	113	Ceiling R-0 to R-49 Insulation (CAC)	Multi-Family	0.00	0.01	0.00	Cooling		
113 Ceiling R-11 to R-38 Insulaton (CAC) Multi-Family 0.05 0.05 0.00 Cooling 113 Cool Roof (CAC) Multi-Family 0.11 0.05 0.00 Cooling 113 Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family 0.03 0.04 0.00 Cooling 113 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling	113		Multi-Family	0.26	0.08	0.00	Cooling		
Wall Blow-in R-0 to R-13 Insulation (CAC) Multi-Family	113		Multi-Family	0.05	0.05	0.00	Cooling		
113 (CAC) Multi-Family 0.03 0.04 0.00 Cooling 113 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling	113	Cool Roof (CAC)	Multi-Family	0.11	0.05	0.00	Cooling		
113 Window Film (CAC) Multi-Family 0.19 0.04 0.00 Cooling	113		Multi-Family	0.03	0.04	0.00	Cooling		
113 Whole House Fans (CAC) Multi-Family 0.18 0.04 0.00 Cooling	113		Multi-Family	0.19	0.04	0.00	Cooling		
	113		Multi-Family	0.18	0.04	0.00	Cooling		

NC Resi	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)							
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use		
113	Ceiling R-11 to R-49 Insulation (CAC)	Multi-Family	0.00	0.01	0.00	Cooling		
113	Ceiling R-19 to R-38 Insulation (CAC)	Multi-Family	0.01	0.03	0.00	Cooling		
113	Ceiling R-19 to R-49 Insulation (CAC)	Multi-Family	0.00	0.01	0.00	Cooling		
113	Floor R-0 to R-19 Insulation-Batts (CAC)	Multi-Family	0.02	0.02	0.00	Cooling		
113	Basement insulation R-13 (CAC)	Multi-Family	0.01	0.02	0.00	Cooling		
113	AC Filter Changes (CAC)	Multi-Family	0.01	0.01	0.00	Cooling		
113	AC Maintenance and/or tune-up (CAC)	Multi-Family	0.01	0.01	0.00	Cooling		
113	Programmable Thermostat (CAC early replacement)	Multi-Family	0.02	1.00	0.00	Cooling		
113	Return Duct Modification (CAC early replacement)	Multi-Family	0.01	0.79	0.00	Cooling		
113	Crawlspace insulation (CAC early replacement)	Multi-Family	0.01	0.66	0.00	Cooling		
113	Cool Roof (CAC early replacement)	Multi-Family	0.22	0.59	0.00	Cooling		
113	Whole House Fans (CAC early replacement)	Multi-Family	0.34	0.44	0.00	Cooling		
113	WINDOWS - Double-Glazed Clear to Energy Star (CAC early replacement)	Multi-Family	0.03	0.30	0.00	Cooling		
113	Ceiling R-0 to R-38 Insulation (CAC	Multi-Family	0.11	0.27	0.00	Cooling		
113	early replacement) Duct Testing and Sealing (CAC early replacement)	Multi-Family	0.04	0.24	0.00	Cooling		
113	Comprehensive Shell Air Sealing - Inf. Reduction (CAC early replacement)	Multi-Family	0.05	0.24	0.00	Cooling		
113	Proper Sizing and Quality Install (CAC early replacement)	Multi-Family	0.13	0.19	0.00	Cooling		
113	Ceiling Fans (CAC early replacement)	Multi-Family	0.03	0.17	0.00	Cooling		
113	Ceiling R-0 to R-49 Insulation (CAC early replacement)	Multi-Family	0.00	0.02	0.00	Cooling		
113	Basement insulation R-13 (CAC early replacement)	Multi-Family	0.01	0.16	0.00	Cooling		
113	Ceiling R-11 to R-38 Insulaton (CAC early replacement)	Multi-Family	0.01	0.09	0.00	Cooling		
113	WINDOWS - Default With Sunscreen (CAC early replacement)	Multi-Family	0.05	0.08	0.00	Cooling		
113	Wall Blow-in R-0 to R-13 Insulation	Multi-Family	0.01	0.07	0.00	Cooling		
113	(CAC early replacement) Ceiling R-11 to R-49 Insulation (CAC	Multi-Family	0.00	0.02	0.00	Cooling		
113	early replacement) Window Film (CAC early replacement)	Multi-Family	0.04	0.05	0.00	Cooling		
113	Ceiling R-19 to R-38 Insulation (CAC early replacement)	Multi-Family	0.00	0.05	0.00	Cooling		
113	Ceiling R-19 to R-49 Insulation (CAC early replacement)	Multi-Family	0.00	0.02	0.00	Cooling		
113	14 SEER (12.15 EER) Split-System Air	Multi-Family	0.04	0.03	0.00	Cooling		
113	Conditioner w/ Quality Install - Early Floor R-0 to R-19 Insulation-Batts (CAC	Multi-Family	0.00	0.03	0.00	Cooling		
113	early replacement) AC Filter Changes (CAC early	Multi-Family	0.00	0.01	0.00	Cooling		
113	replacement) AC Maintenance and/or tune-up (CAC	Multi-Family	0.00	0.01	0.00	Cooling		
113	early replacement) Proper Refrigerant Charging and Air Flow (HP cooling)	, Multi-Family	0.66	0.78	0.00	Cooling		
113	Crawlspace insulation (HP cooling)	Multi-Family	0.03	0.47	0.00	Cooling		
113	Programmable Thermostat (HP cooling)	Multi-Family	0.17	0.43	0.00	Cooling		
113	Cool Roof (HP cooling)	Multi-Family	0.93	0.41	0.00	Cooling		
	<u> </u>							

NC Resi	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use			
113	Whole House Fans (HP cooling)	Multi-Family	1.44	0.30	0.00	Cooling			
113	Ceiling R-0 to R-38 Insulation (HP cooling)	Multi-Family	0.50	0.19	0.00	Cooling			
113	Duct Testing and Sealing (HP cooling)	Multi-Family	0.16	0.17	0.00	Cooling			
113	Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling)	Multi-Family	0.24	0.17	0.00	Cooling			
113	Proper Sizing and Quality Install (HP cooling)	Multi-Family	0.49	0.14	0.00	Cooling			
113	Ceiling R-0 to R-49 Insulation (HP cooling)	Multi-Family	0.01	0.03	0.00	Cooling			
113	Ceiling Fans (HP cooling)	Multi-Family	0.12	0.12	0.00	Cooling			
113	Basement insulation R-13 (HP cooling)	Multi-Family	0.05	0.12	0.00	Cooling			
113	WINDOWS - Double-Glazed Clear to Energy Star (HP cooling)	Multi-Family	0.11	0.10	0.00	Cooling			
113	Ceiling R-11 to R-38 Insulaton (HP cooling)	Multi-Family	0.07	0.06	0.00	Cooling			
113	Ceiling R-11 to R-49 Insulation (HP cooling)	Multi-Family	0.01	0.03	0.00	Cooling			
113	Floor R-0 to R-19 Insulation-Batts (HP cooling)	Multi-Family	0.04	0.05	0.00	Cooling			
113	Ceiling R-19 to R-38 Insulation (HP cooling)	Multi-Family	0.01	0.04	0.00	Cooling			
113	Ceiling R-19 to R-49 Insulation (HP cooling)	Multi-Family	0.00	0.03	0.00	Cooling			
113	Wall Blow-in R-0 to R-13 Insulation (HP cooling)	Multi-Family	0.03	0.01	0.00	Cooling			
113	Heat Pump Filter Replacement	Multi-Family	0.01	0.01	0.00	Cooling			
113	Heat pump tune up	Multi-Family	0.01	0.01	0.00	Cooling			
113	Proper Refrigerant Charging and Air Flow (HP cooling Early Replacement)	Multi-Family	0.12	0.80	0.00	Cooling			
113	Crawlspace insulation (HP cooling Early Replacement)	Multi-Family	0.01	0.48	0.00	Cooling			
113	Programmable Thermostat (HP cooling Early Replacement)	Multi-Family	0.03	0.45	0.00	Cooling			
113	Cool Roof (HP cooling Early Replacement)	Multi-Family	0.17	0.42	0.00	Cooling			
113	Whole House Fans (HP cooling early replacement)	Multi-Family	0.26	0.31	0.00	Cooling			
113	Ceiling R-0 to R-38 Insulation (HP cooling Early Replacement)	Multi-Family	0.09	0.20	0.00	Cooling			
113	Duct Testing and Sealing (HP cooling Early Replacement)	Multi-Family	0.03	0.18	0.00	Cooling			
113	Comprehensive Shell Air Sealing - Inf. Reduction (HP cooling Early	Multi-Family	0.04	0.17	0.00	Cooling			
113	Proper Sizing and Quality Install (HP cooling Early Replacement)	Multi-Family	0.09	0.15	0.00	Cooling			
113	Ceiling R-0 to R-49 Insulation (HP cooling Early Replacement)	Multi-Family	0.00	0.03	0.00	Cooling			
113	Ceiling Fans (HP cooling early replacement)	Multi-Family	0.02	0.13	0.00	Cooling			
113	Basement insulation R-13 (HP cooling Early Replacement)	Multi-Family	0.01	0.12	0.00	Cooling			
113	WINDOWS - Double-Glazed Clear to Energy Star (HP cooling Early	Multi-Family	0.02	0.10	0.00	Cooling			
113	Ceiling R-11 to R-38 Insulaton (HP cooling Early Replacement)	Multi-Family	0.01	0.06	0.00	Cooling			
113	Ceiling R-11 to R-49 Insulation (HP cooling Early Replacement)	Multi-Family	0.00	0.03	0.00	Cooling			
113	Floor R-0 to R-19 Insulation-Batts (HP cooling Early Replacement)	Multi-Family	0.01	0.05	0.00	Cooling			
113	Ceiling R-19 to R-38 Insulation (HP cooling Early Replacement)	Multi-Family	0.00	0.04	0.00	Cooling			
113	Ceiling R-19 to R-49 Insulation (HP cooling Early Replacement)	Multi-Family	0.00	0.03	0.00	Cooling			

NC Residential: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use		
113	Wall Blow-in R-0 to R-13 Insulation (HP cooling Early Replacement)	Multi-Family	0.01	0.01	0.00	Cooling		
113	Heat Pump Filter Replacement	Multi-Family	0.00	0.01	0.00	Cooling		
113	Heat pump tune up	Multi-Family	0.00	0.01	0.00	Cooling		
113	Cool Roof (RAC)	Multi-Family	0.07	0.79	0.00	Cooling		
113	Whole House Fans (RAC)	Multi-Family	0.11	0.58	0.00	Cooling		
113	Comprehensive Shell Air Sealing - Inf. Reduction (RAC)	Multi-Family	0.02	0.43	0.00	Cooling		
113	HE Room Air Conditioner - CEE Tier 1 EER 11.3	Multi-Family	0.03	0.40	0.00	Cooling		
113	WINDOWS - Double-Glazed Clear to Energy Star (RAC)	Multi-Family	0.01	0.35	0.00	Cooling		
113	Ceiling R-0 to R-38 Insulation (RAC)	Multi-Family	0.03	0.30	0.00	Cooling		
113	Ceiling Fans (RAC)	Multi-Family	0.01	0.25	0.00	Cooling		
113	Ceiling R-0 to R-49 Insulation (RAC)	Multi-Family	0.00	0.05	0.00	Cooling		
113	Window Film (RAC)	Multi-Family	0.03	0.17	0.00	Cooling		
113	Wall Blow-in R-0 to R-13 Insulation (RAC)	Multi-Family	0.00	0.11	0.00	Cooling		
113	WINDOWS - Default With Sunscreen (RAC)	Multi-Family	0.01	0.11	0.00	Cooling		
113	Ceiling R-11 to R-38 Insulaton (RAC)	Multi-Family	0.00	0.10	0.00	Cooling		
113	Ceiling R-11 to R-49 Insulation (RAC)	Multi-Family	0.00	0.04	0.00	Cooling		
113	Ceiling R-19 to R-38 Insulation (RAC)	Multi-Family	0.00	0.06	0.00	Cooling		
113	Ceiling R-19 to R-49 Insulation (RAC)	Multi-Family	0.00	0.04	0.00	Cooling		
113	Room AC Filter Replacement	Multi-Family	0.00	0.03	0.00	Cooling		
113	EER 8.5 RAC Early Replacement, CEE Tier 1 EER 11.3 (early replacement)	Multi-Family	0.01	0.08	0.00	Cooling		
113	10% better than Energy Star Dehumidifier ROB (35-45 pints/day)	Multi-Family	0.03	0.50	0.00	Cooling		
113	Heat pump upgrade to 16+ SEER/8.7+ HSPF (HP heating)	Multi-Family	1.52	0.57	0.00	Space Heating		
113	Crawlspace insulation (HP heating)	Multi-Family	0.04	0.47	0.00	Space Heating		
113	Programmable Thermostat (HP heating)	Multi-Family	0.30	0.45	0.00	Space Heating		
113	Comprehensive Shell Air Sealing - Inf. Reduction (HP heating)	Multi-Family	0.67	0.28	0.00	Space Heating		
113	Ceiling R-0 to R-38 Insulation (HP heating)	Multi-Family	1.18	0.26	0.00	Space Heating		
113	Duct Testing and Sealing (HP heating)	Multi-Family	0.38	0.23	0.00	Space Heating		
113	Ceiling R-0 to R-49 Insulation (HP heating)	Multi-Family	0.03	0.05	0.00	Space Heating		
113	Basement insulation R-13 (HP heating)	Multi-Family	0.11	0.18	0.00	Space Heating		
113	Heat Recovery Ventilators (HP heating)	Multi-Family	2.66	0.17	0.00	Space Heating		
113	WINDOWS - Double-Glazed Clear to Energy Star (HP heating)	Multi-Family	0.23	0.12	0.00	Space Heating		
113	Ceiling R-11 to R-38 Insulaton (HP heating)	Multi-Family	0.14	0.08	0.00	Space Heating		
113	Ceiling R-11 to R-49 Insulation (HP heating)	Multi-Family	0.01	0.04	0.00	Space Heating		
113	Floor R-0 to R-19 Insulation-Batts (HP heating)	Multi-Family	0.08	0.06	0.00	Space Heating		
113	Ground Source Heat Pump with Desuperheater (HP heating)	Multi-Family	0.84	0.03	0.00	Space Heating		

Colling R-10 to R-38 Insulation (HP Nutri-Family Description	NC Resi	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)								
Celling R-19 to R-19 Insulation (HP heating)	Rank	Measure Name	_				End Use			
133 Ceiling R-19 to R-49 Insulation (HP Wall Blow-in R-20 to R-13 Insulation (HP Heating) Wall Family Wall F	113		Multi-Family	0.01	0.04	0.00	Space Heating			
Wall Blow-in R-0 to R-13 Insulation (HP heating heating)	113	Ceiling R-19 to R-49 Insulation (HP	Multi-Family	0.00	0.03	0.00	Space Heating			
Heat Pump Filter Replacement Multi-Family 0.02 0.01 0.00 Space Heating Multi-Family 0.03 0.01 0.00 Space Heating Multi-Family 0.05 0.64 0.00 Space Heating Multi-Family 0.07 0.62 0.00 Space Heating Multi-Family 0.05 0.06 0.00 Space Heating Multi-Family 0.08 0.00 Space Heating Multi-Family 0.09 0.32 0.00 Space Heating Multi-Family 0.05 0.06 0.00 Space Heating Multi-Family 0.05 0.06 0.00 Space Heating Multi-Family 0.05 0.05 0.00 Space Heating Multi-Family 0.05 0.06 0.00 Space Heating Multi-Family 0.05 0.00 Space Heating Multi-Family 0.05 0.00 Space Heating Multi-Family 0.05 0.00 Space Heating Multi-Family 0.00 0.05 0.00 Space Heating Multi-Family	113	Wall Blow-in R-0 to R-13 Insulation (HP	Multi-Family	0.07	0.02	0.00	Space Heating			
Heat pump ungrade to 16-1 SEER/8.7+	113		Multi-Family	0.02	0.01	0.00	Space Heating			
HSPF (HP heating early replacement) Green Harmonia Green Harmonia	113	Heat pump tune up	Multi-Family	0.03	0.01	0.00	Space Heating			
113 Crawlspace insulation (IP heating early replacement) Programmable Thermostat (IP heating early replacement) Comprehensive Shell Air Sealing - Inf. Reduction (IP heating early replacement) Multi-Family 0.06 0.08 Space Heating Multi-Family 0.16 0.38 0.00 Space Heating Multi-Family 0.28 0.35 0.00 Space Heating Multi-Family 0.28 0.35 0.00 Space Heating Multi-Family 0.09 0.32 0.00 Space Heating Multi-Family 0.09 0.32 0.00 Space Heating Multi-Family 0.01 0.06 0.00 Space Heating Multi-Family 0.01 0.06 0.00 Space Heating Multi-Family 0.15 0.25 0.00 Space Heating Multi-Family 0.61 0.22 0.00 Space Heating Multi-Family 0.61 0.22 0.00 Space Heating Multi-Family 0.05 0.16 0.00 Space Heating Multi-Family 0.05 0.00 Space Heating Multi-Family 0.00 0.05 0.00 Space Heating Multi-Family 0.00 0.05 0.00 Space Heating Multi-Family 0.01 0.07 0.00 Space Heating Multi-Family 0.10 0.07 0.00 Space Heating Multi-Family 0.10 0.00 Space Heating Multi-Family 0.00 0.00 Space Heating Multi-Family 0.01 0.00 Space Heating Multi-Family 0.01 0.00 Space Heating Multi-Family 0.01 0.00 Space Heating Multi-Family 0.25 0.27 0.00 Space Heating Multi-Family 0.25 0.27 0.00 Space Heating Multi-Fam	113		Multi-Family	0.37	0.79	0.00	Space Heating			
Programmable Thermostat (HP heating early replacement)	113	Crawlspace insulation (HP heating early	Multi-Family	0.06	0.64	0.00	Space Heating			
Comprehensive Shell Air Sealing - Inf. Reduction (HP heating early replacement) Celling R-0 to R-38 Insulation (HP heating early replacement) Celling R-0 to R-39 Insulation (HP heating early replacement) Celling R-0 to R-49 Insulation (HP heating early replacement) Celling R-0 to R-49 Insulation (HP heating early replacement) Celling R-0 to R-49 Insulation (HP heating early replacement) Celling R-0 to R-49 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-49 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Celling R-1 to R-38 Insulation (HP heating early replacement) Multi-Family Co.00 Co.00 Space Heating Celling R-10 to R-38 Insulation (HP heating early replacement) Celling R-10 to R-38 Insulation (HP heating early replacement) Celling R-10 to R-39 Insulation (HP heating early replacement) Celling R-10 to R-39 Insulation (HP heating early replacement) Celling R-10 to R-39 Insulation (HP heating early replacement) Celling R-10 to R-39 Insulation (HP heating early replacement) Celling R-10 to R-39 Insulation (HP heating early replacement) Celling R-10 to R-39 Insulation (HP heating early replacement) Celling R-10 to R-39 Insulation (HP heating) Celling R-10 to R-39 Insulation (HP heating) Celling R-10 to R-39	113	Programmable Thermostat (HP heating	Multi-Family	0.07	0.62	0.00	Space Heating			
113	113	Comprehensive Shell Air Sealing - Inf.	Multi-Family	0.16	0.38	0.00	Space Heating			
Duct Testing and Sealing (HP heating early replacement)	113	Ceiling R-0 to R-38 Insulation (HP	Multi-Family	0.28	0.35	0.00	Space Heating			
Celling R-0 to R-49 Insulation (HP heating early replacement)	113	Duct Testing and Sealing (HP heating	Multi-Family	0.09	0.32	0.00	Space Heating			
Basement insulation R-13 (HP heating early replacement) Heat Recovery Ventilators (HP heating early replacement) WINDOWS - Double-Glazed Clear to Energy Star (HP heating early replacement) Multi-Family Description of the Phaeting early replacement) Multi-Family Description of the Phaeting early replacement) Celling R-11 to R-39 Insulation (HP heating early replacement) Celling R-11 to R-39 Insulation (HP heating early replacement) Celling R-11 to R-39 Insulation (HP heating early replacement) Floor R-0 to R-19 Insulation HP heating early replacement) Ground Source Heat Pump with Desuperheater (HP heating early replacement) Ground Source Heat Pump with Desuperheater (HP heating early replacement) Celling R-19 to R-38 Insulation (HP heating early replacement) Wulti-Family Desuperheater (HP heating) Desuperheater (HP heating) Wulti-Famil	113	Ceiling R-0 to R-49 Insulation (HP	Multi-Family	0.01	0.06	0.00	Space Heating			
Heat Recovery Ventilators (HP heating early replacement) WINDOWS - Double-Glazed Clear to Energy Star (HP heating early ventilations) Multi-Family 0.05 0.16 0.00 Space Heating	113	Basement insulation R-13 (HP heating	Multi-Family	0.15	0.25	0.00	Space Heating			
WINDOWS - Double-Glazed Clear to Energy Star (HP heating early Phaeting early Phaeting early replacement) Celling R-11 to R-38 Insulation (HP heating early replacement) Celling R-11 to R-49 Insulation (HP heating early replacement) Celling R-11 to R-49 Insulation (HP heating early replacement) Floor R-0 to R-19 Insulation (HP heating early replacement) Ground Source Heat Pump with Desuperheater (HP heating early Palenting early Phaeting Phaeting early Phaeting Phaeting Phaeting early Phaeting Phaeti	113	Heat Recovery Ventilators (HP heating	Multi-Family	0.61	0.22	0.00	Space Heating			
113	113	WINDOWS - Double-Glazed Clear to	Multi-Family	0.05	0.16	0.00	Space Heating			
113	113	Ceiling R-11 to R-38 Insulaton (HP	Multi-Family	0.03	0.10	0.00	Space Heating			
Floor R-0 to R-19 Insulation Batts (HP heating early replacement) Ground Source Heat Pump with Desuperheater (HP heating early replacement) Gelling R-19 to R-38 Insulation (HP heating early replacement) Gelling R-19 to R-38 Insulation (HP heating early replacement) Multi-Family 0.00 0.05 0.00 Space Heating Multi-Family 0.00 0.05 0.00 Space Heating Multi-Family 0.00 0.04 0.00 Space Heating Multi-Family 0.00 0.04 0.00 Space Heating Multi-Family 0.02 0.02 0.00 Space Heating Multi-Family 0.02 0.02 0.00 Space Heating Multi-Family 0.01 0.02 0.00 Space Heating Multi-Family 0.01 0.01 0.00 Space Heating Multi-Family 0.01 0.01 0.00 Space Heating Multi-Family 0.05 0.07 0.00 Space Heating Multi-Family 0.05 0.07 0.00 Space Heating Multi-Family 0.05 0.00 Space Heating 0.05 0.00 Space Heating Multi-Family 0.05 0.00 Space Heating 0.05 0.05 0.00 Space Heating 0.05 0.00 Space H	113	Ceiling R-11 to R-49 Insulation (HP	Multi-Family	0.00	0.05	0.00	Space Heating			
113 Ground Source Heat Pump with Desuperheater (HP heating early Ceiling R-19 to R-38 Insulation (HP heating early replacement) Multi-Family 0.00 0.05 0.00 Space Heating 113 Ceiling R-19 to R-49 Insulation (HP heating early replacement) Multi-Family 0.00 0.04 0.00 Space Heating 113 Ceiling R-19 to R-49 Insulation (HP heating early replacement) Multi-Family 0.00 0.04 0.00 Space Heating 113 Heat pump R-0 to R-13 Insulation (HP heating early replacement) Multi-Family 0.01 0.02 0.00 Space Heating 113 Heat pump Filter Replacement (heating) Multi-Family 0.01 0.02 0.00 Space Heating 113 Heat pump tune up (heating) Multi-Family 0.01 0.01 0.00 Space Heating 114 Programmable Thermostat (resistance heating) Multi-Family 0.26 0.87 0.00 Space Heating 115 Crawlspace insulation (resistance heating) Ceiling R-0 to R-38 Insulation (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Multi-Family 0.53 0.37 0.00 Space Heating 113 Multi-Family 0.03 0.06 0.00 Space Heating 114 Multi-Family 0.03 0.06 0.00 Space Heating 115 Multi-Family 0.25 0.27 0.00 Space Heating 116 Multi-Family 0.30 0.25 0.00 Space Heating 117 Multi-Family 0.30 0.25 0.00 Space Heating 118 Multi-Family 0.30 0.25 0.00 Space Heating 119 Multi-Family 0.30 0.25 0.00 Space Heating 110 Ceiling R-11 to R-38 Insulation (resistance heating) Multi-Family 0.14 0.12 0.00 Space Heating 111 Ceiling R-11 to R-49 Insulation Multi-Family 0.16 0.12 0.00 Space Heating 112 Ceiling R-11 to R-49 Insulation Multi-Family 0.16 0.12 0.00 Space Heating 113 Ceiling R-11 to R-49 Insulation Multi-Family 0.16 0.12 0.00 Space Heating 114 Ceiling R-11 to R-49 Insulation Multi-Family 0.16 0.12 0.00 Space Heating 115 Multi-Family 0.16 0.12 0.00 Space Heating	113	Floor R-0 to R-19 Insulation-Batts (HP	Multi-Family	0.10	0.07	0.00	Space Heating			
133 Ceiling R-19 to R-38 Insulation (HP heating early replacement) Multi-Family 0.00 0.05 0.00 Space Heating 134 Ceiling R-19 to R-49 Insulation (HP heating early replacement) Wall Blow-in R-0 to R-13 Insulation (HP heating early replacement) Multi-Family 0.02 0.02 0.00 Space Heating 134 Heat Pump Filter Replacement (heating) Multi-Family 0.01 0.02 0.00 Space Heating 135 Heat pump tune up (heating) Multi-Family 0.01 0.01 0.00 Space Heating 136 Programmable Thermostat (resistance heating) Multi-Family 0.26 0.87 0.00 Space Heating 137 Crawlspace insulation (resistance heating) Ceiling R-0 to R-38 Insulation (resistance heating) Ceiling R-0 to R-38 Insulation (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Multi-Family 0.53 0.37 0.00 Space Heating 138 Space Heating Multi-Family 0.53 0.37 0.00 Space Heating 139 Mind Space Heating Multi-Family 0.03 0.06 0.00 Space Heating 130 Mind Space Heating Multi-Family 0.25 0.27 0.00 Space Heating 131 Mind Space Heating Multi-Family 0.30 0.25 0.00 Space Heating 131 Mind Space Heating Multi-Family 0.30 0.25 0.00 Space Heating 132 Mind Space Heating Multi-Family 0.30 0.25 0.00 Space Heating 133 Mind Space Heating Multi-Family 0.30 0.25 0.00 Space Heating 134 Mind Space Heating Multi-Family 0.30 0.30 0.30 Space Heating 135 Mind Space Heating Multi-Family 0.30 0.30 Space Heating 136 Mind Space Heating Multi-Family 0.30 0.30 Space Heating 137 Mind Space Heating Multi-Family 0.30 Space Heating 138 Mind Space Heating Multi-Family 0.30 Space Heating 139 Mind Space Heating Multi-Family 0.30 Space Heating 130 Mind Space Heating Multi-Family 0.30 Space Heating 134 Mind Space He	113	Ground Source Heat Pump with	Multi-Family	0.19	0.03	0.00	Space Heating			
Ceiling R-19 to R-49 Insulation (HP heating early replacement) Multi-Family 0.00 0.04 0.00 Space Heating Multi-Family 0.02 0.02 0.00 Space Heating Multi-Family 0.01 0.01 0.00 Space Heating Multi-Family 0.01 0.01 0.00 Space Heating Multi-Family 0.01 0.01 0.00 Space Heating Multi-Family 0.06 0.87 0.00 Space Heating Multi-Family 0.07 0.75 0.00 Space Heating Multi-Family 0.08 0.07 0.00 Space Heating Multi-Family 0.09 Space Heating	113	Ceiling R-19 to R-38 Insulation (HP	Multi-Family	0.00	0.05	0.00	Space Heating			
Wall Blow-in R-0 to R-13 Insulation (HP heating early replacement) Multi-Family 0.02 0.02 0.00 Space Heating	113	Ceiling R-19 to R-49 Insulation (HP	Multi-Family	0.00	0.04	0.00	Space Heating			
Heat Pump Filter Replacement (heating) Heat pump tune up (heating) Heat pump tune up (heating) Programmable Thermostat (resistance heating) Crawlspace insulation (resistance heating) Ceiling R-0 to R-49 Insulation Ceiling R-0 to R-38 Insulaton (resistance heating) Multi-Family Dasement insulation R-13 (resistance heating) Basement insulation R-13 (resistance heating) Ceiling R-1 to R-38 Insulaton (resistance heating) Ceiling R-1 to R-38 Insulaton (resistance heating) Ceiling R-1 to R-39 Insulation (resistance heating) Ceiling R-1 to R-19 Insulation (resistance heating) Ceiling R-1 to R-49 Insulation Ceiling R-1 to R-19 Insulation Ceiling R-1 to R-49 Insulation Ceiling R-1 to R-49 Insulation Ceiling R-1 to R-49 Insulation Ceiling R-1 to R-19 Insulation Ceiling R-1 to R-49 Insulation Multi-Family Ceiling R-1 to R-49 Insulation Multi-Family Ceiling R-1 to R-49 Insulation Ceiling R-1 to R-49 Insulation Multi-Family Multi-Family Ceiling R-1 to R-49 Insulation	113	Wall Blow-in R-0 to R-13 Insulation (HP	Multi-Family	0.02	0.02	0.00	Space Heating			
Programmable Thermostat (resistance heating) Crawlspace insulation (resistance heating) Ceiling R-0 to R-38 Insulation (resistance heating) Ceiling R-0 to R-38 Insulation (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Multi-Family 0.07 0.75 0.00 Space Heating Multi-Family 0.42 0.00 Space Heating Multi-Family 0.53 0.37 0.00 Space Heating Multi-Family 0.53 0.37 0.00 Space Heating Multi-Family 0.53 0.37 0.00 Space Heating Multi-Family 0.03 0.06 0.00 Space Heating Multi-Family 0.25 0.27 0.00 Space Heating Multi-Family 0.25 0.27 0.00 Space Heating Multi-Family 0.30 0.25 0.00 Space Heating Multi-Family 0.14 0.12 0.00 Space Heating	113		Multi-Family	0.01	0.02	0.00	Space Heating			
113	113	Heat pump tune up (heating)	Multi-Family	0.01	0.01	0.00	Space Heating			
Crawlspace insulation (resistance heating) Ceiling R-0 to R-38 Insulation (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Basement insulation R-13 (resistance heating) Basement insulation R-13 (resistance heating) Heat Recovery Ventilators (resistance heating) Ceiling R-11 to R-38 Insulaton (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation Multi-Family O.07 O.07 O.08 Space Heating Multi-Family O.25 O.27 O.00 Space Heating Multi-Family O.30 O.25 O.00 Space Heating Multi-Family O.30 O.25 O.00 Space Heating Multi-Family O.31 O.32 O.33 O.37 O.00 Space Heating Multi-Family O.35 O.37 O.00 Space Heating Multi-Family O.30 O.25 O.00 Space Heating Multi-Family O.30 O.31 O.32 O.33 O.37 O.30 O.37 O.30 O.37 O.30 O.30 O.37 O.30 O.37 O.30	113		Multi-Family	0.26	0.87	0.00	Space Heating			
Ceiling R-0 to R-38 Insulation (resistance heating) Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Basement insulation R-13 (resistance heating) Heat Recovery Ventilators (resistance heating) Ceiling R-11 to R-38 Insulation (resistance heating) Ceiling R-11 to R-49 Insulation Multi-Family 1.18 0.42 0.00 Space Heating 0.53 0.37 0.00 Space Heating 0.14 0.12 0.00 Space Heating 0.14 0.12 0.00 Space Heating 0.14 0.15 0.16 0.17 0.18 0.18 0.19 0.10 Space Heating 0.10 Space Heating 0.11 0.12 0.12 0.13 Space Heating	113	Crawlspace insulation (resistance	Multi-Family	0.07	0.75	0.00	Space Heating			
Comprehensive Shell Air Sealing - Inf. Reduction (resistance heating) Ceiling R-0 to R-49 Insulation (resistance heating) Basement insulation R-13 (resistance heating) Heat Recovery Ventilators (resistance heating) Ceiling R-11 to R-38 Insulation (resistance heating) Floor R-0 to R-19 Insulation Ceiling R-11 to R-49 Insulation Multi-Family O.53 O.37 O.00 Space Heating O.00 Space Heating O.00 Space Heating O.00 Space Heating Multi-Family O.00 Space Heating O.00 Space Heating O.00 Space Heating Multi-Family O.00 Space Heating Multi-Family O.14 O.12 O.00 Space Heating Multi-Family O.16 O.12 O.00 Space Heating Multi-Family O.16 O.12 O.00 Space Heating Multi-Family O.16 O.10 Space Heating	113	Ceiling R-0 to R-38 Insulation	Multi-Family	1.18	0.42	0.00	Space Heating			
Ceiling R-0 to R-49 Insulation (resistance heating) Basement insulation R-13 (resistance heating) Multi-Family WINDOWS - Double-Glazed Clear to Energy Star (resistance heating) Heat Recovery Ventilators (resistance heating) Ceiling R-11 to R-38 Insulaton (resistance heating) Floor R-0 to R-19 Insulation Ceiling R-11 to R-49 Insulation Multi-Family O.03 O.06 O.00 Space Heating O.30 O.25 O.00 Space Heating Multi-Family O.30 O.25 O.00 Space Heating Multi-Family O.14 O.12 O.00 Space Heating Multi-Family O.14 O.12 O.00 Space Heating Multi-Family O.14 O.12 O.00 Space Heating Multi-Family O.16 O.12 O.00 Space Heating Multi-Family O.16 O.17 O.18 O.19 O.1	113	Comprehensive Shell Air Sealing - Inf.	Multi-Family	0.53	0.37	0.00	Space Heating			
Basement insulation R-13 (resistance heating) WINDOWS - Double-Glazed Clear to Energy Star (resistance heating) Heat Recovery Ventilators (resistance heating) Ceiling R-11 to R-38 Insulaton (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation Multi-Family 0.25 0.27 0.00 Space Heating 0.30 0.25 0.00 Space Heating 0.14 0.12 0.00 Space Heating Multi-Family 0.14 0.12 0.00 Space Heating Multi-Family 0.16 0.12 0.00 Space Heating Multi-Family Multi-Family 0.16 0.10 Space Heating	113	Ceiling R-0 to R-49 Insulation	Multi-Family	0.03	0.06	0.00	Space Heating			
WINDOWS - Double-Glazed Clear to Energy Star (resistance heating) Heat Recovery Ventilators (resistance heating) Ceiling R-11 to R-38 Insulation Ceiling R-11 to R-49 Insulation Wulti-Family O.30 O.25 O.00 Space Heating O.30 O.30 O.30 O.30 O.30 O.30 O.30 O.30	113	Basement insulation R-13 (resistance	Multi-Family	0.25	0.27	0.00	Space Heating			
Heat Recovery Ventilators (resistance heating) Ceiling R-11 to R-38 Insulaton (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation Multi-Family 0.14 0.02 0.00 Space Heating 0.14 0.12 0.00 Space Heating 0.14 0.12 0.00 Space Heating Multi-Family 0.16 0.12 0.00 Space Heating	113	WINDOWS - Double-Glazed Clear to	Multi-Family	0.30	0.25	0.00	Space Heating			
Ceiling R-11 to R-38 Insulaton (resistance heating) Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation Multi-Family 0.14 0.12 0.00 Space Heating O.14 0.12 0.00 Space Heating O.14 0.12 0.00 Space Heating	113	Heat Recovery Ventilators (resistance	Multi-Family	2.31	0.24	0.00	Space Heating			
Floor R-0 to R-19 Insulation-Batts (resistance heating) Ceiling R-11 to R-49 Insulation Multi-Family 0.16 0.12 0.00 Space Heating Multi-Family 0.16 0.12 0.00 Space Heating	113	Ceiling R-11 to R-38 Insulaton	Multi-Family	0.14	0.12	0.00	Space Heating			
Ceiling R-11 to R-49 Insulation Multi-Family 0.01 0.04 0.00 Space Heating	113	Floor R-0 to R-19 Insulation-Batts	Multi-Family	0.16	0.12	0.00	Space Heating			
	113	Ceiling R-11 to R-49 Insulation (resistance heating)	Multi-Family	0.01	0.04	0.00	Space Heating			

NC Resi	NC Residential: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use			
113	Ground Source Heat Pump with Desuperheater (resistance heating)	Multi-Family	-0.01	0.00	0.00	Space Heating			
113	Ceiling R-19 to R-38 Insulation (resistance heating)	Multi-Family	0.02	0.07	0.00	Space Heating			
113	Ceiling R-19 to R-49 Insulation (resistance heating)	Multi-Family	0.00	0.04	0.00	Space Heating			
113	Wall Blow-in R-0 to R-13 Insulation (resistance heating)	Multi-Family	0.09	0.04	0.00	Space Heating			
113	LEDs (base CFL 0.5 hrs/day) 2020	Multi-Family	0.05	0.29	0.00	Lighting			
113	Refrigerator - Early Replacement (Energy Star)	Multi-Family	0.76	0.42	0.00	Refrigeration			
113	DHW Tank Wrap	Multi-Family	1.81	0.86	0.00	Water Heating			
113	Heat Pump Water Heater - Energy Star	Multi-Family	4.20	0.83	0.00	Water Heating			
113	Solar Domestic Water Heating	Multi-Family	4.11	0.35	0.00	Water Heating			
113	Energy Star CW CEE Tier 2 (MEF=2.0)	Multi-Family	0.09	0.03	0.00	Water Heating			
113	Energy Star Dishwasher (EF=0.72)	Multi-Family	0.05	0.02	0.00	Water Heating			
113	Heat Pump Water Heater - Energy Star - Early Replacement	Multi-Family	0.90	0.82	0.00	Water Heating			
113	Energy Star CW CEE Tier 2 (MEF=2.0)	Multi-Family	0.19	0.06	0.00	Clothes Washer			
113	Heat Pump Dryer	Multi-Family	5.11	0.13	0.00	Clothes Dryer			
113	Energy Star Dishwasher (EF=0.72)	Multi-Family	0.10	0.05	0.00	Dishwashers			
113	Plug Load Controls - Smart Power Strip (base plasma TV)	Multi-Family	0.01	0.02	0.00	Electronics			
113	Plug Load Controls - Smart Power Strip (base LCD TV)	Multi-Family	0.05	0.02	0.00	Electronics			
113	Plug Load Controls - Smart Power Strip (base CRT TV)	Multi-Family	0.06	0.06	0.00	Electronics			
113	Plug Load Controls - Smart Power Strip (base DVD player)	Multi-Family	0.15	0.06	0.00	Electronics			
113	Direct Feedback	Multi-Family	9.16	0.75	0.00	Whole Bldg (Retrofit)			

DNV·GL

VA Com	/A Commercial: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use			
1	LEDs (base incandescent flood) 2020	Office	415.40	11876.08	415.40	Indoor Lighting			
2	LEDs (base incandescent flood) 2020	Retail	262.66	6666.83	262.66	Indoor Lighting			
3	DX Packaged System, EER=13.4, 10 tons	Office	210.96	4.61	210.96	Cooling			
4	LEDs (base incandescent flood) 2020	Misc	201.80	10238.97	201.80	Indoor Lighting			
5	DX Packaged System, EER=13.4, 10	Retail	184.68	3.08	184.68	Cooling			
6	ROB 4L4' Low Watt High Performance T8	Office	169.08	1.56	169.08	Indoor Lighting			
7	(75 W), 2020 DX Packaged System, EER=13.4, 10	School	164.06	1.65	164.06	Cooling			
8	tons Variable Speed Drive Control, 5 HP	Retail	155.79	3.41	155.79	Ventilation			
9	ROB 4L4' High Performance T8 (86 W),	Office	150.71	3.25	150.71	Indoor Lighting			
10	2020 LEDs (base incandescent A-line 72W)	Office	145.74	8333.39	145.74	Indoor Lighting			
11	2020 High Performance Lighting R/R - 25%	Office	119.99	5.76	119.99	Indoor Lighting			
12	Savings (base 4L4'T8), 2020 LEDs (base incandescent flood) 2020	on-Jurisdiction		10492.37	110.64	Indoor Lighting			
13	Variable Speed Drive Control, 15 HP	School	101.22	1.02	101.22	Ventilation			
14	Variable Speed Drive Control, 15 HP	Office	98.38	4.59	98.38	Ventilation			
15	Variable Speed Drive Control, 5 HP	Misc	97.88	1.27	97.88	Ventilation			
16	DX Packaged System, EER=13.4, 10	Restaurant	97.12	5.70	97.12	Cooling			
17	tons ROB 4L4' Low Watt High Performance T8	School	95.60	1.19	95.60	Indoor Lighting			
18	(75 W), 2020 LEDs (base incandescent A-line 53W)	Office	94.76	5418.15	94.76	Indoor Lighting			
19	2020 ROB 4L4' High Performance T8 (86 W),	School	92.98	2.68	92.98	Indoor Lighting			
20	2020 LEDs (base incandescent A-line 72W)	Retail	92.80	4710.80	92.80	Indoor Lighting			
21	2020 ROB 4L4' Low Watt High Performance T8		88.39	1.10	88.39	Indoor Lighting			
22	(75 W), 2020 Occupancy Sensor, 4L4' Fluorescent	Office	85.99	1.00	85.99	Indoor Lighting			
23	Fixtures, 2020 T5 (240W) (base metal halide)	Warehouse	85.98	6.92	85.98	Indoor Lighting Indoor Lighting			
24	ROB 4L4' High Performance T8 (86 W),	Retail	80.64	2.30	80.64	Indoor Lighting Indoor Lighting			
	2020 DX Packaged System, EER=13.4, 10					5 5			
25	tons DX Packaged System, EER=13.4, 10	on-Jurisdiction		3.47	79.22	Cooling			
26	tons Heat Pump Upgrade (15 SEER, 8.2	Lodging	78.69	2.22	78.69	Cooling			
27	HSPF) DX Packaged System, EER=13.4, 10	Office	77.45	6.45	77.45	Cooling			
28	tons	Misc	71.27	3.41	71.27	Cooling			
29	LEDs (base incandescent A-line 72W) 2020	Misc	70.96	7200.52	70.96	Indoor Lighting			
30	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School	69.46	1.96	69.46	Cooling			
31	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Retail	63.58	3.84	63.58	Indoor Lighting			
32	Electronically Commutated Motors (ECM) on an Air Handler Unit	School	63.09	1.37	63.09	Ventilation			
33	LEDs (base incandescent A-line 53W) 2020	Retail	62.28	3161.81	62.28	Indoor Lighting			
34	Variable Speed Drive Control, 15 HP	Health	60.86	13.15	60.86	Ventilation			
35	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	School	60.82	2.17	60.82	Indoor Lighting			

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
36	Solar Water Heater	Office	56.13	1.46	56.13	Water Heating
37	LEDs (base incandescent flood) 2020	Restaurant	54.42	6141.55	54.42	Indoor Lighting
38	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	on-Jurisdiction	54.02	1.47	54.02	Indoor Lighting
39	Data Center Best Practices	Data Centers	52.27	46.96	52.27	Office Equipment
40	Variable Speed Drive Control, 40 HP	School	49.06	8.34	49.06	Ventilation
41	ROB 4L4' High Performance T8 (86 W), 2020	on-Jurisdiction	48.61	3.06	48.61	Indoor Lighting
42	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Warehouse	48.39	1.31	48.39	Indoor Lighting
43	DX Packaged System, EER=13.4, 10 tons	Health	48.24	3.37	48.24	Cooling
44	LEDs (base incandescent A-line 53W) 2020	Misc	46.60	4728.39	46.60	Indoor Lighting
45	Data Center Improved Operations	Data Centers	45.65	115.35	45.65	Office Equipment
46	T5 (240W) (base metal halide)	School	44.31	4.07	44.31	Indoor Lighting
47	Variable Speed Drive Control, 5 HP	on-Jurisdiction	43.99	3.34	43.99	Ventilation
48	Variable Speed Drive Control, 5 HP	School	43.97	1.44	43.97	Ventilation
49	Economizer Repair - DX	Retail	43.20	1.11	43.20	Cooling
50	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Misc	43.09	1.39	43.09	Indoor Lighting
51	LEDs (base incandescent flood) 2020	Lodging	42.49	6200.76	42.49	Indoor Lighting
52	Electronically Commutated Motors (ECM) on an Air Handler Unit	Misc	40.04	2.54	40.04	Ventilation
53	ROB 4L4' High Performance T8 (86 W), 2020	Misc	39.15	2.89	39.15	Indoor Lighting
54	LEDs (base incandescent A-line 72W) 2020	on-Jurisdiction	38.78	7355.84	38.78	Indoor Lighting
55	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	on-Jurisdiction	38.57	4.31	38.57	Indoor Lighting
56	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	36.88	4.32	36.88	Cooling
57	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	36.40	3.18	36.40	Cooling
58	Variable Speed Drive Control, 5 HP	Grocery	35.26	2.07	35.26	Ventilation
59	ROB 4L4' High Performance T8 (86 W), 2020	Warehouse	35.12	2.78	35.12	Indoor Lighting
60	Variable Speed Drive Control, 5 HP	Warehouse	34.77	1.74	34.77	Ventilation
61	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	34.56	3.83	34.56	Cooling
62	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Misc	33.33	1.11	33.33	Indoor Lighting
63	Electronically commutated evaporator fan motor	Grocery	32.81	3.15	32.81	Refrigeration
64	Economizer Repair - DX	Office	31.78	1.67	31.78	Cooling
65	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Misc	30.97	3.42	30.97	Indoor Lighting
66	T5 (240W) (base metal halide)	Misc	28.60	8.00	28.60	Indoor Lighting
67	Heat Recovery Unit	Restaurant	28.06	5.33	28.06	Water Heating
68	PC Network Power Management Enabling	Office	27.44	4.64	27.44	Office Equipment
69	ROB 2L4' High Performance T8 (86 W), 2020	Misc	27.33	2.31	27.33	Indoor Lighting
70	Night covers for display cases (self- contained)	Restaurant	27.03	13.28	27.03	Refrigeration
71	DX Packaged System, EER=13.4, 10 tons	Grocery	26.91	3.35	26.91	Cooling
72	LEDs (base incandescent flood) 2020	Grocery	26.05	8849.41	26.05	Indoor Lighting
73	Data Center Best Practices	School	25.44	42.93	25.44	Office Equipment

VA Com	mercial: All Existing Measures Rar	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
74	Centrifugal Chiller, 0.51 kW/ton, 500 tons	School	25.40	1.57	25.40	Cooling
75	LEDs (base incandescent A-line 53W) 2020	on-Jurisdiction	25.11	4763.43	25.11	Indoor Lighting
76	HE PTAC, EER=9.6, 1 ton	Misc	25.11	1.38	25.11	Cooling
77	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Warehouse	24.97	1.25	24.97	Indoor Lighting
78	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Misc	23.71	2.78	23.71	Indoor Lighting
79	Centrifugal Chiller, 0.51 kW/ton, 500 tons	on-Jurisdiction	23.67	3.29	23.67	Cooling
80	Window Film (Standard) - DX	Restaurant	23.58	3.95	23.58	Cooling
81	Variable Speed Drive Control, 15 HP	on-Jurisdiction	22.93	12.10	22.93	Ventilation
82	Data Center Improved Operations	School	22.21	105.45	22.21	Office Equipment
83	Outdoor Lighting Controls (Photocell/Timeclock)	School	21.53	1.59	21.53	Outdoor Lighting
84	Electronically Commutated Motors (ECM) on an Air Handler Unit	Health	21.50	2.86	21.50	Ventilation
85	LEDs (base incandescent flood) 2020	eligious Worshi	21.44	3978.10	21.44	Indoor Lighting
86	DX Packaged System, EER=13.4, 10 tons	eligious Worshi	20.95	1.70	20.95	Cooling
87	Data Center State of the Art practices	Data Centers	20.08	24.35	20.08	Office Equipment
88	LEDs (base incandescent A-line 72W) 2020	Restaurant	19.15	4322.55	19.15	Indoor Lighting
89	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	on-Jurisdiction	18.51	4.86	18.51	Cooling
90	Window Film (Standard) - DX	Lodging	18.47	2.77	18.47	Cooling
91	Variable Speed Drive Control, 5 HP	Health	17.51	4.54	17.51	Ventilation
92	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Office	17.18	4.38	17.18	Cooling
93	Variable Speed Drive Control, 15 HP	Office	17.04	16.60	17.04	Ventilation
94	Outdoor Lighting Controls (Photocell/Timeclock)	Retail	16.94	1.71	16.94	Outdoor Lighting
95	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	16.53	3.93	16.53	Cooling
96	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	16.37	7.99	16.37	Cooling
97	Air Handler Optimization, 15 HP	Misc	16.26	1.34	16.26	Ventilation
98	Variable Speed Drive Control, 40 HP	on-Jurisdiction	16.20	2.21	16.20	Ventilation
99	ROB 2L4' High Performance T8 (86 W), 2020	Retail	16.11	1.82	16.11	Indoor Lighting
100	Outdoor Lighting Controls (Photocell/Timeclock)	Restaurant	15.88	1.20	15.88	Outdoor Lighting
101	Outdoor Lighting Controls (Photocell/Timeclock)	Office	15.60	1.70	15.60	Outdoor Lighting
102	Air Handler Optimization, 40 HP	Misc	15.08	1.56	15.08	Ventilation
103	LEDs (base incandescent A-line 72W) 2020	Lodging	14.98	4373.16	14.98	Indoor Lighting
104	PC Network Power Management Enabling	School	14.96	3.60	14.96	Office Equipment
105	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Warehouse	14.30	2.71	14.30	Cooling
106	ROB 4L4' High Performance T8 (86 W), 2020	Health	13.77	1.70	13.77	Indoor Lighting
107	ROB 4L4' High Performance T8 (86 W), 2020	Grocery	12.87	1.59	12.87	Indoor Lighting
108	EMS - Chiller	Office	12.72	1.46	12.72	Cooling
109	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Retail	12.70	2.25	12.70	Indoor Lighting
110	LEDs (base incandescent A-line 53W) 2020	Restaurant	12.62	2849.02	12.62	Indoor Lighting

/A Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
111	Lighting Control Tuneup (base 4L4'T8), 2020	Office	12.52	6.42	12.52	Indoor Lighting
112	Data Center Best Practices	Office	12.26	55.52	12.26	Office Equipment
113	High Performance Lighting R/R - 25%	Warehouse	12.26	1.40	12.26	Indoor Lighting
114	Savings (base metal halide) Oversized Air Cooled Condenser	Warehouse	12.13	2.29	12.13	Refrigeration
115	PC Network Power Management	Misc	11.85	4.05	11.85	_
	Enabling					Office Equipment
116	Demand Hot Gas Defrost	Grocery	11.83 11.74	3.45	11.83 11.74	Refrigeration Ventilation
117 118	Variable Speed Drive Control, 40 HP Air Handler Optimization, 40 HP	Warehouse Grocery	11.74	3.40 2.52	11.74	Ventilation
119	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Lodging	11.62	2.15	11.62	Cooling
120	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Health	10.99	2.18	10.99	Indoor Lighting
121	New Economizer - Chiller	Office	10.92	1.10	10.92	Cooling
122	Data Center Improved Operations	Office	10.71	136.37	10.71	Office Equipment
123	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020 RC Notwork Power Management	Grocery	10.43	4.85	10.43	Indoor Lighting
124	PC Network Power Management Enabling	on-Jurisdiction	10.41	4.07	10.41	Office Equipment
125	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	on-Jurisdiction	10.30	1.16	10.30	Indoor Lighting
126	LEDs (base incandescent A-line 53W) 2020	Lodging	9.97	2909.49	9.97	Indoor Lighting
127	Ceiling/roof Insulation - DX	Warehouse	9.83	2.62	9.83	Cooling
128	Data Center State of the Art practices	School	9.77	22.27	9.77	Office Equipment
129	Variable Speed Drive Control, 40 HP	Office	9.72	2.98	9.72	Ventilation
130	Electronically Commutated Motors (ECM) on an Air Handler Unit	on-Jurisdiction	9.64	2.36	9.64	Ventilation
131	T5 (240W) (base metal halide)	Lodging	9.50	3.79	9.50	Indoor Lighting
132	EMS - Chiller	on-Jurisdiction	9.46	1.08	9.46	Cooling
133	Freezer-Cooler Replacement Gaskets (self-contained) Heat Pump Upgrade (15 SEER, 8.2	Retail	9.18	1.46	9.18	Refrigeration
134	HSPF) LEDs (base incandescent A-line 72W)	eligious Worshi	9.17	1.59	9.17	Cooling
135	2020	Grocery	9.01	6122.90	9.01	Indoor Lighting
136	Energy-Star Freezer, glass door	Restaurant	9.00	7.19	9.00	Refrigeration
137	ROB 2L4' High Performance T8 (86 W), 2020	on-Jurisdiction	8.92	2.42	8.92	Indoor Lighting
138	Energy-Star Refrigerator, solid door	Restaurant	8.89	2.30	8.89	Refrigeration
139	Fan Motor, 5hp, 1800rpm, 89.5%	Retail	8.61	3.61	8.61	Ventilation
140	Tankless Water Heater	Office	8.55	1.71	8.55	Water Heating
141	LED Exit Sign Night covers for display cases (self-	Office	8.37	2.49	8.37	Indoor Lighting
142	contained) Freezer-Cooler Replacement Gaskets	Retail	8.17	5.64	8.17	Refrigeration
143	(self-contained) PC Network Power Management	Restaurant	8.13	8.34	8.13	Refrigeration
144	Enabling ROB 2L4' High Performance T8 (86 W),	Warehouse	7.98	3.67	7.98	Office Equipment
145	2020	Restaurant	7.97	1.43	7.97	Indoor Lighting
146	HE PTAC, EER=9.6, 1 ton	Lodging	7.95	1.30	7.95	Cooling
147	Electronically Commutated Motors (ECM) on an Air Handler Unit	eligious Worshi		1.27	7.89	Ventilation
148	. , ,	on-Jurisdiction	7.87	7.50	7.87	Indoor Lighting
149	PC Network Power Management Enabling	Retail	7.73	2.84	7.73	Office Equipment

/A Com	mercial: All Existing Measures Rar	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
150	Outdoor Lighting Controls (Photocell/Timeclock)	Misc	7.73	2.24	7.73	Outdoor Lighting
151	LEDs (base incandescent A-line 72W) 2020	eligious Worshi	7.57	2809.92	7.57	Indoor Lighting
152	Energy Star or Better Monitor - CRT	School	7.56	39.01	7.56	Office Equipment
153	Night covers for display cases (self- contained)	Misc	7.45	38.29	7.45	Refrigeration
154	Lighting Control Tuneup (base 4L4'T8), 2020	School	7.41	2.76	7.41	Indoor Lighting
155	Night covers for display cases (self- contained)	School	7.35	22.13	7.35	Refrigeration
156	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	on-Jurisdiction	7.33	2.87	7.33	Indoor Lighting
157	Heat Recovery Unit	Lodging	7.23	3.37	7.23	Water Heating
158	Air Handler Optimization, 40 HP	on-Jurisdiction	7.22	2.59	7.22	Ventilation
159	Energy Star or Better PC	Office	7.14	2.30	7.14	Office Equipment
160	ENERGY STAR Printer	Office	7.12	48.72	7.12	Office Equipment
161	LEDs (base incandescent flood) 2020	Health	6.89	4873.80	6.89	Indoor Lighting
162	Data Center Best Practices	Misc	6.80	45.26	6.80	Office Equipment
163	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Misc	6.78	3.22	6.78	Cooling
164	ROB 4L4' High Performance T8 (86 W), 2020	eligious Worshi	6.74	1.57	6.74	Indoor Lighting
165	Solar Water Heater	on-Jurisdiction	6.69	1.48	6.69	Water Heating
166	Air Handler Optimization, 15 HP	on-Jurisdiction	6.62	1.83	6.62	Ventilation
167	High Performance Lighting R/R - 25% Savings (base metal halide)	School	6.50	2.58	6.50	Indoor Lighting
168	Fan Motor, 5hp, 1800rpm, 89.5%	Office	6.48	3.61	6.48	Ventilation
169	Tankless Water Heater	Misc	6.38	1.61	6.38	Water Heating
170	Lighting Control Tuneup (base 4L4'T8), 2020	Warehouse	6.36	1.62	6.36	Indoor Lighting
171	Heat Trap	Office	6.36	4.49	6.36	Water Heating
172	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Restaurant	6.31	5.04	6.31	Cooling
173	Data Center Best Practices	Warehouse	6.31	46.14	6.31	Office Equipment
174	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Restaurant	6.27	2.76	6.27	Indoor Lighting
175	Window Film (Standard) - DX	Grocery	6.27	1.06	6.27	Cooling
176	Air Handler Optimization, 15 HP	Office	6.12	2.67	6.12	Ventilation
177	Fan Motor, 5hp, 1800rpm, 89.5%	Misc	6.00	1.34	6.00	Ventilation
178	LED Exit Sign	Retail	5.99	1.38	5.99	Indoor Lighting
179	Data Center Improved Operations	Misc	5.94	111.17	5.94	Office Equipment
180	Heat Recovery Unit	Grocery	5.92	1.04	5.92	Water Heating
181	Solar Water Heater	Lodging	5.91	1.23	5.91	Water Heating
182	Anti-sweat (humidistat) controls ROB 2L4' High Performance T8 (86 W),	Grocery	5.91	1.38	5.91	Refrigeration
183	2020	School	5.86	2.13	5.86	Indoor Lighting
184	Tankless Water Heater	Retail	5.82	1.16	5.82	Water Heating
185	Ceiling/roof Insulation - Chiller Night covers for display cases (self-	Restaurant	5.80	7.47	5.80	Cooling
186	contained)	Lodging	5.77	73.03	5.77	Refrigeration
187	EMS - Chiller	Restaurant	5.73	1.75	5.73	Cooling
188	Lighting Control Tuneup (base 4L4'T8), 2020 Outdoor Lighting Controls	on-Jurisdiction	5.66	4.87	5.66	Indoor Lighting
189	(Photocell/Timeclock)	on-Jurisdiction	5.59	1.90	5.59	Outdoor Lighting
190	Data Center Best Practices	on-Jurisdiction	5.59	44.84	5.59	Office Equipment

VA Com	mercial: All Existing Measures Rar	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
191	LEDs (base incandescent A-line 53W)	Grocery	5.51	3746.84	5.51	Indoor Lighting
192	2020 Data Center Improved Operations	Warehouse	5.51	113.34	5.51	Office Equipment
193	EMS - Chiller	Health	5.41	1.19	5.41	Cooling
194	Energy Star or Better Monitor - CRT	Office	5.37	65.45	5.37	Office Equipment
195	Occupancy Sensor, High Bay T5	Warehouse	5.35	1.79	5.35	Indoor Lighting
196	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Health	5.35	3.21	5.35	Cooling
197	Energy Star or Better PC	School	5.30	1.85	5.30	Office Equipment
198	Optimize Controls - DX	Restaurant	5.27	1.20	5.27	Cooling
199	Air Handler Optimization, 40 HP	Office	5.19	3.59	5.19	Ventilation
200	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	5.13	3.48	5.13	Heating
201	VSD for Chiller Pumps and Towers	on-Jurisdiction	5.11	1.88	5.11	Cooling
202	Window Film (Standard) - Chiller	Lodging	5.10	2.83	5.10	Cooling
203	LEDs (base incandescent A-line 53W) 2020	eligious Worshi	5.07	1882.79	5.07	Indoor Lighting
204	Variable Speed Drive Control, 40 HP	Retail	4.97	1.10	4.97	Ventilation
205	Data Center Improved Operations	on-Jurisdiction	4.88	110.15	4.88	Office Equipment
206	Heat Trap	Misc	4.74	4.22	4.74	Water Heating
207	Data Center State of the Art practices	Office	4.71	28.79	4.71	Office Equipment
208	ROB 2L4' High Performance T8 (86 W), 2020	eligious Worshi	4.70	1.25	4.70	Indoor Lighting
209	Electronically Commutated Motors (ECM) on an Air Handler Unit	Office	4.54	3.52	4.54	Ventilation
210	Energy Star or Better PC	Misc	4.50	2.06	4.50	Office Equipment
211	Data Center Best Practices	Lodging	4.45	44.69	4.45	Office Equipment
212	Heat Trap	Retail	4.33	3.02	4.33	Water Heating
213	PC Network Power Management Enabling	Health	4.32	2.61	4.32	Office Equipment
214	Data Center Best Practices	Health	4.32	44.45	4.32	Office Equipment
215	LED Exit Sign	Misc	4.30	2.06	4.30	Indoor Lighting
216	Energy Star Ice Machines	Misc	4.29	4.27	4.29	Refrigeration
217	Air Handler Optimization, 40 HP	Lodging	4.26	2.13	4.26	Ventilation
218	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	4.23	2.59	4.23	Indoor Lighting
219	Freezer-Cooler Replacement Gaskets (self-contained)	Misc	4.21	36.05	4.21	Refrigeration
220	Duct Testing/Sealing - Chiller	Data Centers	4.17	1.36	4.17	Cooling
221	Energy-Star Refrigerator, glass door	Restaurant	4.12	2.36	4.12	Refrigeration
222	High Performance Lighting R/R - 25% Savings (base metal halide)	Misc	4.10	1.47	4.10	Indoor Lighting
223	Fan Motor, 5hp, 1800rpm, 89.5%	Lodging	4.07	2.52	4.07	Ventilation
224	Energy Star Ice Machines	School	4.05	1.91	4.05	Refrigeration
225	PC Network Power Management Enabling	eligious Worshi	4.04	2.03	4.04	Office Equipment
226	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Lodging	4.01	1.02	4.01	Indoor Lighting
227	Heat Trap	School	3.93	1.37	3.93	Water Heating
228	LED Exit Sign	School	3.90	1.54	3.90	Indoor Lighting
229	Data Center Improved Operations	Lodging	3.89	109.76	3.89	Office Equipment
230	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	School	3.82	1.47	3.82	Indoor Lighting
231	Night covers for display cases (self-	on-Jurisdiction	3.79	80.03	3.79	Refrigeration
231	contained)	on-Jurisdiction	3./9	80.03	3./9	Kerrigeration

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
232	Data Center Improved Operations	Health	3.77	109.18	3.77	Office Equipment
233	Energy-Star Freezer, solid door	Restaurant	3.74	2.89	3.74	Refrigeration
234	Strip curtains for walk-ins (built-up) ROB 2L4' High Performance T8 (86 W),	Grocery	3.71	1.40	3.71	Refrigeration
235	2020	Lodging	3.66	2.12	3.66	Indoor Lighting
236	Outdoor Lighting Controls (Photocell/Timeclock) DX Packaged System, EER=13.4, 10	Warehouse	3.61	1.47	3.61	Outdoor Lighting
237	tons	Data Centers	3.53	7.92	3.53	Cooling
238	Tankless Water Heater	Lodging	3.43	1.43	3.43	Water Heating
239	Energy Star or Better Monitor - CRT	Misc	3.41	44.83	3.41	Office Equipment
240	Vending Misers (Refrigerated units)	Office	3.36	2.01	3.36	Vending
241	Solar Water Heater	Restaurant	3.35	1.60	3.35	Water Heating
242	Outdoor Lighting Controls (Photocell/Timeclock)	Lodging	3.35	1.37	3.35	Outdoor Lighting
243	Energy Star or Better PC	on-Jurisdiction	3.31	2.04	3.31	Office Equipment
244	Energy Star or Better PC	Warehouse	3.29	1.88	3.29	Office Equipment
245	ENERGY STAR Printer	School	3.22	38.09	3.22	Office Equipment
246	Energy-Star Refrigerator, solid door	Misc	3.16	11.68	3.16	Refrigeration
247	PC Network Power Management Enabling	Lodging	3.13	2.96	3.13	Office Equipment
248	Energy Star or Better PC	Retail	3.06	3.61	3.06	Office Equipment
249	Heat Trap	Lodging	3.04	4.50	3.04	Water Heating
250	Heat Trap	Restaurant	3.01	10.16	3.01	Water Heating
251	Vending Misers (Refrigerated units)	School	2.95	1.93	2.95	Vending
252	LED Exit Sign	on-Jurisdiction	2.95	2.12	2.95	Indoor Lighting
253	Vending Misers (Refrigerated units)	Retail	2.94	2.11	2.94	Vending
254	Fan Motor, 5hp, 1800rpm, 89.5%	on-Jurisdiction		2.54	2.93	Ventilation
255	Chiller Tune Up/Diagnostics	Lodging	2.87	1.81	2.87	Cooling
256	ROB 2L4' Low Watt High Performance T8 (75 W), 2020 Lighting Control Tuneup (base other	Опісе	2.85	1.23	2.85	Indoor Lighting
257	fluorescent fixture)	Office	2.83	18.04	2.83	Indoor Lighting
258	Energy-Star Freezer, glass door	Grocery	2.81	2.31	2.81	Refrigeration
259	VSD for Chiller Pumps and Towers Freezer-Cooler Replacement Gaskets	Misc	2.80	1.79	2.80	Cooling
260	(self-contained)	School	2.80	13.65	2.80	Refrigeration
261	LED Exit Sign	Lodging	2.74	1.91	2.74	Indoor Lighting
262	Electronically Commutated Motors (ECM) on an Air Handler Unit	Retail	2.73	2.58	2.73	Ventilation
263	Vending Misers (Refrigerated units)	Misc	2.68	1.91	2.68	Vending
264	LEDs (base incandescent flood) 2020	School	2.66	7612.76	2.66	Indoor Lighting
265	Freezer-Cooler Replacement Gaskets (self-contained)	Office	2.65	24.92	2.65	Refrigeration
266	ENERGY STAR Printer	Misc	2.64	43.63	2.64	Office Equipment
267	Data Center State of the Art practices	Misc	2.61	23.47	2.61	Office Equipment
268	ENERGY STAR Printer	on-Jurisdiction	2.61	43.26	2.61	Office Equipment
269	ROB 2L4' High Performance T8 (86 W), 2020	Office	2.60	2.56	2.60	Indoor Lighting
270	Energy Star or Better Monitor - CRT	Retail	2.59	37.31	2.59	Office Equipment
271	Energy-Star Refrigerator, solid door	School	2.58	5.27	2.58	Refrigeration
272	LEDs (base incandescent flood) 2020	Data Centers	2.54	7768.61	2.54	Indoor Lighting
273	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	2.53	2.03	2.53	Heating
274	Heat Recovery Unit	Misc	2.51	1.17	2.51	Water Heating

/A Com	mercial: All Existing Measures Ran	ked by Econo	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
275	Energy Star or Better Monitor - CRT	on-Jurisdiction	2.47	50.37	2.47	Office Equipment
276	LEDs (base incandescent A-line 72W) 2020	Health	2.43	3442.48	2.43	Indoor Lighting
277	Printer Power Management Enabling	Office	2.43	1.10	2.43	Office Equipment
278	Data Center State of the Art practices	Warehouse	2.42	23.93	2.42	Office Equipment
279	PC Network Power Management Enabling	Restaurant	2.40	2.61	2.40	Office Equipment
280	Centrifugal Chiller, 0.51 kW/ton, 500 tons	eligious Worshi	2.38	1.61	2.38	Cooling
281	Freezer-Cooler Replacement Gaskets (self-contained)	on-Jurisdiction	2.38	32.97	2.38	Refrigeration
282	High Efficiency Water Heater (electric)	Office	2.33	2.40	2.33	Water Heating
283	LED Exit Sign	Restaurant	2.32	1.03	2.32	Indoor Lighting
284	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Data Centers	2.29	7.42	2.29	Cooling
285	Ceiling/roof Insulation - Chiller	on-Jurisdiction	2.27	14.48	2.27	Cooling
286	Energy Star or Better Monitor - CRT	Lodging	2.26	40.15	2.26	Office Equipment
287	T5 (240W) (base metal halide)	Grocery	2.23	5.54	2.23	Indoor Lighting
288	Vending Misers (Refrigerated units)	Lodging	2.21	2.01	2.21	Vending
289	Energy Star Ice Machines	on-Jurisdiction	2.20	6.56	2.20	Refrigeration
290	Data Center State of the Art practices	on-Jurisdiction	2.15	23.26	2.15	Office Equipment
291	Fan Motor, 5hp, 1800rpm, 89.5%	School	2.14	1.04	2.14	Ventilation
292	Lighting Control Tuneup (base 4L4'T8), 2020	Misc	2.13	3.89	2.13	Indoor Lighting
293	Energy Star or Better Monitor - CRT	Warehouse	2.08	41.45	2.08	Office Equipment
294	Fan Motor, 5hp, 1800rpm, 89.5%	Warehouse	2.08	1.94	2.08	Ventilation
295	Energy Star or Better Copier	Office	2.06	38.91	2.06	Office Equipment
296	Tankless Water Heater	on-Jurisdiction	2.04	1.72	2.04	Water Heating
297	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Office	2.03	3.35	2.03	Indoor Lighting
298	Energy-Star Refrigerator, glass door	on-Jurisdiction	1.98	8.65	1.98	Refrigeration
299	Lighting Control Tuneup (base 4L4'T8), 2020	Retail	1.97	4.32	1.97	Indoor Lighting
300	Energy Star Ice Machines	eligious Worshi	1.97	2.15	1.97	Refrigeration
301	Energy-Star Refrigerator, solid door	on-Jurisdiction	1.95	18.24	1.95	Refrigeration
302	Tankless Water Heater	Restaurant	1.94	1.87	1.94	Water Heating
303	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Retail	1.93	2.92	1.93	Cooling
304	Energy-Star Freezer, glass door	Lodging	1.92	21.14	1.92	Refrigeration
305	Air Handler Optimization, 40 HP	Retail	1.89	2.31	1.89	Ventilation
306	Data Center Best Practices	Retail	1.85	46.26	1.85	Office Equipment
307	Occupancy Sensor, High Bay T5 Vending Misers (Refrigerated glass-front	Misc	1.83	2.14	1.83	Indoor Lighting
308	units)	Office	1.82	1.09	1.82	Vending
309	Demand controlled circulating systems	Lodging	1.82	2.32	1.82	Water Heating
310	ROB 2L4' High Performance T8 (86 W), 2020	Health	1.80	1.45	1.80	Indoor Lighting
311	Energy Star or Better PC	Lodging	1.79	3.85	1.79	Office Equipment
312	Energy-Star Freezer, glass door	Retail	1.77	1.64	1.77	Refrigeration
313	High Efficiency Water Heater (electric)	Misc	1.74	2.26	1.74	Water Heating
314	Data Center State of the Art practices	Lodging	1.71	23.18	1.71	Office Equipment
315	New Economizer - Chiller	Data Centers	1.71	2.86	1.71	Cooling

/A Com	A Commercial: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use			
316	Data Center State of the Art practices	Health	1.66	23.05	1.66	Office Equipment			
317	Lighting Control Tuneup (base 2L4'T8), 2020	Misc	1.64	3.16	1.64	Indoor Lighting			
318	Monitor Power Management Enabling - CRT	School	1.64	2.47	1.64	Office Equipment			
319	LEDs (base incandescent A-line 53W) 2020	Health	1.63	2306.27	1.63	Indoor Lighting			
320	Air Handler Optimization, 15 HP	Retail	1.62	1.97	1.62	Ventilation			
321	Data Center Improved Operations	Retail	1.61	113.63	1.61	Office Equipment			
322	Freezer-Cooler Replacement Gaskets (self-contained)	Lodging	1.61	27.75	1.61	Refrigeration			
323	Vending Misers (Refrigerated glass-front units)	School	1.61	1.05	1.61	Vending			
324	Vending Misers (Refrigerated units)	Grocery	1.61	2.07	1.61	Vending			
325	Energy Star or Better Monitor - CRT	Restaurant	1.60	29.38	1.60	Office Equipment			
326	ENERGY STAR Printer	Warehouse	1.60	40.36	1.60	Office Equipment			
327	Vending Misers (Refrigerated glass-front units)	Retail	1.59	1.14	1.59	Vending			
328	Energy Star or Better PC	Health	1.59	1.24	1.59	Office Equipment			
329	Vending Misers (Refrigerated units)	Warehouse	1.57	2.39	1.57	Vending			
330	High Efficiency Water Heater (electric)	Retail	1.56	1.62	1.56	Water Heating			
331	Energy Star or Better PC	eligious Worshi	1.53	1.03	1.53	Office Equipment			
332	ENERGY STAR Printer	Retail	1.52	36.32	1.52	Office Equipment			
333	Heat Trap	on-Jurisdiction	1.52	4.53	1.52	Water Heating			
334	Energy-Star Refrigerator, solid door	eligious Worshi	1.51	5.91	1.51	Refrigeration			
335	Energy Star or Better Monitor - LCD	Office	1.48	7.77	1.48	Office Equipment			
336	Vending Misers (Refrigerated glass-front units)	Misc	1.47	1.05	1.47	Vending			
337	Chiller Tune Up/Diagnostics	on-Jurisdiction	1.46	2.59	1.46	Cooling			
338	Energy Star or Better Copier	Retail	1.43	27.60	1.43	Office Equipment			
339	High Performance Lighting R/R - 25% Savings (base metal halide)	Lodging	1.43	1.33	1.43	Indoor Lighting			
340	Energy Star or Better Monitor - CRT	Health	1.41	28.73	1.41	Office Equipment			
341	Vending Misers (Refrigerated units)	on-Jurisdiction	1.41	1.28	1.41	Vending			
342	Economizer - DX	Data Centers	1.37	2.07	1.37	Cooling			
343	Hot Water Pipe Insulation	Misc	1.36	1.25	1.36	Water Heating			
344	Fan Motor, 5hp, 1800rpm, 89.5%	Grocery	1.36	1.39	1.36	Ventilation			
345	Variable Speed Drive Control, 40 HP	Data Centers	1.35	6.40	1.35	Ventilation			
346	ROB 4L4' High Performance T8 (86 W), 2020	Restaurant	1.34	1.80	1.34	Indoor Lighting			
347	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	1.32	2.26	1.32	Heating			
348	•	eligious Worshi	1.32	2.11	1.32	Water Heating			
349	Night covers for display cases (self- contained)	Grocery	1.30	168.80	1.30	Refrigeration			
350	Energy Star or Better Copier	Misc	1.30	33.51	1.30	Office Equipment			
351	Freezer-Cooler Replacement Gaskets (self-contained)	eligious Worshi	1.30	18.30	1.30	Refrigeration			
352	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	1.29	3.85	1.29	Cooling			
353	Variable Speed Drive Control, 15 HP	Data Centers	1.27	32.21	1.27	Ventilation			
354	Air Handler Optimization, 40 HP	Data Centers	1.25	5.48	1.25	Ventilation			
355	Energy Star or Better Monitor - LCD	School	1.23	5.74	1.23	Office Equipment			
356	Energy-Star Refrigerator, glass door	Misc	1.23	11.89	1.23	Refrigeration			
357	VSD for Chiller Pumps and Towers	Office	1.20	2.58	1.20	Cooling			

	VA Commercial: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use			
358	Vending Misers (Refrigerated glass-front	Lodging	1.20	1.09	1.20	Vending			
359	units) T5 (240W) (base metal halide)	eligious Worshi	1.12	2.57	1.12	Indoor Lighting			
360	High Efficiency Water Heater (electric)	Restaurant	1.10	5.45	1.10	Water Heating			
	Lighting Control Tuneup (base 2L4'T8),	Restaurant				water ricating			
361	2020	on-Jurisdiction	1.09	3.25	1.09	Indoor Lighting			
362	Air Handler Optimization, 15 HP	Data Centers	1.09	5.09	1.09	Ventilation			
363	Energy-Star Freezer, glass door	School	1.09	8.71	1.09	Refrigeration			
364	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Data Centers	1.08	1.26	1.08	Indoor Lighting			
365	Floating head pressure controls	Grocery	1.06	2.92	1.06	Refrigeration			
366	High Performance Lighting R/R - 25%	Restaurant	1.06	5.76	1.06	Indoor Lighting			
367	Savings (base 4L4'T8), 2020 LED Exit Sign	Warehouse	1.03	1.10	1.03	Indoor Lighting			
368	Energy Star or Better Laptop	Office	1.02	6.28	1.02	Office Equipment			
369	Ceiling/roof Insulation - Chiller	Misc	1.00	6.27	1.00	Cooling			
370	Energy Star Ice Machines	Lodging	1.00	2.48	1.00	Refrigeration			
371	Energy Star or Better Monitor - LCD	Misc	0.99	6.57	0.99	Office Equipment			
372 l	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Lodging	0.99	1.29	0.99	Indoor Lighting			
373	Night covers for display cases (self- contained)	Office	0.99	52.72	0.99	Refrigeration			
374	PC Network Power Management Enabling	Grocery	0.97	2.24	0.97	Office Equipment			
375	Monitor Power Management Enabling - CRT	Office	0.97	5.54	0.97	Office Equipment			
376	Energy Star or Better PC	Restaurant	0.97	1.32	0.97	Office Equipment			
377	ROB 4L4' High Performance T8 (86 W), 2020	Data Centers	0.96	2.62	0.96	Indoor Lighting			
378	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	on-Jurisdiction	0.96	1.53	0.96	Indoor Lighting			
379	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	0.95	3.20	0.95	Heating			
380	Fan Motor, 15hp, 1800rpm, 92.4%	on-Jurisdiction	0.94	5.58	0.94	Ventilation			
381	LEDs (base incandescent A-line 72W) 2020	School	0.94	5365.62	0.94	Indoor Lighting			
382	High Efficiency Water Heater (electric)	Lodging	0.93	2.02	0.93	Water Heating			
383	Vending Misers (Refrigerated units)	Health	0.92	1.96	0.92	Vending			
384	Efficient compressor motor	Grocery	0.92	3.73	0.92	Refrigeration			
385	fluorescent fixture)	on-Jurisdiction	0.91	10.96	0.91	Indoor Lighting			
386	ROB 4L4' High Performance T8 (86 W), 2020	Lodging	0.90	2.69	0.90	Indoor Lighting			
387	Ceiling/roof Insulation - Chiller	Office	0.90	19.26	0.90	Cooling			
388	Night covers for display cases (self- contained)	eligious Worshi	0.90	19.07	0.90	Refrigeration			
389	LEDs (base incandescent A-line 72W) 2020	Data Centers	0.89	5476.96	0.89	Indoor Lighting			
390	Data Center Best Practices	eligious Worshi		31.12	0.89	Office Equipment			
391	- ·	eligious Worshi		22.42	0.88	Office Equipment			
392	ENERGY STAR Multi-Function Printer	Office	0.88	10.60	0.88	Office Equipment			
393		eligious Worshi	0.88	1.07	0.88	Indoor Lighting			
394	Vending Misers (Refrigerated glass-front units)	Grocery	0.87	1.12	0.87	Vending			
395 396	Vending Misers (Refrigerated glass-front units) Energy Star or Better Monitor - LCD	Warehouse on-Jurisdiction	0.84 0.82	1.27 6.70	0.84 0.82	Vending Office Equipment			

A Commercial: All Existing Measures Ranked by Economic Potential (GWh)							
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use	
397	Energy-Star Refrigerator, glass door	Office	0.81	8.94	0.81	Refrigeration	
398	Electronically Commutated Motors (ECM) on an Air Handler Unit	Data Centers	0.81	6.42	0.81	Ventilation	
399	Energy-Star Refrigerator, glass door	School	0.79	2.89	0.79	Refrigeration	
400	Energy-Star Freezer, solid door	Lodging	0.79	8.42	0.79	Refrigeration	
401	Data Center Improved Operations	eligious Worshi	0.78	76.43	0.78	Office Equipment	
402	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Data Centers	0.75	4.57	0.75	Indoor Lighting	
403	Heat Trap	Health	0.75	1.55	0.75	Water Heating	
404 405	Energy Star or Better Copier Heat Pump Upgrade (15 SEER, 8.2	on-Jurisdiction Retail	0.74 0.74	33.87 1.37	0.74 0.74	Office Equipment Heating	
406	HSPF) Fan Motor, 5hp, 1800rpm, 89.5%	Health	0.73	2.99	0.73	Ventilation	
407	ENERGY STAR Printer	Health	0.73	27.28	0.73	Office Equipment	
408	Data Center State of the Art practices	Retail	0.71	23.99	0.71	Office Equipment	
409	Energy Star or Better Laptop	School	0.70	4.91	0.70	Office Equipment	
410	Freezer-Cooler Replacement Gaskets (self-contained)	Grocery	0.69	3.88	0.69	Refrigeration	
411	Chiller Tune Up/Diagnostics	School	0.69	1.26	0.69	Cooling	
412	Night covers for display cases (self-	Health	0.68	12.57	0.68	Refrigeration	
413	contained) Vending Misers (Refrigerated units)	eligious Worshi	0.68	1.91	0.68	Vending	
414	Monitor Power Management Enabling - CRT	Misc	0.67	2.93	0.67	Office Equipment	
415	Efficient Steamer	School	0.65	1.10	0.65	Cooking	
416	Freezer-Cooler Replacement Gaskets	Health	0.64	10.86	0.64	Refrigeration	
417	(self-contained) Heat Trap	Grocery	0.63	2.53	0.63	Water Heating	
418	Data Center Best Practices	Restaurant	0.63	41.07	0.63	Office Equipment	
419	EMS - Chiller	Data Centers	0.62	3.64	0.62	Cooling	
420	LEDs (base incandescent A-line 53W) 2020	School	0.62	3559.53	0.62	Indoor Lighting	
421	Vending Misers (Refrigerated units)	Restaurant	0.62	1.94	0.62	Vending	
422	Energy Star or Better Monitor - LCD	Warehouse	0.60	5.91	0.60	Office Equipment	
423	LEDs (base incandescent A-line 53W) 2020	Data Centers	0.59	3637.94	0.59	Indoor Lighting	
424	Occupancy Sensor, High Bay T5	Lodging	0.59	1.01	0.59	Indoor Lighting	
425	Energy-Star Refrigerator, glass door	eligious Worshi	0.58	6.03	0.58	Refrigeration	
426	Demand controlled circulating systems	Health	0.57	1.76	0.57	Water Heating	
427	Duct Testing/Sealing - DX	Data Centers	0.56	1.01	0.56	Cooling	
428	High Efficiency Water Heater (electric)	on-Jurisdiction	0.55	2.42	0.55	Water Heating	
429	Chiller Tune Up/Diagnostics	Office	0.55	3.52	0.55	Cooling	
430	Data Center Improved Operations	Restaurant	0.55	100.89	0.55	Office Equipment	
431	High Performance Lighting R/R - 25% Savings (base metal halide)	Grocery	0.55	11.19	0.55	Indoor Lighting	
432	Energy Star or Better Copier	Warehouse	0.55	31.50	0.55	Office Equipment	
433	High Efficiency Chiller Motors	on-Jurisdiction		2.12	0.54	Cooling	
434 435	Energy-Star Refrigerator, solid door Monitor Power Management Enabling -	Lodging Warehouse	0.54 0.52	6.69 2.26	0.54 0.52	Refrigeration Office Equipment	
436	CRT LED Exit Sign	Health	0.52	2.10	0.52	Indoor Lighting	
436		пеанн eligious Worshi	0.52	2.10	0.52	Office Equipment	
438	Energy Star or Better Copier	School	0.51	31.84	0.51	Office Equipment	

Rank	Measure Name	Building	Technical	Measure	Economic	End Use
Kalik		Туре	GWh	TRC	GWh	Liiu 03e
439	Vending Misers (Refrigerated glass-front units)	Health	0.50	1.07	0.50	Vending
440	Energy Star Ice Machines	Office	0.50	3.16	0.50	Refrigeration
441	Occupancy Sensor, High Bay T5	on-Jurisdiction	0.49	1.95	0.49	Indoor Lighting
442	Monitor Power Management Enabling - CRT	on-Jurisdiction	0.49	3.71	0.49	Office Equipmen
443		eligious Worshi	0.49	16.75	0.49	Office Equipmer
444	Lighting Control Tuneup (base 2L4'T8),	School	0.48	1.68	0.48	Indoor Lighting
445	2020 VSD for Chiller Pumps and Towers	Lodging	0.48	1.24	0.48	Cooling
446	†	eligious Worshi	0.48	1.13	0.48	
	, , , ,					Water Heating
447	Prog. Thermostat - DX	Data Centers	0.48 0.46	1.45 3.59	0.48	Cooling
448 449	Energy-Star Refrigerator, solid door Energy-Star Freezer, solid door	Health School	0.45	3.59 3.48	0.46 0.45	Refrigeration Refrigeration
	Outdoor Lighting Controls					_
450	(Photocell/Timeclock)	eligious Worshi	0.45	1.26	0.45	Outdoor Lightin
451	Energy-Star Freezer, glass door	on-Jurisdiction	0.44	19.38	0.44	Refrigeration
452	Energy Star or Better Copier	Health	0.44	20.12	0.44	Office Equipmen
453 454	Ceiling/roof Insulation - DX Energy Star Ice Machines	School Health	0.43 0.43	4.05 1.31	0.43 0.43	Cooling Refrigeration
	Monitor Power Management Enabling -					
455	CRT	Lodging	0.43	2.83	0.43	Office Equipme
456	Fan Motor, 15hp, 1800rpm, 92.4%	Office	0.41	7.96	0.41	Ventilation
457	Energy Star or Better Monitor - LCD Heat Pump Upgrade (15 SEER, 8.2	Retail	0.40	5.75	0.40	Office Equipme
458	HSPF)	on-Jurisdiction	0.40	2.75	0.40	Heating
459	Lighting Control Tuneup (base 2L4'T8), 2020	Retail	0.39	2.53	0.39	Indoor Lighting
460	Energy Star or Better PC	Grocery	0.38	1.12	0.38	Office Equipme
461	ENERGY STAR Multi-Function Printer	Retail	0.38	7.90	0.38	Office Equipmen
462	Chiller Tune Up/Diagnostics	Misc	0.38	2.49	0.38	Cooling
463	Energy Star or Better Laptop	on-Jurisdiction	0.38	5.58	0.38	Office Equipme
464	ENERGY STAR Printer	Lodging	0.38	39.14	0.38	Office Equipme
465	Monitor Power Management Enabling - CRT	Health	0.38	1.69	0.38	Office Equipme
466	Vending Misers (Refrigerated glass-front	eligious Worshi	0.37	1.05	0.37	Vending
467	units) Variable Speed Drive Control, 5 HP	Data Centers	0.37	8.90	0.37	Ventilation
468	ENERGY STAR Multi-Function Printer	Misc	0.37	9.49	0.37	Office Equipmen
469	Energy-Star Refrigerator, solid door	Office	0.36	8.53	0.36	Refrigeration
470		eligious Worshi	0.35	3.14	0.35	Cooling
471	Fan Motor, 15hp, 1800rpm, 92.4%	Health	0.34	5.28	0.34	Ventilation
472	Data Center State of the Art practices	eligious Worshi	0.34	16.14	0.34	Office Equipme
473	Vending Misers (Refrigerated glass-front	Restaurant	0.34	1.06	0.34	Vending
474	units) VSD for Chiller Pumps and Towers		0.34	1.76	0.34	Cooling
474	VSD for Chiller Pumps and Towers ENERGY STAR Printer	Grocery Restaurant	0.34	28.59	0.34	Office Equipmen
476		eligious Worshi	0.34	3.29	0.34	Office Equipmen
477	DX Tune Up/ Advanced Diagnostics	Restaurant	0.33	1.05	0.33	Cooling
478	High Efficiency Chiller Motors	Office	0.33	2.86	0.33	Cooling
479	Energy Star or Better Copier	Restaurant	0.33	21.61	0.33	Office Equipme
480	Monitor Power Management Enabling -	Retail	0.33	2.86	0.33	Office Equipme
481	CRT Energy Star or Better Monitor - LCD	Health	0.32	4.03	0.32	Office Equipme

/A Commercial: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use		
482	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Grocery	0.32	3.20	0.32	Cooling		
483	Energy-Star Refrigerator, glass door	Health	0.32	3.70	0.32	Refrigeration		
484	Hot Water Pipe Insulation	Restaurant	0.31	1.25	0.31	Water Heating		
485	Monitor Power Management Enabling - CRT	Restaurant	0.31	1.91	0.31	Office Equipmen		
486	Lighting Control Tuneup (base 4L4'T8), 2020	eligious Worshi	0.30	1.12	0.30	Indoor Lighting		
487	Fan Motor, 40hp, 1800rpm, 94.1%	School	0.30	2.30	0.30	Ventilation		
488	ROB 2L4' High Performance T8 (86 W), 2020	Warehouse	0.30	2.15	0.30	Indoor Lighting		
489	Energy Star or Better Laptop	Misc	0.28	5.63	0.28	Office Equipmer		
490	High Efficiency Chiller Motors	School	0.27	1.01	0.27	Cooling		
491	ENERGY STAR Multi-Function Printer	School	0.27	8.29	0.27	Office Equipmer		
492	Economizer Repair - DX	Data Centers	0.26	2.49	0.26	Cooling		
493	ENERGY STAR Multi-Function Printer	Warehouse	0.26	8.78	0.26	Office Equipmer		
494	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Data Centers	0.24	11.09	0.24	Cooling		
495	Energy Star or Better Laptop	Warehouse	0.24	5.21	0.24	Office Equipme		
496	Energy Star or Better Copier	Lodging	0.24	31.34	0.24	Office Equipmen		
497	Data Center State of the Art practices	Restaurant	0.24	21.30	0.24	Office Equipme		
498	Energy Star or Better Monitor - LCD	Restaurant	0.24	4.20	0.24	Office Equipme		
499	Energy-Star Freezer, glass door	Office	0.24	26.55	0.24	Refrigeration		
500	High Efficiency Water Heater (electric)	Grocery	0.23	1.35	0.23	Water Heating		
501	ENERGY STAR Multi-Function Printer	on-Jurisdiction	0.23	9.41	0.23	Office Equipme		
502	Energy Star or Better Monitor - CRT	Grocery	0.23	24.86	0.23	Office Equipmen		
503	Lighting Control Tuneup (base 2L4'T8), 2020	Office	0.22	3.73	0.22	Indoor Lighting		
504	Optimize Controls - DX	Data Centers	0.22	2.40	0.22	Cooling		
505	Outdoor Lighting Controls (Photocell/Timeclock)	Data Centers	0.21	2.90	0.21	Outdoor Lightin		
506	Lighting Control Tuneup (base 4L4'T8), 2020	Health	0.21	2.53	0.21	Indoor Lighting		
507	ENERGY STAR Multi-Function Printer	Restaurant	0.21	6.22	0.21	Office Equipme		
508	Window Film (Standard) - Chiller	Grocery	0.21	1.09	0.21	Cooling		
509	Window Film (Standard) - DX	Data Centers	0.21	1.49	0.21	Cooling		
510	Lighting Control Tuneup (base other fluorescent fixture)	School	0.20	2.28	0.20	Indoor Lighting		
511	Ceiling/roof Insulation - Chiller	Retail	0.20	4.77	0.20	Cooling		
512	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Warehouse	0.19	1.35	0.19	Indoor Lighting		
513	High Efficiency Chiller Motors	Health	0.19	2.07	0.19	Cooling		
514	Energy-Star Freezer, solid door	on-Jurisdiction	0.18	7.69	0.18	Refrigeration		
515	Energy Star or Better Monitor - LCD	Lodging	0.18	6.47	0.18	Office Equipme		
516	Monitor Power Management Enabling -	eligious Worshi	0.17	1.46	0.17	Office Equipme		
517	CRT VSD for Chiller Pumps and Towers	Data Centers	0.17	5.44	0.17	Cooling		
518	Energy Star or Better Laptop	Retail	0.16	4.69	0.16	Office Equipmen		
519	Ceiling/roof Insulation - DX	Grocery	0.15	3.88	0.15	Cooling		
520	Occupancy Sensor, High Bay T5	Grocery	0.15	1.57	0.15	Indoor Lighting		
521	Lighting Control Tuneup (base 4L4'T8),	Grocery	0.14	5.63	0.14	Indoor Lighting		
522	2020 Chiller Tune Up/Diagnostics	Retail	0.14	2.21	0.14	Cooling		
523	Lighting Control Tuneup (base other fluorescent fixture)	Misc	0.13	4.97	0.13	Indoor Lighting		

VA Comi	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
524	Energy Star or Better Monitor - LCD	Grocery	0.13	3.55	0.13	Office Equipment
525	VSD for Chiller Pumps and Towers	Health	0.13	2.10	0.13	Cooling
526	Lighting Control Tuneup (base 2L4'T8), 2020	Restaurant	0.13	3.07	0.13	Indoor Lighting
527	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	eligious Worshi	0.13	1.02	0.13	Heating
528	Chiller Tune Up/Diagnostics	Restaurant	0.13	4.19	0.13	Cooling
529	PC Network Power Management Enabling	Data Centers	0.13	3.68	0.13	Office Equipment
530	Ceiling/roof Insulation - DX	Restaurant	0.12	8.05	0.12	Cooling
531	Ceiling/roof Insulation - Chiller	Data Centers	0.12	32.66	0.12	Cooling
532	ENERGY STAR Multi-Function Printer	eligious Worshi	0.12	4.75	0.12	Office Equipment
533	Energy Star or Better Laptop	eligious Worshi	0.12	2.82	0.12	Office Equipment
534	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Warehouse	0.11	1.77	0.11	Heating
535	High Efficiency Chiller Motors	Grocery	0.11	2.04	0.11	Cooling
536	T5 (240W) (base metal halide)	Restaurant	0.11	5.02	0.11	Indoor Lighting
537	ENERGY STAR Multi-Function Printer	Health	0.11	5.94	0.11	Office Equipment
538	Energy Star or Better Copier	Grocery	0.11	17.09	0.11	Office Equipment
539	Energy-Star Freezer, solid door	Office	0.10	10.62	0.10	Refrigeration
540	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Retail	0.10	1.14	0.10	Indoor Lighting
541	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	0.10	1.13	0.10	Heating
542	ENERGY STAR Multi-Function Printer	Lodging	0.10	8.52	0.10	Office Equipment
543	Energy Star or Better Laptop	Health	0.09	3.52	0.09	Office Equipment
544	Chiller Tune Up/Diagnostics	Health	0.09	2.81	0.09	Cooling
545	Energy Star or Better Laptop	Lodging	0.08	5.05	0.08	Office Equipment
546	Fan Motor, 15hp, 1800rpm, 92.4%	Data Centers	0.07	14.59	0.07	Ventilation
547	LED Exit Sign	Data Centers	0.07	2.00	0.07	Indoor Lighting
548	Monitor Power Management Enabling - CRT	Grocery	0.07	1.16	0.07	Office Equipment
549	Energy Star or Better Monitor - CRT	Data Centers	0.07	55.28	0.07	Office Equipment
550	High Efficiency Chiller Motors	Misc	0.06	2.07	0.06	Cooling
551	ENERGY STAR Printer	Grocery	0.06	24.20	0.06	Office Equipment
552	Fan Motor, 5hp, 1800rpm, 89.5%	Data Centers	0.06	6.62	0.06	Ventilation
553	Fan Motor, 40hp, 1800rpm, 94.1%	Data Centers	0.05	1.64	0.05	Ventilation
554	ENERGY STAR Multi-Function Printer	Grocery	0.05	5.27	0.05	Office Equipment
555	Window Film (Standard) - Chiller	Office	0.05	1.03	0.05	Cooling
556	Data Center Best Practices	Grocery	0.05	46.25	0.05	Office Equipment
557	High Efficiency Chiller Motors	Data Centers	0.04	4.82	0.04	Cooling
558	ROB 2L4' High Performance T8 (86 W), 2020	Grocery	0.04	1.26	0.04	Indoor Lighting
559	Lighting Control Tuneup (base other fluorescent fixture)	Warehouse	0.04	16.05	0.04	Indoor Lighting
560	Lighting Control Tuneup (base 2L4'T8), 2020	Warehouse	0.04	1.53	0.04	Indoor Lighting
561	Data Center Improved Operations	Grocery	0.04	113.60	0.04	Office Equipment
562	Energy Star or Better Laptop	Restaurant	0.04	3.69	0.04	Office Equipment
563	Freezer-Cooler Replacement Gaskets (self-contained)	Data Centers	0.04	27.07	0.04	Refrigeration
564	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Grocery	0.04	4.06	0.04	Indoor Lighting
565	Energy Star or Better PC	Data Centers	0.04	2.03	0.04	Office Equipment
566	Lighting Control Tuneup (base 4L4'T8), 2020	Data Centers	0.03	4.98	0.03	Indoor Lighting

/A Commercial: All Existing Measures Ranked by Economic Potential (GWh)								
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use		
567	Lighting Control Tuneup (base 4L4'T8), 2020	Lodging	0.03	1.06	0.03	Indoor Lighting		
568	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	0.03	1.53	0.03	Heating		
569	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Warehouse	0.03	2.16	0.03	Indoor Lighting		
570	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Data Centers	0.03	2.11	0.03	Indoor Lighting		
571	Lighting Control Tuneup (base other fluorescent fixture)	Health	0.02	6.81	0.02	Indoor Lighting		
572	Vending Misers (Refrigerated units)	Data Centers	0.02	5.70	0.02	Vending		
573	Lighting Control Tuneup (base 2L4'T8),	Health	0.02	1.07	0.02	Indoor Lighting		
574	2020 High Efficiency Chiller Motors		0.02		0.02			
	Lighting Control Tuneup (base other	eligious Worshi		1.04		Cooling		
575	fluorescent fixture)	eligious Worshi	0.02	1.60	0.02	Indoor Lighting		
576	Lighting Control Tuneup (base 4L4'T8), 2020	Restaurant	0.02	6.44	0.02	Indoor Lighting		
577	Lighting Control Tuneup (base other fluorescent fixture)	Lodging	0.02	2.57	0.02	Indoor Lighting		
578	Lighting Control Tuneup (base other fluorescent fixture)	Retail	0.02	7.82	0.02	Indoor Lighting		
579	Data Center State of the Art practices	Grocery	0.02	23.99	0.02	Office Equipmer		
580	Chiller Tune Up/Diagnostics	eligious Worshi	0.02	1.25	0.02	Cooling		
581	ROB 2L4' High Performance T8 (86 W),	Data Centers	0.02	2.06	0.02	Indoor Lighting		
582	2020 Chiller Tune Up/Diagnostics	Data Centers	0.01	8.37	0.01	Cooling		
583	Vending Misers (Refrigerated glass-front	Data Centers	0.01	3.14	0.01	Vending		
584	units) High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Data Centers	0.01	2.66	0.01	Indoor Lighting		
585	Energy Star or Better Laptop	Grocery	0.01	3.13	0.01	Office Equipmen		
586	Monitor Power Management Enabling - CRT	Data Centers	0.01	4.27	0.01	Office Equipmen		
587	Energy Star or Better Monitor - LCD	Data Centers	0.01	6.57	0.01	Office Equipmer		
588	ENERGY STAR Printer	Data Centers	0.01	41.08	0.01	Office Equipmer		
589	Ceiling/roof Insulation - DX	Misc	0.01	6.44	0.01	Cooling		
590	Window Film (Standard) - Chiller	Data Centers	0.01	1.92	0.01	Cooling		
591	Lighting Control Tuneup (base other fluorescent fixture)	Data Centers	0.01	13.99	0.01	Indoor Lighting		
592	Occupancy Sensor, High Bay T5	Restaurant	0.01	1.31	0.01	Indoor Lighting		
593	Chiller Tune Up/Diagnostics	Grocery	0.01	2.64	0.01	Cooling		
594	Energy Star or Better Copier	Data Centers	0.01	32.79	0.01	Office Equipmer		
595 596	LED Exit Sign High Efficiency Chiller Motors	Grocery Lodging	0.01	2.00 1.38	0.01	Indoor Lighting Cooling		
597	Energy Star or Better Laptop	Data Centers	0.00	5.31	0.01	Office Equipmer		
598	DX Tune Up/ Advanced Diagnostics	Data Centers	0.00	1.65	0.00	Cooling		
599	Ceiling/roof Insulation - DX	on-Jurisdiction	0.00	14.82	0.00	Cooling		
600	Ceiling/roof Insulation - DX	eligious Worshi	0.00	3.22	0.00	Cooling		
601	Energy-Star Refrigerator, glass door	Data Centers	0.00	9.73	0.00	Refrigeration		
602	ENERGY STAR Multi-Function Printer	Data Centers	0.00	8.94	0.00	Office Equipmer		
603	Energy Star Ice Machines	Data Centers	0.00	3.46	0.00	Refrigeration		
604	Energy-Star Refrigerator, solid door	Data Centers	0.00	9.32	0.00	Refrigeration		
605	Energy-Star Freezer, glass door	Data Centers	0.00	28.79	0.00	Refrigeration		
606	Lighting Control Tuneup (base 2L4'T8), 2020	Data Centers	0.00	2.89	0.00	Indoor Lighting		

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
607	Lighting Control Tuneup (base 2L4'T8),	Grocery	0.00	4.70	0.00	Indoor Lighting
608	2020 Energy-Star Freezer, solid door	Data Centers	0.00	11.53	0.00	Refrigeration
609	ROB 4L4' LED Tube, 2020	Office	173.03	0.29	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	Office	76.90	0.35	0.00	Indoor Lighting
609	ROB 2L4' LED Tube, 2020	Office	0.95	0.38	0.00	Indoor Lighting
609	Occupancy Sensor, 2L4' Fluorescent	Office	1.38	0.54	0.00	Indoor Lighting
609	Fixtures, 2020 LED Troffer (base 2L4'T8), 2020	Office	1.47	0.28	0.00	Indoor Lighting
609	ROB High Performance T8 (base other	Office	5.42	0.77	0.00	Indoor Lighting
609	fluorescent) Occupancy Sensor, 4L8' Fluorescent Fixtures	Office	6.23	0.56	0.00	Indoor Lighting
609	ROB Low Watt High Performance T8 (base other fluorescent)	Office	5.15	0.32	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 18W) 2020	Office	9.91	0.80	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 23W) 2020	Office	11.88	0.95	0.00	Indoor Lighting
609	LED Outdoor Area Lighting	Office	59.75	0.66	0.00	Outdoor Lighting
609	Bi-Level LED Outdoor Lighting	Office	16.29	0.10	0.00	Outdoor Lighting
609	Duct Testing/Sealing - Chiller	Office	30.08	0.77	0.00	Cooling
609	Cool Roof - Chiller	Office	0.40	0.41	0.00	Cooling
609	Duct/Pipe Insulation - Chiller	Office	0.39	0.05	0.00	Cooling
609	Optimize Controls - DX	Office	11.52	0.95	0.00	Cooling
609	Window Film (Standard) - DX	Office	13.71	0.92	0.00	Cooling
609	DX Tune Up/ Advanced Diagnostics	Office	1.18	0.83	0.00	Cooling
609	Economizer - DX	Office	71.25	0.82	0.00	Cooling
609	Duct Testing/Sealing - DX	Office	35.07	0.62	0.00	Cooling
609	Prog. Thermostat - DX	Office	11.52	0.56	0.00	Cooling
609	Cool Roof - DX	Office	4.52	0.37	0.00	Cooling
609	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Office	0.13	0.30	0.00	Cooling
609	Duct/Pipe Insulation - DX	Office	3.41	0.04	0.00	Cooling
609	Demand Controlled Ventilation	Office	21.29	0.17	0.00	Ventilation
609	Energy Recovery Ventilation (ERV)	Office	1.35	0.48	0.00	Ventilation
609	Demand Controlled Ventilation	Office	3.07	0.14	0.00	Ventilation
609	Fan Motor, 40hp, 1800rpm, 94.1%	Office	0.17	0.90	0.00	Ventilation
609	Demand Controlled Ventilation	Office	2.13	0.16	0.00	Ventilation
609	Reach-in unit occupancy sensors	Office	0.01	0.22	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014	Office	0.03	0.18	0.00	Refrigeration
609	Strip curtains for walk-ins (self- contained)	Office	0.09	0.01	0.00	Refrigeration
609	Laptop Network Power Management Enabling	Office	0.09	0.05	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Office	0.49	0.46	0.00	Office Equipment
609	Monitor Power Management Enabling - LCD	Office	0.73	0.75	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Office	0.71	0.26	0.00	Office Equipment
609	Copier Power Management Enabling	Office	0.80	0.70	0.00	Office Equipment
609	Multifunction Power Management Enabling	Office	0.48	0.24	0.00	Office Equipment
609	Hot Water Pipe Insulation	Office	0.53	0.62	0.00	Water Heating
609	Heat Recovery Unit	Office	3.18	0.54	0.00	Water Heating

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Demand controlled circulating systems	Office	1.37	0.20	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	Office	0.25	0.12	0.00	Vending
609	Xmisc	Office	0.00	0.00	0.00	Miscellaneous
609	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Restaurant	1.47	0.87	0.00	Indoor Lighting
609	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Restaurant	0.14	0.42	0.00	Indoor Lighting
609	ROB 4L4' LED Tube, 2020	Restaurant	1.60	0.17	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	Restaurant	0.71	0.20	0.00	Indoor Lighting
609	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Restaurant	8.73	0.68	0.00	Indoor Lighting
609	ROB 2L4' LED Tube, 2020	Restaurant	2.90	0.21	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020	Restaurant	4.87	0.17	0.00	Indoor Lighting
609	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Restaurant	0.74	0.20	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 18W) 2020	Restaurant	3.27	0.47	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 23W) 2020	Restaurant	3.92	0.56	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings (base metal halide)	Restaurant	0.02	0.06	0.00	Indoor Lighting
609	LED Outdoor Area Lighting	Restaurant	41.93	0.36	0.00	Outdoor Lighting
609	Bi-Level LED Outdoor Lighting	Restaurant	11.38	0.05	0.00	Outdoor Lighting
609	Duct Testing/Sealing - Chiller	Restaurant	10.92	0.95	0.00	Cooling
609	Prog. Thermostat - DX	Restaurant	6.59	0.87	0.00	Cooling
609	Duct Testing/Sealing - DX	Restaurant	16.38	0.84	0.00	Cooling
609	Economizer Repair - DX	Restaurant	12.66	0.71	0.00	Cooling
609	Cool Roof - DX	Restaurant	8.23	0.63	0.00	Cooling
609	Economizer - DX Dual Enthalpy Economizer Replaces Dry	Restaurant	5.16	0.39	0.00	Cooling
609 609	Bulb Economizer - DX Duct/Pipe Insulation - DX	Restaurant Restaurant	0.14 3.01	0.38 0.06	0.00 0.00	Cooling Cooling
609	Fan Motor, 5hp, 1800rpm, 89.5%	Restaurant	2.44	0.00	0.00	Ventilation
609	Variable Speed Drive Control, 5 HP	Restaurant	41.69	0.74	0.00	Ventilation
609	Demand Controlled Ventilation	Restaurant	13.08	0.72	0.00	Ventilation
609	Energy Star Ice Machines	Restaurant	8.09	0.11	0.00	Refrigeration
609	Reach-in unit occupancy sensors	Restaurant	0.23	0.21	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014	Restaurant	1.03	0.17	0.00	Refrigeration
609	Strip curtains for walk-ins (self- contained)	Restaurant	2.06	0.14	0.00	Refrigeration
609	Laptop Network Power Management Enabling	Restaurant	0.00	0.03	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Restaurant	0.07	0.18	0.00	Office Equipment
609	Monitor Power Management Enabling - LCD	Restaurant	0.08	0.38	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Restaurant	0.07	0.13	0.00	Office Equipment
609	Copier Power Management Enabling	Restaurant	0.18	0.35	0.00	Office Equipment
609	Multifunction Power Management Enabling	Restaurant	0.23	0.09	0.00	Office Equipment
609	Printer Power Management Enabling	Restaurant	0.23	0.42	0.00	Office Equipment
609	Demand controlled circulating systems	Restaurant	0.76	0.40	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	Restaurant	0.03	0.12	0.00	Vending
609	Convection Oven	Restaurant	6.16	0.13	0.00	Cooking

		Building	Technical	Measure	Economic	
Rank	Measure Name	Type	GWh	TRC	GWh	End Use
609	Efficient Fryer	Restaurant	2.15	0.04	0.00	Cooking
609	Efficient Steamer	Restaurant	29.72	0.28	0.00	Cooking
609	Xmisc	Restaurant	0.00	0.00	0.00	Miscellaneous
609	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Retail	8.49	0.54	0.00	Indoor Lighting
609	ROB 4L4' LED Tube, 2020	Retail	96.33	0.22	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	Retail	42.81	0.26	0.00	Indoor Lighting
609	ROB 2L4' Low Watt High Performance T8	Retail	17.66	0.87	0.00	Indoor Lighting
	(75 W), 2020					
609	ROB 2L4' LED Tube, 2020	Retail	5.85	0.27	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020 Occupancy Sensor, 2L4' Fluorescent	Retail	9.84	0.21	0.00	Indoor Lighting
609	Fixtures, 2020	Retail	1.48	0.26	0.00	Indoor Lighting
609	ROB High Performance T8 (base other	Retail	0.12	0.56	0.00	Indoor Lighting
	fluorescent) Occupancy Sensor, 4L8' Fluorescent					
609	Fixtures	Retail	0.04	0.45	0.00	Indoor Lighting
609	ROB Low Watt High Performance T8	Retail	0.13	0.26	0.00	Indoor Lighting
609	(base other fluorescent) LED screw-in replacement (base CFL	Retail	25.83	0.61	0.00	Indoor Lighting
009	18W) 2020 LED screw-in replacement (base CFL	Retail	23.63	0.01	0.00	Indoor Lighting
609	23W) 2020	Retail	30.97	0.74	0.00	Indoor Lighting
609	LED Outdoor Area Lighting	Retail	80.02	0.50	0.00	Outdoor Lightin
609	Bi-Level LED Outdoor Lighting	Retail	21.70	0.08	0.00	Outdoor Lightin
609	EMS - Chiller	Retail	1.71	0.88	0.00	Cooling
609	Duct Testing/Sealing - Chiller	Retail	3.57	0.54	0.00	Cooling
609	Cool Roof - DX	Retail	25.55	0.84	0.00	Cooling
609	Optimize Controls - DX	Retail	9.04	0.54	0.00	Cooling
609	DX Tune Up/ Advanced Diagnostics	Retail	2.19	0.50	0.00	Cooling
609	Economizer - DX	Retail	45.84	0.47	0.00	Cooling
609	Duct Testing/Sealing - DX	Retail	29.94	0.40	0.00	Cooling
609	Prog. Thermostat - DX	Retail	12.79	0.33	0.00	Cooling
609	Window Film (Standard) - DX	Retail	1.65	0.26	0.00	Cooling
609	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Retail	0.19	0.22	0.00	Cooling
609	Duct/Pipe Insulation - DX	Retail	3.29	0.03	0.00	Cooling
609	Demand Controlled Ventilation	Retail	39.87	0.09	0.00	Ventilation
609	Variable Speed Drive Control, 15 HP	Retail	4.25	0.92	0.00	Ventilation
609	Fan Motor, 15hp, 1800rpm, 92.4%	Retail	0.03	0.42	0.00	Ventilation
609	Energy Recovery Ventilation (ERV)	Retail	0.71	0.24	0.00	Ventilation
609	Demand Controlled Ventilation	Retail	1.01	0.06	0.00	Ventilation
609	Fan Motor, 40hp, 1800rpm, 94.1%	Retail	0.03	0.31	0.00	Ventilation
609	Demand Controlled Ventilation	Retail	1.27	0.08	0.00	Ventilation
609	Energy-Star Freezer, solid door	Retail	0.72	0.65	0.00	Refrigeration
609	Energy-Star Refrigerator, glass door	Retail	7.05	0.55	0.00	Refrigeration
	5, 5 , 5					_
609	Energy-Star Refrigerator, solid door	Retail	1.14	0.52	0.00	Refrigeration
609	Reach-in unit occupancy sensors	Retail	1.11	0.22	0.00	Refrigeration
609	Energy Star Ice Machines Bi-level LED Case Lighting (self-	Retail	0.76	0.19	0.00	Refrigeration
609	contained units) 2014	Retail	2.01	0.18	0.00	Refrigeration
609	Strip curtains for walk-ins (self- contained)	Retail	0.41	0.03	0.00	Refrigeration
609	Contained) Laptop Network Power Management Enabling	Retail	0.01	0.04	0.00	Office Equipmen

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Retail	0.13	0.26	0.00	Office Equipment
609	Monitor Power Management Enabling - LCD	Retail	0.10	0.56	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Retail	0.18	0.19	0.00	Office Equipment
609	Copier Power Management Enabling	Retail	0.41	0.48	0.00	Office Equipment
609	Multifunction Power Management Enabling	Retail	0.16	0.18	0.00	Office Equipment
609	Printer Power Management Enabling	Retail	0.40	0.84	0.00	Office Equipment
609	Solar Water Heater	Retail	2.01	0.99	0.00	Water Heating
609	Hot Water Pipe Insulation	Retail	1.15	0.87	0.00	Water Heating
609	Heat Recovery Unit	Retail	2.23	0.68	0.00	Water Heating
609	Demand controlled circulating systems	Retail	1.02	0.53	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	Retail	0.04	0.13	0.00	Vending
609	Convection Oven	Retail	3.05	0.25	0.00	Cooking
609	Efficient Fryer	Retail	0.16	0.08	0.00	Cooking
609	Efficient Steamer	Retail	6.12	0.63	0.00	Cooking
609	Xmisc	Retail	0.00	0.00	0.00	Miscellaneous
609	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Grocery	14.35	0.76	0.00	Indoor Lighting
609	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Grocery	1.46	0.54	0.00	Indoor Lighting
609	ROB 4L4' LED Tube, 2020	Grocery	15.63	0.14	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	Grocery	6.94	0.17	0.00	Indoor Lighting
609	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Grocery	0.05	0.61	0.00	Indoor Lighting
609	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Grocery	0.01	0.31	0.00	Indoor Lighting
609	ROB 2L4' LED Tube, 2020	Grocery	0.02	0.17	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020	Grocery	0.03	0.14	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 18W) 2020	Grocery	0.83	0.38	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 23W) 2020	Grocery	0.99	0.46	0.00	Indoor Lighting
609	Outdoor Lighting Controls (Photocell/Timeclock)	Grocery	0.24	0.87	0.00	Outdoor Lighting
609	LED Outdoor Area Lighting	Grocery	1.00	0.22	0.00	Outdoor Lighting
609	Bi-Level LED Outdoor Lighting	Grocery	0.27	0.03	0.00	Outdoor Lighting
609	EMS - Chiller	Grocery	0.28	0.88	0.00	Cooling
609	Cool Roof - Chiller	Grocery	0.19	0.72	0.00	Cooling
609	Duct Testing/Sealing - Chiller	Grocery	0.44	0.44	0.00	Cooling
609	Duct/Pipe Insulation - Chiller	Grocery	0.03	0.02	0.00	Cooling
609	New Economizer - Chiller	Grocery	0.00	0.00	0.00	Cooling
609	Cool Roof - DX	Grocery	6.48	0.78	0.00	Cooling
609	DX Tune Up/ Advanced Diagnostics	Grocery	0.09	0.58	0.00	Cooling
609	Optimize Controls - DX	Grocery	1.35	0.53	0.00	Cooling
609	Prog. Thermostat - DX	Grocery	1.13	0.47	0.00	Cooling
609	Duct Testing/Sealing - DX Dual Enthalpy Economizer Replaces Dry	Grocery	4.55	0.45	0.00	Cooling
609	Bulb Economizer - DX	Grocery	0.02	0.08	0.00	Cooling
609	Economizer Repair - DX	Grocery	0.76	0.06	0.00	Cooling
609	Economizer - DX	Grocery	0.01	0.03	0.00	Cooling
609	Duct/Pipe Insulation - DX	Grocery	1.04	0.03	0.00	Cooling
609	Demand Controlled Ventilation	Grocery	10.99	0.08	0.00	Ventilation

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Demand Controlled Ventilation	Grocery	14.37	0.11	0.00	Ventilation
609	Freezer-Cooler Replacement Gaskets	Grocery	14.25	0.96	0.00	Refrigeration
609	Oversized Air Cooled Condenser	Grocery	16.99	0.90	0.00	Refrigeration
609	Night covers for display cases	Grocery	20.37	0.75	0.00	Refrigeration
609	High-efficiency fan motors	Grocery	12.90	0.68	0.00	Refrigeration
609	Compressor VSD retrofit	Grocery	21.90	0.59	0.00	Refrigeration
609 609	Refrigeration Commissioning Evaporator fan controller for MT walk-	Grocery	1.70 0.23	0.29	0.00	Refrigeration
	ins	Grocery		0.26	0.00	Refrigeration
609 609	Multiplex Compressor System	Grocery	5.80 24.69	0.26 0.13	0.00 0.00	Refrigeration
609	LED Display Lighting High R-Value Glass Doors	Grocery Grocery	4.62	0.13	0.00	Refrigeration Refrigeration
609	Energy-Star Freezer, solid door	Grocery	1.11	0.03	0.00	Refrigeration
609	Energy-Star Refrigerator, glass door	Grocery	0.06	0.69	0.00	Refrigeration
609	Energy-Star Refrigerator, solid door	Grocery	0.02	0.66	0.00	Refrigeration
609	Energy Star Ice Machines	Grocery	0.02	0.00	0.00	Refrigeration
609	Reach-in unit occupancy sensors	Grocery	0.01	0.21	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014	Grocery	0.32	0.17	0.00	Refrigeration
609	Strip curtains for walk-ins (self- contained)	Grocery	0.16	0.08	0.00	Refrigeration
609	Laptop Network Power Management Enabling	Grocery	0.00	0.03	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Grocery	0.01	0.12	0.00	Office Equipment
609	Monitor Power Management Enabling - LCD	Grocery	0.07	0.30	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Grocery	0.03	0.10	0.00	Office Equipment
609	Copier Power Management Enabling	Grocery	0.06	0.26	0.00	Office Equipment
609	Multifunction Power Management Enabling	Grocery	0.04	0.09	0.00	Office Equipment
609	Printer Power Management Enabling	Grocery	0.03	0.43	0.00	Office Equipment
609	Tankless Water Heater	Grocery	0.41	0.46	0.00	Water Heating
609	Solar Water Heater	Grocery	0.71	0.40	0.00	Water Heating
609	Demand controlled circulating systems	Grocery	0.16	0.32	0.00	Water Heating
609	Hot Water Pipe Insulation	Grocery	0.08	0.30	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	Grocery Grocery	0.01	0.12	0.00	Vending
609 609	Efficient Steamer Xmisc	Grocery	15.29 0.00	0.46 0.00	0.00 0.00	Cooking Miscellaneous
609	Occupancy Sensor, 4L4' Fluorescent	Warehouse	6.26	0.61	0.00	Indoor Lighting
609	Fixtures, 2020 ROB 4L4' LED Tube, 2020	Warehouse	48.45	0.24	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	Warehouse	21.53	0.28	0.00	Indoor Lighting
609	ROB 2L4' Low Watt High Performance T8 (75 W), 2020		0.30	0.94	0.00	Indoor Lighting
609	(75 W), 2020 ROB 2L4' LED Tube, 2020	Warehouse	0.10	0.29	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020	Warehouse	0.17	0.23	0.00	Indoor Lighting
609	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Warehouse	0.04	0.29	0.00	Indoor Lighting
609	Occupancy Sensor, 4L8' Fluorescent Fixtures	Warehouse	0.02	0.58	0.00	Indoor Lighting
609	ROB High Performance T8 (base other fluorescent)	Warehouse	0.04	0.53	0.00	Indoor Lighting

Rank			/A Commercial: All Existing Measures Ranked by Economic Potential (GWh)									
	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use						
609	ROB Low Watt High Performance T8 (base other fluorescent)	Warehouse	0.04	0.25	0.00	Indoor Lighting						
609	LED screw-in replacement (base CFL 18W) 2020	Warehouse	4.88	0.64	0.00	Indoor Lighting						
609	LED screw-in replacement (base CFL 23W) 2020	Warehouse	5.85	0.77	0.00	Indoor Lighting						
609	LED Outdoor Area Lighting	Warehouse	47.16	0.55	0.00	Outdoor Lighting						
609	Bi-Level LED Outdoor Lighting	Warehouse	12.87	0.08	0.00	Outdoor Lighting						
609	Cool Roof - DX	Warehouse	15.16	0.89	0.00	Cooling						
609	Optimize Controls - DX	Warehouse	2.80	0.38	0.00	Cooling						
609	DX Packaged System, EER=13.4, 10 tons	Warehouse	42.73	0.27	0.00	Cooling						
609	Duct Testing/Sealing - DX	Warehouse	8.51	0.04	0.00	Cooling						
609	Window Film (Standard) - DX	Warehouse	5.79	0.04	0.00	Cooling						
609	Prog. Thermostat - DX	Warehouse	3.86	0.03	0.00	Cooling						
609	Duct/Pipe Insulation - DX	Warehouse	0.25	0.02	0.00	Cooling						
609	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Warehouse	0.07	0.02	0.00	Cooling						
609	Demand Controlled Ventilation	Warehouse	1.07	0.06	0.00	Ventilation						
609	Air Handler Optimization, 40 HP	Warehouse	2.76	0.83	0.00	Ventilation						
609	Demand Controlled Ventilation	Warehouse	0.33	0.05	0.00	Ventilation						
609	Refrigeration Commissioning	Warehouse	1.42	0.86	0.00	Refrigeration						
609	Electronically commutated evaporator fan motor	Warehouse	16.64	0.67	0.00	Refrigeration						
609	Evaporator fan controller for MT walk- ins	Warehouse	0.05	0.34	0.00	Refrigeration						
609	Strip curtains for walk-ins (built-up)	Warehouse	1.10	0.30	0.00	Refrigeration						
609	High-efficiency fan motors	Warehouse	7.87	0.17	0.00	Refrigeration						
609	Strip curtains for walk-ins (self- contained)	Warehouse	0.12	0.35	0.00	Refrigeration						
609	Laptop Network Power Management Enabling	Warehouse	0.02	0.04	0.00	Office Equipment						
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Warehouse	0.09	0.23	0.00	Office Equipment						
609	Monitor Power Management Enabling - LCD	Warehouse	0.03	0.60	0.00	Office Equipment						
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Warehouse	0.17	0.19	0.00	Office Equipment						
609	Copier Power Management Enabling	Warehouse	0.14	0.55	0.00	Office Equipment						
609	Multifunction Power Management Enabling	Warehouse	0.08	0.21	0.00	Office Equipment						
609	Printer Power Management Enabling	Warehouse	0.30	0.97	0.00	Office Equipment						
609	Heat Recovery Unit	Warehouse	1.32	0.25	0.00	Water Heating						
609	Heat Trap	Warehouse	0.99	0.14	0.00	Water Heating						
609	High Efficiency Water Heater (electric)	Warehouse	0.36	0.07	0.00	Water Heating						
609	Tankless Water Heater	Warehouse	1.33	0.05	0.00	Water Heating						
609	Solar Water Heater	Warehouse	5.62	0.05	0.00	Water Heating						
609	Hot Water Pipe Insulation	Warehouse	0.04	0.03	0.00	Water Heating						
609	Demand controlled circulating systems	Warehouse	0.21	0.02	0.00	Water Heating						
609	Vending Misers (Non-Refrigerated)	Warehouse	0.19	0.14	0.00	Vending						
609	Xmisc	Warehouse	0.00	0.00	0.00	Miscellaneous						
609	ROB 4L4' LED Tube, 2020	School	105.66	0.21	0.00	Indoor Lighting						
609	Occupancy Sensor, 4L4' Fluorescent	School	32.25	0.29	0.00	Indoor Lighting						
609	Fixtures, 2020 LED Troffer (base 4L4'T8), 2020	School	44.21	0.24	0.00	Indoor Lighting						

VA Comi	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	ROB 2L4' Low Watt High Performance T8	School	6.00	0.94	0.00	Indoor Lighting
609	(75 W), 2020 ROB 2L4' LED Tube, 2020	School	1.99	0.26	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020	School	3.34	0.21	0.00	Indoor Lighting
	Occupancy Sensor, 2L4' Fluorescent					<u> </u>
609	Fixtures, 2020	School	2.10	0.17	0.00	Indoor Lighting
609	ROB High Performance T8 (base other fluorescent) ROB Low Watt High Performance T8	School	0.36	0.65	0.00	Indoor Lighting
609	(base other fluorescent)	School	0.49	0.31	0.00	Indoor Lighting
609	Occupancy Sensor, 4L8' Fluorescent Fixtures	School	0.55	0.29	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	School	0.21	0.20	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL	School	18.39	0.62	0.00	Indoor Lighting
609	18W) 2020 LED screw-in replacement (base CFL 23W) 2020	School	22.06	0.74	0.00	Indoor Lighting
609	Occupancy Sensor, High Bay T5	School	2.51	0.99	0.00	Indoor Lighting
609	LED Outdoor Area Lighting	School	99.89	0.67	0.00	Outdoor Lighting
609	Bi-Level LED Outdoor Lighting	School	27.19	0.10	0.00	Outdoor Lighting
609	VSD for Chiller Pumps and Towers	School	0.48	0.94	0.00	Cooling
609	EMS - Chiller	School	14.63	0.52	0.00	Cooling
609	Cool Roof - Chiller	School	4.93	0.40	0.00	Cooling
609	Window Film (Standard) - Chiller	School	1.26	0.35	0.00	Cooling
609	Duct Testing/Sealing - Chiller	School	41.42	0.30	0.00	Cooling
609	New Economizer - Chiller	School	22.19	0.15	0.00	Cooling
609	Duct/Pipe Insulation - Chiller	School	1.11	0.01	0.00	Cooling
609	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	School	0.78	0.34	0.00	Cooling
609	DX Tune Up/ Advanced Diagnostics	School	0.85	0.32	0.00	Cooling
609	Window Film (Standard) - DX	School	5.03	0.32	0.00	Cooling
609	Optimize Controls - DX	School	8.30	0.29	0.00	Cooling
609	Duct Testing/Sealing - DX	School	28.34	0.27	0.00	Cooling
609	Prog. Thermostat - DX	School	4.41	0.24	0.00	Cooling
609	Cool Roof - DX	School	8.85	0.19	0.00	Cooling
609	Economizer Repair - DX	School	9.70	0.08	0.00	Cooling
609	Economizer - DX	School	2.36	0.04	0.00	Cooling
609	Duct/Pipe Insulation - DX	School	5.73	0.02	0.00	Cooling
609	HE PTAC, EER=9.6, 1 ton	School	69.26	0.77	0.00	Cooling
609	Demand Controlled Ventilation	School	18.28	0.04	0.00	Ventilation
609	Air Handler Optimization, 15 HP	School	27.86	0.68	0.00	Ventilation
609	Fan Motor, 15hp, 1800rpm, 92.4%	School	2.50	0.40	0.00	Ventilation
609	Energy Recovery Ventilation (ERV)	School	13.42	0.13	0.00	Ventilation
609	Demand Controlled Ventilation	School	36.27	0.03	0.00	Ventilation
609	Air Handler Optimization, 40 HP	School	13.47	0.79	0.00	Ventilation
609	Demand Controlled Ventilation	School	18.69	0.04	0.00	Ventilation
609	Reach-in unit occupancy sensors	School	0.04	0.21	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014	School	0.17	0.17	0.00	Refrigeration
609	Strip curtains for walk-ins (self- contained)	School	0.16	0.05	0.00	Refrigeration
609	Laptop Network Power Management Enabling	School	0.06	0.04	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	School	0.34	0.23	0.00	Office Equipment

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Monitor Power Management Enabling - LCD	School	0.14	0.59	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	School	0.42	0.20	0.00	Office Equipment
609	Copier Power Management Enabling	School	0.34	0.57	0.00	Office Equipment
609	Multifunction Power Management Enabling	School	0.15	0.18	0.00	Office Equipment
609	Printer Power Management Enabling	School	1.12	0.84	0.00	Office Equipment
609	High Efficiency Water Heater (electric)	School	1.40	0.72	0.00	Water Heating
609	Heat Recovery Unit	School	6.88	0.67	0.00	Water Heating
609	Demand controlled circulating systems	School	2.39	0.56	0.00	Water Heating
609	Tankless Water Heater	School	4.60	0.44	0.00	Water Heating
609	Solar Water Heater	School	3.97	0.38	0.00	Water Heating
609	Hot Water Pipe Insulation	School	0.53	0.32	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	School	0.13	0.11	0.00	Vending
609	Convection Oven	School	4.90	0.42	0.00	Cooking
609	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School	0.77	0.77	0.00	Heating
609	Xmisc	School	0.00	0.00	0.00	Miscellaneous
609	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Health	15.09	0.81	0.00	Indoor Lighting
609	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Health	7.67	0.42	0.00	Indoor Lighting
609	ROB 4L4' LED Tube, 2020	Health	15.45	0.15	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	Health	6.87	0.18	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Health	1.19	0.93	0.00	Indoor Lighting
609	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Health	1.82	0.64	0.00	Indoor Lighting
609	ROB 2L4' LED Tube, 2020	Health	0.60	0.20	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020	Health	1.01	0.16	0.00	Indoor Lighting
609	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Health	0.80	0.21	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Health	0.35	0.82	0.00	Indoor Lighting
609	ROB High Performance T8 (base other fluorescent)	Health	0.44	0.42	0.00	Indoor Lighting
609	Occupancy Sensor, 4L8' Fluorescent Fixtures	Health	0.74	0.36	0.00	Indoor Lighting
609	ROB Low Watt High Performance T8 (base other fluorescent)	Health	0.39	0.16	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 18W) 2020	Health	0.78	0.44	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 23W) 2020	Health	0.94	0.53	0.00	Indoor Lighting
609	Outdoor Lighting Controls (Photocell/Timeclock)	Health	0.94	0.96	0.00	Outdoor Lighting
609	LED Outdoor Area Lighting	Health	5.65	0.37	0.00	Outdoor Lighting
609	Bi-Level LED Outdoor Lighting	Health	1.54	0.06	0.00	Outdoor Lighting
609	Duct Testing/Sealing - Chiller	Health	9.79	0.59	0.00	Cooling
609	New Economizer - Chiller	Health	4.73	0.42	0.00	Cooling
609	Window Film (Standard) - Chiller	Health	0.06	0.28	0.00	Cooling
609	Cool Roof - Chiller	Health	0.10	0.11	0.00	Cooling
609	Duct/Pipe Insulation - Chiller	Health	0.42	0.03	0.00	Cooling
609	DX Tune Up/ Advanced Diagnostics	Health	0.15	0.71	0.00	Cooling

/A Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Optimize Controls - DX	Health	2.95	0.69	0.00	Cooling
609	Prog. Thermostat - DX	Health	3.27	0.60	0.00	Cooling
609	Duct Testing/Sealing - DX	Health	9.43	0.53	0.00	Cooling
609	Window Film (Standard) - DX	Health	0.78	0.33	0.00	Cooling
609	Cool Roof - DX	Health	0.46	0.13	0.00	Cooling
609	Duct/Pipe Insulation - DX	Health	1.59	0.03	0.00	Cooling
609	Economizer Repair - DX	Health	0.00	0.00	0.00	Cooling
609	Economizer - DX	Health	0.00	0.00	0.00	Cooling
609	Demand Controlled Ventilation	Health	3.99	0.11	0.00	Ventilation
609	Energy Recovery Ventilation (ERV)	Health	8.19	0.37	0.00	Ventilation
609	Demand Controlled Ventilation	Health	11.24	0.09	0.00	Ventilation
609	Demand Controlled Ventilation	Health	21.14	0.15	0.00	Ventilation
609	Reach-in unit occupancy sensors	Health	0.01	0.22	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014 Laptop Network Power Management	Health	0.04	0.18	0.00	Refrigeration
609	Enabling	Health	0.01	0.03	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Health	0.06	0.16	0.00	Office Equipment
609	Monitor Power Management Enabling - LCD	Health	0.07	0.41	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Health	0.10	0.14	0.00	Office Equipment
609	Copier Power Management Enabling	Health	0.14	0.35	0.00	Office Equipment
609	Multifunction Power Management Enabling	Health	0.05	0.14	0.00	Office Equipment
609	Printer Power Management Enabling	Health	0.20	0.66	0.00	Office Equipment
609	High Efficiency Water Heater (electric)	Health	0.28	0.83	0.00	Water Heating
609	Heat Recovery Unit	Health	7.01	0.80	0.00	Water Heating
609	Tankless Water Heater	Health	0.49	0.28	0.00	Water Heating
609	Solar Water Heater	Health	0.84	0.24	0.00	Water Heating
609	Hot Water Pipe Insulation	Health	0.05	0.19	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	Health	0.05	0.12	0.00	Vending
609	Efficient Fryer	Health	0.56	0.57	0.00	Cooking
609	Xmisc	Health	0.00	0.00	0.00	Miscellaneous
609	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Lodging	0.52	0.90	0.00	Indoor Lighting
609	ROB 4L4' LED Tube, 2020	Lodging	1.01	0.20	0.00	Indoor Lighting
609	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Lodging	0.15	0.29	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	Lodging	0.43	0.23	0.00	Indoor Lighting
609	Lighting Control Tuneup (base 2L4'T8), 2020	Lodging	0.13	0.76	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Lodging	2.10	0.65	0.00	Indoor Lighting
609	ROB 2L4' LED Tube, 2020	Lodging	1.22	0.24	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020 Occupancy Sensor, 2L4' Fluorescent	Lodging	2.05	0.19	0.00	Indoor Lighting
609	Fixtures, 2020 ROB High Performance T8 (base other	Lodging	0.62	0.17	0.00	Indoor Lighting
609	fluorescent) ROB Low Watt High Performance T8	Lodging	0.07	0.65	0.00	Indoor Lighting
609	(base other fluorescent)	Lodging	0.08	0.31	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Lodging	0.04	0.28	0.00	Indoor Lighting

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL VA Commercial: All Existing Measures Panked by Economic Potential (GWh)

VA Commercial: All Existing Measures Ranked by Economic Potential (GWh)									
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use			
609	Occupancy Sensor, 4L8' Fluorescent	Lodging	0.04	0.26	0.00	Indoor Lighting			
609	Fixtures LED screw-in replacement (base CFL 18W) 2020	Lodging	3.04	0.52	0.00	Indoor Lighting			
609	LED screw-in replacement (base CFL 23W) 2020	Lodging	3.64	0.62	0.00	Indoor Lighting			
609	LED Outdoor Area Lighting	Lodging	19.46	0.65	0.00	Outdoor Lighting			
609	Bi-Level LED Outdoor Lighting	Lodging	5.31	0.10	0.00	Outdoor Lighting			
609	New Economizer - Chiller	Lodging	44.54	0.92	0.00	Cooling			
609	EMS - Chiller	Lodging	6.33	0.49	0.00	Cooling			
609	Duct Testing/Sealing - Chiller	Lodging	13.34	0.25	0.00	Cooling			
609	Cool Roof - Chiller	Lodging	0.11	0.04	0.00	Cooling			
609	Duct/Pipe Insulation - Chiller	Lodging	0.28	0.02	0.00	Cooling			
609	Optimize Controls - DX	Lodging	4.83	0.62	0.00	Cooling			
609	DX Tune Up/ Advanced Diagnostics	Lodging	3.63	0.45	0.00	Cooling			
609	Prog. Thermostat - DX	Lodging	7.49	0.38	0.00	Cooling			
609	Duct Testing/Sealing - DX	Lodging	15.05	0.34	0.00	Cooling			
609	Economizer Repair - DX	Lodging	1.20	0.09	0.00	Cooling			
609	Cool Roof - DX	Lodging	0.45	0.07	0.00	Cooling			
609	Economizer - DX	Lodging	3.79	0.06	0.00	Cooling			
609	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Lodging	0.01	0.03	0.00	Cooling			
609	Duct/Pipe Insulation - DX	Lodging	2.47	0.03	0.00	Cooling			
609	Occupancy Sensor (hotels)	Lodging	5.50	0.38	0.00	Cooling			
609	Demand Controlled Ventilation	Lodging	32.14	0.09	0.00	Ventilation			
609	Demand Controlled Ventilation	Lodging	5.06	0.09	0.00	Ventilation			
609	Bi-level LED Case Lighting (self- contained units) 2014	Lodging	0.03	0.18	0.00	Refrigeration			
609	Strip curtains for walk-ins (self- contained)	Lodging	0.53	0.15	0.00	Refrigeration			
609	Laptop Network Power Management Enabling	Lodging	0.01	0.04	0.00	Office Equipmer			
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Lodging	0.11	0.25	0.00	Office Equipmer			
609	Monitor Power Management Enabling - LCD	Lodging	0.18	0.59	0.00	Office Equipmer			
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Lodging	0.11	0.20	0.00	Office Equipmer			
609	Copier Power Management Enabling	Lodging	0.09	0.57	0.00	Office Equipmer			
609	Multifunction Power Management Enabling	Lodging	0.05	0.19	0.00	Office Equipmer			
609	Printer Power Management Enabling	Lodging	0.13	0.89	0.00	Office Equipmer			
609	Hot Water Pipe Insulation	Lodging	0.62	0.96	0.00	Water Heating			
609	Vending Misers (Non-Refrigerated)	Lodging	0.04	0.12	0.00	Vending			
609	Xmisc	Lodging	0.00	0.00	0.00	Miscellaneous			
609	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Data Centers	0.56	0.74	0.00	Indoor Lighting			
609	ROB 4L4' LED Tube, 2020	Data Centers	1.10	0.23	0.00	Indoor Lighting			
609	LED Troffer (base 4L4'T8), 2020	Data Centers	0.49	0.28	0.00	Indoor Lighting			
609	ROB 2L4' Low Watt High Performance T8	Data Centers	0.02	0.99	0.00	Indoor Lighting			
609	(75 W), 2020 ROB 2L4' LED Tube, 2020	Data Centers	0.01	0.31	0.00	Indoor Lighting			
609	Occupancy Sensor, 2L4' Fluorescent	Data Centers	0.01	0.40	0.00	Indoor Lighting			
	Fixtures, 2020								
609	LED Troffer (base 2L4'T8), 2020	Data Centers	0.01	0.23	0.00	Indoor Lighting			
609	ROB High Performance T8 (base other fluorescent)	Data Centers	0.04	0.63	0.00	Indoor Lighting			

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL VA Commercial: All Existing Measures Panked by Economic Potential (GWh)

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Occupancy Sensor, 4L8' Fluorescent	Data Centers	0.04	0.41	0.00	Indoor Lighting
609	Fixtures ROB Low Watt High Performance T8 (base other fluorescent)	Data Centers	0.03	0.26	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 18W) 2020	Data Centers	0.18	0.64	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 23W) 2020	Data Centers	0.21	0.77	0.00	Indoor Lighting
609	LED Outdoor Area Lighting	Data Centers	1.13	0.58	0.00	Outdoor Lighting
609	Bi-Level LED Outdoor Lighting	Data Centers	0.30	0.09	0.00	Outdoor Lighting
609	Cool Roof - Chiller	Data Centers	0.05	0.77	0.00	Cooling
609	Duct/Pipe Insulation - Chiller	Data Centers	0.05	0.09	0.00	Cooling
609	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	Data Centers	0.00	0.73	0.00	Cooling
609	Cool Roof - DX	Data Centers	0.07	0.65	0.00	Cooling
609	Duct/Pipe Insulation - DX	Data Centers	0.06	0.08	0.00	Cooling
609	Demand Controlled Ventilation	Data Centers	0.20	0.32	0.00	Ventilation
609	Energy Recovery Ventilation (ERV)	Data Centers	0.26	0.90	0.00	Ventilation
609	Demand Controlled Ventilation	Data Centers	0.59	0.26	0.00	Ventilation
609	Demand Controlled Ventilation	Data Centers	0.69	0.29	0.00	Ventilation
609	Reach-in unit occupancy sensors	Data Centers	0.00	0.24	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014	Data Centers	0.00	0.20	0.00	Refrigeration
609	Laptop Network Power Management Enabling	Data Centers	0.00	0.04	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	Data Centers	0.01	0.40	0.00	Office Equipment
609	Monitor Power Management Enabling - LCD	Data Centers	0.00	0.60	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Data Centers	0.00	0.19	0.00	Office Equipment
609	Copier Power Management Enabling Multifunction Power Management	Data Centers	0.00	0.56	0.00	Office Equipment
609	Enabling	Data Centers	0.00	0.19	0.00	Office Equipment
609	Printer Power Management Enabling	Data Centers	0.00	0.86	0.00	Office Equipment
609	Heat Trap	Data Centers	0.01	0.84	0.00	Water Heating
609	High Efficiency Water Heater (electric)	Data Centers	0.00	0.45	0.00	Water Heating
609	Tankless Water Heater	Data Centers	0.02	0.32	0.00	Water Heating
609	Solar Water Heater	Data Centers	0.10	0.27	0.00	Water Heating
609	Heat Recovery Unit	Data Centers	0.01	0.10	0.00	Water Heating
609	Demand controlled circulating systems	Data Centers	0.00	0.04	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	Data Centers	0.00	0.43	0.00	Vending
609	Xmisc Occupancy Sensor, 4L4' Fluorescent	Data Centers	0.00	0.00	0.00	Miscellaneous
609	Fixtures, 2020	on-Jurisdiction		0.81	0.00	Indoor Lighting
609	ROB 4L4' LED Tube, 2020	on-Jurisdiction		0.26	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	on-Jurisdiction		0.32	0.00	Indoor Lighting
609	ROB 2L4' LED Tube, 2020	on-Jurisdiction	3.42	0.34	0.00	Indoor Lighting
609	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	on-Jurisdiction	2.97	0.44	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020	on-Jurisdiction	5.49	0.26	0.00	Indoor Lighting
609	ROB High Performance T8 (base other fluorescent)	on-Jurisdiction	1.06	0.72	0.00	Indoor Lighting
609	Occupancy Sensor, 4L8' Fluorescent Fixtures	on-Jurisdiction	1.05	0.56	0.00	Indoor Lighting

			_		_	
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	ROB Low Watt High Performance T8 (base other fluorescent)	on-Jurisdiction	1.22	0.31	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 18W) 2020	on-Jurisdiction	6.14	0.68	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 23W) 2020	on-Jurisdiction	7.37	0.81	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings (base metal halide)	on-Jurisdiction	1.12	0.68	0.00	Indoor Lighting
609	LED Outdoor Area Lighting	on-Jurisdiction	37.86	0.61	0.00	Outdoor Lightin
609	Bi-Level LED Outdoor Lighting	on-Jurisdiction	10.29	0.09	0.00	Outdoor Lightin
609	Duct Testing/Sealing - Chiller	on-Jurisdiction	44.31	0.63	0.00	Cooling
609	Window Film (Standard) - Chiller	on-Jurisdiction	3.26	0.35	0.00	Cooling
609	New Economizer - Chiller	on-Jurisdiction	15.21	0.27	0.00	Cooling
609	Cool Roof - Chiller	on-Jurisdiction	0.64	0.18	0.00	Cooling
609	Duct/Pipe Insulation - Chiller	on-Jurisdiction	1.44	0.04	0.00	Cooling
609	Optimize Controls - DX	on-Jurisdiction	4.47	0.72	0.00	Cooling
609	DX Tune Up/ Advanced Diagnostics	on-Jurisdiction	0.91	0.65	0.00	Cooling
609	Economizer Repair - DX	on-Jurisdiction	3.78	0.60	0.00	Cooling
609	Duct Testing/Sealing - DX	on-Jurisdiction	15.32	0.55	0.00	Cooling
609	Prog. Thermostat - DX	on-Jurisdiction	8.10	0.48	0.00	Cooling
609	Window Film (Standard) - DX	on-Jurisdiction	3.38	0.35	0.00	Cooling
609	Economizer - DX	on-Jurisdiction	10.22	0.27	0.00	Cooling
609	Cool Roof - DX	on-Jurisdiction	1.17	0.19	0.00	Cooling
609	Dual Enthalpy Economizer Replaces Dry Bulb Economizer - DX	on-Jurisdiction	0.02	0.12	0.00	Cooling
609	Duct/Pipe Insulation - DX	on-Jurisdiction	1.40	0.04	0.00	Cooling
609	Demand Controlled Ventilation	on-Jurisdiction	6.67	0.12	0.00	Ventilation
609	Energy Recovery Ventilation (ERV)	on-Jurisdiction	1.51	0.33	0.00	Ventilation
609	Demand Controlled Ventilation	on-Jurisdiction	2.81	0.10	0.00	Ventilation
609	Fan Motor, 40hp, 1800rpm, 94.1%	on-Jurisdiction	0.27	0.64	0.00	Ventilation
609	Demand Controlled Ventilation	on-Jurisdiction	2.49	0.11	0.00	Ventilation
609	Reach-in unit occupancy sensors	on-Jurisdiction	0.03	0.21	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014	on-Jurisdiction	0.06	0.18	0.00	Refrigeration
609	Strip curtains for walk-ins (self- contained)	on-Jurisdiction	0.08	0.00	0.00	Refrigeration
609	Laptop Network Power Management Enabling	on-Jurisdiction	0.03	0.05	0.00	Office Equipmen
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	on-Jurisdiction	0.15	0.33	0.00	Office Equipme
609	Monitor Power Management Enabling - LCD	on-Jurisdiction	0.24	0.66	0.00	Office Equipme
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	on-Jurisdiction	0.33	0.22	0.00	Office Equipme
609	Copier Power Management Enabling	on-Jurisdiction	0.26	0.60	0.00	Office Equipme
609	Multifunction Power Management Enabling	on-Jurisdiction	0.12	0.21	0.00	Office Equipme
609	Printer Power Management Enabling	on-Jurisdiction	0.85	0.97	0.00	Office Equipme
609	Hot Water Pipe Insulation	on-Jurisdiction		0.98	0.00	Water Heating
609	Heat Recovery Unit	on-Jurisdiction	0.89	0.86	0.00	Water Heating
609	Demand controlled circulating systems	on-Jurisdiction	0.58	0.32	0.00	Water Heating
609	Vending Misers (Refrigerated glass-front units)	on-Jurisaiction	0.76	0.69	0.00	Vending
609	Vending Misers (Non-Refrigerated)	on-Jurisdiction	0.08	0.07	0.00	Vending
609	Efficient Fryer	on-Jurisdiction	0.58	0.05	0.00	Cooking

/A Com	mercial: All Existing Measures Rar	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Xmisc	on-Jurisdiction	0.00	0.00	0.00	Miscellaneous
609	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	eligious Worshi	4.39	0.99	0.00	Indoor Lighting
609	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	eligious Worshi	6.82	0.69	0.00	Indoor Lighting
609	(75 W), 2020 ROB 4L4' LED Tube, 2020	eligious Worshi	7.54	0.13	0.00	Indoor Lighting
609	Occupancy Sensor, 4L4' Fluorescent	eligious Worshi		0.19	0.00	Indoor Lighting
609	Fixtures, 2020 LED Troffer (base 4L4'T8), 2020	3				3 3
	Lighting Control Tuneup (base 2L4'T8),	eligious Worshi	3.26	0.15	0.00	Indoor Lighting
609	2020	eligious Worshi	0.23	0.92	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	eligious Worshi		0.81	0.00	Indoor Lighting
609	ROB 2L4' Low Watt High Performance T8	eligious Worshi	5.27	0.55	0.00	Indoor Lighting
609	(75 W), 2020 ROB 2L4' LED Tube, 2020	eligious Worshi		0.16	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020	eligious Worshi	2.94	0.13	0.00	Indoor Lighting Indoor Lighting
609	Occupancy Sensor, 2L4' Fluorescent	eligious Worshi		0.11	0.00	Indoor Lighting
609	Fixtures, 2020 ROB High Performance T8 (base other	eligious worsili	0.64	0.11	0.00	indoor Lighting
609	fluorescent)	eligious Worshi	0.05	0.39	0.00	Indoor Lighting
609	ROB Low Watt High Performance T8 (base other fluorescent)	eligious Worshi	0.08	0.19	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	eligious Worshi	0.04	0.18	0.00	Indoor Lighting
609	Occupancy Sensor, 4L8' Fluorescent Fixtures	eligious Worshi	0.04	0.17	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 18W) 2020	eligious Worshi	1.08	0.36	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 23W) 2020	eligious Worshi	1.29	0.43	0.00	Indoor Lighting
609	Occupancy Sensor, High Bay T5	eligious Worshi	0.07	0.69	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings (base metal halide)	eligious Worshi	0.16	0.47	0.00	Indoor Lighting
609	LED Outdoor Area Lighting	eligious Worshi	12.07	0.44	0.00	Outdoor Lighting
609	Bi-Level LED Outdoor Lighting	eligious Worshi		0.07	0.00	Outdoor Lighting
609	VSD for Chiller Pumps and Towers	eligious Worshi		0.90	0.00	Cooling
609	EMS - Chiller	eligious Worshi		0.50	0.00	Cooling
609	Duct Testing/Sealing - Chiller	eligious Worshi		0.30	0.00	Cooling
609	Window Film (Standard) - Chiller	eligious Worshi	0.12	0.07	0.00	Cooling
609 609	Cool Roof - Chiller Duct/Pipe Insulation - Chiller	eligious Worshi eligious Worshi		0.02 0.01	0.00 0.00	Cooling Cooling
609	New Economizer - Chiller	eligious Worshi eligious Worshi		0.00	0.00	Cooling
609	DX Tune Up/ Advanced Diagnostics	eligious Worshi		0.32	0.00	Cooling
609	Duct Testing/Sealing - DX	eligious Worshi		0.28	0.00	Cooling
609	Prog. Thermostat - DX	eligious Worshi		0.24	0.00	Cooling
609	Optimize Controls - DX	eligious Worshi		0.21	0.00	Cooling
609	Window Film (Standard) - DX	eligious Worshi		0.08	0.00	Cooling
609	Cool Roof - DX	eligious Worshi		0.02	0.00	Cooling
609	Duct/Pipe Insulation - DX	eligious Worshi		0.01	0.00	Cooling
609	HE PTAC, EER=9.6, 1 ton	eligious Worshi		0.69	0.00	Cooling
609	Fan Motor, 5hp, 1800rpm, 89.5%	eligious Worshi		0.67	0.00	Ventilation
609	Variable Speed Drive Control, 5 HP	eligious Worshi		0.63	0.00	Ventilation
609	Demand Controlled Ventilation	eligious Worshi		0.03	0.00	Ventilation
609	Air Handler Optimization, 15 HP	eligious Worshi		0.67	0.00	Ventilation
609	Variable Speed Drive Control, 15 HP	eligious Worshi	12.92	0.46	0.00	Ventilation

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Fan Motor, 15hp, 1800rpm, 92.4%	eligious Worshi	0.46	0.20	0.00	Ventilation
609	Energy Recovery Ventilation (ERV)	eligious Worshi	0.39	0.13	0.00	Ventilation
609	Demand Controlled Ventilation	eligious Worshi	0.58	0.03	0.00	Ventilation
609	Air Handler Optimization, 40 HP	eligious Worshi	2.97	0.78	0.00	Ventilation
609	Variable Speed Drive Control, 40 HP	eligious Worshi	11.98	0.30	0.00	Ventilation
609	Fan Motor, 40hp, 1800rpm, 94.1%	eligious Worshi	0.11	0.08	0.00	Ventilation
609	Demand Controlled Ventilation	eligious Worshi	0.55	0.03	0.00	Ventilation
609	Reach-in unit occupancy sensors	eligious Worshi	0.01	0.22	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014	eligious Worshi	0.07	0.18	0.00	Refrigeration
609	Laptop Network Power Management Enabling	eligious Worshi	0.01	0.02	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base Monitor CRT)	eligious Worshi	0.04	0.14	0.00	Office Equipment
609	Monitor Power Management Enabling - LCD	eligious Worshi	0.05	0.33	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	eligious Worshi	0.11	0.11	0.00	Office Equipment
609	Copier Power Management Enabling	eligious Worshi	0.16	0.29	0.00	Office Equipment
609	Multifunction Power Management Enabling	eligious Worshi	0.06	0.11	0.00	Office Equipment
609	Printer Power Management Enabling	eligious Worshi	0.16	0.49	0.00	Office Equipment
609	Tankless Water Heater	eligious Worshi	1.77	0.81	0.00	Water Heating
609	Hot Water Pipe Insulation	eligious Worshi	0.42	0.62	0.00	Water Heating
609	Heat Recovery Unit	eligious Worshi	0.70	0.58	0.00	Water Heating
609	Demand controlled circulating systems	eligious Worshi	0.78	0.22	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	eligious Worshi	0.00	0.11	0.00	Vending
609	Efficient Fryer	eligious Worshi	0.08	0.02	0.00	Cooking
609	Xmisc	eligious Worshi	0.00	0.00	0.00	Miscellaneous
609	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Misc	7.87	0.69	0.00	Indoor Lighting
609	ROB 4L4' LED Tube, 2020	Misc	46.36	0.27	0.00	Indoor Lighting
609	LED Troffer (base 4L4'T8), 2020	Misc	20.60	0.32	0.00	Indoor Lighting
609	ROB 2L4' LED Tube, 2020	Misc	11.05	0.34	0.00	Indoor Lighting
609	LED Troffer (base 2L4'T8), 2020 Occupancy Sensor, 2L4' Fluorescent	Misc	18.57	0.27	0.00	Indoor Lighting
609	Fixtures, 2020	Misc	5.30	0.34	0.00	Indoor Lighting
609	ROB High Performance T8 (base other fluorescent)	Misc	0.32	0.78	0.00	Indoor Lighting
609	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Misc	0.29	0.66	0.00	Indoor Lighting
609	Occupancy Sensor, 4L8' Fluorescent Fixtures	Misc	0.25	0.60	0.00	Indoor Lighting
609	ROB Low Watt High Performance T8 (base other fluorescent)	Misc	0.42	0.32	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 18W) 2020	Misc	13.54	0.75	0.00	Indoor Lighting
609	LED screw-in replacement (base CFL 23W) 2020	Misc	16.24	0.90	0.00	Indoor Lighting
609	LED Outdoor Area Lighting	Misc	41.83	0.59	0.00	Outdoor Lighting
609	Bi-Level LED Outdoor Lighting	Misc	11.34	0.09	0.00	Outdoor Lighting
609	EMS - Chiller	Misc	6.12	0.96	0.00	Cooling
609	Duct Testing/Sealing - Chiller	Misc	11.63	0.57	0.00	Cooling
609	Window Film (Standard) - Chiller	Misc	0.33	0.13	0.00	Cooling
609	Cool Roof - Chiller	Misc	0.10	0.03	0.00	Cooling

VA Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
609	Duct/Pipe Insulation - Chiller	Misc	0.68	0.02	0.00	Cooling
609	New Economizer - Chiller	Misc	0.00	0.00	0.00	Cooling
609	DX Tune Up/ Advanced Diagnostics	Misc	0.76	0.64	0.00	Cooling
609	Duct Testing/Sealing - DX	Misc	13.99	0.56	0.00	Cooling
609	Prog. Thermostat - DX	Misc	4.27	0.48	0.00	Cooling
609	Optimize Controls - DX	Misc	3.65	0.42	0.00	Cooling
609	Window Film (Standard) - DX	Misc	0.84	0.16	0.00	Cooling
609	Cool Roof - DX	Misc	0.42	0.03	0.00	Cooling
609	Duct/Pipe Insulation - DX	Misc	1.37	0.03	0.00	Cooling
609	Demand Controlled Ventilation	Misc	4.77	0.07	0.00	Ventilation
609	Variable Speed Drive Control, 15 HP	Misc	63.29	0.93	0.00	Ventilation
609	Fan Motor, 15hp, 1800rpm, 92.4%	Misc	2.36	0.42	0.00	Ventilation
609	Energy Recovery Ventilation (ERV)	Misc	1.99	0.26	0.00	Ventilation
609	Demand Controlled Ventilation	Misc	3.00	0.05	0.00	Ventilation
609	Variable Speed Drive Control, 40 HP	Misc	58.69	0.60	0.00	Ventilation
609	Fan Motor, 40hp, 1800rpm, 94.1%	Misc	0.58	0.17	0.00	Ventilation
609	Demand Controlled Ventilation	Misc	2.85	0.06	0.00	Ventilation
609	Reach-in unit occupancy sensors	Misc	0.01	0.22	0.00	Refrigeration
609	Bi-level LED Case Lighting (self- contained units) 2014 Laptop Network Power Management	Misc	0.06	0.18	0.00	Refrigeration
609	Enabling Plug-load controls - Commercial Smart	Misc	0.03	0.05	0.00	Office Equipment
609	Strip (base Monitor CRT) Monitor Power Management Enabling -	Misc	0.16	0.27	0.00	Office Equipment
609	LCD	Misc	0.16	0.66	0.00	Office Equipment
609	Plug-load controls - Commercial Smart Strip (base monitor LCD)	Misc	0.33	0.22	0.00	Office Equipment
609	Copier Power Management Enabling	Misc	0.42	0.58	0.00	Office Equipment
609	Multifunction Power Management Enabling	Misc	0.18	0.21	0.00	Office Equipment
609	Printer Power Management Enabling	Misc	0.81	0.98	0.00	Office Equipment
609	Demand controlled circulating systems	Misc	2.81	0.45	0.00	Water Heating
609	Vending Misers (Non-Refrigerated)	Misc	0.08	0.11	0.00	Vending
609 609	Efficient Fryer Xmisc	Misc Misc	0.68 0.00	0.02 0.00	0.00 0.00	Cooking Miscellaneous

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL

VA Commercial: All Existing Measures Ranked by Economic Potential (GWh)

Rank	Measure Name	Building	Technical	Measure	Economic	End Use
Kalik	Measure Name	Type	GWh	TRC	GWh	Ena ose

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL

NC Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
1	LEDs (base incandescent flood) 2020	Misc	20.22	7910.67	20.22	Indoor Lighting
2	LEDs (base incandescent flood) 2020	Office	11.35	8259.12	11.35	Indoor Lighting
3	LEDs (base incandescent A-line 72W) 2020	Misc	7.15	5592.75	7.15	Indoor Lighting
4	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Office	6.02	1.50	6.02	Indoor Lighting
5	DX Packaged System, EER=13.4, 10	School	5.71	1.82	5.71	Cooling
6	DX Packaged System, EER=13.4, 10	Retail	5.58	3.08	5.58	Cooling
7	tons ROB 4L4' High Performance T8 (86 W),	Office	5.36	3.14	5.36	Indoor Lighting
8	2020 LEDs (base incandescent A-line 53W)	Misc	4.81	3763.29	4.81	Indoor Lighting
9	2020 Variable Speed Drive Control, 5 HP	Retail	4.53	3.37	4.53	Ventilation
10	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Retail	4.33	1.10	4.33	Indoor Lighting
11	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Office	4.27	5.57	4.27	Indoor Lighting
12	LEDs (base incandescent A-line 72W)	Office	4.01	5836.28	4.01	Indoor Lighting
13	2020 ROB 4L4' High Performance T8 (86 W),	Retail	3.95	2.30	3.95	Indoor Lighting
14	2020 DX Packaged System, EER=13.4, 10	Office	3.80	4.42	3.80	Cooling
15	tons ROB 4L4' Low Watt High Performance T8	Warehouse	3.76	2.40	3.76	Indoor Lighting
16	(75 W), 2020 PC Network Power Management	Office	3.76	4.46	3.76	Office Equipment
17	Enabling Variable Speed Drive Control, 5 HP	Office	3.23	4.01	3.23	Ventilation
18	High Performance Lighting R/R - 25%	Retail	3.11	3.84	3.11	Indoor Lighting
19	Savings (base 4L4'T8), 2020 Variable Speed Drive Control, 5 HP	Misc	2.90	1.25	2.90	Ventilation
20	LEDs (base incandescent A-line 53W) 2020	Office	2.69	3918.32	2.69	Indoor Lighting
21	ROB 4L4' High Performance T8 (86 W), 2020	Warehouse	2.68	5.00	2.68	Indoor Lighting
22	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	2.31	6.20	2.31	Cooling
23	DX Packaged System, EER=13.4, 10	Lodging	2.26	2.00	2.26	Cooling
24	tons Heat Pump Upgrade (15 SEER, 8.2	School	2.20	2.15	2.20	Cooling
25	HSPF) Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	2.14	3.18	2.14	Cooling
26	LEDs (base incandescent flood) 2020	Retail	2.11	6471.89	2.11	Indoor Lighting
27	Variable Speed Drive Control, 15 HP	School	2.04	1.51	2.04	Ventilation
28	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Warehouse	1.94	2.29	1.94	Indoor Lighting
29	Variable Speed Drive Control, 5 HP	Warehouse	1.77	3.13	1.77	Ventilation
30	Electronically Commutated Motors (ECM) on an Air Handler Unit	School	1.67	1.28	1.67	Ventilation
31	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	1.61	4.32	1.61	Cooling
32	DX Packaged System, EER=13.4, 10 tons	Restaurant	1.59	5.70	1.59	Cooling
33	Variable Speed Drive Control, 15 HP	Health	1.58	10.92	1.58	Ventilation
34	Data Center Best Practices	Data Centers	1.57	49.89	1.57	Office Equipment
35	ENERGY STAR Printer	Office	1.49	46.78	1.49	Office Equipment

NC Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
36	Solar Water Heater	Office	1.44	1.41	1.44	Water Heating
37	Heat Recovery Unit	Restaurant	1.44	5.33	1.44	Water Heating
38	Outdoor Lighting Controls (Photocell/Timeclock)	School	1.38	1.56	1.38	Outdoor Lighting
39	Data Center Improved Operations	Data Centers	1.37	122.55	1.37	Office Equipment
40	Data Center Best Practices	School	1.36	42.93	1.36	Office Equipment
41	Centrifugal Chiller, 0.51 kW/ton, 500 tons	School	1.36	1.73	1.36	Cooling
42	Economizer Repair - DX	Retail	1.30	1.11	1.30	Cooling
43	Energy Star or Better Monitor - CRT	Office	1.24	62.83	1.24	Office Equipment
44 45	T5 (240W) (base metal halide)	Misc	1.20	8.00	1.20	Indoor Lighting
	Data Center Improved Operations Heat Pump Upgrade (15 SEER, 8.2	School	1.19	105.45	1.19	Office Equipment
46	HSPF)	Lodging	1.18	3.44	1.18	Cooling
47	HE PTAC, EER=9.6, 1 ton	Lodging	1.18	1.17	1.18	Cooling
48	, ,	eligious Worshi	1.17	3110.09	1.17	Indoor Lighting
49	Electronically Commutated Motors (ECM) on an Air Handler Unit	Misc	1.13	2.54	1.13	Ventilation
50	PC Network Power Management Enabling	School	0.99	3.97	0.99	Office Equipment
51	LEDs (base incandescent flood) 2020	Restaurant	0.98	5705.63	0.98	Indoor Lighting
52	Energy Star or Better PC	Office	0.98	2.21	0.98	Office Equipment
53	LEDs (base incandescent flood) 2020	Lodging	0.92	5388.51	0.92	Indoor Lighting
54	DX Packaged System, EER=13.4, 10 tons	eligious Worshi	0.92	1.43	0.92	Cooling
55	Electronically commutated evaporator fan motor	Grocery	0.85	2.83	0.85	Refrigeration
56	Variable Speed Drive Control, 40 HP	School	0.85	10.60	0.85	Ventilation
57	Variable Speed Drive Control, 5 HP	Grocery	0.83	1.72	0.83	Ventilation
58	ROB 2L4' High Performance T8 (86 W), 2020	Retail	0.79	1.82	0.79	Indoor Lighting
59	Variable Speed Drive Control, 5 HP	School	0.76	1.83	0.76	Ventilation
60	DX Packaged System, EER=13.4, 10 tons	Misc	0.75	3.41	0.75	Cooling
61	LEDs (base incandescent A-line 72W)	Retail	0.74	4575.55	0.74	Indoor Lighting
62	2020 Energy Star or Better Monitor - CRT	School	0.72	42.92	0.72	Office Equipment
63	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Warehouse	0.67	1.04	0.67	Indoor Lighting
64	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	0.65	3.37	0.65	Cooling
65	Economizer Repair - DX	Office	0.62	1.60	0.62	Cooling
66	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Retail	0.62	2.25	0.62	Indoor Lighting
67	DX Packaged System, EER=13.4, 10 tons	Health	0.61	2.89	0.61	Cooling
68	Data Center State of the Art practices	Data Centers	0.60	25.88	0.60	Office Equipment
69	T5 (240W) (base metal halide)	eligious Worshi	0.60	2.11	0.60	Indoor Lighting
70	Variable Speed Drive Control, 40 HP	Warehouse	0.60	6.12	0.60	Ventilation
71	HE PTAC, EER=9.6, 1 ton	Misc	0.58	1.38	0.58	Cooling
72	Variable Speed Drive Control, 15 HP	Office	0.57	14.76	0.57	Ventilation
73	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Misc	0.56	1.39	0.56	Indoor Lighting
74	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	School	0.55	1.31	0.55	Indoor Lighting

NC Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
75	ROB 4L4' High Performance T8 (86 W), 2020	School	0.54	2.96	0.54	Indoor Lighting
76	Window Film (Standard) - DX	Lodging	0.53	2.50	0.53	Cooling
77	Data Center State of the Art practices	School	0.52	22.27	0.52	Office Equipment
78	Printer Power Management Enabling	Office	0.51	1.06	0.51	Office Equipment
79	ROB 4L4' High Performance T8 (86 W),	Misc	0.51	2.91	0.51	Indoor Lighting
80	2020 Electronically Commutated Motors	Health	0.50	2.37	0.50	Ventilation
81	(ECM) on an Air Handler Unit LEDs (base incandescent A-line 53W)	Retail	0.50	3078.83	0.50	Indoor Lighting
82	2020 Air Handler Optimization, 40 HP	School	0.48	1.00	0.48	Ventilation
83	Air Handler Optimization, 40 Hi	Misc	0.46	1.34	0.46	Ventilation
84	Variable Speed Drive Control, 5 HP	Health	0.46	3.77	0.46	Ventilation
85	ROB 2L4' High Performance T8 (86 W), 2020	Restaurant	0.45	1.43	0.45	Indoor Lighting
86	ROB 4L4' High Performance T8 (86 W),	Grocery	0.44	1.33	0.44	Indoor Lighting
87	2020 PC Network Power Management	eligious Worshi	0.44	1.69	0.44	Office Equipment
88	Enabling ROB 2L4' Low Watt High Performance T8	Misc	0.43	1.11	0.43	Indoor Lighting
89	(75 W), 2020 Air Handler Optimization, 40 HP	Misc	0.43	1.56	0.43	Ventilation
90	Night covers for display cases (self- contained)	Restaurant	0.42	13.40	0.42	Refrigeration
91	Heat Pump Upgrade (15 SEER, 8.2	Restaurant	0.42	7.99	0.42	Cooling
92	HSPF) LEDs (base incandescent A-line 72W)	eligious Worshi	0.41	2198.80	0.41	Indoor Lighting
93	2020 Heat Pump Upgrade (15 SEER, 8.2	eligious Worshi	0.41	1.33	0.41	Cooling
94	HSPF) High Performance Lighting R/R - 25%	Misc	0.40	3.44	0.40	Indoor Lighting
95	Savings (base 4L4'T8), 2020 Window Film (Standard) - DX	Restaurant	0.39	3.95	0.39	Cooling
96	ROB 4L4' High Performance T8 (86 W),	Health	0.38	1.45	0.38	Indoor Lighting
97	2020 LEDs (base incandescent flood) 2020	School	0.36	7189.65	0.36	Indoor Lighting
98	High Performance Lighting R/R - 25%	Grocery	0.36	4.05	0.36	Indoor Lighting
99	Savings (base 4L4'T8), 2020 ROB 2L4' High Performance T8 (86 W),	Misc	0.36	2.32	0.36	Indoor Lighting
100	2020 High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Restaurant	0.35	2.76	0.35	Indoor Lighting
101	ENERGY STAR Printer	School	0.35	41.90	0.35	Office Equipment
102	Data Center Best Practices	Health	0.35	33.34	0.35	Office Equipment
103	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	School	0.35	2.40	0.35	Indoor Lighting
104	Energy Star or Better PC	School	0.35	2.03	0.35	Office Equipment
105	Tankless Water Heater	Misc	0.35	1.61	0.35	Water Heating
106	LEDs (base incandescent A-line 72W) 2020	Restaurant	0.34	4022.16	0.34	Indoor Lighting
107	DX Packaged System, EER=13.4, 10 tons	Grocery	0.34	2.79	0.34	Cooling
108	LEDs (base incandescent flood) 2020	Grocery	0.34	3668.60	0.34	Indoor Lighting
109	Energy Star or Better Copier	Office	0.33	37.36	0.33	Office Equipment
110	PC Network Power Management Enabling	Misc	0.33	4.05	0.33	Office Equipment
111	LEDs (base incandescent A-line 72W) 2020	Lodging	0.33	3809.61	0.33	Indoor Lighting

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL NC Commercial: All Existing Measures Ranked by Economic Potential (GWh)

NC Com	mercial: All Existing Measures Ran	iked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
112	Data Center Best Practices	Lodging	0.33	44.69	0.33	Office Equipment
113	Variable Speed Drive Control, 40 HP	Office	0.32	2.65	0.32	Ventilation
114	PC Network Power Management Enabling	Retail	0.31	2.84	0.31	Office Equipment
115	Vending Misers (Refrigerated units)	Office	0.31	1.91	0.31	Vending
116	Demand Hot Gas Defrost	Grocery	0.31	3.45	0.31	Refrigeration
117	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Misc	0.31	2.80	0.31	Indoor Lighting
118	Data Center Improved Operations	Health	0.31	81.88	0.31	Office Equipment
119	Strip curtains for walk-ins (built-up)	Grocery	0.31	1.35	0.31	Refrigeration
120	Outdoor Lighting Controls (Photocell/Timeclock)	Restaurant	0.31	1.20	0.31	Outdoor Lighting
121	Vending Misers (Refrigerated units)	Retail	0.30	1.94	0.30	Vending
122	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Health	0.30	1.86	0.30	Indoor Lighting
123	PC Network Power Management Enabling	Health	0.29	2.24	0.29	Office Equipment
124	Data Center Improved Operations	Lodging	0.28	109.76	0.28	Office Equipment
125	LEDs (base incandescent A-line 53W) 2020	eligious Worshi	0.28	1479.54	0.28	Indoor Lighting
126	Air Handler Optimization, 40 HP	Grocery	0.27	2.10	0.27	Ventilation
127	Heat Recovery Unit	Lodging	0.26	3.03	0.26	Water Heating
128	Heat Trap	Misc	0.26	4.22	0.26	Water Heating
129	Energy-Star Freezer, glass door	Restaurant	0.26	7.34	0.26	Refrigeration
130	Energy-Star Refrigerator, solid door	Restaurant	0.25	2.35	0.25	Refrigeration
131	Fan Motor, 5hp, 1800rpm, 89.5%	Retail	0.24	3.61	0.24	Ventilation
132	Freezer-Cooler Replacement Gaskets (self-contained)	Restaurant	0.24	8.51	0.24	Refrigeration
133	T5 (240W) (base metal halide)	School	0.23	4.48	0.23	Indoor Lighting
134	LEDs (base incandescent A-line 53W) 2020	Restaurant	0.23	2670.44	0.23	Indoor Lighting
135	Vending Misers (Refrigerated units)	School	0.23	1.90	0.23	Vending
136	LED Exit Sign	Office	0.23	2.39	0.23	Indoor Lighting
137	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Misc	0.22	2.03	0.22	Heating
138	Monitor Power Management Enabling - CRT	Office	0.22	5.32	0.22	Office Equipment
139	LEDs (base incandescent A-line 53W) 2020	Lodging	0.22	2563.44	0.22	Indoor Lighting
140	Tankless Water Heater	Office	0.22	1.64	0.22	Water Heating
141	Fan Motor, 5hp, 1800rpm, 89.5%	Office	0.22	4.33	0.22	Ventilation
142	Tankless Water Heater	Retail	0.22	1.16	0.22	Water Heating
143	Solar Water Heater	Lodging	0.21	1.11	0.21	Water Heating
144	Cool Roof - DX	Warehouse	0.21	1.61	0.21	Cooling
145	Data Center Best Practices	Misc	0.21	45.26	0.21	Office Equipment
146	LEDs (base incandescent flood) 2020	Health	0.20	3970.63	0.20	Indoor Lighting
147	Electronically Commutated Motors (ECM) on an Air Handler Unit	eligious Worshi	0.19	1.06	0.19	Ventilation
148	Data Center Improved Operations	Misc	0.18	111.17	0.18	Office Equipment
149	High Performance Lighting R/R - 25% Savings (base metal halide)	Misc	0.17	1.47	0.17	Indoor Lighting
150	Solar Water Heater	Restaurant	0.17	1.60	0.17	Water Heating
151	Vending Misers (Refrigerated glass-front units)	Office	0.17	1.04	0.17	Vending
152	Fan Motor, 5hp, 1800rpm, 89.5%	Misc	0.17	1.34	0.17	Ventilation
153	LED Exit Sign	Retail	0.17	1.38	0.17	Indoor Lighting

NC Com	C Commercial: All Existing Measures Ranked by Economic Potential (GWh)					
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
154	Vending Misers (Refrigerated glass-front units)	Retail	0.17	1.06	0.17	Vending
155	Heat Trap	Office	0.16	4.31	0.16	Water Heating
156	Heat Trap	Retail	0.16	3.02	0.16	Water Heating
157	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Office	0.16	3.34	0.16	Heating
158	Energy Star or Better Monitor - LCD	Office	0.16	5.74	0.16	Office Equipment
159	Air Handler Optimization, 15 HP	Office	0.16	2.42	0.16	Ventilation
160	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Office	0.16	2.60	0.16	Indoor Lighting
161	Monitor Power Management Enabling -	School	0.16	2.72	0.16	Office Equipment
162	CRT Anti-sweat (humidistat) controls	Grocery	0.16	1.39	0.16	Refrigeration
	PC Network Power Management	•				_
163	Enabling	Lodging	0.15	2.66	0.15	Office Equipment
164	Heat Trap	Restaurant	0.15	10.16	0.15	Water Heating
165	Data Center Best Practices Freezer-Cooler Replacement Gaskets	Office	0.15	66.62	0.15	Office Equipment
166	(self-contained)	Misc	0.15	36.96	0.15	Refrigeration
167	Variable Speed Drive Control, 40 HP	Retail	0.14	1.09	0.14	Ventilation
168	Energy Star or Better Monitor - CRT	eligious Worshi	0.14	18.75	0.14	Office Equipment
169	Energy Star or Better Monitor - CRT	Retail	0.14	37.31	0.14	Office Equipment
170	Air Handler Optimization, 40 HP	Office	0.14	3.45	0.14	Ventilation
171	Air Handler Optimization, 40 HP	Warehouse	0.14	1.50	0.14	Ventilation
172		eligious Worshi	0.14	14.01	0.14	Office Equipment
173	Heat Recovery Unit	Misc	0.14	1.17	0.14	Water Heating
174	Ceiling/roof Insulation - DX	Warehouse	0.14	4.72	0.14	Cooling
175	Data Center State of the Art practices	Health	0.14	17.29	0.14	Office Equipment
176	Energy Star or Better Monitor - CRT	Misc	0.14	44.83	0.14	Office Equipment
177	Energy-Star Refrigerator, solid door	School	0.13	5.99	0.13	Refrigeration
178	Energy Star or Better Monitor - CRT	Lodging	0.13	36.14	0.13	Office Equipment
179	Data Center Improved Operations	Office	0.13	163.64	0.13	Office Equipment
180	Outdoor Lighting Controls (Photocell/Timeclock)	Misc	0.13	2.24	0.13	Outdoor Lighting
181	LEDs (base incandescent A-line 72W) 2020	School	0.13	5082.56	0.13	Indoor Lighting
182	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	0.13	3.20	0.13	Cooling
183	Freezer-Cooler Replacement Gaskets (self-contained)	Retail	0.13	1.48	0.13	Refrigeration
184	Data Center State of the Art practices	Lodging	0.12	23.18	0.12	Office Equipment
185	Energy Star or Better PC	Retail	0.12	3.61	0.12	Office Equipment
186	Vending Misers (Refrigerated glass-front units)	School	0.12	1.04	0.12	Vending
187	Energy Star or Better PC	Misc	0.12	2.06	0.12	Office Equipment
188	Tankless Water Heater	Lodging	0.12	1.29	0.12	Water Heating
189	LED Exit Sign	Misc	0.12	2.06	0.12	Indoor Lighting
190	LED Exit Sign	School	0.12	1.70	0.12	Indoor Lighting
191	LEDs (base incandescent A-line 72W) 2020	Grocery	0.12	2589.08	0.12	Indoor Lighting
192	Outdoor Lighting Controls (Photocell/Timeclock)	Office	0.12	1.69	0.12	Outdoor Lighting
193	Energy-Star Refrigerator, glass door	Restaurant	0.12	2.41	0.12	Refrigeration

NC Commercial: All Existing Measures Ranked by Economic Potential (GWh)						
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
194	Electronically Commutated Motors (ECM) on an Air Handler Unit	Office	0.12	3.18	0.12	Ventilation
195	Vending Misers (Refrigerated units)	Grocery	0.12	1.93	0.12	Vending
196	Energy Star Ice Machines	School	0.11	2.15	0.11	Refrigeration
197	ENERGY STAR Multi-Function Device	Office	0.11	10.18	0.11	Office Equipmen
198	Heat Trap	School	0.11	1.50	0.11	Water Heating
199	Heat Trap	Lodging	0.11	4.05	0.11	Water Heating
200	Air Handler Optimization, 40 HP	Lodging	0.11	1.91	0.11	Ventilation
201	PC Network Power Management Enabling	Restaurant	0.11	2.61	0.11	Office Equipmer
202	Energy Star or Better PC	Health	0.11	1.07	0.11	Office Equipmer
203	Energy-Star Freezer, solid door	Restaurant	0.11	2.96	0.11	Refrigeration
204	Fan Motor, 5hp, 1800rpm, 89.5%	Warehouse	0.11	3.48	0.11	Ventilation
205	Night covers for display cases (self- contained)	Lodging	0.10	65.69	0.10	Refrigeration
206	Fan Motor, 5hp, 1800rpm, 89.5%	Lodging	0.10	2.26	0.10	Ventilation
207	Energy Star or Better Monitor - CRT	Health	0.10	24.63	0.10	Office Equipmer
208	Vending Misers (Refrigerated units)	Lodging	0.10	1.93	0.10	Vending
209	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Office	0.10	1.19	0.10	Indoor Lighting
210	Tankless Water Heater	Restaurant	0.10	1.87	0.10	Water Heating
211	Freezer-Cooler Replacement Gaskets (self-contained)	School	0.10	15.54	0.10	Refrigeration
212	Vending Misers (Refrigerated units)	Misc	0.10	1.94	0.10	Vending
213	High Efficiency Water Heater (electric)	Misc	0.09	2.26	0.09	Water Heating
214	ROB 2L4' High Performance T8 (86 W), 2020	Office	0.09	2.47	0.09	Indoor Lighting
215	LED Outdoor Area Lighting	Warehouse	0.09	1.03	0.09	Outdoor Lightin
216	Vending Misers (Refrigerated units)	Health	0.09	1.92	0.09	Vending
217	Freezer-Cooler Replacement Gaskets (self-contained)	Office	0.09	24.13	0.09	Refrigeration
218	Energy Star or Better PC	Lodging	0.09	3.47	0.09	Office Equipmer
219	Optimize Controls - DX	Restaurant	0.09	1.20	0.09	Cooling
220	Night covers for display cases (self- contained)	Grocery	0.09	167.60	0.09	Refrigeration
221	LEDs (base incandescent A-line 53W) 2020	School	0.09	3418.64	0.09	Indoor Lighting
222	Hot Water Pine Insulation	Misc	0.08	1.25	0.08	Water Heating
223	ROB 4L4' High Performance T8 (86 W), 2020	eligious Worshi	0.08	1.28	0.08	Indoor Lighting
224	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Retail	0.08	1.54	0.08	Heating
225	LEDs (base incandescent A-line 53W) 2020	Grocery	0.08	1727.94	0.08	Indoor Lighting
226	Data Center State of the Art practices	Misc	0.08	23.47	0.08	Office Equipmen
227	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Lodging	0.08	2.03	0.08	Heating
228	Electronically Commutated Motors (ECM) on an Air Handler Unit	Retail	0.08	2.58	0.08	Ventilation
229	Fan Motor, 5hp, 1800rpm, 89.5%	School	0.08	1.32	0.08	Ventilation
230	Occupancy Sensor, High Bay T5	Misc	0.08	2.14	0.08	Indoor Lighting
231	ROB 4L4' High Performance T8 (86 W), 2020	Restaurant	0.08	1.81	0.08	Indoor Lighting
232	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Health	0.07	2.74	0.07	Heating
233	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Office	0.07	3.24	0.07	Indoor Lighting

C Commercial: All Existing Measures Ranked by Economic Potential (GWh)						
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
234	LEDs (base incandescent A-line 72W) 2020	Health	0.07	2807.19	0.07	Indoor Lighting
235	Energy Star or Better Copier	Retail	0.07	27.60	0.07	Office Equipment
236	Energy-Star Freezer, glass door	Grocery	0.07	2.20	0.07	Refrigeration
237	LED Exit Sign LED screw-in replacement (base CFL	Lodging	0.07	1.72	0.07	Indoor Lighting
238	23W) 2020	Warehouse	0.07	1.38	0.07	Indoor Lighting
239	Demand controlled circulating systems	Lodging	0.07	2.08	0.07	Water Heating
240	LED Exit Sign	Restaurant	0.07	1.03	0.07	Indoor Lighting
241	DX Packaged System, EER=13.4, 10 tons	Data Centers	0.07	5.18	0.07	Cooling
242	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Office	0.06	4.20	0.06	Cooling
243	Vending Misers (Refrigerated glass-front units)	Grocery	0.06	1.05	0.06	Vending
244	LEDs (base incandescent flood) 2020	Data Centers	0.06	5716.89	0.06	Indoor Lighting
245	Chiller Tune Up/Diagnostics	School	0.06	1.38	0.06	Cooling
246	Variable Speed Drive Control, 15 HP	Data Centers	0.06	16.70	0.06	Ventilation
247	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Restaurant	0.06	5.76	0.06	Indoor Lighting
248	High Efficiency Water Heater (electric)	Office	0.06	2.31	0.06	Water Heating
249	Variable Speed Drive Control, 40 HP	Data Centers	0.06	3.00	0.06	Ventilation
250	Data Center State of the Art practices	Office	0.06	34.55	0.06	Office Equipment
251	T5 (240W) (base metal halide)	Grocery	0.06	4.62	0.06	Indoor Lighting
252	Electronically commutated evaporator fan motor	Warehouse	0.06	1.07	0.06	Refrigeration
253	High Efficiency Water Heater (electric)	Retail	0.06	1.62	0.06	Water Heating
254	LED screw-in replacement (base CFL 18W) 2020	Warehouse	0.06	1.15	0.06	Indoor Lighting
255	ROB 214' High Performance T8 (86 W)	eligious Worshi	0.06	1.03	0.06	Indoor Lighting
256	ROB 2L4' High Performance T8 (86 W), 2020	Lodging	0.06	1.91	0.06	Indoor Lighting
257	Energy-Star Freezer, glass door	School	0.06	9.91	0.06	Refrigeration
258	Energy Star or Better Laptop	School	0.06	5.40	0.06	Office Equipment
259	High Efficiency Water Heater (electric)	Restaurant	0.06	5.45	0.06	Water Heating
260	ENERGY STAR Printer	Misc	0.06	43.63	0.06	Office Equipment
261	Energy Star or Better Monitor - LCD	School	0.06	4.86	0.06	Office Equipment
262	Vending Misers (Refrigerated glass-front units)	Lodging	0.06	1.05	0.06	Vending
263	Energy Star or Better Copier	Health	0.05	17.25	0.05	Office Equipment
264	Air Handler Optimization, 40 HP	Retail	0.05	2.31	0.05	Ventilation
265	Energy-Star Freezer, glass door	Lodging	0.05	19.28	0.05	Refrigeration
266	LED Exit Sign	Warehouse	0.05	1.98	0.05	Indoor Lighting
267	Vending Misers (Refrigerated glass-front units)	Misc	0.05	1.06	0.05	Vending
268	Vending Misers (Refrigerated glass-front units)	Health	0.05	1.05	0.05	Vending
269	ROB 2L4' High Performance T8 (86 W), 2020	Health	0.05	1.25	0.05	Indoor Lighting
270	Data Center Best Practices	Warehouse	0.05	46.14	0.05	Office Equipment

NC Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
272	LEDs (base incandescent A-line 53W) 2020	Health	0.05	1888.92	0.05	Indoor Lighting
273	EMS - Chiller	Office	0.05	1.40	0.05	Cooling
274	Air Handler Optimization, 15 HP	Retail	0.05	1.97	0.05	Ventilation
275	Energy Star or Better PC	Restaurant	0.04	1.32	0.04	Office Equipment
276	Oversized Air Cooled Condenser	Warehouse	0.04	4.12	0.04	Refrigeration
277	Data Center Improved Operations	Warehouse	0.04	113.34	0.04	Office Equipment
278	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Data Centers	0.04	4.86	0.04	Cooling
279	Freezer-Cooler Replacement Gaskets (self-contained)	Lodging	0.04	25.31	0.04	Refrigeration
280	Outdoor Lighting Controls (Photocell/Timeclock)	Lodging	0.04	1.29	0.04	Outdoor Lighting
281	Energy-Star Refrigerator, glass door	School	0.04	3.25	0.04	Refrigeration
282	New Economizer - Chiller	Office	0.04	1.06	0.04	Cooling
283	Energy Star or Better Laptop	Office	0.04	6.03	0.04	Office Equipment
284	T5 (240W) (base metal halide)	Lodging	0.04	3.41	0.04	Indoor Lighting
285	Energy Star or Better Copier ROB 2L4' Low Watt High Performance T8	School	0.03	35.03	0.03	Office Equipment
286	(75 W), 2020 High Performance Lighting R/R - 25%	School	0.03	1.04	0.03	Indoor Lighting
287	Savings (base metal halide)	School	0.03	2.84	0.03	Indoor Lighting
288	High Efficiency Water Heater (electric)	Lodging	0.03	1.81	0.03	Water Heating
289	ROB 2L4' High Performance T8 (86 W), 2020	School	0.03	2.35	0.03	Indoor Lighting
290	Outdoor Lighting Controls (Photocell/Timeclock)	Retail	0.03	1.87	0.03	Outdoor Lighting
291	Centrifugal Chiller, 0.51 kW/ton, 500 tons	Restaurant	0.03	5.04	0.03	Cooling
292	(seir-contained)	eligious Worshi	0.03	15.46	0.03	Refrigeration
293	Fan Motor, 5hp, 1800rpm, 89.5%	Grocery	0.03	1.16	0.03	Ventilation
294	Vending Misers (Refrigerated units)	Restaurant	0.03	1.94	0.03	Vending
295	New Economizer - Chiller Lighting Control Tuneup (base 4L4'T8),	Data Centers	0.03	1.87	0.03	Cooling
296	2020	Office	0.03	6.16	0.03	Indoor Lighting
297	Energy Star or Better Copier	Misc	0.03	33.51	0.03	Office Equipment
298 299	Ceiling/roof Insulation - Chiller	Restaurant Restaurant	0.03 0.03	7.47 29.38	0.03 0.03	Cooling Office Equipment
300	Energy Star or Better Monitor - CRT EMS - Chiller	Restaurant	0.03	1.76	0.03	Office Equipment Cooling
301	Floating head pressure controls	Grocery	0.03	3.14	0.03	Refrigeration
302	ENERGY STAR Printer	Retail	0.03	36.32	0.03	Office Equipment
303	PC Network Power Management	Grocery	0.03	1.87	0.03	Office Equipment
304	Enabling Heat Trap	Health	0.03	1.33	0.03	Water Heating
305	Monitor Power Management Enabling - CRT	eligious Worshi	0.03	1.22	0.03	Office Equipment
306	Monitor Power Management Enabling - CRT	Health	0.03	1.45	0.03	Office Equipment
307	Monitor Power Management Enabling - CRT	Misc	0.03	2.93	0.03	Office Equipment
308	Energy-Star Freezer, glass door	Retail	0.03	1.67	0.03	Refrigeration
309	Energy Star Ice Machines	Lodging	0.03	2.26	0.03	Refrigeration
310	ROB 4L4' Low Watt High Performance T8 (75 W), 2020	Data Centers	0.03	1.07	0.03	Indoor Lighting
311	VSD for Chiller Pumps and Towers	School	0.03	1.04	0.03	Cooling
312	Economizer - DX	Data Centers	0.03	1.36	0.03	Cooling

NC Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
313	Air Handler Optimization, 40 HP	Data Centers	0.03	3.95	0.03	Ventilation
314	Monitor Power Management Enabling - CRT	Lodging	0.03	2.55	0.03	Office Equipment
315	Efficient compressor motor	Grocery	0.02	3.73	0.02	Refrigeration
316	ENERGY STAR Printer	Health	0.02	23.39	0.02	Office Equipment
317	Energy-Star Freezer, solid door	School	0.02	3.92	0.02	Refrigeration
318	ROB 2L4' Low Watt High Performance T8 (75 W), 2020	Warehouse	0.02	1.71	0.02	Indoor Lighting
319	ROB 4L4' High Performance T8 (86 W), 2020	Data Centers	0.02	2.23	0.02	Indoor Lighting
320	ROB 2L4' High Performance T8 (86 W), 2020	Warehouse	0.02	3.86	0.02	Indoor Lighting
321	LEDs (base incandescent A-line 72W) 2020	Data Centers	0.02	4041.77	0.02	Indoor Lighting
322	Energy Star or Better Monitor - LCD	Health	0.02	2.66	0.02	Office Equipment
323	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	School	0.02	1.63	0.02	Indoor Lighting
324	Demand controlled circulating systems	Health	0.02	1.51	0.02	Water Heating
325	Energy-Star Freezer, solid door	Lodging	0.02	7.68	0.02	Refrigeration
326	Hot Water Pipe Insulation	Restaurant	0.02	1.24	0.02	Water Heating
327	Freezer-Cooler Replacement Gaskets (self-contained)	Health	0.02	9.47	0.02	Refrigeration
328	·	eligious Worshi	0.02	1.77	0.02	Water Heating
329	Energy Star or Better Monitor - CRT	Warehouse	0.02	74.61	0.02	Office Equipment
330	ENERGY STAR Multi-Function Device	Retail	0.02	7.90	0.02	Office Equipment
331	Data Center State of the Art practices	Warehouse	0.02	23.93	0.02	Office Equipment
332	Energy Star or Better Copier	Restaurant	0.02	21.61	0.02	Office Equipment
333	High Performance Lighting R/R - 25% Savings (base 4L4'T8), 2020	Data Centers	0.02	3.89	0.02	Indoor Lighting
334	Monitor Power Management Enabling - CRT	Retail	0.02	2.86	0.02	Office Equipment
335	Energy Star or Better Monitor - LCD	Misc	0.02	5.06	0.02	Office Equipment
336	Energy Star Ice Machines	Misc	0.02	4.44	0.02	Refrigeration
337	ENERGY STAR Multi-Function Device	School	0.02	9.12	0.02	Office Equipment
338	Variable Speed Drive Control, 5 HP Vending Misers (Refrigerated glass-front	Data Centers	0.02	4.54	0.02	Ventilation
339	units)	Restaurant	0.02	1.06	0.02	Vending
340	Fan Motor, 5hp, 1800rpm, 89.5%	Health	0.02	2.48	0.02	Ventilation
341	Energy Star or Better Copier	Lodging	0.02	28.21	0.02	Office Equipment
342	Air Handler Optimization, 15 HP	Data Centers	0.02	2.77	0.02	Ventilation
343 344	Heat Trap ROB 4L4' Low Watt High Performance T8	Grocery Lodging	0.02 0.02	2.11 1.16	0.02 0.02	Water Heating Indoor Lighting
345	(75 W), 2020 Freezer-Cooler Replacement Gaskets (self-contained)	Grocery	0.02	3.70	0.02	Refrigeration
346	ENERGY STAR Multi-Function Device	Health	0.02	5.09	0.02	Office Equipment
347	Ceiling/roof Insulation - DX	School	0.02	4.46	0.02	Cooling
348	LEDs (base incandescent A-line 53W) 2020	Data Centers	0.01	2719.65	0.01	Indoor Lighting
349	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Warehouse	0.01	2.47	0.01	Indoor Lighting
350	Energy-Star Refrigerator, solid door	Lodging	0.01	6.10	0.01	Refrigeration
351	Lighting Control Tuneup (base 4L4'T8), 2020	Health	0.01	2.17	0.01	Indoor Lighting
352	High Efficiency Chiller Motors	School	0.01	1.11	0.01	Cooling

NC Com	mercial: All Existing Measures Rar	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
353	High Performance Lighting R/R - 25% Savings (base metal halide)	Grocery	0.01	9.32	0.01	Indoor Lighting
354	ROB 4L4' High Performance T8 (86 W), 2020	Lodging	0.01	2.42	0.01	Indoor Lighting
355	Lighting Control Tuneup (base 4L4'T8), 2020	School	0.01	3.04	0.01	Indoor Lighting
356	Energy-Star Refrigerator, solid door	Misc	0.01	12.02	0.01	Refrigeration
357	Occupancy Sensor, High Bay T5	School	0.01	1.09	0.01	Indoor Lighting
358	Energy Star or Better Monitor - LCD	Restaurant	0.01	3.23	0.01	Office Equipment
359	ENERGY STAR Printer	Restaurant	0.01	28.59	0.01	Office Equipment
360	LED Exit Sign	Health	0.01	1.80	0.01	Indoor Lighting
361	Electronically Commutated Motors (ECM) on an Air Handler Unit	Data Centers	0.01	3.49	0.01	Ventilation
362	Energy Star or Better Monitor - CRT	Grocery	0.01	20.72	0.01	Office Equipment
363	ENERGY STAR Printer	eligious Worshi	0.01	18.25	0.01	Office Equipment
364	ENERGY STAR Printer	Warehouse	0.01	72.65	0.01	Office Equipment
365	EMS - Chiller	Data Centers	0.01	2.38	0.01	Cooling
366	Energy Star or Better Monitor - LCD	Retail	0.01	4.42	0.01	Office Equipment
367	Energy Star or Better Monitor - LCD	Lodging	0.01	4.48	0.01	Office Equipment
368	Fan Motor, 40hp, 1800rpm, 94.1%	School	0.01	2.93	0.01	Ventilation
369	ENERGY STAR Multi-Function Device	Restaurant	0.01	6.22	0.01	Office Equipment
370	Fan Motor, 15hp, 1800rpm, 92.4%	Office	0.01	7.21	0.01	Ventilation
371	Energy Star or Better Copier	Grocery	0.01	14.25	0.01	Office Equipment
372	Energy Star Ice Machines	Office	0.01	3.09	0.01	Refrigeration
373	Data Center Best Practices	eligious Worshi	0.01	26.02	0.01	Office Equipment
374	Data Center Best Practices	Retail	0.01	52.05	0.01	Office Equipment
375	Energy Star or Better Monitor - LCD	eligious Worshi	0.01	2.11	0.01	Office Equipment
376	PC Network Power Management Enabling	Data Centers	0.01	3.12	0.01	Office Equipment
377	Data Center Improved Operations	eligious Worshi	0.01	63.92	0.01	Office Equipment
378	Fan Motor, 15hp, 1800rpm, 92.4%	Health	0.01	4.39	0.01	Ventilation
379	Energy Star Ice Machines	eligious Worshi	0.01	1.86	0.01	Refrigeration
380	Data Center Improved Operations	Retail	0.01	127.84	0.01	Office Equipment
381	Night covers for display cases (self- contained)	School	0.01	24.34	0.01	Refrigeration
382	PC Network Power Management Enabling	Warehouse	0.01	6.61	0.01	Office Equipment
383	Lighting Control Tuneup (base other fluorescent fixture)	Office	0.01	17.31	0.01	Indoor Lighting
384	Energy Star Ice Machines	Health	0.01	1.16	0.01	Refrigeration
385	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Grocery	0.01	1.28	0.01	Heating
386	Data Center Best Practices	Restaurant	0.01	41.07	0.01	Office Equipment
387	Monitor Power Management Enabling - CRT	Restaurant	0.01	1.91	0.01	Office Equipment
388	ENERGY STAR Multi-Function Device	Lodging	0.01	7.66	0.01	Office Equipment
389	High Efficiency Water Heater (electric)	Grocery	0.01	1.13	0.01	Water Heating
390	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Restaurant	0.01	1.13	0.01	Heating
391	High Performance Lighting R/R - 25% Savings (base metal halide)	Lodging	0.01	1.20	0.01	Indoor Lighting
392	Energy-Star Refrigerator, glass door	Misc	0.01	12.18	0.01	Refrigeration
393	ENERGY STAR Multi-Function Device	eligious Worshi	0.01	3.97	0.01	Office Equipment

ic com	C Commercial: All Existing Measures Ranked by Economic Potential (GWh)						
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use	
394	Data Center Improved Operations	Restaurant	0.01	100.89	0.01	Office Equipmen	
395	Refrigeration Commissioning	Warehouse	0.01	1.54	0.01	Refrigeration	
396	ENERGY STAR Multi-Function Device	Misc	0.01	9.49	0.01	Office Equipmen	
397	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Retail	0.00	1.16	0.00	Indoor Lighting	
398	Energy Star or Better Laptop	Misc	0.00	5.63	0.00	Office Equipmen	
399	Energy Star or Better Monitor - CRT	Data Centers	0.00	46.99	0.00	Office Equipmen	
400	Monitor Power Management Enabling - CRT Liabting Control Transport (base 31 4170)	Warehouse	0.00	4.07	0.00	Office Equipmer	
401	Lighting Control Tuneup (base 2L4'T8), 2020	Restaurant	0.00	3.07	0.00	Indoor Lighting	
402	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	Data Centers	0.00	7.25	0.00	Cooling	
403	VSD for Chiller Pumps and Towers	Office	0.00	2.48	0.00	Cooling	
404	Energy-Star Refrigerator, solid door	Health	0.00	3.15	0.00	Refrigeration	
405	Optimize Controls - DX	Data Centers	0.00	1.58	0.00	Cooling	
406	Occupancy Sensor, High Bay T5	Grocery	0.00	1.31	0.00	Indoor Lighting	
407	Data Center State of the Art practices	eligious Worshi	0.00	13.50	0.00	Office Equipmer	
408	Energy Star or Better Laptop	eligious Worshi	0.00	2.35	0.00	Office Equipme	
409	Economizer Repair - DX	Data Centers	0.00	1.63	0.00	Cooling	
410	Data Center State of the Art practices	Retail	0.00	26.99	0.00	Office Equipme	
411	Energy Star or Better Laptop	Health	0.00	3.02	0.00	Office Equipme	
412	Ceiling/roof Insulation - Chiller	Office	0.00	18.49	0.00	Cooling	
413	ROB High Performance T8 (base other	Warehouse	0.00	1.12	0.00	Indoor Lighting	
414	fluorescent) VSD for Chiller Pumps and Towers	Data Centers	0.00	3.56	0.00	Cooling	
	·						
415	Energy-Star Refrigerator, glass door	Health	0.00	3.22	0.00	Refrigeration	
416	Energy Star or Better PC	Warehouse	0.00	3.39	0.00	Office Equipme	
417	ENERGY STAR Printer	Grocery	0.00	20.17	0.00	Office Equipmen	
418	Energy Star or Better Laptop	Restaurant	0.00	3.69	0.00	Office Equipmen	
419	Data Center Best Practices	Grocery	0.00	28.91	0.00	Office Equipme	
420	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Warehouse	0.00	4.32	0.00	Indoor Lighting	
421	Energy Star or Better PC	Data Centers	0.00	1.73	0.00	Office Equipme	
422	Energy Star or Better Monitor - LCD	Grocery	0.00	2.28	0.00	Office Equipme	
423	Data Center State of the Art practices	Restaurant	0.00	21.30	0.00	Office Equipme	
424	Data Center Improved Operations	Grocery	0.00	71.00	0.00	Office Equipme	
425	Ceiling/roof Insulation - Chiller	Data Centers	0.00	21.35	0.00	Cooling	
426	Printer Power Management Enabling	Warehouse	0.00	1.75	0.00	Office Equipme	
427	Ceiling/roof Insulation - DX	Restaurant	0.00	8.05	0.00	Cooling	
428	ENERGY STAR Multi-Function Device	Grocery	0.00	4.39	0.00	Office Equipme	
429	DX Tune Up/ Advanced Diagnostics	Restaurant	0.00	1.05	0.00	Cooling	
430	Energy Star or Better Laptop	Retail	0.00	4.69	0.00	Office Equipme	
431	Ceiling/roof Insulation - DX	Grocery	0.00	3.23	0.00	Cooling	
432	Energy Star or Better Copier	Warehouse	0.00	56.71	0.00	Office Equipme	
433	Energy Star or Better Copier	Data Centers	0.00	27.87	0.00	Office Equipmen	
434	LED Exit Sign	Data Centers	0.00	1.70	0.00	Indoor Lighting	

APPENDIX I: MEASURE-LEVEL RANKING BY ECONOMIC ENERGY SAVINGS POTENTIAL NC Commercial: All Existing Measures Ranked by Economic Potential (GWh)

NC Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
435	Lighting Control Tuneup (base other fluorescent fixture)	Health	0.00	5.84	0.00	Indoor Lighting
436	ROB 2L4' High Performance T8 (86 W), 2020	Grocery	0.00	1.05	0.00	Indoor Lighting
437	Energy Star or Better Laptop	Lodging	0.00	4.54	0.00	Office Equipment
438	High Performance Lighting R/R - 25%	Grocery	0.00	3.38	0.00	Indoor Lighting
439	Savings (base 2L4'T8), 2020 High Efficiency Chiller Motors	Office	0.00	2.75	0.00	Cooling
440	Chiller Tune Up/Diagnostics	Office	0.00	3.38	0.00	Cooling
441	Fan Motor, 5hp, 1800rpm, 89.5%	Data Centers	0.00	4.77	0.00	Ventilation
442	Fan Motor, 15hp, 1800rpm, 92.4%	Data Centers	0.00	7.94	0.00	Ventilation
443	Lighting Control Tuneup (base 4L4'T8), 2020	Misc	0.00	3.89	0.00	Indoor Lighting
444	Heat Pump Upgrade (15 SEER, 8.2 HSPF)	School	0.00	1.06	0.00	Heating
445	Data Center State of the Art practices	Grocery	0.00	14.99	0.00	Office Equipment
446	Freezer-Cooler Replacement Gaskets (self-contained)	Data Centers	0.00	22.09	0.00	Refrigeration
447	Lighting Control Tuneup (base 2L4'T8), 2020	School	0.00	1.84	0.00	Indoor Lighting
448	Lighting Control Tuneup (base 2L4'T8), 2020	Misc	0.00	3.16	0.00	Indoor Lighting
449	High Efficiency Chiller Motors	Data Centers	0.00	3.15	0.00	Cooling
450	Monitor Power Management Enabling - CRT	Data Centers	0.00	3.63	0.00	Office Equipment
451	Lighting Control Tuneup (base 4L4'T8), 2020	Restaurant	0.00	6.44	0.00	Indoor Lighting
452	Energy Star or Better Monitor - LCD	Warehouse	0.00	8.19	0.00	Office Equipment
453	High Performance Lighting R/R - 25% Savings, Base Other Fluorescent	Data Centers	0.00	1.83	0.00	Indoor Lighting
454	ENERGY STAR Multi-Function Device	Data Centers	0.00	7.60	0.00	Office Equipment
455	Heat Trap	Data Centers	0.00	1.51	0.00	Water Heating
456	ENERGY STAR Multi-Function Device	Warehouse	0.00	15.81	0.00	Office Equipment
457	T5 (240W) (base metal halide)	Restaurant	0.00	5.02	0.00	Indoor Lighting
458	Lighting Control Tuneup (base 2L4'T8), 2020	Office	0.00	3.58	0.00	Indoor Lighting
459	Energy Star or Better Monitor - LCD	Data Centers	0.00	4.29	0.00	Office Equipment
460	Energy Star or Better Laptop	Data Centers	0.00	4.51	0.00	Office Equipment
461	Energy Star or Better Laptop	Warehouse	0.00	9.38	0.00	Office Equipment
462	Lighting Control Tuneup (base 4L4'T8), 2020	Grocery	0.00	4.69	0.00	Indoor Lighting
463	ROB 2L4' High Performance T8 (86 W), 2020	Data Centers	0.00	1.76	0.00	Indoor Lighting
464	Lighting Control Tuneup (base other fluorescent fixture)	School	0.00	2.51	0.00	Indoor Lighting
465	High Performance Lighting R/R - 25% Savings (base 2L4'T8), 2020	Data Centers	0.00	2.26	0.00	Indoor Lighting
466	Chiller Tune Up/Diagnostics	Restaurant	0.00	4.20	0.00	Cooling
467	Lighting Control Tuneup (base other fluorescent fixture)	Lodging	0.00	2.32	0.00	Indoor Lighting
468	Energy Star or Better Laptop	Grocery	0.00	2.61	0.00	Office Equipment
469	LED Exit Sign	Grocery	0.00	1.67	0.00	Indoor Lighting
470	Window Film (Standard) - Chiller	Data Centers	0.00	1.26	0.00	Cooling
471	Ceiling/roof Insulation - DX	eligious Worshi		2.69	0.00	Cooling
472	Ceiling/roof Insulation - DX	Misc	0.00	6.44	0.00	Cooling
473	Lighting Control Tuneup (base other fluorescent fixture)	Misc	0.00	4.97	0.00	Indoor Lighting

NC Com	mercial: All Existing Measures Ran	ked by Econ	omic Potenti	al (GWh)		
Rank	Measure Name	Building Type	Technical GWh	Measure TRC	Economic GWh	End Use
474	Occupancy Sensor, High Bay T5	Restaurant	0.00	1.31	0.00	Indoor Lighting
475	Lighting Control Tuneup (base other fluorescent fixture)	eligious Worshi	0.00	1.31	0.00	Indoor Lighting
476	Lighting Control Tuneup (base 2L4'T8), 2020	Grocery	0.00	3.92	0.00	Indoor Lighting
477	Occupancy Sensor, 4L4' Fluorescent Fixtures, 2020	Office	3.44	0.93	0.00	Indoor Lighting
477	ROB 4L4' LED Tube, 2020	Office	6.10	0.28	0.00	Indoor Lighting
477	LED Troffer (base 4L4'T8), 2020	Office	2.71	0.33	0.00	Indoor Lighting
477	ROB 2L4' LED Tube, 2020	Office	0.03	0.37	0.00	Indoor Lighting
477	Occupancy Sensor, 2L4' Fluorescent Fixtures, 2020	Office	0.06	0.50	0.00	Indoor Lighting
477	LED Troffer (base 2L4'T8), 2020	Office	0.05	0.27	0.00	Indoor Lighting
477	ROB High Performance T8 (base other fluorescent)	Office	0.20	0.77	0.00	Indoor Lighting
477	Occupancy Sensor, 4L8' Fluorescent Fixtures	Office	0.25	0.52	0.00	Indoor Lighting
477	LED screw-in replacement (base CFL 18W) 2020	Office	0.07	0.76	0.00	Indoor Lighting
477	LED screw-in replacement (base CFL 23W) 2020	Office	0.08	0.92	0.00	Indoor Lighting
477	LED Outdoor Area Lighting	Office	0.62	0.66	0.00	Outdoor Lighting
477	Bi-Level LED Outdoor Lighting	Office	0.17	0.10	0.00	Outdoor Lighting
477	Window Film (Standard) - Chiller	Office	0.00	0.99	0.00	Cooling
477	Duct Testing/Sealing	Office	0.11	0.74	0.00	Cooling
477	Cool Roof - Chiller	Office	0.00	0.39	0.00	Cooling
477	Duct/Pipe Insulation - Chiller	Office	0.00	0.05	0.00	Cooling
477	Optimize Controls - DX	Office	0.21	0.90	0.00	Cooling
477	Window Film (Standard) - DX	Office	0.25	0.88	0.00	Cooling
477	DX Tune Up/ Advanced Diagnostics	Office	0.01	0.79	0.00	Cooling
477	Economizer - DX	Office	1.28	0.78	0.00	Cooling

J ACHIEVABLE PROGRAM POTENTIAL



DNV·GL DSM ASSYST OUTPUT FILES

Electricity	_
All Segments	
Total	
50 Percent	

APPENDIX J

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	247,007,003	521,899,420	971,886,254	1,398,005,987	1,934,721,680	2,408,799,069	3,117,062,742	3,666,209,201	4,003,106,510	4,196,971,490
Cumulative Gross Peak Demand - kW	42,128	91,323	172,973	250,725	344,853	427,830	545,688	636,642	691,845	723,017
Cumulative Net Energy Savings - kWh	150,835,003	335,066,231	576,828,670	809,488,036	1,067,760,782	1,306,118,916	1,611,066,316	1,855,200,658	2,006,766,263	2,112,314,113
Cumulative Net Peak Demand Savings - kW	26,371	60,575	105,851	149,731	195,308	237,224	286,537	326,356	351,593	370,121
New Net Energy Savings - kWh	150,835,003	184,231,228	241,762,439	232,659,367	258,272,745	238,358,134	304,947,401	244,134,342	151,565,605	105,547,850
New Net Peak Demand Savings - kW	26,371	34,203	45,276	43,880	45,578	41,916	49,312	39,820	25,237	18,528
Administration Costs	10,586,154	12,263,085	15,362,303	16,076,265	17,129,466	17,260,343	18,459,789	18,030,851	16,439,766	16,300,787
Marketing Costs	4,643,279	5,274,940	5,449,330	5,589,000	5,722,094	5,692,538	5,664,250	5,637,176	5,033,111	5,033,111
Incentives Costs	17,042,056	21,079,690	31,068,179	31,988,817	32,938,724	31,988,596	34,027,101	31,935,846	26,174,582	25,770,194
Total	32,271,490	38,617,715	51,879,812	53,654,083	55,790,284	54,941,478	58,151,141	55,603,872	47,647,459	47,104,091
	•	3	3						3	,
PV Net Avoided Cost Benefits	72,683,621	86,672,774	112,361,677	110,026,037	140,617,445	135,013,997	196,712,995	173,634,765	140,080,988	109,908,687
PV Annual Program Marketing and Admin Costs	15,229,433	16,627,256	18,706,215	18,462,210	18,461,858	17,580,719	17,518,195	16,294,508	14,015,523	13,201,680
PV Net Measure Costs	27,721,180	33,808,668	41,040,962	41,027,008	39,923,646	37,546,365	37,096,398	33,816,626	29,378,781	27,410,418
TRC Ratio	1.69	1.72	1.88	1.85	2.41	2.45	3.60	3.46	3.23	2.71
	•	3	3						3	,
Free Riders - kWh	96,172,000	186,833,189	395,075,124	588,557,600	867,121,627	1,103,061,294	1,506,575,682	1,811,872,964	1,844,885,328	1,828,415,888
Free Riders - kW	15,756	30,749	67,126	101,002	149,568	190,661	259,233	310,409	313,447	307,636
Other Naturally Occurring - kWh	0	0	-17,539	-39,650	-160,729	-381,140	-579,257	-864,422	151,454,919	256,241,489
Other Naturally Occurring - kW	0	0	-3	-8	-24	-55	-82	-124	26,805	45,260
Cost per First-Year Net kWh	\$0.21	\$0.21	\$0.21	\$0.23	\$0.22	\$0.23	\$0.19	\$0.23	\$0.31	\$0.45
PV Annual Program Costs	32,271,490	36,612,253	46,631,369	45,721,707	45,073,171	42,082,329	42,227,712	38,281,085	31,099,889	29,148,594
PV Lost Revenue	126,514,070	147,069,586	182,284,820	173,161,991	217,911,407	200,657,423	281,264,230	239,296,614	189,146,721	145,775,323
RIM	0.46	0.47	0.49	0.50	0.53	0.56	0.61	0.63	0.64	0.63



APPENDIX J



Electricity	·
Commercial	
Total	
50 Percent	

Cumulative Gross Peak Demand - RW 20,799 41,267 91,728 137,615 196,320 246,888 323,267 377,435 400,069 402,886 Cumulative Net Energy Savings - kWh 61,051,915 122,887,105 228,448,462 320,607,126 406,519,436 486,568,431 579,959,911 642,538,207 641,048,682 622,761,509 Cumulative Net Energy Savings - kWh 61,051,915 61,053,5189 105,561,357 92,158,064 85,912,309 80,048,996 93,391,480 62,578,296 -1,489,526 -18,287,173 New Net Energy Savings - kWh 61,051,915 61,053,5189 105,561,357 92,158,064 85,912,309 80,048,996 93,391,480 62,578,296 -1,489,526 -18,287,173 New Net Peak Demand Savings - kW 9,936 10,533 18,058 10,533 18,058 10,548 15,782 15,074 17,612 12,357 1,694 -1,325 Administration Costs 2,853,438 3,029,913 5,038,007 5,083,811 4,818,492 4,586,644 4,629,126 4,266,210 2,792,410 2,792,											
Cumulative Gross Peak Demand - RW 20,799 41,267 91,728 137,815 196,320 246,888 323,267 377,435 400,069 402,886 Cumulative Net Energy Savings - kWh 61,051,915 122,887,105 228,448,462 320,607,126 406,519,436 486,588,431 579,959,911 642,538,207 641,048,882 622,761,509 Cumulative Net Energy Savings - kWh 61,051,915 61,835,189 105,561,357 92,158,684 85,912,309 80,048,996 93,91,480 62,578,296 -1,489,526 -18,287,173 New Net Renergy Savings - kWh 61,051,915 61,835,189 105,561,357 92,158,684 85,912,309 80,048,996 93,391,480 62,578,296 -1,489,526 -18,287,173 Administration Costs 2,853,438 3,029,913 5,038,007 5,063,811 4,818,492 4,586,644 4,629,126 4,226,210 2,792,410 2,792,405 Marketing Costs 1,483,752 1,880,066 1,846,355 1,814,091 1,753,654 1,725,366 1,698,292 1,094,227 1,094,227 1,094,227 1,094,227		2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Net Energy Savings - kWh 61,051,915 122,887,105 228,448,462 320,607,126 406,519,436 486,568,431 579,959,911 642,538,207 641,048,682 622,761,508 Cumulative Net Peak Demand Savings - kW 9,936 20,470 39,155 55,800 71,582 86,656 104,268 116,625 118,319 119,994 New Net Energy Savings - kWh 9,936 10,533 18,685 16,645 15,782 15,074 17,612 12,357 1,489,526 18,287,137 New Net Peak Demand Savings - kW 9,936 10,533 18,685 16,645 15,782 15,074 17,612 12,357 1,694 -1,325 Administration Costs 2,853,438 3,029,913 5,038,007 5,063,811 4,818,492 4,586,644 4,629,126 4,266,210 2,792,410 2,794,052 Marketing Costs 1,483,752 1,880,066 1,864,355 1,814,091 1,783,210 1,753,666 1,698,292 1,094,227 1,094,227 1,094,227 1,094,227 1,094,227 1,094,227 1,094,227	Cumulative Gross Energy - kWh	131,238,893	256,743,943	546,870,221	808,467,911	1,139,376,571	1,421,641,062	1,846,816,891	2,145,497,229	2,262,159,349	2,269,182,164
Cumulative Net Peak Demand Savings - kW 9,936 20,470 39,155 55,800 71,582 86,666 104,268 116,625 118,319 116,094 New Net Energy Savings - kWh 61,051,915 61,085,189 105,561,357 92,158,664 85,912,309 80,048,996 93,391,480 62,578,296 -1,489,526 -18,287,173 New Net Peak Demand Savings - kW 9,936 10,533 18,685 16,645 15,7782 15,074 17,612 12,257 1,489,526 -18,287,173 Administration Costs 2,853,438 3,029,913 5,038,007 5,063,811 4,818,492 4,586,644 4,629,126 4,266,210 2,792,410 2,794,052 Marketing Costs 1,483,752 1,880,066 1,846,355 1,814,091 1,783,210 1,753,664 1,725,366 1,689,292 1,094,227 1,094,227 Incentives Costs 4,432,497 4,895,918 12,681,926 12,695,632 11,753,479 10,840,425 11,273,688 9,726,268 4,683,849 4,673,660 Total Costs 2,752,058 2,7336,	Cumulative Gross Peak Demand - kW	20,799	41,267	91,728	137,615	196,320	246,888	323,267	377,435	400,069	402,886
New Net Energy Savings - kWh 61,051,915 61,835,189 105,561,357 92,158,664 85,912,309 80,048,996 93,391,480 62,578,296 -1,499,526 -18,287,173 New Net Peak Demand Savings - kW 9,936 10,533 18,685 16,645 15,782 15,074 17,612 12,357 1,694 -1,225 Administration Costs 2,853,438 3,029,913 5,038,007 5,063,811 4,818,492 4,586,644 4,629,126 4,266,210 2,794,052 2,794,052 Incentives Costs 1,483,752 1,880,066 1,846,355 1,814,091 1,783,210 1,753,656 1,698,292 1,094,227 1,094,227 Incentives Costs 4,432,497 4,995,918 12,691,926 12,696,632 11,753,479 10,840,425 11,127,368 9,726,288 4,683,349 4,673,660 Total Costs 8,769,687 9,805,897 19,566,288 19,573,533 18,355,181 17,180,723 17,481,860 15,690,770 8,470,487 4,805,613 PV Net Measure Costs 2,572,058 27,326,032 4	Cumulative Net Energy Savings - kWh	61,051,915	122,887,105	228,448,462	320,607,126	406,519,436	486,568,431	579,959,911	642,538,207	641,048,682	622,761,509
New Net Peak Demand Savings - kW 9,936 10,533 18,685 16,645 15,782 15,074 17,612 12,357 1,694 -1,325 Administration Costs 2,853,438 3,029,913 5,038,007 5,063,811 4,818,492 4,586,644 4,629,126 4,266,210 2,792,410 2,794,052 Marketing Costs 1,483,752 1,880,066 1,846,355 1,814,091 1,783,210 1,753,654 1,725,366 1,698,292 1,094,227 1,094,227 Incentives Costs 4,432,497 4,895,918 12,681,926 12,695,632 11,753,479 10,840,425 11,127,368 9,726,268 4,583,949 4,094,227 Total Costs 8,769,687 9,805,897 19,566,288 19,573,553 18,355,181 17,180,723 17,481,860 15,690,770 4,649,487 4,654,998 6,187,903 5,861,053 5,333,539 4,856,340 4,614,452 4,106,326 2,536,840 2,406,115 PV Net Measure Costs 5,303,060 5,881,880 10,794,429 10,758,455 8,681,688 8,016,752 7,726,186	Cumulative Net Peak Demand Savings - kW	9,936	20,470	39,155	55,800	71,582	86,656	104,268	116,625	118,319	116,994
Administration Costs 2,853,438 3,029,913 5,038,007 5,063,811 4,818,492 4,586,644 4,629,126 4,266,210 2,792,410 2,794,052 Marketing Costs 1,483,752 1,880,066 1,846,355 1,814,091 1,753,210 1,753,654 1,725,366 1,698,292 1,094,227 1,094,227 Incentives Costs 4,432,497 4,895,918 12,681,926 12,695,632 11,753,479 10,840,425 11,127,368 9,726,268 4,583,849 4,673,660 Total Costs 8,769,687 9,805,897 19,566,288 19,573,533 18,355,181 17,180,723 17,481,860 15,690,770 8,470,487 8,561,938 PV Net Avoided Cost Benefits 27,572,058 27,336,022 41,760,377 38,848,940 36,984,200 32,811,662 35,750,798 26,392,963 7,480,268 2,683,139 PV Annual Program Marketing and Admin Costs 4,337,190 4,654,998 6,187,903 5,861,053 5,333,539 4,856,340 4,614,452 4,106,326 2,536,840 2,406,115 PV Net Measure Costs 5,303,060 5,881,880 10,709,429 10,758,455 8,681,688 8,016,752 7,726,186 6,969,851 4,723,645 4,605,500 TRC Ratio 3,286 2,887,893 2,47 2,34 2,64 2,55 2,90 2,38 1.03 2,38 1.03 2,86 2,879 52,573 81,816 124,744 160,255 219,042 260,887 254,894 240,545 Cher Naturally Occurring - kWh 0 0 0 -8 4,351 48,050 17,2463 -330,244 -574,400 151,830,162 256,807,244 Cost per First-Year Net Wh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.21 \$0.19 \$0.25 \$-\$5.69 \$-\$0.47 PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,89,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	New Net Energy Savings - kWh	61,051,915	61,835,189	105,561,357	92,158,664	85,912,309	80,048,996	93,391,480	62,578,296	-1,489,526	-18,287,173
Marketing Costs	New Net Peak Demand Savings - kW	9,936	10,533	18,685	16,645	15,782	15,074	17,612	12,357	1,694	-1,325
Marketing Costs											
Incentive Costs	Administration Costs	2,853,438	3,029,913	5,038,007	5,063,811	4,818,492	4,586,644	4,629,126	4,266,210	2,792,410	2,794,052
Total Costs	Marketing Costs	1,483,752	1,880,066	1,846,355	1,814,091	1,783,210	1,753,654	1,725,366	1,698,292	1,094,227	1,094,227
PV Net Avoided Cost Benefits 27,572,058 27,336,022 41,760,377 38,848,940 36,984,200 32,811,662 35,750,798 26,392,963 7,480,268 2,683,139 PV Annual Program Marketing and Admin Costs 4,337,190 4,654,998 6,187,903 5,861,053 5,333,539 4,856,340 4,614,452 4,106,326 2,536,840 2,406,115 PV Net Measure Costs 5,303,060 5,881,880 10,709,429 10,758,455 8,681,688 8,016,752 7,726,186 6,969,851 4,723,645 4,605,500 TRC Ratio 2.86 2.59 2.47 2.34 2.64 2.65 2.90 2.38 1.03 0.38 Free Riders - kWh 70,186,977 133,856,838 318,421,767 487,865,136 732,905,186 935,245,093 1,267,187,224 1,503,533,422 1,469,280,505 1,389,613,41 Free Riders - kW 10,863 20,797 52,573 81,816 124,744 160,255 219,042 260,887 254,884 240,545 Other Naturally Occurring - kWh 0 0 0 -8 4,351 -48,050 -172,463 330,244 -574,400 151,830,162 256,807,244 Other Naturally Occurring - kW 0 0 0 -1 -6 -23 -43 -77 26,867 45,348 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.21 \$0.21 \$0.19 \$0.25 -\$5.69 -\$0.47 PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	Incentives Costs	4,432,497	4,895,918	12,681,926	12,695,632	11,753,479	10,840,425	11,127,368	9,726,268	4,583,849	4,673,660
PV Annual Program Marketing and Admin Costs 4,337,190 4,654,998 6,187,903 5,861,053 5,333,539 4,856,340 4,614,452 4,106,326 2,536,840 2,406,115 PV Net Measure Costs 5,303,060 5,881,880 10,709,429 10,758,455 8,681,688 8,016,752 7,726,186 6,969,851 4,723,645 4,605,500 TRC Ratio 2.86 2.59 2.47 2.34 2.64 2.55 2.90 2.38 1.03 0.38 Free Riders - kWh 70,186,977 133,856,838 318,421,767 487,865,136 732,905,186 935,245,093 1,267,187,224 1,503,533,3422 1,469,280,505 1,389,613,41 Free Riders - kW 10,863 20,797 52,573 81,816 124,744 160,255 219,042 260,887 254,884 240,545 Other Naturally Occurring - kWh 0 0 -8 -4,351 -48,050 -17,2463 -330,244 -574,400 151,830,162 256,807,244 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.	Total Costs	8,769,687	9,805,897	19,566,288	19,573,533	18,355,181	17,180,723	17,481,860	15,690,770	8,470,487	8,561,938
PV Annual Program Marketing and Admin Costs 4,337,190 4,654,998 6,187,903 5,861,053 5,333,539 4,856,340 4,614,452 4,106,326 2,536,840 2,406,115 PV Net Measure Costs 5,303,060 5,881,880 10,709,429 10,758,455 8,681,688 8,016,752 7,726,186 6,969,851 4,723,645 4,605,500 TRC Ratio 2.86 2.59 2.47 2.34 2.64 2.55 2.90 2.38 1.03 0.38 Free Riders - kWh 70,186,977 133,856,838 318,421,767 487,865,136 732,905,186 935,245,093 1,267,187,224 1,503,533,3422 1,469,280,505 1,389,613,41 Free Riders - kW 10,863 20,797 52,573 81,816 124,744 160,255 219,042 260,887 254,884 240,545 Other Naturally Occurring - kWh 0 0 -8 -4,351 -48,050 -17,2463 -330,244 -574,400 151,830,162 256,807,244 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.		·	•	•		•	•			•	
PV Net Measure Costs 5,303,060 5,881,880 10,709,429 10,758,455 8,681,688 8,016,752 7,726,186 6,969,851 4,723,645 4,605,500 TRC Ratio 2.86 2.59 2.47 2.34 2.64 2.55 2.90 2.38 1.03 0.38 Free Riders - kWh 70,186,977 133,856,838 318,421,767 487,865,136 732,905,186 935,245,093 1,267,187,224 1,503,533,422 1,469,280,505 1,389,613,41 Free Riders - kWh 10,863 20,797 52,573 81,816 124,744 160,255 219,042 260,887 254,884 240,545 Other Naturally Occurring - kWh 0 0 -8 -4,351 -48,050 -172,463 -330,244 -574,400 151,830,162 256,807,244 Other Naturally Occurring - kWh 0 0 0 -1 -6 -23 -43 -77 26,867 45,348 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.19 <th>PV Net Avoided Cost Benefits</th> <th>27,572,058</th> <th>27,336,022</th> <th>41,760,377</th> <th>38,848,940</th> <th>36,984,200</th> <th>32,811,662</th> <th>35,750,798</th> <th>26,392,963</th> <th>7,480,268</th> <th>2,683,139</th>	PV Net Avoided Cost Benefits	27,572,058	27,336,022	41,760,377	38,848,940	36,984,200	32,811,662	35,750,798	26,392,963	7,480,268	2,683,139
TRC Ratio 2.86 2.59 2.47 2.34 2.64 2.55 2.90 2.38 1.03 0.38 Free Riders - kWh 70,186,977 133,856,838 318,421,767 487,865,136 732,905,186 935,245,093 1,267,187,224 1,503,533,422 1,469,280,505 1,389,613,41 Free Riders - kWh 10,863 20,797 52,573 81,816 124,744 160,255 219,042 260,887 254,884 240,545 Other Naturally Occurring - kWh 0 0 -8 -4,351 -48,050 -172,463 -330,244 -574,400 151,830,162 256,807,244 Other Naturally Occurring - kW 0 0 -1 -6 -23 -43 -77 26,867 45,348 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.19 \$0.25 -\$5.69 -\$0.47 PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,804,878 5,52	PV Annual Program Marketing and Admin Costs	4,337,190	4,654,998	6,187,903	5,861,053	5,333,539	4,856,340	4,614,452	4,106,326	2,536,840	2,406,115
Free Riders - kWh 70,186,977 133,856,838 318,421,767 487,865,136 732,905,186 935,245,093 1,267,187,224 1,503,533,422 1,469,280,505 1,389,613,41 Free Riders - kW 10,863 20,797 52,573 81,816 124,744 160,255 219,042 260,887 254,884 240,545 Other Naturally Occurring - kWh 0 0 -8 -4,351 -48,050 -172,463 -330,244 -574,400 151,830,162 256,807,244 Other Naturally Occurring - kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.21 \$0.21 \$0.19 \$0.25 -\$5,69 -\$0.47 PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	PV Net Measure Costs	5,303,060	5,881,880	10,709,429	10,758,455	8,681,688	8,016,752	7,726,186	6,969,851	4,723,645	4,605,500
Free Riders - kW 10,863 20,797 52,573 81,816 124,744 160,255 219,042 260,887 254,884 240,545 Other Naturally Occurring - kWh 0 0 -8 -4,351 -48,050 -172,463 -330,244 -574,400 151,830,162 256,807,244 Other Naturally Occurring - kW 0 0 -1 -6 -23 -43 -77 26,867 45,348 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.19 \$0.25 -\$5.69 -\$0.47 PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	TRC Ratio	2.86	2.59	2.47	2.34	2.64	2.55	2.90	2.38	1.03	0.38
Free Riders - kW 10,863 20,797 52,573 81,816 124,744 160,255 219,042 260,887 254,884 240,545 Other Naturally Occurring - kWh 0 0 -8 -4,351 -48,050 -172,463 -330,244 -574,400 151,830,162 256,807,244 Other Naturally Occurring - kW 0 0 -1 -6 -23 -43 -77 26,867 45,348 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.19 \$0.25 -\$5.69 -\$0.47 PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705		•	•	3			3			3	
Other Naturally Occurring - kWh 0 0 -8 -4,351 -48,050 -172,463 -330,244 -574,400 151,830,162 256,807,244 Other Naturally Occurring - kW 0 0 0 -1 -6 -23 -43 -77 26,867 45,348 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.19 \$0.25 -\$5.69 -\$0.47 PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	Free Riders - kWh	70,186,977	133,856,838	318,421,767	487,865,136	732,905,186	935,245,093	1,267,187,224	1,503,533,422	1,469,280,505	1,389,613,411
Other Naturally Occurring - kW 0 0 0 -1 -6 -23 -43 -77 26,867 45,348 Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.19 \$0.25 -\$5.69 -\$0.47 PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	Free Riders - kW	10,863	20,797	52,573	81,816	124,744	160,255	219,042	260,887	254,884	240,545
Cost per First-Year Net kWh \$0.14 \$0.16 \$0.19 \$0.21 \$0.21 \$0.21 \$0.19 \$0.25 -\$5.69 -\$0.47 PV Annual Program Costs 8.769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	Other Naturally Occurring - kWh	0	0	-8	-4,351	-48,050	-172,463	-330,244	-574,400	151,830,162	256,807,244
PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	Other Naturally Occurring - kW	0	0	0	-1	-6	-23	-43	-77	26,867	45,348
PV Annual Program Costs 8,769,687 9,296,665 17,586,856 16,679,725 14,829,217 13,159,545 12,694,832 10,802,480 5,528,756 5,298,233 PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705											
PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705	Cost per First-Year Net kWh	\$0.14	\$0.16	\$0.19	\$0.21	\$0.21	\$0.21	\$0.19	\$0.25	-\$5.69	-\$0.47
PV Lost Revenue 38,712,047 36,669,377 55,827,908 49,483,996 44,817,065 38,017,344 40,169,991 28,044,878 5,971,440 724,705											
	PV Annual Program Costs	8,769,687	9,296,665	17,586,856	16,679,725	14,829,217	13,159,545	12,694,832	10,802,480	5,528,756	5,298,233
RIM 0.58 0.59 0.57 0.59 0.62 0.64 0.68 0.68 0.65 0.45	PV Lost Revenue	38,712,047	36,669,377	55,827,908	49,483,996	44,817,065	38,017,344	40,169,991	28,044,878	5,971,440	724,705
	RIM	0.58	0.59	0.57	0.59	0.62	0.64	0.68	0.68	0.65	0.45



Electricity	
Residential	
Total	
50 Percent	

Cumulative Gross Energy - kWh 115,768,110 265,15 Cumulative Gross Peak Demand - kW 21,329 50,0 Cumulative Net Energy Savings - kWh 89,783,087 212,17 Cumulative Net Peak Demand Savings - kW 16,435 40,1 New Net Energy Savings - kWh 89,783,087 122,39 New Net Peak Demand Savings - kW 16,435 23,6 Administration Costs 7,732,716 9,233 Marketing Costs 3,159,527 3,394 Incentives Costs 12,609,559 16,183	55,477 ,057 ,79,126 ,105 ,96,039 ,670 ,670 ,3,172 ,4,874 ,33,772	2016 425,016,033 81,245 348,380,208 66,696 136,201,082 26,590 10,324,296 3,602,974 18,386,254	2017 589,538,076 113,110 488,880,910 93,931 140,500,702 27,235 11,012,454 3,774,910 19,293,186	2018 795,345,108 148,533 661,241,346 123,726 172,360,436 29,795 12,310,974 3,938,884	2019 987,158,008 180,943 819,550,484 150,568 158,309,138 26,842 12,673,699 3,938,884	182,268 211,555,921 31,701 13,830,663	259,207 1,212,662,451 209,731 181,556,046 27,463 13,764,640	2022 1,740,947,161 291,776 1,365,717,581 233,275 153,055,130 23,543 13,647,355	2023 1,927,789,326 320,131 1,489,552,604 253,128 123,835,023 19,853
Cumulative Gross Peak Demand - kW 21,329 50,6 Cumulative Net Energy Savings - kWh 89,783,087 212,17 Cumulative Net Peak Demand Savings - kWh 16,435 40,1 New Net Energy Savings - kWh 89,783,087 122,39 New Net Peak Demand Savings - kW 16,435 23,6 Administration Costs 7,732,716 9,233 Marketing Costs 3,159,527 3,394	,057 79,126 ,105 96,039 ,670 3,172 4,874 33,772	81,245 348,380,208 66,696 136,201,082 26,590 10,324,296 3,602,974 18,386,254	113,110 488,880,910 93,931 140,500,702 27,235 11,012,454 3,774,910	148,533 661,241,346 123,726 172,360,436 29,795 12,310,974 3,938,884	180,943 819,550,484 150,568 158,309,138 26,842 12,673,699	222,421 1,031,106,405 182,268 211,555,921 31,701 13,830,663	259,207 1,212,662,451 209,731 181,556,046 27,463 13,764,640	291,776 1,365,717,581 233,275 153,055,130 23,543 13,647,355	320,131 1,489,552,604 253,128 123,835,023 19,853
Cumulative Net Energy Savings - kWh 89,783,087 212,17 Cumulative Net Peak Demand Savings - kW 16,435 40,1 New Net Energy Savings - kWh 89,783,087 122,39 New Net Peak Demand Savings - kW 16,435 23,6 Administration Costs 7,732,716 9,233 Marketing Costs 3,159,527 3,394	79,126 ,105 96,039 ,670 3,172 4,874 33,772	348,380,208 66,696 136,201,082 26,590 10,324,296 3,602,974 18,386,254	488,880,910 93,931 140,500,702 27,235 11,012,454 3,774,910	661,241,346 123,726 172,360,436 29,795 12,310,974 3,938,884	819,550,484 150,568 158,309,138 26,842 12,673,699	1,031,106,405 182,268 211,555,921 31,701 13,830,663	1,212,662,451 209,731 181,556,046 27,463	1,365,717,581 233,275 153,055,130 23,543 13,647,355	1,489,552,604 253,128 123,835,023 19,853
Cumulative Net Peak Demand Savings - kW 16,435 40,1 New Net Energy Savings - kWh 89,783,087 122,39 New Net Peak Demand Savings - kW 16,435 23,6 Administration Costs 7,732,716 9,233 Marketing Costs 3,159,527 3,394	3,172 4,874 33,772	66,696 136,201,082 26,590 10,324,296 3,602,974 18,386,254	93,931 140,500,702 27,235 11,012,454 3,774,910	123,726 172,360,436 29,795 12,310,974 3,938,884	150,568 158,309,138 26,842 12,673,699	182,268 211,555,921 31,701 13,830,663	209,731 181,556,046 27,463 13,764,640	233,275 153,055,130 23,543 13,647,355	253,128 123,835,023 19,853
New Net Energy Savings - kWh 89,783,087 122,39 New Net Peak Demand Savings - kW 16,435 23,6 Administration Costs 7,732,716 9,233 Marketing Costs 3,159,527 3,394	96,039 ,670 3,172 4,874 33,772	136,201,082 26,590 10,324,296 3,602,974 18,386,254	140,500,702 27,235 11,012,454 3,774,910	172,360,436 29,795 12,310,974 3,938,884	158,309,138 26,842 12,673,699	211,555,921 31,701 13,830,663	181,556,046 27,463 13,764,640	153,055,130 23,543 13,647,355	123,835,023 19,853
New Net Peak Demand Savings - kW 16,435 23,6 Administration Costs 7,732,716 9,233 Marketing Costs 3,159,527 3,394	3,172 4,874 33,772	26,590 10,324,296 3,602,974 18,386,254	27,235 11,012,454 3,774,910	29,795 12,310,974 3,938,884	26,842 12,673,699	31,701 13,830,663	27,463 13,764,640	23,543 13,647,355	19,853
Administration Costs 7,732,716 9,233 Marketing Costs 3,159,527 3,394	3,172 4,874 33,772	10,324,296 3,602,974 18,386,254	11,012,454 3,774,910	12,310,974 3,938,884	12,673,699	13,830,663	13,764,640	13,647,355	
Marketing Costs 3,159,527 3,394	4,874 33,772	3,602,974 18,386,254	3,774,910	3,938,884			-, - ,		13,506,735
Marketing Costs 3,159,527 3,394	4,874 33,772	3,602,974 18,386,254	3,774,910	3,938,884			-, - ,		13,506,735
	33,772	18,386,254			3 938 884	2 020 004			
Incentives Costs 12,609,559 16,183	/	-,, -	19 293 186		0,000,004	3,938,884	3,938,884	3,938,884	3,938,884
	11.818		10,200,100	21,185,245	21,148,172	22,899,733	22,209,577	21,590,733	21,096,534
Total Costs 23,501,803 28,813		32,313,524	34,080,550	37,435,103	37,760,755	40,669,281	39,913,102	39,176,973	38,542,153
·	-	·						-	
PV Net Avoided Cost Benefits 45,111,563 59,336	36,752	70,601,299	71,177,097	103,633,245	102,202,335	160,962,197	147,241,801	132,600,720	107,225,549
PV Annual Program Marketing and Admin Costs 10,892,243 11,972	72,257	12,518,312	12,601,157	13,128,319	12,724,379	12,903,742	12,188,182	11,478,683	10,795,565
PV Net Measure Costs 22,418,120 27,926	26,788	30,331,533	30,268,552	31,241,959	29,529,613	29,370,212	26,846,775	24,655,136	22,804,918
TRC Ratio 1.35 1.4	.49	1.65	1.66	2.34	2.42	3.81	3.77	3.67	3.19
	·							ş	
Free Riders - kWh 25,985,023 52,976	76,350	76,653,357	100,692,464	134,216,442	167,816,201	239,388,458	308,339,542	375,604,823	438,802,477
Free Riders - kW 4,894 9,9	952	14,553	19,186	24,825	30,407	40,192	49,523	58,563	67,092
Other Naturally Occurring - kWh 0	0	-17,531	-35,299	-112,679	-208,677	-249,013	-290,022	-375,243	-565,755
Other Naturally Occurring - kW 0	0	-3	-7	-18	-31	-39	-47	-61	-88
Cost per First-Year Net kWh \$0.26 \$0.).24	\$0.24	\$0.24	\$0.22	\$0.24	\$0.19	\$0.22	\$0.26	\$0.31
<u> </u>									
PV Annual Program Costs 23,501,803 27,315	15,588	29,044,513	29,041,982	30,243,955	28,922,784	29,532,880	27,478,605	25,571,133	23,850,361
PV Lost Revenue 87,802,023 110,40		126,456,912	123,677,995	173,094,342	162,640,080	241,094,239	211,251,736	183,175,281	145,050,618
RIM 0.41 0.4	.43	0.45	0.47	0.51	0.53	0.59	0.62	0.64	0.63



Electricity	
All Segments	
Total	
75 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	394,685,825	849,592,751	1,536,295,710	2,188,486,217	2,919,586,677	3,568,096,715	4,450,682,653	5,146,827,354	5,567,003,717	5,811,228,018
Cumulative Gross Peak Demand - kW	68,237	151,285	276,979	397,202	527,699	643,965	796,644	918,620	995,282	1,042,801
Cumulative Net Energy Savings - kWh	298,513,825	662,759,562	1,141,546,367	1,600,596,739	2,070,088,796	2,496,861,611	2,983,728,308	3,381,833,063	3,622,935,500	3,784,060,444
Cumulative Net Peak Demand Savings - kW	52,480	120,536	209,890	296,277	381,156	458,779	544,010	615,835	663,396	698,967
New Net Energy Savings - kWh	298,513,825	364,245,737	478,786,804	459,050,372	469,492,058	426,772,814	486,866,697	398,104,755	241,102,437	161,124,944
New Net Peak Demand Savings - kW	52,480	68,056	89,354	86,387	84,880	77,623	85,231	71,825	47,560	35,572
Administration Costs	27,717,079	32,344,938	39,384,854	41,293,021	43,104,185	43,400,012	44,769,079	43,982,224	40,656,244	40,237,802
Marketing Costs	5,096,962	7,445,787	7,637,615	7,791,253	7,937,656	7,905,144	7,874,028	7,844,246	7,179,775	7,179,775
Incentives Costs	47,801,989	59,810,884	82,347,356	84,800,314	85,429,096	83,664,862	86,750,423	83,259,170	70,994,164	69,870,803
Total	80,616,030	99,601,608	129,369,825	133,884,587	136,470,936	134,970,018	139,393,529	135,085,639	118,830,183	117,288,380
			3						3	· · · · · · · · · · · · · · · · · · ·
PV Net Avoided Cost Benefits	149,706,194	178,622,619	232,001,155	225,592,558	263,559,312	254,842,969	302,259,377	268,343,077	211,181,284	165,577,189
PV Annual Program Marketing and Admin Costs	32,814,042	37,724,347	42,265,421	41,827,511	41,236,887	39,297,095	38,227,934	35,680,492	31,222,963	29,342,582
PV Net Measure Costs	57,780,388	69,877,600	83,945,765	82,921,670	79,419,234	74,554,579	72,013,700	66,574,375	57,163,489	53,323,168
TRC Ratio	1.65	1.66	1.84	1.81	2.18	2.24	2.74	2.62	2.39	2.00
	•		•			•	•	•	•	•
Free Riders - kWh	96,172,000	186,833,189	394,766,883	587,929,127	849,658,610	1,071,616,244	1,467,533,602	1,765,858,713	1,795,055,805	1,775,305,192
Free Riders - kW	15,756	30,749	67,092	100,933	146,567	185,241	252,715	302,908	305,500	299,325
Other Naturally Occurring - kWh	0	0	-17,539	-39,650	-160,729	-381,140	-579,257	-864,422	149,012,413	251,862,382
Other Naturally Occurring - kW	0	0	-3	-8	-24	-55	-82	-124	26,386	44,509
Cost per First-Year Net kWh	\$0.27	\$0.27	\$0.27	\$0.29	\$0.29	\$0.32	\$0.29	\$0.34	\$0.49	\$0.73
PV Annual Program Costs	80,616,030	94,429,184	116,282,072	114,090,699	110,255,361	103,380,050	101,223,636	93,001,165	77,561,439	72,579,498
PV Lost Revenue	259,308,063	299,725,337	373,068,265	350,551,405	399,202,071	368,813,015	420,355,262	359,779,196	276,943,827	211,191,907
RIM	0.44	0.45	0.47	0.49	0.52	0.54	0.58	0.59	0.60	0.58



Electricity	
Commercial	
Total	
75 Percent	

· ·										
	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	186,779,621	374,044,973	768,042,619	1,127,157,960	1,530,236,843	1,877,982,291	2,392,489,210	2,758,247,652	2,891,577,019	2,903,030,521
Cumulative Gross Peak Demand - kW	29,568	60,394	129,108	192,600	264,656	327,939	421,494	489,316	517,960	524,717
Cumulative Net Energy Savings - kWh	116,592,644	240,188,134	449,720,991	639,494,101	813,409,586	971,870,707	1,158,686,212	1,291,703,581	1,309,539,634	1,297,387,190
Cumulative Net Peak Demand Savings - kW	18,705	39,597	76,546	110,805	142,760	172,849	208,343	234,933	243,098	246,016
New Net Energy Savings - kWh	116,592,644	123,595,491	209,532,857	189,773,110	173,915,485	158,461,121	186,815,506	133,017,369	17,836,053	-12,152,443
New Net Peak Demand Savings - kW	18,705	20,892	36,948	34,259	31,955	30,090	35,494	26,590	8,165	2,919
Administration Costs	7,731,537	8,636,554	12,789,781	13,174,694	12,604,774	12,304,277	12,627,741	12,013,241	9,027,838	8,999,647
Marketing Costs	1,632,127	3,722,070	3,684,988	3,649,497	3,615,528	3,583,017	3,551,900	3,522,118	2,857,647	2,857,647
Incentives Costs	12,034,834	14,367,106	30,957,447	31,976,808	29,413,126	28,176,347	29,953,201	27,629,294	16,872,177	17,199,935
Total Costs	21,398,497	26,725,730	47,432,216	48,800,998	45,633,428	44,063,640	46,132,842	43,164,653	28,757,662	29,057,229
					•			3		3
PV Net Avoided Cost Benefits	56,104,661	58,947,862	87,339,171	83,188,804	79,247,217	70,960,464	77,868,698	61,003,491	24,963,300	15,971,193
PV Annual Program Marketing and Admin Costs	9,363,663	11,716,826	14,808,092	14,336,853	13,104,440	12,168,845	11,749,197	10,695,485	7,757,754	7,337,440
PV Net Measure Costs	12,895,294	15,196,325	25,077,672	25,514,681	22,042,397	20,727,596	20,777,875	19,113,779	13,468,634	13,054,509
TRC Ratio	2.52	2.19	2.19	2.09	2.25	2.16	2.39	2.05	1.18	0.78
•					•			3		3
Free Riders - kWh	70,186,977	133,856,838	318,321,636	487,668,211	716,875,307	906,284,047	1,234,133,242	1,467,118,470	1,432,649,730	1,353,215,194
Free Riders - kW	10,863	20,797	52,563	81,796	121,903	155,113	213,194	254,460	248,415	234,104
Other Naturally Occurring - kWh	0	0	-8	-4,351	-48,050	-172,463	-330,244	-574,400	149,387,655	252,428,137
Other Naturally Occurring - kW	0	0	0	-1	-6	-23	-43	-77	26,447	44,597
Cost per First-Year Net kWh	\$0.18	\$0.22	\$0.23	\$0.26	\$0.26	\$0.28	\$0.25	\$0.32	\$1.61	-\$2.39
								•		•
PV Annual Program Costs	21,398,497	25,337,833	42,633,716	41,586,116	36,867,411	33,750,468	33,500,364	29,717,171	18,770,363	17,980,972
PV Lost Revenue	78,569,064	78,802,971	115,955,029	105,310,984	95,341,321	81,456,946	86,794,134	64,426,333	21,853,993	11,734,790
RIM	0.56	0.57	0.55	0.57	0.60	0.62	0.65	0.65	0.61	0.54



Electricity	
Residential	
Total	
75 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	207,906,204	475,547,778	768,253,091	1,061,328,257	1,389,349,834	1,690,114,424	2,058,193,443	2,388,579,703	2,675,426,698	2,908,197,496
Cumulative Gross Peak Demand - kW	38,669	90,890	147,870	204,602	263,043	316,027	375,150	429,304	477,322	518,083
Cumulative Net Energy Savings - kWh	181,921,181	422,571,428	691,825,376	961,102,638	1,256,679,210	1,524,990,904	1,825,042,095	2,090,129,482	2,313,395,866	2,486,673,254
Cumulative Net Peak Demand Savings - kW	33,775	80,939	133,344	185,472	238,397	285,930	335,667	380,903	420,298	452,951
New Net Energy Savings - kWh	181,921,181	240,650,247	269,253,948	269,277,263	295,576,572	268,311,694	300,051,191	265,087,386	223,266,385	173,277,387
New Net Peak Demand Savings - kW	33,775	47,164	52,405	52,128	52,925	47,533	49,738	45,235	39,395	32,653
Administration Costs	19,985,543	23,708,383	26,595,072	28,118,326	30,499,411	31,095,735	32,141,338	31,968,983	31,628,406	31,238,155
Marketing Costs	3,464,836	3,723,717	3,952,627	4,141,756	4,322,128	4,322,128	4,322,128	4,322,128	4,322,128	4,322,128
Incentives Costs	35,767,155	45,443,778	51,389,909	52,823,506	56,015,970	55,488,516	56,797,221	55,629,876	54,121,987	52,670,868
Total Costs	59,217,533	72,875,878	81,937,609	85,083,589	90,837,508	90,906,378	93,260,687	91,920,986	90,072,521	88,231,150
	•							-		•
PV Net Avoided Cost Benefits	93,601,533	119,674,757	144,661,985	142,403,754	184,312,095	183,882,504	224,390,679	207,339,586	186,217,984	149,605,995
PV Annual Program Marketing and Admin Costs	23,450,378	26,007,520	27,457,329	27,490,658	28,132,446	27,128,250	26,478,737	24,985,006	23,465,209	22,005,142
PV Net Measure Costs	44,885,094	54,681,275	58,868,093	57,406,990	57,376,837	53,826,982	51,235,825	47,460,596	43,694,855	40,268,659
TRC Ratio	1.37	1.48	1.68	1.68	2.16	2.27	2.89	2.86	2.77	2.40
	•							-		•
Free Riders - kWh	25,985,023	52,976,350	76,445,247	100,260,917	132,783,303	165,332,197	233,400,360	298,740,243	362,406,075	422,089,998
Free Riders - kW	4,894	9,952	14,530	19,137	24,664	30,129	39,521	48,448	57,085	65,221
Other Naturally Occurring - kWh	0	0	-17,531	-35,299	-112,679	-208,677	-249,013	-290,022	-375,243	-565,755
Other Naturally Occurring - kW	0	0	-3	-7	-18	-31	-39	-47	-61	-88
Cost per First-Year Net kWh	\$0.33	\$0.30	\$0.30	\$0.32	\$0.31	\$0.34	\$0.31	\$0.35	\$0.40	\$0.51
	•							•		•
PV Annual Program Costs	59,217,533	69,091,351	73,648,356	72,504,583	73,387,950	69,629,582	67,723,271	63,283,994	58,791,076	54,598,526
PV Lost Revenue	180,738,999	220,922,366	257,113,237	245,240,421	303,860,751	287,356,069	333,561,128	295,352,863	255,089,835	199,457,117
RIM	0.39	0.41	0.44	0.45	0.49	0.52	0.56	0.58	0.59	0.59



Electricity	
All Segments	
Total	
50 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	210,040,840	438,880,075	843,249,170	1,228,003,338	1,731,950,922	2,180,323,280	2,865,277,467	3,396,172,671	3,721,005,456	3,905,675,633
Cumulative Gross Peak Demand - kW	33,486	71,294	141,449	208,852	294,893	371,918	484,938	572,397	625,332	654,803
Cumulative Net Energy Savings - kWh	126,867,479	276,169,120	482,995,916	683,993,340	919,236,820	1,140,684,267	1,434,149,714	1,670,551,500	1,817,949,008	1,920,439,654
Cumulative Net Peak Demand Savings - kW	20,107	45,034	80,867	116,308	155,829	193,662	240,499	278,951	303,588	321,781
New Net Energy Savings - kWh	126,867,479	149,301,641	206,826,796	200,997,424	235,243,479	221,447,447	293,465,447	236,401,785	147,397,508	102,490,646
New Net Peak Demand Savings - kW	20,107	24,928	35,832	35,442	39,520	37,833	46,838	38,451	24,638	18,193
Administration Costs	10,048,309	11,644,081	14,645,182	15,335,265	16,398,684	16,536,776	17,768,546	17,366,385	15,794,925	15,668,218
Marketing Costs	4,430,334	5,005,841	5,169,475	5,300,260	5,424,879	5,395,323	5,367,035	5,339,960	4,735,896	4,735,896
Incentives Costs	14,115,056	17,062,232	26,545,276	27,583,394	29,027,783	28,600,316	31,116,160	29,435,017	23,919,266	23,598,896
Total	28,593,700	33,712,154	46,359,932	48,218,918	50,851,346	50,532,415	54,251,740	52,141,362	44,450,087	44,003,010
	•	3	3			•			•	
PV Net Avoided Cost Benefits	61,456,788	70,768,308	95,814,662	95,141,540	129,391,202	126,763,782	191,186,800	169,648,337	137,281,057	107,521,430
PV Annual Program Marketing and Admin Costs	14,478,643	15,785,272	17,810,099	17,584,709	17,631,335	16,798,853	16,800,404	15,632,428	13,400,636	12,626,318
PV Net Measure Costs	22,997,243	27,241,894	34,002,903	34,529,871	34,576,821	33,249,459	33,697,154	31,124,528	27,115,970	25,342,967
TRC Ratio	1.64	1.64	1.85	1.83	2.48	2.53	3.79	3.63	3.39	2.83
	·	•	•			•			•	
Free Riders - kWh	83,173,361	162,710,955	360,259,691	544,027,067	812,816,011	1,039,920,719	1,431,570,787	1,726,315,326	1,751,340,062	1,728,619,987
Free Riders - kW	13,379	26,259	60,583	92,546	139,078	178,294	244,498	293,542	294,895	287,699
Other Naturally Occurring - kWh	0	0	-6,437	-17,070	-101,908	-281,706	-443,035	-694,154	151,716,386	256,615,993
Other Naturally Occurring - kW	0	0	-1	-2	-13	-38	-59	-95	26,849	45,323
Cost per First-Year Net kWh	\$0.23	\$0.23	\$0.22	\$0.24	\$0.22	\$0.23	\$0.18	\$0.22	\$0.30	\$0.43
	•					•	•	•		•
PV Annual Program Costs	28,593,700	31,961,443	41,669,910	41,090,092	41,082,985	38,705,215	39,396,078	35,897,282	29,012,938	27,229,606
PV Lost Revenue	107,339,610	120,716,926	155,716,096	149,826,113	201,033,145	188,614,918	273,355,970	233,633,311	185,273,512	142,454,759
RIM	0.45	0.46	0.49	0.50	0.53	0.56	0.61	0.63	0.64	0.63





Electricity	
Commercial	
Total	
50 Percent	

		2215	2212	2017	2010	2212	2222	2021	2222	2222
	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	120,239,179	236,489,689	517,295,883	771,648,165	1,094,905,598	1,369,019,322			2,182,589,010	
Cumulative Gross Peak Demand - kW	19,151	38,203	87,176	131,893	189,218	238,299	312,716	365,164	386,580	388,565
Cumulative Net Energy Savings - kWh	57,711,570	116,121,513	218,872,145	309,367,810	393,934,132	471,339,908	562,097,115	622,358,009	619,513,813	600,665,775
Cumulative Net Peak Demand Savings - kW	9,283	19,143	37,257	53,526	68,963	83,465	100,509	112,357	113,705	112,170
New Net Energy Savings - kWh	57,711,570	58,409,943	102,750,632	90,495,665	84,566,321	77,405,776	90,757,207	60,260,895	-2,844,196	-18,848,038
New Net Peak Demand Savings - kW	9,283	9,860	18,114	16,268	15,437	14,502	17,045	11,848	1,348	-1,535
Administration Costs	2,678,984	2,852,093	4,802,745	4,825,610	4,584,004	4,358,035	4,411,576	4,060,610	2,598,560	2,611,279
Marketing Costs	1,432,983	1,785,306	1,751,596	1,719,331	1,688,450	1,658,895	1,630,607	1,603,532	999,468	999,468
Incentives Costs	4,069,649	4,533,537	12,230,591	12,245,317	11,313,274	10,413,283	10,720,033	9,342,819	4,224,187	4,336,395
Total Costs	8,181,616	9,170,936	18,784,932	18,790,258	17,585,728	16,430,213	16,762,215	15,006,961	7,822,214	7,947,141
	•	3	s		•				3	
PV Net Avoided Cost Benefits	26,423,857	26,222,045	40,588,807	37,840,597	36,025,594	31,731,076	34,702,410	25,466,278	6,830,129	2,263,945
PV Annual Program Marketing and Admin Costs	4,111,967	4,396,574	5,891,268	5,577,318	5,067,539	4,608,657	4,387,662	3,899,540	2,348,462	2,234,374
PV Net Measure Costs	4,953,535	5,532,775	10,317,392	10,370,859	8,355,436	7,708,684	7,457,080	6,723,720	4,500,409	4,403,501
TRC Ratio	2.91	2.64	2.50	2.37	2.68	2.58	2.93	2.40	1.00	0.34
	•	•	•		•			•	•	
Free Riders - kWh	62,527,608	120,368,176	298,423,745	462,284,138	700,998,801	897,808,058	1,221,484,690	1,450,625,238	1,411,115,609	1,327,639,373
Free Riders - kW	9,868	19,059	49,919	78,368	120,259	154,854	212,244	252,876	245,993	231,021
Other Naturally Occurring - kWh	0	0	-8	-3,783	-27,335	-128,644	-267,233	-494,948	151,959,588	257,008,024
Other Naturally Occurring - kW	0	0	0	-1	-4	-19	-37	-70	26,881	45,374
Cost per First-Year Net kWh	\$0.14	\$0.16	\$0.18	\$0.21	\$0.21	\$0.21	\$0.18	\$0.25	-\$2.75	-\$0.42
PV Annual Program Costs	8,181,616	8,694,679	16,884,546	16,012,252	14,207,573	12,584,693	12,172,246	10,331,704	5,105,623	4,917,789
PV Lost Revenue	37,139,202	35,196,124	54,335,234	48,287,365	43,746,526	36,809,705	39,040,638	27,089,522	5,352,286	367,738
RIM	0.58	0.60	0.57	0.59	0.62	0.64	0.68	0.68	0.65	0.43





Electricity	
Residential	
Total	
50 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	89,801,661	202,390,386	325,953,287	456,355,173	637,045,324	811,303,959	1,081,962,894	1,323,684,372	1,538,416,445	1,720,362,462
Cumulative Gross Peak Demand - kW	14,334	33,091	54,273	76,959	105,676	133,619	172,222	207,234	238,752	266,238
Cumulative Net Energy Savings - kWh	69,155,908	160,047,607	264,123,770	374,625,530	525,302,688	669,344,359	872,052,599	1,048,193,490	1,198,435,195	1,319,773,879
Cumulative Net Peak Demand Savings - kW	10,824	25,891	43,609	62,783	86,866	110,197	139,990	166,594	189,883	209,610
New Net Energy Savings - kWh	69,155,908	90,891,699	104,076,163	110,501,759	150,677,158	144,041,671	202,708,241	176,140,891	150,241,705	121,338,684
New Net Peak Demand Savings - kW	10,824	15,067	17,719	19,173	24,083	23,331	29,793	26,603	23,289	19,728
Administration Costs	7,369,325	8,791,987	9,842,437	10,509,655	11,814,680	12,178,741	13,356,969	13,305,774	13,196,365	13,056,939
Marketing Costs	2,997,351	3,220,535	3,417,879	3,580,929	3,736,428	3,736,428	3,736,428	3,736,428	3,736,428	3,736,428
Incentives Costs	10,045,408	12,528,695	14,314,685	15,338,076	17,714,510	18,187,033	20,396,128	20,092,198	19,695,079	19,262,502
Total Costs	20,412,084	24,541,217	27,575,001	29,428,660	33,265,618	34,102,202	37,489,525	37,134,400	36,627,873	36,055,869
	•	•			-		<u>-</u>			
PV Net Avoided Cost Benefits	35,032,931	44,546,263	55,225,856	57,300,943	93,365,608	95,032,707	156,484,389	144,182,059	130,450,928	105,257,485
PV Annual Program Marketing and Admin Costs	10,366,676	11,388,698	11,918,831	12,007,391	12,563,796	12,190,196	12,412,741	11,732,888	11,052,174	10,391,943
PV Net Measure Costs	18,043,707	21,709,119	23,685,511	24,159,012	26,221,385	25,540,775	26,240,074	24,400,807	22,615,562	20,939,466
TRC Ratio	1.23	1.35	1.55	1.58	2.41	2.52	4.05	3.99	3.87	3.36
	•	•			-		<u>-</u>			
Free Riders - kWh	20,645,753	42,342,779	61,835,946	81,742,929	111,817,210	142,112,661	210,086,097	275,690,088	340,224,452	400,980,614
Free Riders - kW	3,510	7,200	10,664	14,178	18,819	23,441	32,253	40,665	48,901	56,678
Other Naturally Occurring - kWh	0	0	-6,429	-13,287	-74,574	-153,061	-175,802	-199,206	-243,202	-392,031
Other Naturally Occurring - kW	0	0	-1	-2	-9	-18	-22	-25	-32	-51
Cost per First-Year Net kWh	\$0.30	\$0.27	\$0.26	\$0.27	\$0.22	\$0.24	\$0.18	\$0.21	\$0.24	\$0.30
	•	•			•		•			
PV Annual Program Costs	20,412,084	23,266,764	24,785,364	25,077,841	26,875,412	26,120,522	27,223,832	25,565,578	23,907,314	22,311,817
PV Lost Revenue	70,200,408	85,520,802	101,380,862	101,538,749	157,286,619	151,805,213	234,315,332	206,543,789	179,921,227	142,087,022
RIM	0.39	0.41	0.44	0.45	0.51	0.53	0.60	0.62	0.64	0.64



APPENDIX J System



Electricity	
All Segments	
Total	
75 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	344,815,903	736,990,657	1,364,317,594	1,967,341,932	2,664,668,970	3,291,142,541	4,151,776,196	4,827,102,360	5,231,902,577	5,465,570,530
Cumulative Gross Peak Demand - kW	56,194	123,465	234,250	342,481	465,234	576,986	725,677	843,820	917,437	962,862
Cumulative Net Energy Savings - kWh	261,642,542	574,279,702	1,004,372,087	1,423,959,416	1,869,195,525	2,282,521,456	2,758,669,650	3,145,959,789	3,379,139,261	3,535,466,457
Cumulative Net Peak Demand Savings - kW	42,815	97,206	173,701	250,006	329,132	404,074	487,577	557,606	603,712	638,490
New Net Energy Savings - kWh	261,642,542	312,637,160	430,092,384	419,587,330	445,236,109	413,325,931	476,148,194	387,290,140	233,179,472	156,327,196
New Net Peak Demand Savings - kW	42,815	54,390	76,496	76,305	79,126	74,943	83,503	70,028	46,106	34,778
Administration Costs	26,650,764	31,106,042	37,912,141	39,797,441	41,624,823	41,983,959	43,397,323	42,658,169	39,372,060	38,982,444
Marketing Costs	4,863,214	6,509,437	6,689,435	6,833,298	6,970,379	6,937,867	6,906,750	6,876,968	6,212,497	6,212,497
Incentives Costs	41,201,485	50,846,144	72,838,743	76,432,182	78,744,559	78,230,481	81,937,195	78,663,323	66,621,535	65,604,398
Total	72,715,463	88,461,623	117,440,319	123,062,921	127,339,761	127,152,307	132,241,268	128,198,461	112,206,093	110,799,339
	•									
PV Net Avoided Cost Benefits	132,405,740	155,210,837	209,279,118	207,350,450	251,365,351	247,124,405	296,384,667	262,939,508	206,709,005	161,706,196
PV Annual Program Marketing and Admin Costs	31,513,979	35,662,065	40,089,439	39,736,714	39,260,239	37,471,587	36,529,394	34,102,999	29,753,416	27,967,188
PV Net Measure Costs	50,038,758	59,526,640	73,617,520	74,402,932	73,162,698	69,871,129	68,148,263	63,076,696	54,012,273	50,398,660
TRC Ratio	1.62	1.63	1.84	1.82	2.24	2.30	2.83	2.71	2.47	2.06
	•						3			
Free Riders - kWh	83,173,361	162,710,955	359,951,944	543,399,586	795,575,353	1,008,902,791	1,393,549,581	1,681,836,725	1,703,489,439	1,677,867,205
Free Riders - kW	13,379	26,259	60,549	92,477	136,115	172,950	238,159	286,309	287,295	279,801
Other Naturally Occurring - kWh	0	0	-6,437	-17,070	-101,908	-281,706	-443,035	-694,154	149,273,877	252,236,868
Other Naturally Occurring - kW	0	0	-1	-2	-13	-38	-59	-95	26,430	44,572
Cost per First-Year Net kWh	\$0.28	\$0.28	\$0.27	\$0.29	\$0.29	\$0.31	\$0.28	\$0.33	\$0.48	\$0.71
	•						•			
PV Annual Program Costs	72,715,463	83,867,711	105,559,420	104,868,940	102,878,252	97,392,088	96,029,866	88,259,612	73,237,840	68,564,000
PV Lost Revenue	229,602,845	260,785,709	336,550,326	322,032,201	381,330,307	358,065,149	412,549,091	352,555,932	271,154,836	206,194,277
RIM	0.44	0.45	0.47	0.49	0.52	0.54	0.58	0.60	0.60	0.59
	•		•				•		•	



APPENDIX J System



Electricity	
Commercial	
Total	
75 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	174,777,492	351,523,475	733,407,281	1,082,079,891	1,472,731,366	1,808,391,251	2,307,085,666	2,660,107,556	2,785,380,638	2,792,233,968
Cumulative Gross Peak Demand - kW	27,712	56,853	123,533	185,223	255,005	316,026	406,656	472,071	499,094	504,818
Cumulative Net Energy Savings - kWh	112,249,883	231,155,299	435,083,181	619,995,471	787,567,418	939,245,763	1,117,901,317	1,244,856,568	1,259,399,824	1,246,005,999
Cumulative Net Peak Demand Savings - kW	17,844	37,794	73,625	106,877	137,552	166,258	200,117	225,421	232,760	235,202
New Net Energy Savings - kWh	112,249,883	118,905,416	203,927,882	184,912,290	167,571,947	151,678,345	178,655,554	126,955,251	14,543,256	-13,393,825
New Net Peak Demand Savings - kW	17,844	19,950	35,831	33,252	30,675	28,706	33,859	25,304	7,339	2,442
Administration Costs	7,426,622	8,302,848	12,267,485	12,618,224	12,016,114	11,741,768	12,073,247	11,502,902	8,552,382	8,551,871
Marketing Costs	1,576,281	2,977,002	2,939,920	2,904,429	2,870,461	2,837,949	2,806,832	2,777,050	2,112,579	2,112,579
Incentives Costs	11,371,249	13,628,238	29,874,475	30,824,360	28,191,116	26,995,576	28,777,289	26,531,776	15,839,006	16,218,427
Total Costs	20,374,151	24,908,088	45,081,881	46,347,013	43,077,691	41,575,293	43,657,368	40,811,728	26,503,967	26,882,877
	•	•	3				3			3
PV Net Avoided Cost Benefits	54,308,656	57,024,852	84,842,304	80,717,852	76,261,144	68,099,400	74,620,940	58,412,943	23,168,084	14,781,270
PV Annual Program Marketing and Admin Costs	9,002,902	10,694,075	13,668,942	13,227,738	12,026,917	11,167,309	10,805,493	9,831,187	6,961,108	6,599,294
PV Net Measure Costs	12,315,570	14,530,659	24,173,738	24,563,250	21,082,674	19,840,907	19,928,253	18,357,890	12,788,630	12,435,917
TRC Ratio	2.55	2.26	2.24	2.14	2.30	2.20	2.43	2.07	1.17	0.78
	·	•	•	•			•		•	•
Free Riders - kWh	62,527,608	120,368,176	298,324,108	462,088,204	685,191,282	869,274,133	1,189,451,583	1,415,745,936	1,376,463,735	1,293,599,070
Free Riders - kW	9,868	19,059	49,908	78,347	117,457	149,787	206,576	246,719	239,872	224,993
Other Naturally Occurring - kWh	0	0	-8	-3,783	-27,335	-128,644	-267,233	-494,948	149,517,079	252,628,899
Other Naturally Occurring - kW	0	0	0	-1	-4	-19	-37	-70	26,462	44,623
Cost per First-Year Net kWh	\$0.18	\$0.21	\$0.22	\$0.25	\$0.26	\$0.27	\$0.24	\$0.32	\$1.82	-\$2.01
PV Annual Program Costs	20,374,151	23,614,583	40,521,154	39,494,935	34,802,621	31,844,523	31,702,745	28,097,274	17,299,358	16,635,457
PV Lost Revenue	76,129,578	76,305,210	112,767,979	102,316,686	91,828,931	78,224,593	83,223,234	61,735,194	20,135,241	10,709,850
RIM	0.56	0.57	0.55	0.57	0.60	0.62	0.65	0.65	0.62	0.54





Electricity	
Residential	
Total	
75 Percent	

·										
	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	170,038,412	385,467,182	630,910,313	885,262,041	1,191,937,604	1,482,751,290	1,844,690,530	2,166,994,804	2,446,521,939	2,673,336,562
Cumulative Gross Peak Demand - kW	28,482	66,612	110,717	157,258	210,229	260,960	319,021	371,750	418,343	458,044
Cumulative Net Energy Savings - kWh	149,392,659	343,124,403	569,288,906	803,963,945	1,081,628,107	1,343,275,693	1,640,768,333	1,901,103,222	2,119,739,437	2,289,460,458
Cumulative Net Peak Demand Savings - kW	24,971	59,412	100,077	143,129	191,580	237,816	287,460	332,184	370,952	403,288
New Net Energy Savings - kWh	149,392,659	193,731,744	226,164,503	234,675,039	277,664,161	261,647,586	297,492,640	260,334,889	218,636,216	169,721,021
New Net Peak Demand Savings - kW	24,971	34,440	40,665	43,053	48,451	46,236	49,644	44,724	38,767	32,336
Administration Costs	19,224,143	22,803,194	25,644,656	27,179,217	29,608,710	30,242,191	31,324,076	31,155,267	30,819,678	30,430,573
Marketing Costs	3,286,933	3,532,435	3,749,514	3,928,869	4,099,918	4,099,918	4,099,918	4,099,918	4,099,918	4,099,918
Incentives Costs	29,830,236	37,217,906	42,964,267	45,607,822	50,553,443	51,234,905	53,159,906	52,131,547	50,782,530	49,385,971
Total Costs	52,341,312	63,553,535	72,358,438	76,715,908	84,262,070	85,577,014	88,583,900	87,386,732	85,702,125	83,916,462
PV Net Avoided Cost Benefits	78,097,084	98,185,985	124,436,814	126,632,598	175,104,207	179,025,005	221,763,727	204,526,565	183,540,922	146,924,926
PV Annual Program Marketing and Admin Costs	22,511,076	24,967,990	26,420,497	26,508,976	27,233,322	26,304,279	25,723,902	24,271,812	22,792,308	21,367,894
PV Net Measure Costs	37,723,189	44,995,981	49,443,782	49,839,682	52,080,024	50,030,222	48,220,011	44,718,805	41,223,644	37,962,743
TRC Ratio	1.30	1.40	1.64	1.66	2.21	2.35	3.00	2.96	2.87	2.48
•							•			<u>-</u>
Free Riders - kWh	20,645,753	42,342,779	61,627,836	81,311,382	110,384,071	139,628,658	204,097,999	266,090,789	327,025,704	384,268,135
Free Riders - kW	3,510	7,200	10,641	14,130	18,658	23,163	31,583	39,591	47,424	54,807
Other Naturally Occurring - kWh	0	0	-6,429	-13,287	-74,574	-153,061	-175,802	-199,206	-243,202	-392,031
Other Naturally Occurring - kW	0	0	-1	-2	-9	-18	-22	-25	-32	-51
Cost per First-Year Net kWh	\$0.35	\$0.33	\$0.32	\$0.33	\$0.30	\$0.33	\$0.30	\$0.34	\$0.39	\$0.49
PV Annual Program Costs	52,341,312	60,253,129	65,038,266	65,374,005	68,075,630	65,547,565	64,327,121	60,162,338	55,938,483	51,928,543
PV Lost Revenue	153,473,267	184,480,498	223,782,347	219,715,516	289,501,375	279,840,556	329,325,857	290,820,738	251,019,595	195,484,427
RIM	0.38	0.40	0.43	0.44	0.49	0.52	0.56	0.58	0.60	0.59



APPENDIX J System



Electricity	
All Segments	
Total	
50 Percent	

ı						•		•		
	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	36,966,163	83,019,344	128,637,085	170,002,649	202,770,758	228,475,789	251,785,275	270,036,529	282,101,054	291,295,856
Cumulative Gross Peak Demand - kW	8,642	20,030	31,525	41,873	49,959	55,912	60,750	64,245	66,513	68,214
Cumulative Net Energy Savings - kWh	23,967,524	58,897,111	93,832,754	125,494,696	148,523,962	165,434,649	176,916,602	184,649,159	188,817,255	191,874,459
Cumulative Net Peak Demand Savings - kW	6,265	15,540	24,984	33,422	39,480	43,563	46,037	47,406	48,005	48,340
New Net Energy Savings - kWh	23,967,524	34,929,587	34,935,643	31,661,942	23,029,266	16,910,687	11,481,954	7,732,557	4,168,096	3,057,204
New Net Peak Demand Savings - kW	6,265	9,276	9,444	8,438	6,057	4,083	2,475	1,369	599	335
Administration Costs	537,845	619,004	717,121	741,000	730,782	723,567	691,244	664,466	644,841	632,569
Marketing Costs	212,945	269,099	279,854	288,741	297,215	297,215	297,215	297,215	297,215	297,215
Incentives Costs	2,927,000	4,017,458	4,522,904	4,405,424	3,910,940	3,388,281	2,910,941	2,500,829	2,255,316	2,171,297
Total	3,677,790	4,905,561	5,519,880	5,435,165	4,938,938	4,409,063	3,899,400	3,462,510	3,197,372	3,101,082
				•						
PV Net Avoided Cost Benefits	11,226,833	15,904,466	16,547,014	14,884,497	11,226,243	8,250,215	5,526,195	3,986,428	2,799,932	2,387,257
PV Annual Program Marketing and Admin Costs	750,790	841,983	896,116	877,501	830,523	781,866	717,791	662,080	614,888	575,362
PV Net Measure Costs	4,723,938	6,566,774	7,038,059	6,497,137	5,346,825	4,296,906	3,399,243	2,692,099	2,262,810	2,067,451
TRC Ratio	2.05	2.15	2.09	2.02	1.82	1.62	1.34	1.19	0.97	0.90
Free Riders - kWh	12,998,639	24,122,233	34,815,432	44,530,533	54,305,616	63,140,575	75,004,895	85,557,637	93,545,266	99,795,901
Free Riders - kW	2,377	4,489	6,543	8,456	10,491	12,367	14,736	16,868	18,552	19,937
Other Naturally Occurring - kWh	0	0	-11,102	-22,580	-58,821	-99,435	-136,222	-170,267	-261,467	-374,504
Other Naturally Occurring - kW	0	0	-3	-5	-11	-17	-23	-29	-44	-63
	•			•						
Cost per First-Year Net kWh	\$0.15	\$0.14	\$0.16	\$0.17	\$0.21	\$0.26	\$0.34	\$0.45	\$0.77	\$1.01
PV Annual Program Costs	3,677,790	4,650,810	4,961,459	4,631,614	3,990,186	3,377,114	2,831,634	2,383,803	2,086,951	1,918,988
PV Lost Revenue	19,174,460	26,352,660	26,568,724	23,335,878	16,878,262	12,042,505	7,908,260	5,663,303	3,873,209	3,320,564
RIM	0.49	0.51	0.52	0.53	0.54	0.54	0.51	0.50	0.47	0.46

System



Electricity	
Commercial	
Total	
50 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	10,999,714	20,254,254	29,574,339	36,819,746	44,470,973	52,621,740	63,502,319	73,008,930	79,570,338	83,868,992
Cumulative Gross Peak Demand - kW	1,647	3,064	4,552	5,723	7,102	8,589	10,551	12,271	13,489	14,321
Cumulative Net Energy Savings - kWh	3,340,345	6,765,592	9,576,317	11,239,316	12,585,304	15,228,523	17,862,796	20,180,198	21,534,869	22,095,734
Cumulative Net Peak Demand Savings - kW	653	1,326	1,898	2,274	2,619	3,192	3,759	4,268	4,613	4,823
New Net Energy Savings - kWh	3,340,345	3,425,247	2,810,725	1,662,999	1,345,988	2,643,219	2,634,273	2,317,401	1,354,671	560,865
New Net Peak Demand Savings - kW	653	673	572	376	345	573	567	509	345	210
Administration Costs	174,454	177,820	235,262	238,201	234,488	228,609	217,550	205,600	193,851	182,773
Marketing Costs	50,769	94,760	94,760	94,760	94,760	94,760	94,760	94,760	94,760	94,760
Incentives Costs	362,848	362,381	451,335	450,314	440,205	427,141	407,335	383,450	359,662	337,265
Total Costs	588,071	634,960	781,357	783,275	769,453	750,510	719,645	683,809	648,273	614,797
	•			•			,			
PV Net Avoided Cost Benefits	1,148,201	1,113,977	1,171,571	1,008,342	958,606	1,080,586	1,048,388	926,685	650,140	419,194
PV Annual Program Marketing and Admin Costs	225,223	258,424	296,635	283,735	266,000	247,684	226,790	206,786	188,378	171,741
PV Net Measure Costs	349,525	349,105	392,038	387,597	326,252	308,068	269,105	246,131	223,236	201,999
TRC Ratio	2.00	1.83	1.70	1.50	1.62	1.94	2.11	2.05	1.58	1.12
	•	•							•	
Free Riders - kWh	7,659,369	13,488,662	19,998,022	25,580,998	31,906,384	37,437,035	45,702,534	52,908,183	58,164,895	61,974,038
Free Riders - kW	994	1,738	2,655	3,449	4,485	5,401	6,797	8,010	8,890	9,524
Other Naturally Occurring - kWh	0	0	0	-568	-20,715	-43,819	-63,011	-79,451	-129,426	-200,780
Other Naturally Occurring - kW	0	0	0	0	-2	-4	-6	-7	-15	-26
Cost per First-Year Net kWh	\$0.18	\$0.19	\$0.28	\$0.47	\$0.57	\$0.28	\$0.27	\$0.30	\$0.48	\$1.10
PV Annual Program Costs	588,071	601,986	702,310	667,473	621,644	574,852	522,586	470,776	423,133	380,444
PV Lost Revenue	1,572,845	1,473,253	1,492,674	1,196,632	1,070,539	1,207,639	1,129,353	955,356	619,155	356,967
RIM	0.53	0.54	0.53	0.54	0.57	0.61	0.63	0.65	0.62	0.57



Electricity	
Residential	
Total	
50 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	25,966,449	62,765,090	99,062,746	133,182,903	158,299,784	175,854,049	188,282,956	197,027,599	202,530,716	207,426,864
Cumulative Gross Peak Demand - kW	6,995	16,966	26,972	36,150	42,857	47,324	50,199	51,974	53,024	53,893
Cumulative Net Energy Savings - kWh	20,627,179	52,131,519	84,256,438	114,255,381	135,938,658	150,206,125	159,053,806	164,468,961	167,282,386	169,778,725
Cumulative Net Peak Demand Savings - kW	5,611	14,214	23,086	31,148	36,861	40,371	42,278	43,138	43,392	43,517
New Net Energy Savings - kWh	20,627,179	31,504,340	32,124,919	29,998,943	21,683,277	14,267,467	8,847,680	5,415,155	2,813,425	2,496,339
New Net Peak Demand Savings - kW	5,611	8,603	8,872	8,062	5,712	3,510	1,907	859	254	125
Administration Costs	363,391	441,184	481,859	502,799	496,294	494,958	473,694	458,866	450,990	449,796
Marketing Costs	162,176	174,340	185,095	193,981	202,456	202,456	202,456	202,456	202,456	202,456
Incentives Costs	2,564,152	3,655,077	4,071,569	3,955,110	3,470,735	2,961,139	2,503,606	2,117,379	1,895,654	1,834,033
Total Costs	3,089,719	4,270,601	4,738,523	4,651,890	4,169,485	3,658,553	3,179,756	2,778,701	2,549,100	2,486,284
	•									
PV Net Avoided Cost Benefits	10,078,632	14,790,489	15,375,444	13,876,154	10,267,638	7,169,629	4,477,808	3,059,742	2,149,792	1,968,063
PV Annual Program Marketing and Admin Costs	525,567	583,559	599,481	593,766	564,523	534,183	491,001	455,294	426,510	403,621
PV Net Measure Costs	4,374,413	6,217,669	6,646,021	6,109,540	5,020,573	3,988,838	3,130,138	2,445,968	2,039,574	1,865,452
TRC Ratio	2.06	2.17	2.12	2.07	1.84	1.59	1.24	1.05	0.87	0.87
	•	•	•							
Free Riders - kWh	5,339,270	10,633,571	14,817,410	18,949,535	22,399,232	25,703,539	29,302,361	32,649,454	35,380,371	37,821,863
Free Riders - kW	1,383	2,751	3,889	5,007	6,006	6,966	7,938	8,857	9,662	10,413
Other Naturally Occurring - kWh	0	0	-11,102	-22,012	-38,106	-55,616	-73,211	-90,816	-132,041	-173,723
Other Naturally Occurring - kW	0	0	-3	-5	-9	-13	-17	-21	-29	-37
										<u>.</u>
Cost per First-Year Net kWh	\$0.15	\$0.14	\$0.15	\$0.16	\$0.19	\$0.26	\$0.36	\$0.51	\$0.91	\$1.00
PV Annual Program Costs	3,089,719	4,048,824	4,259,148	3,964,141	3,368,542	2,802,262	2,309,048	1,913,027	1,663,818	1,538,543
PV Lost Revenue	17,601,615	24,879,407	25,076,050	22,139,246	15,807,723	10,834,866	6,778,907	4,707,947	3,254,054	2,963,596
RIM	0.49	0.51	0.52	0.53	0.54	0.53	0.49	0.46	0.44	0.44



Electricity	
All Segments	
Total	
75 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	48,125,929	108,702,166	164,048,737	210,103,509	237,693,411	253,266,593	265,188,352	278,588,070	290,119,367	299,357,102
Cumulative Gross Peak Demand - kW	11,741	27,131	41,317	52,738	59,372	62,718	64,913	67,403	69,719	71,527
Cumulative Net Energy Savings - kWh	35,375,442	85,053,114	131,572,528	169,639,142	191,201,648	201,268,273	207,143,588	214,617,063	221,066,188	225,829,242
Cumulative Net Peak Demand Savings - kW	9,407	22,724	35,184	44,996	50,252	52,305	53,149	54,317	55,460	56,192
New Net Energy Savings - kWh	35,375,442	49,677,672	46,519,414	38,066,614	21,562,506	10,066,625	5,875,314	7,473,476	6,449,125	4,763,054
New Net Peak Demand Savings - kW	9,407	13,317	12,460	9,813	5,256	2,053	844	1,168	1,143	731
Administration Costs	1,126,984	1,283,090	1,410,724	1,419,119	1,346,261	1,297,137	1,227,941	1,212,359	1,194,915	1,181,999
Marketing Costs	239,865	253,245	265,076	274,850	284,173	284,173	284,173	284,173	284,173	284,173
Incentives Costs	6,522,297	8,818,258	9,111,074	7,922,394	6,135,767	4,907,155	4,245,571	4,084,995	3,903,440	3,827,502
Total	7,889,146	10,354,592	10,786,873	9,616,363	7,766,201	6,488,464	5,757,685	5,581,526	5,382,528	5,293,674
		3		•						
PV Net Avoided Cost Benefits	17,028,604	22,968,642	21,900,261	17,428,254	10,900,764	6,406,999	4,111,183	4,080,624	3,663,583	3,462,870
PV Annual Program Marketing and Admin Costs	1,366,849	1,456,551	1,506,266	1,443,528	1,317,233	1,211,201	1,098,054	1,030,303	965,413	907,285
PV Net Measure Costs	7,674,900	10,200,467	10,017,058	8,160,698	5,831,404	4,285,212	3,448,559	3,132,899	2,825,782	2,628,576
TRC Ratio	1.88	1.97	1.90	1.81	1.52	1.17	0.90	0.98	0.97	0.98
		•	•					•		
Free Riders - kWh	12,750,486	23,649,051	32,487,310	40,486,386	46,549,455	52,096,624	58,179,770	64,139,631	69,282,940	73,824,336
Free Riders - kW	2,335	4,407	6,136	7,747	9,131	10,430	11,787	13,114	14,297	15,385
Other Naturally Occurring - kWh	0	0	-11,102	-22,020	-57,692	-98,304	-135,006	-168,624	-229,761	-296,476
Other Naturally Occurring - kW	0	0	-3	-5	-11	-17	-23	-28	-38	-49
Cost per First-Year Net kWh	\$0.22	\$0.21	\$0.23	\$0.25	\$0.36	\$0.64	\$0.98	\$0.75	\$0.83	\$1.11
PV Annual Program Costs	7,889,146	9,816,867	9,695,615	8,194,652	6,274,341	4,969,828	4,181,068	3,842,662	3,513,220	3,275,791
PV Lost Revenue	29,286,792	38,317,479	35,425,750	27,521,774	16,318,263	9,222,782	5,803,502	5,799,602	4,984,645	4,646,759
RIM	0.46	0.48	0.49	0.49	0.48	0.45	0.41	0.42	0.43	0.44

System



Electricity	
Commercial	
Total	
75 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	10,258,136	18,621,570	26,705,958	34,037,293	40,281,181	45,903,458	51,685,439	57,003,171	61,214,608	64,496,168
Cumulative Gross Peak Demand - kW	1,554	2,853	4,164	5,394	6,559	7,652	8,785	9,848	10,741	11,488
Cumulative Net Energy Savings - kWh	2,846,920	5,606,089	9,036,059	12,500,449	16,150,544	19,553,062	22,869,825	25,590,803	27,409,759	28,616,447
Cumulative Net Peak Demand Savings - kW	603	1,197	1,917	2,654	3,435	4,191	4,942	5,599	6,114	6,528
New Net Energy Savings - kWh	2,846,920	2,759,170	3,429,969	3,464,391	3,650,095	3,402,518	3,316,763	2,720,978	1,818,956	1,206,688
New Net Peak Demand Savings - kW	603	594	720	737	782	756	751	657	515	414
Administration Costs	365,585	377,900	460,307	480,010	455,560	443,593	410,680	398,643	386,187	374,418
Marketing Costs	61,963	61,963	61,963	61,963	61,963	61,963	61,963	61,963	61,963	61,963
Incentives Costs	585,378	592,386	685,432	706,710	673,240	653,544	608,256	586,666	563,982	542,605
Total Costs	1,012,925	1,032,250	1,207,702	1,248,683	1,190,763	1,159,100	1,080,898	1,047,272	1,012,132	978,985
	•	3	3							
PV Net Avoided Cost Benefits	1,524,155	1,479,870	1,675,090	1,657,098	1,692,875	1,549,500	1,484,231	1,267,603	986,521	781,801
PV Annual Program Marketing and Admin Costs	427,547	417,021	469,434	461,846	418,109	387,230	343,220	317,109	292,511	270,038
PV Net Measure Costs	512,995	515,173	592,747	593,390	534,590	488,451	432,745	391,108	354,571	322,660
TRC Ratio	1.62	1.59	1.58	1.57	1.78	1.77	1.91	1.79	1.52	1.32
	•	-	-							
Free Riders - kWh	7,411,216	13,015,480	17,669,900	21,536,851	24,150,223	26,393,084	28,877,409	31,490,176	33,902,569	36,002,473
Free Riders - kW	951	1,656	2,247	2,740	3,125	3,464	3,848	4,257	4,636	4,972
Other Naturally Occurring - kWh	0	0	0	-8	-19,587	-42,688	-61,795	-77,808	-97,720	-122,752
Other Naturally Occurring - kW	0	0	0	0	-2	-4	-6	-7	-9	-12
Cost per First-Year Net kWh	\$0.36	\$0.37	\$0.35	\$0.36	\$0.33	\$0.34	\$0.33	\$0.38	\$0.56	\$0.81
	•	•	•							
PV Annual Program Costs	1,012,925	978,644	1,085,525	1,064,074	962,022	887,811	784,918	721,006	660,627	605,808
PV Lost Revenue	2,021,061	1,875,612	2,094,860	1,996,868	1,958,888	1,707,269	1,568,231	1,267,477	914,405	674,069
RIM	0.50	0.52	0.53	0.54	0.58	0.60	0.63	0.64	0.63	0.61

APPENDIX J System

	DNV-GL
DSM ASS	SYST OUTPUT FILES

Electricity	
Residential	
Total	
75 Percent	

	2014	2015	2016	2017	2018	2019	2020	2021	2022	2023
Cumulative Gross Energy - kWh	37,867,793	90,080,596	137,342,778	176,066,216	197,412,230	207,363,135	213,502,913	221,584,898	228,904,759	234,860,934
Cumulative Gross Peak Demand - kW	10,187	24,278	37,153	47,345	52,814	55,066	56,128	57,555	58,979	60,040
Cumulative Net Energy Savings - kWh	32,528,522	79,447,025	122,536,470	157,138,693	175,051,104	181,715,211	184,273,762	189,026,260	193,656,429	197,212,795
Cumulative Net Peak Demand Savings - kW	8,804	21,527	33,267	42,343	46,817	48,114	48,207	48,719	49,347	49,663
New Net Energy Savings - kWh	32,528,522	46,918,503	43,089,445	34,602,223	17,912,411	6,664,107	2,558,551	4,752,498	4,630,169	3,556,366
New Net Peak Demand Savings - kW	8,804	12,724	11,740	9,075	4,474	1,297	94	511	628	317
Administration Costs	761,400	905,189	950,416	939,109	890,701	853,544	817,262	813,716	808,728	807,582
Marketing Costs	177,902	191,282	203,113	212,888	222,210	222,210	222,210	222,210	222,210	222,210
Incentives Costs	5,936,919	8,225,871	8,425,642	7,215,684	5,462,527	4,253,611	3,637,316	3,498,329	3,339,458	3,284,897
Total Costs	6,876,221	9,322,343	9,579,171	8,367,680	6,575,438	5,329,364	4,676,787	4,534,254	4,370,396	4,314,688
PV Net Avoided Cost Benefits	15,504,450	21,488,772	20,225,170	15,771,156	9,207,889	4,857,499	2,626,952	2,813,021	2,677,062	2,681,069
PV Annual Program Marketing and Admin Costs	939,302	1,039,530	1,036,832	981,682	899,125	823,971	754,835	713,194	672,902	637,248
PV Net Measure Costs	7,161,905	9,685,294	9,424,311	7,567,308	5,296,814	3,796,760	3,015,814	2,741,791	2,471,211	2,305,916
TRC Ratio	1.91	2.00	1.93	1.84	1.49	1.05	0.70	0.81	0.85	0.91
			3							3
Free Riders - kWh	5,339,270	10,633,571	14,817,410	18,949,535	22,399,232	25,703,539	29,302,361	32,649,454	35,380,371	37,821,863
Free Riders - kW	1,383	2,751	3,889	5,007	6,006	6,966	7,938	8,857	9,662	10,413
Other Naturally Occurring - kWh	0	0	-11,102	-22,012	-38,106	-55,616	-73,211	-90,816	-132,041	-173,723
Other Naturally Occurring - kW	0	0	-3	-5	-9	-13	-17	-21	-29	-37
Cost per First-Year Net kWh	\$0.21	\$0.20	\$0.22	\$0.24	\$0.37	\$0.80	\$1.83	\$0.95	\$0.94	\$1.21
PV Annual Program Costs	6,876,221	8,838,223	8,610,090	7,130,578	5,312,320	4,082,017	3,396,150	3,121,656	2,852,593	2,669,983
PV Lost Revenue	27,265,731	36,441,868	33,330,890	25,524,906	14,359,375	7,515,513	4,235,271	4,532,125	4,070,240	3,972,690
RIM	0.45	0.47	0.48	0.48	0.47	0.42	0.34	0.37	0.39	0.40

About DNV GL Driven by our purpose of safeguarding life, property and the environment, DNV GL enables organizations to advance the safety and sustainability of their business. We provide classification and technical assurance along with software and independent expert advisory services to the maritime, oil and gas, and energy industries. We also provide certification services to customers across a wide range of industries. Operating in more than 100 countries, our 16,000 professionals are dedicated to helping our customers make the world safer, smarter and greener. DNV GL Energy & Sustainability December 9, 2013 K-16

CERTIFICATE OF SERVICE

I hereby certify that a copy of the foregoing <u>Energy Efficiency Potential Study</u>, as filed in Docket No. E-22, Sub 464, was served electronically or via U.S. mail, first-class, postage prepaid, upon all parties of record.

This, the 13th day of May, 2015.

s/ E. Brett Breitschwerdt

E. Brett Breitschwerdt McGuireWoods LLP 434 Fayetteville Street, Suite 2600 PO Box 27507 (27611) Raleigh, North Carolina 27601 (919) 755-6563 Direct bbreitschwerdt@mcguirewoods.com

Attorney for Virginia Electric and Power, d/b/a Dominion North Carolina Power