

Becker / Pearce Excess Capacity Rebuttal Exhibit 10**W-218 Sub 526****The Legacy Service Area Design Flow Summary**

Completed by Joseph Pearce PE

Number of Dwelling Units	241
Number of Bedrooms per Dwelling Unit	4.503
Design Standard	120 gpd per bedroom
Dwelling Unit Design Flow	130224 gallons per day
Amenity Center	1450 gpd per original permit
Guard House	100 gpd per original permit
Total Contributory Design Flow	131774 gpd