

Docket W-218 Sub 526
Aqua North Carolina, Inc.
Berger Direct Exhibit C

Manganese Dioxide Filter Removal Efficiency							
		Prior to Filter		After Filter			
System Name	In Service Date	Fe (mg/L)	Mn (mg/L)	Fe (mg/L)	Mn (mg/L) ²	Average FE Removal %	Average Mn Removal %
Bratyon Park	Mar-19	0.48	0.29	0	0.007	100.00	99.98
Galloway	Apr-18	1.66	0.683	0	0.006	100.00	99.99
Georges Grant (Bayleaf)	Jul-19	0.008	0.017	0.001	0.008	99.88	99.53
Ogburn Farm	Aug-18	0.19	0.05	0	0	100.00	100.00
The Barony	Apr-19	2.35	0.592	0	0.025	100.00	99.96
Upchurch Place	Mar-19	0.78	0.175	0	0.006	100.00	99.97
Westbury/Ridgebrook	Mar-19	0.111	95236	0	0	100.00	100.00
Woodvalley	Apr-19	0.856	0.324	0	0.001	100.00	100.00

OFFICIAL COPY

DEC 16 2020