Building Type <sup>83</sup>	Window Type	Heating System Type <sup>84</sup>	DRF <sub>North</sub> (kW/ft <sup>2</sup> )	DRF <sub>East</sub> (kW/ft <sup>2</sup> )	DRF <sub>South</sub> <sup>85</sup> (kW/ft <sup>2</sup> )	DRF <sub>west</sub> (kW/ft <sup>2</sup> )
	Single	Electric	9.15E-04	1.54E-03	-5.66E-05	2.69E-03
Othor <sup>86</sup>	Pane	Gas	9.24E-04	1.29E-03	-4.56E-04	2.33E-03
Other	Double	Electric	4.63E-04	8.00E-04	-8.48E-04	1.37E-03
	Pane	Gas	4.74E-04	6.64E-04	-1.15E-03	1.18E-03
	Single	Electric	1.10E-03	1.84E-03	1.83E-03	3.88E-03
Public	Pane	Non-electric	1.21E-03	2.04E-03	1.97E-03	4.69E-03
Assembly	Double	Electric	5.61E-04	9.44E-04	9.38E-04	2.48E-03
	Pane	Non-electric	6.10E-04	1.04E-03	1.01E-03	3.19E-03
Public Order	Single Pane	Electric	1.04E-03	2.03E-03	2.34E-03	2.36E-03
and Safety		Non-electric	1.07E-03	2.19E-03	2.54E-03	2.53E-03
(Police and	Double Pane	Electric	1.04E-03	2.03E-03	2.34E-03	2.36E-03
Fire Station)		Non-electric	1.07E-03	2.19E-03	2.54E-03	2.53E-03
	Single	Electric	5.90E-03	1.32E-02	5.95E-03	1.32E-02
Religious	Pane	Non-electric	3.38E-03	7.84E-03	3.33E-03	7.55E-03
Worship	Double	Electric	3.13E-03	6.11E-03	3.55E-03	6.75E-03
	Pane	Non-electric	1.81E-03	3.45E-03	2.14E-03	7.55E-03
Service	Single	Electric	9.37E-04	9.53E-04	1.88E-03	1.70E-03
(Beauty,	Pane	Non-electric	6.39E-04	1.07E-03	1.96E-03	1.69E-03
Auto Repair	Double	Electric	2.99E-04	4.94E-04	1.10E-03	8.64E-04
Workshop)	Pane	Non-electric	3.19E-04	1.15E-03	1.15E-03	5.78E-04

### **Default Savings**

No default savings will be awarded for this measure if the proper values are not provided in the customer application.

### Source

The primary source for this deemed savings approach is prototypical building energy models defined by the 2008 Database for Energy Efficient Resources (DEER),<sup>87</sup> modified to represent Richmond, VA and Elizabeth City, NC weather and program-specific window characteristics.

<sup>&</sup>lt;sup>87</sup> http://www.energy.ca.gov/deer/

### 8 NON-RESIDENTIAL SMALL BUSINESS IMPROVEMENT PROGRAM

Dominion's Non-Residential Small Business Improvement Program provides small business owners incentives to use Dominion-approved contractors to provide many of the measures already provided through existing legacy programs that typically target non-residential building owners: Non-Residential Heating and Cooling Efficiency program and the Non-residential Lighting Systems and Controls program. In addition, four retrocommissioning measures are provided. Program measures are summarized in Table 8-1.

According to the program terms and conditions, as of June 2017, to be eligible to participate in this program, Dominion Energy Virginia non-residential customers must be of a privately-owned business with five or fewer locations that has not exceeded monthly demand threshold of 100 kW three or more times in the past 12 months, has not opted out of participation, is responsible for the electric bill and is the owner of the facility or reasonably able to secure permission to complete measures. Once a customer participates in the program and receive a rebate, they cannot opt out for three years following the year of participation.

Prior to June 1, 2017, the Small Business Improvement Program delivered refrigeration measures to Virginia customers, but stopped per an SCC ruling.<sup>88</sup>

End-Use	Measure	Manual Section
HVAC	Duct Testing & Sealing	Section 8.1.1
	Unitary/Split AC, HP, and Chiller Tune-up	Section 8.1.2
	Refrigerant Charge Correction	Section 8.1.3
	Unitary/Split AC & HP Upgrade	Section 6.1.1
	Mini-split Heat Pump	Section 6.1.2
	Dual Enthalpy Air-side Economizer	Section 6.1.5
	Variable Frequency Drive	Section 6.1.4
	Programmable Thermostat	Section 8.1.8
Lighting	Lighting, Fixtures, Lamps, and Delamping	Section 5.1.1
	Sensors & Controls	Section 5.1.2
	LED Exit Signs	Section 8.2.3
Other	Compressed Air Leak Repair	Section 8.3.1

#### Table 8-1: Non-residential Small Business Improvement Program Measure List

<sup>&</sup>lt;sup>88</sup> As of June 1, 2017, refrigeration measures ceased to be offered through this program as a result of the ruling in Virginia SCC Case No. PUE-2016-00111 issued and effective on the same date.

## Aay 01 2019

## 8.1 Heating Ventilation and Air Conditioning (HVAC) End Use

### 8.1.1 Duct Testing and Sealing

### **Measure Description**

This measures provides building owners incentives to use Dominion-approved, duct-sealing contractors to reduce conditioned-air leakage to unconditioned spaces by the following steps: 1) test non-residential duct systems for air leakage, 2) seal the ducts using an aerosol-based product, and then 3) test the sealed duct systems for air leakage to confirm that sealing the ducts reduced the air-leakage rate.

Eligible ductwork is connected to a unitary HVAC system or a heat pump and occurs within an unconditioned plenum space or between an insulated, finished ceiling and a roof surface. Based on DNV GL's judgment, this measure is applicable to ductwork at unitary and chiller-cooled systems.

## **Savings Estimation Approach**

For all system types, gross annual electric energy savings are calculated according to the following equation:

$$\Delta kWh = \Delta kWh_{cool} + \Delta kWh_{heat}$$

### Unitary Systems, Air Source Heat Pumps, and AC Units

Gross annual electric cooling and heating energy savings are calculated according to the following equations.

Unitary systems, for air-source heat pumps and AC units, Size<sub>cool</sub> < 65,000 Btu/h:

$$\Delta kWh_{cool} = Size_{cool} \times \frac{12 \ kBtuh/ton}{SEER} \times \ FLH_{cool} \times \left(1 - \frac{\overline{n}_{dist,base}}{\overline{n}_{dist,ee}}\right)_{cool}$$

Unitary systems, for air-source heat pumps and AC units, Sizeheat < 65,000 Btu/h:

$$\Delta kWh_{heat} = Size_{heat} \times \frac{1}{HSPF} \times FLH_{heat} \times \left(1 - \frac{\bar{n}_{dist,base}}{\bar{n}_{dist,ee}}\right)_{heat}$$

<u>Unitary systems, for air-source heat pumps and AC units,  $Size_{cool} \ge 65,000Btu/h$  and all ground-source heat pumps:</u>

$$\Delta kWh_{cool} = Size_{cool} \times \frac{12 \ kBtuh/ton}{IEER} \times \ FLH_{cool} \times \left(1 - \frac{\overline{n}_{dist,base}}{\overline{n}_{dist,ee}}\right)_{cool}$$

<u>Unitary systems, for air-source heat pumps and AC units, Size<sub>heat</sub>  $\geq$  65,000 Btu/h and all ground-source heat pumps:</u>

$$\Delta kWh_{heat} = Size_{heat} \times \frac{1}{COP \times 3.412 Btuh/W} \times FLH_{heat} \times \left(1 - \frac{\overline{n}_{dist,base}}{\overline{n}_{dist,ee}}\right)_{heat}$$

Gross coincident demand reduction is calculated according to the following equation:

$$\Delta kW = Size_{cool} \times \frac{12 \ kBtuh/ton}{EER} \times \left(1 - \frac{n_{dist,pk,base}}{n_{dist,pk,ee}}\right) \times \ CF$$

#### **Chiller Systems**

Water-cooled chiller systems, cooling savings:

$$\Delta kWh_{cool} = Size_{cool} \times \frac{kW}{ton_{IPLV}} \times FLH_{cool} \times \left(1 - \frac{\overline{n}_{dist,base}}{\overline{n}_{dist,ee}}\right)_{cool}$$

Air-cooled chiller systems, cooling savings:

$$\Delta kWh_{cool} = Size_{cool} \times \frac{12 \ kBtuh/ton}{EER_{IPLV}} \times FLH_{cool} \times \left(1 - \frac{\overline{n}_{dist,base}}{\overline{n}_{dist,ee}}\right)_{cool}$$

Chiller system heating savings for systems <65,000 Btu/h:

$$\Delta kWh_{heat} = Size_{heat} \times \frac{1}{HSPF} \times FLH_{heat} \times \left(1 - \frac{\bar{n}_{dist,base}}{\bar{n}_{dist,ee}}\right)_{heat}$$

Chiller system heating savings for systems ≥65,000 Btu/h:

$$\Delta kWh_{heat} = Size_{heat} \times \frac{1}{COP \times 3.412 Btuh/W} \times FLH_{heat} \times \left(1 - \frac{\overline{n}_{dist,base}}{\overline{n}_{dist,ee}}\right)_{heat}$$

For all system types, heating systems with non-electric primary heat will receive zero heating savings.

Gross coincident demand reduction is calculated according to the following equations:

Water-cooled chiller systems:

$$\Delta kW = Size_{cool} \times \frac{kW}{ton_{full \ load}} \times \left(1 - \frac{\overline{n}_{dist, peak, base}}{\overline{n}_{dist, peak, ee}}\right) \times \ CF$$

Air-cooled chiller systems:

$$\Delta kW = Size_{cool} \times \frac{12 \ kBtuh/ton}{EER_{full \ load}} \times \left(1 - \frac{\overline{n}_{dist, peak, base}}{\overline{n}_{dist, peak, ee}}\right) \times \ CF$$

Where:

ΔkWh	= gross annual electric energy savings
ΔkW	= gross coincident demand reductions
Sizecool	= system cooling capacity in tons, based on nameplate data
Sizeheat	<ul> <li>nominal rating of the unitary systems (heat pumps or AC units)</li> </ul>
SEER	= seasonal energy efficiency ratio (SEER). It is used for heat pumps and AC units that are smaller than 65,000 Btu/h.
IEER	= integrated energy efficiency ratio (IEER) of a unit's efficiency at four load points: 100%, 75%, 50%, and 25% of full cooling capacity. It is used for heat pumps and AC units that are 65,000 Btu/h or larger.
EER	= energy efficiency ratio (EER) of heat pump and air-conditioning systems at full-load conditions. (See Equation 3 in Sub-appendix V to convert SEER to EER, if EER is not provided.)
HSPF	= heating seasonal performance factor (HSPF). It is used for heat pumps. (See Equation 5 in Sub-appendix V to convert COP to HSPF, if HSPF is not provided.)
COP	= coefficient of performance (heating)
$ar{n}_{dist,base,co}$	ol = duct system average seasonal efficiency of baseline (pre-sealing) cooling system
$ar{n}_{dist,base,he}$	at = duct system average seasonal efficiency of baseline (pre-sealing) heating system
$\bar{n}_{dist,ee,cool}$	= duct system average seasonal efficiency of efficient (post-sealing) cooling system
$\bar{n}_{dist,ee,heat}$	<ul> <li>duct system average seasonal efficiency of efficient (post-sealing) heating system</li> </ul>
n <sub>dist,peak,bo</sub>	$\bar{n}_{se}$ = duct system efficiency of baseline system, under peak conditions (equal to $\bar{n}_{dist hase cool}$ )
n <sub>dist,peak,ee</sub>	= duct system efficiency of efficient system, under peak conditions (equal to $\bar{n}_{dist,ee,cool}$ )
EER <sub>full-load</sub>	=  energy efficiency ratio (EER) of air-cooled chillers at full-load conditions.

EERIPLV	= energy efficiency ratio (EER) of air-cooled chillers at integrated part load value (IPLV).
kW ton <sub>IPLV</sub>	= energy efficiency of water-cooled chiller system at integrated part load value
	(IPLV)
<u>kW</u> tonfull load	= energy efficiency of water-cooled chiller system at full load
<b>FLH</b> <sub>cool</sub>	= annual cooling equivalent full load hours (FLH)
<b>FLH</b> <sub>heat</sub>	= annual heating equivalent FLH
CF	= peak coincidence factor

## **Input Variables**

Component	Туре	Value	Unit	Source(s)
Size <sub>cool</sub>	Variable	See customer application	tons of cooling capacity (per unit)	Customer application
Size <sub>heat</sub>	Variable	See customer application	kBtu/h (per unit)	Customer application
SEER	Variable	See customer application Default: See Table 12-10 and Table 12-11 in Sub- appendix VII	kBtu/kW- hr	Customer application ASHRAE 90.1-2010, Table 6.8.1A and 6.8.1B
		See customer application		Customer application
IEER	Variable	Default: See tables in Sub-appendix VII, based on equipment type	kBtu/kW- hr	ASHRAE 90.1-2010, Table 6.8.1A and 6.8.1B
	Variable	See customer application		Customer application
EER		Default: See tables in Sub-appendix VII, based on equipment type	kBtu/kW- hr	ASHRAE 90.1-2010, Table 6.8.1A and 6.8.1B
HSPF	Variable	See customer application		Customer application
		Default: See tables in Sub-appendix VII, based on equipment type	kBtu/kW- hr	ASHRAE 90.1-2010, Table 6.8.1B
СОР	Variable	See customer application Default: See tables in Sub-appendix VII, based on equipment type	-	Customer application
kW/ton <sub>full load</sub>		See customer application <sup>89</sup>		Customer application
	Variable	Default: see Table 12-13 in Sub-appendix VII	kW/ton	ASHRAE 90.1-2010, Table 6.8.1C
		See customer application		Customer application
kW/ton <sub>IPLV</sub>	Variable	Default: see Table 12-13 in Sub-appendix VII	kW/ton	ASHRAE 90.1-2010, Table 6.8.1C

### Table 8-2: Input Values for Duct Sealing Savings Calculations

<sup>&</sup>lt;sup>89</sup> When missing either the IPLV or the full load value, use either Equation 7 in Sub-appendix V, as relevant.

0
Ž
Σ
Ì

22

Component	Туре	Value	Unit	Source(s)
		See customer application <sup>90</sup>		Customer application
EER <sub>full load</sub>	Variable	Default: see Table 12-13	kBtu/kW-h	ASHRAE 90.1-2010,
	variable	in Sub-appendix VII		Table 6.8.1C
		See customer application		Customer application
EERIPLV	Variable	Default: see Table 12-13	kBtu/kW-h	ASHRAE 90.1-2010,
		in Sub-appendix VII		Table 6.8.1C
_		See customer application		Customer application
$n_{ m dist,base,cool}$	Variable	Default: No insulation,	percent	New York TRM 2018, p.
		See customer application		123 124
		along with Table 8-3 and		Customer application
$\overline{n}_{dist hase heat}$	Variable	Table 8-4	percent	ererer application
uist,buse,neut		Default: No insulation,		New York TRM 2018, p.
		30% leakage		111-112
		See customer application		
		along with Table 8-3 and		Customer application
$\overline{n}_{dist,ee,cool}$	Variable	Table 8-4	percent	
		Default: No insulation,		New York TRM 2018, p.
		15% leakage		111-112
	Variable	See customer application		Custo en en elization
77		Table 8-3 and	porcont	Customer application
ndist,ee,heat		Default: No inculation	percent	New York TPM 2018 p
		15% leakage		111-112
		See customer application		111 112
		along with Table 8-3 and		Customer application
n <sub>dist.peak.base</sub>	Variable	Table 8-4	percent	- F F
		Default: No insulation,		New York TRM 2018, p.
		30% leakage		111-112
		See customer application		
		along with Table 8-3 and		Customer application
n <sub>dist,peak,ee</sub>	Variable	Table 8-4	percent	
		Default: No insulation,		New York TRM 2018, p.
		15% leakage	hours	Mid Atlantic TDM 2019
FLH <sub>heat</sub>	Fixed	appendix II	(appual)	n 418
		For chiller systems see	(annual)	p. 410
		Table 12-5 in Sub-		Mid-Atlantic TRM 2018,
FLH <sub>cool</sub>	Fixed	appendix II: for all other	hours	p. 417;
		system types, see Table	(annual)	Mid-Atlantic TRM 2018 p.
		12-3 in Sub-appendix II		437
				Calculated CF from
				Dominion's DSM Phase I
CF	Fixed	xed 0.68		program. April 1, 2012
				EM&V Report, Sub-
				appendix C-1, p. F-191

<sup>90</sup> When missing either the IPLV or the full load value, use either Equation 8 in Sub-appendix V, as relevant.

<sup>&</sup>lt;sup>91</sup> Appendix C-1, Commercial HVAC Program: Load Shape and Net Savings Analysis Evaluation Report; Evaluation, Measurement and Verification Report for Dominion Virginia Power, Case PUE-2010-00084, Apr. 1, 2012, p. F-1.

The New York TRM (2018) provides values for duct system efficiency for uninsulated ducts and ducts with R-6 insulation for four building types: assembly building, fast food restaurant, full service restaurant, and small retail. The average column in Table 8-3 is a simple average of the four building types. The values for R-2, R-4 and R-8 insulation have been calculated by scaling the results using an engineering relationship of the effectiveness of increasing R-values (non-linear).

The manual provides efficiencies for only five leakage-rate bins: 8%, 15%, 20%, 25%, and 30%. In preparation for receiving duct leakage percentages that do not match these specific values, DNV GL used a linear regression to model duct system efficiency as a function of leakage proportion. The coefficients from this model were used to compute duct system efficiency for any leakage value between 0% and 50%.



Duct Total	Duct System	Duct System R-Value		Fast Food Restaurant		Full Service Restaurant		Small Retail		Average	
(%)	in value	Heating	Cooling	Heating	Cooling	Heating	Cooling	Heating	Cooling	Heating	Cooling
8	Uninsulated	0.857	0.922	0.766	0.866	0.797	0.854	0.614	0.838	0.759	0.870
15	Uninsulated	0.829	0.908	0.734	0.853	0.765	0.845	0.581	0.827	0.727	0.858
20	Uninsulated	0.810	0.897	0.714	0.844	0.743	0.837	0.559	0.818	0.707	0.849
25	Uninsulated	0.793	0.886	0.693	0.834	0.721	0.829	0.538	0.809	0.686	0.840
30	Uninsulated	0.776	0.873	0.675	0.823	0.701	0.820	0.520	0.799	0.668	0.829
8	R-2	0.877	0.954	0.821	0.906	0.845	0.904	0.691	0.885	0.808	0.912
15	R-2	0.846	0.938	0.780	0.889	0.807	0.893	0.648	0.871	0.770	0.898
20	R-2	0.826	0.926	0.754	0.878	0.781	0.884	0.619	0.861	0.745	0.887
25	R-2	0.807	0.913	0.729	0.865	0.755	0.874	0.593	0.850	0.721	0.875
30	R-2	0.789	0.899	0.707	0.852	0.732	0.864	0.570	0.839	0.699	0.863
8	R-4	0.886	0.970	0.848	0.925	0.869	0.929	0.729	0.908	0.833	0.933
15	R-4	0.855	0.952	0.802	0.907	0.827	0.917	0.681	0.893	0.791	0.917
20	R-4	0.833	0.940	0.774	0.894	0.799	0.908	0.649	0.883	0.764	0.906
25	R-4	0.814	0.926	0.747	0.881	0.772	0.897	0.621	0.871	0.738	0.893
30	R-4	0.795	0.911	0.723	0.867	0.748	0.885	0.594	0.859	0.715	0.881
8	R-6	0.896	0.986	0.875	0.945	0.893	0.954	0.767	0.931	0.858	0.954
15	R-6	0.863	0.967	0.825	0.925	0.848	0.941	0.714	0.915	0.813	0.937
20	R-6	0.841	0.954	0.794	0.911	0.818	0.931	0.679	0.904	0.783	0.925
25	R-6	0.821	0.939	0.765	0.896	0.789	0.919	0.648	0.891	0.756	0.911
30	R-6	0.801	0.924	0.739	0.881	0.763	0.907	0.619	0.879	0.731	0.898
8	R-8	0.901	0.994	0.889	0.955	0.905	0.967	0.786	0.943	0.870	0.965
15	R-8	0.867	0.974	0.836	0.934	0.858	0.953	0.731	0.926	0.823	0.947
20	R-8	0.845	0.961	0.804	0.919	0.827	0.943	0.694	0.915	0.793	0.935
25	R-8	0.825	0.946	0.774	0.904	0.798	0.930	0.662	0.901	0.764	0.920
30	R-8	0.804	0.930	0.747	0.888	0.771	0.918	0.631	0.889	0.738	0.906

### Table 8-3: Duct System Efficiency by Broad Building Type Categories<sup>92</sup>

<sup>92</sup> NY TRM 2018, Appendix H. Distribution Efficiencies, p. 509 – 512. New York City values are used for heating and cooling efficiencies for different building types. This table represent more R-Values and total duct leakage (%) than the reference table and for those cases, regression analysis was performed to obtain the respective heating and cooling duct system efficiencies.

Table 8-4: Duct System Efficiency Mapping to Building Type<sup>93</sup>

Building Type	Associated Duct System Efficiency Building Type
Education Education – College and University Education – High School Education – Elementary and Middle School Health Care – inpatient Health Care – outpatient Lodging – (Hotel, Motel, and Dormitory) Office – Small (< 40,000 sq ft) Office – Large (≥ 40,000 sq ft) Other Warehouse and Storage	Average
Food Sales Food Sales – Gas Station Convenience Store Food Sales – Convenience Store Food Sales – Grocery Mercantile (Retail, not Mall) Mercantile (Mall) Service (Beauty, Auto Repair Workshop)	Small Retail
Food Service Food Service – Fast Food Food Service – Other	Fast Food Restaurant
Food Service – Restaurant Food Service – Full Service	Full Service Restaurant
Public Assembly Public Order and Safety (Police and Fire Station) Religious Worship	Assembly Building

## **Default Savings**

If the proper values are not supplied, a default savings may be applied using conservative input values. Default hours of use will be taken from the above chart if the building type is available.

## Source(s)

The primary sources for this deemed savings approach is the New York TRM 2018, p. 111-114, Mid-Atlantic TRM 2018, and ASHRAE 90.1-2010.

<sup>&</sup>lt;sup>93</sup> Where "Building Type" does not clearly map to "Associated Duct System Efficiency Building Type," "Associated Duct System Efficiency Building Type is assigned to most conservative type." Full building type list was consolidated to map directly to 2003 U.S. DOE CBECS building types. Full building type list from Mid-Atlantic TRM. Original sources: Connecticut Program Savings Document for 2012 Program Year (September, 2011), p. 219-220. http://www.ctenergyinfo.com/2012%20CT%20Program%20Savings%20Documentation%20FINAL.pdf. 2003 US DOE CBECS building type definitions. http://www.eia.gov/emeu/cbecs/building\_types.html.

## 8.1.2 Unitary/Split Air Conditioning, Heat Pump, and Chiller Tune-up

### Measure Description

This measure involves tuning up packaged air conditioning units, heat pump units (both air and ground source), and air- and water-cooled cooled chillers at small commercial and industrial sites. All HVAC applications other than space cooling and heating—such as process cooling—are ineligible for this measure.

For the Small Business Improvement Program, this measure is separated from the Refrigerant Charge Adjustment retrocommissioning measure. However, this measure is also offered by the Commercial Non-Residential Prescriptive Program in which case, the tune-up and the refrigerant charge adjustment steps are combined into a single measure.

### **Savings Estimation**

Algorithms and inputs to calculate heating, cooling savings, and demand reductions for unitary/split HVAC and package terminal AC system tune-ups are provided below. Gross annual electric energy savings and gross coincident demand reduction are calculated according to the equations following this section.

#### **Cooling Energy Savings**

For air-source heat pumps and AC units <65,000 Btu/h, the cooling energy savings are calculated as follows:

$$\Delta kWh_{cool} = Size_{cool} \times \frac{12 \ kBtuh/ton}{SEER} \times \ FLH_{cool} \times \ TUF$$

For air-source heat pumps, AC units  $\geq$ 65,000 Btu/h, and all ground-source heat pumps, the cooling savings are calculated as follows:

$$\Delta kWh_{cool} = Size_{cool} \times \frac{12 \ kBtuh/ton}{IEER} \times \ FLH_{cool} \times \ TUF$$

For air- and water-cooled chillers:

$$\Delta kWh_{cool} = Size_{cool} \times IPLV \times FLH_{cool} \times TUF$$

Gross coincident demand reduction is calculated according to the following equation for airconditioning and heat pump systems and chillers:

$$\Delta kW = Size_{cool} \times \frac{12 \ kBtuh/ton}{EER} \times CF \times TUF$$

#### Heating Energy Savings

For air-source heat pumps <65,000 Btu/h, the heating energy savings are calculated as follows:

$$\Delta kWh_{heat} = Size_{heat} \times \frac{1}{HSPF} \times FLH_{heat} \times TUF$$

For air-source heat pumps  $\geq$ 65,000 Btu/h and all ground-source heat pumps, the heating energy savings are calculated as follows:

$$\Delta kWh_{heat} = Size_{heat} \times \frac{1}{COP \times 3.412 Btuh/W} \times FLH_{heat} \times TUF$$

Gross annual electric energy savings are calculated by combining the cooling and heating energy savings according to the following equation:

$$\Delta kWh = \Delta kWh_{cool} + \Delta kWh_{heat}$$

For AC units and air- and water-cooled chillers, there are no heating energy savings:

 $\Delta kWh_{heat}=0$ 

Gross coincident demand reduction is calculated according to the following equation:

$$\Delta kW = Size_{cool} \times \frac{12 \ kBtuh/ton}{EER} \times CF \times TUF$$

Where:

ΔkWh	=	gross annual electric energy savings
ΔkW	=	gross coincident demand reductions
$\Delta kWh_{cool}$	=	gross annual electric cooling energy savings
$\Delta kWh_{heat}$	=	gross annual electric heating energy savings
Size <sub>cool</sub>	=	tons of cooling capacity of equipment
Size <sub>heat</sub>	=	heating capacity of equipment, if applicable.
SEER	=	seasonal energy efficiency ratio (SEER) of the installed air conditioning
		equipment. It is used for heat pumps and AC units that are smaller
		than 65,000 Btu/h.
IEER	=	integrated energy efficiency ratio (IEER) of the existing or baseline air
		conditioning equipment. IEER is a weighted average of a unit's
		efficiency at four load points: 100%, 75%, 50%, and 25% of full
		cooling capacity. It is used for heat pumps and AC units that are
		65,000 Btu/h or larger.
<b>FLH</b> <sub>cool</sub>	=	annual full load cooling hours
$FLH_{heat}$	=	annual full load heating hours
IPLV	=	energy efficiency at integrated part load value (IPLV) of chillers. For air-
		cooled chillers, this is typically shown as $EER_{IPLV}$ ; for water-cooled
		chillers, this is typically shown as $kW/ton_{IPLV}$ .
TUF	=	rate of energy efficiency improvement due to tune-up
EER	=	energy efficiency ratio of air-conditioning and heat pump systems and air-
		and water-cooled chillers at full load conditions.
HSPF	=	heating seasonal performance factor (HSPF) of existing heat pump. HSPF is
		used in heating savings for air-source heat pumps.

_	
o	
-	
9	
R	
_	
ò	
-	
1	t
22	

COP	=	coefficient of performance of existing heating equipment. Ground
		source heat pumps use COP to determine heating savings.
CF	=	coincidence factor

### **Input Variables**

Component	Туре	Value	Units	Source(s)
Size <sub>cool</sub>	Variable	See customer application	tons of refrigeration	Customer application
Size	Variable	See customer application	kBtu/b	Customer application
SIZeheat	Variable	Default for heat pumps: 12 x Size <sub>cool</sub>	Default for heat RBLU/II pumps: 12 x Size <sub>cool</sub>	
FLH <sub>cool</sub>	Fixed	For chillers, see Table 12-5 in Sub-appendix II; for all other systems, see Table 12-3 in Sub-appendix II	hours (annual)	Mid-Atlantic TRM 2018 p. 417
FLH <sub>heat</sub>	Fixed	For heat pumps, see Table 12-4 in Sub- appendix II	hours (annual)	Mid-Atlantic TRM 2018 p. 418
HSPF/SEER/ IEER/ EER/COP	Variable	For AC/HP, see Table 12-11 in Sub-appendix VII; For chillers, see Table 12-13 in Sub- appendix VII	k/kW-hour (except COP is -)	ASHRAE 90.1-2010 Table 6.8.1A and Table 6.8.1B
	Variable	See customer application	For air-cooled chillers,	Customer application
IPLV		Default: See Table 12-13 in Sub-appendix VII	Btu/W; for water-cooled chillers, kW/ton	ASHRAE 90.1-2010 Table 6.8.1B
RCA_Done <sup>94</sup>	Variable	See customer application	True/False	Customer application

Table	8-5-	Innut	Variables	for	AC/HP	/Chiller	Tune-un	Measure
labic	0 0.	Tubac	variables	101	ACTIN	Cinnei	ranc ap	Ficadare

<sup>&</sup>lt;sup>94</sup> RCA\_Done is only relevant to the Non-Residential Prescriptive Program; it is neither collected nor used for the Small Business Improvement Program because Refrigerant Charge Adjustment is a separate measure.

m
ž
ដ
5
2

Component	Туре	Value	Units	Source(s)
TUF	Fixed	If RCA was not done: For AC units: 0.023 For HP units: 0.027 If RCA was done (only for Commercial Non- Residential Prescriptive Program): For AC units: 0.050 For HP units: 0.050 For chillers: 0.050	-	Mid-Atlantic TRM 2018 p. 450, California 2013-14 Evaluation Report, <sup>95</sup> and Wisconsin Focus on Energy 2018 TRM, p. 199-202.
CF	Fixed	Use system capacity to assign CF: < 11.5 tons = $0.588$ $\geq$ 11.5 tons = $0.874$	-	Mid-Atlantic TRM 2018 p. 408

#### Source

The primary sources for this deemed savings approach include the Mid-Atlantic TRM 2018, p. 417-418, the California 2013-14 Impact Evaluation Report,<sup>95</sup> and the Wisconsin Focus on Energy TRM 2017, p. 199-202.

<sup>95</sup> California Public Utilities Commission (2016). Impact Evaluation of 2013-14 Commercial Quality Maintenance Programs (HVAC3): <u>www.calmac.org/publications/HVAC3ImpactReport\_0401ES.pdf</u>.

### 8.1.3 Refrigerant Charge Adjustment

### **Measure Description**

This measure involves adjusting the amount of refrigerant charge at air conditioners and heat pumps for packaged and split systems at small commercial and industrial sites. All HVAC applications other than space cooling and heating—such as process cooling—are ineligible for this measure.

### **Savings Estimation**

Algorithms and inputs to calculate cooling, heating and demand reductions for unitary/split airconditioning and heating pump systems that receive refrigerant charge adjustments are provided below. Gross annual electric energy savings are calculated according to the equations that follow.

### **Cooling Energy Savings**

For air-source heat pumps and AC units <65,000 Btu/h, gross annual electric cooling energy savings are calculated according to the following equation:

$$\Delta kWh_{cool} = Size_{cool} \times \frac{12 \ kBtuh/ton}{SEER} \times FLH_{cool} \times RCF$$

For air-source heat pumps and AC units  $\geq$ 65,000 Btu/h and ground-source heat pumps, gross annual electric cooling energy savings are calculated according to the following equation:

$$\Delta kWh_{cool} = Size_{cool} \times \frac{12 \ kBtuh/ton}{IEER} \times FLH_{cool} \times RCF$$

#### **Heating Energy Savings**

For air-source heat pump units <65,000 Btu/h, gross annual electric heating energy savings are calculated according to the following equation:

$$\Delta kWh_{heat} = Size_{heat} \times \frac{12 \ kBtuh/ton}{HSPF} \times FLH_{heat} \times RCF$$

For air-source heat pump units  $\geq$ 65,000 Btu/h and ground-source heat pumps, gross annual electric heating energy savings are calculated according to the following equation:

$$\Delta kWh_{heat} = Size_{heat} \times \left(\frac{12 \ kBtuh/ton}{COP \ \times \ 3.412 \ Btuh/W}\right) \times FLH_{heat} \times RCF$$

Cooling and heating savings are added to calculate the gross annual electric energy savings as follows:

$$\Delta kWh = \Delta kWh_{cool} + \Delta kWh_{heat}$$

Cross coincident demand reduction is calculated according to he following equation:

$$\Delta kW = Size_{cool} \times \frac{12}{EER} \times RCF \times CF$$

Where,

Size <sub>cool</sub>	= Unit capacity for cooling						
Size <sub>heat</sub>	= Unit capacity for heating						
EER	= Energy Efficiency Ratio (EER) at full load						
SEER	= seasonal energy efficiency ratio (SEER) of the installed air conditioning						
	equipment. It is used for heat pumps and AC units that are smaller than 65,000 Btu/h.						
IEER	= integrated energy efficiency ratio (IEER) of the existing or baseline air conditioning equipment. IEER is a weighted average of a unit's efficiency at four load points: 100%, 75%, 50%, and 25% of full cooling capacity. It is used for heat pumps and AC units that are 65,000 Btu/h or larger.						
HSPF	= Heating Seasonal Performance Factor						
COP	= Coefficient of Performance (heating)						
FLH <sub>cool</sub>	= Full load hours for cooling						
FLH <sub>heat</sub>	= Full load hours for heating						
RCF	= Refrigerant Charge Factor						
CF	= Demand Coincidence Factor						

## **Input Variables**

Component	Туре	Value	Units	Source(s)
Size <sub>cool</sub>	Variable	See customer application	tons (cooling capacity)	Customer application
Sizo	Variable	See customer application	tons	Customer application
Sizeheat	variable	Default: = $Size_{cool}$	tons	
FLH <sub>cool</sub>	Fixed	See see Table 12-5 in Sub-appendix II, Table X, or Table 12-3 in Sub- appendix II, depending upon equipment type	hours (annual)	Mid-Atlantic TRM 2018 p. 418
<b>FLH</b> <sub>heat</sub>	Fixed	Table 12-4 in Sub- appendix II	hours (annual)	Mid-Atlantic TRM 2018 p. 417
EER/SEER	Variable	See customer application		Customer application
		Default = See Table 12-10 and Table 12-11 in Sub-appendix VII	Btu/W-hr	ASHRAE 90.1-2010 Table 6.8.1A and Table 6.8.1B
HSPF/COP		See customer application	Dtu/M/ br (for	Customer application
	Variable	Default = See Table 12-10 and Table 12-11 in Sub-appendix VII	HSPF); COP is	ASHRAE 90.1-2010 Table 6.8.1B

(C)
2
N
õ
2
5

Component	Туре	Value	Units	Source(s)
RCF	Fixed	AC units: 0.027 HP units: 0.022	-	Mid-Atlantic TRM 2018 p. 450 and California 2013- 2014 Evaluation Report <sup>96</sup>
CF	Fixed	Use system capacity to assign CF as follows: < 11.5 tons = 0.588 $\ge 11.5$ tons = 0.874	-	Mid-Atlantic TRM 2018, p. 408

### Source

The primary sources for this deemed savings approach include the Mid-Atlantic TRM 2018, p. 398 - 412 and the California 2013-14 Impact Evaluation Report, p. BB-2 to BB-3.

<sup>&</sup>lt;sup>96</sup> California Public Utilities Commission (2016). Impact Evaluation of 2013-14 Commercial Quality Maintenance Programs (HVAC3). <u>www.calmac.org/publications/HVAC3ImpactReport\_0401ES.pdf</u>

## 8.1.4 Unitary/Split AC & HP Upgrade

This measure is also offered through the Non-Residential Heating and Cooling Efficiency program. The savings approach is described in Section 6.1.1.

### 8.1.5 Mini-split Heat Pump

This measure is also offered through the Non-Residential Heating and Cooling Efficiency program. The savings approach is described in Section 6.1.2.

## 8.1.6 Dual Enthalpy Air-side Economizer

This measure is also offered through the Non-Residential Heating and Cooling Efficiency program. The savings approach is described in Section 6.1.5.

### 8.1.7 Variable Frequency Drive

This measure is also offered through the Non-Residential Heating and Cooling Efficiency program. The savings approach is described in Section 6.1.4.

### 8.1.8 Programmable Thermostats

### Measure Description

This measure involves the installation of programmable thermostats<sup>97</sup> for cooling and/or heating systems in spaces with no existing setback control. The programmable thermostat shall setback the temperature setpoint during unoccupied periods. The savings will be realized from reducing the system usage during unoccupied times. The baseline operation of the HVAC units are assumed to be in continuous ON mode during the unoccupied period with fans cycling to maintain the occupied period temperature setpoints.

### **Savings Estimation**

#### AC Units

Gross annual electric energy savings are calculated according to the following equation for units <65,000 Btu/h:.

$$\Delta kWh = \left[Size_{cool} \times \left(\frac{12}{SEER}\right) \times FLH_{cool} \times ESF_{cool}\right]$$

Gross annual electric energy savings are calculated according to the following equation for units  $\geq$ 65,000 Btu/h:

$$\Delta kWh = \left[Size_{cool} \times \left(\frac{12}{IEER}\right) \times FLH_{cool} \times ESF_{cool}\right]$$

Gross coincident demand reduction is considered to be zero since space conditioning equipment typically operates at maximum capacity during peak periods.

$$\Delta kW = 0$$

#### **Heat Pumps**

Gross annual electric energy savings are calculated according to the following equation for units <65,000 Btu/h:

$$\Delta kWh = \left[Size_{cool} \times \left(\frac{12}{SEER}\right) \times FLH_{cool} \times ESF_{cool}\right] \\ + \left[Size_{heat} \times FLH_{heat} \times \left(\frac{1}{HSPF}\right) \times ESF_{heat}\right]$$

Gross annual electric energy savings are calculated according to the following equation for units  $\geq$ 65,000 Btu/h:

<sup>&</sup>lt;sup>97</sup> Non-communicating thermostats are not eligible for the demand response programs.

$$\begin{split} \Delta kWh &= \left[Size_{cool} \times \left(\frac{12}{IEER}\right) \times FLH_{cool} \times ESF_{cool}\right] \\ &+ \left[Size_{heat} \times FLH_{heat} \times \left(\frac{12}{3.412 \times COP}\right) \times ESF_{heat}\right] \end{split}$$

Gross coincident demand reduction is considered to be zero since space conditioning equipment typically operates at maximum capacity during peak periods.

 $\Delta kW = 0$ 

### **Input Variables**

Component	Туре	Value	Units	Source(s)
Size <sub>cool</sub>	Variable	See customer application	tons of cooling capacity	Customer application
Size <sub>heat</sub>	Variable	See customer application	kBtu/h	Customer application
FLH <sub>heat</sub>	Fixed	Table 12-4 in Sub- appendix II	hours (annual)	Mid-Atlantic TRM 2018, p. 418
FLH <sub>cool</sub>	Fixed	Table 12-5 in Sub- appendix II, Table X, or Table 12-3 in Sub- appendix II, depending upon equipment type	hours (annual)	Mid-Atlantic TRM 2018, p. 417
	Variable	See customer application		Customer application
SEER/IEER		Default: See Table 12-10 and Table 12-11 in Sub-appendix VII	kBtu/kW-hour	ASHRAE 2010, Table 6.8.1A
		See customer application	kBtu/kW-hour	Customer application
HSPF/COP	Variable	See Table 12-10 and Table 12-11 in Sub- appendix VII	(except COP is -)	ASHRAE 2010, Table 6.8.1A
ESF <sub>cool</sub>	Fixed	0.09	-	NY TRM 2018, pg. 140
ESF <sub>heat</sub>	Fixed	0.02	-	NY TRM 2018, pg. 140

Table 8-7:	Input	<b>Parameters</b>	for	Programmable	Thermostat	Measure
------------	-------	-------------------	-----	--------------	------------	---------

### Source

The primary source for this deemed savings approach is the New York TRM 2018, p. 139 to 142.

## 8.2 Lighting End Use

## 8.2.1 Lighting, Fixtures, Lamps, and Delamping

This measure is also offered through the Non-Residential Lighting Systems and Controls program. The savings approach is described in Section 5.1.1.

## 8.2.2 Sensors and Controls

This measure is also offered through the Non-Residential Lighting Systems and Controls program. The savings approach is described in Section 5.1.2.

### 8.2.3 LED Exit Signs

### **Measure Description**

This measure realizes energy savings by installing an exit sign that is illuminated with light emitting diodes (LED). This measure should be limited to retrofit installations.

### **Savings Estimation Approach**

Gross annual electric energy savings are calculated according to the following equation:

$$\Delta kWh = \frac{(Qty_{base} \times watts_{base} - Qty_{ee} \times watts_{ee})}{1,000 W/kW} \times HOU \times WHF_e \times ISR$$

Gross coincident demand reduction is calculated according to the following equation:

$$\Delta kW = \frac{(Qty_{base} \times watts_{base} - Qty_{ee} \times watts_{ee})}{1,000 W/kW} \times WHF_d \times CF \times ISR$$

Where:

ΔkWh	= gross annual electric energy savings
ΔkW	= gross coincident demand reduction
$Qty_{base}$	= number of baseline exit signs
$watts_{base}$	= connected load of the baseline exit sign
watts <sub>ee</sub>	= connected load of the efficient exit sign
$Qty_{base}$	= number of baseline exit signs
Qty <sub>ee</sub>	= number of efficient exit signs
HOU	= average hours of use per year
WHF <sub>e</sub>	<ul> <li>waste heat factor for energy to account for cooling savings from efficient lighting</li> </ul>
WHFd	= waste heat factor for demand to account for cooling savings from efficient lighting
CF	= coincidence factor
ISR	= in-service rate, the percentage of rebated measures actually installed

### **Input Variables**

#### Table 8-8: Input Values for LED Exit Sign Calculations

Component	Туре	Value	Unit	Source(s)
<b>Qty</b> base	Variable	See customer application	-	Customer application
Qtyee	Variable	Default: Equal to Qty <sub>base</sub>	-	Customer application

() ()
হি
2

Component	Туре	Value	Unit	Source(s)
		See customer application		Customer application
watts <sub>base</sub>	Variable	Default: 16 W CFL	watts	Mid-Atlantic TRM 2018 p. 311, ENERGY STAR <sup>®98</sup>
watts <sub>ee</sub>	Variable	See customer application Default: 5 W LED	watts	Mid-Atlantic TRM 2018 p. 311, ENERGY STAR <sup>®</sup>
нои	Fixed	8,760	hours (annual)	Mid-Atlantic TRM 2018 p. 312
WHF <sub>e</sub>	WHF <sub>e</sub> Variable See Table 12-6 in Sub- appendix III		-	Mid-Atlantic TRM 2018 p. 312
WHFdVariableSee Table 12-6 in appendix III		See Table 12-6 in Sub- appendix III	-	Mid-Atlantic TRM 2018 p. 312
CF	Fixed	1.0	percent	Mid-Atlantic TRM 2018 p. 312 <sup>99</sup>
ISR Fixed 1.		1.0	percent	Mid-Atlantic TRM 2018 p. 312 <sup>100</sup>

Note that the coincidence factor (CF) is 1 for this measure since exit signs are on continuously, including during the entirety of the peak period.

### **Default Savings**

If the proper values are not supplied, a default savings may be applied using conservative input values. The default gross annual electric energy savings will be assigned according to the following calculation:

 $\Delta kWh = \frac{(Qty_{base} \times watts_{base} - Qty_{ee} \times watts_{ee})}{1,000 W/kW} \times HOU \times WHF_e \times ISR$  $\Delta kWh = \frac{(1 \times 16W - 1 \times 5W)}{1.000 W/kW} \times 8,760 \text{ hours} \times 1.0 \times 1.0$ 

 $= 96.4 \, kWh$ 

The default gross coincident demand reduction are calculated using the following calculation:

<sup>&</sup>lt;sup>98</sup> LED exit sign default values come from an ENERGY STAR<sup>®</sup> report: Save Energy, Money and Prevent Pollution with Light-Emitting Diode (LED) Exit

Signs: <a href="http://www.energystar.gov/ia/business/small\_business/led\_exitsigns\_techsheet.pdf">http://www.energystar.gov/ia/business/small\_business/led\_exitsigns\_techsheet.pdf</a> (accessed 7/13/2018). <sup>99</sup> Efficiency Vermont Technical Reference Manual 2009-55, December 2008.

<sup>&</sup>lt;sup>100</sup> EmPOWER Maryland DRAFT Final Impact Evaluation Report Evaluation Year 4 (June 1, 2012 – May 31, 2013) Commercial & Industrial Prescriptive & Small Business Programs, Navigant, March 31, 2014.

$$\Delta kW = \frac{(Qty_{base} \times watts_{base} - Qty_{ee} \times watts_{ee})}{1,000 W/kW} \times WHF_d \times CF \times ISR$$

$$=\frac{(1\times 16W - 1\times 5W)}{1,000 W/kW} \times 1.0 \times 1.0 \times 1.0$$

 $= 0.011 \, kW$ 

### Source(s)

The primary source for this deemed savings approach is the Mid-Atlantic TRM 2018, p. 311-314.

### 8.3 Other End Use

### 8.3.1 Air Compressor Leak Repair

#### **Measure Description**

This measure involves improving the performance of an existing air compressor by repairing air leaks.

### **Savings Estimation**

Gross annual electric energy savings are calculated according to the following equation:

$$\Delta kWh = hp \times LF \times \frac{cfm}{hp} \times (Leak_{base} - Leak_{ee}) \times \frac{kW}{cfm} \times HOU$$

Gross coincident demand reduction is calculated according to the following equation:

$$\Delta kW = \frac{\Delta kWh \times CF}{HOU}$$

Where:

∆kWh	= gross annual electric energy savings
ΔkW	= gross coincident demand reduction
hp	= rated horsepower
LF	= load factor of air compressor
cfm/hp	= compressed airflow rate per air compressor motor horsepower
Leak <sub>base</sub>	= baseline percentage of compressed air produced that is leaked
Leak <sub>ee</sub>	= energy-efficient percentage of compressed air produced that is leaked
kW/cfm	= energy consumed for each cubic foot of compressed air per minute produced
HOU	= annual hours of operation
CF	= coincidence factor of air compressor

### **Input Variables**

#### Table 8-9. Input Variables for Air Compressor Leak Repair Measure

Component	Туре	Value	Units	Source(s)
hp	Variable	See customer application	hp	Customer application
LF	Variable	See customer application	percent	Customer application
cfm/hp	Variable	See customer application	cfm/hp	Customer application
Leak <sub>base</sub>	Variable	See customer application	percent	Customer application
Leakee	Variable	See customer application	percent	Customer application

Component	Туре	Value	Units	Source(s)
kW/cfm	Fixed	0.17	kW/cfm	Michigan Energy Measure Database <sup>101</sup>
HOU	Fixed	6,240	hours (annual)	Michigan Energy Measure Database <sup>102</sup>
CF	Fixed	0.865	percent	Michigan Energy Measure Database <sup>103</sup>

### Source

The primary source for this deemed savings approach is the Michigan Energy Measure Database 2018, at <u>http://www.michigan.gov/mpsc</u>, Document "FES-I20 Compressed Air Leak Survey and Repair Michigan 11282017.doc," July 2017.

 <sup>&</sup>lt;sup>101</sup> Michigan Energy Measure Database 2018, at <u>http://www.michigan.gov/mpsc</u>, Document "FES-I20 Compressed Air Leak Survey and Repair Michigan 11282017.doc," July 2017, p. 1.
 <sup>102</sup> Ibid.

<sup>&</sup>lt;sup>103</sup> Ibid.

### **9 NON-RESIDENTIAL PRESCRIPTIVE PROGRAM**

Dominion's Non-Residential Prescriptive Program provides qualifying business owners incentives to use pursue one or more of the qualified energy efficiency measures through a local, participating contractor in Dominion's contractor network. To qualify for this program, the customer must be responsible for the electric bill and must be the owner of the facility or reasonably able to secure permission to complete the measures. All program measures are summarized in Table 9-1.

End-Use	Measure	Manual Section
Cooking	Commercial Convection Oven	Section 9.1.1
	Commercial Electric Combination Oven	Section 9.1.2
	Commercial Electric Fryer	Section 9.1.3
	Commercial Griddle	Section 9.1.4
	Commercial Hot Food Holding Cabinet	Section 9.1.5
	Commercial Steam Cooker	Section 9.1.6
HVAC	Duct Testing & Sealing	Section 8.1.1
	Unitary/Split AC/HP Tune-up	Section 8.1.2
	Variable Speed Drives on Kitchen Fan	Section 9.2.3
Plug Load	Smart Strip	Section 9.3.1
Refrigeration	Door Closer	Section 9.4.1
	Door Gasket	Section 9.4.2
	Commercial Freezers and Refrigerators - Solid Door	Section 9.4.3
	Commercial Ice Maker	Section 9.4.4
	Evaporator Fan ECM Retrofit	Section 9.4.5
	Evaporator Fan Control	Section 9.4.6
	Floating Head Pressure Control	Section 9.4.7
	Low/No-sweat Door Film	Section 9.4.8
	Refrigeration Night Cover	Section 9.4.9
	Refrigerator Coil Cleaning	Section 9.4.10
	Suction Pipe Insulation (Cooler & Freezer)	Section 9.4.11
	Strip Curtain (Cooler & Freezer)	Section 9.4.12
	Vending Machine Miser	Section 9.4.13

#### Table 9-1: Non-residential Prescriptive Program Measure List

## 9.1 Cooking End Use

## 9.1.1 Commercial Convection Oven

### **Measure Description**

This measure involves the installation of an ENERGY STAR<sup>®</sup> qualified commercial convection oven. Commercial convection ovens that are ENERGY STAR<sup>®</sup> certified have higher heavy load cooking efficiencies and lower idle energy rates making them more efficient than standard models.

### **Baseline Description**

The baseline equipment is assumed to be a standard efficiency convection oven with a heavyload efficiency of 65% for full-size electric ovens (i.e., a convection oven this can accommodate full-size sheet pans measuring 18 x 26 x 1-inch) and 68% for half-size electric ovens (i.e., a convection oven that can accommodate half-size sheet pans measuring 18 x 13 x 1-inch).

### **Savings Estimation**

Gross annual electric energy savings are calculated using the following equations:

$$\Delta kWh = kWh_{base} - kWh_{ee}$$

where,

$$kWh_{base} = \left[ lb_{daily} \times \frac{E_{conv.}}{\eta_{base}} + kW_{base,idle} \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{base}} \right) \right] \times Days$$

$$kWh_{ee} = \left[ lb_{daily} \times \frac{E_{conv.}}{\eta_{ee}} + kW_{ee,idle} \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{ee}} \right) \right] \times Days$$

Gross coincident demand reduction is calculated using the following equation:

$$\Delta kW = \frac{\Delta kWh}{Hours_{daily} \times Days}$$

Where:

ΔkWh	=	gross annual electric energy savings
ΔkW	=	gross coincident demand reduction
Hours <sub>daily</sub>	=	average daily operating hours
E <sub>conv</sub> .	=	ASTM Energy to Food; the amount of energy absorbed by food during
		convection cooking
Ib <sub>daily</sub>	=	pounds of food cooked per day
Days	=	annual days of operation
$\eta_{base}$	=	baseline equipment cooking energy efficiency
η <sub>ee</sub>	=	efficient equipment cooking energy efficiency

	-
	277
	_
	·
	_
	_
	Pho.
	100
	10.00
	- C

 $kW_{base,idle} = baseline equipment idle energy rate$ 

 $kW_{ee,idle} = efficient \ equipment \ idle \ energy \ rate$ 

- $PC_{base}$  = baseline equipment production capacity
- $PC_{ee}$  = efficient equipment production capacity

### **Input Variables**

### Table 9-2: Input Parameters for Convection Oven

Component	Туре	Value	Units	Source(s)	
Hours <sub>daily</sub>	Variable	See customer application	hours		
		Default: 12	(ually)		
Dave	Variable	See customer application	days		
Days	Variable	Default: 365	(annual)	Mid-Atlantic TRM	
	) (autobla	See customer application	lb	2018, p. 507	
ID <sub>daily</sub>	variable	Default: 100	(daily)		
E <sub>conv</sub> .	Fixed	0.0732	kWh/lb		
PC <sub>base</sub>	Fixed	Half Size: 45 Full Size: 90	lb/hour		
η <sub>base</sub>	Fixed	Half Size: 0.68 Full Size: 0.65	percent		
kW <sub>base</sub> ,idle	Fixed	Half Size: 1.03 Full Size: 2.00	kW	Mid-Atlantic TRM	
kW <sub>ee,idle</sub>	Fixed	Half Size: 1.00 Full Size: 1.60	kW	2018, p. 508	
PC <sub>ee</sub>	Fixed	Half Size: 50 Full Size: 90	lb/hour		
η <sub>ee</sub>	Fixed	Half Size: 0.71 Full Size: 0.71	percent		

### Source

The primary sources for this deemed savings approach is the Mid-Atlantic TRM 2018, p. 506-509.

## 9.1.2 Commercial Electric Combination Oven

### **Measure Description**

This measure involves the installation of an ENERGY STAR<sup>®</sup> qualified combination oven. A combination oven is a convection oven that includes the added capability to inject steam into the oven cavity and typically offers at least three distinct cooking modes. This measure applies to time of sale opportunities.

### **Baseline Description**

The baseline equipment is assumed to be a typical standard efficiency electric combination oven.

### Savings Estimation

Gross annual electric energy savings are calculated as follows:

$$\Delta kWh = kWh_{base} - kWh_{ee}$$

The baseline annual electric energy consumption is calculated using the following equations:

$$kWh_{base} = kWh_{base,conv.} + kWh_{base,steam}$$

where,

$$\begin{split} kWh_{base,conv.} &= \left[ lb_{daily} \times \frac{E_{conv.}}{\eta_{base,conv.}} + kW_{base,conv.,idle} \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{base,conv.}} \right) \right] \\ &\times (1 - PCT_{steam}) \times Days \\ kWh_{base,steam} &= \left[ lb_{daily} \times \frac{E_{steam}}{\eta_{base,steam}} + kW_{base,steam,idle} \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{base,steam}} \right) \right] \times PCT_{steam} \\ &\times Days \end{split}$$

Similarly, the efficient annual electric energy consumption is calculated using the following equations:

$$kWh_{ee} = kWh_{ee,conv.} + kWh_{ee,steam}$$

where,

$$\begin{split} kWh_{ee,conv.} = \left[ lb_{daily} \times \frac{E_{conv.}}{\eta_{ee,conv.}} + kW_{ee,conv.,idle} \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{ee,conv.}} \right) \right] \\ \times (1 - PCT_{steam}) \times Days \end{split}$$

$$\begin{split} kWh_{ee,steam} = \left[ lb_{daily} \times \frac{E_{steam}}{\eta_{ee,steam}} + kW_{ee,steam,idle} \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{ee,steam}} \right) \right] \\ \times PCT_{steam} \times Days \end{split}$$

Gross coincident demand reduction is calculated using the following equation:

$$\Delta kW = \frac{\Delta kWh}{Hours_{daily} \times Days}$$

Where:

∆kWh	= gross annual electric energy savings
ΔkW	= gross coincident demand reduction
$kWh_{base}$	= annual energy usage of the baseline equipment
kWh <sub>ee</sub>	= annual energy usage of the efficient equipment
kWh <sub>base,co</sub>	<sub>nv.</sub> = baseline annual cooking energy consumption in convection mode
kWh <sub>base,st</sub>	eam = baseline annual steam energy consumption in steam mode
kW <sub>base,conv</sub>	<sub><i>i</i>,<sub>idle</sub> = baseline idle energy rate in convection mode</sub>
kW <sub>base,stea</sub>	m,idle = baseline idle energy rate in steam mode
kWh <sub>ee,conv</sub>	= efficient annual cooking energy consumption in convection mode
kWh <sub>ee,stea</sub>	m = efficient annual steam energy consumption in steam mode
kWee,conv.,	idle = efficient idle energy rate in convection mode
kW <sub>ee,steam</sub>	<sub>,idle</sub> = efficient idle energy rate in steam mode
Hoursdaily	= average daily operating hours
Days	= annual days of operation
<b>Ib</b> daily	= pounds of food cooked per day
Econv.	= ASTM Energy to Food, the amount of energy absorbed by the food during
	convection mode cooking, per pound of food
E <sub>steam</sub>	= ASTM Energy to Food, the amount of energy absorbed by the food during
	steam cooking mode, per pound of food
$\eta_{base,conv.}$	= baseline equipment cooking energy efficiency in convection mode
$\eta_{base,steam}$	= baseline equipment cooking energy efficiency in steam mode
η <sub>ee,conv</sub> .	= efficient equipment cooking energy efficiency in convection mode
$\eta_{ee,steam}$	= efficient equipment cooking energy efficiency in steam mode
$PCT_{steam}$	= percent of food cooked in steam cooking mode
$PC_{base,conv}$	. = baseline equipment production capacity in convection mode
PCee, conv.	<ul> <li>efficient equipment production capacity in convection mode</li> </ul>
PC <sub>base</sub> ,stear	$m_{m}$ = baseline equipment production capacity in steam mode
$PC_{ee,steam}$	= efficient equipment production capacity in steam mode

### **Input Variables**

#### **Table 9-3: Input Parameters for Commercial Electric Combination Ovens**

Component	Туре	Value	Units	Source(s)
Hours <sub>daily</sub>	Variable	See customer application	hours	Mid-Atlantic TRM 2018, p.
	variable	Default: 12	(daily)	511

(	2	)	
	5		
Č	R	l	
	5	)	
		ĵ	
		,	

Component	Туре	Value	Units	Source(s)
Days	Variable	See customer application Default: 365	days (annually)	Mid-Atlantic TRM 2018, p. 511
lb <sub>daily</sub>	Variable	See customer application Default: 200	pounds (daily)	Mid-Atlantic TRM 2018, p. 511
PCT <sub>steam</sub>	Variable	See customer application Default: 0.5	percent	Mid-Atlantic TRM 2018, p. 512
E <sub>conv</sub> .	Fixed	0.0732	kWh/lb	Mid-Atlantic TRM 2018, p. 511
E <sub>steam</sub>	Fixed	0.0308	kWh/lb	Mid-Atlantic TRM 2018, p. 511
PC <sub>base</sub> ,conv.	Fixed	<15 pans: 79 ≥15 pans: 166	lb/hr	
$PC_{base,steam}$	Fixed	<15 pans: 126 ≥15 pans: 295	lb/hr	
$\eta_{\text{base,conv.}}$	Fixed	0.72	percent	
$\eta_{\text{base,steam}}$	Fixed	0.49	percent	
$kW_{base,conv.,idle}$	Fixed	<15 pans: 1.32 ≥15 pans: 2.28	kW	
$kW_{base,steam}$	Fixed	<15 pans: 5.26 ≥15 pans: 8.71	kW	Mid-Atlantic TRM 2018, p.
$kW_{ee,conv.,cooking}$	Variable	= 0.080 x Number of pans + 0.4989	kW	512
kW <sub>ee,steam</sub>	Variable	= 0.133 x Number of pans + 0.6400	kW	
PC <sub>ee,conv</sub> .	Fixed	<15 pans: 119 ≥15 pans: 201	lb/hr	
PC <sub>ee,steam</sub>	Fixed	<15 pans: 177 ≥15 pans: 349	lb/hr	
$\eta_{ee,conv.}$	Fixed	0.76	percent	
$\eta_{ee,steam}$	Fixed	0.55	percent	

### Source

The primary sources for this deemed savings approach is the Mid-Atlantic TRM 2018, p. 510-514.

## Aay 01 2019

### 9.1.3 Commercial Electric Fryer

### **Measure Description**

This measure involves the installation of an ENERGY STAR<sup>®</sup> qualified electric commercial fryer. Commercial fryers with the ENERGY STAR<sup>®</sup> designation offer shorter cook times and higher production rates through advanced burned and heat exchanger designs. Further, frypot insulation reduces standby losses resulting in a lower idle energy rate. This measure applies to both standard-size and large-vat fryers.

### **Baseline Condition**

The baseline equipment is assumed to be a standard efficiency electric fryer with a heavy load efficiency of 75% for standard sized equipment and 70% for large vat equipment.<sup>104</sup>

### **Savings Estimation**

Gross annual energy savings are calculated using the following equation:

$$\Delta kWh = kWh_{base} - kWh_{ee}$$

The baseline gross annual electric energy usage is calculated using the following equation:

$$kWh_{base} = \left[ lb_{daily} \times \frac{E_{fry}}{\eta_{base}} + kW_{base,idle} \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{base}} \right) \right] \times Days$$

Similarly, the efficient gross annual electric energy usage is calculated using the following equation:

$$kWh_{ee} = \left[ lb_{daily} \times \frac{E_{fry}}{\eta_{ee}} + kW_{ee,idle} \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{ee}} \right) \right] \times Days$$

Gross coincident demand reduction is calculated using the following equation:

$$\Delta kW = \frac{\Delta kWh}{\left(Hours_{daily} \times Days\right)}$$

Where:

ΔkWh= gross annual electric energy savingsΔkW= gross coincident demand reductionkWh<sub>base</sub>= annual energy usage of the baseline equipmentkWh<sub>ee</sub>= annual energy usage of the efficient equipmentHours<sub>daily</sub>= average daily operating hours

<sup>&</sup>lt;sup>104</sup> Standard fryers measure 12-18 in. wide and have a shortening capacity of 25-65 lb; large fryers measure 18-24-in. wide and have a shortening capacity greater than 50 lb.

of

<b>5</b>
হ
2

E <sub>fry</sub>	=	ASTM Energy to Food ratio, the amount of energy absorbed by each pound
		food during frying
<b>Ib</b> daily	=	pounds of food cooked per day
Days	=	annual days of operation
$\eta_{\text{base}}$	=	baseline equipment cooking energy efficiency
$\eta_{\text{eff}}$	=	efficient equipment cooking energy efficiency
$kW_{\text{base,idle}}$	=	baseline equipment idle energy rate
$kW_{ee,idle}$	=	efficient equipment idle energy rate
$PC_{base}$	=	baseline equipment production capacity
PCee	=	efficient equipment production capacity

### **Input Variables**

Component	Туре	Value	Units	Source(s)	
		See customer application			
Hours <sub>daily</sub>	Variable	Default: Standard fryer: 16 Large-vat fryer: 12	hours (daily)	Mid-Atlantic TRM 2018, p. 490	
E <sub>fry</sub>	Fixed	0.167	kWh/lb	Mid-Atlantic TRM 2018, p. 490	
lb	Variable	See customer application	lb	Mid-Atlantic TRM 2018,	
IDdaily	variable	Default: 150	(daily)	p. 490	
Davia	Variable	See customer application	days	Mid-Atlantic TRM 2018,	
Days		Default: 365	(annual)	p. 490	
$\eta_{\text{base}}$	Fixed	Standard fryer: 75% Large-vat fryer: 70%	percent	Mid-Atlantic TRM 2018, p. 490	
$kW_{\text{base,idle}}$	Fixed	Standard fryer: 1.05 Large-vat fryer: 1.35	kW	Mid-Atlantic TRM 2018, p. 490	
PC <sub>base</sub>	Fixed	Standard fryer: 65 Large-vat fryer: 100	lb/hr	Mid-Atlantic TRM 2018, p. 490	
$\eta_{ee}$	Fixed	Standard fryer: 83% Large-vat fryer: 80%	percent	Mid-Atlantic TRM 2018, p. 490	
kW <sub>ee,idle</sub>	Fixed	Standard fryer: 0.80 Large-vat fryer: 1.10	kW	Mid-Atlantic TRM 2018, p. 490	
PC <sub>ee</sub>	Fixed	Standard fryer: 70 Large-vat fryer: 110	lb/hr	Mid-Atlantic TRM 2018, p. 490	

### Table 9-4: Input Parameters for Electric Commercial Fryer Measure

### Source

The primary sources for this deemed savings approach is the Mid Atlantic TRM 2018, p. 489-492.

### 9.1.4 Commercial Griddle

### **Measure Description**

This measure involves the installation of an ENERGY STAR<sup>®</sup> qualified commercial griddle. ENERGY STAR<sup>®</sup> qualified commercial griddles have higher cooking energy efficiency and lower idle energy rates than standard equipment. The result is more energy being absorbed by the food compared with the total energy use, and less wasted energy when the griddle is in standby mode. This measure applies to only 10-sq.ft. commercial griddles due to Dominion Energy program requirements.

### **Baseline Condition**

The baseline equipment is assumed to be a standard efficiency electric griddle with a cooking energy efficiency of 65%.

### **Savings Estimation**

Gross annual electric energy savings are calculated using the following equations:

$$\Delta kWh = kWh_{base} - kWh_{ee}$$

where,

$$kWh_{base} = \left[ lb_{daily} \times \frac{E_{griddle}}{\eta_{base}} + kW_{base,idle} \times SqFt \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{base} \times SqFt} \right) \right]$$
$$\times Days$$

$$kWh_{ee} = \left[ lb_{daily} \times \frac{E_{griddle}}{\eta_{ee}} + kW_{ee,idle} \times SqFt \times \left( Hours_{daily} - \frac{lb_{daily}}{PC_{ee} \times SqFt} \right) \right] \times Days$$

Gross coincident demand reduction is calculated using the following equation:

$$\Delta kW = \frac{\Delta kWh}{Hours_{daily} * Days}$$

Where:

∆kWh = gross annual electric energy savings ΔkW = gross coincident demand reduction  $kWh_{base}$  = annual energy usage of the baseline equipment kWhee = annual energy usage of the efficient equipment SqFt = surface area of griddle Hours<sub>daily</sub> = average daily operating hours = ASTM Energy to Food ratio, the amount of energy absorbed by each pound of Egriddle food during griddling **Ib**daily = pounds of food cooked per day = annual days of operation Days

OFFICIAL COPY

May 01 2019

$\eta_{\text{base}}$	=	baseline equipment cooking energy efficiency
$\eta_{ee}$	=	efficient equipment cooking energy efficiency
$kW_{\text{base,idle}}$	=	baseline equipment idle energy rate
$kW_{ee,idle}$	=	efficient equipment equipment idle energy rate
$PC_{base}$	=	baseline equipment production capacity
PCee	=	efficient equipment production capacity

### **Input Variables**

Table 9-5: Input	<b>Parameters</b>	for Commercial	Griddle	Measure
------------------	-------------------	----------------	---------	---------

Component	Туре	Value	Units	Source(s)	
16	Maulahla	See customer application	lb	Customer application	
<b>ID</b> daily	variable	Default: 100	(daily)	Mid-Atlantic TRM 2018, p. 503	
House	Variable	See customer application	hours	Customer application	
HOULSdaily	variable	Default: 12	(daily)	Mid-Atlantic TRM 2018, p. 503	
Davia	Variable	See customer application	days	Customer application	
Days	variable	Default: 365	(annual)	Mid-Atlantic TRM 2018, p. 503	
Egriddle	Fixed	0.139	kWh/lb	Mid-Atlantic TRM 2018, p. 503	
PC <sub>base</sub>	Fixed	5.83	lb/hr/ft²	Mid-Atlantic TRM 2018, p. 504	
$\eta_{base}$	Fixed	65%	percent	Mid-Atlantic TRM 2018, p. 504	
kW <sub>base</sub>	Fixed	0.40	kW/ft <sup>2</sup>	Mid-Atlantic TRM 2018, p. 504	
kW <sub>ee</sub>	Fixed	0.32	kW/ft <sup>2</sup>	Mid-Atlantic TRM 2018, p. 504	
PCee	Fixed	6.67	lb/hour/ft <sup>2</sup>	Mid-Atlantic TRM 2018, p. 504	
$\eta_{ee}$	Fixed	70%	percent	Mid-Atlantic TRM 2018, p. 504	
SqFt	Variable	See customer application	ft <sup>2</sup>	Mid-Atlantic TRM 2018, p. 503	

### Source

The primary source for this deemed savings approach is the Mid-Atlantic TRM 2018, p. 502-505.

## 9.1.5 Commercial Hot Food Holding Cabinet

### **Measure Description**

This measure involves installing an ENERGY STAR<sup>®</sup> qualified commercial hot food holding cabinet. The installed equipment will incorporate better insulation, reducing heat loss, and may also offer additional energy saving devices such as magnetic door gaskets, auto-door closures, or dutch doors. The insulation of the cabinet also offers better temperature uniformity within the cabinet from top to bottom. This means that qualified hot food holding cabinets are more efficient at maintaining food temperature while using less energy.

### **Baseline Description**

The baseline equipment is assumed to be a standard efficiency hot food holding cabinet.

### **Savings Estimation**

Gross annual electric energy savings are calculated according to the following equation:

$$\Delta kWh = \frac{\left(watts_{base,idle} - watts_{ee,idle}\right)}{1,000 W/kW} \times Hours_{daily} \times Days$$

Gross coincident demand reduction is calculated according to the following equation:

$$\Delta kW = \frac{\left(watts_{base,idle} - watts_{ee,idle}\right)}{1,000 W/kW}$$

Where:

### **Input Variables**

#### Table 9-6: Input Parameters for Hot Food Holding Cabinet

Component	Туре	Value	Units	Source(s)
watts <sub>base,idle</sub>	Variable	40 x Volume	watts	Mid-Atlantic TRM 2018, p. 499
watts <sub>ee,idle</sub>	Variable	0 < Volume < 13: 21.5 x Volume + 0.0 13 ≤ Volume < 28: 2.0 x Volume + 254.0 Volume ≥ 28: 3.8 x Volume + 203.5	watts	Mid-Atlantic TRM 2018, p. 499
Days	Variable	See customer application	days (annual)	Mid-Atlantic TRM 2018, p. 499
		Default: 365		

o
5
<u>N</u>
õ
2

Component	Туре	Value	Units	Source(s)
		See customer application	hours	Mid-Atlantic TRM
Hoursdaily	Variable	Default: 15	(daily)	2018, p. 499

Note: Volume = the internal volume of the holding cabinet (ft<sup>3</sup>) = actual volume of installed unit

#### Source

The primary sources for this deemed savings approach is the Mid-Atlantic TRM 2018, p. 499-501.

### 9.1.6 Commercial Steam Cooker

### **Measure Description**

This measure involves an ENERGY STAR<sup>®</sup> qualified commercial steam cookers.Energy efficient steam cookers that have earned the ENERGY STAR<sup>®</sup> label offer shorter cook times, higher production rates, and reduced heat loss due to better insulation and a more efficient steam-delivery system.

### **Baseline Description**

The baseline condition assumes a standard efficiency, electric boiler-style steam cooker.

### Savings Estimation

Gross annual electric energy savings are calculated using the following equation:

$$\Delta kWh = kWh_{base} - kWh_{ee}$$

Baseline annual electric energy consumption is calculated using the following equation:

$$kWh_{base} = kWh_{base,steam} + kWh_{base,idle}$$

where,

$$kWh_{base,steam} = lb_{daily} \times \frac{E_{steam}}{\eta_{base}} \times Days \quad {}_{base,idle}$$

$$= \left[ (1 - PCT_{steam}) \times kW_{base,idle} + PCT_{steam} \times PC_{base} \times Qty_{pans} \times \frac{E_{steam}}{\eta_{base}} \right]$$

$$\times \left( Hours_{daily} - \frac{lb_{daily}}{Qty_{pans} \times PC_{base}} \right) \times Days$$

Similarly, efficient annual electric energy consumption is calculated using the following equation:

$$kWh_{ee} = kWh_{ee,steam} + kWh_{ee,idle}$$

where,

$$kWh_{ee,steam} = lb_{daily} \times \frac{E_{steam}}{\eta_{ee}} \times Days$$

$$kWh_{ee,idle} = \left[ (1 - PCT_{steam}) \times kW_{ee,idle} + PCT_{steam} \times PC_{ee} \times Qty_{pans} \times \frac{E_{steam}}{\eta_{ee}} \right] \times \left( Hours_{daily} - \frac{lb_{daily}}{Qty_{pans} \times PC_{ee}} \right) \times Days$$

Where:

∆kWh	= gross annual electric energy savings
ΔkW	= gross coincident demand reduction
kWh <sub>base</sub>	= the annual energy usage of the baseline equipment
kWh <sub>ee</sub>	= the annual energy usage of the efficient equipment
kWh <sub>base,ste</sub>	eam = baseline daily cooking energy consumption
kWh <sub>base,idl</sub>	e = baseline daily idle energy consumption
Hours <sub>daily</sub>	= average daily operating hours
E <sub>steam</sub>	= ASTM Energy to Food (kWh/lb); the amount of energy absorbed by each
	pound of food during steaming
<b>Ib</b> daily	= pounds of food cooked per day
Days	= annual days of operation
$PCT_{steam}$	= percent of time in constant steam mode
$Qty_{pans}$	= number of pans per unit
$\eta_{base}$	<ul> <li>baseline equipment cooking energy efficiency</li> </ul>
$\eta_{ee}$	= efficienct equipment cooking energy efficiency
$kW_{base,idle}$	= baseline equipment idle energy rate
$kW_{ee,idle}$	= efficient equipment idle energy rate
$PC_{base}$	= baseline equipment production capacity
PCee	= efficient equipment production capacity

## **Input Variables**

Table 9-7:	Input	Parameters	for	Commercial	Steam	Cooker	Measure	
------------	-------	------------	-----	------------	-------	--------	---------	--

Component	Туре	Value	Units	Source(s)
Hours <sub>daily</sub>	Variable	See customer application Default: 12	hours (daily)	Mid-Atlantic TRM 2018, p. 495
Days	Variable	See customer application Default: 365	days (annual)	Mid-Atlantic TRM 2018, p. 495
<b>Ib</b> daily	Variable	See customer application Default: 100	lb (daily)	Mid-Atlantic TRM 2018, p. 495
<b>Qty</b> <sub>pans</sub>	Variable	See customer application.	-	Mid-Atlantic TRM 2018, p. 495
E <sub>steam</sub>	Fixed	0.0308	kWh/lb	Mid-Atlantic TRM 2018, p. 495
PC <sub>base</sub>	Fixed	23.3	lb/hr (per pan)	Mid-Atlantic TRM 2018, p. 495
$\eta_{base}$	Fixed	Steam generator: 0.30 Boiler based: 0.26	-	Mid-Atlantic TRM 2018, p. 495
kW <sub>base</sub> ,idle	Fixed	Steam generator: 1.20 Boiler based: 1.00	kW	Mid-Atlantic TRM 2018, p. 496
kW <sub>ee,idle</sub>	Fixed	3 pans: 0.40 4 pans: 0.53 5 pans: 0.67 6+ pans: 0.80	kW	Mid-Atlantic TRM 2018,p. 496

	6	2	
	-		
	Ę	3	
	č	>	

Component	Туре	Value	Units	Source(s)
PC <sub>ee</sub>	Fixed	16.9	lb/hr (per pan)	Mid-Atlantic TRM 2018, p. 495
$\eta_{ee}$	Fixed	0.5	-	Mid-Atlantic TRM 2018, p. 496
PCT <sub>steam</sub>	Fixed	0.4	-	Mid-Atlantic TRM 2018, p. 495

### Source

The primary sources for this deemed savings approach is the 2018 Mid-Atlantic TRM p. 494-498.

## 9.2 Heating Ventilation and Air Conditioning (HVAC) End Use

### 9.2.1 Duct Testing and Sealing

This measure is also provided by the Non-Residential Small Business Improvement Program. The savings are determined using the methodology described in Section 8.1.1.

### 9.2.2 Unitary/Split Air Conditioning, Heat Pump, and Chiller Tune-up

This measure is also provided by the Non-Residential Small Business Improvement Program. The savings are determined using the methodology described in Section 8.1.2.

### 9.2.3 Variable Speed Drives on Kitchen Exhaust Fan

### **Measure Description**

This measure involves installing variable speed drives at commercial kitchen exhaust fans so that the fan motor speed matches the demand. The baseline condition is the manual on/off switch and magnetic relay or motor starter for commercial kitchen hoods. The baseline assumes that the fan operates at full speed while in operation.

This measure involves retrofitting a variable-speed drive (VSD) controller at an existing kitchen exhaust fan with a make-up-air fan. The measure includes optical and temperature sensors to detect the level of cooking activity and modulate the speed of the exhaust-air fan accordingly. The optical and temperature sensor(s) are typically located either in the collar of or the inlet to the exhaust-fan hood. The kitchen hood exhaust fans are modulated automatically to vary the exhaust airflow rate and make-up (ventilation) air by adjusting the exhaust and make-up air fan speeds.

The total measure energy savings includes the energy savings resulted from fan power reduction during part load operation as well as a decrease in heating and cooling requirement of make-up air. The measure also provides cooling and heating savings for the make-up air if the existing kitchen system(s) supplies conditioned make-up air through a dedicated make-up air unit. If the supplied make-up air is not conditioned, no heating and cooling savings are provided. Furthermore, the measure does not approve heating savings from gas-fired make-up-air units.

This measure is meant for the kitchen hood exhaust flow control only. The exhaust system from kitchen dishwashers is not included in this measure.

### **Savings Estimation**

Gross annual electric energy savings for the exhaust fan are calculated according to the following equation:

$$\Delta kWh_{EF} = hp_{EF} \times LF_{EF} \times \frac{0.746}{\eta_{EF}} \times HOU \times \Delta Power_{EF}$$

If the make-up air is conditioned, then the cooling and heating savings are calculated according to the following equations:

$$\Delta kWh_{cool} = SqFt_{Kitchen} \times \frac{cfm}{SqFt} \times OF_{EF} \times \Delta cfm_{EF} \times CDD \times \frac{24 \times 1.08}{3,412 \times COP_{MUA_{cool}}}$$

$$\Delta kWh_{heat} = SqFt_{Kitchen} \times \frac{cfm}{SqFt} \times OF_{EF} \times \Delta cfm_{EF} \times HDD \times \frac{24 \times 1.08}{3,412 \times COP_{MUA_{heat}}}$$

If make-up air is <u>not</u> conditioned, then the cooling and heating savings equal zero.

$$\Delta kWh_{cool} = \Delta kWh_{heat} = 0$$

The total annual electric energy savings for this measure are calculated as follows:

$$\Delta kWh = \Delta kWh_{EF} + \Delta kWh_{cool} + \Delta kWh_{heat}$$

Gross coincident demand reduction is calculated according to the following equation:

$$\Delta kW = \frac{\Delta kWh}{HOU}$$

Where:

$\Delta kWh_{EF}$	= gross annual electric energy savings for the exhaust fan
$\Delta kWh_{cool}$	= gross annual electric energy savings for cooling the make-up air
$\Delta kWh_{heat}$	= gross annual electric energy savings for heating the make-up air
∆kWh	= gross annual electric energy savings
∆kW	= gross coincident demand reduction
npef	= total motor horsepower of exhaust fan(s)
_F <sub>EF</sub>	= load factor of exhaust fan motor(s)
ηef	= efficiency of exhaust fan motor(s)
HOU	= annual run hours of use of exhaust fan(s)
$\Delta Power_{EF}$	= proportional exhaust fan power reduction due to VFD
SqFt <sub>Kitchem</sub>	$_{i}$ = floor area of kitchen
cfm SqFt	= exhaust airflow rate per square foot of kitchen floor area
$OF_{EF}$	= oversize ratio of exhaust fan system
$\Delta cfm_{EF}$	= proportional exhaust fan airflow reduction due to VFD
CDD	= cooling degree days
COP <sub>MUAcool</sub>	$_{i}$ = coefficient of performance of cooling component of make-up air system
HDD	= heating degree days
COP <sub>MUAhea</sub>	$t_t$ = coefficient of performance of heating component for make-up air system
0.746	= conversion factor for horsepower to kilowatt
3,412	= conversion factor for Btu/h to kilowatt-hour
24	= conversion factor for day to hour
1.08	= sensible heat factor for air, Btuh/cfm/°F

### **Input Variables**

#### Table 9-8: Input Parameters for VSD on Kitchen Fan(s)

Component	Туре	Value	Units	Source(s)
hp <sub>EF</sub>	Variable	See customer application	hp	Customer application
LF <sub>EF</sub>	Fixed	Default: 90%	-	New Jersey Clean Energy Program Protocols to Measure Resource Savings: Revisions to FY2016 Protocols, pg. 89
$\eta_{EF}$	Variable	See customer application	-	Customer application
		Default: See Table 6-6 based on $hp_{EF}$		See Table 6-6 in Section 6.1.4

() ()
হ
5
May

Component	Туре	Value	Units	Source(s)
HOU	Variable	See customer application	hours	Customer application
		Default: See Table 9-9 that follows	(annual)	New Jersey Clean Energy Program Protocols to Measure Resource Savings: Revisions to FY2016 Protocols, pg. 90.
Δ <b>Power</b> <sub>EF</sub>	Variable	See Table 9-9 that follows	-	New Jersey Clean Energy Program Protocols to Measure Resource Savings: Revisions to FY2016 Protocols, pg. 90
SqFt <sub>Kitchen</sub>	Variable	See customer application	ft²	Customer application
cfm SqFt	Fixed	0.7	cfm/ft <sup>2</sup>	ASHRAE 62.1-2010, Table 6.4 – for Kitchen - Commercial
OF <sub>EF</sub>	Fixed	1.4	-	New Jersey Clean Energy Program Protocols to Measure Resource Savings: Revisions to FY2016 Protocols, pg. 90
$\Delta cfm_{EF}$	Variable	See Table 9-9 that follows	-	New Jersey Clean Energy Program Protocols to Measure Resource Savings: Revisions to FY2016 Protocols, pg. 90.
CDD	Variable	See Sub-appendix I	Cooling Degree Days	
HDD	Variable	See Sub-appendix I	Heating Degree Days	
MUA <sub>cool</sub>	Flag	See customer application	True/False	Customer application
		See customer application		Customer application
COP <sub>MUAcool</sub>	Variable	Default: 3.0	-	New Jersey Clean Energy Program Protocols to Measure Resource Savings 2016, page 90.
MUA <sub>electric_heat</sub>	Flag	See customer application	True/False	Customer application
		See customer application		Customer application
COP <sub>MUAheat</sub>	Variable	Default: 3.0	-	New Jersey Clean Energy Program Protocols to Measure Resource Savings 2016, page 90.

0
ž
5
0

### Table 9-9: Annual Hours of Use, Power and Airflow Reductions due to VSD<sup>105</sup>

Facility Type	Annual Hours of Use (hours)	<b>Proportion of Power</b> <b>Reduction</b> $(\Delta Power_{EF})$	<b>Proportion of Airflow</b> <b>Reduction</b> $(\Delta cfm_{EF})$
Campus	5,250	0.568	0.295
Lodging	8,736	0.618	0.330
Restaurant	5,824	0.552	0.295
Supermarket	5,824	0.597	0.320
Other	5,250	0.584	0.310

#### Source

The primary sources for this deemed savings approach include the New Jersey Clean Energy Program Protocols to Measure Resource Savings 2016, pages 88-91.

<sup>&</sup>lt;sup>105</sup> New Jersey Clean Energy Program Protocols to Measure Resource Savings: Revisions to FY2016 Protocols, pg. 88-91: <u>http://www.njcleanenergy.com/files/file/NJCEP Protocols to Measure Resource SavingsFY17 FINAL.pdf</u>.

## Viay 01 2019

### 9.3 Plug Load End-Use

### 9.3.1 Smart Strip

### **Measure Description**

This measure realizes energy savings by installing a "smart-strip" plug outlet in place of a standard "power strip." A smart strip has the ability to minimize energy losses caused by phantom loads when the devices plugged into the smart strip are not in use.

The baseline condition is a standard "power strip". This strip is simply a "plug multiplier" that allows the user to plug in multiple devices using a single wall outlet. Additionally, the baseline unit has no ability to control power flow to the connected devices.

### **Savings Estimation Approach**

Gross annual electric energy savings are assigned per unit as follows:

 $\Delta kWh = 26.9 \ kWh^{106}$ 

Gross coincident demand reduction is assigned as follows:

 $\Delta kW = 0 \ kW$ 

Where:

 $\Delta kWh = gross annual electric energy savings$  $<math>\Delta kW = gross coincident demand reduction$ 

### Source(s)

The primary source for this deemed savings approach is the Mid-Atlantic TRM 2018, p. 487.

<sup>&</sup>lt;sup>106</sup> Energy & Resource Solutions (ERS) 2013. Emerging Technologies Research Report; Advanced Power Strips for Office Environments prepared for the Regional Evaluation, Measurement, and Verification Forum facilitated by the Northeast Energy Efficiency Partnerships." Assumes savings consistent with the 20W threshold setting for the field research site demonstrating higher energy savings (of two available sites). ERS noted that the 20W threshold may be unreliable due to possible inaccuracy of the threshold setting in currently available units. It is assumed that future technology improvements will reduce the significance of this issue. Further, savings from the site with higher average savings was adopted (26.9 kWh versus 4.7 kWh) acknowledging that investigations of APS savings in other jurisdictions have found significantly higher savings. For example, Northwest Power and Conservation Council, Regional Technical Forum. 2011. "Smart Power Strip Energy Savings Evaluation" found average savings of 145 kWh.

## 9.4 Refrigeration End-Use

### 9.4.1 Door Closer (Cooler and Freezer)

### **Measure Description**

This measure realizes energy savings by installing an auto-closer on main doors to walk-in coolers or freezers, or by installing an automatic, hydraulic-type door closer on glass-reach-in doors to coolers or freezers. This measure consists of installing a door closer where none existed before. Gross annual electric energy savings are gained when an auto-closer installation reduces the infiltration of warmer outside air into a cooler or freezer environment.

Savings assume that an auto-closer reduces warm air infiltration on average by 40% and the walk-in coolers and freezer doors have effective strip curtains.<sup>107</sup> To simulate the reduction, the main door open time is reduced by 40%. For walk-in coolers and freezers, savings are calculated with the assumption that strip curtains that are 100% effective are installed on the doorway.

### **Savings Estimation Approach**

Gross annual electric energy savings are assigned according to the refrigeration unit type and temperature setting:

Cooler Doors

 $\Delta kWh = \Delta kWh_{cooler}$ 

Freezer Doors

 $\Delta kWh = \Delta kWh_{freezer}$ 

Gross coincident demand reduction is assigned according to the refrigeration unit type and temperature setting:

Cooler Doors

 $\Delta kW = \Delta kW_{cooler}$ 

Freezer Doors

 $\Delta kW = \Delta kW_{freezer}$ 

Where:

 $\Delta kWh = gross annual electric energy savings$  $<math>\Delta kW = gross coincident demand reduction$ 

<sup>&</sup>lt;sup>107</sup> Tennessee Valley Authority TRM 2017, p. 126. Original sources: California Database for Energy Efficiency Resources, www.deeresources.com (DEER 2008), and San Diego Gas & Electric work paper WPSDGENRRN0110 Rev 0, August, 17, 2012, "Auto-Closers for Main Cooler of Freezer Doors"

 $\begin{array}{l} \Delta k W h_{cooler} = \mbox{ annual electric energy savings for main cooler doors} \\ \Delta k W_{cooler} = \mbox{ coincident demand reduction for main cooler doors} \\ \Delta k W h_{freezer} = \mbox{ annual electric energy savings for main freezer doors} \\ \Delta k W_{freezer} = \mbox{ coincident demand reduction for main freezer doors} \\ \end{array}$ 

### **Input Variables**

## Table 9-10: Door Closer Gross Annual Electric Energy Savings and Gross Coincident Demand Reduction (per Closer)<sup>108</sup>

Refrigenetics limit Two	Looption	Walk-In		Reach-In	
Kenigeration onit Type	Location	ΔkWh	ΔkW	ΔkWh	ΔkW
Cooler	Richmond, VA	44	0.0050	102	0.0116
(High Temperature, 31°F to 55°F)	Charlotte, NC	44	0.0050	101	0.0116
Freezer	Richmond, VA	173	0.0196	439	0.0501
30 °F)	Charlotte, NC	171	0.0195	435	0.0497

### **Default Savings**

In the event of incomplete data, make the following conservative assumptions:

- If the door type is missing, assume it is a walk-in door type.
- If the refrigeration system type is missing, assume it is a high-temperature cooler.

### Source(s)

The primary source for this deemed savings approach is the Tennessee Valley Authority TRM 2017, p. 125-127.

<sup>&</sup>lt;sup>108</sup> Methodology from Tennessee Valley Authority TRM 2017, p. 125-127 was used. Savings were revised using the TMY3 weather data for Richmond, VA and Charlotte, NC.